



MONTICELLO NUCLEAR GENERATING PLANT

Monticello, Minnesota

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE



UNIT 1

RECORDS FACILITY BRANCH

BASELINE INSPECTION - EXAMINATION SUMMARY
RECIRCULATION PIPING REPLACEMENT PROJECT
MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1

FEBRUARY 10, 1984 TO JANUARY 12, 1985

REFUELING OUTAGE NO. 10

INSPECTION PERIOD 1

INTERVAL 2

Docket # 50-263
Control # 8510220361
Date 10-18-85 of Document
REGULATORY DOCKET FILE

REGULATORY DOCKET FILE COPY

N O R T H E R N S T A T E S P O W E R C O M P A N Y

COMMERCIAL SERVICE DATE:
JUNE 30, 1971

MINNEAPOLIS, MINNESOTA

REPORT DATE:
OCTOBER 10, 1985

8510220363 851018
PDR ADDCK 05000263
Q PDR

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATION PLANT - UNIT 1

BASELINE INSPECTION - EXAMINATION SUMMARY

MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1

FEBRUARY 10, 1984 TO JANUARY 12, 1985

RECIRCULATION PIPING REPLACEMENT PROJECT

REFUELING OUTAGE NO. 10

INSPECTION PERIOD 1

INTERVAL 2

Report Date:
October 10, 1985

Prepared by: J. Schanen

Reviewed by: L. C. Dahlman
L. C. Dahlman,
Materials & Special
Processes Specialist

Commerical Service Date:
June 30, 1971

Approved by: G. T. Krause
G. T. Krause
Superintendent
Materials & Special Processes

REGULATORY DOCKET FILE COPY

BASELINE INSPECTION - EXAMINATION SUMMARY
MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1
- INDEX -

- 1.0 Introduction
- 2.0 Inspection Summary
- 3.0 Discussion of Examination Plan
 - 3.1 Inspection Boundary
 - 3.2 Examination Procedures
 - 3.3 Examination Methods
 - 3.4 Equipment and Materials
 - 3.5 Personnel
 - 3.6 Evaluation
 - 3.7 Examination Reports and Documentation
 - 3.8 Summary of Results

Appendix A - ASME Class I Examination

Inservice Inspection - Examination Summary Tables:

- Table 5.1 - Dissimilar Metal Welds
- Table 6.1 - Pressure Retaining Bolting >2"
- Table 7.1 - Pressure Retaining Bolting <2"
- Table 9.1 - Piping Pressure Boundary
- Table 10.1 - Support Members
- Table 11.1 - Component Supports

Appendix B - ASME Class II Examinations
No Examinations Performed

Appendix C

- Table I - Personnel Listing
- Table II - Ultrasonic Calibration Blocks
- Table III - Procedure Listing
- Table IV - Equipment and Materials

Appendix D

Form NIS-1, Owner's Data Report for Inservice Inspections

BASELINE INSPECTION-EXAMINATION SUMMARY
MONTICELLO NUCLEAR GENERATING PLANT - UNIT I
FEBRUARY 10, 1984 TO JANUARY 12, 1985

1.0 INTRODUCTION

This report is a summary of the Monticello Nuclear Generating Plants' baseline examinations performed in conjunction with the Recirculation Piping Replacement Project. The piping replacement and subsequent baseline examinations were performed during the 10th refueling outage from February 10, 1984 to January 12, 1985. The Monticello Nuclear Generating Plant began commercial operation on June 30, 1971.

The examinations were performed on pressure-retaining components and their supports of the reactor coolant and associated auxiliary systems classified as ASME Class I.

2.0 INSPECTION SUMMARY

Baseline examinations revealed surface irregularities as identified by Magnetic Particle and/or Dye Penetrant examination methods. Visual examinations revealed discrepancies on component supports. All anomalies were corrected before startup of the unit. See section 3.8 of this report for the individual listing of anomalies and corrective actions taken.

3.0 DISCUSSION OF EXAMINATION PLAN

3.1 Inspection Boundary

The examination plan focused on the replaced or modified portions of the pressure retaining components and their supports of the Recirculation, Residual Heat Removal, Reactor Water Clean-Up, Jet Pump Instrumentation, and Standby Liquid Control Systems classified as ASME Class I.

The examination plan was based on the examination requirements of the ASME Boiler and Pressure Vessel Code Section XI, 1977 Edition through and including the Summer 1978 addenda, and complied with Monticello's Technical Specification, Section TS4.15. The examination plan is in accordance with the program submitted to the United States Nuclear Regulatory Commission on March 27, 1981 titled, "ASME Code Section XI, Inservice Inspection and Testing Program".

3.2 Examination Procedures

A listing of the procedures used for the examinations is shown in Table III of Appendix C. The ultrasonic examination procedure for pipe welds complied with the requirements of Appendix III of ASME Section XI that was issued in the Summer, 1978 Addenda. All other examination procedures complied with the requirements of the 1977 Edition including the Summer 1978 Addenda of ASME Section XI.

3.3 Examination Methods

Ultrasonic examination methods and techniques were used to perform volumetric examinations. The ultrasonic test system consisted of an ultrasonic digital analog tester and a two channel strip chart recorder. One channel of the recorder was calibrated to record the ultrasonic screen height (amplitude) of the reflector and the second channel was calibrated to record the metal path (sweep) to the reflector. This technique provides a permanent record of the examination for future reference.

Liquid penetrant and magnetic particle examination methods were used to perform the surface examinations. The liquid penetrant examinations were performed using color-contrast-solvent removable materials. Magnetic particle examinations were performed using a yoke and dry powder.

All visual examinations were aided, when necessary, with artificial lighting and verified for adequacy with an 18% neutral gray card with a 1/32 inch black line. Cold hangar load settings were visually verified (when applicable) and recorded on the report along with the piping system temperature.

3.4 Equipment and Materials

All equipment and expendable materials used in the examinations are listed by either serial number or type along with their respective calibration date or batch number in Table IV or Appendix C.

The ultrasonic calibration standards used in the examinations are listed in Table II of Appendix C. These standards are owned and maintained by NSP at the plant site.

3.5 Personnel

Northern States Power Company contracted Lambert, MacGill, Thomas, Inc. to perform the baseline examinations. Hartford Steam Boiler Inspection and Insurance Company, provided the Authorized Nuclear Inspection.

All ultrasonic Level II examiners performing examinations in accordance with NSP-UT-16 Rev. 0 and 1 on stainless piping were EPRI qualified in the detection of IGSCC. Level I examiners were required to demonstrate scanning and detection proficiency on site. Qualification records for examination personnel are maintained on file by Northern States Power Company.

3.6 Evaluation

Any indications found during the examinations were evaluated by the examiner at the time of the examination, in accordance with the procedure and ASME Section XI.

The ultrasonic examiner was aided in his evaluation by a calibration performed on a standard reference before each day's examination and checked before and after each individual examination and at intervals not exceeding 4 hours. In addition, the ultrasonic data was recorded on strip charts, which were made part of the inspection report and permitted further evaluation.

3.7 Examination Reports and Documentation

All examination reports and documentations are maintained on file by Northern States Power Company. Table I of Appendix A lists the results of these baseline examinations. The personnel, ultrasonic calibration blocks, procedures, equipment and materials used for the examinations are identified in the tables of Appendix C. Appendix D contains the Form NIS-1, titled "Owners' Data Report for Inservice Inspections".

3.8 Summary of Results

The following is a list of all anomalies detected:

<u>System</u>	<u>Item ID</u>	<u>Exam Method</u>	<u>Type & No. of Indications</u>	
Recirc."A"	RCAJR-4A to RCAJR-5	PT	1 - 1/4" Linear	
	RCAJR-7 to RCAJR-8	PT	1 - 1/8" slug of metal on weld	
	RCAJR-15 to RCAJR-16 (I.R.)	PT	1 - linear	
	RCAJR-15 to RCAJR-16 (O.R.)	PT	5 - linears	
	RCAJR-17	PT	ARC strike,multiple linears	
	RCAJR-24 to RCAJR-25	PT	1 - linear	
	RRKJR-5	PT	1 linear, 4 rounded	
	RRKJR-7	PT	1 linear, 4 rounded	
	RCAKR-12A VT	VT	loose nut	
	RCAKR-21	PT	1 linear	
	RCAKR-33A(W-8)	PT	1 linear	
	RCAKR-33A(W-9)	PT	Multiple linears	
	RCAKR-33A	VT	loose nut	
	RHAR-4	VT	loose nut	
	RCAKR-29	VT	loose nut	
	RRHK-6	VT	loose nuts	
	Recirc"B"	RCBJR-3 to RCBJR-4	PT	2 linears
		RCBJR-4	PT	2 linears
		RCBJR-7 to RCBJR-8	PT	1 linear
		RCBJR-8 to RCBJR-9	PT	2 linears
RCBJR-10		PT	intermittent linear	
RCBJR-13		PT	3 linears	
RCBJR-14		PT	1 linear	

RCBJR-15 to	PT	1 linear
RCBJR-18		
RCBJR-20	PT	1 linear
RCBJR-21 to	PT	crater crack
RCBJR-22		
RRDJR-4 to	PT	1 linear
RRDJR-5		
RCBKR-10A(W-1)	PT	2 linears
RCBKR-10A(W-2)	PT	2 linears
RCBKR-10A(W-4)	PT	multiple linears
RCBKR-10A	VT	loose nuts
RCBKR-32A(W-8)	PT	4 rounded, 1 linear
RCBKR-32A(W-9)	PT	1 linear
RCBKR-32A(W-10)	PT	multiple linears
RCBKR-27	VT	loose nut
RRAK-6	VT	loose nuts

RHR	POS 2018	VT	loose nuts
	RHAJR-3	PT	3 linears
	RHBJR-7	MT	4 linears
	RHAKR-8	VT	no weep hole
	RHBKR-12	VT	not attached to wall
	RHBKR-18	VT	no weep hole
	RHCKR-9	VT	not attached to wall
	RHCKR-17A	VT	no weep hole
	RHCKR-24	VT	no weep hole

All anomalies were corrected. Loose nuts and bolts were tightened. PT and MT linear and rounded indications were removed by surface blending with a hand grinder. On component supports, weep holes were installed and supports attached to walls.

NOTES

I. Identification of Welds

A. Circumferential Welds

1. These welds are designated by a 4 or 5 letter prefix and a number following the letters. EX. RCAJR-5.

B. Longitudinal Welds

1. These welds are identified by assigning them the circumferential weld number that is on either side of the weld. EX. 1. RCAJR-4 to RCAJR-5

II. Abbreviations used in this report

A. Nomenclature

1. INT. - Intermittent
2. I.R. - Inner Radius
3. O.R. - Outer Radius
4. GEO. - Geometry
5. I.D. - Inside Diameter
6. O.D. - Outside Diameter
7. Long. - Longitudinal
8. AMP - Amplitude

APPENDIX A

ASME CLASS 1 EXAMINATIONS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>REACTOR VESSEL</u>						
<u>B5.10 NOZZLE TO SAFE END WELDS</u>						
STANDBY LIQUID CONTROL N10	17	PT UT UT	CPAFR-2 CPAFR-2 CPAFR-2	84-1170BL 84-1295BL 84-1345BL	NONE NONE S-1, ID GEO, 90% 360° INT. S-2, ID GEO, 65% 360° INT.	NONE L-WAVE EXAM NONE
RECIRC OUTLET N1A	13A	PT UT UT	RCAFR-2 RCAFR-2 RCAFR-2	84-1007BL 84-1034BL 84-1344BL	NONE NONE S-1, ID GEO, 20% INT. 360° S-2, Spot, 12% 30.5" to 31.75" ID OD GEO. < 20% INT. 360° S-3 ID CLAD ROLL < 20% NOZZLE SIDE S-4, ID, CLAD ROLL < 20% 360° INT. S-2S, ID, ROLL < 20% 360° INT. S-3S, ID, OD Roll < 20% 360° INT. S-4S, ID, OD ROLL < 20% 360° INT.	NONE L-WAVE EXAM NONE
RECIRC OUTLET N1B	13B	PT UT UT	RCBFR-2 RCBFR-2 RCBFR-2	84-1027BL 84-1035BL 84-1456BL	NONE NONE S-1, ID CLAD ROLL < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT.	NONE L-WAVE EXAM NONE
JFS073085WMH01-LT						

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

TABLE 5.1
 Page 2 OF 7

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC INLET N2A	13D	PT UT UT	RRAFR-2 RRAFR-2 RRAFR-2	84-1028BL 84-1044BL 84-1392BL	NONE NONE S-1, ID OD GEO.<20% 360° INT. S-2, ID GEO.<20% 360° INT. S-3, ID GEO.<20% 360° INT. NOZZLE SIDE ONLY S-4, ID GEO.<20% 360° INT. NOZZLE SIDE ONLY S-2S, ID GEO.<20% 360° INT. S-3S, ID GEO.<20% 360° INT. NOZZLE SIDE ONLY	NONE L-WAVE EXAM NONE
N2D	13D	PT UT UT	RRDFR-2 RRDFR-2 RRDFR-2	84-1211BL 84-1269BL 84-1389BL	NONE NONE S-1, ID GEO.35% 360° INT. OD GEO.<20% 360° INT. S-2, ID GEO.25% 360° INT. S-3, ID GEO.<20% 360° INT. CLAD SIDE ONLY S-4, ID GEO.<20%, 360° INT. CLAD SIDE ONLY S-3S, ID GEO.< 20% 360° INT. S-4S, ID GEO.<20% 360° INT.	NONE L-WAVE EXAM NONE CLAD ON NOZZLE SIDE ONLY
N2J	13C	PT UT UT	RRJFR-2 RRJFR-2 RRJFR-2	84-1129BL 84-1142BL 84-1395BL	NONE NONE S-1, ID GEO.<20% 360° INT. OD GEO.25% 360° INT. S-2, ID GEO.<20% 360° INT. S-3, ID GEO.<20% 360° INT. S-4, ID OD GEO.<20% 360° INT. S-3S, ID GEO.<20% 360° INT. S-4S, ID GEO.<20% 360° INT.	NONE L-WAVE EXAM NONE
JFS073085WMH01-LT						

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
N2H	13C	PT UT UT	RRHFR-2 RRHFR-2 RRHFR-2	84-1068BL 84-1089BL 84-1412BL	NONE NONE S-1, ID GEO. 30% 360° INT. OD GEO. <20% 360° INT. S-2, ID GEO. 25% 360° INT. S-3, ID GEO. < 20% 360° INT. S-4, ID GEO. < 20% 360° INT. S-3S, ID GEO. < 20% 360° INT. S-4S, ID GEO. < 20% 360° INT.	NONE L-WAVE EXAM NONE
N2E	13D	PT UT UT	RREFR-2 RREFR-2 RREFR-2	84-1130BL 84-1140BL 84-1388BL	NONE NONE S-1, ID OD GEO. <20% 360° INT. S-2, ID GEO. 30% 360° INT. S-3, ID GEO. <20% 360° INT. S-4 ID GEO. <20% 360° INT. S-3S, ID GEO. 360° INT. S-4S, ID GEO. 360° INT.	NONE L-WAVE EXAM NONE
N2G	13C	PT UT UT	RRGFR-2 RRGFR-2 RRGFR-2	84-1049BL 84-1061BL 84-1413BL	NONE NONE S-1, ID GEO. 25% 360° INT. OD GEO. < 20% 360° INT. S-2, ID GEO. 30% 360° INT. S-3, ID GEO. < 20% 360° INT. S-4, OD GEO. < 20% 360° INT. S-3S, ID GEO. < 20% 360° INT. S-4S, ID OD GEO. <20% 360° INT.	NONE L-WAVE EXAM NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
N2B	13D	PT UT UT	RRBFR-2 RRBFR-2 RRBFR-2	84-1033BL 84-1045BL 84-1391BL	NONE NONE S-1, ID GEO. 20-25% 360° INT. OD GEO. <20% 360° INT. S-2, ID GEO. <20% 360° INT. S-3, ID GEO. <20% 360° INT. S-4, ID GEO. <20% 360° INT. S-3S, ID GEO. <20% 360° INT. S-4S, ID GEO. <20% 360° INT.	NONE L-WAVE EXAM NONE
N2F	13C	PT UT UT	RRFFR-2 RRFFR-2 RRFFR-2	84-1054BL 84-1060BL 84-1414BL	NONE NONE S-1, ID OD GEO. <20% 360° INT. S-2, ID GEO. <20% 360° INT. S-3, ID GEO. <20% 360° INT. S-4, ID GEO. <20% 360° INT. S-3S, ID GEO. <20% 360° INT. S-4S, ID GEO. <20% 360° INT.	NONE L-WAVE EXAM NONE
N2C	13D	PT UT UT	RRCFR-2 RRCFR-2 RRCFR-2	84-1038BL 84-1046BL 84-1390BL	NONE NONE S-1, ID GEO. 25 to 30% 360° INT. OD GEO. <20% 360° INT. S-2, ID GEO. <20% 360° INT. S-3, ID GEO. <20% 360° INT. S-4, ID GEO. <20% 360° INT. S-3S, ID GEO. <20% 360° INT.	NONE L-WAVE EXAM NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
N2K	13C	PT UT UT	RRKFR-2 RRKFR-2 RRKFR-2	84-1135BL 84-1141BL 84-1396BL	NONE NONE S-1, ID OD GEO. 20-25% 360° INT. S-2, ID GEO. < 20% 360°INT. S-3, ID GEO. < 20% 360°INT. S-4, ID GEO. < 20% 360°INT. S-3S, ID GEO. < 20% 360°INT. S-4S, ID GEO. < 20% 360°INT.	NONE L-WAVE EXAM NONE
JET PUMP INST. N8A	16	PT UT UT	JPAFR-2 JPAFR-2 JPAFR-2	84-1151BL 84-1294BL 84-1333BL	NONE NONE S-1, ID GEO. Inst. Lines, 55-185%, 360°INT. S-2, ID CLAD ROLL 35% 360° INT. S-3, ID ROLL < 20% S-4, ID ROLL < 20% S-4S, ID ROLL < 20%	NONE L-WAVE EXAM NONE
N8B	16	PT UT UT	JPBFR-2 JPBFR-2 JPBFR-2	84-1152BL 84-1293BL 84-1332BL	NONE NONE S-1, ID GEO. INST. LINES 20-35% 360° INT. S-2, ID CLAD ROLL 20-25% 360° INT. S-4, ID ROLL < 20% S-4S, ID ROLL < 20%	NONE L-WAVE EXAM NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>B5.50 SAFE END WELDS</u>						
RHR REW 10	11A	PT UT UT	RHAFR-4 RHAFR-4 RHAFR-4	84-973BL 84-982BL 84-1335BL	NONE NONE S-1, ID, OD, GEO. <20% 360° IN S-2, ID, OD, GEO. <20% 360° INT S-4, OD, GEO. L.S. 12:00 45% S-1S, ID, OD, GEO. <20% 360° IN S-2S, ID, OD, GEO. <20% 360° IN S-3S, ID, OD, GEO. <20% 360° IN S-4S, ID, GEO. 7:00 <20%	NONE L-WAVE EXAM NONE
RHR TW20	11B	PT UT UT	RHBFR-6 RHBFR-6 RHBFR-6	84-1024BL 84-1025BL 84-1337BL	NONE NONE S-1, ID, OD, GEO. <20% 360° INT S-2, ID, OD, GEO. <20% 360° INT S-3, ID, OD, GEO. <20% 360° INT S-4, ID, OD, GEO. <20% 360° INT S-3S, ID, OD, GEO. <20% 360° IN S-4S, ID, OD, GEO. <20% 360° IN	NONE L-WAVE EXAM NONE
	11B	PT UT UT	RHBFR-23 RHBFR-23 RHBFR-23	84-991BL 84-992BL 84-998BL	NONE NONE S-2, ID, OD, GEO. <20% 360° INT S-3, ID, OD ROLL < 20% S-4, ID ROLL < 20%	NONE L-WAVE EXAM NO S-1, S-1S, S-2S DUE TO CONFIGURATION VALVE
JFS073085WMH01-LT						

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RHR TW20	11B	PT UT UT	RHBFR-24 RHBFR-24 RHBFR-24	84-1002BL 84-1004BL 84-1006BL	NONE NONE S-1, ID, OD, GEO. <20% 360° INT.	NONE L-WAVE EXAM NO S-2, S-3S, S-4S DUE TO CONFIGURATION-VALVE
RHR TW30	11C	PT UT UT	RHCFR-6 RHCFR-6 RHCFR-6	84-974BL 84-983BL 84-1338BL	NONE NONE S-1, ID, OD, GEO. <20% 360° INT. S-2, ID, OD, GEO. <20% 360° INT. S-3, ID, OD, GEO. 12:00 L.S. S-4, ID, OD, GEO. 12:00 L.S. S-3S, ID, OD, GEO. <20% 360° INT. S-4S, ID, OD, GEO. <20% 360° INT.	NONE L-WAVE EXAM NONE
		PT UT UT	RHCFR-23 RHCFR-23 RHCFR-23	84-1029BL 84-1040BL 84-1041BL	NONE NONE S-2, ID, OD, GEO. <20% INT. S-3, ID, OD, GEO. <20% INT. S-4, ID, OD, GEO. <20% INT. S-3S, ID, OD, GEO. <20% INT. S-4S, ID, OD, GEO. <20% INT.	NONE L-WAVE EXAM NO S-1, S-1S, S-2S DUE TO CONFIGURATION-VALVE
	11C	PT UT UT	RHCFR-24 RHCFR-24 RHCFR-24	84-960BL 84-1003BL 84-1005BL	NONE NONE S-1, ID, OD, GEO. <20% INT. S-3, ID, OD, GEO. <20%	NONE L-WAVE EXAM NO S-2, S-3S, S-4S DUE TO CONFIGURATION-VALVE
RWCU	9	PT UT UT	CWAFR-3R CWAFR-3R CWAFR-3R	84-1267BL 84-1277BL 84-1341BL	NONE NONE S-1, ID, GEO. 35% 360° INT. S-2, ID, GEO. 30% 360° INT. S-3, ID, OD, GEO. <20% 360° INT. S-4, ID, OD, GEO. <20%	NONE L-WAVE EXAM NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>B6.230 BOLTING</u>						
RECIRC "A"	13A	VT-1	M02-53A	84-1469BL	NONE	NONE
RECIRC "A"		VT-1	M02-43A	84-1490BL	NONE	NONE
RECIRC "B"	13B	VT-1	M02-53B	84-1471BL	NONE	NONE
RECIRC "B"		VT-1	M02-43B	84-1470BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>B7.70 VALVES</u> <u>BOLTS, STUDS, AND NUTS</u>						
RHR TW20	11B	VT-1	POS-2019	84-1468BL	NONE	NONE
RHR TW30	11C	VT-1 VT-1	POS-2018 POS-2018	84-1467BL 84-1467BLR	LOOSE NUTS NONE-NUTS TIGHTENED	NONE NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 <u>CIRCUMFERENTIAL AND LONGITUDINAL WELDS</u> RWCU LINE	9	PT UT UT	CWAJR-2 CWAJR-2 CWAJR-2	84-1266BL 84-1276BL 84-1307BL	NONE NONE S-2, ID OD GEO. <20%, 360° INT. S-4, ID OD GEO. <20%, 360° INT.	NONE L-WAVE EXAM NO S-1, S-1S, AND S-3S DUE TO CONFIGURATION
	9	MT UT	CWAJR-4R CWAJR-4R	84-1291BL 84-1310BL	NONE NONE	NONE L-WAVE EXAM
	9	UT	CWAJR-4R	84-1313BL	S-1, ID GEO. 40% 360° INT. OD GEO. 50% 360° INT. S-2, ID GEO. 60% 360° INT.	S-1 LIMITED 10:00 TO 2:00, INNER RADIUS OF ELBOW
	9	MT UT UT	CWAJR-5R CWAJR-5R CWAJR-5R	84-1288BL 84-1309BL 84-1306BL	NONE NONE S-1, ID, GEO 55-60% 360° INT. S-2, ID, GEO 80-100% 360° INT.	NONE L-WAVE EXAM S-2 LIMITED 5:00 TO 7:00 INNER RADIUS OF ELBOW

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 9.12 (CONT.) RWCU	9	MT	CWAJR-6	84-1292BL	NONE	NONE L-WAVE EXAM S-1 LIMITED 5:00 TO 7:00 INNER RADIUS OF ELBOW
		UT	CWAJR-6	84-1285BL	NONE	
		UT	CWAJR-6	84-1305BL	S-1, ID GEO. 75-80% 360° INT. S-2, ID GEO. 50% 360° INT.	
	9	MT	CWAJR-7	84-1278BL	NONE	NONE L-WAVE EXAM S-2 LIMITED 10:00 TO 2:00 INNER RADIUS OF ELBOW
		UT	CWAJR-7	84-1273BL	NONE	
UT		CWAJR-7	84-1304BL	S-2, ID GEO. 75-80% 360° INT.		
9	MT	CWAJR-8	84-1279BL	NONE	NONE L-WAVE EXAM NO. S-2, VALVE	
	UT	CWAJR-8	84-1274BL	NONE		
	UT	CWAJR-8	84-1303BL	S-1, ID GEO. 55-75% 360° INT.		
9	MT	CWAJR-9	84-1280BL	NONE	NONE L-WAVE EXAM NONE	
	UT	CWAJR-9	84-1275BL	NONE		
	UT	CWAJR-9	84-1302BL	S-1, ID GEO. 3:00 < 20% S-2, ID GEO. 50-60% 360° INT.		
9	MT	CWAJR-10	84-1509BL	NONE	NONE L-WAVE EXAM STAMP ON OD AT 10:00	
	UT	CWAJR-10	84-1518BL	NONE		
	UT	CWAJR-10	84-1571BL	S-1, ID GEO. 60% 360° INT. S-2, ID GEO. 40% 360° INT. S-3, OD GEO. 10:00 < 20%		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT)	9	MT	CWAJR-11	84-1570BL	NONE	NONE L-WAVE EXAM LIMITED CONTACT ALL SCANS DUE TO TO INNER RADIUS	
		UT	CWAJR-11	84-1519BL	NONE		
		UT	CWAJR-11	84-1572BL	S-1, ID GEO.60-70% 360°INT. S-2, ID GEO.50-60% 360°INT.		
	9	MT	CWAJR-12	84-1510BL	NONE	NONE L-WAVE EXAM LIMITED CONTACT FROM 11:00 to 1:00 INNER RADIUS OF ELBOW	
		UT	CWAJR-12	84-1520BL	NONE		
		UT	CWAJR-12	84-1573BL	S-1, ID GEO.95% 360°INT. S-2, ID GEO.60-65% 360°INT.		
	9	MT	CWAJR-13	84-1511BL	NONE	NONE L-WAVE EXAM LIMITED CONTACT FROM 11:00 to 1:00 INNER RADIUS OF ELBOW	
		UT	CWAJR-13	84-1521BL	NONE		
		UT	CWAJR-13	84-1574BL	S-1, ID GEO.35-50% 360°INT. S-2, ID GEO.55-90% 360°INT.		
	B9.11 & 9.12 (CONT)	9	MT	CWAJR-13A	84-1512BL	NONE	NONE L-WAVE EXAM NONE
			UT	CWAJR-13A	84-1522BL	NONE	
			UT	CWAJR-13A	84-1575BL	S-1, ID GEO.45-65% 360°INT. S-2, ID GEO.70-75% 360°INT.	
B9.11 & 9.12 (CONT)	9	MT	CWAJR-14	84-1513BL	NONE	NONE L-WAVE EXAM NONE	
		UT	CWAJR-14	84-1523BL	NONE		
		UT	CWAJR-14	84-1592BL	S-1, ID GEO.50% 360°INT. S-2, ID GEO.25-45% 360°INT.		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	9	MT	CWAJR-15	84-1514BL	NONE	NONE L-WAVE EXAM NONE
		UT	CWAJR-15	84-1524BL	NONE	
		UT	CWAJR-15	84-1591BL	S-1, ID GEO. 50-95% 360° INT. S-2, ID GEO. 60-80% 360° INT.	
	9	MT	CWAJR-16	84-1582BL	NONE	NONE L-WAVE EXAM NO S-2, DUE TO CONFIGURATION VALVE
		UT	CWAJR-16	84-1588BL	NONE	
		UT	CWAJR-16	84-1590BL	S-1, ID GEO. 50% 360° INT.	
	9	MT	CWAJR-17	84-1515BL	NONE	NONE L-WAVE EXAM NO. S-1 DUE TO CONFIGURATION VALVE
		UT	CWAJR-17	84-1525BL	NONE	
		UT	CWAJR-17	84-1589BL	S-2, ID GEO. 45-50% 360° INT.	
	9	MT	CWAJR-18	84-1516BL	NONE	NONE L-WAVE EXAM LIMITED SCANS FROM 11:00 to 1:00 DUE TO INNER RADIUS
		UT	CWAJR-18	84-1526BL	NONE	
		UT	CWAJR-18	84-1576BL	S-1, ID GEO. 70-95% 360° INT. S-2, ID GEO. 60-75% 360° INT.	
	9	MT	CWAJR-19	84-1517BL	NONE	NONE L-WAVE EXAM LIMITED SCANS FROM 11:00 TO 1:00 DUE TO INNER RADIUS
		UT	CWAJR-19	84-1527BL	NONE	
		UT	CWAJR-19	84-1577BL	S-1, ID GEO. 50% 360° INT. S-2, ID GEO. 50% 360° INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT) RHR REW 10	11A	PT	RHAJR-1	84-994BL	NONE	NONE L-WAVE EXAM NO S-1, S-1S S-2S DUE TO CONFIGURATION TEE	
		UT	RHAJR-1	84-980BL	NONE		
		UT	RHAJR-1	84-1334BL	S-2, ID OD GEO. <20% 360° INT. S-3, ID OD GEO. <20% 360° INT. S-4, ID GEO. 12:00 35% LONG SEAM ID OD GEO. <20% 360° INT.		
			PT	RHAJR-1 TO RHAJR-2	84-054BL	NONE	NONE
			UT	RHAJR-1 TO RHAJR-2	84-258BL	S-5, ID OD GEO. 10-30% 0" to 24", INT. S-6, ID OD GEO. 15-25% 0" to 24", INT.	NONE
		11A	PT	RHAJR-2	84-053BL	NONE	NONE
		11A	UT	RHAJR-2	84-236BL	S-1, ID OD GEO. 10% 6:00 TO 12:00, INT. S-2, ID OD GEO. 10-30% 360° INT.	AREAS OF MISMATCH WAVY OD SURFACE
		11A	PT	RHAJR-2 TO RHJAR-3	84-055BL	NONE	NONE
		UT	RHAJR-2 TO RHJAR-3	84-257BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11A	PT	RHAJR-3	84-062BL	3 LINEARS	NONE NONE 360° MISMATCH
		PT	RHAJR-3	84-170BLR	NONE LINEARS REMOVED	
		UT	RHAJR-3	84-237BL	S-1, ID OD GEO. 10-25% 360° INT. S-2, OD GEO. 12% 360° INT.	
	11A	PT	RHAJR-3 TO RHAJR-4	84-061BL	NONE	NONE
		UT	RHAJR-3 TO RHAJR-4	84-256BL	S-1, ID OD GEO. 10-15% "0 to 24" INT. S-2, ID OD GEO. 15-35% "0 to 24" INT.	NONE
	11A	MT	RHAJR-5	84-1216BL	NONE	NONE L-WAVE EXAM NO S-2, DUE TO CONFIGURATION VALVE
		UT	RHAJR-5	84-1235BL	NONE	
		UT	RHAJR-5	84-1281BL	NONE	
	11A	MT	RHAJR-6	84-1215BL	NONE	NONE L-WAVE EXAM NO S-1 DUE TO CONFIGURATION VALVE
		UT	RHAJR-6	84-1234BL	NONE	
UT		RHAJR-6	84-1282BL	S-2, ID OD GEO. <20% 360° INT.		
11A	MT	RHAJR-7	84-1214BL	NONE	NONE L-WAVE EXAM NONE	
	UT	RHAJR-7	84-1233BL	NONE		
	UT	RHAJR-7	84-1283BL	S-1, ID GEO. 30% 360° INT.		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11A	MT	RHAJR-11	84-946BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHAJR-11	84-944BL	NONE	
		UT	RHAJR-11	84-950BL	S-1, ID GEO.25% 1:00-3:00	
	11A	MT	RHAJR-12	84-947BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHAJR-12	84-945BL	NONE	
		UT	RHAJR-12	84-951BL	S-1, ID GEO.40% 360°INT. S-2, ID GEO.25% 4:00-8:30	
	11A	MT	RHAJR-16	84-1217BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHAJR-16	84-1232BL	NONE	
		UT	RHAJR-16	84-1284BL	S-1, OD GEO.10:30 <20% S-2, ID OD GEO.<20% 360°INT	
	11A	MT	RHAJR-9	84-1357BL	NONE	NONE NO S-1,S-2,S-3 S-4 DUE TO CONFIGURATION WELDED NECK & FLANGE FITTING.
		UT	RHAJR-9	-----	----	
	11A	MT	RHAJR-14	84-1351BL	NONE	NONE NO S-1,S-2,S-3, S-4 DUE TO CONFIGURATION WELDED NECK & FLANGE FITTING
		UT	RHAJR-14	-----	----	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RHR TW20	11B	PT UT UT	RHBJR-1 RHBJR-1 RHBJR-1	84-1008BL 84-1010BL 84-1339BL	NONE NONE S-1, ID OD GEO. <20% 360° INT. S-3, OD GEO. 6:00 60% LONG. S. S-4, ID OD GEO. <20% 360° INT. OD GEO. 6:00 30% LONG. S. S-1S, ID OD GEO. <20% 360° INT. S-2S, ID OD GEO. <20% 360° INT.	NONE L-WAVE EXAM NO. S-2, S-3S & S-4S DUE TO CONFIGURATION TEE
	11B	PT	RHBJR-1 TO RHBJR-2	84-104BL	NONE	NONE
		UT	RHBJR-1 TO RHBJR-2	84-242BL	S-5, OD GEO. 15% 0" to 12" INT. S-6, OD GEO. 50% 0" to 12" INT.	NONE
	11B	PT UT	RHBJR-2 RHBJR-2	84-103BL 84-240BL	NONE S-1, OD GEO. 25% 360° INT. S-2, ID OD GEO. 25-30% 360° INT.	NONE S-2 LIMITED 9:00 TO 3:00 OD MISMATCH, TOE OF WELD BACK 1" DUE TO TAPER
	11B	PT	RHBJR-2 TO RHBJR-3	84-102BL	NONE	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.I
PAGE 9 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)		UT	RHBJR-2 TO RHBJR-3	84-238BL	S-5,OD GEO. 10% 0" TO 42" INT. S-6,OD GEO. 30% 0" TO 42" INT.	NONE
	11B	PT UT	RHBJR-3 RHBJR-3	84-096BL 84-248BL	NONE S-1,ID OD GEO. 20-30% 360° INT. S-2,OD GEO. 10% 360°INT.	NONE MINOR MISMATCH
	11B	PT	RHBJR-3 TO RHBJR-4	84-090BL	NONE	NONE
		UT	RHBJR-3 TO RHBJR-4	84-239BL	S-5,ID GEO. 10% 0" TO 6" INT. S-6,OD GEO. 10% 1" TO 4" INT.	NONE
	11B	PT UT	RHBJR-4 RHBJR-4	84-094BL 84-249BL	NONE S-1,OD GEO. 20% 360°INT. S-2,ID OD GEO. 15-20% 360° INT.	NONE NONE
	11B	PT	RHBJR-4 TO RHBJR-5	84-101BL	NONE	PUNCH MARK ON WELD.
		UT	RHBJR-4 TO RHBJR-5	84-243BL	S-5,ID GEO. 10% 0" TO 15" INT. S-6,ID GEO. 10% 0" TO 15" INT.	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS																																													
B9.11 & 9.12 (CONT)	11B	PT	RHBJR-5	84-095BL	NONE S-1, ID OD GEO.20% 360° INT. S-2, OD GEO.10% 360° INT.	NONE NONE																																													
		UT	RHBJR-5	84-247BL			11B	PT	RHBJR-5 TO RHBFR-6	84-089BL	NONE	NONE	UT	RHBJR-5 TO RHBFR-6	84-244BL	S-5, OD GEO. 15% 0" TO 6" INT. S-6, ID OD GEO.10-12% 0" TO 6" INT.	NONE	11B	MT	RHBJR-7	84-964BL	FOUR LINEARS	NONE NONE NO S-1 DUE TO CONFIGURATION VALVE	MT	RHBJR-7	84-964BLR	NONE LINEARS REMOVED	UT	RHBJR-7	84-968BL	NONE	11B	MT	RHBJR-8	84-1132BL	NONE	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION VALVE	UT	RHBJR-8	84-1153BL	NONE	UT	RHBJR-8	84-1154BL	NONE	11B	MT	RHBJR-12	84-917BL	NONE S-1, ID OD GEO.17% 360° INT. S-2, ID OD GEO.25% to 30% 360° INT.	NONE NONE
	11B	PT	RHBJR-5 TO RHBFR-6	84-089BL	NONE	NONE																																													
		UT	RHBJR-5 TO RHBFR-6	84-244BL	S-5, OD GEO. 15% 0" TO 6" INT. S-6, ID OD GEO.10-12% 0" TO 6" INT.	NONE																																													
	11B	MT	RHBJR-7	84-964BL	FOUR LINEARS	NONE NONE NO S-1 DUE TO CONFIGURATION VALVE																																													
		MT	RHBJR-7	84-964BLR	NONE LINEARS REMOVED																																														
		UT	RHBJR-7	84-968BL	NONE																																														
	11B	MT	RHBJR-8	84-1132BL	NONE	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION VALVE																																													
		UT	RHBJR-8	84-1153BL	NONE																																														
		UT	RHBJR-8	84-1154BL	NONE																																														
	11B	MT	RHBJR-12	84-917BL	NONE S-1, ID OD GEO.17% 360° INT. S-2, ID OD GEO.25% to 30% 360° INT.	NONE NONE																																													
		UT	RHBJR-12	84-930BL																																															

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11B	MT UT	RHBJR-13 RHBJR-13	84-928BL 84-929BL	NONE S-1, ID OD GEO. 25% TO 50% 360° INT. S-2, ID OD GEO. 20% 360° INT.	NONE NONE
	11B	MT UT UT	RHBJR-14 RHBJR-14 RHBJR-14	84-1221BL 84-1253BL 84-1255BL	NONE NONE S-1, ID OD GEO. < 20% INT. MAX AMP 40-50% S-2, ID OD GEO. < 20% INT. MAX AMP 50-80% S-4 SPOT, 30-50% 10:00 TO 10:30 ON CL	NONE L-WAVE EXAM NONE
	11B	MT UT UT	RHBJR-14A RHBJR-14A RHBJR-14A	84-1125BL 84-1126BL 84-1127BL	NONE NONE S-1, ID OD GEO. < 20%	NONE L-WAVE EXAM NONE
	11B	MT UT UT	RHBJR-15 RHBJR-15 RHBJR-15	84-1219BL 84-1254BL 84-1256BL	NONE NONE S-2, ID OD GEO. 60%-75% INT.	NONE L-WAVE EXAM MOST OD SIGNALS ARE COUPLANT NOISE
	11B	MT UT UT	RHBJR-16 RHBJR-16 RHBJR-16	84-922BL 84-924BL 84-926BL	NONE NONE S-1, ID GEO. 40%-85% 360° INT. S-2, ID OD GEO. < 20%	NONE L-WAVE EXAM NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11B	MT	RHBJR-17	84-1037BL	NONE	NONE L-WAVE EXAM S-2 LIMITED DUE TO INNER RADIUS
		UT	RHBJR-17	84-1042BL	NONE	
		UT	RHBJR-17	84-1043BL	S-1, ID OD GEO. 20% INT. MAX AMP. 90%-95% S-2, ID GEO. 50%-60% INT.	
	11B	MT	RHBJR-18	84-923BL	NONE	NONE L-WAVE EXAM COUNTER BORE
		UT	RHBJR-18	84-925BL	NONE	
		UT	RHBJR-18	84-927BL	S-1, ID GEO. 50%-90% 360° INT. S-2, ID GEO. 65% 360° INT.	
	11B	MT	RHBJR-19	84-1193BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHBJR-19	84-1257BL	NONE	
		UT	RHBJR-19	84-1263BL	S-2, ID OD GEO. < 20% INT. MAX AMP. 20%-50%	
	11B	MT	RHBJR-25	84-1222BL	NONE	NONE L-WAVE EXAM REDIRECTED BEAM FROM ID
		UT	RHBJR-25	84-1265BL	NONE	
		UT	RHBJR-25	84-1262BL	S-1, ID OD GEO. 80%-105% INT S-2, ID OD GEO. 55%-65%	
	11B	MT	RHBJR-10	84-1353BL	NONE	NONE NO S-1, S-2, S-3, & S-4, WELDED NECK & FLANGE FITTING
		UT	RHBJR-10	-----	----	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11B	MT UT	RHBJR-21 RHBJR-21	84-1355BL -----	NONE -----	NONE NO S-1,S-2,S-3, & S-4,WELDED NECK & FLANGE FITTING
RHR TW30	11C	PT UT UT	RHCJR-1 RHCJR-1 RHCJR-1	84-1009BL 84-1011BL 84-1336BL	NONE NONE S-1, ID OD GEO. <20% 360° INT. S-2, ID GEO. < 20% S-2, OD GEO. 40% LONG. SEAM S-1S, ID OD GEO. <20% 360° INT. S-2S, ID OD GEO. <20% 360° INT.	NONE L-WAVE EXAM NO S-2,S-3S & S-4S DUE TO CONFIGURATION TEE
	11C	PT	RHCJR-1 TO RHCJR-2	84-082BL	NONE	NONE
		UT	RHCJR-1 TO RHCJR-2	84-241BL	S-5, OD GEO. 35% 0" TO 12" INT. S-6, ID OD GEO. 20% TO 35% 0" TO 12" INT.	NONE
RHR TW30	11C	PT UT	RHCJR-2 RHCJR-2	84-097BL 84-250BL	NONE S-1, OD GEO. 15% 360° INT. S-2, OD GEO. 25% 360° INT.	NONE MISMATCH ON ELBOW, NO SCAN ON WELD, MOST AREAS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11C	PT	RHCJR-2 TO RHCJR-3	84-081BL	NONE	NONE
		UT	RHCJR-2 TO RHCJR-3	84-251BL	S-5,OD GEO.10% 0"TO 42"INT. S-6,OD GEO.12% 0"TO 42"INT.	NONE
	11C	PT	RHCJR-3	84-098BL	NONE	NONE NONE
		UT	RHCJR-3	84-252BL	S-1,ID OD GEO. 15%-65% 360° INT. S-2,ID OD GEO. 10%-25% 360° INT.	
	11C	PT	RHCJR-3 TO RHCJR-4	84-099BL	NONE	NONE
		UT	RHCJR-3 TO RHCJR-4	84-253BL	S-5,ID OD GEO. 10%-20% 0" TO 6" INT. S-6,ID OD GEO. 10%-15% 0" TO 6" INT.	NONE
	11C	PT	RHCJR-4	84-091BL	NONE	NONE NONE
		UT	RHCJR-4	84-254BL	S-1,ID OD GEO. 10%-15% 360° INT. S-2,ID OD GEO. 10%-15% 360° INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11C	PT	RHCJR-4 TO RHCJR-5	84-100BL	NONE	NONE
		UT	RHCJR-4 TO RHCJR-5	84-255BL	S-5, ID OD GEO. 10%-25% 0" TO 15" INT. S-6, ID OD GEO. 10%-15% 0" TO 15" INT.	T T
	11C	PT UT	RHCJR-5 RHCJR-5	84-083BL 84-246BL	NONE S-1, ID OD GEO. 20%-25% 360° INT.	NONE NONE
	11C	PT	RHCJR-5 TO RHCJR-6	84-079BL	NONE	NONE
	11C	UT	RHCJR-5 TO RHCJR-6	84-245BL	S-5, ID OD GEO. 10-15% 0" TO 6" INT. S-6, ID OD GEO. 15% 0" TO 6" INT.	NONE
	11C	MT UT	RHCJR-7 RHCJR-7	84-963BL 84-967BL	NONE S-2, ID GEO. 25-30% 360° INT.	NONE NO S-1 DUE TO CONFIGURATION VALUE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 16 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11C	MT	RHCJR-8	84-1220BL	NONE	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION VALUE
		UT	RHCJR-8	84-1249BL	NONE	
		UT	RHCJR-8	84-1261BL	S-1, ID GEO. 45% INT.	
	11C	MT	RHCJR-12	84-941BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-12	84-942BL	NONE	
		UT	RHCJR-12	84-952BL	S-1, ID OD GEO. 50% 360° INT. S-2, ID SPOT 50% 6:00 ID OD GEO. 35-40% 360° INT.	
	11C	MT	RHCJR-13	84-940BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-13	84-943BL	NONE	
		UT	RHCJR-13	84-953BL	S-1, ID GEO. 30% 360° INT. S-2, ID OD GEO. 35-50% 360° INT.	
	11C	MT	RHCJR-14	84-1196BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-14	84-1251BL	NONE	
		UT	RHCJR-14	84-1260BL	S-1, ID GEO. 55-65% INT. OD GEO. <20% INT.	
	11C	MT	RHCJR-15	84-1195BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-15	84-1250BL	NONE	
		UT	RHCJR-15	84-1259BL	S-1, ID GEO. <20% OD GEO. <20%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11C	MT	RHCJR-16	84-997BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-16	84-995BL	NONE	
		UT	RHCJR-16	84-996BL	S-1, ID GEO. 60-75% 360° INT. OD GEO. 50% 360° INT. S-2, ID GEO. 25-50% 360° INT. OD GEO. 50% 360° INT.	
	11C	MT	RHCJR-17	84-1088BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-17	84-1111BL	NONE	
		UT	RHCJR-17	84-1112BL	S-1, ID OD GEO. < 20% S-2, ID OD GEO. 25-40% INT.	
	11C	MT	RHCJR-18	84-962BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-18	84-957BL	NONE	
		UT	RHCJR-18	84-959BL	S-1, ID OD GEO. 25-100% 360° INT. S-2, ID GEO. 35% 360° INT.	
	11C	MT	RHCJR-19	84-1016BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-19	84-1014BL	NONE	
		UT	RHCJR-19	84-1015BL	S-1, ID GEO. 40% 360° INT. S-2, ID GEO. 45-80% 360° INT.	
	11C	MT	RHCJR-25	84-1194BL	NONE	NONE L-WAVE EXAM NONE
		UT	RHCJR-25	84-1252BL	NONE	
		UT	RHCJR-25	84-1258BL	S-1, ID GEO. 50-60% INT. S-2, ID GEO. 50% INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	11C	MT UT	RHCJR-10 RHCJR-10	84-1347BL -----	NONE ----	NONE NO S-1,S-2,S-3, & S-4 DUE TO CONFIGURATION WELDED NECK & FLANGE FITTING
	11C	MT UT	RHCJR-21 RHCJR-21	84-1348BL -----	NONE ----	NONE NO S-1,S-2,S-3, & S-4 DUE TO CONFIGURATION WELDED NECK & FLANGE FITTING
RHR TW40		MT UT UT	RHEJR-2 RHEJR-2 RHEJR-2	84-1180BL 84-1209BL 84-1227BL	NONE NONE S-1, ID GEO. 25% 360° INT.	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION NOISE AND STANDING WAVE 360°
RHR TW40		MT UT UT	RHEJR-3 RHEJR-3 RHEJR-3	84-880BL 84-893BL 84-893BL	NONE NONE S-1, ID GEO. 70% INT. S-2, ID GEO. 40% INT. OD GEO. 80% INT.	NONE L-WAVE EXAM NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS			
B9.11 & 9.12 (CONT)		MT	RHEJR-4	84-879BL	NONE	NONE L-WAVE EXAM NONE			
		UT	RHEJR-4	84-891BL	NONE				
		UT	RHEJR-4	84-891BL	S-1, ID GEO. 40% INT. OD GEO. 80% INT. S-2, ID GEO. 50% INT. OD GEO. 75% INT.				
		MT	RHEJR-5	84-1133BL	NONE		NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION		
		UT	RHEJR-5	84-1148BL	NONE				
		UT	RHEJR-5	84-1150BL	S-1, ID GEO. 50-60%				
		MT	RHEJR-6	84-1182BL	NONE		NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION NOISE AND STANDING WAVES, 360°		
		UT	RHEJR-6	84-1208BL	NONE				
		UT	RHEJR-6	84-1228BL	S-1, ID GEO. 30% 360° INT. OD GEO. <20% 360° INT.				
		RHR TW40		MT	RHEJR-7		84-858BL	NONE	NONE L-WAVE EXAM NONE
				UT	RHEJR-7		84-862BL	NONE	
				UT	RHEJR-7		84-862BL	S-1, ID GEO. 45% INT. OD GEO. 50% INT. S-2, ID OD GEO. 85-100% S-3, OD GEO. 4:30, 25-35%	
MT	RHEJR-8			84-1134BL	NONE	NONE L-WAVE EXAM LIMITED SCAN 3:00 TO 9:00 I.R. OF ELBOW			
UT	RHEJR-8	84-1147BL	NONE						
UT	RHEJR-8	84-1149BL	S-1, ID GEO. 60-65% INT. OD GEO. 50% S-2, ID GEO. 40-45%						

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT)		MT	RHEJR-9	84-1290BL	NONE	NONE L-WAVE EXAM LIMITED S-1 DUE TO IR OF OF ELBOW	
		UT	RHEJR-9	84-1311BL	NONE		
		UT	RHEJR-9	84-1315BL	S-1, ID GEO. 75-125% 3.4" CCW TO 12:00 S-2, ID GEO. 50% 360° INT.		
		MT	RHEJR-10	84-881BL	NONE	NONE L-WAVE EXAM NONE	
		UT	RHEJR-10	84-892BL	NONE		
		UT	RHEJR-10	84-892BL	S-1, ID GEO. 35-45% INT. S-2, ID GEO. 75-80% INT.		
	RHR TW40		MT	RHEJR-10A	84-1163BL	NONE	NONE L-WAVE EXAM INDICATIONS LIKELY DUE TO PIPE TO ELBOW MISMATCH
			UT	RHEJR-10A	84-1164BL	NONE	
			UT	RHEJR-10A	84-1166BL	S-1, ID GEO. 120% 5 3/4" TO 6 3/4" CW S-2, ID GEO. 120% 5 3/4" TO 6 3/4" CW	
			MT	RHEJR-11	84-1183BL	NONE	NONE L-WAVE EXAM NO S-1, 10:30 TO 1:30 DUE TO CONFIGURATION TEE. NOISE AND STANDING WAVE 360°
			UT	RHEJR-11	84-1204BL	NONE	
			UT	RHEJR-11	84-1223BL	S-1, ID GEO. 90% 3" TO 0" S-2, ID GEO. 85-100% 1" TO 2" CW	
		MT	RHEJR-12	84-1188BL	84-1188BL	NONE	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION TEE. NOISE AND STANDING WAVE 360°
		UT	RHEJR-12	84-1205BL	84-1205BL	NONE	
		UT	RHEJR-12	84-1224BL	84-1224BL	S-1, ID GEO. 60% 360° INT.	

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RHR TW40 (CONT)		MT UT UT	RHEJR-13 RHEJR-13 RHEJR-13	84-1192BL 84-1203BL 84-1229BL	NONE NONE S-2, ID GEO. 65% INT.	NONE L-WAVE EXAM NO S-1 DUE TO CONFIGURATION VALVE
		MT UT UT	RHEJR-14 RHEJR-14 RHEJR-14	84-1190BL 84-1207BL 84-1231BL	NONE NONE S-1, ID GEO. <20% 360° INT.	NONE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION VALVE. STANDING WAVE AND NOISE, 360°
		MT UT UT	RHEJR-15 RHEJR-15 RHEJR-15	84-889BL 84-897BL 84-897BL	NONE NONE S-1, ID OD GEO. 45-80% INT. S-2, ID OD GEO. 50-85% INT.	NONE L-WAVE EXAM NONE
		MT UT UT	RHEJR-16 RHEJR-16 RHEJR-16	84-1173BL 84-1128BL 84-1176BL	NONE NONE S-1, ID OD GEO. 100% 360° INT. S-2, ID GEO. 65-75% 360° INT.	NONE L-WAVE EXAM NOISE AND STANDING WAVE AT 3 DIV.
		MT UT UT	RHEJR-17 RHEJR-17 RHEJR-17	84-887BL 84-895BL 84-895BL	NONE NONE S-2, OD GEO. 65%	NONE L-WAVE EXAM STAMP ON WELD

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 22 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RHR TW40 (CONT)		MT UT UT	RHEJR-18 RHEJR-18 RHEJR-18	84-888BL 84-896BL 84-896BL	NONE NONE S-1, ID GEO. 50-85% INT. S-2, ID OD GEO. 50-90% INT.	NONE L-WAVE EXAM NONE
		MT UT UT	RHEJR-19 RHEJR-19 RHEJR-19	84-1237BL 84-1272BL 84-1244BL	NONE NONE S-2, ID GEO. 60-110% 0" TO 1" C.W.	NONE L-WAVE EXAM NO S-1 DUE TO CONFIGURATION SWEEP-0-LET
		MT UT UT	RHEJR-21 RHEJR-21 RHEJR-21	84-882BL 84-899BL 84-899BL	NONE NONE S-1, ID OD GEO. 55-90% INT. S-2, ID GEO. 3:00 40%	NONE L-WAVE EXAM POOR CONTACT S-1 I.R. OF TEE
		MT UT UT	RHEJR-22 RHEJR-22 RHEJR-22	84-1186BL 84-1202BL 84-1225BL	NONE NONE S-1, ID GEO. 80% 360° INT. S-2, ID GEO. 100% 360° INT.	NONE L-WAVE EXAM NONE
		MT UT UT	RHEJR-23 RHEJR-23 RHEJR-23	84-1157BL 84-1162BL 84-1165BL	NONE NONE S-1, ID GEO. 8:30 100% OD GEO. 3:30 20%	NONE L-WAVE EXAM NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RHR TW40		MT UT UT	RHEJR-24 RHEJR-24 RHEJR-24	84-1181BL 84-1201BL 84-1226BL	NONE NONE S-1, ID GEO. 60-70% 360° INT. S-2, ID GEO. 60-75% 360° INT.	NONE L-WAVE EXAM S-2 LIMITED CONTACT 10:00 TO 2:00 I.R. OF ELBOW
		MT UT UT	RHEJR-25 RHEJR-25 RHEJR-25	84-1187BL 84-1200BL 84-1230BL	NONE NONE S-1, ID GEO. 55-75% 360° INT. S-2, ID GEO. 5:00 TO 6:30 35-45%	NONE L-WAVE EXAM S-1 LIMITED CONTACT 10:00 TO 2:00 I.R. OF ELBOW. NOISE & STANDING WAVE S-3 AND S-4
		MT UT UT	RHEJR-26 RHEJR-26 RHEJR-26	84-1218BL 84-1271BL 84-1240BL	NONE NONE S-1, ID GEO. 1/2" CCW TO 1/2" CW, 50%	NONE L-WAVE EXAM NO S-2 DUE CONFIGURATION VALVE
		MT UT UT	RHEJR-27 RHEJR-27 RHEJR-27	84-1191BL 84-1198BL 84-1241BL	NONE NONE S-2, ID GEO. 3:00 <20%	NONE L-WAVE EXAM NO S-1 DUE TO CONFIGURATION VALVE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT) RHR TW40		MT UT UT	RHEJR-28	84-1185BL	NONE	NONE L-WAVE EXAM NONE	
			RHEJR-28	84-1206BL	NONE		
			RHEJR-28	84-1242BL	S-1, ID GEO. 95-100% 360° INT. S-2, ID GEO. 40-100% 360° INT.		
		MT UT UT	RHEJR-29	RHEJR-29	84-1184BL	NONE	NONE L-WAVE EXAM NONE
				RHEJR-29	84-1197BL	NONE	
				RHEJR-29	84-1243BL	S-1, ID GEO. 50-100% 360° INT. S-2, ID GEO. 9:00 TO 10:00 100%	
		MT UT UT	RHEJR-30	RHEJR-30	84-913BL	NONE	NONE L-WAVE EXAM NONE
				RHEJR-30	84-920BL	NONE	
				RHEJR-30	84-920BL	S-1, ID GEO. 100% 360° INT. OD GEO. 50% 360° INT. S-2, ID OD GEO. 50% 360° INT.	
		MT UT UT	RHEJR-31	RHEJR-31	84-1289BL	NONE	NONE L-WAVE EXAM NONE
				RHEJR-31	84-1312BL	NONE	
				RHEJR-31	84-1314BL	S-1, ID GEO. 10:00 TO 12:00 25% S-2, ID GEO. 70-80% 360° INT.	
		MT UT UT	RHEJR-32	RHEJR-32	84-1189BL	NONE	NONE L-WAVE EXAM NONE
				RHEJR-32	84-1199BL	NONE	
				RHEJR-32	84-1239BL	S-1, ID GEO. 100% 360° INT. S-2, ID GEO. 80% 360° INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RECIRC A	13A	MT	RHEJR-33	84-886BL	NONE	NONE L-WAVE EXAM POOR CONTACT S-1,S-2 DUE TO INNER RADIUS OF ELBOW
		UT	RHEJR-33	84-902BL	NONE	
		UT	RHEJR-33	84-902BL	S-1, ID OD GEO. 40-80% INT. S-2, ID OD GEO. 60-85% INT.	
		MT	RHEJR-34	84-1248BL	NONE	
		UT	RHEJR-34	84-1270BL	NONE	
		UT	RHEJR-34	84-1238BL	S-1, ID GEO. 55-65% 360° INT.	
	13A	PT	RCAFR-2 TO RCAJR-3	84-615BL	NONE	NONE
		UT	RCAFR-2 TO RCAJR-3	84-626BL	S-5, ID GEO. < 20% INT. S-7, ID ROLL < 20% S-8, ID ROLL < 20% S-5S, ID GEO. < 20% S-6S, ID GEO. < 20% S-7S, ID GEO. < 20% S-8S, ID GEO. < 20%	1" NOT EXAMINED EITHER SIDE - TAPERED EDGE OF WELD PREP.
		PT	RCAJR-3	84-1113BL	NONE	NONE L-WAVE EXAM NONE
		UT	RCAJR-3	84-1117BL	NONE	
		UT	RCAJR-3	84-1343BL	S-1, ID GEO. 50% 360° INT. OD GEO. < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT. S-3, ID GEO. 25% LONG. SEAM S-4, OD GEO. 25% LONG. SEAM S-1S, ID OD GEO. < 20% 360° INT. S-3S, ID OD GEO. < 20% 360° INT. S-4S, ID OD GEO. < 20% 360° INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-3 TO RCAJR-4	84-016BL	NONE	NONE
		UT	RCAJR-3 TO RCAJR-4	84-596BL	S-5, ID OD GEO. 0" TO 49" < 20% S-6, ID OD GEO. 0" TO 49" < 20% S-6S, ID OD GEO. 0" TO 49" < 20% INT. S-7S, ID OD GEO. 0" TO 49" < 20% INT.	NONE
	13A	PT	RCAJR-4	84-065BL	NONE	1/8" GRINDING GOUGE MARKS ON WELD. INT. 360° NONE
		UT	RCAJR-4	84-602BL	S-1, ID OD GEO. <20% 360° INT. S-2, OD GEO. < 20% 360° INT.	
	13A	PT	RCAJR-4 TO RCAJR-4A	84-056BL	NONE	NONE
		UT	RCAJR-4 TO RCAJR-4A	84-597BL	NONE	NONE
	13A	PT UT	RCAJR-4A RCAJR-4A	84-060BL 84-601BL	NONE S-1, OD GEO. 40% 360° INT. S-2, ID OD GEO. <20% 360° INT. S-1S, ID OD GEO. 6:00 TO 8:00 <20% INT.	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-4A TO RCAJR-5	84-010BL	1/4" LINEAR	NONE
		PT	RCAJR-4A TO RCAJR-5	84-108BLR	NONE LINEAR BUFFED OUT	NONE
		UT	RCAJR-4A TO RCAJR-5	84-600BL	S-9, ID OD GEO. < 20% 0" TO 33" INT. S-10, ID OD GEO. < 20% 0" TO 33" INT. S-10S, ID OD GEO. < 20% 0" TO 33" INT. S-12S, ID OD GEO. < 20% 0" TO 33" INT.	NONE
	13A	PT	RCAJR-5	84-1030BL	NONE	NONE L-WAVE EXAM NO S-2, S-3S AND S-4S DUE TO CONFIGURATION
		UT	RCAJR-5	84-1031BL	NONE	
		UT	RCAJR-5	84-1441BL	S-1, ID GEO. < 20% INT. S-3, GEO. LONG. SEAM S-4, OD GEO. < 20% LONG. SEAM	
	13A	PT	RCAJR-5 TO RCAJR-7	84-023BL	NONE	MINOR GRINDING GOUGES ALONG WELD
		UT	RCAJR-5 TO RCAJR-7	84-507BL	S-9, ID GEO. < 20% S-10, ID GEO. < 20% S-9S, ID GEO. < 20% S-10S, ID GEO. < 20% S-11S, ID GEO. < 20%	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-7	84-024BL	NONE	NONE MISMATCH BETWEEN PIPE AND TEE. 1/2" GRINDING GOUGE MARKS ON WELD
		UT	RCAJR-7	84-509BL	S-1, ID OD GEO. < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT. S-3, OD GEO. < 20% 360° INT. S-4, ID OD GEO. < 20% 360° INT.	
	13A	PT	RCAJR-7 TO RCAJR-8	84-009BL	1/8" SLUG OF METAL ON WELD.	NONE
		PT	RCAJR-7 TO RCAJR-8	84-156BLR	NONE, SLUG REMOVED	NONE
		UT	RCAJR-7 TO RCAJR-8	84 508BL	S-5, ID OD GEO. < 20% S-6, ID OD GEO < 20% S-5S, ID OD GEO. < 20% S-6S, ID OD GEO. < 20% S-7S, ID OD GEO. < 20% S-8S, ID OD GEO. < 20%	NONE
	13A	PT	RCAJR-8	84-1053BL	NONE	NONE L-WAVE EXAM NONE
		UT	RCAJR-8	84-1059BL	NONE	
		UT	RCAJR-8	84-1442BL	S-1, ID OD GEO. 25% INT. REDIRECTED BEAM FROM ID S-2, ID OD GEO. < 20% INT. REDIRECTED BEAM FROM COUNTER BORE 20-33% INTERMITTENT S-3, GEO. LONG. SEAM < 20% S-4, GEO. LONG. SEAM < 20%	

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

TABLE 9.1
 PAGE 29 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-8 TO RCAJR-9	84-022BL	NONE	GRINDING MARKS ALONG LENGTH OF WELD. SLIGHT DENT IN BASE METAL NONE
		UT	RCAJR-8 TO RCAJR-9	84-537BL	S-5, ID OD GEO. < 20% 0" TO 142" INT. S-6, ID OD GEO. < 20% 0" 142" INT. S-7, ID OD GEO. < 20% 84" TO 130" INT. S-8, ID OD GEO. < 20% 12" TO 115" INT. S-5S, ID OD GEO. < 20% 0" TO 142" INT. S-6S, ID OD GEO. < 20% 0" TO 142" INT. S-7S, ID OD GEO. < 20% 0" TO 142" INT. S-8S, ID OD GEO. < 20% 0" TO 142" INT.	
	13A	PT	RCAJR-9	84-1001BL	NONE	NONE L-WAVE EXAM
		UT	RCAJR-9	84-999BL	NONE	
	13A	UT	RCAJR-9	84-1443BL	S-1, ID OD GEO < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT. S-3, ID OD GEO. 6:00 < 20% LONG. SEAM S-4, ID OD GEO. 6:00 < 20% LONG. SEAM S-2S, ID GEO. 3:00 < 20%	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 30 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-9 TO RCAJR-10	84-018BL	NONE	GRINDING MARKS ALONG LENGTH OF WELD.
		UT	RCAJR-9 TO RCAJR-10	84-512BL	S-6, ID OD GEO. < 20% INT. S-7, ID GEO. < 20% AFTER 84" - PIPE EDGE. S-6S, GEO. PIPE EDGE AFTER 96" S-7S, ID GEO. < 10% CIRC. WELD	NONE
	13A	PT	RCAJR-10	84-020BL	NONE	.06" GRINDING GOUGE AT CIRC. AND LONG SEAM INTERSECTION
		UT	RCAJR-10	84-511BL	S-1, ID OD GEO. < 20% INT. OD GEO. DUE TO BEAM REDIRECTION S-2, ID OD GEO. < 20% INT.	NONE
	13A	PT	RCAJR-10 TO RCAJR-11	84-019BL	NONE	1/8" & 1/8" GOUGE MARK. GRINDING MARKS ALONG WELD
		UT	RCAJR-10 TO RCAJR-11	84-510BL	S-9, ID GEO. < 10% S-10, SPOT AT 33 3/8" < 10% S-11, GEO. FROM PIPE EDGE AFTER 72" S-12, GEO. FROM CIRC. WELD AFTER 12" S-11S, GEO. FROM PIPE EDGE AFTER 84"	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 31 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-11	84-873BL	NONE	NONE L-WAVE EXAM NO S-2,S-3S AND S-4S DUE TO CONFIGURATION VALVE
		UT	RCAJR-11	84-876BL	NONE	
		UT	RCAJR-11	84-1452BL	S-1,ID OD GEO. 20-40%INT. OD REDIRECTED FROM ID, COUNTER BORE S-3,OD GEO.< 20% STAMP MARK S-4,ID GEO.< 20% LONG. SEAM	
	13A	PT	RCAJR-12	84-857BL	NONE	NONE L-WAVE EXAM NO S-1,S-1S, & S-2S DUE TO CONFIGURATION VALVE
		UT	RCAJR-12	84-877BL	NONE	
		UT	RCAJR-12	84-1444BL	S-2,ID GEO. 30% 360°INT. OD GEO.< 20% 360°INT. S-3,ID OD GEO. 9:00 <20% LONG. SEAM S-4,OD GEO. 9:00 <20% LONG.SEAM S-3S,ID GEO. 9:00.<20% LONG.SEAM	
13A	PT	RCAJR-12 TO RCAJR-15	84-064BL	NONE	NONE	
	UT	RCAJR-12 TO RCAJR-15	84-469BL	S-5,ID OD GEO. 20% INT. S-6,ID OD GEO. 20% INT.	NONE	
JFS073085WMH04-LT						

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT UT	RCAJR-15 RCAJR-15	84-048BL 84-470BL	NONE S-1, ID OD GEO. <20% 360° INT. S-2, ID OD GEO. <20% 360° INT.	NONE NONE
	13A	PT	RCAJR-15 TO RCAJR-16 I.R.	84-002BL	ONE LINEAR	MINOR GRINDING MARKS ALONG WELD
	13A	PT	RCAJR-15 TO RCAJR-16 I.R.	84-111BLR	NONE LINEAR REMOVED	NONE
	13A	PT	RCAJR-15 TO RCAJR-16 O.R.	84-003BL	FIVE LINEARS	NONE
		PT	RCAJR-15 TO RCAJR-16 O.R.	84-143R1	TWO LINEARS, THREE BUFFED OUT	NONE
		PT	RCAJR-15 TO RCAJR-16 O.R.	84-144R2	NONE, LINEARS BUFFED OUT	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12(CONT)	13A	UT	RCAJR-15 TO RCAJR-16 I.R.	84-466BL	S-5, ID OD GEO. < 20% S-6, ID OD GEO. < 20% INT.	LIMITED CONTACT SCANS 7 & 8 DUE TO INNER RADIUS OF ELBOW
		UT	RCAJR-15 TO RCAJR-16 O.R.	84-468BL	NONE	NONE
	13A	PT	RCAJR-16	84-851BL	NONE	NONE L-WAVE EXAM NO S-2, S-3S OR S-4S DUE TO CONFIGURATION PUMP
		UT	RCAJR-16	84-966BL	NONE	
		UT	RCAJR-16	84-1445BL	S-1, ID OD GEO. < 20% 360° INT. S-3, ID OD GEO. 3:00 AND 12:00 20% LONG. SEAMS S-4, ID OD GEO. 3:00 AND 12:00 20% LONG. SEAMS	
	13A	PT	RCAJR-17	84-856BL	ARC STRIKE, MULTIPLE LINEAR 1/4" x 3/16" DIA. AT 19 1/2" CCW	NONE
		PT	RCAJR-17	84-856BLR	NONE ARC STRIKE, MULTIPLE LINEAR INDICATION REMOVED	NONE
		UT	RCAJR-17	84-907BL	NONE	L-WAVE EXAM
		UT	RCAJR-17	84-1446BL	S-2, ID OD GEO. 9:00 TO 12:00 < 20% INT. S-3S, OD GEO. 3:00 < 20% LONG. SEAM	NO S-1, S-1S OR S-2S DUE TO CONFIGURATION PUMP

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-17 TO RCAJR-20	84-042BL	NONE	NONE
		UT	RCAJR-17 TO RCAJR-20	84-467BL	S-5, ID OD GEO. < 20% INT. S-6, ID OD GEO. < 20% INT. S-7S, ID GEO. < 20%	ROUGH ID SURFACE
	13A	PT	RCAJR-20	84-801BL	NONE	NONE L-WAVE EXAM NO S-2, S-3S OR S-4S DUE TO CONFIGURATION VALVE
		UT	RCAJR-20	84-1172BL	NONE	
		UT	RCAJR-20	84-1447BL	S-1, ID GEO. < 20% 360° INT. S-4, ID GEO. 5:00 < 20%	
	13A	PT	RCAJR-21	84-1236BL	NONE	NONE L-WAVE EXAM OD REDIRECTED FROM ID-COUNTER BORE NO S-1, S-1S, S-2S, DUE TO CONFIGURATION VALVE
		UT	RCAJR-21	84-1247BL	NONE	
		UT	RCAJR-21	84-1453BL	S-2, ID OD GEO. 20-30% INT. S-3, ID GEO. 6:00, 50% LONG. SEAM S-4, ID GEO. 6:00 25% LONG. SEAM S-4S, GEO. < 20% LONG. SEAM	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 912 (CONT)	13A	PT	RCAJR-21 TO RCAJR-22	84-027BL	NONE	NONE
		UT	RCAJR-21 TO RCAJR-22	84-593BL	S-5, ID OD GEO. 20% S-7, ID GEO. FROM CIRC. WELD S-8, GEO. AFTER 74" - PIPE EDGE S-6S, OD GEO. 20% S-7S, OD GEO 20% S-8S, OD GEO. 20%	NONE
	13A	PT	RCAJR-22	84-026BL	NONE	MINOR GRINDING MARKS 360° NONE
		UT	RCAJR-22	84-595BL	S-1, ID OD GEO. 20% INT. S-2, ID OD GEO. 30% INT. S-3, ID GEO. LONG. SEAM S-4, OD GEO. LONG. SEAM S-2S, ID ROLL 20%	
	13A	PT	RCAJR-22 TO RCAJR-23	84-028BL	NONE	MINOR GRINDING MARKS ALONG LONG. SEAM.
	13A	UT	RCAJR-22 TO RCAJR-23	84-592BL	S-9, ID OD GEO. 20% INT. S-10, ID OD GEO. 20% INT. S-11, GEO. AFTER 84" PIPE EDGE S-12, ID OD GEO. CIRC. WELD S-9S, ID OD GEO. 20% S-10S, ID GEO. 20%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT UT UT	RCAJR-23 RCAJR-23 RCAJR-23	84-1156BL 84-1159BL 84-1448BL	NONE NONE S-1, ID OD GEO. <20% 360° INT. S-2, ID GEO. 35% 360° INT. OD GEO. < 20% 360° INT. S-3, ID OD GEO. 3:00 AND 12:00 <20% LONG. SEAMS S-4, ID OD GEO. 3:00 AND 12:00 <20% LONG. SEAMS	NONE L-WAVE EXAM NONE
	13A	PT	RCAJR-23 TO RCAJR-24	84-158BL	NONE	MINOR GRINDING MARKS ALONG LENGTH OF WELD
	13A	UT	RCAJR-23 TO RCAJR-24	84-503BL	S-5, ID OD GEO. < 20% S-6, ID OD GEO. < 20% S-7, ID OD GEO. AT 13.5" 40% S-8, ID OD GEO. < 20% S-5S, ID OD GEO. < 20% S-6S, ID OD GEO. < 20% S-7S, ID OD GEO. < 20% S-8S, ID OD GEO. < 20%	NONE
	13A	PT UT UT	RCAJR-24 RCAJR-24 RCAJR-24	84-1155BL 84-1158BL 84-1449BL	NONE NONE S-1, ID OD GEO <20% 360° INT.	NONE L-WAVE EXAM NO S-2, 3S OR 4S DUE TO CONFIGURATION TEE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13A	PT	RCAJR-24 TO RCAJR-25	84-078BL	ONE LINEAR	NONE
		PT	RCAJR-24 TO RCAJR-25	84-113BLR	NONE LINEAR BUFFED OUT	NONE
	13A	UT	RCAJR-24 TO RCAJR-25	84-504BL	S-7,GEO.INT. FROM PIPE EDGE AFTER 24" S-8,GEO. INT. FROM PIPE EDGE AFTER 24"	NONE
	13A	PT	RCAJR-25	84-836BL	NONE	NONE 1/2 NODE EXAM
		UT	RCAJR-25	84-1439BL	S-2,ID GEO. 40% 360° INT.	
	RECIRC B	13B	PT	RCBFR-2 TO RCBJR-3	84-616BL	NONE
UT			RCBFR-2 TO RCBJR-3	84-627BL	S-5,ID GEO. < 20% INT. S-6,ID GEO. < 20% INT. S-7,ID ROLL < 20% S-8,ID ROLL < 20% S-5S,ID GEO < 20% S-6S,ID GEO < 20% S-7S,ID GEO. < 20% S-8S,ID GEO.<20%	1" ON EITHER SIDE, NOT EXAMINED DUE TO TAPERED EDGE OF WELD PREP.

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-3	84-908BL	NONE	NONE L-WAVE EXAM NONE
		UT	RCBJR-3	84-906BL	NONE	
		UT	RCBJR-3	84-1457BL	S-1, ID GEO. 25-30% 360° INT. OD GEO. < 20% 360° INT. S-2, ID GEO. 30% 360° INT. OD GEO. < 20% 360° INT.	
	13B	PT	RCBJR-3 TO RCBJR-4	84-004BL	TWO LINEARS	NONE
		PT	RCBJR-3 TO RCBJR-4	84-147BLR	NONE, LINEARS BUFFED OUT	NONE
		UT	RCBJR-3 TO RCBJR-4	84-499BL	S-9, ID OD GEO. < 20% S-10, ID OD GEO. < 20%	NONE
	13B	PT	RCBJR-4	84-057BL	TWO LINEARS	NONE NONE MINOR MISMATCH
		PT	RCBJR-4	84-152BL	NONE, LINEARS BUFFED OUT	
		UT	RCBJR-4	84-501BL	S-1, ID OD GEO. < 20% S-2, ID OD GEO. < 20% S-3S, ID OD GEO. < 20% S-4S, ID OD GEO. < 20%	
	13B	PT	RCBJR-4 TO RCBJR-5	84-058BL	NONE	PUNCH MARKS ON WELD
		UT	RCBJR-4 TO RCBJR-5	84-500BL	S-6, ID OD GEO. < 20%	NONE
	13B	PT	RCBJR-5	84-1017BL	NONE	NONE L-WAVE EXAM
UT		RCBJR-5	84-1018BL	NONE		

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

TABLE 9.1
 PAGE 39 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	UT	RCBJR-5	84-1458BL	S-1, ID GEO. 30-35% 360° INT. OD GEO. < 20% 360° INT. S-2, ID GEO. 12:00 TO 3:00 < 20% S-3, OD GEO. 6:00 < 20% LONG. SEAM	NONE
	13B	PT	RCBJR-5 TO RCBJR-6	84-030BL	NONE	NONE
		UT	RCBJR-5 TO RCBJR-6	84-531BL	S-5, ID OD GEO. < 20% INT. S-6, ID OD GEO. < 20% INT. S-7, INT. GEO. AFTER 132", PIPE EDGE S-8, INT. ID OD GEO < 10% AFTER 12"-PIPE EDGE S-6S, PIPE EDGE GEO. AFTER 12"	NONE
	13B	PT	RCBJR-6	84-1167BL	NONE	NONE
		UT	RCBJR-6	84-1168BL	NONE	L-WAVE EXAM
		UT	RCBJR-6	84-1459BL	S-1, ID OD GEO. 360° INT. S-2, ID OD GEO. < 20% 360° INT.	NONE
	13B	PT	RCBJR-6 TO RCBJR-7	84-080BL	NONE	NONE
		UT	RCBJR-6 TO	84-532BL	S-5, ID OD GEO < 20% INT. S-6, ID OD GEO. < 20% INT.	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT UT UT	RCBJR-7		S-7, PIPE EDGE GEO. AFTER 132" S-8, PIPE EDGE GEO. AFTER 12" S-5S, ID GEO. < 20% S-7S, ID OD GEO. < 20% INT. S-8S, ID OD GEO. < 20% INT.	
			RCBJR-7	84-1022BL	NONE	
			RCBJR-7	84-1020BL	NONE	
			RCBJR-7	84-1460BL	S-1, ID GEO. 20% 360° INT. OD GEO. < 20% 360° INT. S-2, ID GEO. < 20% 360° INT. S-4, OD GEO. 6:00 < 20% LONG. SEAM	NONE L-WAVE EXAM NONE
	13B	PT PT UT	RCBJR-7 TO RCBJR-8	84-008BL	ONE LINEAR	GRINDING MARKS ALONG WELD
			RCBJR-7 TO RCBJR-8	84-214BLR	NONE, LINEAR BUFFED OUT	NONE
			RCBJR-7 TO RCBJR-8	84-594BL	S-5, OD GEO. < 20% INT. S-6, OD GEO. < 20% INT. S-7, ID GEO. FROM CIRC. WELD AFTER 12" S-8, PIPE EDGE GEO. AFTER 84" S-7S, CIRC. WELD GEO. AND OD GEO. < 20% S-8S, ID GEO. < 20%	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT UT	RCBJR-8	84-072BL	NONE S-1, OD GEO. < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT.	NONE MINOR MISMATCH
			RCBJR-8	84-552BL		
	13B	PT	RCBJR-8 TO RCBJR-9	84-762BL	TWO LINEARS	NONE
			RCBJR-8 TO RCBJR-9	84-797BL	NONE LINEARS BUFFED OUT	NONE
			RCBJR-8 TO RCBJR-9	84-551BL	S-9, ID GEO. 0" TO 86" < 20% INT. S-9S, ID OD GEO. 34" TO 64" < 20% INT.	NONE
	13B	PT UT UT	RCBJR-9	84-1286BL	NONE NONE S-1, ID OD GEO. 20-43% INT. S-3, SPOT 25% 15.6" CCW FROM 12:00 LONG. SEAM GEO. < 20% INT. S-4, SPOT < 20% 3.5" TO 4.5" CCW AND 13.5" CCW FROM 12:00 S-1S, ID GEO. < 20% S-2S, ID OD GEO. < 20%	NONE L-WAVE EXAM NO S-2, S-3S, AND S-4S, DUE TO CONFIGURATION VALVE. OD ON S-1 DUE TO BEAM REDIRECT FROM ID AND COUNTER BORE
			RCBJR-9	84-1287BL		
			RCBJR-9	84-1455BL		

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

TABLE 9.1
 PAGE 42 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT.)	13B	PT	RCBJR-10	84-969BL	INTERMITTENT LINEARS 360° VALVE SIDE, TOE OF WELD	NONE
		PT	RCBJR-10	84-977BLR	NONE-LINEARS BUFFED OUT	NONE
		UT	RCBJR-10	84-978BL	NONE	L-WAVE EXAM
		UT	RCBJR-10	84-1464BL	NONE	NO S-1,S-1S, OR S-2S DUE TO CONFIGURATION VALVE
	13B	PT	RCBJR-10 TO RCBJR-13	84-049BL	NONE	NONE
		UT	RCBJR-10 TO RCBJR-13	84-536BL	S-9, ID OD GEO. < 20% 0" TO 20" INT. S-10, ID OD GEO. < 20% 0" TO 35" INT. S-9S, ID OD GEO. < 20% 0" TO 35" INT. S-10S, ID OD GEO. < 20% 0" TO 35" INT. S-11S, ID OD GEO. < 20% 0" TO 35" INT. S-12S, ID OD GEO. < 20% 0" TO 35" INT.	NONE
	13B	PT	RCBJR-13	84-011BL	3 LINEARS	NONE
		PT	RCBJR-13	84-114BLR	NONE-LINEARS BUFFED OUT	NONE
		UT	RCBJR-13	84-534BL	S-1, ID OD GEO. < 20% 360° INT. S-2, ID OD GEO. < 20% 360° INT. S-1S, ID OD GEO. < 20% 360° INT. S-2S, ID OD GEO. < 20% 360° INT. S-3S, ID OD GEO. < 20% 360° INT.	MINOR MISMATCH

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-13 TO RCBJR-14	84-052BL	NONE	NONE O.R. ELBOW
		PT	RCBJR-13 TO RCBJR-14	84-063BL	NONE	NONE I.R. ELBOW
		UT	RCBJR-13 TO RCBJR-14	84-533BL	S-5, ID OD GEO. 15" TO 19" INT. < 20% S-8S, ID GEO. 21" TO 41" INT. < 20%	NONE O.R. ELBOW
		UT	RCBJR-13 TO RCBJR-14	84-535BL	S-5, ID OD GEO. 0" TO 22" INT. < 20% S-6, ID OD GEO. 0" TO 32" INT. < 20%	NONE I.R. ELBOW
	13B	PT	RCBJR-14	84-855BL	ONE LINEAR	NONE
		PT	RCBJR-14	84-855BLR	NONE-LINEARS BUFFED OUT	NONE
		UT	RCBJR-14	84-965BL	NONE	L-WAVE EXAM
		UT	RCBJR-14	84-1461BL	S-1, ID GEO. 40% 360° INT. OD GEO. < 20% 360° INT.	NO S-2, S-3S, OR S-4S DUE TO CONFIGURATION PUMP
	13B	PT	RCBJR-15	84-938BL	NONE	NONE
		UT	RCBJR-15	84-939BL	NONE	L-WAVE EXAM
UT		RCBJR-15	84-1462BL	S-2, OD GEO. < 20% 360° INT.	NO S-1, S-1S OR S-2S DUE TO CONFIGURATION PUMP	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-15 TO RCBJR-18	84-007BL	ONE LINEAR	NONE	
		PT	RCBJR-15 TO RCBJR-18	84-110BLR	NONE-LINEAR BUFFED OUT	NONE	
		UT	RCBJR-15 TO RCBJR-18	84-506BL	S-5, ID OD GEO. < 20% S-6, ID OD GEO. < 20% S-5S, ID OD GEO. < 20% S-6S, ID OD GEO. < 20% S-7S, ID OD GEO. < 20% S-8S, ID OD GEO. < 20%	NONE	
	13B	PT	RCBJR-18	84-850BL	NONE	S-1, ID GEO. < 20% 360° INT.	NONE
		UT	RCBJR-18	84-1171BL	NONE		L-WAVE EXAM
		UT	RCBJR-18	84-1463BL			NO S-2, S-3S, OR S-4S DUE TO CONFIGURATION VALVE
	13B	PT	RCBJR-19	84-1213BL	NONE	S-2, ID OD GEO. 23-65% INT. OD GEO. DUE TO REDIRECTED BEAM FROM ID & COUNTER BORE S-3, LONG. SEAM GEO. < 20% INT. S-4, LONG. SEAM GEO. 6:00 20-40% INT. S-3S, ID GEO. < 20% S-4S, ID ROLL < 20%	NONE L-WAVE EXAM NO S-1, S-1S, OR S-2S DUE TO CONFIGURATION VALVE
		UT	RCBJR-19	84-1246BL	NONE		
		UT	RCBJR-19	84-1454BL			

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-19 TO RCBJR-20	84-032BL	NONE	NONE
		UT	RCBJR-19 TO RCBJR-20	84-554BL	S-6S, ID GEO. 55" TO 65" < 20% INT. S-7S, ID GEO. 0" TO 89" < 20% INT. S-8S, ID GEO. 24" TO 30" < 20% INT.	NO SCAN FROM 30" TO 52" DUE TO PIPE SUPPORT WELDED ON ELBOW
	13B	PT	RCBJR-20	84-006BL	ONE LINEAR	NONE
		PT	RCBJR-20	84-151BLR	NONE-LINEAR BUFFED OUT	NONE
		UT	RCBJR-20	84-555BL	S-1, OD GEO. 20-50% 360° INT. S-2, ID OD GEO. <20% 360° INT.	MINOR MISMATCH
	13B	PT	RCBJR-20 TO RCBJR-21	84-033BL	NONE	MINOR GRINDING MARKS ALONG LENGTH OF WELD
		UT	RCBJR-20 TO RCBJR-21	84-553BL	S-9, ID OD GEO. 0" TO 100" < 20% INT. S-10, ID OD GEO. 0" TO 100" < 20% INT. S-10S, ID OD GEO. 60" TO 96" < 20% INT. S-11S, ID OD GEO. 20" TO 78" < 20% INT. S-12S, ID OD GEO. 70" TO 0" < 20% INT.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-21	84-1212BL	NONE	NONE L-WAVE EXAM NONE
		UT	RCBJR-21	84-1245BL	NONE	
		UT	RCBJR-21	84-1465BL	S-1, ID GEO. 25% 360° INT. OD GEO. < 20% 360° INT. S-2, ID GEO. AND REDIRECTED BEAM 35-40%, 360° INT. OD GEO. < 20% 360° INT.	
	13B	PT	RCBJR-21 TO RCBJR-22	84-207BL	CRATER CRACK	NONE
		PT	RCBJR-21 TO RCBJR-22	84-701BL	NONE - CRATER CRACK BUFFED OUT	NONE
		UT	RCBJR-21 TO RCBJR-22	84-502BL	S-5, ID OD GEO. < 20% S-6, ID OD GEO. < 20% S-7, ID OD GEO. < 20% S-8, ID OD GEO. < 20% S-5S, ID OD GEO. < 20% S-6S, ID OD GEO. < 20% S-7S, ID OD GEO. < 20% S-8S, ID OD GEO. < 20%	NONE
	13B	PT	RCBJR-22	84-1087BL	NONE	NONE L-WAVE EXAM NO S-2, S-3S, OR S-4S, DUE TO CONFIGURATION TEE
		UT	RCBJR-22	84-1099BL	NONE	
		UT	RCBJR-22	84-1466BL	S-1, ID OD GEO. < 20% 360° INT. S-3, OD GEO 3:00 < 20% S-4, ID OD GEO. 6:00 < 20% LONG. SEAM	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13B	PT	RCBJR-22 TO RCBJR-23	84-145BL	NONE	NONE
		UT	RCBJR-22 TO RCBJR-23	84-505BL	S-5, ID OD GEO. < 20% TAPERED EDGE S-7, PIPE EDGE GEO. AFTER 36" INT. S-8, PIPE EDGE GEO. AFTER 12" INT.	NONE
	13B	PT	RCBJR-23	84-793BL	NONE	NONE L-WAVE EXAM 1/2 NODE EXAM
		UT	RCBJR-23	84-921BL	NONE	
		UT	RCBJR-23	84-1440BL	S-1, ID GEO. 50% 360° INT. S-2, ID GEO. 50% 360° INT.	
	RECIRC. "A"	13C	PT	RMAJR-1 TO RRFJR-7	84-315BL	NONE
PT			RMAJR-1 TO RRFJR-7	84-316BL	NONE	NONE TWO LONG. SEAMS
UT			RMAJR-1 TO RRFJR-7	84-366BL	NONE	NONE
UT			RMAJR-1 TO RRFJR-7	84-369BL	NONE	NONE TWO LONG. SEAMS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RECIRC."A"	13C	PT UT	RMAJR-1 RMAJR-1	84-307BL 84-362BL	NONE S-1,OD GEO. 20% 360° INT. S-2, ID OD GEO.25% 360°INT.	NONE S-2 LIMITED TO 2½" SCAN PATH DUE TO CONFIG. REDUCER. MINOR OD MISMATCH
	13C	PT	RMAJR-1 TO RMAJR-2	84-319BL	NONE	STAMP ON WELD
		UT	RMAJR-1 TO RMAJR-2	84-370BL	NONE	NONE
	13C	PT UT	RMAJR-2 RMAJR-2	84-306BL 84-359BL	NONE S-1, ID OD GEO. 9:00 TO 12:00 10% INT.	NONE NONE
	13C	PT	RMAJR-2 TO RMAJR-3	84-318BL	NONE	NONE
		UT	RMAJR-2 TO RMAJR-3	84-867BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13C	PT UT UT	RMAJR-3 RMAJR-3 RMAJR-3	84-909BL 84-904BL 84-142BL	NONE NONE S-2, ID OD GEO. <20% 360° IN S-3, OD GEO. 9:00 <20% S-4S, ID OD GEO. <20% 360° I	NONE L-WAVE EXAM NO S-1, S-1S OR S-2S DUE TO CONFIGURATION OF CROSS
	13C	PT UT	RMAJR-3 TO RMAJR-3A RMAJR-3 TO RMAJR-3A	84-067BL 84-461BL	NONE S-1, OD GEO. < 20% ID, REDIRECTED BEAM	NONE S-1, B.E. S-2 LIMITED TO 1 NODE
	13C	PT UT	RMAJR-3A RMAJR-3A	84-066BL 84-461BL	NONE S-1, OD GEO. < 20% ID, REDIRECTED BEAM	NONE S-1, B.E. S-2 LIMITED TO 1 NODE DUE TO CONFIGURATION
	13C	PT UT	RMAJR-4 RMAJR-4	84-092BL 84-400BL	NONE S-2, ID OD GEO. 8-30% OD DUE TO BEAM REDIRECTED FROM FROM COUNTER BORE	NONE NO S-1, S-1S OR S-2S DUE TO CONFIGURATION REDUCER
	13C	PT UT UT	RMAJR-5 RMAJR-5 RMAJR-5	84-1071BL 84-1091BL 84-1428BL	NONE NONE S-2, ID OD GEO. <20% 360° INT. S-3, ID OD GEO. <20% 360° INT. S-4, ID OD GEO. <20% 360° INT. S-3S, ID GEO. <20% 360° INT.	NONE L-WAVE EXAM NO S-1, S-1S OR S-2S DUE TO CONFIGURATION OF CROSS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13C	PT	RMAJR-5 TO RMAJR-5A	84-069BL	S-4S, ID GEO. <20% 360° INT. NONE	NONE
		UT	RMAJR-5 TO RMAJR-5A	84-453BL	S-1, OD GEO. < 20% 360° INT.	S-1 BE S-2 LIMITED TO 1 NODE DUE TO CONFIGURATION
	13C	PT	RMAJR-5A RMAJR-5A	84-068BL	NONE	NONE S-1 BE S-2 LIMITED TO 1 NODE DUE TO CONFIGURATION
		UT		84-453BL	S-1, OD GEO. <20% 360° INT.	
	13C	PT	RMAJR-5 TO RMAJR-6	84-342BL	NONE	NONE
		UT	RMAJR-5 TO RMAJR-6	84-383BL	S-5, OD GEO. 10% 360° INT. S-6, OD GEO. 10% 360° INT.	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13C	PT	RMAJR-6	84-341BL	NONE	NONE NONE
		UT	RMAJR-6	84-379BL	NONE	
	13C	PT	RMAJR-6 TO RMAJR-7	84-340BL	NONE	NONE
		UT	RMAJR-6 TO RMAJR-7	84-368BL	S-5,OD GEO. 0" TO 33" 10% INT.	NONE
	13C	PT	RMAJR-7	84-336BL	NONE	NONE
		UT	RMAJR-7	84-380BL	S-1,OD GEO. 20% 360° INT. S-2,ID OD GEO. 10-15% 360° INT.	
	13C	PT	RMAJR-7 TO RRKJR-7	84-334BL	NONE	NONE
		PT	RMAJR-7 TO RRKJR-7	84-335BL	NONE	NONE REDUCER HAS TWO LONG. SEAMS
13C	UT	RMAJR-7 TO RRKJR-7	84-381BL	NONE	NONE O.R.	
	UT	RMAJR-7 TO RRKJR-7	84-382BL	S-5,SPOT AT 16" 10% S-6,SPOT AT 16" 10%	NONE I.R.	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13C	PT	RCAJR-25 TO RMAJR-4	84-087BL	NONE	NONE
		UT	RCAJR-25 TO RMAJR-4	84-399BL	S-5, ID GEO. 10% S-6, ID OD GEO. 5-20% 3.5" FROM REDUCER S-7, ID CIRC WELD 40-50% S-8, CROSS EDGE GEO. 40-45%	NONE
	13C	PT	RMAJR-4 TO RRHJR-4	84-084BL	NONE	NONE
		PT	RMAJR-4 TO RRHJR-4	84-088BL	NONE	NONE TWO LONG. SEAMS
	13C	UT	RMAJR-4 TO RRHJR-4	84-451BL	S-8, COUNTER BORE GEO. <20%	NONE
		UT	RMAJR-4 TO RRHJR-4	84-452BL	S-8, COUNTER BORE GEO. <20%	NONE TWO LONG. SEAMS
RECIRC"B"	13D	PT	RMBJR-1 TO RREJR-7	84-279BL	NONE	NONE
		PT	RMBJR-1 TO RREJR-7	84-280BL	NONE	NONE REDUCER HAS TWO LONG SEAMS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RECIRC."B"	13D	UT	RMBJR-1 TO RREJR-7	84-387BL	NONE	NONE
		UT	RMBJR-1 TO RREJR-7	84-388BL	NONE	NONE REDUCER HAS TWO LONG SEAMS
	13D	PT	RMBJR-1	84-271BL	NONE	MINOR GRINDING MARKS NONE
		UT	RMBJR-1	84-386BL	NONE	
	13D	PT	RMBJR-1 TO RMBJR-2	84-277BL	NONE	NONE
		UT	RMBJR-1 TO RMBJR-2	84-385BL	S-5, ID GEO 0" TO 33" 10% INT.	NONE
	13D	PT UT	RMBJR-2 RMBJR-2	84-272BL 84-384BL	NONE S-1, ID OD GEO. 15-20% 360° INT.	NONE NONE
	13D	PT	RMBJR-2 TO RMBJR-3	84-284BL	NONE	MINOR GRINDING MARKS ON WELD
		UT	RMBJR-2 TO RMBJR-3	84-389BL	S-5, OD GEO. 0" TO 58" 10% S-6, ID GEO. 0" TO 58" 12%	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13D	PT UT UT	RMBJR-3 RMBJR-3 RMBJR-3	84-854BL 84-916BL 84-1426BL	NONE NONE S-2, ID GEO. 30% 360° INT. OD GEO. < 20% 360° INT. S-3, ID GEO. 12:00 < 20% LONG. SEAM S-4, ID GEO. 12:00 < 20% LONG. SEAM S-3S, OD GEO. < 20% 360° INT. S-4S, ID GEO. < 20% 360° INT.	NONE L-WAVE EXAM NO S-1, S-1S OR S-2S DUE TO CONFIGURATION OF CROSS
	13D	PT	RMBJR-3 TO RMBJR-3A	84-075BL	NONE	ID STAMP ON WELD
		UT	RMBJR-3 TO RMBJR-3A	84-462BL	NONE	NONE
	13D	PT UT	RMBJR-3A RMBJR-3A	84-074BL 84-462BL	NONE S-1, OD GEO. < 20% 360° INT.	NONE S-1, B.E. S-2 LIMITED TO ONE NODE EXAM DUE TO CONFIGURATION
	13D	PT UT	RMBJR-4 RMBJR-4	84-093BL 84-459BL	NONE S-2, ID GEO. COUNTER BORE 30% 360° INT.	NONE S-1 LIMITED DUE TO OD MISMATCH

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13D	PT	RMBJR-5	84-853BL	NONE	NONE L-WAVE EXAM NO S-1,S-1S OR S-2S DUE TO CONFIGURATION CROSS
		UT	RMBJR-5	84-905BL	NONE	
		UT	RMBJR-5	84-1427BL	S-2, ID OD GEO. <20% 360° INT. S-3, ID OD GEO. <20% 360° INT.	
	13D	PT	RMBJR-5 TO RMBJR-5A	84-076	BL	NONE
		UT	RMBJR-5 TO RMBJR-5A	84-464BL	NONE	NONE
	13D	PT	RMBJR-5A	84-077BL	NONE	NONE S-1 B.E. S-2 LIMITED TO ONE NODE EXAM DUE TO CONFIGURATION
		UT	RMBJR-5A	84-464BL	S-1, OD GEO. 20% 360° INT.	
	13D	PT	RMBJR-5 TO RMBJR-6	84-305BL	NONE	NONE
UT		RMBJR-5 TO RMBJR-6	84-363BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)	13D	PT	RMBJR-6	84-291BL	NONE	NONE NONE
		UT	RMBJR-6	84-361BL	S-1, ID GEO. 20% 360° INT. OD GEO. 10% 360° INT.	
	13D	PT	RMBJR-6 TO RMBJR-7	84-304BL	NONE	NONE
		UT	RMBJR-6 TO RMBJR-7	84-364BL	S-5, ID GEO. 30% 360° INT. S-6, ID GEO. 15% 360° INT.	NONE
	13D	PT	RMBJR-7	84-292BL	NONE	NONE S-2 LIMITED DUE TO CONFIGURATION MINOR OD MISMATCH
		UT	RMBJR-7	84-360BL	S-1, OD GEO. 8:00 TO 9:00 INT. 25%	
	13D	PT	RMBJR-7 TO RRAJR-7	84-301BL	NONE	NONE
		PT	RMBJR-7 TO RRAJR-7	84-302BL	NONE	NONE
	13D	UT	RMBJR-7 TO RRAJR-7	84-365BL	NONE	NONE
UT		RMBJR-7 TO RRAJR-7	84-371BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT)	13D	PT	RCBJR-23 TO RMBJR-4	84-070BL	NONE	NONE	
		UT	RCBJR-23 TO RMBJR-4	84-460BL	S-5,OD GEO.<20% INT.	NONE	
	13D	PT	RMBJR-4 TO RRCJR-4	84-085BL	NONE	NONE	
		PT	RMBJR-4 TO RRCJR-4	84-086BL	NONE	NONE	
		UT	RMBJR-4 TO RRCJR-4	84-463BL	S-6, ID GEO. < 20%	NONE	
		UT	RMBJR-4 TO RRCJR-4	84-465BL	S-5, ID GEO. < 20% S-6, ID GEO. < 20%	NONE	
	RECIRC. RISERS RISER F	13C	PT	RRFJR-3	84-1075BL	NONE	NONE L-WAVE EXAM LIMITED S-2 DUE TO TAPER ON S.E.
			UT	RRFJR-3	84-1096BL	NONE	
			UT	RRFJR-3	84-1415BL	S-1, ID GEO. 20% INT. OD GEO. 25% INT. S-2, ID OD GEO.<20% INT. S-3, OD GEO.<20% S-4, OD GEO. < 20% S-4S, OD GEO.<20%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER F	13C	PT	RRFJR-4	84-1116BL	NONE	NONE L-WAVE EXAM NONE
		UT	RRFJR-4	84-1119BL	NONE	
		UT	RRFJR-4	84-1433BL	S-2, ID GEO. 20% INT.	
	13C	PT	RRFJR-4 TO RRFJR-5	84-312BL	NONE	NONE
		UT	RRFJR-4 TO RRFJR-5	84-409BL	NONE	NONE
	13C	PT	RRFJR-5	84-310BL	NONE	NONE NONE
		UT	RRFJR-5	84-408BL	S-1, ID GEO. 5-20% INT. OD GEO. 5-20% REDIRECTED BEAM FROM ID S-1S, ID OD GEO. 5-10% INT. S-2S, ID OD GEO. 5-10% INT. S-3S, ID OD GEO. 10% INT. S-4S, ID GEO. 10%	
	13C	PT	RRFJR-5 TO RRFJR-6	84-313BL	NONE	NONE
		UT	RRFJR-5 TO RRFJR-6	84-407BL	S-7, OD GEO. 10% S-8, OD GEO. 10% INT. S-5S, OD GEO. 10% S-6S, OD GEO. 10%	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 59 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER F	13C	PT UT	RRFJR-6 RRFJR-6	84-309BL 84-404BL	NONE S-1, ID OD GEO. 5-25% INT. S-2, ID GEO. 8-20% INT. OD GEO. 8-20% INT. BEAM FROM ID S-4, ID OD GEO. 10% S-1S, ID OD GEO. 10% S-2S, ID GEO. 8-15% S-3S, ID OD GEO. 10% S-4S, OD GEO. 10%	NONE NONE
	13C	PT	RRFJR-6 TO RRFJR-7	84-314BL	NONE	NONE
		UT	RRFJR-6 TO RRFJR-7	84-406BL	S-5, ID OD GEO. 8-15% INT. S-6, ID OD GEO. 8-15% INT. S-7, ID GEO. 10% CIRC WELD S-8, ID OD GEO. 10-20% CIRC WELD	NONE
	13C	PT UT	RRFJR-7 RRFJR-7	84-308BL 84-405BL	NONE S-1, ID GEO. 5-10% INT. OD GEO. 5-10% REDIRECTED BEAM FROM ID COUNTER BORE S-2, ID GEO. 10-50% INT. OD GEO. 10-50% REDIRECTED BEAM FROM ID COUNTER BORE S-4, OD GEO. 10% LONG. SEAM S-1S, ID OD GEO. 10% S-2S, ID GEO. 10% S-3S, ID OD GEO. 10% S-4S, OD GEO. 10%	NONE S-1 BE DUE TO CONFIGURATION REDUCER

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

TABLE 9.1
 PAGE 60 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER G	13C	PT	RRGJR-3	84-1070BL	NONE	NONE L-WAVE EXAM LIMITED S-2 DUE TO TAPER ON S.E.
		UT	RRGJR-3	84-1082BL	NONE	
		UT	RRGJR-3	84-1416BL	S-1, ID OD GEO. <20% INT. S-2, ID OD GEO. 20% INT. 2ND ID OD GEO. <20% INT. S-3S, ID GEO. <20% S-4S, OD GEO. <20%	
	13C	PT	RRGJR-4	84-1073BL	NONE	NONE L-WAVE EXAM NONE
		UT	RRGJR-4	84-1097BL	NONE	
		UT	RRGJR-4	84-1432BL	S-1, ID GEO. <20% INT. S-2, ID GEO. 20% INT.	
	13C	PT	RRGJR-4 TO RRGJR-5	84-317BL	NONE	NONE
		UT	RRGJR-4 TO RRGJR-5	84-411BL	S-10, ID GEO. 8% S-11, ID OD GEO. -PIPE EDGE	NONE
	13C	PT	RRGJR-5	84-311BL	NONE	NONE NO S-1, S-1S & S-2S DUE TO CONFIGURATION
		UT	RRGJR-5	84-410BL	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER H	13C	PT UT UT	RRHJR-3 RRHJR-3 RRHJR-3	84-1069BL	NONE	NONE L-WAVE EXAM S-2 LIMITED, TAPER ON SAFE END
				84-1079BL 84-1417BL	NONE S-1, ID OD GEO. 50% INT. S-2, ID OD GEO. < 20% INT. S-3S, OD GEO. < 20% S-4S, OD GEO. < 20%	
RISER J	13C	PT UT UT	RRHJR-4 RRHJR-4 RRHJR-4	84-1072BL	NONE	NONE L-WAVE EXAM NONE
				84-1098BL 84-1431BL	NONE S-1, OD GEO. < 20% INT. S-2, ID GEO. < 20%	
	13C	PT UT UT	RRJJR-3 RRJJR-3 RRJJR-3	84-1131BL	NONE	NONE L-WAVE EXAM S-2 LIMITED DUE TO TAPER ON SAFE END
				84-1136BL 84-1393BL	NONE S-1, ID OD GEO. INT. S-2, ID OD GEO. 20-22% INT. S-4S, OD GEO. < 20%	
13C	PT UT UT	RRJJR-4 RRJJR-4 RRJJR-4	84-1146BL	NONE	NONE L-WAVE EXAM NONE	
			84-1137BL 84-1430BL	NONE S-2, ID GEO. 23% INT.		
13C	PT	RRJJR-4 TO RRJJR-5	84-338BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER J	13C	UT	RRJJR-4 TO RRJJR-5	84-398BL	S-9, ID GEO. 10% S-11, PIPE EDGE GEO. S-12, ID GEO. 10% S-10S, ID GEO. 10%	NONE
	13C	PT UT	RRJJR-5 RRJJR-5	84-339BL 84-403BL	NONE S-2, ID OD GEO. 10% INT.	NONE NO S-1, S-1S & S-2S DUE TO CONFIGURATION
RISER K	13C	PT	RRKJR-3	84-1210BL	NONE	NONE L-WAVE EXAM LIMITED SCAN DUE TO TAPER ON SAFE END
		UT	RRKJR-3	84-1268BL	NONE	
		UT	RRKJR-3	84-1394BL	S-1, ID OD GEO. 20-35% INT. S-2, ID OD GEO. 20-25% INT. S-1S, OD GEO. < 20% INT. S-2S, OD GEO. < 20% INT. S-3S, OD GEO. < 20% INT. S-4S, OD GEO. < 20% INT.	
	13C	PT UT UT	RRKJR-4 RRKJR-4 RRKJR-4	84-1114BL 84-1120BL 84-1429BL	NONE NONE S-2, ID GEO. 30% INT. OD GEO. < 20%	NONE L-WAVE EXAM NONE
13C	PT	RRKJR-4 TO RRKJR-5	84-330BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER K	13C	UT	RRKJR-4 TO RRKJR-5	84-395BL	S-9, ID OD GEO. 5-10% S-11, PIPE EDGE GEO. 30-35% S-12, ID GEO. 10% S-12S, PIPE EDGE GEO.	NONE
	13C	PT	RRKJR-5	84-332BL	ONE LINEAR FOUR ROUNDED	NONE
		PT	RRKJR-5	84-432BLR	NONE, INDICATIONS BUFFED OUT	NONE
	13C	UT	RRKJR-5	84-394BL	S-1, ID OD GEO. 5-10% INT. S-2, ID OD GEO. 10-15% INT. S-3, ID OD GEO. L.S. 5-10% S-1S, ID OD GEO. 12:00 5-10% S-2S, ID GEO. 12:00 5%	NONE
		PT	RRKJR-5 TO RRKJR-6	84-331BL	NONE	NONE
		UT	RRKJR-5 TO RRKJR-6	84-396BL	S-6, OD GEO. 5-10% S-7, ID OD GEO. 5-10% S-8, ID OD GEO. 8-15%	OD TRIPS DUE TO REDIRECTED BEAM FROM COUNTER BORE
	13C	PT	RRKJR-6	84-329BL	NONE	NONE
		UT	RRKJR-6	84-397BL	S-1, ID OD GEO. 10-15% INT. S-2, ID OD GEO. 5-20% INT.	OD TRIPS DUE TO REDIRECTED BEAM FROM COUNTER BORE

NORTHERN STATES POWER COMPANY
 MONTICELLO NUCLEAR GENERATING PLANT
 BASELINE SUMMARY

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER K	13C	PT	RRKJR-6 TO RRKJR-7	84-333BL	NONE	NONE
		UT	RRKJR-6 TO RRKJR-7	84-401BL	S-5, ID OD GEO. 8-15% INT. S-6, ID OD GEO. 8-15% INT. S-5S, ID GEO. 10% INT. S-6S, ID OD GEO. 8-15% CIRC WELD S-7S, ID GEO. 10% S-8S, ID GEO 10%	NONE
	13C	PT	RRKJR-7	84-337BL	ONE LINEAR FOUR ROUNDED	NONE
		PT	RRKJR-7	84-435BLR	NONE, INDICATIONS BUFFED OUT	NONE
		UT	RRKJR-7	84-402BL	S-1, ID OD GEO. 8-15% OD GEO. REDIRECTED BEAM FROM I.D. S-2, ID OD GEO. 5-10% INT. S-3, OD GEO. 10% LONG SEAM S-1S, ID OD GEO. 5-10% INT. S-2S, OD GEO. 10% INT. S-3S, OD GEO. 10% S-4S, ID OD GEO. 10%	S-1 B.E. DUE TO CONFIGURATION
	13D	PT	RRAJR-3	84-1085BL	NONE	NONE
UT		RRAJR-3	84-1092BL	NONE	L-WAVE EXAM	
UT		RRAJR-3	84-1386BL	S-1, ID GEO. < 20% INT. OD GEO. 20% INT. S-2, ID GEO. 20% INT.	S-2 LIMITED DUE TO TAPER OF SAFE END	
RISER A						

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER A	13D	PT	RRAJR-4	84-1086BL	NONE	NONE L-WAVE EXAM NONE
		UT	RRAJR-4	84-1093BL	NONE	
		UT	RRAJR-4	84-1434BL	NONE	
	13D	PT	RRAJR-4 TO RRAJR-5	84-298BL	NONE	NONE
		UT	RRAJR-4 TO RRAJR-5	84-420BL	NONE	NONE
	13D	PT	RRAJR-5	84-295BL	NONE S-1, ID OD GEO. 10-20% 360° INT.	NONE NONE
		UT	RRAJR-5	84-415BL		
	13D	PT	RRAJR-5 TO RRAJR-6	84-299BL	NONE	STAMP ON WELD
		UT	RRAJR-5 TO RRAJR-6	84-417BL	NONE	NONE
	13D	PT	RRAJR-6	84-294BL	NONE S-2, ID OD GEO. 15-30% 360° INT.	NONE
	UT	RRAJR-6	84-421BL			

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER A	13D	PT	RRAJR-6 TO RRAJR-7	84-300BL	NONE	NONE
		UT	RRAJR-6 TO RRAJR-7	84-416BL	S-5, ID OD GEO. 0" TO 40" 10-15% INT. S-6, ID OD GEO. 0" TO 40" 10% INT.	NONE
RISER B	13D	PT	RRAJR-7	84-293BL	NONE	NONE S-1 LIMITED TO 2" DUE TO REDUCER CONFIGURATION
		UT	RRAJR-7	84-422BL	S-1, ID OD GEO. 15-30% 360° INT. S-2, ID OD GEO. 10-30% 360° INT.	
	13D	PT	RRBJR-3	84-1056BL	NONE	NONE L-WAVE EXAM S-2 LIMITED DUE TO TAPER ON SAFE ENDS
		UT	RRBJR-3	84-1062BL	NONE	
UT	RRBJR-3	84-1385BL	S-1, ID OD GEO. 25-40% INT. S-2, ID OD GEO. 20-25% INT. S-2S, OD GEO. < 20%			
13D	PT	RRBJR-4	84-1115BL	NONE	STENCIL PUNCH MARKS, TOE TO WELD 8:00 TO 9:30 L-WAVE EXAM NONE	
		UT	RRBJR-4	84-1121BL		NONE
		UT	RRBJR-4	84-1435BL	S-2, ID OD GEO. < 20% INT.	

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 9.1
PAGE 67 OF 73

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT)						
RISER B	13D	PT	RRBJR-4 TO RRBJR-5	84-303BL	NONE	NONE
		UT	RRBJR-4 TO RRBJR-5	84-419BL	NONE	NONE
	13D	PT UT	RRBJR-5 RRBJR-5	84-296BL 84-418BL	NONE S-1, ID OD GEO. 10-20% 360° INT. S-2, ID GEO 15% 360° INT.	NONE S-1 LIMITED 3:00 & 9:00 DUE TO CONFIGURATION
RISER C	13D	PT UT UT	RRCJR-3 RRCJR-3 RRCJR-3	84-1055BL 84-1063BL 84-1387BL	NONE NONE S-1, ID OD GEO. 20-30% INT. S-2, ID GEO. 20% INT.	NONE L-WAVE EXAM S-2 LIMITED DUE TO TAPER ON SAFE END
	13D	PT UT UT	RRCJR-4 RRCJR-4 RRCJR-4	84-1052BL 84-1064BL 84-1436BL	NONE NONE S-1, OD GEO. 20-23% INT.	NONE L-WAVE EXAM
RISER D	13D	PT UT UT	RRDJR-3 RRDJR-3 RRDJR-3	84-1077BL 84-1094BL 84-1371BL	NONE NONE S-1, ID GEO. < 20% INT. OD GEO. < 20% INT. S-2, ID OD GEO. 20-35% INT. S-1S, OD GEO. < 20%	NONE L-WAVE EXAM S-2 LIMITED DUE TO TAPER OF SAFE END

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT) RISER D	13D	PT	RRDJR-4	84-1074BL	NONE	NONE L-WAVE EXAM NONE	
		UT	RRDJR-4	84-1081BL	NONE		
		UT	RRDJR-4	84-1437BL	S-2, OD GEO. 20% INT.		
	13D	PT	RRDJR-4 TO RRDJR-5	84-278BL	ONE LINEAR	NONE	
		PT	RRDJR-4 TO RRDJR-5	84-353BLR	NONE LINEAR BUFFED OUT	NONE	
		UT	RRDJR-4 TO RRDJR-5	84-413BL	S-9, ID GEO. 12% 0" TO 6" INT. OD GEO. 10% 0" TO 6" INT. S-10, ID GEO. 12% 0" TO 6" INT. OD GEO. 10% 0" TO 6" INT.	NONE	
		PT UT	RRDJR-5 RRDJR-5	84-276BL 84-414BL	NONE S-1, ID OD GEO. 15-20% 360° INT. S-2, ID OD GEO. 10-15% 360° INT.	NONE SCANS LIMITED AT 3:00 & 9:00 DUE TO CONFIGURATION	
	RISER E	13D	PT	RREJR-3	84-1076BL	NONE	NONE L-WAVE EXAM S-2 LIMITED DUE TO TAPER ON SAFE END
			UT	RREJR-3	84-1095BL	NONE	
			UT	RREJR-3	84-1372BL	S-1, ID OD GEO. < 20% S-2, ID OD GEO. < 20% S-4, STANDING WAVE < 20%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.11 & 9.12 (CONT) RISER E	13D	PT	RREJR-4	84-1078BL	NONE	NONE L-WAVE EXAM NONE
		UT	RREJR-4	84-1080BL	NONE	
		UT	RREJR-4	84-1438BL	S-2,OD GEO. < 20%	
	13D	PT	RREJR-4 TO RREJR-5	84-282BL	NONE	NONE
		UT	RREJR-4 TO RREJR-5	84-458BL	S-9,OD GEO. < 20% 360° INT. S-10,OD GEO.<20% 360° INT.	NONE
	13D	PT	RREJR-5	84-275BL	NONE	NONE OD MISMATCH LIMITS S-1
		UT	RREJR-5	84-455BL	S-1,ID OD GEO.30% 360°INT. S-2,OD GEO. < 20% 360° INT.	
	13D	PT	RREJR-5 TO RREJR-6	84-283BL	NONE	NONE
		UT	RREJR-5 TO RREJR-6	84-412BL	S-5,ID GEO. 10% 0" TO 38" INT.	NONE
	13D	PT	RREJR-6	84-274BL	NONE	NONE NONE
	UT	RREJR-6	84-456BL	S-1,ID OD GEO. 30% 360°INT. S-2,ID OD GEO. 40% 360°INT. S-1S, OD GEO. <20% S-2S,OD GEO. <20% S-3S,OD GEO. <20% S-4S,OD GEO. <20%		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
B9.11 & 9.12 (CONT)	13D	PT	RREJR-6 TO RREJR-7	84-281BL	NONE	NONE	
		UT	RREJR-6 TO RREJR-7	84-454BL	S-5,OD GEO.<20% INT. S-6,OD GEO. < 20% INT. S-7,COUNTER BORE GEO.20%	NONE	
	13D	PT	RREJR-7	84-273BL	NONE	NONE	
		UT	RREJR-7	84-457BL 84-446BL	S-1,ID GEO. COUNTER BORE 20% OD GEO. LONG.SEAM 20%	S-1,B.E. DUE TO OD MISMATCH	
	B9.21 & 9.22 <u>CIRCUMFERENTIAL AND LONGITUDINAL WELDS</u> STANDBY LIQUID CONTROL	22	PT	CPAJR-3	84-931BL	NONE	NONE
			PT	CPAJR-4	84-932BL	NONE	NONE
PT			CPAJR-6	84-933BL	NONE	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
<u>B9.30 BRANCH CONNECTIONS</u> <u>WELDS</u> <u>B9.31 NOMINAL PIPE SIZE</u> <u>GREATER THAN 2"</u>	9	PT	CWAJR-1	84-029BL	NONE	NONE NO S-2, S-3S AND S-4S DUE TO CONFIGURATION	
		UT	CWAJR-1	84-903BL	NONE		
	RHR "A"	11A	MT	RHAJR-8	84-1356BL	NONE	NONE L-WAVE EXAM NO SCANS ON 4" PIPE NO S-2 DUE TO CONFIGURATION OF BRANCH CONNECTIONS
			UT	RHAJR-8	84-1359BL	NONE	
			UT	RHAJR-8	84-1361BL	S-1, ID GEO. < 20% DAC AT 12.00 & 6.00 S-3, ID GEO. < 20% DAC AT 6.00	
		11A	MT	RHAJR-13	84-1350BL	NONE	
	UT		RHAJR-13	84-1358BL	NONE		
			UT	RHAJR-13	84-1360BL	NONE	NONE L-WAVE EXAM NO SCANS ON 4" PIPE NO S-2 DUE TO CONFIGURATION OF BRANCH CONNECTIONS

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.30 & 9.31 (CONT) RHR "B"	11A	MT	RHEJ-20	84-1174BL	NONE	MACHINING MARKS FROM 9.00 TO 12.00 L-WAVE EXAM NONE NO S-2 DUE TO CONFIGURATION
		UT	RHEJ-20	84-1177BL	NONE	
		UT	RHEJ-20	84-1178BL	NONE	
	11B	MT	RHBJR-9	84-1352BL	NONE	NONE L-WAVE EXAM NO EXAM FROM 4" SIDE NO S-2 DUE TO CONFIGURATION
		UT	RHBJR-9	84-1362BL	NONE	
		UT	RHBJR-9	84-1369BL	NONE	
	11B	MT	RHBJR-20	84-1354BL	NONE	EXAM LIMITED FROM 2.00 TO 4.00 DUE TO U-BOLT NO EXAM FROM 4" SIDE L-WAVE EXAM NO S-2 DUE TO CONFIGURATION
		UT	RHBJR-20	84-1365BL	NONE	
		UT	RHBJR-20	84-1366BL	NONE	
	11B	MT	RHEJ-37	84-1175BL	NONE	NONE L-WAVE EXAM NONE NO S-2 DUE TO CONFIGURATION
		UT	RHEJ-37	84-1179BL	NONE	
		UT	RHEJ-37	84-1264BL	S-1, ID GEO. @ 12.00	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
B9.30 & 9.31 (CONT) RHR "C"	11C	MT	RHCJR-9	84-1346BL	NONE	NONE L-WAVE EXAM NO EXAM FROM 4" SIDE NO S-2 DUE TO CONFIGURATION
		UT	RHCJR-9	84-1363BL	NONE	
		UT	RHCJR-9	84-1368BL	NONE	
	11C	MT	RHCJR-20	84-1349BL	NONE	
		UT	RHCJR-20	84-1364BL	NONE	
		UT	RHCJR-20	84-1367BL	NONE	
11C	MT	RHEJ-1	84-961BL	NONE	NONE L-WAVE EXAM NO SCAN FROM 4" SIDE NO S-2 DUE TO CONFIGURATION	
	UT	RHEJ-1	84-956BL	NONE		
	UT	RHEJ-1	84-958BL	OD GEO. 360° INTERMITTENT 50% DAC MAX.		
<u>B9.32 NOMINAL PIPE SIZE 2" AND LESS</u>	26	PT	RCAJR-13	84-045BL	NONE	NONE NONE NONE NONE
RECIRC.DRAIN A & B		PT	RCAJR-18	84-608BL	NONE	
		PT	RCBJR-11	84-681BL	NONE	
		PT	RCBJR-16	84-037BL	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>B10.10 INTEGRALLY WELDED ATTACHMENTS AND B11.10 COMPONENT SUPPORTS</u> RWCU RECIRC A	9	VT	CWAK-14	84-1630BL	NONE	NONE
	13A	PT	RCAKR-12A W-1	84-738BL	NONE	NONE
		PT	RCAKR-12A W-2	84-740BL	NONE	NONE
		PT	RCAKR-12A W-3	84-739BL	NONE	NONE
		PT	RCAKR-12A W-4	84-741BL	NONE	NONE
	13A	VT	RCAKR-12A	84-1542BL	LOOSE NUT	NONE
		VT	RCAKR-12A	84-1542BLR	NONE-NUT TIGHTENED	NONE
	13A	PT	RCAKR-16	84-1579BL	NONE	NONE
		VT	RCAKR-16	84-1543BL	NONE	NONE
	13A	PT	RCAKR-18	84-1578BL	NONE	NONE
		VT	RCAKR-18	84-1544BL	NONE	NONE
	13A	PT	RCAKR-21	84-015BL	ONE LINEAR	NONE
		PT	RCAKR-21	84-153BLR	NONE LINEAR BUFFED OUT	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC A (CONT)	13A	PT	RCAKR-33A W-8	84-712BL	ONE LINEAR	NONE
		PT	RCAKR-33A W-8	84-790BLR	NONE LINEAR BUFFED OUT	NONE
	13A	PT	RCAKR-33A W-9	84-708BL	MULTIPLE LINEARS	NONE
		PT	RCAKR-33A W-9	84-800BLR	NONE LINEARS BUFFED OUT	NONE
	13A	PT	RCAKR-33A W-10	84-778BL	NONE	NONE
	13A	PT	RCAKR-33A W-11	84-791BL	NONE	NONE
	13A	VT VT	RCAKR-33A RCAKR-33A	84-1546BL 84-1546BLR	LOOSE NUT NONE NUT TIGHTENED	NONE NONE
	RECIRCULATION PUMP A	13A SHT.2	VT	PHAR-3	84-1535BL	NONE
13A SHT.2		VT VT	PHAR-4 PHAR-4	84-1537BL 84-1537BLR	LOOSE NUT NONE NUT TIGHTENED	NONE NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRCULATION PUMP A (CONT)	13A SHT.2	VT	PHAR-5	84-1536BL	NONE	NONE
	13A SHT.2	VT	PSSAR-4A	84-1539BL	NONE	NONE
	13A SHT.2	VT	PSSAR-4B	84-1540BL	NONE	NONE
	13A SHT.2	VT	PSSAR-5	84-1541BL	NONE	NONE
	13A SHT.2	VT	RCAKR-22	84-1533BL	NONE	NONE
	13A SHT.2	VT	RCAKR-24A	84-1534BL	NONE	NONE
	13A SHT.2	VT	RCAKR-24B	84-1538BL	NONE	NONE
RECIRC B	13B	PT	RCBKR-10A W-1	84-744BL	TWO LINEARS	NONE
		PT	RCBKR-10A W-1	84-754BL	NONE LINEARS REMOVED	NONE
	13B	PT	RCBKR-10A W-2	84-733BL	TWO LINEARS	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC B (CONT)		PT	RCBKR-10A W-2	84-753BL	NONE LINEARS REMOVED	NONE
	13B	PT	RCBKR-10A W-3	84-749BL	NONE	NONE
	13B	PT	RCBKR-10A W-4	84-707BL	MULTIPLE LINEARS	NONE
		PT	RCBKR-10A W-4	84-755BL	NONE LINEARS REMOVED	NONE
	13B	VT VT	RCBKR-10A RCBKR-10A	84-1553BL 84-1553BLR	LOOSE NUTS NONE NUTS TIGHTENED	NONE NONE
	13B	PT VT	RCBKR-14 RCBKR-14	84-1580BL 84-1555BL	NONE NONE	NONE NONE
	13B	PT VT	RCBKR-16 RCBKR-16	84-1581BL 84-1557BL	NONE NONE	NONE NONE
	13B	PT	RCBKR-19	84-031BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC B (CONT)	13B	PT	RCBKR-32A W-8	84-759BL	FOUR ROUNDED	NONE
		PT	RCBKR-32A W-8	84-780BLR	ONE LINEAR	NONE
		PT	RCBKR-32A W-8	84-825BLR	NONE LINEAR REMOVED	NONE
	13B	PT	RCBKR-32A W-9	84-757BL	ONE LINEAR	NONE
		PT	RCBKR-32A W-9	84-772BLR	ONE LINEAR	NONE
		PT	RCBKR-32A W-9	84-816BLR	NONE LINEAR REMOVED	NONE
		PT	RCBKR-32A W-10	84-760BL	MULTIPLE LINEARS	NONE
		PT	RCBKR-32A W-10	84-777BLR	NONE LINEARS REMOVED	NONE
		PT	RCBKR-32A W-11	84-768BL	NONE	NONE
		RECIRCULATION PUMP B	13B SHT.2	VT	PHBR-3	84-1568BL
	13B SHT.2	VT	PHBR-6	84-1567BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRCULATION PUMP B (CONT)	13B SHT.2	VT	PHBR-7	84-1566BL	NONE	NONE
	13B SHT.2	VT	PSSBR-4A	84-1561BL	NONE	NONE
	13B SHT.2	VT	PSSBR-4B	84-1562BL	NONE	NONE
	13B SHT.2	VT	PSSBR-5	84-1558BL	NONE	NONE
	13B SHT.2	VT	RCBKR-20	84-1565BL	NONE	NONE
	13B SHT.2	VT	RCBKR-25	84-1563BL	NONE	NONE
	13B SHT.2	VT	RCBKR-25A	84-1564BL	NONE	NONE
RECIRC MANIFOLD "A"	13C	PT	RMAKR-4	84-1583BL	NONE	NONE
		VT	RMAKR-4	84-1532BL	NONE	NONE
	13C	PT	RMAKR-6	84-1586BL	NONE	NONE
		VT	RMAKR-6	84-1530BL	NONE	NONE
	13C	PT	RMAKR-13	84-1584BL	NONE	NONE
		VT	RMAKR-13	84-1531BL	NONE	NONE
	13C	PT	RMAKR-13B	84-1585BL	NONE	NONE
		VT	RMAKR-13B	84-1545BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRCULATION MANIFOLD B	13D	PT	RMBKR-4	84-1593BL	NONE	NONE
		VT	RMBKR-4	84-1549BL	NONE	NONE
	13D	PT	RMBKR-6A	84-1595BL	NONE	NONE
		VT	RMBKR-6A	84-1556BL	NONE	NONE
	13D	PT	RMBKR-13	84-1594BL	NONE	NONE
		VT	RMBKR-13	84-1550BL	NONE	NONE
	13D	PT	RMBKR-13C	84-1596BL	NONE	NONE
		VT	RMBKR-13C	84-1551BL	NONE	NONE

NORTHERN STATES POWER COMPANY
MONTICELLO NUCLEAR GENERATING PLANT
BASELINE SUMMARY

TABLE 11.1
Page 1 OF 4

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
<u>B11.10</u> <u>COMPONENT SUPPORTS</u>						
RWCU	9	VT	CWAK-11	84-1629BL	NONE	NONE
RHR REW10	11A	VT	RHAKR-8	84-1504BL	NO WEEP HOLE	NONE
		VT	RHAKR-8	84-1504BLR	NONE WEEP HOLE INSTALLED	NONE
	11A	VT	RHAKR-13	84-1501BL	NONE	NONE
	11A	VT	RHAKR-14	84-1500BL	NONE	NONE
	11A	VT	RHAKR-19	84-1503BL	NONE	NONE
RHR TW20	11A	VT	RHAKR-22	84-1502BL	NONE	NONE
	11B	VT	RHBKR-10	84-1499BL	NONE	NONE
	11B	VT	RHBKR-12	84-1498BL	NOT ATTACHED TO WALL	NONE
		VT	RHBKR-12	84-1498BLR	NONE ATTACHED TO WALL	NONE
	11B	VT	RHBKR-18	84-1497BL	NO WEEP HOLE	NONE
VT		RHBKR-18	84-1497BLR	NONE WEEP HOLE INSTALLED	NONE	
RHR TW30	11C	VT	RHCKR-9	84-1493BL	NOT ATTACHED TO WALL	NONE
		VT	RHCKR-9	84-1493BLR	NONE ATTACHED TO WALL	NONE
	11C	VT	RHCKR-10	84-1494BL	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS	
RHR TW30 (CONT)	11C	VT	RHCKR-17A	84-1492BL	NO WEEP HOLE	NONE	
		VT	RHCKR-17A	84-1492BLR	NONE WEEP HOLE INSTALLED	NONE	
	11C	VT	RHCKR-24	84-1495BL	NO WEEP HOLE	NONE	
		VT	RHCKR-24	84-1495BLR	NONE WEEP HOLE INSTALLED	NONE	
	RHR TW40		VT	RHEK-10	84-1508BL	NONE	NONE
			VT	RHEK-12	84-1505BL	NONE	NONE
		VT	RHEK-23	84-1507BL	NONE	NONE	
		VT	RHEK-25	84-1506BL	NONE	NONE	
RECIRC A	13A	VT	RCAK-6	84-1486BL	NONE	NONE	
	13A	VT	RCAK-12	84-1483BL	NONE	NONE	
	13A	VT	RCAKR-12B	84-1529BL	NONE	NONE	
	13A	VT	RCAKR-29	84-1547BL	LOOSE NUT	NONE	
		VT	RCAKR-29	84-1547BLR	NONE NUT TIGHTENED	NONE	
	13A	VT	RCAKR-30A	84-1548BL	NONE	NONE	
	13A	VT	RCAK-33	84-1627BL	NONE	NONE	
	13A	VT	RCAKR-33B	84-1528BL	NONE	NONE	
13A	VT	RCAK-34	84-1626BL	NONE	NONE		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC B	13B	VT	RCBK-8	84-1482BL	NONE	NONE
	13B	VT	RCBK-10	84-1489BL	NONE	NONE
	13B	VT	RCBKR-10B	84-1552BL	NONE	NONE
	13B	VT	RCBKR-27	84-1560BL	LOOSE NUT	NONE
			RCBKR-27	84-1560BLR	NONE NUT TIGHTENED	NONE
	13B	VT	RCBKR-29	84-1559BL	NONE	NONE
	13B	VT	RCBK-32	84-1625BL	NONE	NONE
	13B	VT	RCBKR-32A	84-1554BL	NONE	NONE
	13B	VT	RCBKR-32B	84-1569BL	NONE	NONE
	13B	VT	RCBK-33	84-1624BL	NONE	NONE
RECIRC MANIFOLD A	13C	VT	RMAK-11	84-1485BL	NONE	NONE
RECIRC MANIFOLD B	13D	VT	RMBK-13A	84-1484BL	NONE	NONE
RECIRC RISERS "A"	13C	VT	RRFK-6	84-1477BL	NONE	NONE
	13C	VT	RRGK-6	84-1478BL	NONE	NONE
	13C	VT	RRHK-6	84-1479BL	LOOSE NUTS	NONE
RRHK-6			84-1479BLR	NONE NUTS TIGHTENED	NONE	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	EXAMINATION LIMITATIONS
RECIRC RISERS "A" (CONT)	13C	VT	RRJK-6	84-1480BL	NONE	NONE
	13C	VT	RRKK-6	84-1481BL	NONE	NONE
RECIRC RISERS "B"	13D	VT	RRAK-6	84-1472BL	LOOSE NUTS	NONE
		VT	RRAK-6	84-1472BLR	NONE NUTS TIGHTENED	NONE
	13D	VT	RRBK-6	84-1473BL	NONE	NONE
	13D	VT	RRCK-6	84-1474BL	NONE	NONE
	13D	VT	RRDK-6	84-1475BL	NONE	NONE
13D	VT	RREK-6	84-1476BL	NONE	NONE	

APPENDIX B

ASME CLASS II EXAMINATIONS

(NO EXAMINATIONS PERFORMED)

APPENDIX C

TABLE I - Personnel Listing

TABLE II - Ultrasonic Calibration Blocks

TABLE III - Procedure Listing

TABLE IV - Equipment and Materials

PERSONNEL LISTING

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL					
			UT	PT	MT	VT	ET	RT
G. R. ADAMS	SUPERVISOR	LMT	III	III	II	III (1c)		
R. G. AUER	TECHNICIAN	LMT	II	II	II	II (1a, 1c)		
J. E. BIGHAM	TECHNICIAN	LMT	I					
W. D. CARLIN	TECHNICIAN	LMT	I	II			II (1b)	
J. D. ELLIOTT	TECHNICIAN	LMT	II	II	II	II (1b)		
S.R. FETHERSTON	TECHNICIAN	LMT	I	I				
D. A. HALL	TECHNICIAN	LMT	II				II (1c)	
K. L. HALL	TECHNICIAN	LMT	I					
D. E. HARVEY	SUPERVISOR	LMT	III	III	III	III (1a, c)		
R.A.KELLERHALL	SUPERVISOR	LMT	III	III	III	III (1a, c)		
T. KIMBALL	TECHNICIAN	LMT	II	II	II	II (1b) (1c)		
Q. LOREDO	TECHNICIAN	LMT	I					
R. W. PECHACEK	TECHNICIAN	LMT	II	II	II	II (1a, 1b)		
K. E. SCRIVNER	TECHNICIAN	LMT	I					
R. A. SEALS	TECHNICIAN	LMT	II	II	II	II (1a, 1c)		
E. L. THOMAS	SUPERVISOR	LMT	III	III	III	III (1a, 1c)		
R. J. WATKINS	TECHNICIAN	LMT	II		II (1b)			
A. S. WHEALDON	TECHNICIAN	LMT	III	III	III	II (1c)		
L. C. DAHLMAN	MATERIALS AND SPECIAL PROCESS SPECIALIST	NSP	II	III	III	II (1b)		
J. F. SCHANEN	MATERIALS AND SPECIAL PROCESS SPECIALIST	NSP	II	II	II	II (1b)		
R. HUGHES	ANII	HARTFORD STEAM BOILER INSPECTION INSURANCE COMPANY						

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL						
			UT	PT	MT	VT	ET	RT	

FOOTNOTES:

- (1a) Certified by NSP to perform visual determination of structural integrity for hangar assemblies in accordance with NSP-VT 2.0.
- (1b) Inspection experience and NDE qualifications were determined to be adequate to perform visual examinations in accordance with NSP-VT 1.0.
- (1c) Personnel certified in accordance with contractor's Quality Assurance Program.
- (2) Organization: Lambert, MacGill; Thomas, Inc. (LMT)
515 Aldo Avenue
Santa Clara, CA 95054

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
4	4"	80 .337"	A106B	L42009	RGA-031BL RGA-033BL RGA-037BL JE-005BL DH-026BL DH-047BL DH-052BL DH-055BL DH-056BL DH-057BL DH-061BL DH-063BL DH-064BL DH-086BL DH-087BL DH-088BL DH-089BL RK-001BL TK-034BL TK-035BL TK-036BL TK-041BL TK-065BL TK-066BL TK-069BL TK-070BL AW-006BL	9-28-84 9-29-84 9-29-84 7-12-84 7-25-84 9-21-84 9-21-84 9-25-84 9-26-84 9-27-84 9-29-84 9-29-84 10-3-84 11-30-84 12-1-84 12-3-84 12-1-84 7-26-84 5-31-84 6-1-84 6-4-84 6-19-84 9-13-84 9-13-84 9-17-84 9-19-84 6-14-84

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
8	18"	80 .937"	A106B	122491	RGA-027BL DH-031BL DH-032BL DH-054BL DH-058BL DH-072BL TK-073BL AW-012BL	9-27-84 8-6-84 8-7-84 9-21-84 9-28-84 10-23-84 9-21-84 7-13-84
10	16"	80 .843"	A106B	N36809	JE-003BL DH-021BL DH-022BL DH-023BL DH-024BL DH-025BL DH-033BL DH-036BL DH-073BL TK-051BL TK-062BL TK-064BL TK-067BL TK-068BL TK-074BL TK-075BL TK-076BL AW-007BL AW-009BL AW-010BL	7-10-84 6-18-84 6-18-84 7-20-84 7-23-84 7-24-84 8-8-84 8-20-84 10-23-84 8-28-84 9-7-84 9-11-84 9-14-84 9-14-84 9-21-84 9-27-84 9-27-84 6-27-84 7-11-84 7-16-84

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
11	8"	80 .500"	304 S/S	15885	DH-080BL TK-083BL	11-13-84 11-11-84
12-2	4"	80 .337"	304 S/S	7-73280	RGA-032BL DH-068BL	9-28-84 10-20-84
36	10" & 13.43"	80 .491" & .875"	B166	BGM	DH-077BL DH-079BL	11-11-84 11-12-84
62	22"	80 .919"	316 S/S	13549	DH-005BL DH-006BL DH-007BL DH-020BL DH-081BL TK-037BL TK-058BL RS-002BL RS-005BL	3-22-84 3-21-84 3-20-84 6-14-84 11-13-84 6-7-84 9-5-84 3-4-84 3-26-84
63	28"	80 1.015"	316 S/S	32681	RGA-028BL RGA-034BL DH-009BL DH-010BL DH-011BL DH-012BL DH-037BL DH-051BL	9-27-84 9-29-84 4-2-84 4-3-84 4-4-84 4-5-84 8-21-84 9-17-84

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
63 (Cont)					DH-069BL DH-082BL DH-083BL DH-084BL DH-085BL TK-002BL TK-004BL TK-005BL TK-006BL TK-011BL TK-033BL TK-038BL TK-040BL TK-042BL TK-047BL TK-055BL TK-060BL TK-063BL TK-071BL TK-072BL TK-086BL RS-004BL RS-006BL AW-004BL AW-005BL AW-008BL AW-011BL AW-015BL AW-016BL	10-20-84 11-14-84 11-15-84 11-16-84 11-16-84 3-22-84 4-2-84 4-3-84 4-4-84 4-7-84 5-29-84 6-7-84 6-15-84 8-1-84 8-20-84 8-30-84 9-5-84 9-10-84 9-19-84 9-20-84 11-14-84 3-26-84 3-30-84 5-25-84 6-4-84 7-9-84 7-23-84 8-10-84 8-24-84

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
64	12"	80 .688"	316 S/S	32657	RGA-029BL DH-008BL DH-042BL DH-043BL DH-046BL DH-048BL TK-001BL TK-003BL TK-059BL TK-081BL TK-082BL TK-084BL TK-085BL RS-001BL RS-003BL	9-28-84 3-24-84 8-30-84 9-4-84 9-10-84 9-13-84 3-23-84 3-24-84 9-5-84 11-9-84 11-10-84 11-12-84 11-13-84 3-27-84 3-23-84
65	16"	80 .681"	316 S/S	13549	DH-003BL DH-027BL DH-038BL DH-067BL TK-044BL TK-045BL TK-046BL TK-049BL TK-050BL AW-013BL AW-014BL	3-16-84 7-31-84 8-22-84 10-19-84 8-9-84 8-10-84 8-10-84 8-27-84 8-28-84 8-7-84 8-7-84

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
66	28"	160 2.25"	316 S/S	13515	TK-087BL TK-088BL	11-15-84 11-16-84
67	18"	80 .751"	316 S/S	13549	DH-001BL DH-002BL DH-004BL DH-028BL DH-034BL DH-035BL DH-066BL TK-043BL	3-16-84 3-14-84 3-15-84 7-31-84 8-13-84 8-13-84 10-18-84 8-2-84
70	12"	80 .83" .66"	316 S/S	626390	TGA-030BL DH-040BL DH-041BL DH-049BL DH-050BL DH-074BL DH-075BL DH-076BL DH-078BL DH-056BL DH-057BL	9-28-84 8-28-84 8-30-84 9-13-84 9-13-84 11-9-84 11-9-84 11-10-84 11-12-84 8-30-84 9-4-84

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
71	28"	1.6"	316 S/S	13515	DH-070BL TK-048BL TK-089BL	10-21-84 8-24-84 11-16-84
72	5.6"	.875"	A182GRF 316L S/S	82661	RGA-035BL TK-079BL	9-29-84 10-5-84
73/73A		.87"	A-479 316L S/S	A13719	RGA-036BL DH-071BL	9-29-84 10-21-84

NORTHERN STATES POWER COMPANY

MONTICELLO
PROCEDURE LISTING

APPENDIX C
TABLE III
PAGE 1 of 1

PROCEDURE NUMBER AND REVISION	FIELD CHANGE	PROCEDURE TITLE	PLANT APPROVAL DATE	FIELD CHANGE REMARKS	CHANGE DESCRIPTION
NSP-MT-1 Rev.3	NONE	MAGNETIC PARTICLE EXAMINATION	8-26-82	NONE	
NSP-PT-1 Rev. 3	FC 1 FC 2	LIQUID PENETRANT EXAMINATION	3-6-84 5-21-84		F.C.#1 Change rounded indication reporting requirements, INCREASE DWELL AND DEVELOPMENT TIME. F.C.#2 Re-instate original procedure.
NSP-UT-1 Rev.2	None	ULTRASONIC EXAMINATION OF PIPE WELDS	8-26-82	NONE	
NSP-UT-2 Rev.2	NONE	AUTOMATIC DATA RECORDING	8-26-82	NONE	
NSP-UT-16 Rev.0	NONE	ULTRASONIC EXAMINATION FOR INTERGRANULAR STRESS CORROSION CRACKING (IGSCC)	2-17-84	NONE	
NSP-UT-16 Rev.1	NONE	ULTRASONIC EXAMINATION FOR INTERGRANULAR STRESS CORROSION CRACKING (IGSCC)	3-2-84	NONE	
NSP-VT-1.0 Rev.0	NONE	VISUAL EXAMINATION	8-26-82	NONE	
NSP-VT-2.0 Rev.0	NONE	VISUAL EXAMINATION OF HANGER ASSEMBLIES	9-2-82	NONE	

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC SCOPES</u>			
NORTEC 131D	S/N 111	12/10/83	OFFSITE 3/10/84
NORTEC 131D	S/N 126	3/13/84	OFFSITE 6/13/84
NORTEC 131D	S/N 129	2/24/84	OFFSITE 4/24/84
NORTEC 131D	S/N 129	4/25/84	OFFSITE 7/25/84
NORTEC 131D	S/N 129	10/18/84	
NORTEC 131D	S/N 167	2/27/84	OFFSITE 5/21/84
NORTEC 131D	S/N 167	5/22/84	OFFSITE 8/21/84
NORTEC 131D	S/N 167	8/23/84	OFFSITE 11/23/84
NORTEC 131D	S/N 269	3/12/84	OFFSITE 6/11/84
NORTEC 131D	S/N 269	6/12/84	OFFSITE 9/12/84
NORTEC 131D	S/N 287	12/29/83	OFFSITE 3/29/84
NORTEC 131D	S/N 287	6/27/84	OFFSITE 9/27/84
NORTEC 131D	S/N 287	10/2/84	OFFSITE 1/2/85
NORTEC 131D	S/N 291	12/21/83	OFFSITE 3/21/83
NORTEC 131D	S/N 311	1/27/84	OFFSITE 4/27/84
NORTEC 131D	S/N 311	10/31/84	
NORTEC 131D	S/N 322	1/26/84	OFFSITE 4/24/84
NORTEC 131D	S/N 322	4/25/84	OFFSITE 5/25/84
NORTEC 131D	S/N 322	6/26/84	OFFSITE 9/26/84
NORTEC 131D	S/N 371	2/27/84	OFFSITE 5/27/84
NORTEC 131D	S/N 410	3/28/84	OFFSITE 6/28/84
NORTEC 131D	S/N 410	9/19/84	OFFSITE 12/19/84
NORTEC 131D	S/N 409	5/21/84	OFFSITE 8/21/84
NORTEC 131D	S/N 417	6/12/84	OFFSITE 9/12/84
NORTEC 131D	S/N 530-B	2/1/84	OFFSITE 4/24/84
NORTEC 131D	S/N 530-B	4/25/84	OFFSITE 7/25/84
<u>ULTRASONIC SCOPES</u>			
SLAVE	S/N 1	3/1/84	
SLAVE	S/N 1	6/5/84	
SLAVE	S/N 2	8/20/84	
SLAVE	S/N 12	12/28/83	
SLAVE	S/N 13	1/12/84	
SLAVE	S/N 14	2/23/84	
SLAVE	S/N 14	6/5/84	
JFS032585WMH01			

NORTHERN STATES POWER COMPANY
MONTICELLO
EQUIPMENT AND MATERIALS

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>RECORDERS</u>			
GOULD BRUSH 220	S/N 3018	2/7/84	OFFSITE 8/7/84
GOULD BRUSH 220	S/N 8188-252	3/30/84	OFFSITE 9/30/84
GOULD BRUSH 220	S/N 08343	12/6/83	OFFSITE 6/6/84
GOULD BRUSH 220	S/N 08343	6/7/84	OFFSITE 12/7/84
GOULD BRUSH 220	S/N 15452	12/1/83	OFFSITE 6/1/84
GOULD BRUSH 220	S/N 18687	2/3/84	OFFSITE 8/3/84
GOULD BRUSH 220	S/N 18687	8/7/84	
GOULD BRUSH 220	S/N 18940	1/5/84	OFFSITE 6/21/84
GOULD BRUSH 220	S/N 18940	6/22/84	OFFSITE 12/22/84
GOULD BRUSH 220	S/N 19016	3/5/84	OFFSITE 8/29/84
GOULD BRUSH 220	S/N 19016	8/30/84	
GOULD BRUSH 220	S/N 19023	3/5/84	OFFSITE 9/5/84
GOULD BRUSH 220	S/N 19023	9/6/84	
<u>TEMPERATURE GAUGES</u>			
PTC Surface Thermometers 0° to 300°F			
	S/N 555	Cal:10/21/83	CERTIFIED BY MANUFACTURER " "
	S/N 559	Cal:10/21/83	
	S/N 563	Cal:10/21/83	
	S/N 566	Cal:11/15/83	
	S/N 569	Cal:11/15/83	
	S/N 570	Cal:11/15/83	
	S/N 572	Cal:11/15/83	
	S/N 574	Cal:11/15/83	
	S/N 582	Cal:11/15/83	
	S/N 583	Cal:11/15/83	
	S/N 584	Cal:11/15/83	
	S/N 585	Cal:11/15/83	
	S/N 586	Cal:11/15/83	
	S/N 587	Cal:11/15/83	
	S/N 590	Cal:3/09/84	
	S/N 591	Cal:3/09/84	
	S/N 592	Cal:3/09/84	
	S/N 597	Cal:3/09/84	
	S/N 598	Cal:3/09/84	
	S/N 599	Cal:3/09/84	
	S/N 605	Cal:3/09/84	
	S/N 608	Cal:3/09/84	
	S/N 612	Cal:5/11/84	
JFS032585WMH01			

NORTHERN STATES POWER COMPANY
 MONTICELLO
 EQUIPMENT AND MATERIALS

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>Temperature Gauges</u> (Continued)	S/N 613 S/N 614 S/N 616 S/N 617 S/N 618 S/N 619 S/N 621 S/N 625 S/N 631 S/N 632 S/N 633 S/N 634 S/N 635 S/N 636 S/N 637 S/N 630 S/N 655	Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:5/11/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84 Cal:7/19/84	Certified By Manufacturer "
<u>MAGNETIC PARTICLE</u> Y-6 Yoke	S/N LMT-003 S/N KBM-3	2/8/84 7/20/84	On Site Qualification
<u>ROMPAS BLOCKS:</u> 4140 C/S 4140 C/S 304 S/S 304 S/S 304 S/S 304 S/S 304 S/S 304 S/S 304 S/S	S/N 403 S/N LMT-012 S/N LMT-008 S/N 021 S/N 3 S/N LMT-026 S/N 4 S/N 310	7/6/82 9/8/77 9/8/77 1/3/79 9/13/76 4/28/81 7/6/82 8/19/83	Earle M. Jorgenson Orla's Machine Shop Orla's Machine Shop Orla's Machine Shop Orla's Machine Shop Dimac Machine Co. Orla's Machine Shop JR Design & Mfg.
<u>IIW BLOCK:</u> A36	S/N LMT 002	5/22/80	Dimac Machine Co.
<u>THICKNESS CALIBRATION</u> <u>STEP B BLOCK:</u> c/s	S/N LMT-001	7/22/80	Dimac Machine Co.
JFS032585WMH01			

NORTHERN STATES POWER COMPANY
 MONTICELLO
 EQUIPMENT AND MATERIALS

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>MATERIALS:</u>			
ULTRASONIC COUPLANT	LMT GEL	Batch # 61384 12484 1110812	
PENETRANT MATERIALS SPOTCHECK	PENETRANT	5F086 83M015 83M051 83M072	SKL-HF/SKL-S
DUBL-CHEK		40D-806 54A-531 329-D54	BY-Lux K017-Hi-Temp
SPOTCHECK	DEVELOPER	5F102 81K118 82G057 83L094 84C057	SKD-NF SKD-NF/ZP-9B
DUBL-CHEK		215C6 223-D71	D-100 D-350 Hi-Temp
SPOTCHECK	CLEANER/REMOVER	5G006 82G049 82G079 82L031 83A002 84B008 83C028 83M043 83M064 84D051	SKC-NF SKC-NF/ZC-7B
DUBL-CHECK		33-K4 329-D56	DR-60 K017-Hi-Temp
JFS032585WMH01			

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC TRANSDUCERS:</u>			
AEROTECH	B17348	SIZE	FREQUENCY
AEROTECH	C29610	.5" DIA.	2.25 MHz
AEROTECH	F26143	.5" DIA.	2.25 MHz
AEROTECH	G22167	.5" DIA.	2.25 MHz
AEROTECH	G22168	.5" DIA.	2.25 MHz
AEROTECH	54018	.5" DIA.	2.25 MHz
AEROTECH	54017	.375" DIA.	3.5 MHz
AEROTECH	016575	.375" DIA.	3.5 MHz
AEROTECH	A30160	1.0" DIA.	2.25 MHz
AEROTECH	E13044	.5" DIA.	2.25 MHz
AEROTECH	H10142	.5" DIA.	2.25 MHz
AEROTECH	54010	.5" DIA.	1.5 MHz
AEROTECH	012674	.375" DIA.	3.5 MHz
AEROTECH	H21033	.5"x.5" DIA.	2.25 MHz
		.5" DIA.	2.25 MHz
HARISONICS	T10224	.5"x.5" DIA.	2.25 MHz
HARISONICS	P360V	.5" DIA.	2.25 MHz
HARISONICS	W1815	.25"x.25"DIA.	5.0 MHz
HARISONICS	W2123	.25" DIA.	5.0 MHz
HARISONICS	T3206	.25" DIA.	5.0 MHz
HARISONICS	R2147	.5"x.5" DIA.	2.25 MHz
HARISONICS	T7463	.5"x.5" DIA.	2.25 MHz
HARISONICS	W6207	.5"x.5" DIA.	2.25 MHz
HARISONICS	V11055	.5"x.5" DIA.	2.25 MHz
HARISONICS	S2285	.5" DIA.	1.5 MHz
HARISONICS	R1150	.25" DIA.	2.25 MHz
HARISONICS	S2286	.5" DIA.	1.5 MHz
HARISONICS	V10704	1.0"x1.0"DIA.	2.25 MHz
HARISONICS	V10705	1.0"x1.0"DIA.	2.25 MHz
HARISONICS	W2149	1.5" DIA.	1.0 MHz
HARISONICS	S5139	1.0" DIA.	2.25 MHz
HARISONICS	T8312	.25" DIA.	5.0 MHz
HARISONICS	8301	.25" DIA.	2.25 MHz
HARISONICS	V12038	.25" DIA.	2.25 MHz
HARISONICS	8402	.375" x	5.0 MHz
		.375" DIA.	
HARISONICS	R30131	.375" x	3.5 MHz
		.375" DIA.	
HARISONICS	W8561	.375" x	2.25 MHz
		.375" DIA.	
HARISONICS	Y2880	.25"x.25"DIA.	2.25 MHz

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC TRANSDUCERS</u>		<u>Size</u>	<u>Frequency</u>
HARISONICS	V11111	.5"x.5" DIA.	1.0 MHz
HARISONICS	V10600	.25" DIA.	5.0 MHz
HARISONICS	Y3410	.5"x.5" DIA.	2.25 MHz
HARISONICS	P928	1.0" DIA.	1.0 MHz
HARISONICS	P927	1.5" DIA.	1.0 MHz
HARISONICS	R3162	.5"x.5" DIA.	2.25 MHz
HARISONICS	R5239	.5"x1.0"DIA.	2.25 MHz
KRAUTKRAMER	56526	12MM x 6MM	2.0 MHz
KRAUTKRAMER	54576	12MM x 6MM	4.0 MHz
NORTEC	978	.75" DIA.	2.25 MHz
NORTEC	979	.75" DIA.	2.25 MHz
PANAMETRICS	11908	.25" DIA.	2.25 MHz
JFS032585WMH01			

APPENDIX D

NIS FORM

OWNER'S DATA REPORT FOR INSERVICE INSPECTIONS

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Apurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B5.10 Nozzle to Safe End Welds</u>				
Standby Liquid Control CPAFR-2	GE/Bechtel	-----	-----	-----
Recirc.Outlets RCAFR-2 RCBFR-2	GE/Bechtel	-----	-----	-----
Recirc.Inlets RRAFR-2 RRDFR-2 RRJFR-2 RRHFR-2 RREFR-2 RRGFR-2 RRBFR-2 RRFFR-2 RRCFR-2 RRKFR-2	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Jet Pump Instrumentation JPAFR-2 JPBFR-2	GE/Bechtel	-----	-----	-----
<u>B5.50 Safe End Welds</u>				
Residual Heat Removal (REW10) RHAFR-4 (TW20) RHBFR-6 RHBFR-23 RHBFR-24 (TW30) RHCFR-6 RHCFR-23 RHCFR-24	GE/Bechtel	-----	-----	-----
Reactor Water Clean Up CWAFR-3R	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B6.230 Bolting</u>				
Recirc."A" M02-53A M02-43A	GE/Bechtel	-----	-----	-----
Recirc."B" M02-53B M02-43B	GE/Bechtel	-----	-----	-----
<u>Pressure Retaining Bolting</u>				
<u>B7.70 Valves Bolts, Studs and Nuts</u>				
Residual Heat Removal (TW20) POS-2019 (TW30) POS-2018	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

B9.10 Nominal Pipe Size
4 in. and Greater

B9.11 & B9.12 Circumferential and Longitudinal Welds

Reactor Water Clean Up	GE/Bechtel	-----	-----	-----
CWAJR-2				
CWAJR-4R				
CWAJR-5R				
CWAJR-6				
CWAJR-7				
CWAJR-8				
CWAJR-9				
CWAJR-10				
CWAJR-11				
CWAJR-12				
CWAJR-13				
CWAJR-13A				
CWAJR-14				
CWAJR-15				
CWAJR-16				
CWAJR-17				
CWAJR-18				
CWAJR-19				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Residual Heat Removal (REW10)	GE/Bechtel	-----	-----	-----
RHAJR-1				
RHAJR-1 to RHAJR-2				
RHAJR-2				
RHAJR-2 to RHAJR-3				
RHAJR-3				
RHAJR-3 to RHAJR-4				
RHAJR-5				
RHAJR-6				
RHAJR-7				
RHAJR-11				
RHAJR-12				
RHAJR-16				
RHAJR-9				
RHAJR-14				
(TW20)				
RHBJR-1				
RHBJR-1 to RHBJR-2				
RHBJR-2				
RHBJR-2 to RHBJR-3				
RHBJR-3				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Residual Heat Removal Cont.

RHBJR-3 to RHBJR-4
 RHBJR-4
 RHBJR-4 to RHBJR-5
 RHBJR-5
 RHBJR-5 to RHBJR-6
 RHBJR-7
 RHBJR-8
 RHBJR-12
 RHBJR-13
 RHBJR-14
 RHBJR-14A
 RHBJR-15
 RHBJR-16
 RHBJR-17
 RHBJR-18
 RHBJR-19
 RHBJR-25
 RHBJR-10
 RHBJR-21
 (TW30)
 RHCJR-1
 RHCJR-1 to RHCJR-2
 RHCJR-2

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Residual Heat Removal Cont.

- RHCJR-2 to RHCJR-3
- RHCJR-3
- RHCJR-3 to RHCJR-4
- RHCJR-4
- RHCJR-4 to RHCJR-5
- RHCJR-5
- RHCJR-5 to RHCJR-6
- RHCJR-7
- RHCJR-8
- RHCJR-12
- RHCJR-13
- RHCJR-14
- RHCJR-15
- RHCJR-16
- RHCJR-17
- RHCJR-18
- RHCJR-19
- RHCJR-25
- RHCJR-10
- RHCJR-21
- (TW40)
- RHEJR-2
- RHEJR-3
- RHEJR-4

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Residual Heat Removal Cont.

- RHEJR-5
- RHEJR-6
- RHEJR-7
- RHEJR-8
- RHEJR-9
- RHEJR-10
- RHEJR-10A
- RHEJR-11
- RHEJR-12
- RHEJR-13
- RHEJR-14
- RHEJR-15
- RHEJR-16
- RHEJR-17
- RHEJR-18
- RHEJR-19
- RHEJR-21
- RHEJR-22
- RHEJR-23
- RHEJR-24
- RHEJR-25
- RHEJR-26
- RHEJR-27
- RHEJR-28

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Residual Heat Removal Cont.

RHEJR-29
 RHEJR-30
 RHEJR-31
 RHEJR-32
 RHEJR-33
 RHEJR-34

<u>Recirc."A"</u>	<u>GE/Bechtel</u>	<u>-----</u>	<u>-----</u>	<u>-----</u>
-------------------	-------------------	--------------	--------------	--------------

RCAFR-2 to RCAJR-3
 RCAJR-3
 RCAJR-3 to RCAJR-4
 RCAJR-4
 RCAJR-4 to RCAJR-4A
 RCAJR-4A
 RCAJR-4A to RCAJR-5
 RCAJR-5
 RCAJR-5 to RCAJR-7
 RCAJR-7
 RCAJR-7 to RCAJR-8
 RCAJR-8
 RCAJR-8 to RCAJR-9
 RCAJR-9

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
--------------------------------------	--------------------------------------	---	----------------------------------	-------------------------------

Recirc."A" cont.

RCAJR-9 RCAJR-10
 RCAJR-10
 RCAJR-10 to RCAJR-11
 RCAJR-11
 RCAJR-12
 RCAJR-12 to RCAJR-15
 RCAJR-15
 RCAJR-15 to RCAJR-16
 RCAJR-16
 RCAJR-17
 RCAJR-17 to RCAJR-20
 RCAJR-20
 RCAJR-21
 RCAJR-21 to RCAJR-22
 RCAJR-22
 RCAJR-22 to RCAJR-23
 RCAJR-23
 RCAJR-23 to RCAJR-24
 RCAJR-24
 RCAJR-24 to RCAJR-25
 RCAJR-25

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc."B"	GE/Bechtel	-----	-----	-----
RCBFR-2 to RCBJR-3				
RCBJR-3				
RCBJR-3 to RCBJR-4				
RCBJR-4				
RCBJR-4 to RCBJR-5				
RCBJR-5				
RCBJR-5 to RCJBR-6				
RCBJR-6				
RCBJR-6 to RCJBR-7				
RCBJR-7				
RCBJR-7 to RCJBR-8				
RCJBR-8				
RCJBR-8 to RCBJR-9				
RCBJR-9				
RCBJR-10				
RCBJR-10 to RCBJR-13				
RCBJR-13				
RCBJR-13 to RCBJR-14				
RCBJR-14				
RCBJR-15				
RCBJR-15 to RCBJR-18				
RCBJR-18				
RCBJR-19				
RCBJR-19 to RCBJR-20				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Recirc."B" cont.

RCBJR-20
 RCBJR-20 to RCBJR-21
 RCBJR-21
 RCBJR-21 to RCBJR-22
 RCBJR-22
 RCBJR-22 to RCBJR-23
 RCBJR-23

Recirc.
 Manifold "A"

GE/Bechtel

RMAJR-1 to RRFJR-7
 RMAJR-1
 RMAJR-1 to RMAJR-2
 RMAJR-2
 RMAJR-2 to RMAJR-3
 RMAJR-3
 RMAJR-3 to RMAJR-3A
 RMAJR-3A
 RMAJR-4
 RMAJR-5
 RMAJR-5 to RMAJR-5A
 RMAJR-5A
 RMAJR-5 to RMAJR-6

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Recirc."A" cont.

RMAJR-6
 RMAJR-6 to RMAJR-7
 RMAJR-7
 RMAJR-7 to RRKJR-7
 RCAJR-25 to RMAJR-4
 RMAJR-4 to RRHJR-4

<u>Recirc. Manifold "B"</u>	<u>GE/Bechtel</u>	<u>-----</u>	<u>-----</u>	<u>-----</u>
-----------------------------	-------------------	--------------	--------------	--------------

RMBJR-1 to RREJR-7
 RMBJR-1
 RMBJR-1 to RMBJR-2
 RMBJR-2
 RMBJR-2 to RMBJR-3
 RMBJR-3
 RMBJR- 3 to RMBJR-3A
 RMBJR-3A
 RMBJR-4
 RMBJR-5
 RMBJR-5 to RMBJR-5A
 RMBJR-5A
 RMBJR-6
 RMBJR-6 to RMBJR-7
 RMBJR-7
 RMBJR-7 to RRAJR-7
 RCBJR-23 to RMBJR-4
 RMBJR-4 to RRCJR-4

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc. Risers	GE/Bechtel	-----	-----	-----
Riser F				
RRFJR-3				
RRFJR-4				
RRFJR-4 to RRFJR-5				
RRFJR-5				
RRFJR-5 to RRFJR-6				
RRFJR-6				
RRFJR-6 to RRFJR-7				
RRFJR-7				
Riser G				
RRGJR-3				
RRGJR-4				
RRGJR-4 to RRGJR-5				
RRGJR-5				
Riser H				
RRHJR-3				
RRHJR-4				
Riser J				
RRJJR-3				
RRJJR-4				
RRJJR-4 to RRJJR-5				
RRJJR-5				
Riser K				
RRKJR-3				
RRKJR-4				
RRKJR-4 to RRKJR-5				
RRKJR-5				
RRKJR-5 to RRKJR-6				
RRKJR-6				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

Recirc. Risers Cont.

RRKJR-6 to RRKJR-7
 RRKJR-7

Riser A

RRAJR-3
 RRAJR-4
 RRAJR-4 to RRAJR-5
 RRAJR-5
 RRAJR-5 to RRAJR-6
 RRAJR-6
 RRAJR-6 to RRAJR-7
 RRAJR-7

Riser B

RRBJR-3
 RRBJR-4
 RRBJR-4 to RRBJR-5
 RRBJR-5

Riser C

RRCJR-3
 RRCJR-4

Riser D

RRDJR-3
 RRDJR-4
 RRDJR-4 to RRDJR-5
 RRDJR-5

Riser E

RREJR-3
 RREJR-4
 RREJR-4 to RREJR-5
 RREJR-5
 RREJR-5 to RREJR-6
 RREJR-6
 RREJR-6 to RREJR-7
 RREJR-7

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B9.20 Nominal Pipe Size Less Than 4 in.</u>				
<u>B9.21 & B9.22 Circumferential and Longitudinal Welds</u>				
Standby Liquid Control	GE/Bechtel	-----	-----	-----
CPAJR-3				
CPAJR-4				
CPAJR-6				
<u>B9.30 Branch Connections</u>				
<u>B9.31 Nominal Pipe Size Greater than 2"</u>				
RWCU	GE/Bechtel	-----	-----	-----
CWAJR-1				
RHR"A"	GE/Bechtel	-----	-----	-----
RHAJR-8				
RHAJR-13				
RHEJ-20				
RHR"B"	GE/Bechtel	-----	-----	-----
RHBJR-9				
RHBJR-20				
RHEJ-37				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

B9.31 Nominal Pipe Size Greater than 2" Cont.

RHR"C"	GE/Bechtel	-----	-----	-----
RHCJR-9				
RHCJR-20				
RHEJ-1				

B9.32 Nominal Pipe Size less than 2"

Recirc Drains A & B	GE/Bechtel	-----	-----	-----
RCAJR-13				
RCAJR-18				
RCBJR-11				
RCBJR-16				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
B10.10 Integrally Welded Attachment and B11.10 Component Supports				
Reactor Water Clean Up CWAK-14	GE/Bechtel	-----	-----	-----
Recirc."A" RCAKR-12A RCAKR-16 RCAKR-18 RCAKR-21 RCAKR-33A PHAR-3 PHAR-4 PHAR-5 PSSAR-4A PSSAR-4B PSSAR-5 RCAKR-22 RCAKR-24A RCAKR-24B	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc."B" RCBKR-10A RCBKR-14 RCBKR-16 RCBKR-19 RCBKR-32A PHBR-3 PHBR-6 PHBR-7 PSSBR-4A PSSBR-4B RCBKR-20 RCBKR-25 RCBKR-25A	GE/Bechtel	-----	-----	-----
Recirc. Manifold"A" RMAKR-4 RMAKR-6 RMAKR-13 RMAKR-13B	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc. Manifold"B" RMBKR-4 RMBKR-6A RMBKR-13 RMBKR-13C	GE/Bechtel	-----	-----	-----

B11.10 Component Supports

Reactor Water Clean-up CWAK-11	GE/Bechtel	-----	-----	-----
Residual Heat Removal (REW10) RHA KR-8 RHA KR-13 RHA KR-14 RHA KR-19 RHA KR-22 (TW20) RHBKR-10 RHBKR-12 RHBKR-18 RHBKR-23	GE/Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

B11.10 Component Supports Cont.

(TW30)
 RHCKR-9
 RHCKR-10
 RHCKR-17A
 RHCKR-24

(TW40)
 RHEK-10
 RHEK-12
 RHEK-23
 RHEK-25

Recirc."A"	GE/Bechtel	-----	-----	-----
------------	------------	-------	-------	-------

RCAK-6
 RCAK-12
 RCAKR-12B
 RCAKR-29
 RCAKR-30A
 RCAK-33
 RCAKR-33B
 RCAK-34

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc."B"	GE/Bechtel	-----	-----	-----
RCBK-8				
RCBK-10				
RCBKR-10B				
RCBKR-27				
RCBKR-29				
RCBK-32				
RCBKR-32A				
RCBKR-32B				
RCBK-33				
Recirc. Manifold"A"	GE/Bechtel	-----	-----	-----
RMAK-11				
Recirc. Manifold"B"	GE/Bechtel	-----	-----	-----
RMBK-13A				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT
 Address: MONTICELLO MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Recirc. Risers"A"	GE/Bechtel	-----	-----	-----
RRFK-6				
RRGK-6				
RRHK-6				
RRJK-6				
RRKK-6				
Recirc. Risers"B"	GE/Bechtel	-----	-----	-----
RRAK-6				
RRBK-6				
RRCK-6				
RRDK-6				
RREK-6				

FORM NIS-1 (back)

- 8.) Examination Dates 2/10/85 to 1/12/85
 9.) Inspection Interval 6/30/81 to 6/30/91
 10.) Abstract of Examinations.

This Baseline Examination was conducted in Inspection Period One of the Plant's second ten year interval. The examinations were performed on pressure retaining componenets and their supports of the reactor coolant and associated auxiliary systems classified as ASME Class I.

- 11.) Abstract of Conditions Noted.

The following is a list of all anomalies detected:

<u>System</u>	<u>Item ID</u>	<u>Exam Method</u>	<u>Type & No. of Indications</u>	
Recirc."A"	RCAJR-4A to RCAJR-5	PT	1 - 1/4" Linear	
	RCAJR-7 to RCAJR-8	PT	1 - 1/8" slug of metal in weld	
	RCAJR-15 to RCAJR-16 (I.R.)	PT	1 - linear	
	RCAJR-15 to RCAJR-16 (O.R.)	PT	5 - linears	
	RCAJR-17	PT	ARC strike, multiple linears	
	RCAJR-24 to RCAJR-25	PT	1 - linear	
	RRKJR-5	PT	1 linear, 4 rounded	
	RRKJR-7	PT	1 linear, 4 rounded	
	RCAKR-12A VT	VT	loose nut	
	RCAKR-21	PT	1 linear	
	RCAKR-33A(W-8)	PT	1 linear	
	RCAKR-33A(W-9)	PT	Multiple linears	
	RCAKR-33A	VT	loose nut	
	RHAR-4	VT	loose nut	
	RCAKR-29	VT	loose nut	
	RRHK-6	VT	loose nuts	
	Recirc."B"	RCBJR-3 to RCBJR-4	PT	2 linears
		RCBJR-4	PT	2 linears
		RCBJR-7 to RCBJR-8	PT	1 linear
		RCBJR-8 to RCBJR-9	PT	2 linears
RCBJR-10		PT	intermittent linear	
RCBJR-13		PT	3 linears	
RCBJR-14		PT	1 linear	
RCBJR-15 to RCBJR-18		PT	1 linear	
RCBJR-20		PT	1 linear	

	RCBJR-21 to	PT	crater crack
	RCBJR-22		
	RRDJR-4 to	PT	1 linear
	RRDJR-5		
	RCBKR-10A(W-1)	PT	2 linears
	RCBKR-10A(W-2)	PT	2 linears
	RCBKR-10A(W-4)	PT	multiple linears
	RCBKR-10A	VT	loose nuts
	RCBKR-32A(W-8)	PT	4 rounded, 1 linear
	RCBKR-32A(W-9)	PT	1 linear
	RCBKR-32A(W-10)	PT	multiple linears
	RCBKR-27	VT	loose nut
	RRAK-6	VT	loose nuts
RHR	POS 2018	VT	loose nuts
	RHAJR-3	PT	3 linears
	RHBJR-7	MT	4 linears
	RHAKR-8	VT	no weep hole
	RHBKR-12	VT	not attached to wall
	RHBKR-18	VT	no weep hole
	RHCKR-9	VT	not attached to wall
	RHCKR-17A	VT	no weep hole
	RHCKR-24	VT	no weep hole

12.) Abstract of Corrective Measures Recommended and Taken.

All anomalies were corrected. Loose nuts and bolts were tightened. PT and MT linear and rounded indications were removed by surface blending with a hand grinder. On component supports, weepholes were installed and those supports not attached, were attached to their respective walls.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date 10/10 19 85 Signed Matheson States Power Co. By J. J. Schaner
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MINNESOTA and employed by HSB I-I-I Co. of HARTFORD, MN have inspected the components described in this Owner's Data Report during the period 2/14/84 to 1/12/85, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date Oct. 10 19 85

R. J. Kuyler
Inspector's Signature

Commissions NB 9904, MA 85-34
National Board, State, Province & No