



- NOTES:**
1. FOR GENERAL NOTES, SEE DWG. M-0035A.
 2. DELETED.
 3. DELETED.
 4. DELETED.
 5. DELETED.
 6. 10\"/>
 7. VALVE IS LOCKED CLOSED BECAUSE UNIT 2 PIPING IS NOT INSTALLED OR INCOMPLETE.
 8. DRAWING M-0035S & M-0035T ARE VOIDED BY MCP 92/1092. DESIGN FOR NEW UNIT 2 FIRE PROTECTION SYSTEMS IS PROVIDED ON VENDOR DRAWINGS DEVELOPED BY UNITED PIPING SYSTEMS, INC., UNDER CONTRACT G-3479. REFERENCE FACILITIES PROJECTS PACKAGE No. 92-001, "UNIT 2 FP UPGRADE", FOR DETAILS.
 9. TEMPORARY HYDRANT IS TAGGED "ABANDONED IN PLACE". HYDRANT VALVE IS CLOSED AND OPERATING NUT HAS BEEN REMOVED. ASSOCIATED ISOLATION VALVE IS LOCKED CLOSED.

COMPONENTS SUBJECT TO AMR
 FIRE PROTECTION WATER SYSTEM AMM15

No.	REV	ENG	CHKD	APPR	DATE
013	AS-BUILT PER DRN 7977	WC	N/A	N/A	5-7-02
012	AS-BUILT PER DRN 7285	SIGN-OFF			ON RECORD

GRAND GULF NUCLEAR STATION					
UNIT 1					
NUCLEAR PLANT ENGINEERING					
UPDATED FINAL SAFETY ANALYSIS REPORT					
FIGURE NUMBER - 9.5-008B					
P. & I. DIAGRAM					
FIRE PROTECTION SYSTEM					
UNIT 1					

MPL No. SP64 1015M	SCALE: NONE	DRAWING No. M-0035K	REV. 013
--------------------	-------------	---------------------	----------

DFN: m0035k.dgn

NO	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-0035K						