



- NOTES:
- FOR NOTES SEE DRAWING M-1069A.
 - SUPPLY WITH CONDENSATE DEMINERALIZER CONTROL PANEL.
 - COORD.FLAG () PARENTICAL NUMBER REFERS TO SAMPLE CONDITIONS; SEE IDENTICALLY NUMBERED SAMPLE POINTS IN SYSTEM DESCRIPTION SD-1069 PAR.3.1.3.
 - DELETED.
 - DELETED.
 - GRAB SAMPLING SHALL BE DESIGNED AS "FLOW THROUGH SAMPLING CYLINDER" WITH QUICK CONNECTION FITTINGS.
 - COOLING COIL/IX WITH WATERS TEMPERATURE CONTROL VALVE.

020	AS-BUILT PER DRN 84-461	SIP	N/A	N/A	MC	5-1-2007
019	AS-BUILT PER DRN 84-714	MC	SIGN-OFF	ON RECORD		

GRAND GULF NUCLEAR STATION
 UNIT 1
 NUCLEAR PLANT ENGINEERING
UPDATED FINAL SAFETY ANALYSIS REPORT
 FIGURE NUMBER - 9.3-006
P&I DIAGRAM
PROCESS SAMPLING SYSTEM

SCALE: NONE DRAWING No. M-1069B REV. 020
 HYBRID DFN: m1069b.dgn

COMPONENTS SUBJECT TO AMR
 NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMR20

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1069B						
CAD FILE: m1069b.dgn						
MASTER FILE:						

D189