

Davis-BesseNPEm Resource

From: CuadradoDeJesus, Samuel
Sent: Tuesday, August 02, 2011 10:59 AM
To: 'custerc@firstenergycorp.com'; dorts@firstenergycorp.com
Subject: Additioanl topic for today's Teleconference

Cliff:

Below is our concern with the OTI enhancement. Let me know if we can still discuss this issue on today's teleconference or if you'll rather discuss this later.

LRA Section B.2.30's amendment dated June 3, 2011 states an enhancement that the "scope" program element is to include visual and volumetric inspections of the stainless steel makeup pump casings for cracking due to cyclic loading but it does not state what type of visual examinations will be used to detect cracking.

The GALL AMP XI.M32, "One-Time Inspection" states in the "detection of aging effects" program element that the program manages cracking due to cyclic loading using enhanced visual (EVT-1 or equivalent), surface, or volumetric examinations.

Some types of visual examination may not be sufficient to identify cracking and it is unclear what visual examinations will be performed to meet this need.

The NRC is requesting a discussion, followed by a docketed letter response later, of the type of visual examinations that will be used to identify cracking as part of the One-Time Inspection Program.

Regards,

Samuel Cuadrado de Jesús

Project Manager

Projects Branch1

Division of License Renewal

U.S. Nuclear Regulatory Commission

Phone: 301-415-2946

Samuel.CuadradoDeJesus@nrc.gov

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 3094

Mail Envelope Properties (Samuel.CuadradoDeJesus@nrc.gov20110802105800)

Subject: Additioanl topic for today's Teleconference
Sent Date: 8/2/2011 10:58:38 AM
Received Date: 8/2/2011 10:58:00 AM
From: CuadradoDeJesus, Samuel

Created By: Samuel.CuadradoDeJesus@nrc.gov

Recipients:
"custerc@firstenergycorp.com" <custerc@firstenergycorp.com>
Tracking Status: None
"dorts@firstenergycorp.com" <dorts@firstenergycorp.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1391	8/2/2011 10:58:00 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: