

171

**Martin, Robert**

---

**From:** Khanna, Meena *meena*  
**Sent:** Friday, September 16, 2011 5:38 PM  
**To:** Karwoski, Kenneth; Stuchell, Sheldon  
**Cc:** Manoly, Kamal; Wilson, George; Boyle, Patrick; Martin, Robert  
**Subject:** North Anna Acceptance Criteria R2 Comments.docx  
**Attachments:** North Anna Acceptance Criteria R2 Comments.docx

Ken and Sheldon,

Attached are some comments that we received regarding the proposed acceptance criteria from Gerry McCoy in Region II. Could we pls meet on Monday to discuss and then conduct a call with him? I plan to go ahead and send the proposed acceptance criteria to OGC so that we can obtain input from them in parallel.

Thanks!

Meena

*D* / 171

**Short-Term Technical Acceptance Criteria  
For Demonstrating The Acceptability For North Anna Plant Restart**

Confirm the adequacy of the scope of the licensee's inspections, tests and analyses which demonstrate that no functional damage resulted from the earthquake to systems, subsystems, trains, components and devices (systems, structures, or components [SSCs]) for the current licensing basis (1) that are required to be operable by TSs, (2) SSCs not explicitly required to be operable by TSs, but that perform required support functions to maintain a TS required system operable; and (3) SSCs that are not described in TSs but which warrant programmatic controls to ensure that SSC availability and reliability are maintained. Refer to NRC Inspection Manual Part 9900, "Operability Determinations and Functionality Assessments for Resolution of Degraded or NonConforming Conditions Adverse to Quality or Safety" for more detailed guidance for determinations of operability and resolution of degraded or nonconforming conditions.