

Exelon Nuclear

Job Performance Measure

Calculate a Reactivity Change

JPM Number: RA 1a

Revision Number: 01

Date: 10/17/2011

Developed By: Bill Hochstetter 10/17/2011
Instructor Date

Validated By: Brain Lewin 11/6/2011
SME or Instructor Date

Approved By: Rob Lawlor 11/6/2011
Facility Representative Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, simulator, or other)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating cue (and terminating cue if required) are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure OP-AP-300-1004 Rev: 2
 Procedure _____ Rev: _____
 Procedure _____ Rev: _____
- _____ 9. Verify cues both verbal and visual are free of conflict.
- _____ 10. Verify performance time is accurate
- _____ 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)**Revision 01** Initial revision of JPM

Comment	Resolution
Revised JPM for 2012 NRC Exam	

INITIAL CONDITIONS:

1. Unit 1 is at 95% power, 6200 EFPH, 892 ppm boron, with CB D at 215 steps.
2. Tave is 1 degree less than Tref.

INITIATING CUES:

1. The QNE has advised Control Bank D should be withdrawn to 221 steps to control PDMA02 on the desired target.
 2. The US has directed you to calculate a reactivity change, utilizing OP-AP-300-1004, that will allow rod withdrawal and match Tave to Tref keeping turbine load constant.
- Provide blank copy of OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements
 - Provide copy of Unit 1 Rema Thumbrules

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* **Denotes critical steps 2 & 3**

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

TASK STANDARDS:

1. Evaluate the reactivity change to match Tave to Tref
2. Calculate the Reactivity Change Determination Form.

MATERIALS:

- Blank copy of OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements
- Unit 1 Rema Thumbrules at 6211 EFPH

RECORD START TIME: _____

EVALUATOR NOTE: These steps may be performed in any order.					
STEP	ELEMENT	STANDARD	SAT	UNSAT	CMT#
CUE	Provide copy of OP-AP-300-1004 and a copy of the Unit 1 Rema thumbrules				
1	Refer to <ul style="list-style-type: none"> OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements Unit 1 Rema Thumbrules 	In accordance with the provided: <ul style="list-style-type: none"> OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements Unit 1 Rema Thumbrules 	_____	_____	_____
*2	Compute Attachment 1 of OP-AP-300-1004	<ul style="list-style-type: none"> Station: Byron Unit: 1 Date and time Desired change <ul style="list-style-type: none"> Withdraw Rods 6 steps for PDMA02 control Raise RCS temp. 1 degree Reason for change (per QNE recommendation) <ul style="list-style-type: none"> PDMA02 control Temperature control What is the method & am't for the reactivity change? <ul style="list-style-type: none"> 6 steps withdrawal of CB D 224 gallons dilution per 1 degree F change Inputs <ul style="list-style-type: none"> Rema thumbrules 	_____	_____	_____
NOTE: The correctly calculated numbers are listed below.					
*3	Evaluate calculation	<ul style="list-style-type: none"> Calculation of change (Uses numbers as calculated above) <ul style="list-style-type: none"> 6 steps of Control Bank D at 100% power: Tave-Tref = 1/2° rise in temperature -1° + 0.5° (mismatch after rod movement) = -0.5° 224 gallons PW/1° x .5° = 112 gallons dilution 			
CUE	This JPM is complete.				

RECORD STOP TIME: _____

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

- 1 Unit 1 is at 95% power, 6200 EFPH, 892 ppm boron, with CB D at 215 steps.
- 2 Tave is 1 degree less than Tref.

INITIATING CUES:

1. The QNE has advised Control Bank D should be withdrawn to 221 steps to control PDMA02 on the desired target.
- 2 The US has directed you to calculate a reactivity change, utilizing OP-AP-300-1004, that will allow rod withdrawal and match Tave to Tref keeping turbine load constant.

Exelon Nuclear

Job Performance Measure

Perform Offsite AC Power Availability Surveillance (ACB 2424 OOS)

JPM Number: RA-1.b

Revision Number: 11

Date: 10/21/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/21/2011</u> Date
-------------	---------------------------------------	---------------------------

Validated By:	<u>Brain Lewin</u> SME or Instructor	<u>11/06/2011</u> Date
---------------	-----------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date
--------------	----------------------------------------------	---------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure 1BOSR 8.1.1-1 Rev: 009
 Procedure _____ Rev: _____
 Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)

Revision 11

Revised to current format

SIMULATOR SETUP INSTRUCTIONS

- 1) Reset to IC-21

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

- 2) When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
- 3) This completes the setup for this JPM

INITIAL CONDITIONS

1. You are an extra NSO.
2. Unit 1 is in Mode 1, steady state power.

INITIATING CUE

1. The 1A DG has been declared inoperable and the US has directed you to perform 1BOSR 8.1.1-1, Normal and Reserve Offsite AC Power Availability Weekly Surveillance.
2. An SRO has signed and dated the 1BOSR 8.1.1-1 data package cover sheet.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p align="center">Provide examinee with a copy of 1BOSR 8.1.1-1 to complete</p>				
<p>1. Circle status of offsite power sources.</p> <p>Note: The bus alive light alone is NOT adequate verification of bus status.</p>	<p>At 0PM03J, OBSERVE bus alive lights, line amps, and MWs for all 345 KV lines:</p> <ul style="list-style-type: none"> ◦ Line 0621 ◦ Line 0627 ◦ Line 0624 ◦ Line 0622 ◦ CIRCLE 'energized' for all 345 KV lines 	_____	_____	_____
<p>2. Indicate status of disconnects, breakers and SAT links</p> <p>Cue: <u>Both units SAT x-tie links are REMOVED</u></p> <p>Cue: <u>Both units SAT disconnect links are INSTALLED</u></p>	<p>INDICATE:</p> <ul style="list-style-type: none"> • Open disconnects, breakers and removed SAT links using " O " • Closed disconnects, breakers and installed SAT links using " X " 	_____	_____	_____
<p>3. Trace path along dashed lines from any energized offsite power source to the unit <u>ONE</u> SAT banks</p>	<p>TRACE path correctly on data sheet:</p> <ul style="list-style-type: none"> • Line energized, breakers and disconnects closed 	_____	_____	_____
<p>4. Trace second path from second independent power source to unit <u>TWO</u> SAT bank.</p>	<p>TRACE SECOND path correctly on data sheet:</p> <ul style="list-style-type: none"> • Line energized, breakers and disconnects closed 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*5. Verify independent paths exist from offsite power thru switchyard to both units SAT banks	Verify independent paths <ul style="list-style-type: none"> • L0621 and L0622 NOT BOTH used • Two paths DO NOT overlap • ENTER 'Yes' for step 5 of data sheet 	_____	_____	_____
*6. Check normal and reserve 345 KV buses energized	At 0PM03J, VERIFY bus alive light and voltmeter indications for: <ul style="list-style-type: none"> • 345 KV bus 6 • 345 KV bus 13 ENTER 'Yes' for steps 6a and 6b on data sheet	_____	_____	_____
*7. Check normal and reserve power SATs available <i>Cue: <u>SATs 242-1 and 242-2</u> <u>ENERGIZED</u></i>	At 1/2PM01J, VERIFY 'X' and 'Y' winding MW and amps indication for: <ul style="list-style-type: none"> • SATs 142-1 and 142-2 • SATs 242-1 and 242-2 ENTER 'Yes' for steps 7a and 7b on data sheet	_____	_____	_____
*8. Check ESF buses 141 and 142 energized	At 1PM01J, CHECK bus alive lights, SAT feeder breaker to bus position and bus voltmeter indication for: <ul style="list-style-type: none"> • Bus 141 • Bus 142 ENTER 'Yes' for steps 8a and 8b on data sheet	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>*9. CHECK ESF buses 241 and 242 energized</p> <p>Cue: <u>BUS 241 BUS ALIVE light is LIT and voltage is normal</u></p> <p>Cue: <u>BUS 242 BUS ALIVE light is LIT and voltage is normal</u></p>	<p>At 2PM01J, CHECK bus alive lights, SAT feeder breaker to bus position and bus voltmeter indication for:</p> <ul style="list-style-type: none"> • Bus 241 • Bus 242 <p>ENTER 'Yes' for steps 9a and 9b on data sheet</p>	_____	_____	_____
<p>*10. Check SAT Feed breakers are closed and connected</p> <p>Cue: <u>ACB 2412 'GREEN' light LIT</u></p> <p>Cue: <u>ACB 2422 'GREEN' light LIT</u></p>	<p>At 1/2PM01J, VERIFY position and control power available:</p> <ul style="list-style-type: none"> • ACB 1412 • ACB 2412 • ACB 1422 • ACB 2422 <p>ENTER 'Yes' for steps 10a through 10d on data sheet</p>	_____	_____	_____
<p style="text-align: center;"><u>NOTE</u></p> <p style="text-align: center;">Faulted portion of JPM is initiated in the following step.</p>				
<p>*11. Check SAT Reserve Feed breakers are closed and connected</p> <p>Cue: <u>ACB 2414 'GREEN' light LIT</u></p> <p>Cue: <u>ACB 2424 control switch is in PTL and OOS</u></p>	<p>At 1/2PM01J, VERIFY position and control power available:</p> <ul style="list-style-type: none"> • ACB 1414 • ACB 1424 • ACB 2414 • ACB 2424 <p>ENTER 'No' for step 11d and 'Yes' for steps 11a through 11c on data sheet</p>	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*12. Determine acceptance criteria are NOT met	<ul style="list-style-type: none"> DETERMINE acceptance criteria are NOT MET 	—	—	—
13. Notify US that acceptance criteria are not met Cue: <u>US has verified 1BOL 8.1 has been implemented.</u>	<ul style="list-style-type: none"> Notify US verbally or by checking NO and writing in Remarks on cover sheet. 	—	—	—
Cue: <u>This JPM is completed.</u>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Perform Offsite AC Power Availability Surveillance (ACB 2424 OOS)

JPM Number: RA 1 (N-75a) Revision Number: 11

Task Number and Title: 4C.AP-06 Perform the Offsite AC Power Availability Surveillance.

K/A Number and Importance: 2.1.31 4.6

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

1BOSR 8.1.1-1, Rev 9, Normal and Reserve Offsite AC Power Availability Weekly Surveillance
CRITICAL STEPS (*) 5 through 12

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments:

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an extra NSO.
2. Unit 1 is in Mode 1, steady state power.

INITIATING CUE

1. The 1A DG has been declared inoperable and the US has directed you to perform 1BOSR 8.1.1-1, Normal and Reserve Offsite AC Power Availability Weekly Surveillance.
2. An SRO has signed and dated the 1BOSR 8.1.1-1 data package cover sheet.

Job Performance Measure

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure P & ID M-46 sht.1B Rev: AR
9. Procedure Schematic 6E-1-4030CS06 Rev: M

10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)

Revision 0

- Modified from Braidwood. Rev. 0 at Byron

INITIAL CONDITIONS

1. You are an extra NSO.
2. Both units are at 100% steady state power.
3. The Aux. Building EO has just reported 1CS043A, 1A CS EDUC INLET HDR DRN CONN ISOL VLV, has a leak at the welded inlet connection to the valve.

INITIATING CUE

1. The Shift Manager has directed you to recommend mechanical isolation points for the leak as close as possible to the source and report back with your recommendation.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

*- Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;">NOTE</p> <p style="text-align: center;">Once the examinee demonstrates the ability to locate the required mechanical print, provide a copy of print M-46 sheet 1B</p>				
1. Locate correct P& ID Note: When examinee determines M-46 sheet 1B is required, then provide copy of M-46 sheet 1B.	<ul style="list-style-type: none"> • LOCATE M-46 sheet 1B <ul style="list-style-type: none"> ○ Use computer such as Passport or EDMS ○ Use P&ID book 	_____	_____	_____
*2 Determine upstream acceptable isolation point	<ul style="list-style-type: none"> • Refers to M-46 sheet 1B and determine upstream isolation point is 1CS046A – CLOSED. 	_____	_____	_____
*3. Determine downstream acceptable isolation points	<ul style="list-style-type: none"> • Refers to M-46 sheet 1B and determine downstream isolation point is 1CS019A – CLOSED. 	_____	_____	_____
4. Shift Manager notified Cue: <u>The SM requests that you identify the breaker to be opened to provide electrical isolation for the MOV.</u>	<ul style="list-style-type: none"> ◦ NOTIFY SM of Isolation points 	_____	_____	_____
5. Locate correct schematic Note: When examinee determines 6E-1-4030CS06 is required, then provide copy of 6E-1-4030CS06 .	<ul style="list-style-type: none"> • LOCATE 6E-1-4030CS06 <ul style="list-style-type: none"> ○ Use computer such as Passport or EDMS ○ Use Electrical Schematic book 	_____	_____	_____
*6. Determines Breaker to be opened to provide Electrical Isolation. Cue: <u>This JPM is complete.</u>	<ul style="list-style-type: none"> • Determine 480VAC MCC 131X1 Compt. K2 is correct breaker to be opened and Notify SM. 	_____	_____	_____

RECORD STOP TIME: _____

INITIAL CONDITIONS

1. You are an extra NSO.
2. Both units are at 100% steady state power.
4. The Aux. Building EO has just reported 1CS043A, 1A CS EDUC INLET HDR DRN CONN ISOL VLV, has a leak at the welded inlet connection to the valve.

INITIATING CUE

The Shift Manager has directed you to recommend isolation points for the leak as close as possible to the source and report back to him with your recommendation.

Exelon Nuclear

Job Performance Measure

Change RM-11 Setpoints in Preparation for a Unit 1 Containment Release

JPM Number: RA-3

Revision Number: 5

Date: 12/30/2011

Revised By:	<u>Bill Hochstetter *</u> Instructor	<u>12/30/2012</u> Date
-------------	-----------------------------------------	---------------------------

Validated By:	<u>*</u> SME or Instructor	<u> </u> Date
---------------	-------------------------------	-------------------------------------

Approved By:	<u>*</u> Facility Representative	<u> </u> Date
--------------	-------------------------------------	-------------------------------------

* Signature on File

See File Copy

- | | |
|-----------------------------------|------------|
| W. Hochstetter(Signature on file) | 12/30/2011 |
| SME / Instructor | Date |
| (Signature on file) | |
| SME / Instructor | Date |
| | |
| SME / Instructor | Date |

Revision Record (Summary)

Revision 4

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator

Revision 5

- Generated a new BCP 400-Tcnmt/routine

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Ensure that either the 0A or 0B Aux Building Exhaust Fan is in operation.
3. Verify that the RM-11 values for the appropriate channels agree with the surveillance paperwork and Supervisory key for the RM-11 available.
4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
5. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. A Unit 1 Containment release is pending.
3. 1PR11J is inoperable.

INITIATING CUE

You have been instructed to perform Section 4 of BCP 400-TCNMT/ROUTINE in preparation for this release.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the <u>underlined</u> cue needs to be provided to the examinee.</p> <p>To initiate this JPM, hand the partially completed BCP 400-TCNMT/ROUTINE to the examinee.</p>				
1. Refer to the partially completed BCP 400-TCNMT/ROUTINE Cue: (if asked) Section 2 has been verified along with the RETDAS Gaseous Release Rate printouts.	° REVIEW BCP 400-TCNMT/ROUTINE for completeness up to Section 3	_____	_____	_____
2. Complete daily channel checks Cue: <u>The daily channel check of 1RE-PR001 has been performed satisfactorily</u>	° VERIFY/COMPLETE the daily channel check on 1RE-PR001	_____	_____	_____
3. Perform Source/Channel check Cue: <u>1BOSR 11.b.6-1 has been completed and reviewed satisfactorily.</u>	° PERFORM the 1PR01J source/channel check	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p>In the following JPM step, the examinee should N/A the step because 1PR11J is inoperable.</p>				
4. Noble gas trend Cue: <u>1PR11J is inoperable</u>	° VERIFY noble gas trend	_____	_____	_____
5. "As Found" setpoints of 1RE-PR001 Note: The High alarm setpoint is 4.83 E-04 Note: The Alert alarm setpoint is 2.42 E-04	At the RM-11, RECORD "As Found" setpoints of 1RE-PR001 gas channel: ° High alarm setpoint ° Alert alarm setpoint	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*6. RM-11 supervisory mode Cue: <i>Give candidate the Supervisory key for RM-11 when requested.</i>	At the RM-11: <ul style="list-style-type: none"> Obtain Supervisory Key from Unit. Supervisor. PLACE RM-11 in Supervisory Mode 			
*7. Select monitor	At the RM-11, Grid 2: <ul style="list-style-type: none"> SELECT 1PB101 and DEPRESS the SEL key 			
*8. Select high alarm setpoint channel	At the RM-11: <ul style="list-style-type: none"> DEPRESS Channel Item key KEY IN "9" DEPRESS the SEL key 			
*9. High alarm setpoint Note: <i>The setpoint to be entered is 5.60 E-04</i> Cue: <i><u>Your request for verification is acknowledged, please continue.</u></i>	At the RM-11: <ul style="list-style-type: none"> ENTER high alarm setpoint on 1PB101 per Step 4.1.1.8 <ul style="list-style-type: none"> RECORD new value Request verification 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*10. Select alert alarm channel Note: The setpoint to be entered is 3.14 E-04. Cue: Your request for verification is acknowledged, please continue.	At the RM-11: <ul style="list-style-type: none"> • DEPRESS Channel Item key • KEY IN "10" • DEPRESS the SEL • ENTER alert alarm setpoint on 1PB101 per Step 4.1.1.8 <ul style="list-style-type: none"> ◦ RECORD new value ◦ Request verification 			
11. Place the RM-11 in Normal Mode	At the RM-11: <ul style="list-style-type: none"> ◦ PLACE the RM-11 in NORMAL MODE 			
12. Aux building exhaust fan status	At OPM02J: <ul style="list-style-type: none"> ◦ ENSURE the 0A <u>OR</u> 0B Aux Building Exhaust Fan is in operation 			
13. Turn in Package for approval Cue: <u>The US will continue at step 5.</u> Cue: <u>This JPM is completed.</u>	Hand in Release package to Unit Supervisor for approval.			

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Change RM-11 Setpoints in Preparation for a Unit 1 Containment Release

JPM Number: RA/SA-3 Revision Number: 4

Task Number and Title: 4C.GW-01 PERFORM a Gaseous Release.

K/A Number and Importance: Generic 2.3.5 2.9/2.9

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form Type: Routine Containment Release (Rev. 20)

CRITICAL STEPS (*) 6, 7, 8, 9 & 10

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. A Unit 1 Containment release is pending.
3. 1PR11J is inoperable.

INITIATING CUE

You have been instructed to perform Section 4 of BCP 400-TCNMT/ROUTINE in preparation for this release.

.....

Exelon Nuclear

Job Performance Measure

Determine venting time for Reactor Vessel void

JPM Number: SA-1.b

Revision Number: 0

Date: 10/18/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/18/2011</u> Date
-------------	---------------------------------------	---------------------------

Validated By:	<u>Brian Lewin</u> SME or Instructor	<u>11/06/2011</u> Date
---------------	-----------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date
--------------	----------------------------------------------	---------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure: 1BFR I.3 Rev: 200
 Procedure Rev:
 Procedure Rev:
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)

Revision 11

Revised to current format

INITIAL CONDITIONS

1. You are an extra SRO.
2. Unit 1 is recovering from an event that caused a suspected hydrogen bubble to accumulate in the reactor vessel head.
3. The crew is performing 1BFR-I.3, RESPONSE TO VOIDS IN THE REACTOR VESSEL.
4. Attempts to condense the vessel head void have been unsuccessful and the TSC has directed the crew to perform a direct vessel vent.
5. Current plant conditions are as follows
 - Containment temperature (dry bulb) = 135 degreesF
 - Containment pressure = 2.1 psig
 - Containment hydrogen concentration = 1%
 - RCS pressure = 1500 psig

INITIATING CUE

1. The Shift Manager directs you to assist the Unit 1 SRO by calculating reactor vessel vent time per 1BFR-I.3, Attachment B.
2. Inform the SM when you have completed 1BFR-I.3, Attachment B

Fill in the JPM Start Time when the student acknowledges the Initiating Cue

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<u>NOTE</u>				
Provide examinee with a copy of 1BFR-I.3				
1. Refer to 1BFR-I.3. Note: Provide copy of 1BFR-I.3 and a calculator to examinee.	Refer to 1BFR-I.3	_____	_____	_____
*2. Calculate containment temperature in Rankine	Perform Attachment B, step 1: <ul style="list-style-type: none"> Enter 135 in degrees F blank Add 460 to 135 and enter 595 in degree R blank 	_____	_____	_____
*3. Calculate containment air volume based on current temperature and pressure.	Perform Attachment B, step 2 <ul style="list-style-type: none"> Enter 595 in degree R blank Enter 2.1 in CNMT press blank Perform calculation and enter 2,646,050 (or approx.) in cu. ft. blank 	_____	_____	_____
*4. Calculate maximum hydrogen volume that can be vented keeping cnmt concentration below 3%	Perform Attachment B, step 3 <ul style="list-style-type: none"> Enter 1 in cnmt hydrogen conc. blank. Enter 2,646,050 (or approx.) in cu. ft. blank Perform calculation and enter 52,921 (or approx.) in cu. ft. blank 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*5. Determine hydrogen flow rate from RCS vent.	Perform Attachment B, step 4 <ul style="list-style-type: none"> Plot RCS pressure on 1BFR-I.3-4 and determine flow rate will be about 4725 scfm (4675-4775) Enter flow rate in step 4 SCFM blank 	_____	_____	_____
*6. Calculate maximum venting time.	Perform Attachment B, step 5 <ul style="list-style-type: none"> Enter 52,921 (or approx.) in cu. ft. blank Enter 4725 (4675-4775) in SCFM blank Calculate minutes and enter 11.2 (11.08 to 11.32) in minutes blank 	_____	_____	_____
7. Report to SM results of venting calculation Cue: <u>This JPM is completed.</u>	Notify SM that RCS venting can be performed for approx. 11.1 to 11.3 minutes:	_____	_____	_____

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Determine Venting time for Reactor Vessel Void

JPM Number: SA-1.b Revision Number: 0

Task Number and Title: Diagnose and analyze voids in the reactor vessel (T.FR6-04)

K/A Number and Importance: 2.1.25 4.2

Suggested Testing Environment: Simulator or classroom

Alternate Path: ☐ Yes ☒ No SRO Only: ☒ Yes ☐ No Time Critical: ☐ Yes ☒ No

Reference(s):

1BFR-I.3, Response to voids in the reactor vessel

CRITICAL STEPS (*) 2, 3, 4, 5, & 6

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments:

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an extra SRO.
2. Unit 1 is recovering from an event that caused a suspected hydrogen bubble to accumulate in the reactor vessel head.
3. The crew is performing 1BFR-I.3, RESPONSE TO VOIDS IN THE REACTOR VESSEL.
4. Attempts to condense the vessel head void have been unsuccessful and the TSC has directed the crew to perform a direct vessel vent.
5. Current plant conditions are as follows
 - Containment temperature (dry bulb) = 135 degreesF
 - Containment pressure = 2.1 psig
 - Containment hydrogen concentration = 1%
 - RCS pressure = 1500 psig

INITIATING CUE

1. The Shift Manager directs you to assist the Unit 1 SRO by calculating reactor vessel vent time per 1BFR-I.3, Attachment B.
2. Inform the SM when you have completed 1BFR-I.3, Attachment B

Exelon Nuclear

Job Performance Measure

Evaluate a Reactivity Change

JPM Number: SA 1a

Revision Number: 01

Date: 10/17/2011

Developed By:	<u>Bill Hochstetter</u>	<u>10/17/2011</u>
	Instructor	Date

Validated By:	<u>Brian Lewin</u>	<u>11/06/2011</u>
	SME or Instructor	Date

Approved By:	<u>Rob Lawlor</u>	<u>11/06/2011</u>
	Facility Representative	Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, simulator, or other)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating cue (and terminating cue if required) are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure OP-AP-300-1004 Rev: 2
 Procedure _____ Rev: _____
 Procedure _____ Rev: _____
- _____ 9. Verify cues both verbal and visual are free of conflict.
- _____ 10. Verify performance time is accurate
- _____ 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)**Revision 01** Initial revision of JPM

Comment	Resolution
Revised JPM for 2012 NRC Exam	

INITIAL CONDITIONS:

1. Unit 1 is at 95% power, 6300 EFPH, 892 ppm boron, with CB D at 215 steps, steady state and equilibrium Xenon
2. Tave is 1 degree less than Tref.
3. The QNE has advised Control Bank D should be withdrawn to 221 steps to control PDMA02 on the desired target.
4. The NSO has calculated a reactivity change to match Tave with Tref.

INITIATING CUES:

1. Evaluate the reactivity change to match Tave to Tref by reviewing OP-AA-300-1004, Att. 1, Reactivity Change Determination Form.
 - Provide completed copy of OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements
 - Provide copy of Unit 1 Rema Thumbrules

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

*** Denotes critical steps 3 & 4**

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

TASK STANDARDS:

1. Evaluate the reactivity change to match Tave to Tref.
2. Review the Reactivity Change Determination Form.

MATERIALS:

- Completed OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements (Attachment 1 is attached)
- Unit 1 Rema Thumbrules at 6211 EFPH

RECORD START TIME: _____

EVALUATOR NOTE: These steps may be performed in any order.					
STEP	ELEMENT	STANDARD	SAT	UNSAT	CMT#
CUE	Provide completed copy of OP-AP-300-1004 (att. 1) and a copy of the Unit 1 Rema thumbrules				
1	Refer to <ul style="list-style-type: none"> OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements Unit 1 Rema Thumbrules 	In accordance with the provided: <ul style="list-style-type: none"> OP-AP-300-1004, Rev 2, Pwr Boration and Dilution Requirements Unit 1 Rema Thumbrules 			
2	Review Attachment 1 of OP-AP-300-1004	Review Attachment 1 of OP-AP-300-1004	_____	_____	_____
	Evaluator note: 6 step withdrawal of CB D will raise temperature 0.5 degrees calculation is flawed because it omits above from calculation and dilutes a full 224 gallons of primary water, which is 1 degree, rather than taking into account the control rod withdrawal. Correct dilution volume is 112 gallons				
*3	Evaluate calculation for dilution volume listed at 224 gallons, should be 112 gallons. Cue: <u>SM has instructed you to correct the identified error and continue your review.</u>	Determine dilution volume <ul style="list-style-type: none"> Should identify volume of dilution is incorrect. 			
*4	Evaluate calculation and determine that rod withdrawal was omitted from calculation	Determine rod withdrawal			
CUE	<u>This JPM is complete.</u>				

RECORD STOP TIME: _____

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. Unit 1 is at 95% power, 6300 EFPH, 892 ppm boron, with CB D at 215 steps, steady state and equilibrium Xenon
2. Tave is 1 degree less than Tref.
3. The QNE has advised Control Bank D should be withdrawn to 221 steps to control PDMA02 on the desired target.
4. The NSO has calculated a reactivity change to match Tave with Tref.

INITIATING CUES:

1. Evaluate the reactivity change to match Tave to Tref by reviewing OP-AA-300-1004, Att. 1, Reactivity Change Determination Form.

OP-AP-300-1004

Revision 2

Page 4 of 4

ATTACHMENT 1 **REACTIVITY CHANGE DETERMINATION FORM**

Station: Byron Unit: ① 2 Time: Now Date: Today

Desired change:

(Parameter, Magnitude, and Direction: Reactor Power, Rod Position, RCS Temp, Delta I, etc.)

Withdraw Rods 6 steps for PDMA02 control
Raise RCS Ave. Temp by 1 degree

Reason for Change:

(Temperature control, flux control, fuel burn up)

PDMA02 control and temperature control.

What is the method and amount required for the reactivity change?

(Bleed Tank Volume, Gallons of Dilution/Boration/Blended Flow, Rod Insertion/Rod Withdrawal steps/percent)

6 steps withdrawal of CB D and 224 gallons dilution per 1 degree Fahrenheit change.

Inputs:

(ReMA Thumbrules, ReMA maneuver guidance, Curve Book Figure/Table, Computer based trend plot, RCS Cb, EFPD – Preparer and Reviewer should use independent inputs when possible)

ReMA thumbrules for Unit 1 at 6211 EFPD

Calculation of change:

(E.G. Bwd/Byr: ReMA Thumbrule identifies 20 gallons BA = 1.0°F RCS temp reduction.

*Desired change = 0.5°F drop. Calculation of change: (20 gal/1.0°F) * 0.5°F = 10 gal., previously used borations and dilutions)*

(TMI: Procedure 1102-4 Power Operations Fig. 1, Volume of Demineralized Water for 1% Rod Insertion)

1.0° low x 224 gallons dilution per degree raised = 224 gallons dilution

Joe Rowe

Preparer

(RC)

P Check

Reviewer

(RO/SRO)

Approver

(SRO)

Shift Manager Notified: Yes No

Exelon Nuclear

Job Performance Measure

Initiate a LCOAR

JPM Number: SA-2 New

Revision Number: 0

Date: 10/19/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/19/2011</u> Date
-------------	---------------------------------------	---------------------------

Validated By:	<u>Brian Lewin</u> SME or Instructor	<u>11/06/2011</u> Date
---------------	-----------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date
--------------	----------------------------------------------	---------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure BAP 1400-6 Rev: 28
 Procedure 1BOL 7.6 Rev: 6
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

Revision Record (Summary)

Revision 0

- Modified S009 Rev. 6
- Changed component that is in LCOAR

INITIAL CONDITIONS

1. You are the Unit 1 Unit Supervisor.
2. The unit is at 90% steady state power, all conditions normal.

INITIATING CUE

1. The Unit 1 Assist NSO notified you 5 minutes ago; the Unit 1 CST level is 58%.
2. The Shift Manager directs that it is NOT necessary to update the DEL per LCO 3.0.6 for this LCO.
3. IR 1234567 has been written to document the issue.
4. No other LCOARs or DELs exist on Unit 1.
5. Initiate the LCOAR paperwork as necessary.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

*- Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center">NOTE</p> <p align="center">Once the student demonstrates the ability to locate referenced procedure provide the student with a copy of the procedure.</p> <p align="center">Step 1 of this JPM is optional</p>				
1. Refer to BAP 1400-6, Technical Specification Limiting Conditions for Operation Action Requirements (LCOAR)	◦ LOCATE and OPEN BAP 1400-6	_____	_____	_____
2. Refer to 1BOL 7.6, LCOAR Condensate Storage Tank –Tech Spec LCO 3.7.6	◦ LOCATE and OPEN 1BOL 7.6	_____	_____	_____
*3. Section A of 1 BOL 7.6 Note: Notification occurred 5 minutes ago per initiating Cue.	ENTER into Section A: <ul style="list-style-type: none"> • Time/Date ◦ By ◦ Title • Present mode • Initiating event • Condition 	_____	_____	_____
*4. Safety function determination Cue: <u>There is no other inoperable or degraded support or supported equipment on the A train.</u>	PERFORM SFD <ul style="list-style-type: none"> • Indicate No in Section C • Sign Coversheet • Indicate NO on coversheet for invalidating current SFD 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
5. Update DEL: <i>N/A - from initiating cue information</i>	<ul style="list-style-type: none"> Check "N/A" box 	_____	_____	_____
6. Determine Planned or Unplanned	<ul style="list-style-type: none"> Mark UNPLANNED on coversheet 	_____	_____	_____
<p style="text-align: center;">NOTE</p> <p>Examinee may inform SM of entry at this time, however, the SM Notified and time/date is typically completed after Peer Check received by another SRO.</p>				
7. Related WR/WO block Note: IR # should be recorded here	<ul style="list-style-type: none"> N/A OR List IR # 	_____	_____	_____
8. Fill in Related Clearance Orders Note: Acceptable if left Blank	<ul style="list-style-type: none"> N/A OR Leave Blank 	_____	_____	_____
9. Was an IR written?	<ul style="list-style-type: none"> Check "Yes" box 	_____	_____	_____
*10. LCOAR TABLE of 1 BOL 7.6	<p>COMPLETE LCOAR Table:</p> <ul style="list-style-type: none"> CIRCLE Condition A ENTER notification Time/Date <u>AND</u> sign Condition A 	_____	_____	_____
<p>*11. Goes to ATTACHMENT A</p> <p>Cue: <u>An Extra NSO will perform 1BOSR 7.8.1-1.</u></p> <p>Per Initiating Cue: 1AF006 and 1AF017 A&B are operable.</p> <p>Cue: <u>SX basin level is 90%</u></p>	<ul style="list-style-type: none"> Recognized the need to perform the following within 4 hours: <ul style="list-style-type: none"> 1BOSR 7.8.1-1 1AF006A & B and 1AF017A&B are operable SX basin above its limit 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
12. Peer check prior to SM review Cue: <u>A second SRO has provided a peer check.</u>	<ul style="list-style-type: none"> ◦ BAP 1400-6 for Peer check ◦ Get an additional SRO to Peer check the BOL package 	—	—	—
13. Signed by Shift Manager Cue: <u>The shift manager acknowledges LCOAR entry and review request.</u> Cue: <u>This JPM is complete.</u>	<ul style="list-style-type: none"> ◦ NOTIFY SM 	—	—	—

RECORD STOP TIME: _____

.....

INITIAL CONDITIONS

1. You are the Unit 1 Unit Supervisor.
2. The unit is at 90% steady state power, all conditions normal.

INITIATING CUE

1. The Unit 1 Assist NSO notified you 5 minutes ago; the Unit 1 CST level is 58%.
2. The Shift Manager directs that it is NOT necessary to update the DEL per LCO 3.0.6 for this LCO.
3. IR 1234567 has been written to document the issue.
4. No other LCOARs or DELs exist on Unit 1.
5. Initiate the LCOAR paperwork as necessary.

Exelon Nuclear

Job Performance Measure

Review Containment Release package in preparation for a Unit 1 Containment Release

JPM Number: SA-3

Revision Number: 5

Date: 12/30/2011

Revised By:	<u>Bill Hochstetter *</u>	<u>12/30/2011</u>
	Instructor	Date

Validated By:	<u>*</u>	<u> </u>
	SME or Instructor	Date

Approved By:	<u>*</u>	<u> </u>
	Facility Representative	Date

* Signature on File

See File Copy

- | | |
|--------------------------------------|------------|
| Bill Hochstetter (Signature on file) | 12/30/2011 |
| SME / Instructor | Date |
| (Signature on file) | |
| SME / Instructor | Date |
| | |
| SME / Instructor | Date |

Revision Record (Summary)

Revision 4

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator

Revision 5

Revised to SRO Only review of containment release prior to approval

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Ensure that either the 0A or 0B Aux Building Exhaust Fan is in operation.
3. Verify that the RM-11 values for the appropriate channels agree with the surveillance paperwork and Supervisory key for the RM-11 available.
4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
5. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Unit 1 Unit Supervisor.
2. A Unit 1 Containment release is pending.
3. 1PR11J is inoperable.
4. The Unit has been at 100% power and stable for the past 72 hours

INITIATING CUE

You have been instructed to review Sections 1 through 5 of BCP 400-TCNMT/ROUTINE in preparation for this release.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the <u>underlined</u> cue needs to be provided to the examinee.</p> <p>To initiate this JPM, hand the partially completed BCP 400-TCNMT/ROUTINE to the examinee.</p> <p>Examine may start with section 5 first (step 4 below), then continue with review of previous sections.</p>				
<p>1. Refer to the partially completed BCP 400-TCNMT/ROUTINE</p> <p>Cue: <i>(if asked) Section 2 has been verified along with the RETDAS Gaseous Release Rate printouts.</i></p>	<p>◦ REVIEW BCP 400-TCNMT/ROUTINE for completeness up to Section 3.</p>	_____	_____	_____
<p>*2. Notices signature missing in Section 3 page 9.</p> <p>Note: The examinee should determine the release cannot occur until this is resolved.</p> <p>Cue: <u>Acknowledge the error and request further review for accuracy.</u></p>	<p>• Notices Rad protection HP or SRO signature is NOT signed and dated</p>	_____	_____	_____
<p>*3. Reviews Section 4</p> <p>Note: The examinee should determine the release cannot proceed at this time. Proceed to step 5.</p>	<p>• REVIEW BCP 400-TCNMT/ROUTINE for completeness of Section 4</p> <p>• Determine Step 8 numbers don't match section 2.5 (6.05 E-04 versus 5.60 E-04)</p>	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
4. Reviews Section 5: Found in initial conditions Cue: <u><i>The unit NSO will place the placard.</i></u> Cue: <u><i>The Unit 2 Unit Supervisor has verified 1BOSR 11.b.6-1 is complete and has been reviewed.</i></u>	<ul style="list-style-type: none"> ◦ Determines that the first paragraph is satisfied. ◦ Determines that “containment release placard must be placed on OPM02J ◦ Determines that 1BOSR 11.b.6-1 must be completed and reviewed 	_____	_____	_____
*5. Does NOT approve the release Cue: <u><i>This JPM is complete.</i></u>	<ul style="list-style-type: none"> • Determines that the release should NOT be approved. 	_____	_____	_____

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Review Containment release package in preparation for a Unit 1 Containment Release

JPM Number: SA-3 Revision Number: 5

Task Number and Title: 4C.GW-01 PERFORM a Gaseous Release.

K/A Number and Importance: Generic 2.3.5 2.9/2.9

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☒ Yes ☐ No Time Critical: ☐ Yes ☒ No

Reference(s):

BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form Type: Routine Containment Release (Rev. 20)

CRITICAL STEPS (*) 2, 3, & 5

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Unit Supervisor.
2. A Unit 1 Containment release is pending.
3. 1PR11J is inoperable.
4. The Unit has been at 100% power and stable for the past 72 hours

INITIATING CUE

You have been instructed to review Sections 1 through 5 of BCP 400-TCNMT/ROUTINE in preparation for this release.

.

.....

Exelon Nuclear

Job Performance Measure

Classify Event and Fill Out a NARS Form (LBLOCA)

JPM Number: SA-4

Revision Number: 5

Date: 10/28/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/28/2011</u> Date
-------------	---------------------------------------	---------------------------

Reviewed By:	<u>Brian Lewin</u> Operations Representative	<u>11/06/2011</u> Date
--------------	-------------------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date
--------------	----------------------------------------------	---------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure EP-MW-114-100 Rev: 11
Procedure EP-MW-114-100-F-01 Rev: F
Procedure EP-AA-1002 Rev: 28
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Lynn Sanders (Signature on file) 9/09/11
SME / Instructor Date

X X
SME / Instructor Date

Revision Record (Summary)

Revision 4

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator
- Validated 9/20/11 by Lynn Sanders and Mike McCue, only change was procedure rev that did not affect JPM.
- New event created for 2011 Requal, classified as modified for ILT exam since this specific item has not been tested previously in ILT.
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

2. None.
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Shift Emergency Director.
2. The Unit 1 Supervisor has provided you with information related to a Unit 1 event and informed you to perform an Emergency Plan evaluation.

INITIATING CUE

1. Perform an Emergency Plan evaluation and fill out the NARS form for transmittal for the plant conditions provided
2. **This is a time critical JPM.**

PLANT CONDITIONS

- Unit 1 and 2 were both at full power.
- A Unit 1 Reactor Trip and Safety Injection occurred based on the following conditions:
- A large break Loss of Primary Coolant
- Containment Spray pumps did not automatically start and could NOT be manually started.
- Containment pressure peaked at 29 psig.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p align="center">The completion of Step 2 fulfills the critical time portion of this JPM.</p>				
<p>1. Refer to Exelon Nuclear – Radiological Emergency Plan Annex for Byron Station.</p> <p>Note: This step may be performed at any time.</p>	<p>o Refer to EAL Matrix, EP-AA-1002</p>	_____	_____	_____
<p>*2. Classify the Event utilizing EAL Matrix.</p> <p>Critical portion stop time _____</p>	<p>• Classify event as SITE AREA EMERGENCY, from FS1 Loss OR Potential Loss of 2 Fission Product Barriers (RCS and CNMT).</p>	_____	_____	_____
<p>Time from start to Classification = _____ minutes</p>	<p>¢ ≤ 15 minutes</p>	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p align="center">Provide the examinee with a copy of the NARS form.</p>				
<p>3. Obtain NARS form, EP-MW-114-100-F-01, Nuclear Accident Reporting System (NARS).</p> <p>Note: Step 3 may be performed at any time.</p>	<p>o Obtain NARS form.</p>	_____	_____	_____
<p>4. Refer to EP-MW-114-100, MWROG Offsite Notifications, to complete NARS form.</p> <p>Note: Step 4 may be performed at any time.</p>	<p>o Locate and Open, EP-MW-114-100, MWROG Offsite Notifications, Section 4.2, to complete NARS form.</p>	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>Provide the examinee with Wind Speed and Wind Direction cues after examinee has demonstrated the ability to obtain the information from the computer or from the main control board.</p>				
<p>*5. Fill out NARS form according to instructions, EP-MW-114-100, Section 4.2, Completing the NARS Form.</p> <p>Cue: <u>The wind direction on AM004 is 286°.</u></p> <p>Cue: <u>The wind speed on AM001 is 3 mph.</u></p>	<ul style="list-style-type: none"> Fill out NARS form according to instructions, EP-MW-114-100, Section 4.2 Completing the NARS Form. BLOCKS 2 thru 9 must be filled correctly to meet the critical portion of filling out the NARS form. (See attached KEY). 			
<p>Time to complete NARS Form = _____ minutes</p>	<p>¢ < 12 minutes</p>	_____	_____	_____

RECORD STOP TIME: _____

.....

Nuclear Accident Reporting System (NARS) Form

UTILITY MESSAGE NO. 1STATE MESSAGE NO. N/A**1. STATUS**

[A] ACTUAL
[X] DRILL/EXERCISE

2. STATION

[A] BRAIDWOOD [C] CLINTON
[X] BYRON [D] DRESDEN

[E] LASALLE [G] ZION
[F] QUAD CITIES

3. ONSITE CONDITION

[A] UNUSUAL EVENT
[B] ALERT
[X] SITE AREA EMERGENCY
[D] GENERAL EMERGENCY
[E] RECOVERY
[F] TERMINATED

4. ACCIDENT CLASSIFIED

TIME (3[A-E]): Now
DATE (3[A-E]): Today
EAL#: FS1

ACCIDENT TERMINATED

TIME (3[F]): N/A
DATE (3[F]): N/A

5. RELEASE STATUS

[X] NONE
[B] OCCURRING
[C] TERMINATED

6. TYPE OF RELEASE

[X] NOT APPLICABLE
[B] GASEOUS
[C] LIQUID

7. WIND DIR

286°
(DEGREES FROM)

8. WIND SPEED

[A] METERS/SEC.: _____
[X] MILES/HR.: 3

9. RECOMMENDED ACTIONS**UTILITY RECOMMENDATION**

[X] NONE (UE, Alert and SAE Only)

----- (GE Only) -----

[B] SHELTER ILLINOIS SUB-AREAS: _____
AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[C] SHELTER IOWA SUB-AREAS: _____
AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[D] EVACUATE ILLINOIS SUB-AREAS: _____
AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[E] EVACUATE IOWA SUB-AREAS: _____
AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

STATE RECOMMENDATION

[F] NONE
[G] SHELTER SUB-AREAS: _____
[H] EVACUATE SUB-AREAS: _____
[I] RECOMMEND POTASSIUM IODIDE (KI) PER PROCEDURES
[J] COMMENCE RETURN OF PUBLIC
[K] OTHER _____

10. ADDITIONAL INFORMATION NoneVerified With: STAApproved By: SRO**11. TRANSMITTED BY:**NAMEPHONE NUMBERTIME/DATE

[A] EXELON: _____

[B] STATE: _____

[C] COUNTY: _____

12. RECEIVED BY:NAMEORGANIZATIONTIME/DATE

Nuclear Accident Reporting System (NARS) Form

Braidwood		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 20</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 38</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# Grundy Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Kankakee Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Will County Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	Grundy Co. EMA	<input type="checkbox"/>
<input type="checkbox"/>	Kankakee Co. EOC	<input type="checkbox"/>
<input type="checkbox"/>	Will Co. EOC	<input type="checkbox"/>

ROLL CALL	
Initial Roll Call Complete:	
<hr/>	
(time / date)	

Clinton		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 98</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 36</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# DeWitt Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	DeWitt Co. EOC	<input type="checkbox"/>

LaSalle		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 20</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 25</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# Grundy Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# LaSalle Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	Grundy Co. EMA	<input type="checkbox"/>
<input type="checkbox"/>	LaSalle Co. ESDA	<input type="checkbox"/>

Byron		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 20</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 37</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	**Ogle Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	**Rochelle Police	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	Ogle Co. ESDA	<input type="checkbox"/>
<input type="checkbox"/>	Ogle Co. EOC	<input type="checkbox"/>

Commercial numbers:
IEMA **217-782-7860**
 (QC only)
Iowa EMD **515-281-3231**

Dresden		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 20</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 22</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# Grundy Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Kendall Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Will County Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	Grundy Co. EMA	<input type="checkbox"/>
<input type="checkbox"/>	Kendall Co. EOC	<input type="checkbox"/>
<input type="checkbox"/>	Will Co. EOC	<input type="checkbox"/>

Quad Cities		
(UE, Alert, SAE, escalated GE(s), Termination and Recovery)		
<u>NARS Code 43</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# Iowa EMD	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>
<input type="checkbox"/>	Scott Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	Clinton Co. EOC	<input type="checkbox"/>
<input type="checkbox"/>	Scott Co. EOC	<input type="checkbox"/>
(Only if NARS #1 is a GE)		
<u>NARS Code 23</u>		
<u>Initial</u>		<u>Final</u>
<input type="checkbox"/>	# Illinois EMA	<input type="checkbox"/>
<input type="checkbox"/>	# Iowa EMD	<input type="checkbox"/>
<input type="checkbox"/>	# Clinton Co. EOC	<input type="checkbox"/>
<input type="checkbox"/>	# Rock Island Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Whiteside Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Scott Co. Sheriff	<input type="checkbox"/>
<input type="checkbox"/>	# Scott Co. EOC	<input type="checkbox"/>
<input type="checkbox"/>	Whiteside Co. ESDA	<input type="checkbox"/>
<input type="checkbox"/>	Rock Island ESDA	<input type="checkbox"/>
<input type="checkbox"/>	Illinois REAC	<input type="checkbox"/>

NOTES: # Indicates that this agency is required to be notified within 15 minutes.
 ** Only one needs to answer for notification.

SRRS: 3D.105 (when utilized for operator initial or continuing training)

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Classify Event and Fill Out a NARS Form (LOCA)

JPM Number: S016t

Revision Number: 4

Task Number and Title: S-ZP-008 CLASSIFY/RECLASSIFY Emergency Action Levels.

K/A Number and Importance: 2.4.41 4.6

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☒ Yes ☐ No Time Critical: ☒ Yes ☐ No

Reference(s):

EP-MW-114-100 (Rev 11), Midwest Region Offsite Notifications

EP-MW-114-100-F-01 (Rev. F) Nuclear Accident Reporting System (NARS) Form

EP-AA-1002 (Rev 28) Exelon Nuclear Radiological Emergency Plan Annex for Byron Station

CRITICAL STEPS (*) 2 & 5

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Shift Emergency Director.
2. The Unit 1 Supervisor has provided you with information related to a Unit 1 event and informed you to perform an Emergency Plan evaluation.

INITIATING CUE

1. Perform an Emergency Plan evaluation and fill out the NARS form for transmittal for the plant conditions provided
2. **This is a time critical JPM.**

PLANT CONDITIONS

- Unit 1 and 2 were both at full power.
- A Unit 1 Reactor Trip and Safety Injection occurred based on the following conditions:
- A large break Loss of Primary Coolant
- Containment Spray pumps did not automatically start and could NOT be manually started.
- Containment pressure peaked at 29 psig.

Exelon Nuclear

Job Performance Measure

Perform Moveable Control Assemblies Quarterly Surveillance

JPM Number: CR-A

Revision Number: 10

Date: 10/20/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/20/11</u> Date
Reviewed By:	<u>Rob Friskey</u> Operations Representative	<u>11/06/2011</u> Date
Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure 1BOSR 1.4.2-1 Rev: 17
Procedure Rev:
Procedure _____ Rev:
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/20/11
SME / Instructor Date

X X
SME / Instructor Date

Revision Record (Summary)

Revision 10

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor.
- Placed some examiner notes concerning alarms received during step performance
- Created from JPM No. N-41
- Changed to Alt. Path based on NRC request

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

2. **Insert Malfunction RD05F08 prior to running this JPM to fail rod F-08 when it steps to 222 steps.**
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. Unit 1 is at 100% power, steady state, equilibrium Xenon, MOL

INITIATING CUE

1. You have been directed to perform a partial surveillance of 1BOSR 1.4.2-1, Moveable Control Assemblies Quarterly Surveillance. You are to perform the surveillance on SD Bank E and Control Banks A through D.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined</u> are required to be provided to the examinee</p>				
<p>1. Refer to 1BOSR 1.4.2-1, Moveable Control Assemblies Quarterly Surveillance</p> <p>Note: Step 1 may be performed at any time</p> <p>Cue: <u>All prerequisites are met</u></p>	<ul style="list-style-type: none"> LOCATE and OPEN 1BOSR 1.4.2-1 	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p align="center">Provide the examinee with a copy of the 1BOSR 1.4.2-1.</p>				
2. Transfer rod control to manual	<p>At 1PM05J:</p> <ul style="list-style-type: none"> PLACE Rod Bank Selector switch to MANUAL MAINTAIN T_{ave} matched with T_{ref} using rod motion control 	_____	_____	_____
3. Record initial shutdown bank step counter readings	<p>In column 2a:</p> <ul style="list-style-type: none"> ENTER initial step counter readings for Shutdown Bank E 	_____	_____	_____
*4. Shutdown bank E	<p>At 1PM05J:</p> <ul style="list-style-type: none"> SELECT SBE position on Rod Bank Selector switch 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*5. Insert Shutdown Bank E 1 step	At 1PM05J: • Using the rod motion control switch, INSERT Shutdown Bank E 1 step			
*6. Withdraw shutdown bank E	At 1PM05J: • Using the rod motion control switch, WITHDRAW Shutdown Bank E to 231 steps			
7. DRPI indication	At 1PM05J: ◦ VERIFY DRPI indicates 228 steps withdrawn			
<p align="center"><u>NOTE</u></p> <p>Annunciator 1-10-A7 ROD DEV POWER RNG TILT, will alarm during performance of step 8</p>				
*8. Insert shutdown bank E	At 1PM05J: • Using the rod motion control switch, INSERT Shutdown Bank E 10 to 15 steps			
9. Record step counter readings	In column 2g: ◦ RECORD shutdown bank E step counter reading			
10. Shutdown bank E DRPI	In column 2h: ◦ VERIFY each rod in shutdown bank E moved 10 – 15 steps using DRPI and INITIAL			
*11. Return rods to initial position	At 1PM05J: • WITHDRAW shutdown bank E rods to 228 steps			

<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
12. Final shutdown bank E position	In column 2j: ◦ RECORD final shutdown bank E position			
13. Final shutdown bank E DRPI	In column 2k: ◦ VERIFY each rod in shutdown bank E is restored to original position and INITIAL			
<p style="text-align: center;"><u>NOTE</u></p> <p>The steps for Shutdown Banks A, B, C, and D will not be performed. The examinee should go to the next step that addresses control banks.</p>				
14. Record initial control rod bank step counter readings	In column 3a: ◦ ENTER initial step counter readings for Control Banks A, B, C, and D			
*15. Control bank A	At 1PM05J: • SELECT CBA position on Rod Bank Selector switch			
*16. Insert Control Bank A 1 step	At 1PM05J: • Using the rod motion control switch, INSERT Control Bank A 1 step			
*17. Withdraw control bank A	At 1PM05J: • Using the rod motion control switch, WITHDRAW Control Bank A to 231 steps			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p align="center">The following Annunciators will alarm during the performance of step 18 1-10-A6 ROD BANK LO-2 INSERTION LIMIT, 1-10-A7 ROD DEV POWER RNG TILT, and 1-10-B6 ROD BANK LO INSERTION LIMIT</p>				
<p align="center"><u>NOTE</u></p> <p align="center">Alternate Path starts HERE</p>				
*18. Insert control bank A	<p>At 1PM05J:</p> <ul style="list-style-type: none"> Using the rod motion control switch, INSERT Control Bank A 10 to 15 steps 			
<p align="center"><u>NOTE</u></p> <p>The examinee may notice that DRPI for Rod F-8 stayed at 222 steps while the rest of the Bank continued to 216 steps, depending on how far the candidate inserts rods. If the above occurs, then, the examinee should Notify the Unit Sup. and the evaluator should go to step 24.</p>				
19. Record step counter readings	<p>In column 3f:</p> <ul style="list-style-type: none"> RECORD control rod bank A step counter readings for both groups 1 and 2 			
20. Control bank A DRPI	<p>In column 3g:</p> <ul style="list-style-type: none"> VERIFY each rod in control bank A moved 10 – 15 steps using DRPI and INITIAL (DRPI will not change by 2 LEDs for the failed rod) 			
*21. Return rods to initial position	<p>At 1PM05J:</p> <ul style="list-style-type: none"> WITHDRAW control bank A to original position 			
22. Final control rod bank A position	<p>In column 3i:</p> <ul style="list-style-type: none"> RECORD final control bank A position 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*23. Final control bank A DRPI <i>NOTE: Examinee should note F-08 DRPI does not agree with other rods in that Group</i>	In column 3j: <ul style="list-style-type: none"> VERIFY each rod in control bank A is at its original position 			
*24 Notifies Unit Supervisor	<ul style="list-style-type: none"> Notify Unit Supervisor of failure of Rod F-08 to withdraw 			
<i>Cue: (if required) <u>This JPM is completed</u></i>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Moveable Control Assemblies Quarterly Surveillance

JPM Number: CR-A Revision Number: 10

Task Number and Title: 4C.RD-01 PERFORM Control Rod Exercises

K/A Number and Importance: 014A4.02 3.4/3.2

Suggested Testing Environment: Simulator

Alternate Path: ☒ Yes ☐ No SRO Only: ☐ Yes ☐ No Time Critical: ☐ Yes ☐ No

Reference(s):

1BOSR 1.4.2-1 - Moveable Control Assemblies Quarterly Surveillance

CRITICAL STEPS (*) 4, 5, 6, 8, 11, 15, 16, 17, 18 & 21, 23 and 24 (21 and 23 may not be performed if failure is noted during inward rod motion).

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 23 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. Unit 1 is at 100% power, steady state, equilibrium Xenon, MOL

INITIATING CUE

1. You have been directed to perform a partial surveillance of 1BOSR 1.4.2-1, Moveable Control Assemblies Quarterly Surveillance. You are to perform the surveillance on SD Bank E and Control Banks A through D.

.

Exelon Nuclear

Job Performance Measure

Raise Accumulator Level With SI Pump

JPM Number: CR-b

Revision Number: 0

Date: 10/21/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/20/11</u> Date
Reviewed By:	<u>Rob Friskey</u> Operations Representative	<u>11/06/2011</u> Date
Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP SI-22 Rev: 10
Procedure _____ Rev: _____
9. Procedure _____ Rev: _____
10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/21/11
SME / Instructor Date

x x
SME / Instructor Date

Revision Record (Summary)

Revision 0

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor,. Created from JPM No. N-73
- Changed NLO to EO
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

2. Set "C" accumulator level to 30% by:

set SIMACC(3)= 58065

set SIMN2ACC93)= 1290

3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist

4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Extra NSO.
2. Unit 1 is at full power, steady state, equilibrium Xenon, MOL
3. All plant systems and controls are normal

INITIATING CUE

1. The chemistry department left accumulator 1C sample valve open after sampling, resulting in a low level of 30%.
2. The sample valve has been closed, and the lineup returned to normal.
3. The accumulator has been declared inoperable due to the low level and the LCOAR 1BOL 5.1 has been entered.
4. U-1 RWST boron concentration is 2350 ppm.
5. 1B SI pump is OPERABLE
6. The US has directed you to return the accumulator level to the normal band using the 1A SI pump.
7. An EO is standing by the 1A SI pp with a copy of BOP SI-1T1

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined</u> are required to be provided to the examinee</p>				
<p>1. Refer to BOP SI-22, Raising SI Accumulator Level in Mode 1, 2 or 3</p> <p>Note: Step 1 may be performed at any time.</p>	<ul style="list-style-type: none"> o LOCATE and OPEN BOP SI-22 	_____	_____	_____
<p>2. VERIFY the following NOT discharging to applicable RWST</p> <p>Cue: <u>The Field Supervisor/WEC reports the purification pumps are not discharging to the RWST</u></p> <p>Cue: <u>The Field Supervisor/WEC reports the RWST heating pump is not discharging to the RWST</u></p> <p>Cue: <u>The Field Supervisor/WEC reports that the SFP demineralizer is not discharging to the RWST</u></p> <p>Note: Examinee checks 1CS01PA/B 'GREEN' lights are LIT</p> <p>Cue: <u>Makeup from BA blender not aligned to RWST:</u></p>	<p>Verify nothing discharging to RWST:</p> <ul style="list-style-type: none"> o 0FC03PA/B, 0A/B refueling water purification pumps o 1SI03P, RWST heating pump (May mark N/A per NOTE) o 1RE01PA/B, RCDT pump A/B o 1FC01D, spent fuel pit demineralizer effluents o 1CS01PA/B, CS pump A/B o RWST makeup from BA blender 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
3. Align mini-flow path for 1A SI pump	VERIFY/CLOSE: <ul style="list-style-type: none"> • 1CV8804A (A pump) ◦ 1SI8804B (B pump) VERIFY/OPEN: <ul style="list-style-type: none"> • 1SI8814 (A pump) ◦ 1SI8920 (B pump) • 1SI8813 (both pumps) 			
*4. Align SI pump to accumulator	At 1PM06J VERIFY/OPEN: (both pumps) <ul style="list-style-type: none"> • 1SI8806 • 1SI8923A • 1SI8888 • 1SI8871 			
5. Verify SI to radwaste isolated	At 1PM11J: <ul style="list-style-type: none"> • VERIFY/CLOSE 1SI8964 (both pumps) 			
6. Verify SI pump isolated to hot legs	At 1PM06J: VERIFY CLOSED and DEENERGIZED: (Both pumps) <ul style="list-style-type: none"> • 1SI8802A • 1SI8802B 			
<p style="text-align: center;"><u>NOTE</u></p> <p>The procedure branches at this point dependent on the SI pump to be used. The intent of this JPM is to use the 1A SI pump, therefore the examinee should proceed to step F.7.b</p> <p>Cue: <u>The SM directs that step F.7.a be omitted.</u></p>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>The Examinee may elect to have an EO do a pre-start check of the 1A SI pump prior to starting.</p> <p>Cue: (if asked): <u>The 1A SI pump is ready for a start and I am clear of the pump</u></p>				
<p>*7. Start the 1A SI pump</p> <p><i>CUE: The EO will perform the applicable portions of BOP SI-1T1</i></p>	<p>At 1PM06J:</p> <ul style="list-style-type: none"> • Take 1A SI pump C/S to start • Ensure discharge pressure does NOT exceed 1700 psig <ul style="list-style-type: none"> ◦ Initiate BOP SI-1T1 			
<p style="text-align: center;"><u>NOTE</u></p> <p>When the examinee fills the accumulator 1% to 2% above the low level alarm setpoint (alarm clears) provide the following cue:</p> <p>Cue: <u>The desired accumulator level has been achieved.</u></p>				
<p>*8. Fill 1C Accumulator</p> <p>Cue: Unit 1 Unit Supervisor acknowledges entry into 1BOL 5.1</p>	<p>At 1PM06J:</p> <ul style="list-style-type: none"> ◦ Enter 1BOL 5.1 • OPEN 1SI8878C 			
<p>*9. Stop filling accumulator</p> <p><i>Cue: <u>Unit 1 Unit Supervisor acknowledges exit BOL 5.1</u></i></p>	<p>At 1PM06J:</p> <ul style="list-style-type: none"> • CLOSE 1SI8878C when accumulator level is between 31% and <63% ◦ Exit 1BOL 5.1 			
<p>10. Stop the 1A SI pump</p>	<p>At 1PM06J:</p> <ul style="list-style-type: none"> ◦ STOP the 1A SI pump 			
<p>11. Verify/Open 1SI8821A</p>	<p>At 1PM06J:</p> <ul style="list-style-type: none"> ◦ Verify/Open 1SI8821A 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
12. Isolate accumulator fill	At 1PM06J: <ul style="list-style-type: none"> CLOSE 1SI8871 			
13. Vent SI train to SI accumulators	At 1PM011J: <ul style="list-style-type: none"> At 1PM11J, OPEN 1SI8964 At 1PM06J, MONITOR SI pump discharge pressure At PM11J, CLOSE 1SI8964 			
14. Isolate SI pump from accumulator	At 1PM06J: <ul style="list-style-type: none"> CLOSE 1SI8888 			
15. Notify chemistry to initiate 1BCSR 5.1.5 <u>Cue: Chemistry has been notified to initiate 1BCSR 5.1.5</u> <u>Cue: This JPM is completed</u>	<ul style="list-style-type: none"> NOTIFY chemistry to initiate 1BCSR 5.1.5 per Tech Spec 3.5.1 			

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Raise Accumulator Level With SI Pump

JPM Number: CR-b

Revision Number: 00

Task Number and Title: 4C.SI-02 FILL the SI System Accumulators

K/A Number and Importance: 006A1.13 3.5/3.7

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☐ No Time Critical: ☐ Yes ☐ No

Reference(s):

BOP SI-22, Raising SI Accumulator Level in Modes 1,2 or 3 (Rev. 10)

CRITICAL STEPS (*) 4, 7, 8, & 9

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 23 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Extra NSO.
2. Unit 1 is at full power, steady state, equilibrium Xenon, MOL
3. All plant systems and controls are normal

INITIATING CUE

1. The chemistry department left accumulator 1C sample valve open after sampling, resulting in a low level of 30%.
2. The sample valve has been closed, and the lineup returned to normal.
3. The accumulator has been declared inoperable due to the low level and the LCOAR (1BOL 5.1) has been entered.
4. U-1 RWST boron concentration is 2350 ppm.
5. 1B SI pump is OPERABLE
6. The US has directed you to return the accumulator level to the normal band using the 1A SI pump.
7. An EO is standing by the 1A SI pp with a copy of BOP SI-1T1

Exelon Nuclear

Job Performance Measure

Perform Transfer to Hot Leg Recirc

JPM Number: CR-c

Revision Number: 00

Date: 10/24/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/24/11</u> Date
Reviewed By:	<u>Brian Lewin</u> Operations Representative	<u>11/06/2011</u> Date
Approved By:	<u>Rob Lawlor</u> Training Department	<u>11/06/2011</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure 1BEP ES-1.4 Rev: 200
Procedure Rev:
Procedure _____ Rev:
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/20/11
SME / Instructor Date

x x
SME / Instructor Date

Revision Record (Summary)

Revision 0

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, revised to make alternate path
- Created from JPM No. N-30.
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-180 (LOCA and currently on Cold Leg Recirc)

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

2. Turn annunciators to OFF.
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. A large LOCA is in progress.
3. 1BEP-1 step 19 has been completed.
4. 5 hours 50 minutes has elapsed since SI was actuated.

INITIATING CUE

1. The Unit Supervisor has directed you to proceed with 1BEP ES-1.4, Transfer to Hot Leg Recirculation.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator’s Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the “Comment Number” column on the following pages. Then annotate that comment in the “Comments” section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site’s appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined></u> are required to be provided to the examinee</p>				
1. Refer to 1BEP ES-1.4, Transfer to Hot Leg Recirculation Note: This step may be performed at any time.	<ul style="list-style-type: none"> o LOCATE and OPEN 1BEP ES-1.4 	_____	_____	_____
*2. Place SVAG Valve Bus Feeds to Close.	At 1PM06J, CLOSE: <ul style="list-style-type: none"> • 480V Feed to Bus 131X1A/X2A • 480V Feed to Bus 132X2A/X4A 	_____	_____	_____
*3. Close RH to cold legs isol valves.	At 1PM06J, CLOSE: <ul style="list-style-type: none"> • 1SI8809A • 1SI8809B 	_____	_____	_____
<p style="text-align: center;"><u>NOTE</u></p> <p style="text-align: center;">Alternate Path JPM starts here</p>				
*4. Check 1A RH pump running.	At 1PM06J: <ul style="list-style-type: none"> • CHECK RHR pump 1A NOT RUNNING 	_____	_____	_____
*5 OPEN Train B RH HX discharge crosstie header valve	At 1PM06J: <ul style="list-style-type: none"> • OPEN 1RH8716B 	_____	_____	_____
*6. Open RH to hot legs isol valve.	At 1PM06J: <ul style="list-style-type: none"> • OPEN 1SI8840 	_____	_____	_____
*7. Stop SI pump 1A.	At 1PM06J: STOP 1A SI pump	_____	_____	_____
*8. Close SI pump 1A to cold legs isol valve.	At 1PM06J: <ul style="list-style-type: none"> • CLOSE 1SI8821A 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*9. Open SI pump 1A to hot legs isol valve.	At 1PM06J: • OPEN 1SI8802A			
*10. Start the 1A SI pump.	At 1PM06J: • START 1A SI pump			
*11. Stop SI pump 1B.	At 1PM06J: o STOP 1B SI pump			
*12. Close SI pump 1B to cold legs isol valve.	At 1PM06J: • CLOSE 1SI8821B			
*13. Open SI pump 1B to hot legs isol valve.	At 1PM06J: • OPEN 1SI8802B			
*14. Start the 1B SI pump.	At 1PM06J: • START 1B SI pump			
15. Check SI pumps to hot legs isol valves open	At 1PM06J, Verify OPEN o 1SI8802A o 1SI8802B			
16. Close SI pumps to cold leg isol valve	At 1PM06J: o CLOSE 1SI8835			
17. Place SVAG Valve Bus Feeds to TRIP.	At 1PM06J, TRIP o 480V Feed to Bus 131X1A/X2A o 480V Feed to Bus 132X2A/X4A			
Cue: <u>This JPM is completed</u>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Align ECCS to Hot Leg Recirc

JPM Number: CR-c

Revision Number: 0

Task Number and Title: 4D.EP-15 TRANSFER ECCS to Hot Leg Recirculation

K/A Number and Importance: 011EA1.11 4.2/4.2

Suggested Testing Environment: Simulator

Alternate Path: ☒ Yes ☐ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

1BEP ES1.4, Transfer to Hot Leg Recirculation (Rev. 200)

CRITICAL STEPS (*) 2 through 14

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 23 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. A large LOCA is in progress.
3. 1BEP-1 step 19 has been completed.
4. 5 hours 50 minutes has elapsed since SI was actuated.

INITIATING CUE

2. The Unit Supervisor has directed you to proceed with 1BEP ES-1.4, Transfer to Hot Leg Recirculation.

Exelon Nuclear

Job Performance Measure

Respond To 1A SX Pump Trip (Standby Pump Does Not Start)

JPM Number: CR-d

Revision Number: 0

Date: 10/20/2011

Developed By: Bill Hochstetter 10/20/2011
Instructor Date

Validated By: Mark Ristau 11/06/2011
SME or Instructor Date

Approved By: Rob Lawlor * 11/06/2011
Training Department Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See
File
Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BAR 1-2-A1 Rev 4
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

<u>Lynn Sanders (Signature on File)</u>	<u>9/24/09</u>
SME / Instructor	Date

<u>Brian Clark (Signature on File)</u>	<u>9/24/09</u>
SME / Instructor	Date

Revision Record (Summary)

Revision 00

1. New JPM
2. Operator Actions PRA Establish SX Crosstie across units.
3. The examinee will direct the performance of 3 critical steps. The high PRA value of establish SX Crosstie across units justifies counting these steps as critical steps.
4. Validated 11/06/11 by Rob Lawlor and Bill Hochstetter.

SIMULATOR SETUP INSTRUCTIONS

NOTE:

It is okay to use a similar IC to the IC listed below, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

1. Reset to IC-13
2. Verify 1A SX is running
3. Insert malfunction **SW01B** to trip the 1B SX pump
4. Insert malfunction PN1427 to off
5. Place the simulator in **RUN**.
6. On the Examiner's cue insert malfunction **SW01A (15 sec delay)** to trip the 1A SX pump
7. When Unit 2 NSO is requested to open 2SX005 modify remote function **SW07** to **100**

INITIAL CONDITIONS

You are the Unit1 NSO.

INITIATING CUE

Respond to alarms on 1PM06J.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

Note

If this JPM is performed on the simulator, only the cues underlined are required to be provided to the examinee.

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p><u>NOTE</u></p> <p>The examinee may refer to BAR 1-2-A1 at any time.</p> <p>If this JPM is performed on the simulator, only the <u>underlined</u> cue need to be provided to the examinee.</p>				
1. Refer to BAR 1-2-A1	o Locate and Open BAR 1-2-A1	—	—	—
<p><u>NOTE</u></p> <p>The next step begins the alternate path steps.</p>				
2. Start 1B SX Pump (This is an Immediate Action)	At 1PM06J: • Start 1B SX pump	—	—	—
<p><u>NOTE</u></p> <p>If this is being performed on the simulator, the Simulator Operator will act as the U2 NSO and will perform steps 3 and 5 when requested. <u>Have examinee call Unit 2 @ X-2209 during the next step.</u></p>				
*3. Determines SX Pump unavailable and DIRECTS U2 NSO to START the standby SX Pump on Unit 2 <u>Cue: Unit 2 NSO reports the Unit 2 Standby SX pump is running</u>	• DIRECTS U2 NSO to START the standby SX Pump on Unit 2	—	—	—
<p><u>NOTE</u></p> <p>Steps 4 and 5 may be performed in any order.</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
*4. Open 1SX005.	At 1PM06J: • Open 1SX005:	—	—	—
*5. DIRECTS U2 NSO to OPEN 2SX005	• DIRECTS U2 NSO to OPEN 2SX005	—	—	—
6. DETERMINE cause of trip. <u>Cue: EO reports phase C overcurrent target is up on the 1A SX pump breaker.</u> <u>Cue: EO reports phase B overcurrent target is up on the 1B SX pump breaker.</u>	o Dispatch an EO to check the 1A SX pump (BUS 141 Cub 2) o Dispatch an EO to check the 1B SX pump (BUS 142 Cub 2)	—	—	—
7. REFER to 1BOA PRI-7 <u>Cue: The Unit Supervisor will refer to 1BOA PRI-7</u>	o Direct Unit Supervisor to refer to 1BOA PRI-7.	—	—	—
<p style="text-align: center;"><u>NOTE</u></p> <p style="text-align: center;">The following steps from 1BOA PRI-7 may not be performed, if they were essentially performed per the BAR .</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
<p>7A. NOTE: if examinee performs actions contained in 1BOA PRI-7, the steps are outlined in this sub-step: Determines no SX pp running</p> <p>Note: pp fails to start Note: The solid bullet steps are the Critical Steps of the expected path of this JPM.</p> <p>Already running if following the BAR. If not following the BAR report: <u>Unit 2 NSO reports the Unit 2 Standby SX pump is running</u> Cross-tie to both U-2 SX pps</p> <p><u>Cue: 2SX033 and 034 indicates open</u></p> <p><u>Cue: U-2 SX pp disc. pressure indicates 95 psig</u></p> <p>Goes to step 6 of attachment A of 1BOA PRI-7</p>	<ul style="list-style-type: none"> o Check at least 1 SX pp running on Unit 1 o Manually open 1SX016B and 1SX027B (RCFC inlet and outlet valves) o Start 1B SX pp o Go to attachment A o Direct U-2 NSO to check RCFC inlet and outlet isolation valves for standby SX pump OPEN AND <ul style="list-style-type: none"> • Start standby U-2 SX pp • *Open 1SX005 • *Direct U-2 to open 2SX005 o Check open 1SX033 and 1SX034 o Direct U-2 to check open 2SX033 and 034 o Direct U-2 to check SX pp disc. press. > 90 psig o Check that 1 MCR Chiller and 1 Cnmt. Chiller running o Returns to main body step 2. 			
<p>8. REFER to Technical Specification 3.7.8.</p> <p><u>Cue: The Unit Supervisor will refer to Technical Specification 3.7.8.</u></p>	<ul style="list-style-type: none"> o Direct Unit Supervisor to refer to Technical Specification 3.7.8. 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
9. INITIATE corrective action. Cue: <u>The Unit Supervisor will INITIATE corrective action.</u>	o Direct Unit Supervisor to INITIATE corrective action	—	—	—
Cue: <u>This JPM is complete</u>		—	—	—

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Respond To 1A SX Pump Trip (Standby Pump Does Not Start)

JPM Number: N130a Revision Number: 0

Task Number and Title: R-OA-108 Respond to Essential Service Water Malfunction.

K/A Number and Importance: 076 A2.01 (3.5/3.7)

Suggested Testing Environment: Simulator

Alternate Path: ☒Yes ☐No SRO Only: ☐Yes ☒No Time Critical: ☐Yes ☒No

Reference(s): BAR 1-2-A1 Rev 4

CRITICAL STEPS (*) 3, 4 & 5

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 5 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments:

Evaluator's Name:_____ (Print)

Evaluator's Signature:_____ **Date:**_____

INITIAL CONDITIONS

You are the Unit1 NSO.

INITIATING CUE

Respond to alarms on 1PM06J.

Exelon Nuclear

Job Performance Measure

MANUALLY INITIATE CONTAINMENT SPRAY (BEP-0)

JPM Number: CR-e

Revision Number: 4

Date: 11/06/2011

Developed By:	<u>Brian Clark (<i>Signature on file</i>)</u>	<u>10/04/07</u>
	Instructor	Date
Validated By:	<u>Bill Hochstetter (<i>Signature on file</i>)</u>	<u>11/06/11</u>
	SME or Instructor	Date
Approved By:	<u>Rob Lawlor (<i>Signature on file</i>)</u>	<u>11/06/11</u>
	Operations Representative	Date
:	<u></u>	<u></u>

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
_____ BEP-0, Reactor Trip or Safety Injection.
_____ Procedure Rev. 202 Verified Date: 10/28/2011
- _____ 9. Pilot test the JPM:
 - a. verify cues both verbal and visual are free of conflict, and
 - b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

Revision Record (Summary)

1. **Revision 3** Changed task conditions from “CNMT press is 25#” to “Containment pressure peaked at 25#”. RCPs will be tripped in setup and action has been deleted as a critical task. The two actions of manually opening of _CS019A and placing _A CS pump to Test are each designated as critical tasks.
2. **Revision 4** Changed attachment B to attachment C based on rev. to _BEP-0

SIMULATOR SETUP INSTRUCTIONS

1. Reset the simulator to IC 179

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Turn annunciators OFF
3. When the above steps are completed for this and other JPMs to be run concurrently, then validate the concurrently run JPMs using the JPM Validation Checklist.
4. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are a unit NSO.
2. A LOCA has just occurred and 1BEP-0 is in progress.
3. The ECCS is in the injection mode with dropping RCS pressure.
4. Containment pressure peaked at 25 psig.

INITIATING CUE

The Unit Supervisor has directed you to perform step 14 of 1BEP-0, Reactor Trip or Safety Injection.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

CRITICAL ELEMENTS(*): **9, 10 & 13**

APPROXIMATE COMPLETION TIME: **26 minutes**

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
RECORD START TIME _____					
<div style="border: 1px solid black; padding: 10px; text-align: center;"> <p><u>NOTE</u></p> <p>If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the examinee.</p> </div>					
1.	Enter BEP-0 at step 14	<ul style="list-style-type: none"> ◦ LOCATE and OPEN 1BEP-0 to step 14 	o	o	
2.	Check containment pressure	At 1PM06J: <ul style="list-style-type: none"> ◦ CHECK Containment pressure 	o	o	
3.	Group 6 containment spray monitor lights	At 1PM06J: <ul style="list-style-type: none"> ◦ CHECK Group 6 CS Monitor lights LIT 	o	o	
4.	1BEP-0, Step 14.b RNO	At 1PM05J or 1PM06J: <ul style="list-style-type: none"> ◦ MANUALLY ACTUATE Containment Spray and Phase B Isolation ◦ CHECK Group 6 CS Monitor lights LIT 	o	o	
5.	1BEP-0, Attachment C	<ul style="list-style-type: none"> ◦ GO TO BEP-0, Attachment C 	o	o	
6.	1BEP-0, Attachment C, CS RWST Suction valves	At 1PM06J, CHECK OPEN: <ul style="list-style-type: none"> ◦ 1CS001A ◦ 1CS001B 	o	o	
7.	1BEP-0, Attachment C, CS Pump Header isol valves	At 1PM06J, CHECK OPEN: <ul style="list-style-type: none"> ◦ 1CS007A ◦ 1CS007B 	o	o	

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
8.	1BEP-0, Attachment C, CS eductor spray additive valves	At 1PM06J, CHECK OPEN: <ul style="list-style-type: none"> 1CS019A 1CS019B 	o	o	
<div style="border: 3px double black; padding: 10px; text-align: center;"> <p>NOTE</p> <p>Alternate path begins with step 9 and ends with step 10</p> </div>					
*9. RNO	1BEP-0, Attachment C, Step 1.c	At 1PM06J; <ul style="list-style-type: none"> PLACE 1A and/or 1B CS pump test switch in TEST 	o	o	
*10 RNO (continued)	1BEP-0, Attachment C, Step 1.c	At 1PM06J; <ul style="list-style-type: none"> MANUALLY OPEN 1CS19A and/or 1CS019B 	o	o	
11. RNO (continued)	1BEP-0, Attachment C, Step 1.c	At 1PM06J; <ul style="list-style-type: none"> PLACE 1A and/or 1B CS pump test switch in NORMAL 	o	o	
12.	1BEP-0, Attachment C, CS Eductor Inlet FCV's	At 1PM06J, CHECK OPEN: <ul style="list-style-type: none"> 1CS010A 1CS010B 	o	o	
*13. Pumps	1BEP-0, Attachment C, CS	At 1PM06J: <ul style="list-style-type: none"> Check at least <u>one</u> CS pump RUNNING 	o	o	
14.	1BEP-0, Attachment C, Step 3	<ul style="list-style-type: none"> RETURN TO BEP-0, Step 14.c 	o	o	

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
15.	Group 6 Phase B isolation monitor lights	At 1PM06J: ◦ CHECK Group 6 Phase B Isolation monitor lights LIT	o	o	
16.	Stop All Reactor Coolant Pumps	At 1PM05J: ◦ Check all RCPs STOPPED	o	o	
15.	Check CS eductor suction flow > 15 gpm	At 1PM06J: ◦ CHECK CS eductor suction flow on 1FI-CS013 and/or 1FI-CS014	o	o	
16.	Check CS eductor additive flow > 5 gpm Cue: <u>This JPM is completed</u>	At 1PM06J: ◦ CHECK CS eductor additive flow on 1FI-CS015 and/or 1FI-CS016	o	o	

RECORD STOP TIME_____

.....

Operator's Name: _____
Job Title: ☐ RO ☐ SRO ☐ SRO Cert

JPM Title: Manually Initiate Containment Spray (BEP-0)

JPM Number: N-46a

Revision Number: 4

Task Number and Title: 4D.CS-01 Manually Initiate Containment Spray (BEP-0)

K/A Number and Importance: 026A4.01 (4.5 / 4.3)

Task Standard: Manually Initiate Containment Spray BEP-0 Step 14

Suggested Testing Environment: Simulator

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant

Testing Method: ☐ Simulate ☒ Perform
Alternate Path: ☒ Yes ☐ No
SRO Only: ☐ Yes ☒ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 20 minutes **Actual Time Used:** _____ minutes

References: BEP-0, Step 14

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

INITIAL CONDITIONS

TASK CONDITIONS:

1. You are the Unit NSO.
2. A LOCA has just occurred and 1BEP-0 is in progress.
3. The ECCS is in the injection mode with decreasing RCS pressure.
4. Containment pressure peaked at 25 psig.

INITIATING CUES:

The US has directed you to initiate Containment Spray per 1BEP-0, Step 14.

Exelon Nuclear

Job Performance Measure

Unload D/G that is paralleled to the SAT

JPM Number: CR-f

Revision Number: 15

Date: 10/29/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/29/2011</u> Date
Reviewed By:	<u>Mark Ristau</u> Operations Representative	<u>11/06/2011</u> Date
Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP DG-12 Rev: 20
Procedure BOP DG-11T1, Diesel Generator Start/Stop Log Rev: 2
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/29/11
SME / Instructor Date

x x
SME / Instructor Date

Revision Record (Summary)

Revision 15

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, change was procedure rev that added 1 step to the JPM.
- Created from JPM No. N-6 rev.14
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

<p>NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.</p>

2. Start, parallel, and load DG to 5500 KW using procedure then snap for succeeding uses.
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the extra NSO.
2. The Unit is in mode 1, with a normal "at power" electrical lineup.
3. Diesel Generator 1A has been running paralleled to the grid for 4 hours at 5500 KW

INITIATING CUE

1. The Unit Supervisor has just directed you to shutdown the 1A Diesel Generator per BOP DG-12 from the Control Room.
2. Electric Operations has been notified and expects the DG load to be reduced and then removed from parallel operation.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined</u> are required to be provided to the examinee</p>				
<p>1. Refer to BOP DG-12, Diesel Generator Shutdown</p> <p>Note: Step 1 may be performed at any time</p> <p>Cue: <u>All prerequisites are met</u></p>	<p>o LOCATE and OPEN BOP DG-12</p>	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p align="center">Cue the candidate at each plateau that the time frame has been met.</p>				
<p>*2. Reduce load on the 1A DG to less than 250 KW using DG 1A Gov Adj control.</p> <p>Note: <i>The examinee may adjust VAR loading as necessary while unloading the machine</i></p>	<p>At 1PM01J:</p> <ul style="list-style-type: none"> • LOWER the DG Gov Adj control to REDUCE load to < 250 KW per the schedule in the note o 4100 KW for 2 minutes o 2750 KW for 2 minutes o 1400 KW for 15 minutes o < 250 KW 	_____	_____	_____
<p>3. Adjust reactive load to zero KVARs using Diesel Gen 1A Volt Adj. Control.</p>	<p>At 1PM01J:</p> <ul style="list-style-type: none"> o ADJUST DG KVARs to ZERO using the 1A DG VOLT ADJ 	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p align="center">The following annunciator will alarm after DG output breaker is opened:</p> <p align="center">1-21-D9, DG 1A RUNNING UNLOADED</p> <p align="center">The diesel will continue running for 5 minutes after step 10 execution of this JPM</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4. Open ACB 1413 DG 1A Feed to 4KV Bus 141.	At 1PM01J: <ul style="list-style-type: none">• OPEN ACB 1413			
NOTE: The completion of BOP DG-11T1 is NOT required for this JPM.				
5. Record the time ACB 1413 was opened on BOP DG-11T1 Cue: <u>The Unit NSO will complete BOP DG-11T1</u>	<ul style="list-style-type: none">◦ RECORD the time ACB 1413 was opened on BOP DG-11T1			
*6. VERIFY/PLACE DG 1A ACB 1413 auto re-close circuit arm selector switch in the NORM position.	At 1PM01J: <ul style="list-style-type: none">• VERIFY/PLACE DG 1A ACB 1413 auto re-close circuit arm selector switch in the NORM position.			
7. VERIFY/PLACE the Start Mode Selector Switch at 1PL07J in FAST. Cue: <u>The EO reports the start mode selector switch is in FAST</u>	Locally Start mode selector switch: <ul style="list-style-type: none">◦ DIRECT NLO to VERIFY/PLACE the Start Mode Selector switch in FAST at 1PL07J			
8. VERIFY DG air receiver pressures are ≥ 175 psig prior to stopping DG to ensure operability. Cue: <u>The EO reports the air receiver pressures are > 175 psig.</u>	Locally: Starting Air receiver pressures <ul style="list-style-type: none">◦ DIRECT NLO to VERIFY DG starting air receiver pressures ≥ 175 psig			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
9. VERIFY control mode selector switch <u>Cue: The EO reports the control mode selector switch is in REMOTE</u> Note: The operator may check the 'LOCAL' white light NOT LIT	Locally: Control mode selector switch <ul style="list-style-type: none"> DIRECT the NLO to VERIFY the Control Mode Selector Switch is in REMOTE 			
*10. PLACE the DG 1A Start Switch in STOP position. <u>Cue: This JPM is complete</u>	At 1PM01J: Stop the 1A DG <ul style="list-style-type: none"> PLACE the 1A DG Start Switch to STOP <ul style="list-style-type: none"> CHECK STOP light LIT 			

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Unload and Shutdown a Diesel Generator

JPM Number: CR-f Revision Number: 15

Task Number and Title: 4C.DG-04,05 UNLOAD a DG & SHUTDOWN a DG

K/A Number and Importance: 064A4.06 3.1/3.9

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

1. BOP DG-11T1, Diesel Generator Start/Stop Log (Rev 2)
2. BOP DG-12, Diesel Generator Shutdown (Rev. 20)

CRITICAL STEPS (*) 2, 4, 6 & 10

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 20 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the extra NSO.
2. The unit is in mode 1, with a normal "at power" electrical lineup.
3. Diesel Generator 1A has been running paralleled to the grid for 4 hours at 5500 KW.

INITIATING CUE

1. The Unit Supervisor has just directed you to shutdown the 1A Diesel Generator, per BOP DG-12 from the Control Room.
2. Electric Operations has been notified and expects the DG load to be reduced and then removed from parallel operation.

Exelon Nuclear

Job Performance Measure

Align Ventilation Systems for Emergency Operations (Failure of Fuel Handling Building Fans to Start)

JPM Number: CR-g

Revision Number: 6

Date: 10/29/2011

Revised By:	<u>Bill Hochstetter</u>	<u>10/29/2011</u>
	Instructor	Date

Reviewed By:	<u>Mark Ristau</u>	<u>11/06/2011</u>
	Operations Representative	Date

Approved By:	<u>Rob Lawlor</u>	<u>11/06/2011</u>
	Facility Representative	Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP VA-6 Rev: 4
Procedure 2BEP-0 Rev: 202
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/29/11
SME / Instructor Date

x x
SME / Instructor Date

Revision Record (Summary)

Revision X

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, only change was procedure rev that did not affect JPM.
- Created from JPM No. N-99b
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-22

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Verify:

- 0VA085Y closed
- 0VA084Y open
- 0VA086Y open

3. VC M/U Filter Unit on running VC Train

4. Place VC Recirc Charcoal Adsorber Selector Switches on **BOTH** trains of VC to ABSORB, allow dampers to realign, then place both switches back to AUTO

5. Start 0B and 0F VA Inaccessible Plenum Charcoal Booster Fans

6. Close FHB Pre-Filter Isolation Dampers:

- a. 0VA058Y/0VA059Y
- b. 0VA053Y/0VA054Y

7. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist

8. Obtain Unit-2 E-0 Attachment. B binder with steps for the examinee

9. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 2 has experienced a LOCA.
3. 2BEP-0 is in progress in response to the event.

INITIATING CUE

You are directed to verify Fuel Handling Building ventilation is aligned for emergency operation per step 6 of 2BEP-0 Attachment B.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.
.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.
.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined</u> are required to be provided to the examinee</p>				
<p>1. Refer to 2BEP-0, Reactor Trip or Safety Injection, Attachment B step 6</p> <p>Note: JPM step 1 may be performed at any time</p>	<ul style="list-style-type: none"> o LOCATE and OPEN 2BEP-0 to Attachment B step 6 o 	_____	_____	_____
<p align="center"><u>NOTE</u> <u>ALTERNATE PATH STARTS HERE</u></p> <p>JPM steps 2 through 10 verify the fuel handling building ventilation is aligned for emergency operation. The fuel handling building fans fail to start initially</p>				
<p>2. Verify FH building ventilation aligned</p>	<p>At 1PM02J, VERIFY</p> <ul style="list-style-type: none"> • 0VA04CA NOT running AND • 0VA04CB NOT running 	_____	_____	_____
<p>3. Refer to BOP VA-6, Fuel Handling Building Charcoal Booster Fan Operation</p> <p>Note: JPM step 10 may be performed at any time</p> <p>Cue: <u>(if asked) The system is lined up IAW BOP VA-E3</u></p>	<ul style="list-style-type: none"> o LOCATE and OPEN BOP VA-6 o 	_____	_____	_____
<p align="center"><u>NOTE</u></p> <p>In the following JPM steps, provide cues to the examinee based on which train is started</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4. Place one FHB Exhaust Plenum on line	At 0PM02J, VERIFY/OPEN: <ul style="list-style-type: none"> 0VA058Y and 0VA059Y (A Train) OR <ul style="list-style-type: none"> 0VA053Y and 0VA054Y (B Train) 			
5. Ensure the other train's FHB Filter Flow Control damper is CLOSED.	At 1PM02J, VERIFY/CLOSE for fan NOT being started: <ul style="list-style-type: none"> 0VA062Y (for 'A' fan) OR <ul style="list-style-type: none"> 0VA057Y (for 'B' fan) 			
6. Verify the fan transfer switch is in remote. Note: The student may use the Stop light (green) on the associated control switch to verify the fan is in REMOTE <u>Cue: The EO reports that the fan transfer switch is in the REMOTE position at 0VA01JA</u>	<ul style="list-style-type: none"> VERIFY fan transfer switch is in REMOTE 			
*7. Start one train of Fuel Handling Building Charcoal Booster fan.	At 0PM02J, START: <ul style="list-style-type: none"> 0VA04CA OR <ul style="list-style-type: none"> 0VA04CB 			
8. Ensure FHB Filter Train Flow Control damper opens.	At 0PM02J, VERIFY/OPEN: <ul style="list-style-type: none"> 0VA057Y (for 'A' fan) OR <ul style="list-style-type: none"> 0VA062Y (for 'B' fan) 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
9. Ensure FHB Charcoal Adsorber Inlet Isol opens.	At 0PM02J, VERIFY/OPEN: ○ 0VA060Y (for 'A' fan) OR ○ 0VA055Y (for 'B' fan)			
10. Ensure FHB Charcoal Adsorber Bypass Isol damper closes.	At 0PM02J, VERIFY/CLOSE: ○ 0VA051Y (for 'A' fan) OR ○ 0VA435Y (for 'B' fan)			
<i>Cue: (if required) <u>This JPM is completed</u></i>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Align Ventilation Systems for Emergency Operation (Failure of FHB)

JPM Number: CR-g Revision Number: 6

Task Number and Title: 4D.EP-19 RESPOND to Safety Injection Signal

K/A Number and Importance: 072A3.01 2.9/3.1

Suggested Testing Environment: Simulator

Alternate Path: ☒ Yes ☐ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s): BOP VA-6 Rev: 4
2BEP-0 Rev: 202

CRITICAL STEPS (*) 4 and 7

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 12 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 2 has experienced a LOCA.
3. 2BEP-0 is in progress in response to the event.

INITIATING CUE

You are directed to verify Fuel Handling Building ventilation is aligned for emergency operation per step 6 of 2BEP-0 Attachment B.

Exelon Nuclear

Job Performance Measure

Establish and Secure Normal and RH Letdown flow

JPM Number: CR-h

Revision Number: 09

Date: 10/29/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/29/2011</u> Date
-------------	---------------------------------------	---------------------------

Reviewed By:	<u>Mark Ristau</u> Operations Representative	<u>11/06/2011</u> Date
--------------	-------------------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor</u> Facility Representative	<u>11/06/2011</u> Date
--------------	----------------------------------------------	---------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP CV-17 Rev: 25
Procedure Rev: _____
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/29/11
SME / Instructor Date

X X
SME / Instructor Date

Revision Record (Summary)

Revision 9

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, only change was procedure rev that did not affect JPM.
- Created from JPM No. N-64 R8
-

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-25

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Modify Remote Function **RH02 to 100**, to open 1RH8734B when called as EO by examinee.
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
4. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are the unit NSO.
2. The plant is in MODE 4 with RHR in shutdown cooling.
3. Normal letdown is in service.
4. Train B RHR is operating with train A in stand-by.
5. Degassing of the RCS is NOT required at this time.

INITIATING CUE

The US directs you to establish 55 gpm letdown from RH and secure normal letdown per BOP CV-17.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center"><u>NOTE</u></p> <p>If this JPM is performed on the simulator, only the cues <u>underlined</u> are required to be provided to the examinee</p>				
1. Refer to BOP CV-17, step F.1 Note: May be performed at any time <u>Cue: Prerequisites are met</u>	<ul style="list-style-type: none"> LOCATE and OPEN BOP CV-17 	_____	_____	_____
2. Verify/Open 1CV460	At 1PM05J: <ul style="list-style-type: none"> VERIFY/OPEN 1CV460 	_____	_____	_____
3. Verify/Open 1CV459	At 1PM05J: <ul style="list-style-type: none"> VERIFY/OPEN 1CV459 	_____	_____	_____
4. Verify/Open 1CV8389A/B	At 1PM05J: <ul style="list-style-type: none"> VERIFY/OPEN 1CV8389A/B 	_____	_____	_____
5. Verify/Open 1CV8160	At 1PM05J: <ul style="list-style-type: none"> VERIFY/OPEN 1CV8160 	_____	_____	_____
6. Verify/Open 1CV8149A/B/C	At 1PM05J: <ul style="list-style-type: none"> VERIFY/OPEN 1CV8149A/B/C 	_____	_____	_____
7. Verify RH letdown control valve position	At 1PM05J: <ul style="list-style-type: none"> VERIFY/REDUCE 1CV128 demand to 0% 	_____	_____	_____
*8. Align RH letdown flowpath <u>Cue: Operator reports 1RH8734B is OPEN</u>	<ul style="list-style-type: none"> DISPATCH operator to locally open 1RH8734B 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*9. Place 1CC130A to Manual at 40%	At 1PM05J: <ul style="list-style-type: none">PLACE 1CC130A in MANUAL and ADJUST demand to 40%			
*10. Place 1CV131 to Manual at 40%	At 1PM05J: <ul style="list-style-type: none">PLACE 1CV131 in MANUAL and ADJUST demand to 40%			
11. Place the 1CV129 to VCT	At 1PM05J: <ul style="list-style-type: none">PLACE 1CV129 to the VCT position			
12. Adjust 1LK-112	At 1PM05J: <ul style="list-style-type: none">ADJUST 1LK-112 pot setting to 7.3 AND <ul style="list-style-type: none">PLACE 1LK-112 in AUTO			
13. Place 1CV112A in Auto	At 1PM05J: <ul style="list-style-type: none">PLACE 1CV-112A in AUTO			
*14. Establish RH Letdown Flow	At 1PM05J: <ul style="list-style-type: none">OPEN/THROTTLE 1CV-128			
*15. Adjust RH Letdown Flow	At 1PM05J: <ul style="list-style-type: none">ADJUST 1CV131 in manual to obtain desired flow			
16. Place 1CV131 in Auto, if required	At 1PM05J: <ul style="list-style-type: none">PLACE 1CV131 in AUTO, IF required			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
17. Adjust letdown temperature NOTE: When examiner is satisfied, CUE the examinee that temp= 110°F	At 1PM05J: o ADJUST 1CC130A to obtain ~ 110°F			
18. Establish auto temperature control	At 1PM05J: o PLACE 1CC130A in AUTO			
19. Verify letdown radiation monitor in service Cue: <u>An extra NSO will place 1RE-PR006 in service</u>	At the RM-11: o VERIFY/PLACE 1RE-PR006 in service per BOP AR/PR-1			
*20. Isolate normal letdown flowpath	At 1PM05J: • CLOSE 1CV8152			
21. Align 1CV129 for RCS cleanup Cue: <u>Place 1CV129 is in DEMIN position to allow continued cleanup.</u>	At 1PM05J: o PLACE 1CV129 in the proper position for RCS cleanup			
Cue: <u>This JPM is complete</u>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Establish and Secure Normal and RH Letdown

JPM Number: CR-h

Revision Number: 09

Task Number and Title: 4C.CV-16 ESTABLISHING and SECURING Normal and RH Letdown flow.

K/A Number and Importance: 005 2.1.23 4.3/4.4

Suggested Testing Environment: Simulator

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

1BOP CV-17 Rev. 25

CRITICAL STEPS (*) 8, 9, 10, 14, 15, & 20

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 20 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the unit NSO.
2. The plant is in MODE 4 with RHR in shutdown cooling.
3. Normal letdown is in service.
4. Train B RHR is operating with train A in stand-by.
5. Degassing of the RCS is NOT required at this time.

INITIATING CUE

The US directs you to establish 55 gpm letdown from RH and secure normal letdown per BOP CV-17.

Exelon Nuclear

Job Performance Measure

Operate the Fire Detection/Alarm Equipment (without control power)

JPM Number: IP-i

Revision Number: 07

Date: 10/30/2011

Revised By:	<u>Bill Hochstetter</u> Instructor	<u>10/30/2011</u> Date
-------------	---------------------------------------	---------------------------

Reviewed By:	<u>Brian Lewin</u> Operations Representative	<u>11/6/2011</u> Date
--------------	-------------------------------------------------	--------------------------

Approved By:	<u>/s/ Rob Lawlor</u> Facility Representative	<u>11/6/2011</u> Date
--------------	--------------------------------------------------	--------------------------

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP FP-22 Rev: 6
Procedure BOP FP-22A20 Rev: 0
Procedure BOP FP-22A25 Rev: 0
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 10/30/11
SME / Instructor Date

Revision Record (Summary)

Revision 7

- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, only change was procedure rev that did not affect JPM.
- Created from JPM No. N-49a R6
-

INITIAL CONDITIONS

1. You are an Equipment Operator.
2. A fire exists in the _B Diesel Generator room as determined by an alarm at _PM09J and local report.
3. Automatic actuation of CO₂ to the _B Diesel Generator room has failed.

INITIATING CUE

The Fire Chief directs you to manually initiate CO₂ to the _B Diesel Generator room using BOP FP-22.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.
.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.
.....

RECORD START TIME: _____

ELEMENT		STANDARD	SAT	UNSAT	Comment Number
1.	Refer to BOP FP-22, Manual Operation of the Carbon Dioxide and Halon Fire Suppression Systems	◦ LOCATE and OPEN BOP FP-22	—	—	—
CUE	All prerequisites have been met				
NOTE: Provide the examinee with a copy of BOP FP-22.					
2.	Refer to Section G to determine attachment	DETERMINE attachment: ◦ FP-22A20 for DG 1B ◦ FP-22A25 for DG 2B	—	—	—
CUE	(if requested) The detection zone in alarm is _D-71 Note: (If requested), local panel has control power indication				
NOTE: Provide the examinee with a copy of FP-22A20 for DG 1B <u>OR</u> FP-22A25 for DG 2B as appropriate.					
3.	Request MCR to contact Security	REQUEST Center Desk to: ◦ Call Security to ensure room clear of personnel	—	—	—
CUE	Security has verified the room is clear of personnel				
NOTE: This is a prerequisite, and was met in JPM step 1.					
4.	Request a page announcement.	REQUEST Center Desk to: ◦ Page plant for pending initiation	—	—	—
CUE	Page announcement has been made				
5.	Verify open CO2 block valve.	◦ VERIFY/OPEN _CO5022B	—	—	—
CUE	_CO5022B is 'PARALLEL' to the piping (OPEN)				

<u>ELEMENT</u>		<u>STANDARD</u>	SAT	UNSAT	Comment Number
6.	Verify Abort Switch not in Abort.	VERIFY _HS-CO004 NOT in ABORT	—	—	—
CUE	HS-CO004 is NOT in ABORT				
7.	Pull down the CO2 push button station cover.	PULL DOWN cover for: o _HS-CO002 OR o _HS-CO003	—	—	—
CUE	HS-CO002 button cover is DOWN OR				
CUE	HS-CO003 button cover is DOWN				
CUE	(if asked) The red light associated with the button is off				
NOTE: Alternate path initiated in the following step.					
8.	Locally actuate system	DEPRESS CO2 button: o _HS-CO002 OR o _HS-CO003	—	—	—
CUE	HS-CO002 button is DEPRESSED OR				
CUE	_HS-CO003 button is DEPRESSED				
9.	Verify system actuates locally.	At _CO03J: o Verify CO2 System Actuated light LIT	—	—	—
CUE	The CO2 System Actuated light is NOT LIT on _CO03J				
NOTE: If the examinee elects to try the other push button – repeat this cue.					

<u>ELEMENT</u>		<u>STANDARD</u>	SAT	UNSAT	Comment Number
10.	Verify alarm received on _PM09J.	VERIFY: <ul style="list-style-type: none">◦ Suppression alarm on _PM09J	—	—	—
CUE	The Unit NSO reports that the suppression alarm was NOT received on _PM09J				
NOTE: If the examinee elects to try the other push button – repeat this cue.					
11.	Determine manual initiation without control power is required	<ul style="list-style-type: none">◦ PROCEED to step B.1	—	—	—
*12.	Open the Master EMPC.	VERIFY/OPEN: <ul style="list-style-type: none">• 0CO09J	—	—	—
CUE	0CO09J actuator lever is in the OPEN position				
13.	Verify open CO2 block valve.	VERIFY/OPEN: <ul style="list-style-type: none">◦ _CO5022B	—	—	—
CUE	_CO5022B is ‘PARALLEL’ to the piping (OPEN)				
NOTE: _C05022B was previously verified open (JPM step 5)					
*14.	Break glass on _CO03JB	<ul style="list-style-type: none">• BREAK glass cover on _CO03JB	—	—	—
CUE	The glass cover has been broken on _CO03JB				
*15.	Actuate using EMPC actuator lever	<ul style="list-style-type: none">• PLACE actuator lever for _CO03JB in OPEN• NOTE time	—	—	—
CUE	_CO03JB actuator lever is in the OPEN position				
CUE	Use current time				

<u>ELEMENT</u>		<u>STANDARD</u>	SAT	UNSAT	Comment Number
16.	Verify alarm received on _PM09J.	VERIFY: <ul style="list-style-type: none">◦ Suppression alarm on _PM09J (_S-37)	—	—	—
CUE	The Unit NSO reports that the suppression alarm _S-37 was received on _PM09J				
*17.	Terminate CO ₂	WHEN 1 minute for 1B DG <u>OR</u> 1 minute and 40 seconds for 2B DG has passed, THEN: <ul style="list-style-type: none">• PLACE _CO03JB actuator lever in CLOSE	—	—	—
CUE	(If the 1B DG, then) 1 minute has passed				
CUE	(If the 2B DG, then) 1 minute and 40 seconds has passed				
CUE	The _CO03JB actuator lever is in the CLOSED position				
NOTE:					
*18.	Close CO2 block valve.	CLOSE: <ul style="list-style-type: none">◦ _CO5022B	—	—	—
CUE	_CO5022B is 'PERPENDICULAR' to the piping (CLOSE)				
CUE	This JPM is completed				
			—	—	—

JPM Stop Time: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Operate the Fire Detection/Alarm Equipment (without control power)

JPM Number: IP-i

Revision Number: 07

Task Number and Title: 4C.FP-02 OPERATE the Fire Detection/Alarm equipment.

K/A Number and Importance: 086A2.04 3.3/3.9

Suggested Testing Environment:: ☐ Simulator ☐ Control Room ☒ In-Plant ☐ Other

Alternate Path: ☒ Yes ☐ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

BOP FP-22, Manual Operation of the CO2 and Halon Fire Suppression Systems (Rev 6)

BOP FP-22A20, Manual Initiation of CO2 to 1B Diesel Generator Room (Rev. 0)

BOP FP-22A25, Manual Initiation of CO2 to 2B Diesel Generator Room (Rev. 0)

CRITICAL STEPS (*) 12, 14, 15, 17, & 18

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 15 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an Equipment Operator.
2. A fire exists in the _B Diesel Generator room as determined by an alarm at _PM09J and local report.
3. Automatic actuation of CO₂ to the _B Diesel Generator room has failed.

INITIATING CUE

The Fire Chief directs you to manually initiate CO₂ to the _B Diesel Generator room using BOP FP-22.

Exelon Nuclear

Job Performance Measure

Perform a Local Emergency Start of the 1B AF pp using BOA ELECT-5, Attachment D.

JPM Number: IP-j

Revision Number: 08

Date: 11/02/2011

Revised By:	<u>Bill Hochstetter</u>	<u>11/02/2011</u>
	Instructor	Date

Reviewed By:	<u>Brian Lewin</u>	<u>11/6/2011</u>
	Operations Representative	Date

Approved By:	<u>/s/ Rob Lawlor</u>	<u>11/6/2011</u>
	Facility Representative	Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure 1BOA ELEC-5 att. D Rev: 101
Procedure _____ Rev: _____
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file) 11/02/2011
SME / Instructor Date

Revision Record (Summary)

Revision 8

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 11/06/11 by Bill Hochstetter and Rob Lawlor, only change was procedure rev that did not affect JPM.
- Created from JPM No. N-56 Rev. 7
- Specified to use on Unit 1 only.

INITIAL CONDITIONS

1. You are a Non-Licensed Operator.
2. The unit has just tripped in conjunction with an electrical fire in the unit's Remote Shutdown Panel.
3. The 1A AF pump is OOS for maintenance and the 1B AF pump did not automatically start, and will not manually start with the MCR switch.

INITIATING CUE

The Shift Manager has just directed you to initiate a local emergency start of the 1B AF pump using BOA ELEC-5, Attachment D

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Locate the 1B AF pump. Note: Provide the Candidate with a copy of 1 or 2BOA ELEC-5, Attachment D.	On 383' Aux Bldg: o LOCATE _B AF pump.	_____	_____	_____
<p style="text-align: center;"><u>NOTE</u></p> <p style="text-align: center;"><u>Double Hearing Protection will be required prior to room entry. Ensure double hearing protection is available.</u></p> <p style="text-align: center;">JPM steps 2 and 3 may be performed in any order</p>				
2. Verify/Start associated Aux Lube Oil Pump. Cue: <u>Aux Lube Oil Pump CS is in the 'START' position.</u>	Inside pp room 383 L15 (U-1) Inside pp room 383 L18 (U-2) o VERIFY/START _B Aux Lube Oil Pump	_____	_____	_____
3. Verify/Start Gearbox Lube Oil Pump. Cue: <u>Gearbox Lube Oil Pump CS is in the 'START' position.</u>	Inside pp room 383 L16 (U-1) Inside pp room 383 L19 (U-2) o VERIFY/START _B Gearbox Lube Oil Pump	_____	_____	_____
*4. Place ENGINE START Switch to MAN. Cue: <u>ENGINE START Switch is in MAN.</u> Note: The "blue" "Engine ready to start" light will extinguish when switch is repositioned.	At _AF01J: • PLACE Engine Start Switch to MAN	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
5. Verify Diesel Air Box Trip reset. Cue: <u>Air Box Trip Annunciator is NOT LIT.</u>	At _AF01J o CHECK Diesel Air Box Trip reset			
6. Momentarily depress the RESET button. Cue: <u>Reset pushbutton depressed and released</u>	At _AF01J: o DEPRESS and RELEASE the Reset button			
*7. Start the 1B AF Pump. Cue: <u>The ENGINE RUNNING light is LIT.</u> Note: engine should start within 60 seconds	At _AF01J: • DEPRESS the Start button. o VERIFY the Engine Running Light is lit			
8. Monitor _B AF pump operation. Cue: <u>AF-7T1 will be completed by another NLO who will monitor the pump.</u>	o PERFORM BOP AF-7T1			
Cue: <u>This JPM is completed</u>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Local Emergency start of the B AF pump

JPM Number: IP-j Revision Number: 08

Task Number and Title: 4D.OA-35 Establish Emergency Control of Safe Shutdown Equipment

K/A Number and Importance: 061.2.1.30 4.4/4.0

Suggested Testing Environment: In-Plant

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☐ No

Reference(s):

1BOA ELECT-5 att. D

Rev: 101

CRITICAL STEPS (*) 4 & 7

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 12 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

TASK CONDITIONS

1. You are a Non-Licensed Operator.
2. The unit has just tripped in conjunction with an electrical fire in the unit's Remote Shutdown Panel.
3. The 1A AF pump is OOS for maintenance and the 1B AF pump did not automatically start, and will not manually start with the MCR switch.

INITIATING CUES

The Shift Manager has just directed you to initiate a local emergency start of the 1B AF pump using BOA ELEC-5, Attachment D.

Exelon Nuclear

Job Performance Measure

Instrument Bus Inverter Startup

JPM Number: IP-k

Revision Number: 11

Date: 9/17/2009

Revised By:	<u>Bill Hochstetter *</u> Instructor	<u>11/01/2011</u> Date
-------------	-----------------------------------------	---------------------------

Validated By:	<u>Brian Lewin *</u> SME or Instructor	<u>11/06/2011</u> Date
---------------	-------------------------------------------	---------------------------

Approved By:	<u>Rob Lawlor *</u> Training Department	<u>11/06/2011</u> Date
--------------	--------------------------------------------	---------------------------

* Signature on File

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP IP-1 Rev: 14
Procedure _____ Rev: _____
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Brian Clark (Signature on file) 9/18/09
SME / Instructor Date

Lynn Sanders (Signature on file) 9/18/09
SME / Instructor Date

SME / Instructor Date

Revision Record (Summary)

Revision 11

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator
- Added statement concerning critical step
- Added photos of panels

INITIAL CONDITIONS

1. You are an Equipment Operator.
2. The unit is at 65% power.
3. The unit has experienced a loss of Instrument Bus _11 due to failure of Instrument Inverter _11.
4. All maintenance is completed on Instrument Inverter _11 and the Clearance Order Tags have been removed.
5. Instrument Bus _11 is currently energized from the constant voltage transformer (_IP01E).

INITIATING CUE

1. The Unit Supervisor directs you to startup Instrument _11 Inverter _IP05E and to transfer Instrument Bus _11 power to the inverter per BOP IP-1.
2. An Equipment Operator is standing by at MCC _31X2.
3. All prerequisites associated with any critical step are met.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Refer to BOP IP-1 Cue: (If requested) No instrument channels are in a tripped condition and the control room has reviewed _BOA Elec-2. Cue: <u>Prerequisites are met</u>	<ul style="list-style-type: none"> LOCATE and OPEN BOP IP-1 	_____	_____	_____
2. VERIFY On Inverter Fan _IP09E. Cue: Inverter fan switch is in ON or the 'ORANGE' light is lit	At _IP09E: <ul style="list-style-type: none"> VERIFY/PLACE Inverter Fan _IP09E ON 	_____	_____	_____
*3. VERIFY/CLOSE Inverter AC feed breaker at MCC _31X2 Cub. C2. Cue: <u>EO reports that feed breaker _31X2 cub C2 is CLOSED</u>	Close Inverter AC feed breaker. <ul style="list-style-type: none"> DIRECT EO to CLOSE AC feed breaker at _31X2 cub C2 	_____	_____	_____
*4. VERIFY/CLOSE Inverter DC feed breaker, at 125 VDC Distribution Panel _11 BF1, CKT 1. Note: Located 451' elevation MEER Cue: DC feed breaker at 125 VDC panel _11 BF1, Ckt #1 is to the 'RIGHT' (CLOSED)	Close Inverter DC feed breaker. <ul style="list-style-type: none"> LOCATE 125 VDC Distribution Panel _11 BF1 CLOSE 125 VDC Distribution Panel _11 BF1 Breaker, ckt 1 	_____	_____	_____
*5. CLOSE Battery input breaker 2CB Note: Located 451' elevation MEER Cue: Battery input breaker 2CB is in the 'UP' position (ON)	At Inverter _IP05E: <ul style="list-style-type: none"> LOCATE Instrument Inverter _11 (_IP05E) CLOSE "Battery Input Bkr 2CB" on the inverter 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>The pre-charge pushbutton should not be released until DC Input Breaker, 3CB, is closed</p>				
<p>*6. DEPRESS and HOLD pre-charge button 1PB for at least 15 seconds</p> <p>Cue: <u>The Pre-charge 1PB button has been DEPRESSED and HELD for at least 15 seconds</u></p> <p>If asked: Output volts indicate > 110 on volt meter.</p>	<p>At _IP05E:</p> <ul style="list-style-type: none"> DEPRESS and HOLD “Pre-charge 1PB” button for at least 15 seconds 			
<p>*7. CLOSE DC input breaker 3CB</p> <p>Cue: <u>DC Input Breaker 3CB is in the ‘UP’ position (ON)</u></p>	<p>At _IP05E:</p> <ul style="list-style-type: none"> CLOSE “DC Input Breaker 3CB” on the inverter 			
<p>8. Release pre-charge button 1PB</p> <p>Cue: <u>The Pre-charge 1PB button has been RELEASED</u></p>	<p>At _IP05E:</p> <ul style="list-style-type: none"> RELEASE “Pre-charge 1PB” button 			
<p>9. VERIFY AC output voltage greater than 110 V</p> <p>Cue: <u>AC voltmeter indicates 119V (or as indicated)</u></p>	<p>At _IP05E, on 2VM:</p> <ul style="list-style-type: none"> VERIFY output voltage greater than 110V 			
<p>*10. CLOSE AC output breaker 4CB</p> <p>Cue: <u>AC Output Breaker 4CB is in the ‘UP’ position (ON)</u></p>	<p>At _IP05E:</p> <ul style="list-style-type: none"> CLOSE “AC Output Brkr 4CB” on the inverter 			
<p>11. Establish communications with Unit NSO</p> <p>Cue: <u>The Unit NSO has been contacted and directs you to proceed</u></p> <p>NOTE: The AEER is a ‘No Radio Zone’</p>	<ul style="list-style-type: none"> Establish communications with Unit NSO 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
12. PLACE Rod Control in MANUAL at discretion of US. Cue: <u>Rod Control is in MANUAL</u>	<ul style="list-style-type: none"> Request NSO/ US to place Rod Control in MANUAL if desired. 			
<p align="center"><u>NOTE</u></p> <p align="center">The examinee may verify that the CAUTION prior to step F.1.m is met, if the MCR is contacted give the following cue:</p> <p align="center">Cue: 1) The SR and IR trips are blocked and/or 2) No instrument channels are in a tripped condition</p> <p align="center"><i>If asked about the "critical" step give the following cue:</i></p> <p align="center">Cue: All prerequisite requirements associated with the critical step have been met. (This includes an SRO present, and US permission)</p> <p align="center">Note:</p> <p align="center">The examiner may want to use the attached picture of the Instrument bus and have the examinee explain the operation, rather than opening the panel.</p>				
13. PLACE Reserve AC feed breaker to OFF Cue: <u>RESERVE AC feed breaker is to the 'LEFT' (OFF position)</u>	<p>At 120 VAC Instr Panel _11:</p> <ul style="list-style-type: none"> PLACE the RESERVE AC feed breaker to OFF 			
14. PLACE NORMAL/RESERVE feed breaker interlock bar in a position to allow operation of the NORMAL AC Feed Breaker Cue: <u>Interlock bar is in a position to allow NORMAL AC feed breaker is operation</u>	<p>At 120 VAC Instr Panel _11:</p> <ul style="list-style-type: none"> PLACE the NORMAL/RESERVE feed brkr interlock bar in position to allow for operation of NORMAL AC feed breaker 			
*15. Place Normal AC feed breaker to ON Cue: <u>The normal AC feed breaker is to the 'LEFT' (ON position)</u>	<p>At 120 VAC Instr Panel _11:</p> <ul style="list-style-type: none"> PLACE the NORMAL AC feed breaker to the ON position 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
16. VERIFY N41 energized at _PM02J Cue: <u>The Unit NSO confirms that N41 is ENERGIZED</u>	◦ CONTACT Unit NSO to verify N41 is energized			
17. RESET N41 Positive Rate Trip as required. Cue: <u>The Unit NSO confirms that N41 Positive Rate Trip is RESET</u>	◦ CONTACT Unit NSO to verify N41 positive rate trip is reset.			
18. CLOSE Rectifier AC input breaker 1CB Cue: <u>The rectifier AC input breaker 1CB is in the 'UP' position (ON)</u>	At _IP05E: ◦ CLOSE "Rectifier AC INPUT Brkr 1CB"			
19. PLACE Rod Control in AUTO at discretion of US. Cue: <u>Rod Control is in AUTO</u>	◦ Request NSO/ US to place Rod Control in AUTO if desired.			
20. PLACE Instrument Bus _11 transformer Input breaker in OFF position. Note: Located 451' elevation MEER Cue: <u>Transformer input breaker at _IP01E is in the 'DOWN' position (OFF)</u>	◦ LOCATE Inverter Transformer _IP01E ◦ PLACE the Instrument Bus _11 Transformer Input breaker at _IP01E to OFF			
Cue: <u>This JPM is complete</u>				

RECORD STOP TIME: _____

.....

JPM SUMMARY

Operator's Name: _____ **Job Title:** ☐ EO ☐ RO ☐ SRO ☐ FS
☐ STA/IA ☐ SRO Cert

JPM Title: Instrument Bus Inverter Startup

JPM Number: IP-k Revision Number: 11

Task Number and Title: 4D.OA-22 RESPOND to a Loss of Vital AC Electrical Instrument Bus.

K/A Number and Importance: 057 AA1.01 3.7/3.7

Suggested Testing Environment: In-Plant

Alternate Path: ☐ Yes ☒ No SRO Only: ☐ Yes ☒ No Time Critical: ☐ Yes ☒ No

Reference(s):

BOP IP-1, Instrument Bus Inverter Startup (Rev. 14)

CRITICAL STEPS (*) 3, 4, 5, 6, 7 10, & 15

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☐ Other

Testing Method: ☐ Simulate ☐ Perform

Estimated Time to Complete: 20 minutes

Actual Time Used: _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments:_____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an Equipment Operator.
2. The unit is at 65% power.
3. The unit has experienced a loss of Instrument Bus _11 due to failure of Instrument Inverter _11.
4. All maintenance is completed on Instrument Inverter _11 and the Clearance Order Tags have been removed.
5. Instrument Bus _11 is currently energized from the constant voltage transformer (_IP01E).

INITIATING CUE

1. The Unit Supervisor directs you to startup Instrument _11 Inverter _IP05E and to transfer Instrument Bus _11 power to the inverter per BOP IP-1.
2. An Equipment Operator is standing by at MCC _31X2.
3. All prerequisites associated with any critical step are met.