Mark J. Ajluni, P.E. Nuclear Licensing Director Southern Nuclear Operating Company, Inc. 40 Inverness Center Parkway Post Office Box 1295 Birmingham, Alabama 35201

Tel 205.992.7673 Fax 205.992.7885

February 23, 2012

1



Docket No.: 50-425

NL-12-0371

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555-0001

Vogtle Electric Generating Plant – Unit 2 Provision of Engineering Drawings is Support of Technical Specification Revision Request for TS 3.7.14 Engineered Safety Features (ESF) Room Cooler and Safety-Related Chiller System

Ladies and Gentlemen:

Southern Nuclear Operating Company (SNC) in Letter NL-11-1628, dated December 19, 2011, proposed to revise the Vogtle Electric Generating Plant (VEGP) Unit 2 Technical Specification (TS), Appendix A to Operating License NPF-81 (specifically, TS 3.7.14) in accordance with 10 CFR 50.90.

In the course of the Nuclear Regulatory Commission's (NRC) review of that proposed TS change, a need for certain engineering drawings was recognized by the NRC staff, and a request for those drawings was made to SNC. Pursuant to that request, please find the enclosed subject drawings.

As noted in its initial proposed TS revision, SNC requests that the proposal be reviewed and approved on or before December 21, 2012, such that the revised TS can be applied prior to the refueling outage scheduled to begin on March 10, 2013.

This letter contains no commitments to the NRC. If you have any questions, please contact Mr. B. D. McKinney at (205) 992-5982.

U. S. Nuclear Regulatory Commission NL-12-0371 Page 2

Mr. M. J. Ajluni states he is Nuclear Licensing Director of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and to the best of his knowledge and belief, the facts set forth in this letter are true. Respectfully submitted.

Mark & Cijlim

M. J. Ajluni Nuclear Licensing Director

Sworn to and subscribed before me this 23 day of Felenary, 2012. Notary Public

My commission expires: 1 - 2 - 20 13

MJA /WEB

- Enclosure: Four Piping and Instrument Diagrams (P&ID) for ESF Room Cooler and Safety-Related Chiller System
- cc: <u>Southern Nuclear Operating Company</u> Mr. S. E. Kuczynski, Chairman, President & CEO (w/o enclosure) Mr. D. G. Bost, Chief Nuclear Officer (w/o enclosure) Mr. B. L. Ivey, Vice President – Regulatory Affairs (w/o enclosure) Mr. B. J. Adams, Vice President – Fleet Operations (w/o enclosure) Mr. T. E. Tynan, Vice President – Vogtle (w/o enclosure) RType: CVC7000

U. S. Nuclear Regulatory Commission

Mr. V. M. McCree, Regional Administrator

Mr. P. G. Boyle, NRR Senior Project Manager - Vogtle

Mr. L. M. Cain, Senior Resident Inspector - Vogtle



Vogtle Electric Generating Plant Unit 2 Engineering Drawings is Support of Request For TS Revision for TS 3.7.14 ESF Room Cooler and Safety-Related Chiller System

Enclosure 1 NL-12-0371


Alvin W. Vogtle Nuclear Plant P&I Diagram – ESF Room Coolers, System 1555 2X4DB228


Alvin W. Vogtle Nuclear Plant P&I Diagram – Safety Related (Essential) Chillers Unit 2 Trains A and B, System 1592 2X4DB221

Alvin W. Vogtle Nuclear Plant P&I Diagram – Essential Chilled Water Cooling Coils Unit 2 Trains A, System 1592 2X4DB233

Alvin W. Vogtle Nuclear Plant P&I Diagram – Essential Chilled Water Cooling Coils Unit 2 Trains B, System 1592 2X4DB234

Time : 01:06:40 PM





Title: C:\Documents and Settings\jlseay\Documentum\Viewed\2X4DB221.cal

LEVEL 3

LEVEL 2

LEVEL 1

LEVEL A

LEVEL E

8

COOLING

TO ESF CHILLER (X-239) 064-4* 2-1531-N7-002-000 COOLING COIL CONTROL BUILDING X-245 008-4" 221 (0-4) (341-3/4" LEVEL 3 V[-249 Ĭ >221 (D-4)> -(344-3/4 (X-336) X-107 X-414 V **H** X-416 X-415 **H** C V **H** X-460 X-417 112-1" 110-4" 110-4* 2-1561-E7-001-000 COOLING COIL AUXILIARY BUILDING Ĭ X-089 111-1" (X-458) ¥ ¥ v[→∞4 (X-334) (X-335 (X-460) 109-4" 2-1555-A7-002-000 COOLING COIL AUXILIARY BUILDING SWITCHING GEAR 2-1539-A7-002-000 COOLING COIL CONTROL BUILDING LEVEL 2 2-1555-A7-DD8-000 COOLING COIL AITYII JARY BUILDING SWITCHING GEAR 062-1*) D[D[LEVEL 1 FOR LOOP 12125 ONLY X-292 X-34D 2-1555-A7-012-000 COOLING COLL AUXILIARY BUILDING COMPONENT COOLING (12125) ZS 12125 ¥ (X−293) -(060-1 1/2* -1555-A7-018-000 COOLING COL FUEL HANDLING BUILDING X-342 -(049-1 1/2")-LEVEL A DETAIL X 4 x-009 059-1/2 2-1555-A7-016-000 COOLING COIL AUXILIARY BUILDING SAFETY INJ PUMP 2-1532-A7-002-000 CUOLING CUIL CONTROL BUILDING X-02D Å6" x 4" (050-1 1/2* X-188) 2-1555-A7-DD4-000 COOLING COIL AUXILIARY BUILDING SWITCHING GEAR (X-147) 6" X 2 1/2" x-006 -1 (X-29B) **∑**α-005) X-404) (X-14D) 6" X 2 1/2" LEVEL B DETAIL 1 X-228 NOTE 1 AV-E 2-1555-A7-014-000 cooling coll AUXILIARY BUILDING CHARGING PUMP 恸 1/Z" X Z" 052-1 1/2 XXX-B) 1 2 1/2" X 2" æ 313 3/4* 10 40 (FP NOTES: 1. ALL PIPING IS PROJECT CLASS 313 UNLESS OTHERWISE NOTED. 2. ALL PIPING MATERIALS ARE CLASS LL2. LEVEL C (II) 2* X 1 1/2* NOTE 6 (054-1 1/2")-(UNIT NO.) IS SAME AS ASSOCIATED EQUIPMENT'S UNIT NO. 2-1555-A7-010-000 COOLING COIL AUXILIARY BUILDING 054-2* (SEE TYPICAL DETA OF COOLING COILS) 2" X 1 -(XXX-A)-XXX-A) æ * X 1 1/2* <u>22</u> (TYP LINE NO. & SIZE) STRAINERS 2" AND SMALLER SHALL BE SOCKET WELDED. ¥3/4* X-193 (X-192) 2" X WELDED, 5. DELETED. 6. GTRAINER GIALL DE DAGKET 7. DELETED. 77 P 10 V (X-194) (X-196) 2-1555-A/-008-000 COOLING COIL AUXILIARY BUILDING 138 139 (X-040) VENT & DRAIN LINES SHALL BE 1" FOR PIPE HEADERS 1" AND LARGER. FOR PIPE HEADERS 3/4" AND SMALLER, VENTS AND DRAINS SHALL BE THE SAME SIZE AS THE HEADER. (x-039) (x-195) (x-197) COOLING COIL PIPING DETAIL (TYP) LEVEL D BYPASS LINE AND VALVE SHALL BE PROVIDED ON UNIT 2-1531-N7-002-000. CONTROL BUILDING XILIARY BUILDI
 10. ALL EQUIPMENT INLETS & OUTLETS ARE 3" EXCEPT THE INLET & OUTLET OF 2-1561-E7-OOT ARE 2 1/2

 11. FE-22182 (FOR EQUIPMENT 2-1555-A7-018-000) IS LOCATED UP-STREAM OF TI-22181.
CHILLED WATER COIL REFERENCE TABLE NSTRUMENT ROOT INSTRUMENTATION NUMBER CONTROL VALVE PIPE & VALVE TAG IN SEQUENCE NUMBERS AND SIZE IN INCHES ALVE TAG NUMBER VENT & D = DRAIN EQUIPMENT NO. TV (4) SIZE 2" P & ID (5) 12125 206-1 (H-3) TI (1) TI (2) FE (3) NO. SIZE NO. D E 0. SIZE NO. SIZE IS LUGATED DF-SINEAM OF IT-22181. 12. ALL ROOT VALVE NUMBERS SHALL HAVE THE PREFIX "X". 13. BYPASS VALVE 088 MUST BE THROTTLED TO PROVIDE FLOW OF APPROX. 100 GPM TO PREVENT CHILLER TRIP IN THE EVENT THE FLOW CONTROL VALVE FALS IN THE CLOSED POSITION. NO. SIZE NO. SIZE -238 D-236 D-248 V-237 22168 22169 22170 22183 22184 22185 21982 21983 21984 VALVES 2-1592-X4-114 & 2-1592-X4-115 SHALL BE GATE VALVES, MK NO. 144. 22189 22190 22174 22198 22195 22199 22200 22196 22197 026 029 028 131 148 161 133 149 162 V-02 D-468 22195 22196 22197 22177 22178 22179 22192 22193 22194 22186 22187 22188 22180 22181 22182 22223 22224 22225 1555-A7-012-000 1555-A7-014-000 1555-A7-016-000 ▲ SOUTHERN COMPANY GEORGIA POWER COMPANY ALVIN W. VOGTLE NUCLEAR PLANT

CAD 2X4DB234 ACAD2002 CYN - 01

1-23-06 CYN LCF EPD X DATE DR CHK APPV DTL

0 REDRAWN PER ABN- 52270, VER. 1.

3

SCALE: NONE

JOB NO.10604

SIZE E 34X44

P & I DIAGRAM ESSENTIAL CHILLED WATER COOLING COILS UNIT 2, TRAIN B B SYSTEM NO. 1592

DRAWING NO.

2X4DB234

1 DRAWING CATEGORY: ORITIOAL

VER


25.0

Title: C:\Documents and Settings\jlseay\Documentum\Viewed\2X4DB234.cal

THIS DOOLNENT CONTINUE PROPERTIARY, CONFEDENTIAL, MOU/OR TRUCE SCORET INFORMATION OF THE SUBBOARES OF THE SQUITEREN COMPANY OR OF THEO PARTIES. IT IS INTENDED FOR USE ONLY BY DREIDVERSE OF, OR AUTHORIZED CONTINUCTORS OF, THE SUBBOARES OF THE SQUITEREN COMPANY. UNAUTHORIZED SCOSSION, USE, DETRIBUTION, COMPANS, DSSOM-NATION, OR DISCLUSJARE OF AMY PORTION HEREOF IS PROHEBIED.

• NOTE 13

6



Title: C:\Documents and Settings\jlseay\Documentum\Viewed\2X4DB233.cal