

RULES AND DIRECTIVES

2012 FEB 23 At 7: 32

Ravi K. Aggarwal Senior Manager 312-269-6734 ravi k aggarwat@sargeritiungy.com

RECEIVED

February 22, 2012

12/30 |2011 76 FR 82323

Rules, Announcements, and Directives Branch Office of Administration U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

Dear Sirs

Subject. Comments on Draft Regulatory Guide DG-1274

suggestions to the NRC to consider for the proposed revisions.

Sargent & Lundy is pleased to have the opportunity to provide the following comments and

- 1. Page 6: add post filter or HEPA to Figure 1
- 2. Page 7: add post filter or HEPA to Figure 2
- Page 7 add "for design of test canisters only" after (ref 11) in first sentence of C.1.
- 4. Page 7: delete 'In accordance with Section 4.4 of ASME N509-2002 (Ref. 11) in first sentence of C.2.a
- Page 8: add "for design of test canisters only" after (ref 11) in first sentence of C.3
- 6. Page 9. C.3.f addresses filter layout for walk-in units, add recommended filter layout for bag-in/bag-out type units
- 7. Page 9: delete 'and Section 4.9 of ASME N509-2002 (Ref. 11) from C 3 g
- 8 Page 9, C.3 g: Table 1 of this guide is not consistent with Non-Mandatory Appendix Table 1A-C1000 Suggest deleting Table 1 from this guide.
- 9. Page 10, C.3.j. Clarify replacement of segmented sections as ultimately the entire filter unit would be replaced
- 10. Page 10, C.3.I. also refer to Section HA-4500
- 11. Page 11, C4 i suggest relocating humidity control discussion to heater section C.4.b
- 12. Page 12, C 4 j: are the manual fire systems safety-related or non-safety related?
- 13 Page 13, C.4 m. add 'section 4 13 b and' before Appendix I
- 14 Page 14, C.6.c: replace 'of' with 'and' in third line
- 15. Page 15, C.6.fr replace of with and in second line

SUNST ferieur Complète
Templote = ADH-213

E-REDS=BDM-03 Cell=M. Bayssie (MMb1) M. Come (M5c)



Office of Administration U. S. Nuclear Regulatory Commission February 22, 2012 Page 2 of 2

Yours very truly,

Senior Manager

cc Distribution:

D. H. Flens, S&L

T. J. Vogan, S&L