



U.S. Nuclear Power Plant Simulation Facility Perspective

Larry Vick & Peter Presby
NRR/DIRS/IOLB
U.S. Nuclear Regulatory Commission

DATED FEBRUARY 27, 2012



U.S. Nuclear Power Plant Simulation Facility Perspective

Larry Vick & Peter Presby
NRR/DIRS/IOLB
U.S. Nuclear Regulatory Commission

International Conference on Simulation Technology for Power Plants (PPS)
Catamaran Resort Hotel, San Diego, CA
February 15, 2012



Topics

- NRC Actions
- One Standard & One Inspection Approach
- Simulation Facility Reviews
- SBT Inspections Under RG 1.149 R4
- IMC 0609, Appendix I





NRC Actions

- **RG 1.149 Revision 4 (ML110420119)**
 - Endorsement of ANSI/ANS-3.5-2009 (ANS Copyright)
 - Endorsement of NEI-09-09 Revision 1 (ML093521659)
- **IP-71111.11 Revised (ML113270192)**
 - Biennial simulation facility inspection approach remains unchanged
- **IMC 0609, Appendix I Revised (ML113270313)**
 - Simulator SDP flowchart now has two possible color findings (GREEN and/or WHITE) instead of one (GREEN)



NRC Actions



ATTACHMENT 71111.11

INSPECTABLE AREA:	Licensed Operator Recqualification Program and Licensed Operator Performance
CORNERSTONES:	Initiating Events (10%) Mitigating Systems (10%) Barrier Integrity (10%) Emergency Preparedness (10%)
INSPECTION BASES:	<p>This inspection evaluates licensed operator performance during the conduct of facility-administered recqualification examinations, training exercises, and other examinations, such as training exercises and during selected evaluations conducted in the actual plant/main control room. This inspection also reviews the ability of the facility licensee to identify and resolve problems associated with licensed operator performance. Poor licensed operator performance can result in an increase in risk due to: (1) an increase in human errors which cause initiating events, and (2) an increase in human errors that result in taking timely and correct mitigating actions after an event. Licensed operator errors can also impact barrier integrity and emergency preparedness.</p> <p>In order to utilize recqualification examinations for measuring licensed operator performance, it is necessary that facility licensees properly develop and administer these examinations such that they are effective tools for evaluating licensed operators. Therefore, this inspection evaluates the facility licensee's ability to develop and administer these examinations. In addition, this inspection checks that licensed operators are properly maintaining their licenses by meeting requirements for training attendance, on-watch proficiency, and medical fitness.</p> <p>Finally, a portion of all licensed operator training and examination is conducted on the control room simulator, and in order for these activities to be conducted in a realistic fashion, it is necessary that the control room simulator properly model expected plant performance. Therefore, this inspection also evaluates control room</p>

¹ Throughout this inspection procedure, "licensed operator" is used to collectively refer to both licensed reactor operator and licensed senior reactor operator.
Issue Date: 12/09/11
Effective Date: 01/01/12

71111.11
1

IMC 0609, Appendix I

RG 1.149, Rev 4

Protecting People and the Environment



NRC Actions - continued

- NRC Public Web Page “Operator Licensing Program Feedback” on “Simulators” Updated
 - Removed outdated material
 - Incorporates current practices concerning simulator scope, fidelity, and performance testing
- NRC is considering a new supplemental inspection procedure IP-41502, “Nuclear Power Plant Simulation Facilities” for use on new and/or current simulators – it will be a stand-alone document apart from IP-71111.11



One Standard & One Inspection Approach

- NRC advocates the use of a single industry consensus standard (preferably the most recently adopted standard, ANSI/ANS-3.5-2009) to facilitate one inspection approach.
- Approximately 33% of all 10 CFR 55.46(c) U.S. simulation facilities have moved to ANSI/ANS-3.5-2009.
- Another 15% have plans to move to the adopted new standard this year (after their current operator licensing training cycle ends and or during the next scheduled refueling outage).



Simulation Facility Reviews

- NRC inspectors use IP-71111.11 to evaluate and assess conformance with 10 CFR 55.46
- NRC conducted about 35 simulation facility reviews in FY2011 (review schedule is posted on NRC web page)



Simulation Facility Reviews -continued

- NRC resident inspectors also conduct quarterly reviews using IP-71111.11
- Simulator fidelity discrepancies observed during the conduct of NRC operating tests are documented in the site-specific NRC Examination Report under “Simulator Fidelity Report”



Simulation Facility Reviews -continued

- Most simulator regulatory findings have been Non-Cited Violations (NCVs) against 10 CFR 55.46(c)(1) and/or (d)(1)
- Very few regulatory findings have been cited against other requirements of 55.46
- Most ANSI/ANS-3.5 findings have been against implementation of specific requirements of the standard and the conduct of simulator performance tests.



Simulation Facility Reviews -continued

- Verify adequacy of plant-referenced simulator for use in operator licensing examinations (initial & requalification) and/or for use in satisfying experience requirements
- Review samples of simulator performance tests as well as samples of modeling and hardware discrepancies (open & closed)
- Review licensee's process for ensuring continued simulator fidelity



SBT Inspections Under RG 1.149 R4

- Inspectors use IP-71111.11 to evaluate and assess licensee's compliance with 10 CFR 55.46(c) and (d)
- Review sample(s) are taken from the following types of simulator scenarios:
 - NRC Initial License Examinations (operating tests scenarios not JPMs)
 - Licensed Operator Requalification Annual Examinations (operating tests scenarios not JPMs)
 - Scenarios used for reactivity control manipulation experience



SBT Inspections - continued

- Confirmation regarding ANS-3.5 standard and associated RG 1.149 commitment
- Confirmation sampled SBT testing and methodology aligns with NEI-09-09 Revision 1
- Evaluate and assess SBT sample(s) as simulator performance tests



SBT Inspections - continued

- Confirmation ANS-3.5 related malfunction tests & test results demonstrate expected reference plant response
- Process identified simulator issue(s) that warrants entry into 0609, Appendix I SDP flowchart block #13 with follow-up, as needed, in the inspection report.



SBT Inspections - continued

- Confirmation that simulator fidelity has been sufficiently demonstrated and met
- Confirmation that significant control manipulations are completed without procedural exceptions, simulator performance exceptions, or deviations from the approved training scenario sequence.




SBT Inspections - continued

- Confirmation of the simulator's demonstrated expected plant response to operator input and to normal, transient, and accident conditions to which the simulator has been designed to respond.
- Confirm the simulator is sufficient in scope and fidelity to allow conduct of the evolutions listed in 10 CFR 55.45(a)(1) through (13), and 55.59(c)(3)(i)(A) through (AA), as applicable to the design of the reference plant.



IMC 0609 Appendix I (old)

Operator Requalification Human Performance SDP
Appendix I



Issue Date: 08/22/05


I-11

0609, App I



IMC 0609 SDP Appendix I (Revised)

Licensed Operator Requalification SDP – Appendix I



Issue Date: 12/06/11
Effective Date: 01/01/2012

I-9

0609, App. I



IMC 0609 SDP Appendix I (Revised)

- Block #13 - “Related to simulator performance, testing, maintenance, or modification?” (03.09).
 - Top-level entry block associated with control room simulator performance, maintenance, and testing, as specified in 10 CFR 55.46.
 - Answered “yes” or “no” based upon completing the specific guidance contained in section 03.09 and Appendix G of IP-71111.11, and upon completing the screening of inspection issues in accordance with IMC 0612.



IMC 0609 SDP Appendix I (Revised)

- Block #14 - “Was a simulator performance, modeling, or fidelity deficiency identified?”
 - Block differentiates between deficiencies associated simulator performance (including modeling or fidelity) and deficiencies associated with simulator testing, maintenance, and modification.
 - These issues have the potential for unrealistic operator training due to deficient simulator performance.
 - If answered “no,” deficiency is related to testing, maintenance, or modification – results in a GREEN finding.
 - If answered “yes,” proceed to block #15.



IMC 0609 SDP Appendix I (Revised)

- Block #15 - “Did deficient simulator performance, modeling, or fidelity negatively impact operator performance in the actual plant during a reportable event?”
 - Simulator provided un-realistic or negative training to licensed operators (due to deficiencies in simulator performance, modeling, or fidelity), which impacted operator performance during an event that was reportable per 10 CFR 50.72 or 50.73.
 - If answered “no,” deficient simulator performance was still identified – results in a GREEN finding.
 - If answered “yes,” results in a WHITE finding based upon deficient simulator performance affecting licensed operator performance during a plant event of NRC concern.



The End

- Questions & Comments