

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 U.S. EPR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, February 21, 2012

Work Order No.: NRC-1468

Pages 1-276

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

U.S. EPR SUBCOMMITTEE

+ + + + +

TUESDAY

FEBRUARY 21, 2012

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Dana A.
Powers, Chairman, presiding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 COMMITTEE MEMBERS:

2 DANA A. POWERS, Chairman

3 CHARLES H. BROWN, JR., Member

4 MICHAEL T. RYAN, Member

5 JOHN STETKAR, Member

6 GORDON R. SKILLMAN, Member

7

8

9 NRC STAFF PRESENT:

10 KATHY WEAVER, Designated Federal Official

11 STEPHEN HAMBRIC, NRO

12 RENEE LI, NRO

13 JULES LINDAU, NRO

14 MICHAEL MIERNICKI, NRO

15 ERIC REICHELT, NRO

16 DAVID TERAQ, NRO

17 GETACHEW TESFAYE, NRO

18 JIM XU, NRO

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ALSO PRESENT:

2 JOSEPH BRAVERMAN, BNL

3 JOHN BURGESS, AREVA NP

4 NISSEN BURSTEIN, AREVA NP

5 CARL CONSTANTINO, NUMARC

6 DAVID FOSTER, NUMARC

7 MARK FOSTER, AREVA NP

8 DARRELL GARDNER, AREVA NP

9 THOMAS HOUSTON, NUMARC

10 PRABHAT KRISHNASWAMY, Emc²

11 CHRIS McGAUGHY, AREVA NP

12 MANUEL MIRANDA, BNL

13 ASHOK NANA, AREVA NP

14 DENNIS NEWTON, AREVA NP

15 TODD OSWALD, AREVA NP

16 DO-JUN SHIM, Emc²

17 TIM STACK, AREVA NP

18 PAVAN THALLAPRAGADA, AREVA NP

19 RUSS WELLS, AREVA NP

20 KEITH WICHMAN, Emc²

21 CALVIN WONG, AREVA NP

22

23

24

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

| | |
|-------------------------------------------------------------------------------------------------------|-----|
| Call to Order and Opening Remarks Dana Powers Chairman | 5 |
| NRC Staff Opening Comments Getachew Tesfaye NRO Project Manager for the EPR DCD review | 10 |
| U.S. EPR DC Application FSAR Chapter 3, Design of Structures, Components, Equipment and Systems | 14 |
| Darrell Gardner Manager, Regulatory Affairs for U.S. EPR AREVA | 14 |
| Dennis Newton Supervisor, Nuclear Island Systems Engineering Group AREVA | 17 |
| Todd Oswald Technical Consultant, Civil Structural AREVA | 28 |
| Chris McGaughy Advisory Engineer AREVA | 112 |
| Ashok Nana AREVA | |
| John Burgess Advisory Engineer AREVA | |
| Pavan Thallapragada AREVA | |
| Mark Foster AREVA | |
| Nissen Burstein Technical Consultant AREVA | 139 |

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S (CONTINUED)

| | |
|-------------------------------------------------------------------------------------------------------------------------------|-----|
| U.S. EPR DC Application FSAR Chapter 3, Design of Structures, Components, Equipment and Systems | 166 |
| Michael Miernicki Chapter 3 Project Manager NRO | 166 |
| Section 3.6.3, Leak-Before-Break Design | 176 |
| Eric Reichelt Senior Materials Engineer Office of New Reactors Division of Engineering Component Integrity Branch | 176 |
| Dr. Prabhat Krishnaswamy Engineering Mechanics Corporation of Columbus (Emc ²) | 177 |
| Dr. Do-Jun Shim Engineering Mechanics Corporation of Columbus (Emc ²) | |
| Keith Wichman Engineering Mechanics Corporation of Columbus (Emc ²) | |
| David Terao Branch Chief Component Integrity Branch | |
| Section 3.6.2, Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping | 183 |
| Dr. Renee Li Engineering Mechanics Branch | 183 |
| Dr. Steve Hambric Applied Research Lab Penn State | 189 |
| Dr. Jules Lindau Applies Research Lab Penn State | |

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

| | |
|------------------------------------------------------------------------------|-----|
| Section 3.7.1, Seismic Design Parameters | 210 |
| Jim Xu Senior Structural Engineer Structural Engineering Branch NRO | 210 |
| Dr. David Foster NUMARC | |
| Dr. Carl Constantino | |
| Thomas Houston | |
| Joseph Braverman Brookhaven National Laboratories | |
| Dr. Manuel Miranda Brookhaven National Laboratories | |
| Questions to be Addressed on the Following Day John Stetkar | 271 |

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR POWERS: The meeting will now come to order.

This is the first day of the Advisory Committee on Reactor Safeguards, U.S. EPR Subcommittee.

I'm Dana Powers, Chairman of the Subcommittee.

ACRS members in attendance are Dick Skillman, John Stetkar, Mike Ryan, and Charles H. Brown, Jr.

MEMBER BROWN: This is the first time anybody has ever used the whole words.

CHAIR POWERS: Signs of respect just pour in around you.

(Laughter.)

Kathy Weaver of the ACRS staff is the Designated Federal Official for this meeting.

The purpose of this three-day meeting is to continue our review of the SER with open items for the Design Certification Document submitted by AREVA NP for the U.S. EPR design. Over the next three days we will hear presentations and discuss Chapter 3, Design of Structures, Components, Equipment and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Systems, Section 9.1, Fuel Handling and Storage, of
2 Chapter 9, Auxiliary Systems; and everyone's favorite,
3 Chapter 14, Initial Test Program and ITAAC, a non-
4 controversial issue, if ever there were one.

5 A portion of this meeting may need to be
6 closed to the public to protect proprietary interests.

7 I am asking this staff and the applicant to identify
8 the need for closing the meeting before we enter such
9 discussions, for the simple reason that I have no idea
10 what parts are proprietary and which parts are not.
11 And we will verify, then, that only people with higher
12 clearance and need to know are present.

13 The Subcommittee will hear presentations
14 by and hold discussions with representatives of AREVA
15 NP and the NRC and other interested persons regarding
16 these matters. The Subcommittee will gather relevant
17 information and plans to take results of the reviews
18 of these chapters, along with other chapters reviewed
19 by the Subcommittee, to the full Committee at a future
20 full Committee meeting to be determined.

21 Rules for participation in today's meeting
22 have been announced as part of the notice of this
23 meeting previously published in The Federal Register.

24 We have received no written comments or
25 requests for time to make oral statements from members

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the public regarding today's meeting. Let that not
2 be a deterrence. If you have something to say, please
3 contact either me or Ms. Weaver, and we will get you
4 on the agenda.

5 A transcript of this meeting is being kept
6 and will be made available, as stated in The Federal
7 Register notice. Therefore, we request that
8 participants in the meeting use the microphones
9 located throughout the meeting room when addressing
10 the Subcommittee. Participants should first identify
11 themselves and speak with sufficient clarity and
12 volume, so they may be readily heard.

13 Copies of the meeting agenda and handouts
14 are available in the back of the meeting room.

15 There is a telephone bridge line today,
16 and I understand we will have participants from NRC
17 consultants on the line periodically during the
18 meeting. We request that the participants on the
19 bridge line identify themselves when they speak and to
20 keep their telephone on mute during time when they are
21 just listening.

22 Do any members of the Subcommittee have
23 opening statements?

24 (No response.)

25 Seeing none, I do have one. We will mess

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the agenda on Thursday. I intend to recess after
2 the 10:30 break and to resume at 1:30, so that members
3 can be briefed on some of the initiatives that the
4 Commission has in mind. I think we can accommodate
5 that interruption in the agenda we have now.

6 If there are no other opening comments to
7 be made, I will turn to Getachew Tesfaye, the NRO
8 Project Manager for the EPR DCD review to make his
9 opening statements.

10 MR. TESFAYE: Thank you, Mr. Chairman.

11 Good morning, everyone. My name is
12 Getachew Tesfaye. I am the NRC Project Manager for
13 the AREVA U.S. EPR design certification project.

14 Today we continue our phase 3 ACRS
15 presentation of the staff's Safety Evaluation with
16 open items.

17 For the record, I will briefly summarize
18 our first three activities. To date, we have
19 completed the phase 3 presentation of 15 of 19
20 chapters and portions of another chapter.

21 We presented Chapter 8, Electric Power,
22 and Chapter 2, Site Characterization, on November 3rd,
23 2009, and Chapter 10, Steam Power Conversion System,
24 and Chapter 12, Radiation Protection, on November
25 19th, 2009.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 On February 18 and 19, 2010, we presented
2 Chapter 17, Quality Assurance, and portions of Chapter
3 19, Probabilistic Risk Assessment and Severe Accident
4 Evaluation.

5 On March 3rd, 2010, we presented Chapter
6 4, Reactor, and Chapter 5, Reactor Coolant System and
7 Connective Systems.

8 On April 6th, 2010, we presented Chapter
9 11, Radioactive Waste Management, and Chapter 16,
10 Technical Specifications.

11 On April 8th, 2010, we briefed the ACRS
12 full Committee on the seven chapters that were
13 completed through March 2010.

14 On April 21, 2010, we completed the
15 Chapter 19 presentation.

16 Also on April 21, 2010, we received a
17 letter from the ACRS full Committee Chairman on the
18 seven chapters that were completed through March 2010.

19 The letter stated ACRS has not identified any issues
20 that merit further discussion.

21 On March 27th, 2010, the staff submitted
22 its reply to ACRS.

23 On November 30, 2010, we presented Chapter
24 13, Conduct of Operation.

25 On February 7 and 8, 2011, we presented

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Group 1 section of Chapter 15, Transient and Accident
2 Analysis.

3 On March 23rd, 2011, we began the Chapter
4 15, Group 2 presentation with realistic large-break
5 LOCA topical report presentation.

6 On April 5, 2011, we presented Chapter 6,
7 Engineered Safety Features.

8 On August 18, 2011, we presented Chapter
9 18, Human Factors Engineering, and completed Chapter
10 15, Transients and Accidents, by presenting Group 2
11 sections.

12 On November 14 and 15, 2011, we presented
13 Chapter 9, Auxiliary Systems, all sections except 9.1,
14 and Chapter 7, Instrumentation and Controls.

15 This week we will complete our first
16 representation by presenting Chapter 3, Design of
17 Structures, Components, Equipment, and Systems;
18 Chapter 9, Section 9.1, Fuel Storage and Handling, and
19 Chapter 14, Verification Programs.

20 We have issued the Safety Evaluation for
21 Chapter 1, Introduction, but have no plan to make a
22 formal presentation, as it contains no new material
23 that is not covered by the other 18 chapters.

24 Our next ACRS activity is a full Committee
25 briefing on Chapters 6, 7, 11, 13, 15, 16, and 18,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 scheduled for March 8th, 2012. The full Committee
2 briefing for the remaining five chapters tentatively
3 scheduled for May 2012.

4 Mr. Chairman, on Thursday afternoon, for
5 the time allotted for Chapter 1, we may bring back
6 Chapter 7 discussions --

7 CHAIR POWERS: The watchdog timer stuff?

8 MR. TESFAYE: Yes.

9 CHAIR POWERS: Fantastic.

10 MR. TESFAYE: All right. Thank you.

11 CHAIR POWERS: Fantastic.

12 MR. TESFAYE: That completes my prepared
13 remarks.

14 CHAIR POWERS: I mean, that would be
15 terrific because, like you say, Chapter 1 is probably
16 not going to have us on the edge of our chair.

17 (Laughter.)

18 I think we could probably cruise through
19 Chapter 1 very quickly, like acknowledge its there and
20 go on.

21 But the watchdog timer is an issue. If we
22 can get that --

23 MR. TESFAYE: Well, they are working on
24 it. I am hoping they will get an answer by then.

25 CHAIR POWERS: Fantastic. That would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 terrific, if we could.

2 MR. TESFAYE: Thank you.

3 CHAIR POWERS: Okay. Darrell, are you
4 ready?

5 MR. GARDNER: I am.

6 CHAIR POWERS: Let's do it.

7 MR. GARDNER: Okay. Good morning. I am
8 Darrell Gardner, Manager, Regulatory Affairs for the
9 U.S. EPR for AREVA.

10 Obviously, we're glad to be back --

11 CHAIR POWERS: Oh, like to me some more.

12 (Laughter.)

13 MR. GARDNER: -- for what we hope is the
14 home stretch here.

15 As Getachew mentioned, we are covering
16 Chapter 3, Section 9.1, and Chapter 14. Today our
17 presentation on Chapter 3 will provide an overview of
18 this chapter of the EPR. This chapter includes a
19 variety of topics, including civil structural design,
20 pipe break analysis, equipment qualification, and
21 other topics. We have not prepared a specific
22 presentation on Section 3.1. We will describe
23 conformance to the GDC as discussed within the various
24 chapters of the FSAR.

25 AREVA's presentation for this session is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 non-proprietary. However, portions of the materials
2 that AREVA has used to support some of the pipe
3 hazards analysis in this chapter are contained within
4 proprietary technical reports. I would ask the
5 members and our presenters that, should a question
6 border on proprietary, we would request the session be
7 closed or save that question until a time we could
8 close the session.

9 The AREVA team presenting this morning
10 will be Dennis Newton, Todd Oswald, and Calvin Wong.
11 That will get us through the civil structural session.

12 We will do a little bit of personnel changeout to
13 discuss the afternoon sessions related to pipe
14 hazards, leak-before-breaks.

15 Dr. Powers, we would hope that we would be
16 able to complete Chapter 3 today. So, that is our
17 objective.

18 CHAIR POWERS: A good objective.

19 MR. GARDNER: Okay.

20 CHAIR POWERS: I do have one comment

21 MR. GARDNER: Okay.

22 CHAIR POWERS: A personal anecdote. When
23 I got out of school, a young, bushy-tailed individual,
24 I went to work for a relatively-stern director who
25 told me, in no uncertain terms, that if you use visual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 aids in a talk, they should have no more than 15 words
2 on them. And he enforced that by only reading the
3 first 15 words on any visual aid. I just toss that
4 out, having briefly gone through your visual aids
5 here.

6 (Laughter.)

7 MR. GARDNER: Well, that is encouraging.
8 Then, our presentation will go a lot faster. Okay.

9 CHAIR POWERS: It was incredible. He
10 would read the first 15 words on your viewgraph, and
11 if you had any more, he would simply deny they were
12 there because he had dictated there would only be 15
13 words on a viewgraph, and he knew you would not
14 violate his dictate.

15 (Laughter.)

16 MR. GARDNER: Right. Fifteen lines.

17 CHAIR POWERS: You violate that several
18 times.

19 (Laughter.)

20 MR. GARDNER: Can we go to the next slide,
21 please?

22 Okay. So, as I mentioned earlier, we are
23 not preparing a specific presentation on 3.1. The
24 U.S. EPR conforms to the GDC. The section of the FSAR
25 does not provide a comparison to the GDC and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 identifies the specific FSAR sections where we
2 demonstrate conformance. There is one COL information
3 item in this section, and that is that the COL
4 applicant will identify their site-specific QA program
5 plan for compliance with GDC 1.

6 That is all we had on 3.1.

7 With that, I will turn it over to Dennis
8 Newton.

9 MR. NEWTON: Okay. Good morning. My name
10 is Dennis Newton. I am Supervisor in the Nuclear
11 Island Systems Engineering Group at AREVA. I have
12 over 35 years' experience in nuclear power plant
13 design and operation and testing. I have been
14 involved with ANS standards, working on SSC
15 classifications.

16 Now that you know who I am, let's go to
17 slide 6.

18 The U.S. EPR uses three types of
19 classifications. They are the safety classification,
20 seismic classification, and quality group
21 classification. They are typically classifications
22 that are used in the nuclear industry.

23 This slide, slide 6, addresses safety
24 classification. There are three categories. There is
25 safety-related, supplemented grade, and non-safety-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 related.

2 The safety-related is based on the
3 definition of safety-related in the Code of Federal
4 Regulations.

5 The supplemented grade applies to
6 structures, systems, and components that have a
7 license requirement or commitment. And it is based on
8 NRC regulations or guidance.

9 There are three examples that I have on
10 the slide there, such as the oil collection tanks.
11 That is addressed in Reg Guide 1.189. The station
12 blackout diesel generators are addressed in Reg Guide
13 1.155. And liquid waste storage tanks are addressed
14 in Reg Guide 1.143.

15 And the third category is non-safety-
16 related.

17 MEMBER STETKAR: Dennis?

18 MR. NEWTON: Yes?

19 MEMBER STETKAR: Where does equipment,
20 within these three categories, where does equipment on
21 your design reliability assurance program list fit
22 within these three categories? I know it is not
23 safety-related, but is it supplemented grade?

24 MR. NEWTON: It would fit on the
25 supplemented grade.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: Okay. Thanks. Thank
2 you.

3 MR. NEWTON: Okay. Slide 7.

4 CHAIR POWERS: We have on occasion seen
5 analyses and that people create four categories.
6 Among those categories, they have categories for
7 equipment that proves to be risk-significant, but it
8 is not in a category of safety standard.

9 Do you have items of that nature?

10 MR. GARDNER: You're speaking about RTNSS,
11 regulatory treatment of non-safety systems?

12 CHAIR POWERS: No. No, when they look at
13 their PRA, they come up with metrics, Fussell-Vesely,
14 risk achievement with risk reduction work, that are
15 significant for the equipment, but it is equipment
16 that does not appear in the list of safety-related
17 equipment.

18 MEMBER STETKAR: That is the D-RAP.

19 MR. GARDNER: That would be the D-RAP list
20 that Mr. Stetkar spoke of.

21 MEMBER STETKAR: And you said that is in
22 your non-safety whatever it is called?

23 MR. GARDNER: Those are --

24 MEMBER STETKAR: NS-AQ.

25 MR. GARDNER: -- Supplemental QA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements for those D-RAP components.

2 MR. NEWTON: Slide 7.

3 This slide addresses seismic
4 classifications. The classification is based on Reg
5 Guide 1.29, the seismic design classification; Reg
6 Guide 1.143 on design guidance for radioactive waste
7 management, and, of course, standard review plan;
8 3.2.1.

9 There are five categories: Seismic
10 Category I. That applies to SSEs and remains
11 functional during and following an SSE.

12 Seismic Category II, radwaste seismic,
13 conventional seismic, and non-seismic.

14 CHAIR POWERS: We have recently had an
15 interesting seismic event in Virginia not too far away
16 from where your RCOLA licensee proposes to build a
17 plant. Does that have any impact on your thinking
18 about seismic?

19 MR. NEWTON: It wouldn't have any. It
20 does not have any impact on the classification. The
21 classification is based on the function that the
22 system structure or component has to perform as
23 opposed to the design criteria for assuring that that
24 can occur.

25 MR. GARDNER: Maybe another way to answer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, Dr. Powers, is that as we get into the civil
2 structural part, we could talk about how the design
3 envelopes four specific seismic considerations. But,
4 as Dennis said, it wouldn't change how you classify
5 components in terms of --

6 CHAIR POWERS: My question really is, did
7 it change any of your thinking about this plant?

8 MR. GARDNER: In what way?

9 CHAIR POWERS: Go through and say, gee, I
10 didn't think this thing would be involved in a seismic
11 event, and it was. I mean, not very much happened at
12 North Anna. It is actually kind of boring, what
13 happened at North Anna.

14 MR. GARDNER: Not for the operators.

15 CHAIR POWERS: Yes, not for the guys at
16 the plant.

17 (Laughter.)

18 MR. OSWALD: Right. I think, Dr. Powers,
19 between post-Fukushima and the Mineral, Virginia,
20 earthquake, we certainly have given it a lot of
21 thought.

22 The EPR is a pretty rugged seismic design.

23 We have a very broad spectra that we are using for
24 our certified design response spectra. We also have
25 an EOC in the Section 3.7 discussion. The high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency, we have included an additional high-
2 frequency motion.

3 But, yes, we certainly have given it a lot
4 of thought, and we feel pretty good about the Mineral,
5 Virginia earthquake and our ability to withstand that.

6 CHAIR POWERS: Interesting. Yes, go
7 ahead.

8 MR. NEWTON: Okay. Slide 8.

9 This slide addresses the quality group
10 classifications. The quality group classifications
11 are based on Reg Guide 1.26, which addresses quality
12 group classification, and on Standard Review Plan
13 3.2.2.

14 The quality group classifications apply to
15 pressure-retaining components. There are five
16 categories. The first three quality groups, A, B, and
17 C, apply to safety-related components. And the
18 classification is based primarily on the functions
19 that are given in Reg Guide 1.26.

20 And then, there is Quality Group D and
21 Quality Group E, which has -- it is not Quality Group
22 A, B, C, or D.

23 CHAIR POWERS: What you are telling me is
24 that staff told you how to do this and you did it that
25 way. Would you have done it any different? If the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Reg Guide didn't exist, would you have done it any
2 different?

3 MR. NEWTON: Well, I think the Reg Guide
4 gives a pretty good process, and we would have done it
5 similar to that. And it is pretty typical throughout
6 the nuclear industry. So, we wouldn't want to do
7 something that is totally alien from what everybody
8 else is doing.

9 CHAIR POWERS: At a different plant. I
10 mean, Darrell pointed out, you have got a fairly
11 robust plant, a little bit different design than most
12 plants. I wonder, I mean, is there a better way,
13 would there be a better way to do it for this
14 particular plant? Or it doesn't matter? All you have
15 to do is have a way of doing it.

16 MR. GARDNER: A, B, and C are Code-driven,
17 right?

18 MR. NEWTON: Yes. Yes, as Darrell is
19 mentioning, A, B, and C are based on 10 CFR 50.55(a).
20 So, it parallels the Code.

21 CHAIR POWERS: So, what you are telling me
22 is this is not a forced fit?

23 MEMBER SKILLMAN: Dennis, if I look at
24 slide 7 and 8 --

25 MR. NEWTON: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: -- if I were to look at
2 those side-by-side, could you describe where fire
3 systems are categorized, please?

4 MR. NEWTON: Well, the fire systems would
5 be, the components would be supplemented grade because
6 they are addressed in Reg Guide 1.89.

7 MEMBER SKILLMAN: These would be CS,
8 conventional seismic, CS, on your slide 7?

9 MR. NEWTON: It depends on what is called
10 out in Reg Guide 1.89 on seismic. If it gives special
11 seismic considerations for a particular component,
12 then that is what would be applied.

13 MR. GARDNER: I think the short answer to
14 your question, Mr. Skillman, is there is a table in
15 the SER that would identify the specific
16 classification for each of those components. We could
17 have someone look up if there was a specific one, but
18 there are many components listed related to fire
19 protection/detection systems. Is there a particular
20 one you had in mind?

21 MEMBER SKILLMAN: Well, I am thinking of
22 the bulk of the plumbing. I think the industry has
23 pretty much taken it onboard. We have got Seismic I
24 and Category I for reactor coolant system pressure
25 boundary, ECCS, and those SSCs that we depend upon for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 an accident.

2 It seems also to me that in many cases the
3 hardware of the fire protection system has been simply
4 related to commercial grade and possibly non-seismic,
5 unless someone pushes pretty hard to get them there.

6 MR. GARDNER: We can have someone look
7 that up. I believe ours is a higher classification.

8 MEMBER SKILLMAN: That is a curiosity
9 question. I would like that. I would like to know.

10 And if I look at slide 8, I would ask,
11 also, where it fits in your quality group
12 classification.

13 MR. GARDNER: Sure. I think we have
14 somebody who will answer back here.

15 MR. WELLS: Hi. I'm Russ Wells with
16 AREVA, the licensing group.

17 To just go ahead and answer your question,
18 part of our distribution system, as Mr. Newton
19 mentioned, is NS-AQ, based on the various Reg Guides
20 and NFPA standards. There are some portions of that
21 system that are designed to Seismic Category II that
22 are needed for the conventional area, for safe
23 shutdown equipment protection. And then, those that
24 are outside of the nuclear island are non-seismic.
25 But those that are needed to ensure inside the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conventional area and needed for safe shutdown, we
2 make a Seismic Category II.

3 MEMBER SKILLMAN: Thank you.

4 MR. WELLS: You're welcome.

5 MEMBER STETKAR: Dennis?

6 MR. NEWTON: Yes?

7 MEMBER STETKAR: Before you flip over on
8 this, I will go back to my D-RAP question. In terms
9 of quality group, equipment on a D-RAP list, where
10 does it fit into your quality group categories? It is
11 not safety-related. So, it is probably not A, B, and
12 C.

13 MR. NEWTON: It would fit under
14 supplemented grade. The method, the process that we
15 use is still being discussed between AREVA and the
16 NRC.

17 MEMBER STETKAR: Oh, is that still open?

18 MR. GARDNER: I think maybe, Mr. Stetkar,
19 where you are headed with that is it depends on the
20 components. So, if we are talking about a pressure-
21 retaining component that will be subject to quality
22 group classifications, it would fit in one of these
23 classifications.

24 MEMBER STETKAR: Thank you. Thank you.

25 MR. GARDNER: It really depends on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 component.

2 MEMBER STETKAR: Thank you.

3 MR. NEWTON: Okay. Slide 9.

4 The seismic safety and quality group
5 classification is shown in the FSAR Tier 2, table
6 3.2.2-1. That was what Russ Wells was just looking
7 at. So, if you want to get a classification for a
8 specific component, you have to look at that table.

9 MEMBER STETKAR: It is only 188 pages
10 long.

11 (Laughter.)

12 MR. NEWTON: Yes. That is why I really
13 couldn't answer the question. I don't remember them
14 all.

15 And the combined license applicant will
16 identify the site-specific SSCs.

17 CHAIR POWERS: Thank you, Mr. Newton.

18 MR. GARDNER: That is all we had on that.
19 Thank you, Dennis.

20 We will move along to Todd Oswald. We are
21 going to do this a little bit out of sequence from
22 what is in the FSAR, simply because --

23 CHAIR POWERS: Why should this be any
24 different than anything else we have done in this
25 plant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. GARDNER: It will eliminate some of
3 the shuffle of presenters, I'll say.

4 CHAIR POWERS: I think Todd gets extra
5 gold stars. I mean, Dennis gets to do 3.2. You have
6 got a whole list of things here to do.

7 MR. OSWALD: They're all tied together.

8 (Laughter.)

9 MR. GARDNER: He drew the short straw.

10 CHAIR POWERS: Serious seismic
11 implications tying these all together here.

12 Go ahead.

13 MR. OSWALD: Okay. Good morning. I'm
14 Todd Oswald. I am a technical consultant with AREVA
15 in the civil structural area.

16 My background, I came out of the Navy and
17 went into the nuclear Navy with a civil degree because
18 Mr. Rickover didn't have enough people at the time.
19 He was looking for folks. So, have a Navy nuclear
20 background, and went to McGuire Nuclear Station for
21 about eight years, and then came out, wanted to get
22 civil structural design experience. So, I was
23 involved in the System 80-Plus licensing, some work on
24 North Korean plants, and then with AREVA on the U.S.
25 EPR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: This must have been a
2 cultural shock coming from the nuclear Navy to Duke.

3 (Laughter.)

4 MR. OSWALD: Yes. Good times, all good
5 times in the past.

6 CHAIR POWERS: We would love to hear what
7 you did with the North Korean plants, but on another
8 day.

9 (Laughter.)

10 MR. OSWALD: Next slide.

11 Just to familiarize yourself, this is the
12 structures involved in the U.S. EPR design.
13 Everything you see here is in the scope with the
14 exception of the turbine building and the switchgear,
15 and then, that one building, the access building that
16 is kind of stuck in the middle there, the lighter
17 color. But these, the turbine building and the access
18 building, are included in a conceptual manner because
19 they are Category II structures. So, we have to put
20 some criteria in there, but it is conceptual design in
21 the U.S. EPR.

22 CHAIR POWERS: For the structures?

23 MR. OSWALD: For the structures, yes.

24 Okay. Section 3.3 describes the basis
25 used in the U.S. EPR design for our wind and tornado

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loading and hurricane loading. The basic wind design
2 is based on the ASCE Standard 7-05, and it represents
3 the highest hurricane wind speed for the U.S. with the
4 exception of there is an area around the tip of
5 Florida or the eastern tip of Louisiana that is not
6 enveloped by that 145-mile-an-hour basic wind speed.

7 CHAIR POWERS: Is there a physical law
8 that limits it to 145 miles per hour?

9 MR. OSWALD: A physical law?

10 CHAIR POWERS: I mean, somebody has judged
11 that 145 miles per hour is the open-terrain maximum
12 speed that we are ever going to have in the United
13 States. I have whole vast numbers of people telling
14 me that the climate is changing and things are
15 evolving, and the former Vice President is preaching
16 the gospel how things are going to be very different
17 in the coming 60 years. Is that 145 a golden number
18 now?

19 MR. OSWALD: That is in the current
20 standard.

21 CHAIR POWERS: Yes, I know. Current
22 standard is --

23 MR. OSWALD: With our importance factor we
24 apply, we end up with about a 100-year --

25 MEMBER STETKAR: Let me follow up on that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just a little bit because I do want to understand this
2 a little bit better.

3 As I understand it, that 145 miles per
4 hour is based on a 50-year, five-zero-year, recurrence
5 interval scaled by a nominal importance factor of
6 1.15. That is inferred that that is, then, a 100-year
7 recurrence interval, is that correct?

8 MR. OSWALD: That is my understanding of
9 the ASCE.

10 MEMBER STETKAR: So, there is a 60 percent
11 probability that we will exceed this in the 60-year
12 life of the plant, is that correct?

13 MR. OSWALD: That sounds --

14 MEMBER STETKAR: This is design basis.
15 There is a 60 percent probability that we will exceed
16 the design basis over the life of the plant at least
17 once.

18 MR. OSWALD: Okay.

19 MEMBER STETKAR: I'm curious why we are
20 setting the design basis on something that I would
21 bet, not a lot but I would bet, that we would exceed.

22 MR. OSWALD: Well, also, the hurricane
23 doesn't typically control our design, particularly in
24 this design.

25 MEMBER STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: We have the seismic is
2 usually predominant.

3 CHAIR POWERS: Well, if we made 165 or
4 185, there is a good chance it might control your
5 design.

6 MR. OSWALD: I would have to work through
7 the load combinations and see. I know, currently, it
8 is not a controlling load combination.

9 MEMBER STETKAR: It couldn't be at that.
10 But if you flip back to slide 11, which of the
11 buildings on this slide are designed to that 145-mile-
12 per-hour wind loading?

13 MR. OSWALD: Okay. All of them would be
14 evaluated. The 145-mile-an-hour -- let's see. Let me
15 clarify that. The Seismic Category II buildings, the
16 access building and the turbine building, they would
17 be evaluated at that 145-miles-an-hour, along with the
18 seismic design, for interaction, for their safety, to
19 protect the safety-related features. The radwaste
20 building would be designed, it is about three-fifths
21 of that value, according to Reg Guide 1.143.

22 So, essentially, everything is evaluated
23 to that with the exception of the radwaste building,
24 which would is not a Category II structure. It is not
25 a safety-related structure. It falls under our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 radwaste seismic category, and it would be evaluated
2 about three-fifths of the value. So, everything there
3 would be evaluated by that.

4 MEMBER STETKAR: I am still curious,
5 because there is a Reg Guide that says you should
6 evaluate your plant for hurricane loads at a 10 to the
7 minus 7 recurrence -- I'm sorry -- exceedance
8 frequency, which is about 1 in 10 million years rather
9 than 1 in 100 years. I am curious why you are using
10 1-in-100-year wind loading that is actually derived
11 from some scaling of 1-in-50-year wind loading. It
12 just doesn't seem consistent.

13 I have no idea, you know, I don't know
14 what the -- actually, I do, but it is beyond this
15 discussion for this Subcommittee. I don't know what
16 that 1-in-10-million-year, straightline, 3-second wind
17 gust speed would be for a bounding site, if you want
18 to exclude the coastal zones along the southeastern
19 coast and Gulf Coast. I suspect it would be higher
20 than 145.

21 MR. OSWALD: I suspect it would at that
22 return period.

23 MEMBER STETKAR: Yes.

24 MR. OSWALD: I don't know what the number
25 is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GARDNER: I think we can say, though,
2 this is the design envelope. Of course, if you were
3 to site it in areas where you saw that, then you would
4 evaluate those higher loads and see whether or not
5 those were controlling loads.

6 MEMBER STETKAR: Do you have any idea what
7 fraction of the U.S. would exceed it, if I used a 1-
8 in-10-million-year recurrence interval rather than a
9 1-in-100-year recurrence interval? You know, if the
10 COL went out and looked at what is their site-specific
11 1-in-10-million-year recurrence interval, would that
12 exceed 145 miles per hour? What fraction of the
13 potential sites in the U.S. might exceed that?

14 MR. OSWALD: I don't know. I would guess
15 any hurricane-prone region would --

16 MEMBER STETKAR: I don't know. I mean, I
17 have no idea, even on straightline winds inland. I
18 just don't know.

19 MR. OSWALD: Yes, I don't, either. I
20 don't know what that --

21 MEMBER STETKAR: But that is the way it is
22 derived, right? It is a nominal 50-year recurrence
23 interval scaled by that magic 1.15 factor?

24 MR. OSWALD: 1.15.

25 MEMBER STETKAR: And that is inferred

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that it is a 1-in-100-year event?

2 MR. OSWALD: That's correct, to meet the
3 SRP.

4 MEMBER STETKAR: Which, if I operate the
5 plant for 60 years, there is a 60 percent probability
6 that that event would occur at least once during the
7 life of the plant.

8 MR. GARDNER: It would depend on the site-
9 specific location.

10 MEMBER STETKAR: For the certified design,
11 there is a 60 percent probability that you will exceed
12 the straightline wind-loading design basis over the
13 life of the plant. For the certified design. Now I
14 am not sure about site-specific. There may be a
15 higher or lower probability.

16 MR. OSWALD: Right. It would depend on
17 the site-specific value.

18 Okay? Moving on there, we talk about
19 exposure Category C is used when determining the
20 velocity pressure coefficients. And again, as you
21 mentioned, Category C is applicable to flat, open
22 country, grasslands and all water surfaces in
23 hurricane-prone regions.

24 As far as round structures, we use ASCE
25 Paper 3269 to derive those pressure velocity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 coefficients.

2 Tornado wind design, tornado winds are
3 considered in the design of all the Category I
4 structures and in the evaluation of the potential for
5 non-seismic Category I structures to interact with
6 Category I structures, as we talked about earlier.

7 Again, the tornado wind design is per the
8 Reg Guide 1.76, Region 1, which is the most severe
9 region identified in the Reg Guide. As I mentioned,
10 Reg Guide 1.143 is used for the radwaste structures,
11 which is about three-fifths of the Reg Guide 1.76
12 tornado wind design parameters.

13 The tornado wind design parameters are 230
14 miles an hour total, which consists of 184-mile-an-
15 hour rotational wind speed and 46-mile-an-hour
16 translational. The maximum radius considered is 150
17 feet for the tornado.

18 As discussed earlier, also, there are COL
19 information actions for the COL to ensure that our
20 design envelopes their site.

21 MEMBER STETKAR: Todd, I was reading in
22 the SER. There is quite a long discussion about
23 tornado wind-loading designs. Have you committed to
24 design the nuclear auxiliary building, turbine
25 building, and access building to that 230-mile-per-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hour tornado wind-loading?

2 MR. OSWALD: For the interaction.

3 MEMBER STETKAR: Yes.

4 MR. OSWALD: For the interaction, Seismic
5 Category II interaction, yes, we have.

6 MEMBER STETKAR: Okay. So, that is just
7 interaction --

8 MR. OSWALD: Correct, not the missiles.

9 MEMBER STETKAR: -- but not
10 necessarily structural integrity, if it is not an
11 interaction?

12 MR. OSWALD: That's correct.

13 MEMBER STETKAR: Okay.

14 MR. OSWALD: And not the missile design,
15 not the missile barrier design, because there is no
16 safety-related equipment there.

17 MEMBER STETKAR: Okay. Thank you.

18 MR. OSWALD: Okay?

19 Section 3.4 describes the basis used for
20 the design for flood for the U.S. EPR. The internal
21 flood protection strategy is based on physical
22 separation to limit the damage to one division. The
23 safeguard buildings, the emergency power generation
24 buildings, and the central service water buildings are
25 separated by divisions. The fuel building is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 separated into two separate divisions.

2 There are no doors or unsealed
3 penetrations in division walls below grade in the U.S.
4 EPR design.

5 The reactor building interior and reactor
6 building annulus have no physical divisional
7 separation for flood barriers. The maximum water
8 inventory of the reactor building all floors into the
9 IRWST, the In-Containment Refueling Water Storage
10 Tank. And the water inventory in the annulus is
11 calculated that it wouldn't result in a flood level
12 high enough to reach safety-related equipment.

13 For the external design, the U.S. EPR
14 uses, what we refer to as, a dry site concept, where
15 we have site grade level is above the maximum design
16 flood level or the maximum flood level for a given
17 site. The site grade is at least 1 foot above the
18 maximum flood level. Groundwater is at least 1 meter
19 below the grade elevation.

20 And the COL applicants are required to
21 determine the probable maximum flood, the probable
22 maximum precipitation, evaluate the seiche and other
23 hydrologic conditions per Reg Guide 1.159 and Reg
24 Guide 1.102.

25 MEMBER RYAN: Just a quick question on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 groundwater, what groundwater level is that? Is that
2 the maximum groundwater elevation or some average? Or
3 how do you do it?

4 MR. OSWALD: No, that is maximum. We
5 consider in our structural design that that ground
6 water is the 1-meter below grade for all the stability
7 considerations, sliding and overturning.

8 MEMBER RYAN: So, how do you know that 1-
9 meter below grade is the maximum groundwater level for
10 every site or for any site?

11 MR. OSWALD: Well, we don't. We have to
12 evaluate it. If the site comes in and it is above
13 that, we are into a site-specific evaluation. But the
14 standard design is based on the 1-meter below grade.

15 MEMBER RYAN: All right. So, you've got a
16 provision to deal with that, if you have to?

17 MR. OSWALD: Right.

18 MEMBER RYAN: Okay.

19 MR. OSWALD: The COL applicant has to
20 demonstrate that.

21 MEMBER RYAN: Thanks. Yes.

22 MR. OSWALD: And if it is above, we look
23 at site conditions and evaluate it.

24 MEMBER STETKAR: A couple of questions,
25 Todd.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 One is I was reading about the external
2 flooding. In one place, I see that it says -- it is
3 Section 3.4.2.4.1 of the SER, but I didn't bother
4 going back and finding if in the FSAR. But the U.S.
5 EPR design, the yard grade elevation is assumed to be
6 .305 meters, 1 foot above the elevation of the
7 probable maximum flood, which is what is on your slide
8 there.

9 In another place, there were questions
10 about access barriers from external flooding. In
11 other words, door heights above grade and things like
12 that. There was a statement -- and this, again, is
13 from the SER, so I want to make sure that I am
14 understanding it correctly.

15 It says, the applicant stated that
16 elevation zero is the elevation of the threshold of
17 the lowest personnel access penetration through which
18 flood water might gain access. Plant grade is the
19 finished top of the supporting soil. Elevation zero
20 is approximately 1 foot above plant grade.

21 MR. OSWALD: Yes.

22 MEMBER STETKAR: Now I am just sort of a
23 simple guy. If I walk up and I am standing on the
24 ground, and I look at a door and that door has a gap
25 under it, is that gap 1 foot above the maximum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 external flood level from the probable maximum flood
2 or is it 2 feet above that level?

3 MR. OSWALD: In our evaluations, that
4 actually is 1 foot in our calculations.

5 MEMBER STETKAR: So, all I am doing is
6 trying to understand the margins that are available in
7 the certified design. So, I basically have a 1-foot
8 margin for water intrusion from the nominal probable
9 maximum flood. Is that --

10 MR. OSWALD: Let me clarify. In our
11 evaluations, we have calculated. That is what we use
12 for our structural design. Actually, we are requiring
13 it to be 1 foot below finished grade, the nominal
14 finished grade. If you look at table 2.1.1 -- and we
15 will check that. You should have table 2.1.1. It is
16 described as 1 foot below finished grade is the
17 maximum flood level.

18 MEMBER STETKAR: Well, my question is --

19 MR. OSWALD: That would put it 2 feet
20 below the door threshold.

21 MEMBER STETKAR: Two feet below the door
22 threshold?

23 MR. OSWALD: Yes.

24 MEMBER STETKAR: Okay. At times, the term
25 finished grade sometimes gets a bit muddied. That is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what I was trying to understand.

2 MR. OSWALD: Right. And we will look at
3 table 2.1.1 here in a moment --

4 MEMBER STETKAR: Okay.

5 MR. OSWALD: -- and see how it is worded.
6 But it is worded, it will be 1 foot below the
7 finished grade, is the requirement.

8 MEMBER STETKAR: But the door threshold
9 is --

10 MR. OSWALD: Is a foot above.

11 MEMBER STETKAR: Is a foot above finished
12 grade?

13 MR. OSWALD: Right. Two feet above the --

14 MEMBER STETKAR: Is that true for all
15 structures in the plant?

16 MR. OSWALD: All safety-related, yes.

17 MEMBER STETKAR: All safety-related.

18 MR. OSWALD: All safety-related
19 structures.

20 MEMBER STETKAR: Thanks, Mr. Chair. Thank
21 you.

22 MR. OSWALD: Yes. It gets very confusing.

23 MEMBER STETKAR: Make sure that is
24 consistent.

25 MR. OSWALD: It gets very consistent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And again, was reading
2 from the SER, and sometimes the nuances get a bit
3 muddled in the translations. These are from RAIs. We
4 don't have all of the RAIs and responses, as far as
5 the Subcommittee, nor do we want them. We don't want
6 them.

7 (Laughter.)

8 CHAIR POWERS: On the other hand, I think
9 you deserve them.

10 MEMBER STETKAR: No, I don't.

11 (Laughter.)

12 I will just forward them to you, and they
13 will disappear down the black hole that we were
14 talking about.

15 (Laughter.)

16 MR. OSWALD: Okay. The next slide.

17 MEMBER STETKAR: Oh, I'm sorry.

18 MR. OSWALD: Okay.

19 MEMBER STETKAR: I was in these side
20 conversations.

21 Also, again, reading from the SER, there
22 was some discussion in the reactor building. I
23 understand flood levels in the annulus. I understand
24 where safety-related -- I guess cable penetrations are
25 relative to the maximum flood level in the annulus.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In the reactor building, there was some
2 discussion -- and again, it is filtered through SER
3 summaries of RAI responses -- it seemed as though
4 there may be safety-related, I'll call them, SSCs,
5 because I don't know what they are, inside the reactor
6 building that may be below the nominal flood level,
7 below zero elevation. Is that true? And if so, what
8 are they?

9 MR. OSWALD: Below the zero elevation are
10 --

11 MEMBER STETKAR: Let me tell you what got
12 me. There are a couple of sentences that said,
13 submerged operation of safety-related -- I'm sorry --
14 no submerged SSCs perform a safety-related function
15 for safe shutdown of the plant or to mitigate the
16 consequences of an accident and no safety-related SSCs
17 that perform safety-related functions while being
18 partially or completely flooded.

19 There were a lot of qualifying phrases
20 like it led me to believe that there might be safety-
21 related things that could be flooded, but some
22 determination was made that they were not necessary
23 for some type of accident.

24 MR. OSWALD: I am not aware of -- I am
25 going to ask Tim --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Or are you aware that in
2 the reactor building all safety-related equipment is
3 above the flood level? I mean, if you can say that,
4 that would solve my problem. But all is a big word.

5 MR. STACK: Yes, John, all is a big word.

6 MEMBER STETKAR: All is a big word.

7 MR. STACK: This is Tim Stack from AREVA.

8 What I would like to do is I would like to
9 follow up with you today. I would like to retalk with
10 our design engineers directly and determine if there
11 is anything below the flood plain that we excluded
12 because we don't need it.

13 MEMBER STETKAR: Yes, that's what I was --

14 MR. STACK: That is what you are trying to
15 determine.

16 MEMBER STETKAR: That is what I was
17 curious about because I was just curious because of
18 the way the phrases were put. I couldn't find a
19 phrase that said no safety-related equipment in the
20 reactor building is below the flood level.

21 MR. STACK: Right. We will follow up and
22 we will confirm that today.

23 MEMBER STETKAR: Okay. Thanks, Tim.

24 MR. OSWALD: That is the flood level being
25 zero or 1 foot below --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: No, well, I think for
2 internal flooding, I'm talking internal flood. I
3 mean, it could come in from the outside or it could
4 come in -- it is based on the fire water piping, I
5 think.

6 MR. STACK: So, again, you are just asking
7 for confirmation that there are no safety-related
8 components below the flood plain or, if there are,
9 that we have evaluated and determined they are not
10 needed?

11 MEMBER STETKAR: That's correct. And
12 what's the basis for why they are not needed then?
13 And I think it was -- you know, I don't care whether
14 the water comes in from the outside or whether it is a
15 fire water pipe break inside. The source of the water
16 is irrelevant. It is just the flood elevation and if
17 there is anything below it.

18 Thanks. Thanks, Tim.

19 MR. OSWALD: Okay. We will follow up on
20 that one.

21 Okay. Section 3.5 describes the approach
22 used to protect the safety-related SSCs from
23 externally- and internally-generated missiles. There
24 is a screening criteria that we are using. Missiles
25 are screened out if the probability is less than 1

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 times 10 to the minus 7.

2 The internal missile sources include the
3 high-energy fluid systems, rotating equipment, and
4 pipe ruptures. The external missile sources include
5 turbine missiles or tornados missiles.

6 The strategy we are using in the U.S. EPR
7 design for missile protection is to locate the safety-
8 related SSC within a missile-resistant structure, such
9 as a Seismic Category I structure; separating
10 redundant systems from missile path or the range of
11 the missile, or use local shields or barriers, or
12 design the SSC to withstand the impact of the missile.

13 Design features to prevent the generation
14 of missiles are also included, such as valve bonnet
15 designs where we don't have the valve stem coming out,
16 and then the orientation of the missiles to prevent a
17 strike on safety-related equipment.

18 COL applicants are required to evaluate
19 their site-specific conditions to see if there are any
20 other missiles to be considered for a site.

21 CHAIR POWERS: When you are relying on
22 orientation, that means you have either some physical
23 rule that says a missile cannot come in certain
24 directions or a probability distribution.

25 MR. OSWALD: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Which is it? You can take
2 the turbine as an example.

3 MR. OSWALD: It is a physical. Physical,
4 yes, probability and physical. You said, which is it.
5 It would be both.

6 CHAIR POWERS: Yes, I mean, if I look at
7 my turbine and I say, okay, the turbine blade
8 breaks --

9 MR. OSWALD: Right.

10 CHAIR POWERS: -- and the rotor breaks,
11 and it is most likely to come out orthogonal to its
12 axis, but it promptly encounters some structures. And
13 so, there is some probability that it is actually
14 going to come up in a direction of less than 90
15 degrees to the axis.

16 So, what do you do? Do you just say it is
17 going to be 90 degrees to the axis, and there is a
18 physical law that says that? Or is it some
19 probability that it will be less than 90 degrees?

20 MR. OSWALD: Right. We are looking at 45
21 degrees, typically, is what we are looking at.

22 CHAIR POWERS: Forty-five degrees, and it
23 will never come off less than that?

24 MR. GARDNER: Yes, there is a zone of
25 influence in one of the Reg Guides, and I don't recall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Reg Guide number. It may be that one.

2 MEMBER STETKAR: 1.115.

3 MR. GARDNER: Thank you.

4 MEMBER STETKAR: You're welcome.

5 MR. GARDNER: And that is the zone of
6 influence that we use for turbine missiles.

7 CHAIR POWERS: Okay. So, you just use
8 what that tells you to use? Okay.

9 MR. GARDNER: Right.

10 CHAIR POWERS: They would never lead you
11 astray.

12 (Laughter.)

13 MEMBER STETKAR: Let me follow up on
14 turbine missiles. It is my understanding, and if you
15 go back to slide 11, it is graphically a little bit
16 more clear, the central service water buildings 3 and
17 4 are well within whatever that footprint is. They
18 are directly orthogonal to the turbine. And whatever
19 direction plant north is, the closer to our viewpoint
20 ends both emergency power generating building 3 and 4
21 and 1 and 2, the near ends of those are, as I
22 understand it, just within that possible footprint.

23 So, for this plant, there are safety-
24 related SSCs that are within that nominal footprint.
25 And yet, you claim that this turbine is favorably-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 oriented. I don't understand that.

2 And I will read a quote out of the Reg
3 Guide. Plants designed with no -- no is a very small
4 word or very big, depending on how you interpret it --
5 plants designed with no essential SSCs within the low-
6 trajectory hazard zone are considered to have a
7 favorable turbine orientation.

8 As I understand it, you have got four
9 safety-related SSCs within this footprint. So, I
10 don't understand why you characterize your plant as
11 having favorable turbine orientation.

12 The difference being that, if you have a
13 favorable turbine orientation, you only have to show
14 that missile ejection frequency is less-than-10-to-
15 the-minus-4 event per year for a favorably-oriented
16 turbine. If you have an unfavorably-oriented turbine,
17 that criterion drops to 10 to the minus 5 per year, a
18 decade lower.

19 So, I was going to ask the staff about
20 this because they have, apparently, agreed that you
21 are favorably-oriented, which is troubling to me. But
22 I am curious what basis you used for making that
23 determination.

24 MR. GARDNER: I will attempt to give that
25 a shot. I don't have that Reg Guide in front of me,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Mr. Stetkar. But one part of the language, as I
2 recall, was that that definition is with respect to
3 the containment, and there's probably some other words
4 that you have read. But it is the favorable
5 orientation was with respect to the containment.

6 MEMBER STETKAR: I don't believe it's --

7 MR. GARDNER: Now we have also evaluated
8 other SSCs that are in that zone of influence, and we
9 have done that evaluation. So, in that context, that
10 is why we say it is favorably-oriented with respect to
11 the containment.

12 MEMBER STETKAR: I would be curious to
13 find that qualification because I searched the Reg
14 Guide, and they do talk about impacts on containment,
15 but to try to find a definition of what a favorably-
16 or unfavorably-oriented turbine is, I mean, it is not
17 a crisp, one-line definition.

18 MR. GARDNER: We can look for that
19 language that I am referring to during one of the
20 breaks.

21 MEMBER STETKAR: Because I find, this is a
22 direct quote: plants designed with no essential SSCs
23 within the low-trajectory hazard zone are considered
24 to have a favorable turbine orientation. And by
25 exclusion, anything else would be an unfavorably-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 oriented --

2 MR. GARDNER: Are you reading from the SER
3 or the Reg Guide?

4 MEMBER STETKAR: I am reading directly
5 from the Reg Guide, Revision 2.

6 MR. GARDNER: We will look for the
7 language I am referring to.

8 CHAIR POWERS: The language is less of
9 concern than the design here.

10 MEMBER STETKAR: The language is less of a
11 concern than the design, that's right.

12 CHAIR POWERS: And it would appear that
13 the essential service water building is subject to
14 missiles.

15 MEMBER STETKAR: It would appear that.

16 MR. OSWALD: Some portion. One of them is
17 blocked.

18 CHAIR POWERS: Yes, one of them is blocked
19 by the other one.

20 (Laughter.)

21 MR. OSWALD: Well, we also have the
22 requirement of the frequency, the 1 times 10 to the
23 minus 7. And I will look at that. Is that on the
24 turbine --

25 MEMBER STETKAR: I don't want to get into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a long discussion, because of time, on Reg Guide
2 1.115. But what they say is that you have three
3 probabilities. P1 is the missile ejection. P2 is the
4 likelihood of a missile, given it is ejected, striking
5 a target. And P3 is the likelihood that the target
6 damaged, given that it is struck.

7 The Reg Guide essentially provides a very,
8 very coarse screening process, and it says, unless you
9 are going to do a detailed evaluation of P2 and P3,
10 they will take some nominal values. And they focus on
11 the missile ejection probability.

12 So, they basically presume 10 to the minus
13 3 conditional strike and damage probability for a
14 favorably-oriented turbine, the product of P2/P3; a 10
15 to the minus 2 for an unfavorably-oriented turbine.
16 They back out from 10 to the minus 7, then, the
17 frequencies of 10-to-the-minus-4 missile ejection or
18 10 to the minus 5, depending on the turbine
19 orientation.

20 And most people focus on the missile
21 ejection frequency as the basis, and you do the
22 turbine missile, you know, the turbine overspeed
23 analysis and turbine missile ejection probabilities to
24 meet those 10-to-the-minus-4 or 10-to-the-minus-5
25 numerical criteria, without doing the full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 quantification of P2 and P3, which is a more involved
2 process.

3 That option is always open to somebody.
4 If you have an unfavorably-oriented turbine with a
5 higher missile ejection frequency, you can, then, go
6 out and do the rest of the math. But you would have
7 to do that.

8 MR. GARDNER: Right. I think our SAR
9 demonstrates that, considering the orientation with
10 respect to containment, we have also looked at those
11 things within the zone of influence and demonstrated
12 in the FSAR that you can still safely shut down the
13 plant, that there is not a --

14 MEMBER STETKAR: That isn't what this
15 coarse screening process does. If you want to talk
16 about doing a more detailed analysis, you can always
17 do that. The coarse screening process essentially
18 gives you a free pass to not have to do that analysis.

19 MR. GARDNER: But we did the additional
20 discussion of the impact.

21 MEMBER STETKAR: The qualitative
22 discussion?

23 MR. GARDNER: The qualitative discussion?

24 MEMBER STETKAR: That is a qualitative
25 discussion. It is not a quantitative discussion where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you look at actual probabilities of turbine overspeed,
2 missile ejection. You look at what is P2, what is P3,
3 and then a conditional probability of core damage,
4 given whatever damage that, then, instills.

5 If you say you comply with the Reg Guide,
6 you are essentially taking the free pass. But if you
7 say you comply with the Reg Guide, you had better
8 comply with the Reg Guide, is my whole point.

9 I think that is enough for here. I kind
10 of got it out on the table. I really want to quiz the
11 staff about this because they essentially accepted
12 your arguments, and I don't understand the basis for
13 that.

14 MR. GARDNER: Okay. I will look into it a
15 little closer, too. We just need to look at it
16 closer.

17 MEMBER STETKAR: By the way, Darrell, if
18 you do look in the Reg Guide and if you do find that
19 it is restricted to only the containment, I would be
20 interested in that.

21 MR. GARDNER: We will hunt that language
22 down, right.

23 MR. OSWALD: Okay. On to the next slide.
24 The next section is Section 3.7, and Section 3.7
25 describes the seismic analysis methods for designing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of structures, systems, and components to withstand
2 the effects of the Certified Design Respond Spectra,
3 which is really, essentially, our SSE for our
4 certified design.

5 You see the four subsections of 3.7, which
6 should be familiar to everyone.

7 Next slide.

8 Section 3.7.1 discusses the seismic design
9 input parameters used for the U.S. EPR design. The
10 Certified Seismic Design Response Spectra for the U.S.
11 EPR is based on three individual control motions which
12 are developed for soft, medium, and a hard soil, all
13 anchored to a .3 g P ground acceleration. In
14 addition, we have a high-frequency motion which is
15 included, and it is based on one of our U.S. EPR
16 target sites.

17 The response factor for these motions will
18 be shown in the next couple of slides, and I will show
19 you a comparison where our three control motions meet
20 the Appendix S requirements of an appropriate shape
21 and anchored at least a .1 g.

22 For the structures that aren't on the
23 nuclear island common basemat, we consider the effects
24 of the structure-to-soil-to-structure interaction in
25 our evaluations. So, there is some amplification that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is considered for the design input of the other
2 structures.

3 Our time histories are developed which
4 meet the Reg Guide CR-6728 criteria.

5 There is prescription for the COL
6 applicant to do the reconciliation to make sure that
7 his seismic design parameters are within the envelope
8 of the U.S. EPR design.

9 The next slide.

10 This is a slide showing all of our control
11 motions, our input control motions or our Certified
12 Design Response Spectra. You notice the three shapes
13 that we are using for hard, medium, and soft soil.
14 Those are anchored at .3 g.

15 And then, also, we have the high-frequency
16 motion, which is the red and the blue lines there that
17 are shown. One is the horizontal, the higher one, and
18 then the blue line is the vertical high-frequency
19 motion that we are using.

20 On the next slide, there is a comparison
21 with the Reg Guide 1.60 and the minimum requirements
22 of Appendix S. Again, the three flat curves are U.S.
23 EPR spectra, soft, medium, and hard. Then, the curve
24 with the peak, the dark brownish-looking curve is our
25 Reg Guide 1.60 spectra, anchored at .3 g.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And then, we have the light blue line at
2 the bottom is an envelope of our three control
3 motions, anchored at .1 g, which is the minimum
4 Appendix S requirement. And the red line is just our
5 horizontal high-frequency design spectrum.

6 The next, there is a two-part --

7 CHAIR POWERS: The axis on this particular
8 plot is mysterious to me.

9 MR. OSWALD: Oh, you don't have it. That
10 is the g-level or the acceleration, and it is, the
11 first bottom, there you go, .1, .2, .3, .4. I didn't
12 realize that acceleration wasn't labeled. Sorry about
13 that.

14 CHAIR POWERS: And your ability to
15 distinguish colors greatly exceeds mine. Which is the
16 Reg Guide? This one there?

17 MR. OSWALD: The Reg Guide 1.60 has that
18 peak at about 2.5 Hertz.

19 CHAIR POWERS: Thank you.

20 MR. OSWALD: Okay. The next slide,
21 there's two parts to your seismic design inputs, one
22 being your control motion, which we discussed, and
23 then the soil profiles is the next key parameter in
24 your design input.

25 We used eight different soil profiles in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our design. Each one has a control motion associated
2 with those soil profiles. I will show you that on the
3 next slide that follows.

4 Our damping we use is per Reg Guide 1.61.

5 This slide is probably one of the busy
6 slides you mentioned when we opened up. This is just
7 so you would have the numbers to see how it all fits
8 together, which control motion is associated with
9 which soil case or which soil profile. And the next
10 two slides I will show you the soil profiles, and it
11 will explain this.

12 Okay. What you see here is our five
13 standard soil profiles, not our high-frequency site on
14 this slide. And as I mentioned, the slide before
15 shows which one of these is associated with the hard,
16 medium, or soft control motion. Again, these
17 different soil profiles will give us a broad range of
18 excitation along with the different input control
19 motions.

20 You will notice our basemat, what you have
21 here on the left side is the depth down below grade,
22 starting at the top right, and you work your way down.

23 The top right, that zero would be essentially
24 finished grade elevation. So, our basemat, where you
25 see that horizontal line there, that is actually a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 blue horizontal line at about minus 42 feet; that is
2 the bottom of our basemat.

3 So, as you move from left to right across
4 this slide, you have your softer soils, as indicated
5 by the shear wave velocities in the horizontal
6 profile. Then, you have the stiffer soils on the
7 right. So, the soft soils on the left, the stiffer
8 soils on the right. Again, depth versus shear wave
9 velocity is the chart.

10 Okay. The first soil profile on the left,
11 which is pink, is the 1n2ue case, and that is a linear
12 gradient soil profile where the soil gets stiffer down
13 below the basemat.

14 Okay. The next soil profile, blue, is our
15 soil case, what we call 1n5ae, and it represents with
16 a soft backfill and a hard soil below the foundation.

17 So, it is, essentially, sitting on a pretty stiff
18 component, uniform down below.

19 The next soil profile that you see,
20 orange, is one of our layered soil cases. It is a
21 soft backfill along the side walls and a soft soil
22 layer below the foundation on top of sort of a medium
23 stiff layer.

24 And again, what we are trying to do is set
25 up different impedances, capture different motion to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get it into our structure.

2 The next soil profile, you see green is a
3 condition which is kind of a uniform, medium stiffness
4 of the surface all the way down below the foundation.

5 And then, the soil case on the far right
6 is a very stiff soil. It is a hard soil all the way
7 down below the basemat.

8 MEMBER STETKAR: Todd?

9 MR. OSWALD: Yes?

10 MEMBER STETKAR: If I recall, some of
11 these adopted from the European standard, is that
12 right, the soil profiles?

13 MR. OSWALD: The control motions.

14 MEMBER STETKAR: The control motions?

15 MR. OSWALD: The control motions on the
16 previous slide were adopted --

17 MEMBER STETKAR: Okay. I'm sorry.
18 Thanks.

19 MR. OSWALD: -- from the European
20 standard. That is why they have an EUR, European
21 Utility Requirement, document.

22 MEMBER STETKAR: Thanks.

23 MEMBER SKILLMAN: As you explained the
24 layered consistencies of the soil there, are you
25 communicating that those are engineered layers or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those are natural layers? Do these characteristics
2 exist because of excavation and compacting or because
3 that is the true underlying characteristic of the
4 foundation?

5 MR. OSWALD: It could actually be either,
6 but we are assuming this -- I mean, we are idealizing
7 soil columns here. Anything we actually have is going
8 to be multiple layers, typically, unless it is on
9 rock. So, that is where we end up in the site-
10 specific evaluation, looking at the real site
11 condition.

12 And what we were trying to do here is get
13 enough input into our building where, when we make our
14 comparisons, that we are enveloped with any given
15 site.

16 MEMBER SKILLMAN: Okay. Thank you.

17 MR. OSWALD: That's the objective.

18 CHAIR POWERS: The COL applicant has to
19 show that one or more of these bounds whatever he has
20 got, right?

21 MR. OSWALD: Right. And most likely, he
22 is not going to match these exactly. Now the next
23 slide is our high-frequency site. So, that is our
24 actual site. You can see what a real site would look
25 like, as an example. We have a reconciliation process

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in Chapter 2 that it uses.

2 Slide 15, this is our high-frequency soil
3 profiles. These are actual lower bound, upper bound,
4 and best estimate of soil profile prediction. You can
5 see it is a relatively-soft backfill alongside a
6 relatively-stiff material below the basemat. Again,
7 the horizontal line is the bottom of our basemat
8 elevation.

9 CHAIR POWERS: Physically, what happens
10 when a shear wave comes in and it has a high natural
11 velocity, and it starts encountering regions of low
12 velocity? You get a shock?

13 MR. OSWALD: You are talking about lateral
14 variability within --

15 CHAIR POWERS: I mean, I know what happens
16 in a gas. I am trying to understand what happens in a
17 solid. In a gas, I know what happens. You create a
18 shock wave --

19 MR. OSWALD: Uh-hum, uh-hum.

20 CHAIR POWERS: -- when you have got
21 impedance mismatches in the velocities. What happens
22 in the solid physically?

23 MR. OSWALD: So, what you are asking is --

24 CHAIR POWERS: The physical phenomena?

25 MR. OSWALD: The physical phenomena of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wave passing through stiffer and softer soils?

2 CHAIR POWERS: Yes, if I am riding on the
3 wave front, and I am coming from below, what happens?

4 What do I see?

5 MR. OSWALD: Not being a geologist and
6 seismologist, I am sitting here trying to imagine. I
7 am not sure I am qualified to explain exactly what is
8 happening other than the wave passed through the soil
9 and it slows down and speeds up, just excites the soil
10 in a different frequency.

11 CHAIR POWERS: Yes, but, see, the other
12 wave fronts are coming right behind. They are coming
13 fast, and so they catch up with me. And I start
14 seeing my neighboring wave front. I am just not
15 physically sure what happens.

16 MR. OSWALD: Well, that is what we refer
17 to as coherent sea or incoherent sea, you know, what
18 those wave fronts are doing as they come up and catch
19 up with each other. And these large basemat, it
20 typically helps us a little bit in the higher
21 frequencies as they aren't hitting us at the same
22 time.

23 Do you want to take a shot at that?

24 MR. WONG: Yes, my name is Calvin Wong
25 with AREVA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Maybe looking at this slide here as an
2 example, you have a wave coming through here. One of
3 the challenges that we do have is you do have a soft
4 layer right here. So, the waves coming up here do get
5 trapped, for example, in this layer and you get a lot
6 of excitation. So, that is an example.

7 What you said about the waves combining,
8 and whatnot, it is the same theory. The waves will
9 start adding/subtracting from each other.

10 CHAIR POWERS: So, I get bigger peaks and
11 deeper troughs is what you are telling me?

12 MR. WONG: Yes. This right in here, you
13 can get a lot of energy trapped in that layer because
14 you have a reflective boundary here.

15 CHAIR POWERS: I would think that that's
16 exactly what happens, is suddenly you start focusing
17 the energy in on the basemat.

18 MR. WONG: Right. And in this case, it
19 would be at the frequency of this soil layer.

20 CHAIR POWERS: Okay. Thank you. It's
21 really interesting.

22 MR. OSWALD: Okay. The next slide.

23 Section 3.7.2 discusses the seismic
24 analysis methodologies we use. We have three major
25 seismic categories, as you saw earlier this morning in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 3.2.2, discussed by Dennis there.

2 U.S. EPR structures, the major seismic
3 categories are Seismic Category I, which has the
4 safety-related structure; Seismic Category II is any
5 non-safety-related structure which has the potential
6 to interact with the safety-related structure, and
7 then, we have our Radwaste Seismic. Again, that is
8 anything that has a potential for offsite release. We
9 use the seismic criteria in Reg Guide 1.143.

10 What you see here at the buildings that
11 are included in each of these seismic categories, our
12 nuclear island and the EPGB or essential service water
13 building, emergency power generation buildings. Those
14 are Seismic Category I.

15 The buildings with the potential to
16 interact with Seismic Category I are the nuclear
17 auxiliary building, the access building, and the
18 turbine building, and switchgear building. Again,
19 these are site-specific structures, and they have to
20 be evaluated on a site-specific basis.

21 And then, the radwaste seismic structures
22 include the radwaste building and the nuclear
23 auxiliary building because of their content.

24 MEMBER RYAN: The nuclear auxiliary
25 building is in Seismic Category II and Radwaste

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Seismic?

2 MR. OSWALD: Yes, it is. The structural
3 interaction evaluation is based on Seismic Category II
4 criteria. So, we use the full SSC, the full tornado
5 wind loads, and everything, and then the design of the
6 components inside the building would be just as
7 required for Reg Guide 1.143.

8 MEMBER RYAN: Got it. Thank you.

9 MR. OSWALD: Okay. The next slide, as we
10 went through the evolution of the EPR, we started off
11 with our distinct model designs which have been used
12 for a while. They seemed to give us pretty good
13 results. We evolved to an embedded stick model
14 because we were asked questions by the staff in the
15 effects if embedment; whereas, before we had
16 considered the embedment effects would only help lower
17 our response. But the staff continued to ask
18 questions. So, we went and modeled the embedment.

19 And then, as our software capabilities and
20 our hardware capabilities increased, we moved to an
21 embedded finite element model, and our soil structure
22 and our action analyses, and one of the major reasons
23 for doing that was to capture the high-frequency
24 motion that is now known to be evident in the central
25 and eastern U.S. sites. So, in order to propagate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that up into the structure, we have evolved to a
2 fairly-complicated 3D finite element model included
3 our soil structure action analyses.

4 Okay. The analysis of the Category I
5 structures involves, as you saw on the previous slide,
6 a rigorous analysis approach using 3D finite element
7 models and seismic analysis computer codes to
8 determine the response and generate in-structure
9 response spectra to feed into the design of the
10 structure systems and components within the building.

11 CHAIR POWERS: How do you know that the
12 models are right?

13 MR. OSWALD: How do we know that the
14 models are right? We have done sensitivity studies to
15 ensure our --

16 CHAIR POWERS: You can run the model until
17 your eyes fall out --

18 MR. OSWALD: Right.

19 CHAIR POWERS: -- but that doesn't tell
20 you it's correct.

21 MR. OSWALD: Okay. How do we know? The
22 model is considered a pretty good approximation of
23 giving us a response.

24 CHAIR POWERS: Somebody must make that
25 consideration and there must be some basis. What is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the basis for thinking that the 3D finite element
2 model is an adequate description?

3 MR. GARDNER: Are you asking in the
4 context of modeling the behavior or how well do we
5 just translate physical structures into models?

6 CHAIR POWERS: I am really interested in,
7 I have got a real structure. I calculate how it is
8 going to respond to a loading. How do I know that the
9 model is right, gives me a good answer?

10 What model is it, by the way? Yours or
11 somebody else's?

12 MR. OSWALD: This is our model. We have
13 our model for our seismic or our dynamic analysis or
14 seismic analysis.

15 CHAIR POWERS: It is one you wrote?

16 MR. OSWALD: It is one that we developed
17 based on the general arrangements of the structure,
18 and we did an ANSYS finite element model and converted
19 it to a dynamic model to use in SASSI.

20 CHAIR POWERS: So, how do we know it is
21 correct, that it gives us an answer that is useful?

22 MR. GARDNER: Well, what we do on our
23 dynamic model, we benchmark against an ANSYS 3D finite
24 element model, the static model. Do the modal
25 analysis, a comparison to tune it up, so to speak,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with our 3D.

2 But I guess your question is more along
3 the lines of, how do we know that what we are tuning
4 to is correct?

5 MR. OSWALD: It is about the best tool we
6 have available to us right now.

7 CHAIR POWERS: What does your model
8 predict? Stress? Strain?

9 MR. OSWALD: The static model does predict
10 the stresses in the building. The dynamic model is
11 used to capture the dynamic properties and feed it
12 into our soil structure action analyses model to
13 capture the response of the structure. We are trying
14 to predict in-structure response spectra.

15 CHAIR POWERS: So, how do you know it is
16 right? I mean, it gives you a number. It probably
17 gives you a number to a great number of significant
18 digits, too, if I'm guessing. How do you know it's
19 right? Or close?

20 MR. WONG: This is Calvin Wong again.

21 I guess, if you ask, how do we know it's
22 right, there are some physical laws that we can relate
23 to. There is also past experience, benchmarks against
24 real structures. I would venture to say concrete
25 structures, while complicated in some sense, are not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really all that complicated. We get the stiffness of
2 the structure. We have properties of the structure,
3 and we know how stiff it is, the material properties.

4 As I referred to earlier, the physical
5 laws are, if you have a rigid structure, it is going
6 to behave a certain way, and we know how it behaves
7 with respect to the input motion. So, there are
8 bounds that we can rely on to understand if our model
9 is behaving properly.

10 So, that is the structural model. The
11 soil model that we include in there is another factor.

12 But in terms of the structure itself, as Todd alluded
13 to earlier, we have gone from simple stick models to
14 more complicated finite element models. We show that
15 we see certain trends. As you get more sophisticated,
16 the response, global responses remain essentially the
17 same, but you get additional detail.

18 CHAIR POWERS: And you have never
19 calculated a real structure subjected to a real load
20 to see if you get the observed result?

21 MR. WONG: There have been past studies
22 where you have built real structures that you
23 benchmarked against, in academia, in industry.

24 So, really, the models that we have, for
25 example, are just extensions of beam models, if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will. And those are all classical theory.

2 CHAIR POWERS: The trouble is that a beam
3 I can understand. A structure this complicated I
4 cannot understand. And so, you are telling me that
5 the computer code does. And I am saying, why do you
6 think that? What leads to your confidence?

7 MR. WONG: My confidence would be, going
8 back to this slide, when we go from a simple stick
9 model to the finite element model, there will be
10 similarities between the two. The overall global
11 response of the structure should be evidence in both
12 models. And we do see that in terms of the specific
13 details when you go to the finer model. When you go
14 from the very specific details, the only check that
15 you could rely on would be breaking it down to more
16 simpler models to see if --

17 CHAIR POWERS: I mean, I understand you
18 are saying that my model will, when taken to the
19 limit, go to your stick, and I understand the stick.

20 MR. WONG: Uh-hum.

21 CHAIR POWERS: The part of the model
22 output that I am interested in, however, is not built
23 into the stick. It is something peculiar to the
24 global structure. That is the output I am interested
25 in. How do I know I get that right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WONG: Well, I guess one of the things
2 that we want to get out of this, even for our large
3 model, is basically accelerations. That is one of the
4 products that we want out of it.

5 And as I stated earlier, you do get
6 certain bounds that the more complicated model will
7 still have to comply with. So, really, the difference
8 between going from the stick to the finite element
9 model is we are trying to capture a little bit more
10 detail to capture the high-frequency response. But
11 the overall global responses remain the same. So,
12 that gives us confidence in our larger, more
13 complicated model, that we have captured the essence
14 of the destructive behavior.

15 CHAIR POWERS: Thank you.

16 MEMBER SKILLMAN: Let me build on Dr.
17 Powers' question, please. Is the model that you are
18 using peer-reviewed? Are other people who are in this
19 business using, if you will, the same or similar
20 model, the same or similar technology? So that, if
21 peers were to get together, one would say, using this
22 complicated model versus this other complicated model,
23 for all intents and purposes, they are predicting the
24 frequencies, the accelerations that are similar,
25 without those parties revealing, if you will, their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 intellectual property?

2 I hear you, you know, just in a word, you
3 have gone from a simple model to a very complex model.

4 Those are the words you used. So, my colleague says,
5 how do you know it is predicting accurate results, so
6 that we can take it to the bank?

7 And I hear your words. I understand the
8 technical logic that you are using. But I wonder,
9 have you done a peer review? Do you have other people
10 who are from the civil structural area, from different
11 portions of the industry, or a different industry,
12 that would say, yes, that's representative. That will
13 do it for you? Have you done something like that?

14 MR. OSWALD: This one has not been peer-
15 reviewed, but it tends to respond, as to what we have
16 seen in the past on other models, but we haven't
17 done -- we have had review sessions with other
18 experts, but there has not been an independent model
19 built.

20 We did have, we call it, a design review
21 board, where we brought in four or five -- I could get
22 the names; I remember the names; I don't remember the
23 number of experts -- to take a look at our results and
24 look at our in-structure spectra results and our
25 global results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: My comment is not to
2 suggest an inadequacy. It is to dig into what Dr.
3 Powers is asking. How do you know the results are
4 ones that appropriately and accurately predict motions
5 and accelerations?

6 MR. WONG: If I may interject, I would
7 just say that in terms of the procedures that we use
8 in building the models, they are really conventional
9 methods. The models that we use are standard
10 structure-analysis-type models. So, in that sense, we
11 are not breaking in any new ground.

12 If the other vendors and structural
13 analysis, any type of structure analysis would use
14 similar methods that we used. So, in that sense, our
15 building model is nothing that is out of the ordinary.

16 We have concrete shear walls, and we model them with
17 shell elements. Standard practice, if you will.

18 MR. GARDNER: I was going to say, maybe
19 some of the challenge I am listening to here is that
20 we are using the term model. The model, the physical
21 model of the structure was just our physical model
22 because it is our structure. It is not a model anyone
23 else would use because they have their own structure,
24 their own model for their structures.

25 But the tools and techniques you use to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analyze that model are consistent with the same
2 tools --

3 MR. WONG: Yes, it is general practice.

4 MR. GARDNER: -- that everyone else is
5 using.

6 MEMBER SKILLMAN: Thank you. Thanks.

7 I think we will follow up with the staff
8 later. This gets into how they evaluated your model
9 with your structures.

10 CHAIR POWERS: Most guaranteed, we will
11 have more discussion of this with the staff.

12 MEMBER SKILLMAN: Darrell, thank you.
13 Todd, thank you. Calvin, thank you.

14 MR. OSWALD: Okay. Let's go to the
15 seismic model, yes, okay. A little more description
16 on these seismic models and the analysis approach.

17 Also, in these models we looked at the
18 effects of embedment, as described before, and we
19 looked at the effects of concrete cracking. We
20 considered both cracked and uncracked properties
21 because the real answer probably lies somewhere in
22 between. So, we look at the two bounds of cracked and
23 uncracked conditions.

24 The mass of components within these models
25 is included in two manners. One is just lump mass

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we have included to capture the weight effects.
2 Some large components, such as the reactor coolant
3 system, is explicitly modeled in a beam simplified
4 compared to what the reactor coolant guys use. We use
5 a simplified beam and lump mass model to capture that
6 stiffness in the mass and its effect on our building.

7 And then, again, we also include our
8 nuclear auxiliary building as a separate stick model
9 because of its mass and its potential to influence the
10 response of our nuclear island.

11 We use what we refer to as the MTR version
12 of the SASSI computer code. If you are not familiar
13 with SASSI, SASSI stands for a System for Analysis of
14 Soil Structure Interaction.

15 Again, each of the eight control motions
16 and soil combinations that I showed you on the
17 previous slide, we run each of those cases up through
18 the structure and generate in-structure response
19 spectra for the design of our structure systems and
20 components.

21 That is all I want to say on this slide.
22 Next.

23 The way we look at Seismic Category II
24 structures, we look at Seismic Category II structures
25 in the same manner as we look at Seismic Category I.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It is a rigorous analysis, and we evaluate that.

2 CHAIR POWERS: When you say rigorous, what
3 does that mean?

4 MR. OSWALD: Well, we do a response -- it
5 is not a static simple application of accelerations.
6 It is a response spectra analysis that we input.

7 CHAIR POWERS: I mean, I am trying to
8 understand what the word rigor means in this context.

9 MR. OSWALD: Well, essentially, we do a
10 full dynamic analyses, instead of just application of
11 static accelerations into the models, to look at, say,
12 a pushover effect or a simple static evaluation.

13 We run through all of the required
14 evaluations that we would have on a Seismic Category I
15 structure from a structural perspective. And these
16 buildings will be designed to the Seismic Category I
17 codes, which is ACI-349 and N690, which are the
18 nuclear design codes. Okay?

19 CHAIR POWERS: So, rigorous just means you
20 comply with the codes?

21 MR. OSWALD: Comply with --

22 CHAIR POWERS: With the requirements of
23 the codes?

24 MR. OSWALD: Yes, that's correct.

25 MR. GARDNER: Dr. Powers, I just want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 come back to that -- sorry -- just to make sure we
2 communicate correctly.

3 For these structures, if they were just
4 looked at as Cat II, you wouldn't have done this level
5 of analysis for these normally. So, we have imposed a
6 higher level of analytical tools onto these structures
7 because of the interaction.

8 MR. OSWALD: Right. Yes, you said Cat II,
9 you mean non-Seismic --

10 MR. GARDNER: Right.

11 MR. OSWALD: If they were non-seismic.
12 Cat II, by definition, we are applying all the
13 Category I criteria to the evaluation.

14 Let's see where we are at here. The
15 seismic input for the NAB, the nuclear auxiliary
16 building, is obtained from the analysis of the NI
17 common basemat, as we talked about, to capture those
18 interaction effects.

19 The Seismic Category II criteria for the
20 access building, turbine building, switchgear
21 buildings, are conceptual in the U.S. EPR design,
22 since they are not in the scope of this certified
23 design. The COL applicant will make the determination
24 if they will continue to use that Seismic Category I
25 criteria, which we are fairly confident they will, or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 present another criteria, showing full details of how
2 they demonstrate an equivalent margin of safety as a
3 Category I structure.

4 The access building and the turbine
5 building are evaluated to the site-specific SSC by the
6 COL applicant, in lieu of the certified design
7 response spectra.

8 Again, there is a requirement to check the
9 gap between all the structures to ensure there is no
10 interaction from the seismic loads or any settlement
11 contribution to those, you know, the ability to close
12 the gap between structures.

13 But, again, the COL applicant has to look
14 at their site-specific conditions to verify that gap
15 is adequate.

16 MEMBER STETKAR: Todd, for those gaps,
17 since there are gaps, and I guess the values of the
18 gaps may be proprietary -- I don't know -- but they
19 vary. According to my reading, they are about a foot
20 to a foot and a half, depending on the building and
21 things like that.

22 MR. OSWALD: Correct.

23 MEMBER STETKAR: Who does the evaluation
24 of relative motions of those buildings with respect to
25 potential failures of piping, cables, and so forth,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that go through those gaps? Is that the COL?

2 MR. OSWALD: The scope of the COL is the
3 buried piping and buried conduits. But for between
4 the buildings --

5 MEMBER STETKAR: For example, turbine
6 building versus the NI or the nuclear auxiliary
7 building, if there is relative vertical motion or
8 horizontal motion between those buildings, I am
9 assuming there is a fairly large number of piping and
10 cable penetrations that span those gaps. Who does the
11 analysis to assure that those things don't break? Or
12 are none of those required for safe shutdown?

13 MR. OSWALD: We do, the civil structural
14 group, we provide the seismic anchor motions, as we
15 refer to it, between the buildings, and they are
16 considered all out of phase.

17 MEMBER STETKAR: Well, but that is for
18 structural interactions. I am talking about
19 penetrations.

20 MR. OSWALD: Correct, but the seismic
21 anchor motions are the structural displacements, and
22 they are applied to the piping analysis or to --

23 MEMBER STETKAR: Okay.

24 MR. OSWALD: -- whatever component.

25 MEMBER STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: But we provide them that. We
2 have a book of instruction responses.

3 MEMBER STETKAR: Okay. Okay. So, they
4 just have to show that they meet those?

5 MR. OSWALD: Correct. They have put those
6 seismic anchor motions into their analyses.

7 MEMBER STETKAR: Okay. Thank you.

8 MR. OSWALD: Yes.

9 Okay. Next slide, 3.7.3 is about seismic
10 subsystem analyses. The ones you see here listed are
11 what is included in the scope of 3.7.3, everything
12 from HVAC ductwork, cable tray. We call them
13 distributed systems and platforms. Everything, all
14 the remainder of the items are in 3.7.3.

15 Seismic Category I systems are designed to
16 withstand the certified seismic design response
17 spectra and still perform their safety function. The
18 methods for the subsystem analyses include response
19 spectra methods, time history methods, or equivalent
20 static load methods.

21 We do consider -- well, the operating
22 basis earthquake is not explicitly considered for the
23 SECY 93-087, but we do look at the exemptions for
24 elimination of the OBE, as addressed in the SECY, to
25 address the fatigue loading.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Any site-specific subsystems or anything,
2 the COL applicant is required to address.

3 Section 3.7.4 describes the seismic
4 instrumentation requirements to ensure plant features
5 important to safety can be evaluated promptly
6 following an earthquake. The instrumentation is
7 required to conform to the Reg Guide 1.112; in other
8 words, qualified the IEEE standards 344.

9 Pre-earthquake planning and post-
10 earthquake actions are required to conform to the Reg
11 Guide 1.166, and the exceedance criteria is
12 established per the EPRI reports NP-6695 and NP-5930.

13 And the CAV, the cumulative absolute velocity, is
14 calculated in accordance with the EPRI Technical
15 Report 100082.

16 Then, we require the restart requirements
17 to conform to the Reg Guide 1.167.

18 There is a requirement for the COL
19 applicant to ensure he has his free-field sensors
20 located where he can adequately assess the earthquake
21 that has come on his site and he can assess it as a
22 free-field, compare it back to his design basis
23 earthquake appropriately.

24 CHAIR POWERS: I have -- excuse me.

25 MEMBER STETKAR: No, go on. You're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably on this slide. I'm slow.

2 (Laughter.)

3 CHAIR POWERS: No, I am just as
4 disconnected as the submission of this material is.

5 (Laughter.)

6 If I have an earthquake that exceeds my
7 OBE, but it is less than my SSE, I have to inspect
8 this plant?

9 MR. OSWALD: That's correct.

10 CHAIR POWERS: Do you provide any guidance
11 on what I ought to look at, based on your analyses?

12 MR. OSWALD: Other than what is in the Reg
13 Guide 1.166, we have not provided --

14 CHAIR POWERS: You don't provide anything
15 special?

16 MR. OSWALD: We haven't provided anything
17 special here at this stage.

18 MEMBER STETKAR: I was going to ask you a
19 curiosity question. You don't have to flip back to
20 the previous slide. But I was thinking about, you
21 know, you have added the high-frequency spectrum to
22 the plant design.

23 MR. OSWALD: Uh-hum.

24 MEMBER STETKAR: When you added that, did
25 you find anything that required a rework, let's say?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In other words, did you find very stiff equipment? I
2 am thinking mostly electrical/electronic stuff --

3 MR. OSWALD: Right.

4 MEMBER STETKAR: -- in a fairly stiff
5 building that could be susceptible to high natural
6 frequencies. Did you find any of that?

7 MR. OSWALD: I am not aware of any --
8 obviously, it didn't affect any of the structures that
9 we deal with. I am not aware of any of the other
10 disciplines having issues. It will show up in the
11 required response spectra for testing --

12 MEMBER STETKAR: Yes.

13 MR. OSWALD: -- in the IPEEE or the 344
14 testing.

15 But I am not aware -- I will look at my
16 colleagues around the room to see if anyone else is
17 aware of anything that changed as a result of the high
18 frequency.

19 MEMBER STETKAR: I was just curious. The
20 question has come up before.

21 MEMBER SKILLMAN: If they haven't done the
22 piping, detailed piping design or anchorage --

23 MEMBER STETKAR: Yes. Yes, piping I am
24 not so concerned about. I was thinking more of
25 support for electrical things. And I don't know. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 am not a structural engineer, so I am not really
2 familiar kind of in an intuitive sense with what the
3 natural frequencies of those sorts of things tend to
4 be, anyway. I was just curious.

5 MEMBER SKILLMAN: Yes, I would have
6 thought you would have answered cabinets, racks,
7 smaller structures that are fairly compact that may
8 have a relatively high natural frequency.

9 MR. OSWALD: Yes, that is what we refer to
10 as chatter-sensitive equipment. That will be impacted
11 when -- I mean, right now, what we have done is
12 generate that motion, so they have their required
13 testing structure.

14 MEMBER STETKAR: Okay.

15 MR. OSWALD: They will have that motion.

16 MEMBER STETKAR: I understand.

17 MEMBER SKILLMAN: The answer is there is
18 some stuff that is swept in --

19 MEMBER STETKAR: Yes, yes.

20 MEMBER SKILLMAN: -- with the higher
21 frequency.

22 MR. GARDNER: It has the potential for
23 being impacted. We just haven't done those analyses.

24 Practically speaking, I think we are going to find --

25 MEMBER STETKAR: You don't have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anchorages and everything. You are just specifying
2 the anchorages right now?

3 MR. OSWALD: Correct. Up to this point,
4 we just haven't seen it. It will be in the test
5 requirements.

6 MEMBER SKILLMAN: Thank you.

7 MR. OSWALD: Uh-hum.

8 MEMBER STETKAR: Sometimes I get ahead
9 myself, thinking you actually have a real design.

10 (Laughter.)

11 MR. OSWALD: It would allow us to answer
12 some questions sometimes.

13 CHAIR POWERS: Some places they do have a
14 real design.

15 MEMBER STETKAR: No, I'm being facetious a
16 bit.

17 MR. GARDNER: Dr. Powers, this may be a
18 good spot for a break.

19 CHAIR POWERS: I was thinking that we
20 would probably take a brief recess, if you guys are
21 done with 3.7.

22 There was one question. You went through
23 it, and I'm slow. Analyzing the building, and you
24 have a big, heavy reactor inside of it. And what you
25 do is you approximate that as a hanging mass, if I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 understood you correctly.

2 MR. OSWALD: The reactor itself and the
3 component steam generator is a beam and lump mass
4 model lumped in the power finite element.

5 CHAIR POWERS: Yes. So, that stuff has
6 the potential of getting out of phase with the
7 building itself responding to things. Does it? And
8 how big is the relative motion?

9 MR. OSWALD: So, the question is, does the
10 reactor coolant system get out of phase with the
11 building?

12 CHAIR POWERS: Yes.

13 MR. OSWALD: I am looking at my reactor
14 coolant system colleagues in the back.

15 (Laughter.)

16 We get a lot of complaining from them, but
17 I am not sure how he wants to categorize it.

18 MS. WEAVER: The microphone, yes, sir.

19 MEMBER STETKAR: You have to identify.

20 MR. McGAUGHY: I'm sorry.

21 MEMBER STETKAR: Just give your name for
22 the record.

23 MR. McGAUGHY: This is Chris McGaughy. I
24 do reactor coolant system analysis for AREVA.

25 Of course, we do have a lot of components

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that are supported in different ways. I am sure that
2 some of them do get somewhat out of phase with the
3 reactor building. But we have a very detailed model
4 of the reactor coolant system, along with a simplified
5 stick model of the interior concrete structure. So,
6 we try to incorporate any of those phase differences
7 in our model.

8 And alternatively, they have a more
9 detailed model of the reactor building and a less
10 detailed model of the reactor coolant system. And so,
11 we compare those two to make sure that we are getting
12 similar results, especially loads in the supports and
13 response factors.

14 CHAIR POWERS: What I am trying to do is
15 get a physical feel of how big the relative motions
16 can be.

17 MR. McGAUGHY: Like, for example, in the
18 reactor vessel?

19 CHAIR POWERS: Yes, take the vessel. That
20 is an easy one.

21 MR. McGAUGHY: Okay. Yes, and, as a
22 matter of fact, we have compared relative motions
23 between the reactor vessel and the building, and it is
24 actually quite small.

25 CHAIR POWERS: Small like in a four-door

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 model or small in like a nanometer?

2 MR. McGAUGHY: It's like an eighth of an
3 inch. It is a small number, yes.

4 CHAIR POWERS: Okay. So, it rattles a
5 little bit.

6 Your steam generators are on, I mean, the
7 big, large ones, what kind of motions do I get on the
8 steam generators?

9 (Laughter.)

10 Hey, you've got numbers.

11 MR. McGAUGHY: I'm sorry, what was that
12 question?

13 CHAIR POWERS: Well, I mean, the steam
14 generator is a big thing hanging up in the air.

15 MR. McGAUGHY: Sure.

16 CHAIR POWERS: And so, when it gets to
17 moving, you have got a big lever arm on that.

18 MR. McGAUGHY: Sure, sure.

19 CHAIR POWERS: And I am trying to get a
20 feel for the relative motions, you know, the magnitude
21 of the swing there.

22 MR. McGAUGHY: Okay. I am not sure
23 exactly what the values are --

24 CHAIR POWERS: Yes, sure.

25 MR. McGAUGHY: -- where the steam line

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 connects to it, for example.

2 CHAIR POWERS: Yes.

3 MR. McGAUGHY: But it is in the
4 neighborhood of an inch or so.

5 CHAIR POWERS: Okay. So, it swings
6 around, but --

7 MR. McGAUGHY: Yes, it does swing around a
8 bit. Yes, it is not a foot.

9 CHAIR POWERS: It would be fun riding on
10 the top of it. You're telling me that.

11 MR. McGAUGHY: It might be interesting.

12 CHAIR POWERS: Yes. Wear your brown pants
13 that day.

14 (Laughter.)

15 Okay. With that poignant comment, we will
16 take a recess for 15 minutes.

17 (Whereupon, the above-entitled matter went
18 off the record at 10:15 a.m. and resumed at 10:32
19 a.m.)

20 CHAIR POWERS: Let's come back into
21 session and hear about Section 3, which I believe is
22 on design of Category I structures.

23 MR. OSWALD: That's correct.

24 Section 3.8, there's five sections,
25 subsections of Section 3.8 we will address here today.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 3.8.1 is containment, concrete
2 containment. 3.8.2 is the steel containments, which
3 there is some scope in the U.S. EPR, although we have
4 post-tension concrete containment. Section 3.8.3 is
5 the concrete and steel internal structures that make
6 up the inside of the containment. 3.8.4 is the other
7 Seismic Category I structures, and 3.8.5 is the
8 foundations.

9 Next slide.

10 CHAIR POWERS: Can I ask -- and maybe you
11 don't even know the answer to this -- but I will ask,
12 anyway. Why a post-tension concrete structure?

13 MR. OSWALD: Why do we have the post-
14 tension concrete structure for the U.S. EPR?

15 CHAIR POWERS: Yes.

16 MR. OSWALD: It is the standard design
17 that has been used over in Europe for quite some time.
18 Part of it is, if you have a tendon failure, I mean
19 why post-tension is to --

20 CHAIR POWERS: I understand those things.
21 Of all the designs you could have picked, you picked
22 a post-tension design. And maybe it was, then, just
23 because historically that is what you did. It happens
24 to be one we have tested a lot. I just wondered if
25 there was any particular reason.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: No, other than that was the
2 standard design that had been developed by AREVA over
3 in Europe.

4 CHAIR POWERS: Well, fortunately, it is
5 one we kind of understand.

6 MR. OSWALD: Yes.

7 CHAIR POWERS: Okay. I was just curious.

8 MR. OSWALD: Okay. 3.8.1 is our post-
9 tension reinforced concrete containment. Just one
10 comment. We have a concrete shield building on the
11 exterior, in addition to our post-tension concrete
12 containment. So, what I am talking about here is the
13 pressure vessel itself, the ASME concrete containment
14 pressure vessel. It is the interior concrete
15 building.

16 It is reinforced concrete, post-tension
17 reinforced concrete, designed for protection against
18 the missiles. It is designed per ASME Section III,
19 Division 2, since it is a pressure vessel. It does
20 include a quarter-inch steel liner plate, which is
21 pretty common here in the U.S.

22 One thing that is a little bit unique --

23 CHAIR POWERS: Hopefully, there are no
24 2x4's.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: Well, it hasn't been built
2 yet. There's certainly none in our finite element
3 models that we included, I can tell you that.

4 We use a grouted tendon design in the U..
5 EPR, which is very common in France, and they have had
6 very good performance of the grouted tendon design.
7 It meets the requirements of the Reg Guide 1.90 for
8 the use of grouted tendons.

9 CHAIR POWERS: These tendons are just
10 cable, seven-cable kind of tendons, or something like
11 that?

12 MR. OSWALD: Yes. Seven is not the right
13 number, but I am sitting here drawing a blank. I have
14 got a presentation. I can pull that information out.

15 But that is the pretty standard cables that will be
16 pulled through and anchored as post-tension.

17 MEMBER SKILLMAN: Let me ask, please,
18 about the ASME Section III, Class 2. Should we
19 interpret that to mean the liner on the concrete, the
20 penetrations, the ground mat --

21 MR. OSWALD: That should be interpreted --

22 MEMBER SKILLMAN: -- the extensions, if
23 you will, of the membrane that would be that pressure
24 vessel to all pertinences that are classified as
25 containment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. OSWALD: Yes, the scope of the ASME
2 Section III, Division 2, will be all the concrete-
3 backed containment where concrete is used for the
4 structural component. It would be the concrete-backed
5 steel components. Once you get to a steel component
6 that is not concrete-backed, that is Class 2,
7 Subsection NE, component.

8 I need to give you an example, such as the
9 sleeves that penetrate through containment where we
10 have components attached to it. Well, where it is
11 backed by concrete, that is governed by ASME Section
12 III, Division 2. Where it is not backed by concrete,
13 that is Subsection NE in the ASME.

14 And so, that would include --

15 MEMBER SKILLMAN: Hatches?

16 MR. OSWALD: Well, the hatches would be in
17 III.8.2, which would be Subsection NE.

18 MEMBER SKILLMAN: Got you. Thank you.

19 MR. OSWALD: Uh-huh. And it does include
20 the basemat, also.

21 MEMBER SKILLMAN: Thank you.

22 MR. OSWALD: All right.

23 See, the containment designed for normal
24 loads, such as dead load, live load, and severe
25 environmental loads, such as wind. Well, wind is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicable because we have the 60-year shield
2 building. And then, the extreme environmental loads
3 would be something such as the SSE, and abnormal loads
4 are such as line breaks or combustible gas loading.

5 The containment design pressure is 62
6 psig.

7 Again, the COL applicant has to make sure
8 that there aren't any site-specific loads that need to
9 be considered for containment design that we haven't
10 considered in the design certification.

11 The next slide is just a representation of
12 our detailed finite element model, which is what we
13 use to get our loads distributed out through the
14 building and get them to the structural elements. So,
15 the results from this model are used to design the
16 structural elements.

17 MEMBER SKILLMAN: Do the discolorations or
18 the variances in color at the crown, where the crown
19 meets the cylinder, have any mean -- yes, right there,
20 those -- or is that just part of the --

21 MR. OSWALD: It is just the graphics.

22 MEMBER SKILLMAN: -- way the graphics --

23 MR. OSWALD: It is just the way it is
24 shown there.

25 MEMBER SKILLMAN: It is meshing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: Yes, the meshing is just the
2 view we have cut out.

3 MEMBER SKILLMAN: Thank you.

4 MR. OSWALD: Okay. Section 3.8.2
5 describes the steel components of the concrete
6 containment. Again, these are still components that
7 form the pressure boundary that fall into Section
8 3.8.2.

9 It includes the penetration, such as
10 equipment hatch. There is a dedicated spare
11 penetration, personnel airlocks. There is a
12 construction opening. It is sealed up after
13 construction. Pipe penetration sleeves, electrical
14 penetration sleeves, and fuel transfer tube sleeve
15 design. Again, these components are ASME Section III,
16 Subsection NE.

17 And again, these steel components or
18 containment are designed for the service loads,
19 factored loads, and other loads required by the ASME
20 code.

21 MEMBER SKILLMAN: So, does it suggest that
22 the pertinences or these penetrations are actually an
23 ASME division higher than the concrete-backed steel?

24 MR. OSWALD: No, there's not -- well, I am
25 not sure when we talk about hierarchy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: You are showing on slide
2 31, Division 2, the design meets the requirements of
3 ASME III, Division 2. But on 33, you are showing that
4 the penetrations are Division 1, NE.

5 MR. OSWALD: Yes, there is no hierarchy
6 there. It is just the way the code is organized.

7 MEMBER SKILLMAN: Okay. Thank you.

8 MR. OSWALD: All right.

9 Okay. The next slide.

10 Section 3.8.3 describes the reinforced
11 concrete walls and the floors, the steel framing
12 members, and other concrete and steel structural
13 elements that are located within the containment
14 structure, including the structural elements listed
15 there.

16 Okay. The next slide.

17 CHAIR POWERS: The IRWST, your analysis is
18 just of the structure? You don't take into account
19 the sloshing load?

20 MR. OSWALD: Yes, we do.

21 CHAIR POWERS: How do you do that?

22 MR. OSWALD: The sloshing loads are
23 accounted for by looking at the response spectra
24 input. I would have to go back and look at the
25 details on the impulse of the convective and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loadings. But we consider, by looking at the response
2 spectra that is calculated and its effect on that
3 fluid mass, and calculating the --

4 CHAIR POWERS: Is it a big effect or a
5 little effect? Is the sloshing load a big effect or a
6 little effect? And my intuition in this particular
7 design is it is no effect at all, but I don't --

8 MR. OSWALD: I would have to go back and
9 look at the details. I don't think it governed the
10 design, but it certainly depends on the load
11 combination that we are looking at. Off the top of my
12 head, I can't tell you the magnitude.

13 MEMBER SKILLMAN: For the core melt
14 retention area, your last bullet, what are the
15 requirements for the concrete in that area?

16 MR. OSWALD: The requirement, there is
17 some ceramic bricks that are on top of the concrete.

18 Tim, do you happen to recall much of the
19 detail on that core melt retention area with the
20 ceramic bricks and the water cycling?

21 MR. STACK: Yes, I do. I am not sure, do
22 you have a specific question in mind?

23 MEMBER SKILLMAN: Yes. I'm wondering if
24 the core melt retention area has a requirement for
25 basaltic-type concrete as opposed to a carbonatic or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calcium carbonate limestone that is a carbon dioxide
2 generator on core melt. The basaltic material is
3 resistant to that; whereas, the limestone-type is a
4 source of carbon dioxide.

5 CHAIR POWERS: I will comment. There is a
6 wide misconception that the two categories, siliceous
7 and calcareous concretes, have wildly-different
8 responses to core melt because the calcareous has a
9 lot of carbon dioxide generation. That is a
10 misconception people have.

11 And the misconception arises because they
12 look at the inventory of gas-producing material. They
13 don't consider that you get gas only because of
14 thermal decomposition, and siliceous concretes have a
15 much lower enthalpy of decomposition than do
16 calcareous materials.

17 As a result, when you analyze them or when
18 you experiment with them, you get about the same
19 amount of gas from both of them. The enthalpy of
20 decomposition of a calcareous concrete is so high
21 that, yes, per-unit volume of concrete decomposed, you
22 get a lot of gas, but you don't decompose nearly as
23 much volume.

24 Here in your design you have got a bunch
25 of, I think they are either magnesia or zirconia

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bricks on top of them, and whatnot. And so, you are
2 not really affecting the concrete per se, until you go
3 through the bricks, and that is an inspirational event
4 when you do it, should you happen to do it. You are
5 trying to drain it off before you do it, but if you do
6 -- we have done that experiment, and you don't want to
7 do that.

8 (Laughter.)

9 MR. STACK: We agree.

10 MEMBER SKILLMAN: Thank you, Dana, for
11 your explanation.

12 CHAIR POWERS: Yes. I mean, it's floating
13 around. Everybody says, oh, my god, don't use
14 calcareous. Actually, calcareous concrete is a really
15 good thing to use because it will suck the heat right
16 out of your metal, and whatnot. Basaltic concretes
17 are really nice because they provide lots of material
18 to dilute and things like that. I think it doesn't
19 matter. You know, use whatever concrete you want, and
20 whatnot. The basic answer is don't melt down the
21 core. That is a really bad idea, as it turns out.

22 (Laughter.)

23 MEMBER SKILLMAN: Thank you. I'm good.
24 Thanks.

25 MR. OSWALD: Okay. Let's go down to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 next slide.

2 The internal structure of the concrete
3 meets the requirements of, we use ACI-349 and ANSI
4 N690 for the steel design. These are safety-related
5 components.

6 We design for normal loads, severe
7 environmental loads, extreme environmental loads, and
8 abnormal loads, such as high-energy line break.

9 Again, there is a requirement for the COL
10 applicant to determine if there are any site-specific
11 loads that we haven't considered in design
12 certification.

13 What you see there is just the
14 representation of our finite element model that we are
15 using for the interior structure, the concrete.

16 Okay. Moving on to 3.8.4, this section
17 talks about the other Seismic Category I structures
18 that are not on the nuclear island -- well, that are
19 on the nuclear island common basemat and those that
20 are not on the nuclear island common basemat, such as
21 our central service water building and emergency power
22 generation building.

23 I have the structures listed and indicated
24 their location. They are either on the common basemat
25 or separate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You will also notice that we do talk about
2 buried conduit and duct banks and the buried pipe and
3 pipe ducts. But, essentially, it is a COL scope. It
4 is not part of certified design.

5 CHAIR POWERS: If you were to change this
6 containment to a filtered vent containment, where
7 would you put the filter vent?

8 MR. OSWALD: Well, we have a dedicated
9 spare penetration. I don't know if the size is right.
10 I haven't reviewed that. So, there is a dedicated
11 spare penetration that we have here.

12 MR. STACK: Tim Stack again from AREVA.

13 Yes, we are required to have a spare
14 penetration, and we do. My recollection, it is about
15 3 feet. It is per the Code of Federal Regulations.

16 I will also add that some of the other
17 EPRs worldwide actually have filtered, vented
18 containments.

19 CHAIR POWERS: And that, too, is another
20 really, really bad idea in this world.

21 Please go ahead.

22 MR. OSWALD: Okay. Section 3.8.4, right.
23 Again, as mentioned, it is designed to meet ACI-349
24 and ANSI N690. We do not use any masonry walls in the
25 design of Seismic Category I structures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Yay, yes.

2 (Laughter.)

3 MR. OSWALD: It's a nice architectural
4 feature, but that's about it.

5 (Laughter.)

6 We design for normal loads, severe
7 environmental loads, extreme environmental loads, and
8 abnormal loads.

9 And again, the COL applicant always has
10 the requirement to make sure that he is not going to
11 do something that we haven't considered in our design
12 certification for our structures.

13 CHAIR POWERS: Do you take account of high
14 whip, I mean pipe whip, in these breaks?

15 MR. OSWALD: Yes.

16 CHAIR POWERS: You do?

17 MR. OSWALD: Yes, it is a requirement for
18 pipe whip, absolutely.

19 Section 3.8.5, foundations. The Seismic
20 Category I foundations in the U.S. EPR design include
21 the nuclear island common basemat -- and that is the
22 foundation that is under everything, as you see in the
23 picture there -- the emergency power generation
24 building basemat, and the central service water
25 foundation basemat.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Again, these components are designed to
2 meet ACI-349, the nuclear concrete code, and then,
3 ASME Section III, Division 2, where the basemat forms
4 the pressure boundary of containment, essentially, the
5 round portions of the basemat there you see in that
6 figure.

7 CHAIR POWERS: Do they have an embedded
8 liner in them?

9 MR. OSWALD: Yes.

10 CHAIR POWERS: How thick is that? Is that
11 still a quarter inch?

12 MR. OSWALD: Still a quarter inch.

13 CHAIR POWERS: And how thick is the
14 basemat all together?

15 MR. OSWALD: About 9 feet, 13 feet. It
16 depends.

17 CHAIR POWERS: Yes, but, I mean, there is
18 nothing special about it? It is kind of like
19 everybody else?

20 MR. OSWALD: Right. Correct. It is just
21 a big, thick basemat.

22 Okay. For foundations, we look at
23 stability, the sliding and overturning evaluations.
24 Those are always challenging to show.

25 CHAIR POWERS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: Analytically, it has cost us
2 quite a lot of angst to try to come to those
3 conclusions, a lot of analysis.

4 CHAIR POWERS: So, what kind of torque on
5 the basemat do you get?

6 MR. OSWALD: We are seeing some uplift on
7 the basemat. I am trying to remember our latest
8 results. I don't recall exactly. In the 10 to 15
9 percent range, something maybe. I would have to go
10 back and look at our latest results.

11 CHAIR POWERS: So, I mean, it is non-zero
12 by law?

13 MR. OSWALD: It is non-zero.

14 CHAIR POWERS: It has got a big torque.

15 MR. OSWALD: Yes.

16 CHAIR POWERS: And I guess it makes some
17 sense.

18 MR. OSWALD: I would have to look at the
19 final numbers, where we were. I recall some earlier
20 numbers.

21 CHAIR POWERS: Interesting. Interesting.

22 MR. OSWALD: Again, the COL applicant has
23 to make sure that he is not doing anything to our
24 basemat that we haven't considered in our certified
25 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR POWERS: If you get a 10 to 15
2 percent torque, again, you have this problem of all
3 the penetrations coming in from the adjacent
4 structures that are separated here. That's a lot.

5 MR. OSWALD: Well, when I say 10, what I
6 am saying is you see some of the basemat uplift.

7 CHAIR POWERS: Yes.

8 MR. OSWALD: Now when you say torque,
9 there is some basemat uplift experienced, and that is
10 calculated in our seismic anchor motions that we
11 consider for all of these umbilicals attached. We do
12 have to consider that.

13 CHAIR POWERS: What do you bend it on?

14 (Laughter.)

15 MR. OSWALD: Yes. I mean, the key is get
16 enough distance where you can get flexibility.

17 CHAIR POWERS: Yes, yes.

18 MR. OSWALD: And that is our challenge.

19 CHAIR POWERS: Yes, you want some give n
20 these things.

21 MR. OSWALD: Uh-hum.

22 Okay. I think this is actually the last
23 slide I have to give you on Section 3.8.

24 MEMBER STETKAR: I was reading the SER.
25 Have you finished the analyses of the ESWB, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 essential service water building?

2 MR. OSWALD: No, we haven't.

3 MEMBER STETKAR: You are still in
4 progress?

5 MR. OSWALD: Right, we are, and stability
6 is one of the key --

7 MEMBER STETKAR: That is the sense that I
8 got, but sometimes, you know --

9 MR. OSWALD: Yes.

10 MEMBER STETKAR: -- we are not operating,
11 necessarily, in real-time, but those are still being
12 worked on?

13 MR. OSWALD: That is correct.

14 MEMBER STETKAR: Okay.

15 MR. OSWALD: Stability analysis is where
16 we are at now. We are into time history analyses.

17 The last slide I have for you this morning
18 is there is a requirement in 10 CFR 52.47 which says,
19 for design certification, you have to have an
20 essentially complete design. So, we refer to our
21 critical sections design. We are not doing everything
22 on the U.S. EPR structure. So, we select certain
23 areas to demonstrate that the design is good.

24 And we have a selection methodology that
25 we created to do this. There are three sections to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it: a qualitative criteria, a quantitative criteria,
2 and then a supplemental criteria, where it just says,
3 well, we want to look at this, too, essentially; it is
4 important.

5 Again, our qualitative criteria is
6 something that is critical to perform a safety
7 function. Now you can argue the whole building is,
8 but we kind of looked at containment. I mean, by
9 definition, we are going to look at containment. That
10 is the one that fell out into our first criteria
11 there.

12 Our quantitative criteria, we have our
13 finite element results, where we have thrown all the
14 load combinations, multiple thousands of load
15 combinations, worked through that, sorted it down, and
16 looked at certain high-stressed areas, which we say we
17 had better look at that a little closer.

18 And then, we have supplemental criteria.
19 It didn't show up in the first two criteria. We said,
20 well, we need to make sure that we can do the steel
21 designs, the steel component. It is really more on
22 judgment, kind of looking at things that we want to
23 make sure that it is going to work.

24 So, that is what we have used. We ended
25 up with about 35-36 areas. Now when I say area, I am

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not talking about just a wall panel. I am talking
2 about a wall. You know, it is an area. It is a large
3 area, not just a little element that we are trying to
4 design.

5 So, we ended up with about a total,
6 between the nuclear island and the other buildings, of
7 about 36 sections to do detailed concrete design or
8 steel design on, and that is work-in-progress, an open
9 item right now.

10 CHAIR POWERS: When we have tested
11 concrete structures -- and usually these tests are not
12 seismic tests; they are structural tests,
13 overpressurization tests -- we have always found the
14 failures occur at details below the level of
15 resolution of any computer code. And the argument has
16 always been that: oh, well, yes, it failed at
17 something that we actually don't want, but had it not
18 failed, it would have failed at slightly higher
19 pressures at a membrane section. And so, it's okay.

20 Do you have the same problem here, that
21 you model these things, but there is a limit to the
22 detail that you are going to try to model? And
23 sometimes those things that you don't model are, in
24 fact, the high-stress or weak regions?

25 MR. OSWALD: Well, the detail in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements and the code requirements sort of address
2 the majority of that in concrete. I am trying to
3 think of what examples you may have been talking
4 about. I mean, absolutely, we are not finite element
5 modeling every little detail, but there's requirements
6 built into the codes to have the margins in your
7 connections. I mean, in structural design, we really
8 focus a lot on connection design.

9 I know I am not answering your question,
10 but I am not really sure --

11 CHAIR POWERS: Well, I think you are. I
12 think you are saying that you are fairly confident
13 that you modeled those things that are likely to be
14 the points of failure. I mean, you are not going to
15 model it rock-by-rock.

16 (Laughter.)

17 MR. OSWALD: We are going to get our loads
18 out of our big model results as finite element models.

19 Those are used to get the loads distributed
20 throughout the structure. And then, we go from there.

21 Then, it is really the detail design is a lot of code
22 application and a lot of design details that have to
23 be thought out.

24 We don't get the answer out of the finite
25 element model, absolutely not. Well, we get the load,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 but we don't get design for this exactly.

2 That should be the last slide that I have
3 there, yes, for Section 3.8.

4 MR. GARDNER: If you will be patient with
5 us, we are going to do Curly shuffle with presenters.

6 CHAIR POWERS: Are we going to let them
7 shuffle or should we just make Darrell do the rest of
8 it?

9 MEMBER SKILLMAN: I want to see the Curly
10 shuffle.

11 (Laughter.)

12 CHAIR POWERS: Yes, please go ahead.

13 MR. McGAUGHY: All right. Good morning,
14 everyone. I am Chris McGaughy. I am a professional
15 engineer in Virginia, an advisory engineer with AREVA.
16 I have been working for the company for 22 years,
17 mostly in structural and thermal hydraulic analysis of
18 reactor coolant system and Class 1 piping components
19 and supporters.

20 I have got a few subject matter experts
21 here with me to help me through this complicated
22 section.

23 This is Ashok Nana. He has been with the
24 company for 31 years. He is our expert in leak-
25 before-break and fracture mechanics analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I have John Burgess over on the wall, who
2 is also an advisory engineer with AREVA. He works
3 with flow-induced vibration.

4 And Pavan Thallapragada works in Class 1
5 component analysis.

6 And also, Mark Foster is in our civil and
7 layout group.

8 So, let's move to the next slide here.

9 Okay. This is on Section 3.6, which
10 discusses design of the EPR relative to dynamic
11 effects associated with pipe rupture, termination of
12 rupture locations, and also leak-before-break
13 evaluation procedures.

14 Section 3.6.1 covers the design for
15 protection of essential systems, and it follows the
16 guidance of BTP 3-3 and the SRP.

17 The EPR design employs redundancy,
18 distance, intervening structures, and separation of
19 the four safeguards building when exiting containment.

20 Physical protection includes the use of barriers,
21 enclosures for essential equipment, and guard pipes
22 also.

23 Section 3.6.2 discusses ruptures in the
24 high- and moderate-energy piping inside and outside
25 containment. The ruptures and leakage cracks are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 located using the guidance of BTP 3-4 and the SRP.
2 This includes circumferential and longitudinal breaks
3 and leakage cracks in high-energy lines, and only
4 leakage cracks in moderate-energy lines.

5 Pipe whip analysis, the dynamic effects
6 are evaluated if it is determined that an essential
7 SSC can be affected by the break. And the whipping of
8 a broken pipe is evaluated based on SRP criteria.

9 Continuing on with Section 3.6.2, we have
10 a tech report, ANP-10318P, that describes the
11 methodology used for jet impingement loads on
12 essential SSC. The methodology addresses jet
13 unsteadiness, resonance, and deflection of jets.

14 The methodology was developed based on
15 concerns of the ACRS with ANSI standard 58.2
16 methodology. And briefly, the method uses the
17 following basic principles:

18 Source conditions are evaluated throughout
19 the blowdown to determine the worst-case loading after
20 the rupture. The jet plume effective link for two-
21 phase jets is based on NUREG/CR-2913, and for steam
22 jets it is based on NEA Report NEA/CSNI/R (95)11,
23 which was based on some testing in real situations.

24 Jet properties are based on basic
25 thermodynamic principles. Resonance minimum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequencies are based on a paper by Dr. Chris Tam, who
2 is a Florida State University noted member of the
3 applied math, acoustics, and fluid dynamics community.

4 As a side note, Dr. Tam provided us a great amount of
5 help in developing our approach to resonance.

6 Higher frequencies are assumed to line up
7 with the structure natural frequencies. So,
8 basically, we have a method to develop what the
9 minimum natural frequency or resonance frequency is
10 within the jet, but that doesn't tell us what all the
11 possible frequencies are for the jet. So, we assumed
12 that any higher frequencies would just line up with
13 the structure that is being impinged upon. And so, we
14 will just apply loads at that frequency to that
15 component, and we will calculate stresses that way.

16 CHAIR POWERS: So, how do you calculate
17 amplitudes?

18 MR. McGAUGHY: Okay. We have done it
19 about as conservatively as we possibly could. We took
20 the --

21 CHAIR POWERS: Well, you certainly were
22 conservative in your choice of frequencies.

23 (Laughter.)

24 MR. McGAUGHY: Exactly.

25 CHAIR POWERS: I don't see how you could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be more conservative than that.

2 MR. McGAUGHY: That is what we are hoping
3 for, yes.

4 Basically, we take the force on the jet,
5 which is basically the exit-plane forces, and we take
6 that as the amplitude of the --

7 CHAIR POWERS: So, your high-frequency
8 components have the same --

9 MR. McGAUGHY: That's right, and what we
10 found is, after you get past a certain frequency,
11 usually in the neighborhood of 75 Hertz or something,
12 the response to that really drops off a lot and the
13 stresses are pretty small. But we still, for like a
14 plate-and-shell-type structure, like a pressure
15 vessel, our criteria is we go up to a minimum of 500
16 Hertz. And then, hopefully, the stresses will start
17 coming down in the component, but we make sure that we
18 have dropped at least 75 percent before we stop
19 looking at frequencies.

20 CHAIR POWERS: That is pretty interesting.
21 Resonances are all equal amplitude.

22 MR. McGAUGHY: And especially in a
23 pressure-vessel-type structure, the shell, it starts a
24 lot of localized modes where you get multiple peaks in
25 it. And really, with a jet, you are only loading at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one spot. So, it doesn't really respond very well to
2 that type of a load, which is helpful for us.

3 MEMBER SKILLMAN: Chris, how did you
4 choose your target population?

5 MR. McGAUGHY: Well, basically, anywhere
6 that the jet can strike. You know, we have terminal
7 end-breaks and, also, intermediate breaks based on
8 stresses. And so, anywhere that that jet can strike,
9 that would be a target.

10 MEMBER SKILLMAN: Thank you.

11 MR. McGAUGHY: And we have a flowchart of
12 our methodology included in our tech report and, also,
13 in the response to RAI-354, Question 36233.

14 And also, blast effects, we have found
15 that blast effects only occur in lines containing
16 steam, and the steam lines outside --

17 CHAIR POWERS: I am not sure what you mean
18 by blast effect.

19 MR. McGAUGHY: Okay. Okay. Well, a
20 blast, basically, if you have a disturbance in the
21 atmosphere that is high-speed, and it would be a
22 compression or heating or both, like in the event of
23 TNT, then --

24 CHAIR POWERS: So, you are just saying you
25 have shock waves?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. McGAUGHY: Exactly. It is a shock
2 wave traveling at the speed of sound --

3 CHAIR POWERS: All right. Now I
4 understand.

5 MR. McGAUGHY: -- and that is a blast.

6 CHAIR POWERS: Absolutely. So, you can
7 have them with steam, yes.

8 MR. McGAUGHY: Yes, definitely with steam,
9 and with cold water or saturated water, you typically
10 would not see that until you get up into a higher
11 quality. Because, really, the speed of sound of the
12 fluid at the higher qualities, it is really low when
13 it is coming out of the break. So, it is difficult to
14 develop a blast wave if you have such low speeds.

15 CHAIR POWERS: Right.

16 MR. McGAUGHY: Now the steam lines inside
17 containment are not evaluated for pipe rupture effects
18 because we have qualified those to LBB. But we know
19 right outside containment we have the main steam
20 isolation valves, and they are in rooms right next to
21 each other. And so, we have to evaluate a break there
22 which could affect the opposing main steam isolation
23 valve.

24 MEMBER SKILLMAN: What actions have you
25 taken for the certified design to ensure that there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are not target locations out in the plant where there
2 is vulnerability to important equipment? I am
3 thinking of the trauma that the industry has gone
4 through over the years where there have been theorized
5 breaks at some arcane steam location out in the
6 turbine building.

7 MR. McGAUGHY: Sure.

8 MEMBER SKILLMAN: But there is a panel
9 that has an important-to-safety instrument, and the
10 work the industry has had to go through to protect
11 that panel or that instrument. What effort has been
12 invested in this certified design to ensure that there
13 is not a population of orphans out there where, when
14 we look at the robust part of the building, we are
15 saying everything is protected, but there are these
16 other vulnerabilities that may not have been
17 considered?

18 MR. McGAUGHY: Okay. So, you are speaking
19 of like a panel outside the containment building, for
20 example?

21 MEMBER SKILLMAN: It could be in the
22 turbine building.

23 MR. McGAUGHY: It could be anywhere.

24 MEMBER SKILLMAN: It could be over in
25 the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. McGAUGHY: And if it has a safety-
2 related function --

3 MEMBER SKILLMAN: And gee whiz, there is
4 an energy supply in a contained pipe or compressed
5 air, and, all of a sudden, I now have vulnerability
6 that I must factor back into my risk assessment.

7 MR. McGAUGHY: Well, if that were a
8 safety-related piece of equipment, then it would have
9 to be in an enclosure or protected by some sort of a
10 barrier.

11 MEMBER SKILLMAN: Would the barrier have
12 been evaluated for blast effect?

13 MR. McGAUGHY: Yes. If that barrier is
14 intended to protect safety-related equipment, then it
15 would be safety -- well, it is not really safety-
16 related, but it has to be evaluated for the blast or
17 the jet impingement just as well.

18 MEMBER SKILLMAN: Thank you.

19 MR. McGAUGHY: Okay. Leak-before-break.
20 Section 3.6.3 discusses leak-before-break and
21 methodologies used to apply to U.S. EPR piping
22 systems. The methods used are consistent with
23 NUREG-1061 and SRP 3.6.3.

24 LBB has been applied to the RCS leak
25 piping, the pressurizer surge line, and, also, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 main steam line inside containment, as I mentioned a
2 moment ago.

3 CHAIR POWERS: Go over those again?

4 MR. McGAUGHY: I'm sorry, what's that?

5 CHAIR POWERS: Which ones are you --

6 MR. McGAUGHY: The main steam line inside
7 containment, the pressurizer surge line, and the main
8 coolant loop piping, hot legs and cold legs.

9 CHAIR POWERS: Surge line, and what was
10 the third one?

11 MR. McGAUGHY: Main coolant loop piping,
12 hot leg, cold leg, crossover leg.

13 The LBB results are illustrated in the
14 form of an Allowable Load Limit diagram which provides
15 minimum moment along the X-axis and maximum moment
16 along the Y-axis. And then, you have to show that
17 your point fits within the boundaries of the curves.

18 MEMBER SKILLMAN: Let's look at that
19 population again. Main coolant pipe, I understand.
20 Surge line, I understand. Main steam lines inside
21 containment, I understand.

22 How about LBB values in CS lines?

23 MR. McGAUGHY: No, we have not applied LBB
24 to any other lines.

25 MEMBER SKILLMAN: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McGAUGHY: The critical location is
2 the surge line dissimilar metal weld at the
3 pressurizer surge nozzle.

4 Leakage detection. Continuing on with
5 3.6.3, leakage rates for the reactor coolant system
6 and the surge line piping are 5 gallons per minute,
7 and for the steam line it is 1 gallon per minute.
8 This provides a factor of 10 over the leakage
9 detection capabilities of the EPR systems, per the
10 guidance of SRP 3.6.3.

11 Leakage detection methods include local
12 humidity detection and containment sump level. The
13 local humidity detection systems are discussed in
14 Section 7.1.1, and leakage detection systems are
15 discussed in Section 5.2.5.

16 CHAIR POWERS: What size of crack would I
17 need in the main --

18 MR. McGAUGHY: The main steam line?

19 CHAIR POWERS: -- the main steam line to
20 get 5 gallons per minute?

21 MR. McGAUGHY: It is 1 gallon per minute
22 for the steam line.

23 CHAIR POWERS: I'm sorry.

24 MR. McGAUGHY: Yes.

25 CHAIR POWERS: One gallon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McGAUGHY: I will turn that to Mr.
2 Nana.

3 MR. NANA: Pardon me. Can you phrase your
4 question again?

5 CHAIR POWERS: How big of a crack do I
6 have to have in the main steam line to get 1 gallon
7 per minute?

8 MR. NANA: I am not sure I have the
9 answers about --

10 CHAIR POWERS: I mean you don't have to
11 give me a number to three significant digits. This
12 big or this big?

13 MS. WEAVER: Could you please say your
14 name for the court reporter?

15 MR. NANA: Oh, this is Ashok Nana.

16 MS. WEAVER: Okay.

17 MR. NANA: From AREVA.

18 I think it is -- and this is my
19 recollection -- 8-inch size.

20 CHAIR POWERS: Eighth inch?

21 MR. NANA: Eight inch. Eight inch.

22 CHAIR POWERS: Eight inch? An 8-inch
23 size, and what the unstable size?

24 MR. NANA: About 22.

25 CHAIR POWERS: Twenty-two? So, a factor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of three on the critical crack size. That's not a
2 lot, is it? Well, it depends on the crack growth
3 rate, I agree with that.

4 MR. NANA: You know, the requirement is a
5 factor of two for leak-before-break demonstration.

6 CHAIR POWERS: I mean, this is a guy that
7 puts all of his frequencies right at the resonance
8 frequency. I mean, he is a very conservative guy.

9 (Laughter.)

10 For crack lengths, he is not so
11 conservative.

12 (Laughter.)

13 MEMBER STETKAR: Does the LBB analysis on
14 the main steam lines extend out through the annulus?
15 Or do you just take credit for the guard pipes out
16 there?

17 MR. NANA: It does not extend past the
18 annulus area.

19 MEMBER STETKAR: I am talking about the
20 space in the annulus.

21 MR. NANA: I think it is before the
22 annulus itself, just prior to the annulus.

23 MR. McGAUGHY: We have the sleeve or the
24 guard pipe that goes into the inner containment, and
25 we have that anchorage that is in the middle of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guard pipe, right? I think we go up to that
2 anchorage, right, but it is inside the guard pipe at
3 that point?

4 MR. NANA: Yes, up to the anchorage point
5 potentially.

6 MEMBER STETKAR: Thanks.

7 MR. McGAUGHY: Okay. This is Section 3.9,
8 which covers mechanical systems and components.

9 Section 3.9.1 covers a few topics,
10 including design transients, computer programs and
11 stress analysis methods. A listing of the design
12 transients can be found in table 3.9.1-1 of the FSAR,
13 and U.S. EPR considers a standard set of transients.
14 There is nothing special about the transients for the
15 U.S. EPR.

16 MEMBER STETKAR: Well, I mean, there is
17 how you have subdivided some of them, because you have
18 taken credit, apparently, for the plant runback
19 capability for loss of offsite power in terms of
20 numbers of events and severity of events, as best as I
21 can tell.

22 (Laughter.)

23 Is that correct? Because the way that you
24 have subdivided loss of offsite power is in short
25 duration with a return to power from a thermal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 perspective versus a longer duration with a natural
2 cooldown. It seems to account for the plant design
3 capability to rapidly reduce power --

4 MR. McGAUGHY: Right.

5 MEMBER STETKAR: -- and remain non-
6 tripped, for example. Is that a right interpretation?
7 I mean, I have read the short paragraphs.

8 MR. STACK: The answer is, yes, that is a
9 correct interpretation.

10 MEMBER STETKAR: Okay.

11 MR. STACK: We will also be covering that
12 when we do Chapter 14 as the testing. We will discuss
13 that, if you have further questions, and we will have
14 our experts then.

15 MEMBER STETKAR: Thanks.

16 MR. McGAUGHY: Software used in the
17 mechanical design of the EPR is listed in Appendix
18 3(c) of the FSAR and the Piping Topical Report. All
19 software used in safety-related applications are
20 verified, validated, and maintained, per internal
21 procedures. And we do not use any experimental stress
22 analysis techniques in the design of the EPR.

23 CHAIR POWERS: When you do a leak-before-
24 break analysis, you are taking into account all of
25 these conditions, normal and upset. How far up the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spectrum do you go?

2 MR. McGAUGHY: It is all the normal and
3 upset transients, plus SSE, right? Or is it just
4 normal?

5 MR. NANA: Essentially, it is leak-before-
6 break analysis is done with the steady-state normal
7 operating conditions. And then, in addition to that,
8 for the followup conditions, the SSE loads.

9 CHAIR POWERS: Okay.

10 MR. NANA: It doesn't go through per se an
11 upset condition.

12 MR. McGAUGHY: The SSE load, I believe, is
13 just for the crack stability analysis, right?

14 CHAIR POWERS: Yes. I mean, that is kind
15 of what you are worried about right now.

16 MR. NANA: Well, for example, for the
17 surge line, I can just say, the stratification loads
18 are actually lower, significantly lower, than the SSE
19 loads. We ensure that we have got the bounding load
20 set.

21 MR. McGAUGHY: Okay. Section 3.9.2
22 describes the startup testing and dynamic vibration
23 analysis performed for the EPR, the flow-induced
24 vibration analyses described in the Technical Report
25 ANP-10306. The Tech Report also describes how the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design of EPR conforms to Reg Guide 1.20, Rev. 3.

2 There are two areas where we departed from
3 the Reg Guide, as you can see on this slide.
4 Basically, looking at vibration analysis of the steam
5 generator upper internals and vibration of the
6 condensate system; we are using hand-held devices
7 instead of mounted vibration protection systems.

8 CHAIR POWERS: Do you attempt to predict
9 the vibrations in these upper internal structures?

10 MR. McGAUGHY: I'm sorry, what's that?

11 CHAIR POWERS: Do you predict the acoustic
12 vibrations of these upper internal structures?

13 MR. McGAUGHY: John?

14 MR. BURGESS: Yes, sir, my name is John
15 Burgess.

16 MEMBER STETKAR: You have to come to the
17 microphone.

18 MR. BURGESS: Yes, my name is John Burgess
19 with AREVA.

20 In regards to evaluating the steam
21 generator upper internals for acoustic resonance, a
22 screening criteria was applied to the steam line and,
23 also, the main feeder water lines to ensure that the
24 design was free of that source of flow excitation.
25 So, in effect, the upper internals of the steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 generator are susceptible to those types of loadings.

2 CHAIR POWERS: Uh-hum, but you don't
3 actually predict them? You just screen them out or --

4 MR. BURGESS: That is correct, sir. We
5 ensure that those two piping systems are free of that
6 source of flow excitation.

7 MEMBER SKILLMAN: How is vane-passing
8 frequency factored into your screening criteria,
9 reactor coolant pump vane-passing frequency?

10 MR. BURGESS: Okay. That type of flow
11 excitation is unique to the primary system. And since
12 the secondary system is separated from the effects of
13 that, that is not specifically vib wave, although we
14 do consider feedwater pump vane-passing frequency.
15 But, for the most part, we disposition those as being
16 ineffective in creating significant excitation to the
17 tube model.

18 MEMBER SKILLMAN: Do you have data to show
19 that that assumption is accurate?

20 MR. BURGESS: No, sir, we do not. It is
21 primarily established on the basis of the impedance
22 that is created by the void fractions, the secondary
23 side fluids, and its inability to transmit those
24 particular waves through two-phase matrix.

25 MEMBER SKILLMAN: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McGAUGHY: Okay. Section 3.9.3
2 describes the structural stress and fatigue analysis
3 methodologies, including environmental fatigue used
4 for ASME components. It is environmental fatigue for
5 ASME components. The component supports do not
6 consider environmental fatigue.

7 Structural design of piping and pipe
8 supports is discussed in the Piping Topical Report
9 ANP-10264NP-A. The topics covered include applied
10 loads and load combinations, allowable limits,
11 operability criteria for components, functionality
12 requirements for piping, and jurisdictional boundaries
13 for the supports.

14 The boiler pressure vessel code
15 requirements are called for the stress of fatigue
16 analysis, and QME-1 governs the functional design and
17 qualification of components.

18 Section 3.9.4 considers the control rod
19 drive system, and 3.9.4 addresses control rod drive
20 mechanism, rod cluster control assembly, as well as
21 the operation and prototype-testing of the control rod
22 drive mechanism.

23 CRDMs are based on a proven design which
24 has more than 30 years of performance history, and it
25 uses the Mag-Jack design principle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The prototype testing was conducted at
2 AREVA facilities in Germany for the U.S. EPR control
3 rod drive system, and it was conducted to establish
4 functionality at operating conditions, endurance, and
5 also drop times.

6 Details for the CRDMs are discussed more
7 in Chapter 4.

8 CHAIR POWERS: So, you don't look at
9 functionality outside of the operating condition
10 envelope?

11 MR. McGAUGHY: Functionality of the CRDMs?

12 CHAIR POWERS: Uh-hum.

13 MR. McGAUGHY: You mean for like during an
14 earthquake or --

15 CHAIR POWERS: Yes.

16 MR. McGAUGHY: Yes, I mean, we look at
17 drop times during a safe shutdown earthquake, yes.

18 Okay. Section 3.9.5 is the reactor
19 pressure vessel upper and lower internals.

20 CHAIR POWERS: Yes. I mean, do you have a
21 topical report or something on this testing?

22 MR. McGAUGHY: Oh, on the testing?

23 CHAIR POWERS: Yes.

24 MR. McGAUGHY: I don't believe there is a
25 topical report on the control rod drive testing, was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there?

2 CHAIR POWERS: I was just anxious to read
3 all the gory details on this.

4 MR. WELLS: This is Russ Wells of AREVA.

5 No, there is no specific topical reports,
6 but the results of the testing were shared with the
7 staff. It was during an audit that was conducted here
8 in Rockville. So, we brought some of our experts over
9 from France who brought the results with them, and
10 they were shared with the staff.

11 CHAIR POWERS: Okay.

12 MR. WELLS: I believe that also was
13 documented in the staff's SER, too.

14 CHAIR POWERS: Oh, okay.

15 MR. McGAUGHY: Okay. Section 3.9.5, as I
16 said a minute ago, is reactor pressure vessel
17 internals. It provides a description of the important
18 parts of the core support structures and reactor
19 internals. It describes the coolant flow through the
20 vessel and, also, loading conditions we consider in
21 the design.

22 Table 3.9.5-1 provides a classification of
23 the major internal components with regards to whether
24 core support structures or internal structures are
25 classified by Subsection NG.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Section 3.9.6 describes the functional
2 design, qualification, in-service testing programs for
3 pumps, valves, and dynamic restraints used in the
4 safety-related systems.

5 In-service testing is performed in
6 accordance with the ASME OM Code as well as Reg Guide
7 1.192 and NUREG-1482, Rev. 1.

8 Description of the functional design and
9 qualification and IST programs in Section 3.9.6 allows
10 the COL applicants to incorporate the description of
11 these programs in their COL applications by reference
12 with only plant-specific information needed to
13 supplement the program descriptions.

14 Functional design and qualification in
15 accordance with QME-1-2007.

16 The U.S. EPR design provides access to
17 system structure and the components to allow testing
18 using currently-available equipment and techniques.

19 The system allows full-flow testing of
20 pumps and valves and permits check valves to be tested
21 for performance in both flow directions.

22 MEMBER SKILLMAN: Let me ask you to
23 reinforce that communication.

24 MR. McGAUGHY: Okay.

25 MEMBER SKILLMAN: If I would let my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 imagination wonder, what you are communicating here is
2 where the industry has been stymied in the past by
3 inability to confirm ECCS in all accident modes
4 because of alignment issues or because of outage
5 contest issues between DK8 and ECCS, this certified
6 design purposefully prevents that complication, such
7 that these systems can fully flow test it?

8 MR. McGAUGHY: I will ask Tim Stack to
9 help me with that answer.

10 MR. STACK: Tim Stack again from AREVA.

11 The answer is yes. One qualifier is that
12 the mode that the testing is performed in may be a
13 shutdown mode, but, in fact, we can do full-flow
14 testing on all of the safety-related pumps.

15 MEMBER SKILLMAN: And the check valves?

16 MR. STACK: Yes, sir.

17 MEMBER SKILLMAN: Thank you.

18 MR. McGAUGHY: Let's see, Section 3.9.6
19 continuing, this slide provides some additional
20 details concerning the IST programs for motor-operated
21 valves and pilot-operated valves. A list of the pumps
22 and valves included in the IST programs are found in
23 FSAR tables 3.9.6-1 and 3.9.6-2.

24 Visual examination of the snubbers will be
25 performed in accordance with the Code Case OMN-13m as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 accepted by the NRC in Reg Guide 1.192.

2 CHAIR POWERS: What is that visual
3 examination?

4 MR. McGAUGHY: I'm sorry, what's that?

5 CHAIR POWERS: What is required?

6 MR. McGAUGHY: For a visual examination of
7 like snubbers?

8 CHAIR POWERS: Yes.

9 MR. McGAUGHY: Well, basically, one would
10 make sure that no oil is leaking out of it or --

11 CHAIR POWERS: It just looks like it is
12 what it should be.

13 MR. McGAUGHY: Yes.

14 CHAIR POWERS: It looked like what was
15 installed.

16 MR. McGAUGHY: Right.

17 CHAIR POWERS: Okay. It is not much of an
18 examination, but --

19 MR. McGAUGHY: Yes.

20 MEMBER STETKAR: Chris, let me sandbag you
21 a little bit here. Reading in the SER, apparently,
22 the staff had a question about leak tightness testing
23 of the main steam isolation valves in the reverse-flow
24 direction, not the forward-flow direction, but the
25 reverse-flow direction.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And apparently, there was a statement made
2 that the MSIVs don't need to close, don't need to
3 isolate in the reverse-flow direction for any credible
4 event, I think is the term. And again, I am
5 extracting things from the SER, which is in answer to
6 an RAI. And I don't have the exact words. So,
7 forgive me that.

8 Thinking about that, does the EPR safety
9 analysis of a main steam line break upstream from the
10 MSIVs, so inside containment or anything upstream from
11 the MSIVs, include credit for closure of the main
12 steam isolation valve in the faulted steam line to
13 isolate reverse-flow from the other steam generators?

14 And if it does, then it seems like the design does,
15 indeed, include credit for isolation in the reverse-
16 flow direction.

17 So, the question is, does the safety
18 analysis include credit for closure of that valve?
19 And I looked at Tim because I know Tim has the answer.

20 I'm sure he does.

21 (Laughter.)

22 MR. STACK: The answer is yes.

23 MEMBER STETKAR: Yes. Okay. So, okay, we
24 will follow up with the staff on why they accepted
25 that. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McGAUGHY: Section 3.12 describes the
2 design analysis methods used for piping and piping
3 supports in the U.S. EPR systems. The detail of these
4 methods is included in the Piping Topical Report. The
5 topical report addresses all aspects of piping and
6 pipe support design, including loading methodologies,
7 load combinations, acceptance criteria, and special
8 topics such as thermal stratification.
9 Environmentally, system fatigue is evaluated in
10 accordance with Reg Guide 1.207, which references
11 NUREG/CR-6909.

12 Section 3.13 covers the design of threaded
13 fasteners using pressure-retaining components. Design
14 of these fasteners follows ASME Boiler and Pressure
15 Vessel Code guidance with consideration from
16 regulatory guidance such as Reg Guide 1.65, which
17 addresses specifically requirements for RV closure
18 head studs. Inspection of the fasteners is per
19 Section 11 of the ASME Code.

20 CHAIR POWERS: And, of course, we have had
21 some difficulties late in the precise area. Does that
22 prompt you to do anything in your design? Bolt
23 enclosures?

24 MR. McGAUGHY: Right.

25 CHAIR POWERS: I mean, we have had some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 people -- not molting, bolting (laughter).

2 MR. McGAUGHY: You mean ensuring that the
3 bolted closure is, indeed, tight?

4 CHAIR POWERS: Yes. Yes, tight.

5 MR. McGAUGHY: Well, I am sure that would
6 follow basic procedures for installing the closure,
7 which we would always have bolting --

8 CHAIR POWERS: I mean, you have
9 requirements and things like that, but you haven't
10 done -- I mean, it is basically an operator's problem.

11 Did you do anything in the design to help him?

12 (Laughter.)

13 It is kind of an appalling thing.

14 MR. McGAUGHY: Right.

15 CHAIR POWERS: And it seems obvious that
16 you ought to bolt things that are supposed to be
17 bolted, but sometimes we don't.

18 (Laughter.)

19 MR. McGAUGHY: Right, things do happen.
20 But, yes, we do ask them to follow the procedures.

21 CHAIR POWERS: The procedure?

22 MR. McGAUGHY: Right.

23 CHAIR POWERS: Just as a change on the
24 routine, let's follow the procedure.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McGAUGHY: Okay, and I believe that is
2 about all we have. I believe Nissen is up next.

3 MEMBER STETKAR: In that, does AREVA
4 supply the tensioning stuff for the head bolts?

5 CHAIR POWERS: I would assume they would.
6 I would assume they would have to.

7 MR. McGAUGHY: I would assume so, too.

8 CHAIR POWERS: Yes. It doesn't matter if
9 we don't pay any attention to them. Who are these
10 guys? What do they know?

11 (Laughter.)

12 MR. GARDNER: Some more topics here. For
13 3.10 and 3.11, Nissen Burstein will be our presenter.

14 MR. BURSTEIN: Good morning. My name is
15 Nissen Burstein. I am a technical consultant, and I
16 have been associated with B&W, Framatome, and AREVA
17 since 1978. I am a lead EQ engineer and a principal
18 author of Sections 3.10 and 3.11 of the FSAR for EPR.

19 I belong to the Electrical Engineering
20 Design Analysis and New Builds Group of AREVA. I
21 earned bachelor's and master's degrees in aerospace
22 engineering from Penn State and a master's in business
23 from Lynchburg College.

24 I have been involved in EQ for over 40
25 years, starting at the Franklin Institute in the late

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sixties. I was the Vice Chair for five years and the
2 Chairman for two years of the IEEE Nuclear Power
3 Engineering Committee on Equipment Qualification. I
4 am currently a member of numerous committees and
5 working groups on nuclear power and EQ within IEEE,
6 ASME, and IEC.

7 I am here to discuss the Sections 3.10 and
8 3.11 with you on seismic and dynamic qualification of
9 mechanical and electrical equipment.

10 Section 3.10 provides the requirements for
11 seismic and dynamic qualification, as seismic
12 qualification is performed by test analysis or a
13 combination of test and analysis. It is all done in
14 accordance with IEEE 344-2004 and ASME QME-1-2007, as
15 endorsed by Reg Guide 1.100, Revision 3. It should be
16 noted that the seismic qualification by experience
17 that is allowed by IEEE 344 is not utilized on the
18 U.S. EPR.

19 Electrical and mechanical equipment is
20 qualified for the SSE, as defined in Section 3.7.1,
21 with low-level effects considered through five OBE
22 testing, also in accordance with IEEE 344.

23 We have a section within 3.10 that lists
24 all of the electrical and the I&C equipment that is
25 being seismically-qualified in accordance with 344.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Can I ask a question?

2 MR. BURSTEIN: Yes, sir.

3 MEMBER BROWN: Relative to the testing
4 regime, I have taken it, after you have gone through
5 the litany, that that means you are going to actually
6 do a seismic test on the reactor instrumentation
7 control systems, protection systems, and various other
8 electrical systems associated with monitoring and
9 controlling?

10 MR. BURSTEIN: Yes, sir, that's true.

11 MEMBER BROWN: Okay. So, it will not be
12 analyzed or based on experience. It will be tested?
13 You are only dictating that or is that required by the
14 DCD or your other design --

15 MR. BURSTEIN: No, we are allowing the
16 methods by 344 that --

17 MEMBER BROWN: I understand that. It
18 allows people to do that.

19 MR. BURSTEIN: If we can provide suitable,
20 to us, suitable justification for doing analysis or
21 previous operating experience, then we will.

22 MEMBER BROWN: To whom? Who do you
23 provide that to? You said if you can provide a basis
24 for doing the analysis --

25 MR. BURSTEIN: Well, that would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 essentially provided by the vendor to us. We would
2 agree that they have met the requirements.

3 MEMBER BROWN: Okay. So, this spills down
4 to when you actually place a contract for
5 manufacturing in accordance with your design
6 documents? And at that point, you will, then, wait
7 for the vendor to request whether they either actually
8 test it or whether they do it by analysis?

9 MR. BURSTEIN: Yes.

10 MEMBER BROWN: Is that what you are
11 telling me?

12 MR. BURSTEIN: Yes. We allow that by our
13 specifications.

14 MEMBER BROWN: Okay.

15 MR. BURSTEIN: Yes.

16 MEMBER BROWN: And your specifications are
17 just by the IEEE standard?

18 MR. BURSTEIN: Well, both.

19 MEMBER BROWN: Okay. So, it is not locked
20 in by any means? You are providing variability, in
21 other words?

22 MR. BURSTEIN: Yes. There are some cases
23 you just can't test something, diesel generators, for
24 example.

25 MEMBER BROWN: Yes, I understand that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BURSTEIN: The equipment can come in
2 on -- well, the control equipment for a diesel can
3 come in on a pallet. We could require that to be
4 tested.

5 MEMBER BROWN: I understand diesel
6 generators, turbine generators, things like that,
7 which are relatively huge, have a more difficult time
8 if you don't do them by pieces. But, normally, the
9 I&C equipment, cabinets, and other racks, and things
10 of that nature, aren't necessarily huge components.
11 Or the main control panels, they come in groups. They
12 are not brought in in a 27-foot-wide trailer. They
13 are brought in in assemblies and, then, assembled
14 together.

15 So, I was wondering which way, if I can
16 separate out the stuff that is huge from the stuff
17 that is small --

18 MR. BURSTEIN: If the vendor cannot
19 provide the evidence to us that those components are
20 qualified to our requirements, then they have to be
21 tested, if they can't provide the justification. I
22 mean, we have pressure transmitters that have been
23 qualified forever, and they are used on operating
24 plants. In most cases, we would not expect them to
25 have to be requalified.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Okay, separate, I
2 understand the little transmitters, but the cabinets
3 and the racks, and all that type of stuff is not
4 necessarily in its assembly, and whatever it is for
5 this plant has not necessarily been tested before.

6 MR. BURSTEIN: Correct. And if not --

7 MEMBER BROWN: I would expect those to be
8 tested, but I am trying to figure out whether there is
9 going to be some -- I don't want to call it sleight of
10 hand, but some -- (laughter) I call it sleight of
11 hand. I mean, the vendors love to come in and say, I
12 don't want to test this stuff because, No. 1, it is
13 difficult and it might show it breaks. Whereas, if
14 they do it by analysis, you can --

15 MR. BURSTEIN: If they don't have
16 something to back up the analysis, we won't accept it.

17 MEMBER BROWN: Well, after listening to
18 the discussion of models earlier on other
19 substructures and other things like that, you can
20 always question whether the models are really suitable
21 models for analyzing whether the cabinet will come
22 apart or whether the welds will break, or whether the
23 controls will come apart, et cetera. It is very
24 difficult, particularly in electrical cabinets where
25 you have connectors and other types of devices that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have to be fastened together and have far more little
2 pieces that you have got to deal with than when you
3 have a large structure like a concrete wall.

4 So, I have stayed quiet during the other
5 part because I was more interested in this, since I
6 read back in the slides and saw it was coming. I am
7 just interested in trying to figure out if you all
8 were going to just wait. So, nobody will know for
9 another five or six years whether they are going to
10 get tested or whether you will accept it by analysis
11 is effectively what I am walking away from.

12 MR. BURSTEIN: That's correct.

13 MEMBER BROWN: It is a nice, mushy answer.

14 Okay.

15 Excuse me, Dana, but that is --

16 MEMBER SKILLMAN: I would like to ask for
17 clarification, please, Nissen. Your fourth bullet,
18 would you explain that bullet to us, please?

19 MR. BURSTEIN: About not being based on
20 experience?

21 MEMBER SKILLMAN: Yes. What does that
22 mean?

23 MR. BURSTEIN: There is a section in 344
24 that allows you to qualify by experience if you meet
25 certain criteria. In our discussions with the staff,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they have basically explicitly told us that is not
2 acceptable. So, we have revised the FSAR to take that
3 portion out, that we will not allow that.

4 MEMBER SKILLMAN: Okay. Does that now
5 require that you either actually do a test or have
6 some analytical qualification --

7 MR. BURSTEIN: Yes.

8 MEMBER SKILLMAN: -- that provides the
9 qualification for that device?

10 MR. BURSTEIN: Yes. That's correct.

11 CHAIR POWERS: But in your oral response
12 to Mr. Brown, you said, gee, we have this pressure
13 transmitter that has been used forever in the plants.

14 I can't remember the exact words. You wouldn't
15 expect to have to requalify that. How does that jibe
16 with bullet four?

17 MR. BURSTEIN: That's a good question
18 because the experience is used in two different
19 fashions.

20 In regard to the experience factor that is
21 in 344, it is not the same experience factor that we
22 are talking about with respect to that transmitter.
23 It is an experience factor related to earthquakes,
24 real earthquakes, going and taking a real earthquake
25 and saying, okay, I don't have to do this because I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 meet that earthquake and that's what the staff say,
2 no, you can't do that. That is the experience factor
3 that is in the 344 comment.

4 MR. GARDNER: We would not requalify
5 something already qualified, I think really was the
6 point he was trying to make. If there was already an
7 existing test for a component --

8 MEMBER BROWN: Yes, but when you go to a
9 detector -- let me just go back to your point on the
10 detector. The pressure detector, differential
11 pressure detector, normally, those are tested; you
12 have got to have a foundation inside of your structure
13 that mounts those. And the testing of that detector
14 itself is very dependent on the characteristics of the
15 foundation and the springiness or non-springiness of
16 the materials and how it is oriented.

17 So, I mean, if you are going to put
18 something in and says, well, gee, it's qualified
19 already, to me, that means you have to go look at the
20 exact method of mounting under which it was qualified.

21 That is the mounting methodology you have to do, and
22 you have to analyze that mounting foundation structure
23 to see that it passes through your seismic and other
24 stress-type conditions that it has to endure.

25 Now I don't know if the vendor can do that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or whether you have to do that in the context of
2 accepting that qualification, the way you phrased it,
3 for your particular plant design. So, it just seems a
4 little fuzzy to me as to how you are going to get to
5 the endpoint on this with some of these.

6 I understand the point of qualifications.

7 I have done that. That was part of my past. We had
8 qualify detectors, but, yet, we always got wrapped
9 around the axle in terms of actual application within
10 the structure of the reactor compartments or other
11 parts of the ship we were putting it in, and why did
12 it still meet -- why could you accept that
13 qualification or those circumstances?

14 And I am not quite sure of the process
15 because it seems that it stops with AREVA and it
16 doesn't stop with -- there is no other higher-level
17 authority in terms of finally accepting that.

18 It is just a question; that's all. I am
19 trying to figure out what we, as a Committee, maybe
20 ought to do.

21 So, that is all I have on that, Dana,
22 unless you all have something else. I am not trying
23 to cut it off, but I presume you wanted to get moving.

24 So, I have got my answer right now.

25 CHAIR POWERS: You're satisfied?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, I'm not
2 overwhelmingly satisfied. For big, big things, I can
3 understand it. For the smaller cabinets, if you look
4 at all the stuff we have looked at in the other
5 designs so far, the structure is for the cabinets and
6 the main control room racks and everything. They are
7 not the same. Everybody's is a little bit different.

8 Qualifying, say, a circuit card for one
9 thing is interesting, but it doesn't qualify if you
10 put it in a cabinet and that cabinet does not support
11 it the same way it was qualified.

12 MR. BURSTEIN: That's correct, and if it
13 doesn't, then it has to be done over again.

14 MEMBER BROWN: Yes, I am trying to hope
15 that you all test it, but it's very difficult for each
16 and every cabinet --

17 MR. BURSTEIN: We allow for analysis as
18 well.

19 MEMBER BROWN: I understand that. I
20 didn't say I liked it, though, did I?

21 MR. BURSTEIN: And previous experience.
22 And previous experience.

23 MR. GARDNER: I think maybe the challenge
24 would be to say we're only going to test something
25 without knowing everything until you get the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 components. There may be things you couldn't commit
2 to that 100 percent. There may have to be a
3 combination of analysis to go along with that.

4 I understand your point, but I am not sure
5 how to give you an absolute --

6 MEMBER BROWN: Yes, I'm just not
7 comfortable on some of the stuff unless they are
8 identical applications, totally identical in terms of
9 the applications and number of circuit cards,
10 structure inside of them, and the backplanes, the
11 whole rest of the smear.

12 I am just trying to grapple with that, the
13 difference between the way I did the business in the
14 naval nuclear program and the way it appears to be
15 being done in the commercial world, which is
16 considerably different in terms of qualification by
17 extension, which is roughly what you are talking
18 about, based on a past installation and it is supposed
19 to look the same. So, I have just got to think about
20 that now in the context of your answer. Okay?

21 Thank you for bearing with me, Dana.

22 MR. BURSTEIN: Continuing on with what we
23 have in 3.10, we developed what we call an SQDP, which
24 is a seismic qualification data package, for each
25 equipment that documents the qualification results

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that established the capability of the equipment to
2 meet its requirements. I know it is kind of going
3 around what you were saying, but this is the paper
4 trail that we developed or that is developed.

5 We have a sample SQDP format that is
6 included in Appendix 3D. The Appendix also includes a
7 procedure for qualification procedures that are more
8 in detail for mechanical and electrical equipment also
9 in 3D.

10 Lastly, if the COL applicant identifies
11 any site-specific components, then they need to be
12 added to the equipment list that is in table 3.10,
13 which is our overall list of the seismic components
14 that are being qualified.

15 MEMBER SKILLMAN: Let's go back to a
16 comment that you made a few minutes ago that I think
17 is indicative of the type of thing that Charlie is
18 pointing to. Let's talk for a minute about 5-megawatt
19 emergency diesel generator, a big diesel engine.

20 So, I have got a large mechanical machine.
21 I have got a governor. But I also have the rack
22 control. I have got the instrumentation tubing
23 associated with that engine. Then, I have basically
24 my ECCS power supply on the other end of the drive
25 shaft. That is my ECCS power.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 How do you envision qualification of that
2 device under 3.10?

3 MR. BURSTEIN: Well, part of that is
4 functionally we look at that with respect to 497 for
5 diesel generators. The big pieces, if you will, are
6 generally qualified on the basis of analysis and
7 operating experience from before. Similar machines in
8 the same family have been tested and qualified one way
9 or another.

10 As far as the smaller components, if you
11 will, and I wouldn't say piping so much as tubing,
12 they would typically be qualified by themselves on
13 racks that would be used on the engine, and they would
14 generally be put on the table.

15 MEMBER SKILLMAN: The shaker table?

16 MR. BURSTEIN: The shaker table, yes.
17 Excuse me. They would be put on the shaker table and
18 subjected to the ROS that we have for their location.

19 And they would be put through functionally. There
20 would be air in the lines. There would be electrical
21 wires connected. They would be operating, to show
22 that this does, in fact, meet the seismic
23 requirements.

24 MEMBER SKILLMAN: Thank you.

25 MR. BURSTEIN: Section 3.11 discusses the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 environmental qualification of mechanical and
2 electrical equipment. This provides our approach to
3 how we are qualifying to meet 10 CFR 50.49, including
4 instead of just the I&C and certain post-accident,
5 there are basically three classes: the class safety-
6 related equipment, the post-accident monitoring
7 equipment, and then the class of non-safety equipment
8 whose failure cannot affect the performance of a
9 safety function. Those are the three classes of
10 equipment that are qualified.

11 CHAIR POWERS: When you qualify equipment,
12 safety-related equipment for the post-LOCA
13 environment, what do you do? What do you consider?

14 MR. BURSTEIN: Well, without going into a
15 whole long thing, we will age it, dump it, thermally
16 age it, subject it to radiation, non-seismic
17 vibration, then the seismic vibration, and then we put
18 it into a pressure vessel to hit it with steam and
19 chemical spray.

20 CHAIR POWERS: In the post-LOCA
21 environment what kind of doses do you consider?

22 MR. BURSTEIN: Excuse me. What kind of
23 what?

24 CHAIR POWERS: Dose, radiation dose.

25 MR. BURSTEIN: The post-accident doses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we are provided. We have a normal aging dose and
2 then we have a post-accident dose that are provided by
3 the folks who give us the environmental conditions
4 from the accident analysis. Typically, we will test
5 to 200 megarads of radiation.

6 CHAIR POWERS: And roughly what, a megarad
7 per hour?

8 MR. BURSTEIN: Typically, yes.

9 CHAIR POWERS: If I subject cabling to a
10 megarad per hour and it is polyvinyl chloride, won't I
11 get a substantial hydrochloric acid?

12 MR. BURSTEIN: No. What do you mean
13 substantial? No, I would say no, not hydrochloric
14 acid.

15 CHAIR POWERS: Why would you say that?

16 MR. BURSTEIN: Well, first off, we don't
17 typically use polyvinyl chloride inside the
18 containment.

19 CHAIR POWERS: What kind of cabling do you
20 have?

21 MR. BURSTEIN: EPR, ethylene propylene
22 silicone cable.

23 CHAIR POWERS: You don't need to have any
24 Hypalon?

25 MR. BURSTEIN: They are not making Hypalon

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anymore.

2 CHAIR POWERS: The equivalent thereof?

3 MR. BURSTEIN: Yes. But, no, PVC, no, it
4 is almost like Teflon. We don't use that inside the
5 containment.

6 CHAIR POWERS: Okay. All right. A
7 megarad per hour, you have a substantial nitric acid
8 dose?

9 MR. BURSTEIN: Not that I'm aware of.

10 CHAIR POWERS: If I irradiate air, and you
11 have an air containment, I am going to get nitric
12 acid.

13 MR. BURSTEIN: I'm not aware of that.

14 CHAIR POWERS: I hate to say trust me, but
15 you can trust me on this one.

16 (Laughter.)

17 So, do you take into account acids?

18 MR. BURSTEIN: We will look into that.
19 Not specifically. We do irradiation in air, but not
20 in acidic environments, no, nor do I know of anyone
21 that does that.

22 CHAIR POWERS: The question is, why not?

23 MR. BURSTEIN: To my knowledge, it has
24 never been a concern, that it needs to be. There was
25 no degradation as a result of it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: You have got 30 days that
2 you have to survive and your electrical equipment in
3 an irradiated environment at roughly a megarad per
4 hour. I don't see how you would avoid forming nitric
5 acid, and I can't imagine nitric acid is good for
6 electrical equipment.

7 MR. BURSTEIN: Well, you are not
8 irradiating it for 30 days. The post-LOCA environment
9 is typically your steam environment. The radiation is
10 done before the LOCA testing.

11 CHAIR POWERS: If I have a LOCA, I am
12 going to have a radiation environment in my
13 containment.

14 MR. BURSTEIN: Yes.

15 CHAIR POWERS: Now what you do in the
16 testing, I don't care. But in the environment, in the
17 post-LOCA environment, I am definitely going to have
18 irradiation events.

19 MR. BURSTEIN: I have to agree. What I am
20 describing has been acceptable to the industry, the
21 staff, et cetera, on all operating plants.

22 CHAIR POWERS: And I am trying to find out
23 why.

24 MR. GARDNER: Why don't we take an action
25 and get back?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BURSTEIN: We can look at it. I can't
2 tell you any more than what I have.

3 CHAIR POWERS: Okay.

4 MR. BURSTEIN: Equipment in the scope of
5 our 50.49 program is qualified on the basis of IEEE
6 323-1974, endorsed by Reg Guide 1.89 and related
7 standards that we have in table 3.11-4 of our Section
8 3.11.

9 The environmental conditions that we
10 qualify to include anticipated operational
11 occurrences, normal, accident, and post-accident
12 environments due to a DBE.

13 The FSAR includes a detailed listing by
14 part number, or tag number -- excuse me -- of all of
15 the equipment that is being qualified. The listing is
16 approximately 200 pages long, including 15,000-odd
17 pieces of equipment.

18 In addition, we are also considering a new
19 environment, if you will, electromagnetic
20 compatibility, from the standpoint of equipment
21 susceptibility and emissions, particularly because of
22 the real operational involvement, if you will, of
23 digital equipment and equipment that emits EMC. So,
24 we have required that as one of our qualification
25 environments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SKILLMAN: A question, please.

2 MR. BURSTEIN: Yes, sir.

3 MEMBER SKILLMAN: The choice of the
4 exterior or interior pressure, temperature, humidity,
5 radiation environment and other environmental factors
6 for each device depends on where it is located in the
7 plant.

8 MR. BURSTEIN: Yes.

9 MEMBER SKILLMAN: And I believe what that
10 means is that for this program to have foundational
11 importance for the EPR, the device's location must be
12 associated with a compartment-by-compartment analysis
13 of the mass and energy and radiation as it reaches
14 those compartments.

15 So, my question is, what effort is AREVA
16 investing to ensure that a compartment location for a
17 certain device -- and therefore, the EQ requirements
18 for that certain device -- match?

19 MR. BURSTEIN: I am not sure I follow the
20 last part of your question, but let me try to answer
21 what I think --

22 MEMBER SKILLMAN: Let me suggest that
23 there is a high-energy line break.

24 MR. BURSTEIN: Okay.

25 MEMBER SKILLMAN: And the rarefaction wave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has worked its way through the various compartments.
2 The steam and the humidity are chasing into those
3 compartments, and I have important devices in those
4 compartments.

5 MR. BURSTEIN: Okay.

6 MEMBER SKILLMAN: And so, for the EQ
7 evaluation to be meaningful, then the device's
8 qualification must represent what is the maximum
9 pressure, temperature, radiation --

10 MR. BURSTEIN: Yes.

11 MEMBER SKILLMAN: -- for that compartment.
12 So, what is the matching between the required
13 environmental qualification for the device and the
14 compartment where that device resides?

15 MR. BURSTEIN: Essentially, what we do is
16 require qualification to the most severe environment,
17 which is inside the containment.

18 MEMBER SKILLMAN: For everything?

19 MR. BURSTEIN: For everything inside, not
20 counting outside, not with the steam line breaks in a
21 second here, but everything that is inside the
22 containment has to be qualified to the most severe
23 conditions that are inside the containment --

24 MEMBER SKILLMAN: Okay.

25 MR. BURSTEIN: -- which is the most severe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for any of these compartments and rooms that you are
2 talking about.

3 When we go outside, the only concerns that
4 we have outside are for feedwater and main steam
5 vault, valve vaults, and those are not as severe as
6 the condition inside the containment. And so, we do
7 qualify separately for those.

8 But if we qualify, and we could qualify a
9 piece of equipment for the containment condition, so
10 it could be used anywhere in the plant. Is that what
11 you're asking?

12 MEMBER SKILLMAN: Yes, what I am really
13 wondering is, if in your EQ program which is really
14 good, old, classic 50.49, one could say in this
15 compartment for this accident, these are the pressure,
16 temperature, humidity, radiation environment
17 conditions, and, by golly, here is the qualification
18 paperwork for those devices --

19 MR. BURSTEIN: Yes.

20 MEMBER SKILLMAN: -- that shows that these
21 devices are --

22 MR. BURSTEIN: And that environment will
23 be less than what is in the containment, which is what
24 it was qualified for.

25 MEMBER SKILLMAN: As long as you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 qualified it.

2 MR. BURSTEIN: So, we can use this device
3 anywhere. That is the purpose of it. So, we don't
4 have a big inventory problem of keeping track of where
5 that device can only go.

6 MEMBER SKILLMAN: So, how does the EPR, if
7 you will, configuration control program assure that
8 the device is parked where it is qualified for? This
9 is a configuration management issue.

10 Now I have got a device off in yonder
11 compartment.

12 MR. BURSTEIN: That compartment
13 environment is no worse than what it was qualified
14 for; i.e., what is in the containment.

15 MEMBER SKILLMAN: So, is there a list that
16 shows which device and which compartment and what it
17 is qualified for?

18 MR. BURSTEIN: Yes.

19 MEMBER SKILLMAN: Okay.

20 MR. BURSTEIN: Yes.

21 MEMBER SKILLMAN: I think that is the
22 answer to my question.

23 MR. BURSTEIN: Okay. Yes, it does show
24 where it is located and what conditions it has been
25 qualified for.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay. Thank you.

2 MEMBER STETKAR: The concern, obviously,
3 Nissen, is there are a fairly-large inventory of
4 equipment that are only qualified for a mild
5 environment in a plant.

6 MR. BURSTEIN: Yes.

7 MEMBER STETKAR: How do we have assurance
8 that none of that equipment creeps into a location
9 that is classified as a harsh environment location?

10 MR. BURSTEIN: That basically --

11 MEMBER STETKAR: You attack the problem --

12 MR. BURSTEIN: Yes.

13 MEMBER STETKAR: -- from the good-to-bad
14 correction.

15 MR. BURSTEIN: We would hope that --

16 MEMBER STETKAR: We are concerned --

17 MR. BURSTEIN: We have the program for
18 configuration control.

19 MEMBER STETKAR: We hope.

20 MR. BURSTEIN: It is not something, unless
21 I am -- Russ? -- unless I am speaking incorrectly --

22 MEMBER SKILLMAN: Well, unless you have a
23 COL item that puts the burden on the applicant, then
24 this is very much an EPR design issue.

25 MR. BURSTEIN: Could you help me out here?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GARDNER: I think we are answering
2 that we are identifying within that list component-by-
3 component what the qualification requirement is. At
4 that point, the ITAAC that are in place will confirm
5 that the components go into the location for which
6 they were qualified for. There is an ITAAC for EQ.

7 MR. WELLS: Yes, this is Russ Wells.

8 Yes, there is an ITAAC for both the
9 environmental qualification and seismic qualification.

10 Furthermore, we have information items that are the
11 applicant's responsibility for the maintenance and
12 control program. So, a lot of those components you
13 are talking about would be part of the maintenance
14 program, which is the COL applicant's responsibility.

15 So, that would be as part of both the configuration
16 and maintenance control program.

17 MR. BURSTEIN: But they are all for ITAAC
18 4 installation? I think that is what you are asking.

19 MR. WELLS: Well, the ITAAC is to ensure
20 that the as-built conforms to the as-designed. And
21 again, as far as the configuration control and
22 maintenance to ensure that those components are
23 properly maintained and put in their proper location,
24 that would be under the COL's maintenance program.

25 MEMBER SKILLMAN: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WELLS: Uh-hum.

2 MR. BURSTEIN: Okay. On this slide, we
3 are discussing that we are also qualifying PAM, post-
4 accident monitoring, equipment in accordance with Reg
5 Guide 1.97, that it gets environmentally-qualified.

6 Our Section 3.11.2.2 demonstrates that our
7 approach to qualification of mechanical equipment
8 agrees with the SRP 3.11 and GDC 4. Specifically,
9 mechanical pressure boundary components are qualified
10 by virtue of an end stamp.

11 Components that contain mechanical non-
12 metallic or consumable parts -- we call those C/NM --
13 are qualified in accordance with Appendix QR-B to ASME
14 QME-1. And the qualification is maintained via
15 preventive and surveillance maintenance and periodic
16 testing.

17 The summaries of the qualification
18 activities are documented in what we call an EQDP,
19 which is an Environmental Qualification Data Package,
20 similar to the seismic data package.

21 And again, if a COL applicant has site-
22 specific equipment, that has to be added to the
23 qualification list of Section 3.11-1.

24 CHAIR POWERS: Any other questions to pose
25 to the speakers on generally Section 3?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (No response.)

2 MR. GARDNER: That completes our
3 presentation.

4 CHAIR POWERS: Seeing none, I think I will
5 recess for a lunch break, and we will resume at one
6 o'clock.

7 (Whereupon, the above-entitled matter went
8 off the record for lunch at 12:02 p.m. and resumed at
9 1:00 p.m.)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1:00 p.m.

CHAIR POWERS: It is time to come back into session.

It's your show.

MR. MIERNICKI: Okay. This afternoon we have the staff's presentation on Chapter 3, Design of Structures, Components, Equipment and Systems.

My name is Mike Miernicki. I am the Chapter PM for Chapter 3. I am going to provide a brief overview for the side packages that you have of the Chapter, some metrics and stuff like that about the review. And then, we are going to move on to several of the topical areas that the staff selected that might be of interest to the ACRS.

So, on slide 2 there, you can see the staff review team.

MEMBER STETKAR: By the way, upfront, be real careful with your paper, that you don't hit those things. We don't care, but she will kill you.

(Laughter.)

CHAIR POWERS: She's got tae kwon do skills.

MEMBER STETKAR: It just explodes in her ears.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MIERNICKI: Okay, we don't want to do
2 that.

3 Okay. On slide 2, we have got the staff
4 review team. Chapter 3 is a large chapter.

5 CHAIR POWERS: No kidding.

6 (Laughter.)

7 MR. MIERNICKI: Lots of pages, a long SER
8 was written by the staff. So, we had quite a big
9 review team that represents a number of branches,
10 Engineering Mechanics, Structural Engineering, Balance
11 of Plant, Component Integrity, Rad Protection,
12 Accident Consequences, Geoscience and Geotech
13 Engineering, and Instrument Controls and Electrical
14 Engineering. So, you can see on the next several
15 slides here the names of all key reviewers.

16 And then, moving along, the overview slide
17 there, slide 6, you can see a table of the various
18 sections in the FSAR and SRP and the number of
19 questions asked in each section. So, there is a grand
20 total of 828 questions asked. The last column there,
21 you see the number of open items that were listed in
22 the SER. So, we have 68 open items at this point.

23 Chapter 3, being a large chapter, we
24 issued it in a couple of groups, going back to 2010.
25 So, we have been able to resolve a number of questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 since then, and since the SER, actually, for the last
2 two groups, staff has been able to resolve a number of
3 questions with the applicant.

4 So, starting on page 7, you see brief
5 descriptions of the open items. The next several
6 slides list all those. As I said, there is a grand
7 total of 68, and 26 of which have been resolved to the
8 satisfaction of the staff reviewers.

9 MEMBER STETKAR: Mike?

10 MR. MIERNICKI: Yes?

11 MEMBER STETKAR: This is an awful lot of
12 material to digest in real-time. So, you are going to
13 have to help me at least understand where and when I
14 should ask questions. I see that you are planning to
15 have more detailed presentations on parts of 3.6, 3.7,
16 3.8 I guess.

17 I had a couple of questions. And the
18 first open item on page 7 --

19 MR. TESFAYE: Mr. Stetkar, may I interrupt
20 there?

21 MEMBER STETKAR: Yes.

22 MR. TESFAYE: You know, that list that we
23 gave you is just for documentation purpose. Any open
24 items that you would like to discuss, you can defer
25 it. When the technical staff gets here to address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that section, that would be appropriate.

2 MEMBER STETKAR: Okay.

3 CHAIR POWERS: The trouble is we have no
4 idea when the technical staff will be here. I think
5 what we will do is ask the question. You may defer
6 the answer until later. Otherwise, we don't know how
7 to do our timing, unless you put up a card that says,
8 you may ask questions about 3.5 at this time.
9 Otherwise, we have no idea when to ask questions.

10 MR. MIERNICKI: I invited several of the
11 key staff members, then, Dr. Powers, as part of the
12 discussion to be here right after I went through this
13 list of open items. That is the first opportunity we
14 would. Some of the reviewers will be here and, if
15 not, we will have to defer the question, try to pick
16 it up at the end of the day.

17 MEMBER STETKAR: Okay. That's fine.

18 MR. MIERNICKI: That will be a game plan.

19 MEMBER STETKAR: I get the message. I
20 will wait.

21 CHAIR POWERS: I won't.

22 (Laughter.)

23 On this first item, one of the questions I
24 posed to the applicant when he presented this, because
25 we have some experience, particularly at South Texas

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where they showed us safety-significant and risk-
2 significant. And there were some items that fell in
3 the not safety-significant, but they were risk-
4 significant.

5 Are there such items in connection with
6 the EPR and, if so, shouldn't we do something about
7 that?

8 MR. MIERNICKI: Well, okay, I don't know
9 if we have anyone who wants to step up from the Tech
10 Branch on it.

11 I guess for STP that was --

12 MR. TESFAYE: What is the question, Dr.
13 Powers? Let me try to understand this. Are you
14 saying, is there a distinction between safety-
15 significant and risk-significant, and how is it
16 addressed in the EPR?

17 CHAIR POWERS: What my concern is, when
18 South Texas did their analyses, they came back and
19 said, gee, there are items that do not get classified
20 as safety-significant items, but they turn out to be
21 risk-significant. And that's interesting because they
22 ordinarily are not subjected to the enhanced QA
23 requirements, and they probably don't even get the
24 kind of surveillance that you might.

25 I am asking, are there such items in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 EPR that are risk-significant, but not classified as
2 safety-significant? And if there are, should we do
3 something about them?

4 MR. TESFAYE: I understand the question,
5 and I don't have the answer, and I will get back to
6 you.

7 CHAIR POWERS: Okay. Yes, I mean, that is
8 a fair answer.

9 MEMBER SKILLMAN: I would like to pile
10 onto Dr. Powers' question. It seems to me that at
11 this early stage -- and it is, before one of these
12 plants has been built -- resolving the terminology
13 will prevent future years of heartburn as the
14 licensees attempt to describe what is safety-related
15 and is important to safe, what is risk-significant,
16 what is not.

17 Our experience over the past 40 years has
18 been that these terms begin to become knotted together
19 or become shades of gray with each other. Words
20 matter in this business. And it seems like there
21 ought to be a lexicon early on that defines these
22 terms, so that the future licensees know precisely
23 what the terms mean.

24 We would have benefitted immensely years
25 ago if we had resolved this terminology. And it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not just the licensee. It is the NRC. It is
2 everybody who is involved. There seem to be probably
3 a half a dozen or nine or ten of these terms that, if
4 codified, may make life simpler for everybody who is
5 involved in the design, licensing, and operation of
6 these systems.

7 So, I would like to offer, that ought to
8 be something that is seriously considered, a lexicon
9 that really clarifies what these terms mean and what
10 they don't mean.

11 MEMBER STETKAR: Getachew, let me try a
12 little --

13 CHAIR POWERS: Well, important to safety
14 is very well-defined. The items on risk-significant,
15 I mean, I don't think that appears anywhere in Reg
16 Guides or anything else. But important to safety and
17 safety-significant are well-defined terms.

18 So, it is the risk terms that you are
19 asking about.

20 MEMBER SKILLMAN: I still think there are
21 shades of gray in there, Dana.

22 CHAIR POWERS: Undoubtedly.

23 MEMBER STETKAR: As a card-carrying PRA
24 guy, let me shed my insights on this. Every design
25 certification is required to identify a list of SSCs,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on safety-related SSCs, that are, quote/unquote,
2 important to safety as a result of the risk
3 assessment. You use a PRA. You develop measures,
4 numeric measures, of the equipment that, if it is
5 above the line, it is important to safety. If it is
6 below the line, it isn't.

7 Now you can argue about where should that
8 line, but there is a line. In particular, for the
9 EPR, that line is drawn on any component whose
10 Fussell-Vesely importance is greater 0.005 or risk
11 achievement worth is greater than 2.0. So, that is a
12 very, very -- as I said, you can argue about how those
13 things are defined, but anything that is above those
14 lines are on this D-RAP list. That is why I keep
15 coming back to D-RAP list as opposed to some
16 combination of words in quotes, because that is at
17 least something that I can point to, and I understand
18 how it is populated.

19 So, it has actually been defined. I don't
20 rely on those words. So, in effect, what we are
21 asking is, if you go back to slide 7, the first open
22 item there is requests clarification on how systems
23 safety-related and important to safety -- I don't care
24 about stuff in quotes. Is your question about how
25 equipment on the D-RAP list is going to be treated?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For the life of me, reading through the
2 pages of stuff in the SER regarding this particular
3 topic, I couldn't understand what you were asking for.

4 So, first, I am not sure what that open item means.

5 MR. MIERNICKI: My recollection is that
6 this asked about coming to terms with the terms that
7 you said, correct, and finalizing a list. That is my
8 recollection on this question, but we will have to get
9 back to you on that.

10 MEMBER STETKAR: Let me add my additional
11 spin on that. Everything that I read about this open
12 item focuses on seismic, seismic, seismic. If I read
13 other parts of the SER, and I start to think about
14 winds and floods and pipe breaks, and everything else
15 that can occur that can affect stuff in the plant --
16 and I will use the generic term stuff to avoid any of
17 these --

18 CHAIR POWERS: Yes, the highly-precise
19 technical term, stuff.

20 MEMBER STETKAR: It invariably focuses
21 only on safety-related. I can't find any questions
22 from the staff similar to seismic regarding the
23 apparent confusion between safety-related, important
24 to safety, risk-significant, or any of those other
25 ill-defined terms.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, I am curious about why you are
2 concerned about this nebulous distinction only
3 regarding seismic classification and not for other
4 types of hazards that exist in the plant.

5 MR. TESHAYE: That is a fair question. I
6 am sure we will get back to you. And it is a
7 relatively-new --

8 MEMBER STETKAR: But, first, I would like
9 to understand what the whole notion of that open item
10 is.

11 MR. TESHAYE: A fair question. We will
12 get back to you.

13 MR. MIERNICKI: Any other questions about
14 any of the items at this point on the open items list?
15 Of course, we can come back and ask them at the end,
16 if you have any questions.

17 CHAIR POWERS: We will.

18 MR. MIERNICKI: Okay. What we are going
19 to do next is we are going to go a little bit out of
20 order, based upon tech reviewer availabilities and
21 their consultant availabilities. So, we are going to
22 jump to one of the technical topics of interest is LBB
23 in 3.6.3, and that starts on page --

24 MR. TESHAYE: Thirty-two.

25 MR. MIERNICKI: -- 32. We will move to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that slide.

2 I am going to turn the presentation over
3 to Eric Reichelt, who is going to give an overview and
4 introduce his contractor skill through this section of
5 the presentation.

6 MR. REICHELT: Good afternoon. My name is
7 Eric Reichelt, and I'm a Senior Materials Engineer in
8 the Office of New Reactors, Division of Engineering,
9 the Component Integrity Branch. I am the technical
10 reviewer for Sections 3.6, leak-before-break design
11 for the EPR DCD.

12 At this time, I would like to give you a
13 brief overview and introduction on work that was
14 performed for this section, since it has been quite
15 some time since we last addressed the ASCR on LBB.

16 The use of LBB applications has been
17 utilized in previous design certification
18 applications, including the System 80 Plus, AP600, and
19 the AP1000.

20 It should be pointed out that LBB is part
21 of a piping design acceptance criteria, or DAC, and is
22 based on preliminary piping design and the use of
23 bounding LBB parameters.

24 The leak-before-break approach for new
25 reactors to use bounding limits established during the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design certification phase and to verify the final as-
2 built design during the construction used in ITAAC was
3 approved by the Commission in its SRM for SECY-93-087,
4 and which will be discussed by our contractor in more
5 detail.

6 The technical review was performed by
7 Engineering Mechanics Corporation of Columbus,
8 otherwise known to us as Emc².

9 At this time, I would like to turn the
10 presentation over to Dr. Prabhat Krishnaswamy and Dr.
11 Do-Jun Shim to discuss the technical review and
12 conclusions for Section 3.6.3. In addition, in the
13 bullpen, we have Mr. Keith Wichman of Emc² and Mr.
14 David Terao, a Branch Chief of the Component Integrity
15 Branch, for additional technical support.

16 DR. KRISHNASWAMY: Good afternoon,
17 everybody. My name is Prabhat Krishnaswamy. I am
18 with Engineering Mechanics Corporation of Columbus.
19 We are a contractor to the NRC. And I am here along
20 with my colleagues, Dr. Do-Jun Shim and Mr. Keith
21 Wichman.

22 The outline of my presentation in the next
23 few slides is to review the leak-before-break or the
24 LBB methodology, the regulatory approach, followed by
25 the two main things that we did, which is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 confirmatory analysis of the leak prediction procedure
2 and the confirmatory analysis of the flaw stability
3 procedure in the ALL diagram. Those are the two parts
4 of the LBB methodology, and we did a confirmatory
5 analysis of each one of those. That is the core of
6 our work. And then, of course, we will end with some
7 conclusions on where we are in the LBB analysis.

8 The regulatory requirements and acceptance
9 criteria for LBB essentially states that the basis for
10 excluding dynamic effects associated with postulated
11 pipe ruptures in nuclear power plants, that is in 10
12 CFR Part 50, Appendix A, GDC 4.

13 As part of that, the SRP 363 calls for
14 specific safety margins in performing the LBB
15 analysis, and it involves a factor of 10 on the leak
16 rate and a factor of two safety margins on the crack
17 size.

18 Go ahead.

19 The EPR LBB methodology essentially
20 involved developing the ALL diagrams that are used as
21 a bounding criteria. The confirmatory work involved,
22 there are three parts to this. One is the
23 degradation, the mechanisms involving water hammer,
24 corrosion, creep, fatigue, et cetera. We have
25 confirmed that they are extremely low causes of pipe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 rupture.

2 The core of the analysis involves
3 deterministic fracture mechanics evaluation, and I
4 will show those in a couple of slides.

5 CHAIR POWERS: When you say extremely low,
6 you are speaking of the probability?

7 DR. KRISHNASWAMY: The deterministic
8 analysis, yes, extremely low probability of rupture,
9 but the analysis is deterministic in nature.

10 CHAIR POWERS: Uh-hum. Yes, I understand.

11 DR. KRISHNASWAMY: And then, the last
12 bullet there talks about the leak detection system
13 that feeds into the LBB analysis that has to be
14 reliable and redundant. So, you can estimate the flaw
15 size and, then, the flaw stability.

16 CHAIR POWERS: When you do your
17 deterministic fracture mechanic evaluations, you use
18 something like APPRAISE or some computer code?

19 DR. KRISHNASWAMY: Yes, there are two
20 codes involved, and I will go through that in a couple
21 of slides.

22 CHAIR POWERS: Do they presume square flaw
23 sizes, you know, rectangular flaw sizes, or things
24 like that?

25 DR. KRISHNASWAMY: Yes, we can define the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 flaw sizes.

2 CHAIR POWERS: So, nothing special? I
3 mean, rectangular flaw sizes are thought to be fairly
4 conservative.

5 DR. KRISHNASWAMY: This is the first of
6 the confirmatory analyses for the leak rate prediction
7 procedure. What you see is a graph of the moment
8 versus crack length for each specific case of the
9 surge line nozzle width at a 5-gallons-per-minute
10 leakage rate. And for a given leakage rate, you can
11 have a combination of crack length and moment that
12 results in that.

13 What we did was to confirm what AREVA's
14 calculation was using bare code, proprietary code,
15 KRAKFLO, with the NRC-developed code SQUIRT. As you
16 can tell, we confirmed the moment with this crack
17 length curve very correctly and duplicated it.

18 CHAIR POWERS: This is pretty much
19 contained, completely independent --

20 DR. KRISHNASWAMY: Yes.

21 CHAIR POWERS: -- confirmatory analysis?

22 DR. KRISHNASWAMY: Yes, independent
23 confirmatory.

24 CHAIR POWERS: Very good.

25 DR. KRISHNASWAMY: And this is also for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the critical location that was identified in AREVA's
2 presentation.

3 CHAIR POWERS: The critical location you
4 just took, right?

5 DR. KRISHNASWAMY: Yes.

6 CHAIR POWERS: I mean, you are just doing
7 the analysis?

8 DR. KRISHNASWAMY: Yes.

9 CHAIR POWERS: But that is very nice.

10 DR. KRISHNASWAMY: Now this is the second
11 part of the confirmatory analysis involving the ALL,
12 what we call the Allowable Load Limit diagram. And it
13 shows the curve, the maximum moment versus minimum
14 moment for the same location that we showed the leak
15 rate curve.

16 What is shown are the applied moment, the
17 maximum for the X-axis is the operating moment. For
18 those values, the upper curve shows the maximum load-
19 carrying moment for various values of the actual load.

20 As you can tell, our calculations match those of
21 AREVA and presented by AREVA very well. And that is
22 the bounding curve that is shown, the top curve. So,
23 the design point of the requirements has to be under
24 that. And we have confirmed this analysis for the
25 surge line case at the pressurizer surge nozzle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The overall conclusion is that the LBB
2 procedure -- and we have done that for a number of
3 cases -- and the overall conclusion is that the
4 acceptance criteria are satisfied, and that dynamic
5 effects of pipe rupture may be eliminated from design.

6 There is one open item here involving a
7 confirmatory analysis for one specific case where we
8 are just going through the data that is required to
9 complete it. And apart from that, we are done with
10 this analysis.

11 CHAIR POWERS: Very nice. I mean, leak-
12 before-break is a critical item. I am glad to see the
13 staff is doing completely independent confirmatory
14 analysis, at least on some aspects of it, where you
15 can. I think that is an advertising point, that we
16 need to make sure that the Commission knows you are
17 doing that, because, I mean, this is a critical issue
18 that gets a lot of the public attention. To have that
19 kind of a technical understanding speaks well for what
20 you are doing.

21 DR. KRISHNASWAMY: Thank you.

22 MR. MIERNICKI: Okay. Any other questions
23 on this area, then?

24 (No response.)

25 Well, then, thank you very much, everyone.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We will have the next group of people come
2 up. And we are going to move back to 3.6.2 and back
3 to slide 21.

4 CHAIR POWERS: It seems to be a
5 characteristic of Chapter 3 that one cannot go
6 linearly through this chapter.

7 (Laughter.)

8 MR. MIERNICKI: Okay. I am going to
9 introduce Renee Li, who is from the Engineering
10 Mechanics Branch.

11 And, Renee, you can introduce your
12 supporting cast here.

13 DR. LI: Okay. As Mike mentioned, I am
14 Renee Li from the Engineering Mechanics Branch. I am
15 the Senior Technical Reviewer responsible for Section
16 3.6.2 review.

17 Next to me are Dr. Steve Hambric and,
18 also, Dr. Jules Lindau from Applied Research Lab, Penn
19 State.

20 With technical assistance from ARL, the
21 staff reviews EPR FSAR Section 3.6.2. The topic is
22 determination of rupture locations and their
23 associated dynamic effects.

24 Today, Dr. Hambric and I, we will jointly
25 today this topic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 During this presentation, we will discuss
2 the principal regulations and items of interest,
3 including IEI summary for Section 3.6.2 review.

4 This slide shows our applicable
5 regulations and the review guidance for Section 3.6.2
6 review. The application regulation is 10 CFR Part 50,
7 Appendix A, General Design Criteria 4, which requires
8 structures, systems, and the components important to
9 safety to be designed to accommodate the environmental
10 and dynamic effects resulting from postulating pipe
11 failures.

12 To meet the GDC 4 requirements, SRP
13 Section 3.6.2, including Branch Technical Position 3-4
14 and SRP Section 3.6.1, including Branch Technical
15 Position 3-3, provides staff's guidelines for
16 postulating pipe failures and the evaluation of their
17 associated dynamic and environmental effects.

18 As you may know, ANSI 58.2 standard
19 entitled, Design Basis for Protection of Lightwater
20 Nuclear Power Plants Against the Effects of Postulated
21 Pipe Rupture is commonly used by the nuclear industry
22 for evaluating the dynamic effects of postulated pipe
23 rupture.

24 However, it has some deficiencies and
25 omissions which we will discuss later. Because of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this deficiency, other technical journal articles and
2 reports were used during the resolution of some of the
3 staff's RAIs. A list of these articles and the
4 reports are included in the backup slide 68 of this
5 staff presentation package.

6 The other related regulation is 10 CFR
7 50.47(b)(1), which related to ITAAC. That is the
8 inspections, tests, analyses, and the acceptance
9 criteria.

10 Next slide, please.

11 There are two major areas of review in
12 Section 3.6.2. First, it relates to criteria used to
13 define pipe break and crack locations and the
14 configurations. The staff's review of the criteria
15 described in EPR FSAR determined that they are
16 consistent with the staff guideline as described in
17 SRPs and their associated Branch Technical Positions
18 and are, therefore, acceptable. This area of review
19 will not be discussed today.

20 The second review area relates to the
21 evaluation of jet impingement and pipe whip effects.
22 I would like to note that the original EPR FSAR makes
23 a reference to the use of ANS 58.2 standard for the
24 evaluation of jet impingement load on the nearby
25 safety-related SSC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 As I mentioned earlier, the ANS 58.2
2 standard is commonly used by the nuclear industry for
3 the jet evaluation and, to date, has been accepted by
4 staff. However, during the review of GSI-191, which
5 addresses the containment sump blockage by insulation
6 in an event of nearby pipe ruptures, Drs. Wallis and
7 Ransom from ACRS identified some potential non-
8 conservatism in this standard, although the focus of
9 the ACRS was on debris generation and some blockage.
10 However, their comments directly impact the assessment
11 of jet impingement loading from postulated pipe breaks
12 on neighboring SSCs.

13 Next slide.

14 MEMBER STETKAR: Renee?

15 DR. LI: Yes?

16 MEMBER STETKAR: Before you leave this,
17 this is an area that is far, far, far beyond my area
18 of expertise. So, excuse the stupidity of my
19 question. And the reason I ask it is you said you are
20 not going to discuss the first bullet on this slide.

21 The applicant has evaluated leak-before-
22 break for main steam line reactor coolant system and
23 surge line.

24 DR. LI: Right.

25 MEMBER STETKAR: Why not the main

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feedwater lines?

2 DR. LI: Okay. Because the SRP 363, they
3 have a threshold of what type of systems can use the
4 leak-before-break criteria.

5 MEMBER STETKAR: Yes, you know, I am not
6 familiar with the SRP. I am more interested in terms
7 of an energy release and the possibility of getting
8 jet impingements from breaks or leaks in the main
9 feedwater line.

10 DR. LI: The main feedwater line, since
11 the leak-before-break is not applicable; therefore,
12 they have to postulate break based on --

13 MEMBER STETKAR: And they do that?

14 DR. LI: Yes.

15 MEMBER STETKAR: Okay.

16 DR. LI: They do, yes.

17 MEMBER STETKAR: Okay. Thanks. Thanks.

18 DR. LI: Okay. And where am I?

19 MEMBER STETKAR: I'm sorry. It's the way
20 we are.

21 (Laughter.)

22 DR. LI: Okay. This slide shows a brief
23 summary of the inaccuracies and omissions of the
24 standard. Later in the presentation, Dr. Hambric will
25 discuss them in more detail and just go through it on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a high level.

2 First, the standard ignores the effects of
3 blast wave effects. Also, the standard has
4 deficiencies in jet expansion modeling and jet
5 pressure distribution within the jet plume.

6 The standard treats all jets as having
7 uniform plume expansion and assumes a simplified
8 special pressure distribution within the jet plume.
9 In addition, the standard, it ignored the jet dynamic
10 loading and structural dynamic response, including
11 potential feedback amplification of blowdown force and
12 jet resonance effects.

13 Because of these deficiencies and
14 omissions of the ANSI 58.2 standard, during the EPR
15 review the staff issued RAIs 03.06.02-6 through
16 03.06.02-13 and their associated supplement to RAIs,
17 requesting the applicant to address this potential
18 non-conservatism.

19 Next slide.

20 Before Dr. Hambric presents and discusses
21 the details of our review of these issues, I would
22 like to briefly summarize the current status of the
23 RAIs.

24 For the jet dynamic effects, the staff
25 found the applicant's jet impingement assessments are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conservative. However, their final documentation is
2 pending, and this issue remains a confirmatory item.

3 For the blast wave, the applicant is
4 examining their current plant design to determine
5 regions where blast wave may be important, along with
6 the potential blast wave assessment. Therefore, this
7 issue remains an open item.

8 With that, Dr. Hambric will present and
9 discuss the details of our review on these issues.

10 Thank you.

11 DR. HAMBRIC: Good afternoon.

12 As Renee said, Dr. Lindau and I are both
13 from the Applied Research Lab at Penn State. We do a
14 lot of hydrodynamic, hydroacoustic work. Jay's
15 background is in computational flow dynamics as well
16 as flow mechanics. I am more what happens when the
17 fluid hits the structure and how the structure
18 responds to that, and whether it can withstand those
19 sorts of loads.

20 Now, as Renee pointed out, past procedures
21 that the industry has used to assess high-energy line
22 breaks, HELBs, has been lacking in a couple of key
23 areas. One key area is just completely ignoring the
24 fact that you get an explosion and a blast wave that
25 propagates into an enclosed space and strikes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 structures, potentially causing them to fail.

2 CHAIR POWERS: I find the nomenclature
3 very remarkable. It is not in the nuclear trial
4 reviews. You always get a shock wave. You really
5 don't get an explosion. It is just a shock wave,
6 right? Is my physical understanding correct?

7 DR. HAMBRIC: It is a shock wave, but I am
8 dramaticizing the shock wave to make people understand
9 it. But it is a shock wave that propagates through
10 the internal region and strikes structures in a
11 nonlinear way and causes them to vibrate
12 substantially.

13 DR. LINDAU: It is similar to an explosive
14 wave in almost every physical aspect other than --

15 CHAIR POWERS: Well, a shock wave is a
16 shock wave, but --

17 DR. LINDAU: But a moving shock wave is
18 referred to as a blast wave commonly.

19 CHAIR POWERS: I mean, I don't know. I
20 can certainly understand how a shock wave would form
21 in this circumstance. I mean, it makes sense, if you
22 are blowing down steam, just because the velocity of
23 sound is a function of temperature. But it seems like
24 it would be a fairly broad shock wave. I mean, I
25 don't think it would be a high-brisance kind of shock

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wave, would it?

2 DR. LINDAU: A high what?

3 CHAIR POWERS: Brisance.

4 DR. LINDAU: High-risk?

5 CHAIR POWERS: Brisance. When we shoot
6 off explosives, we get really sharp shocks, and then
7 we get sometimes long, broad shocks. But shocks are
8 shocks, but the time it has on the structure changes.

9 In my experience, I have, quite frankly, never broken
10 a steam pipe line myself. You are about to convince
11 me to go do it, just to find out what it looks like.

12 (Laughter.)

13 But I would think it would be kind of a
14 broad shock wave. Now that can be very misleading
15 because broad ones are ones that can do a lot of
16 damage because they stay a long time on the structural
17 surface. So, the things that are loose, they are
18 going to get blown off really badly; whereas, high-
19 brisance might not.

20 But it just seems like strange
21 nomenclature. I would just call it a shock wave. But
22 go ahead.

23 DR. HAMBRIC: Sure. Okay. Along with
24 that initial shock wave, which can load structures, we
25 also get jets. And two of the issues that the ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 had concerns about was how the ANS 58.2 assumed the
2 jets' shapes and pressure distributions behaved. And
3 the applicants addressed that.

4 But another area that we were mostly
5 concerned about was the fact that jets, up to this
6 point, had been considered by the industry as just
7 sudden impulse loads on structures with a static load
8 applied over some small instant in time.

9 And the oscillatory loads in a turbulent,
10 high-amplitude jet were completely ignored. So, we
11 have asked the industry to address those issues, and
12 they do now. You will find at the end of the slide
13 package some more backup material on this issue, if
14 you would like to get into that.

15 What I will now do is talk about how AREVA
16 has been addressing these two topics, starting with
17 the blast wave effects. This is still an open item.
18 We are working with them to ensure that they have a
19 design procedure that is conservative that addresses
20 some of the topics you just mentioned, Mr. Powers.

21 Before they do, are examining their
22 current plant layout to bound the problem. They are
23 going to determine key regions that they really have
24 to assess for blast wave effects. Based on their
25 design, it looks like they only have to worry about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 steam line ruptures. After they come through the
2 kinds of analyses they will be required to do for an
3 EPR, they are going to present to us software which
4 will look at the time-varying loads induced by the
5 blast waves and the target SSCs. We have asked them
6 to make sure that their procedures are validated using
7 existing literature and are converged, that they have
8 got sufficient mesh resolution and time
9 discretization, and, most importantly, that they are
10 handling reflections from indoor walls and ceilings
11 and floors in their analysis.

12 CHAIR POWERS: I mean, that can be a real
13 difficult analysis.

14 DR. HAMBRIC: I think it would be
15 extremely difficult to get it exactly correct. It may
16 not be extremely difficult to get conservatively
17 bounding. So, that is the approach they have been
18 taking in the jet problem, which I will address in a
19 moment. But I think they are going to try to come up
20 with a conservative loading methodology as opposed to
21 an accurate loading methodology, which is fine with
22 us. As long as they are conservative, we are happy.

23 MEMBER BROWN: How do you know it is
24 conservative, not accurate? Is that a dumb question?

25 DR. HAMBRIC: I think that in the case of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis of these blasts, it will be conservative in
2 that they will provide a conservative estimate of the
3 initial energy behind the blast.

4 CHAIR POWERS: Yes, you just don't put any
5 dispersion in the calculation and just do a perfect
6 reflection.

7 DR. HAMBRIC: That's right. Well, it will
8 be an oiler calculation --

9 CHAIR POWERS: Yes, yes.

10 DR. HAMBRIC: -- using ideal gas
11 assumptions. And that will be a pretty conservative,
12 that will be a conservative estimate of the strengths
13 of reflective waves.

14 CHAIR POWERS: I would just suspect that
15 these kinds of shock waves have a high dispersive
16 content, and when you do these things, it is really a
17 geometry calculation and you take perfect reflection
18 and things like that. And you are just looking for
19 where you get reinforcement on the structure. I mean,
20 you don't care about reinforcement in the middle of
21 space, but you are looking for reinforcement on a
22 structure.

23 We did it once for containment for
24 hydrogen shock waves, and it drives you nuts, to be
25 honest with you. But I would think these waves would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be very dispersive.

2 DR. HAMBRIC: Well, that is part of why
3 they are looking at their layout. If they get a
4 certain distance away, they can argue it is not the
5 problem.

6 CHAIR POWERS: Yes, and a shock coming on
7 a cylindrical body is going to be disperse like crazy.

8 DR. HAMBRIC: Right, but if it strikes a
9 corner --

10 CHAIR POWERS: Yes, straight-on, it is
11 going to come right back at you. The worst ones are
12 the ones that make the two corner shots, you know, off
13 of corner, up off another one, and then come back into
14 the main one, and you get a reinforcement there.
15 Those are the ones that drive you nuts.

16 DR. HAMBRIC: So, we are still waiting for
17 the response. I suspect it will be a combination of
18 design to avoid the kinds of problems that you just
19 mentioned as well as a conservative software route
20 approach.

21 Now AREVA is further along in resolving
22 the jet impingement portion. In fact, they have given
23 us a Draft Technical Report that we are satisfied
24 with, but they have not issued a final version yet.
25 They have also included a summary of their procedures

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in the FSAR. But, again, we just have a draft. So,
2 pending finalization of the report and the FSAR, the
3 jet impingement resolution remains a confirmatory
4 item. But barring some sudden change in the approach
5 at AREVA, what I am about to tell you about next is,
6 in our opinion, conservative and acceptable.

7 CHAIR POWERS: I have one question that
8 has nothing to do with on the EPR, but just
9 philosophically here. When you think about these
10 jets, you think about them in terms of fluid. Do you
11 ever think about them in terms of entrained solid
12 particles?

13 DR. HAMBRIC: Like for two-phase flow?

14 CHAIR POWERS: Well, it would be
15 definitely a two-phase flow at that point, but you
16 don't ordinarily think --

17 DR. HAMBRIC: Like projectiles?

18 CHAIR POWERS: Yes, yes,

19 DR. HAMBRIC: For instance, the blast
20 itself.

21 CHAIR POWERS: Yes, I was thinking -- I
22 have not dreamed up where the particles are coming
23 from yet, but, presumably, with a little imagination,
24 I could. I am just wondering if anybody has ever
25 thought about that sort of thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And in advance, now that is fine, and
2 please do not write that down as an action item to
3 think about. I am just speculating here out of
4 curiosity.

5 The other question is, we know that these
6 jets tear up fibrous insulation like crazy, and we
7 have forced current plans to take out a lot of fibrous
8 insulation and they have replaced it with reflective
9 metal insulation. Do we know what the jets do to
10 reflective metal insulation?

11 DR. HAMBRIC: We are not reviewing that
12 here.

13 CHAIR POWERS: Okay.

14 DR. HAMBRIC: But the GSI-191 folks I
15 think did that.

16 CHAIR POWERS: I guess what I am asking is
17 where the state-of-the-art stands on that. Because
18 the last time I left, they had done an experiment that
19 said they tore up some RMI, and then I never heard
20 back. Are we predictive on that, tearing up the RMI
21 from these things?

22 DR. HAMBRIC: We are not part of the group
23 doing that.

24 CHAIR POWERS: Oh, okay. So, you can't --

25 DR. HAMBRIC: We can't comment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: That's fine. That's fine.
2 Just curiosity on my part.

3 DR. HAMBRIC: Like you, I knew they were
4 doing that kind of study.

5 CHAIR POWERS: Yes.

6 MEMBER SKILLMAN: I would like to ask how
7 in your jet dynamic loading, how the timing,
8 particularly to the end of the transient, is addressed
9 and, also, how the reaction on the broken component is
10 being addressed. So, it is a dynamic question. How
11 long does it last based on what? And how is the
12 reaction on the component that is actually the origin
13 of the jet being handled?

14 DR. HAMBRIC: Right. A reaction force is
15 applied to the pipe. And I believe Mano will be
16 reviewing that.

17 DR. LI: As far as the pipe that
18 postulates rupture, they would be, could be restrained
19 to stop the motion within the pipe.

20 CHAIR POWERS: Okay.

21 DR. LI: Okay. And, of course, when a
22 pipe fails, they don't take credit of that pipe. So,
23 is that your question, how they --

24 MEMBER SKILLMAN: Well, my question is two
25 pieces. How is the reaction load accommodated? You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have just communicated it is through restraints or
2 pipe restraints or supports.

3 DR. LI: Right.

4 MEMBER SKILLMAN: What is the physical
5 phenomenon that you use to calculate the timing of the
6 jet force? Obviously, it is going to continue as long
7 as there is a driving head to drive the two-phase or
8 one-phase fluid to the point where the delta P no
9 longer drives the jet. So, what do you use to
10 calculate the dynamic time, the time length?

11 DR. HAMBRIC: Right. That is actually
12 coming up on the next slide. We will walk through
13 their procedure.

14 MEMBER SKILLMAN: Oh, okay.

15 DR. HAMBRIC: Okay. So, next.

16 Over the next couple of slides, we will
17 summarize for you what AREVA is doing. We believe it
18 is in the report. They provided a detailed assessment
19 procedure. It is conservative. They look at the
20 dynamic nature of the forcing functions, their impact
21 on SSCs, as well as barriers and shields.

22 So, for a given break -- and I think this
23 is the first part of your question -- they need to
24 compute the source flow parameters, temperature, and
25 pressure, size of the break. And they do that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 throughout the blowdown process, using thermohydraulic
2 codes. They haven't committed to one in particular
3 yet, but they have cited RELAP and CRAFT2. It is our
4 understanding those are acceptable codes for assessing
5 the source-terms.

6 Now, for the initial impulse, we did not
7 put that in the slides here. But if AREVA can chime
8 in -- I forget how long they assume it takes for the
9 pressure to go from zero to source pressure, like a
10 millisecond perhaps.

11 DR. LI: Yes, one millisecond.

12 MR. McGAUGHY: Typically, it is used as a
13 millisecond. But, typically, when we are loading a
14 structure, we will rise it up even more quickly than
15 that, just so we can make sure that we get the dynamic
16 portion of that rise --

17 CHAIR POWERS: Mr. Conservative here.

18 (Laughter.)

19 MR. McGAUGHY: Exactly.

20 MEMBER STETKAR: Just make sure they got
21 your name.

22 MR. McGAUGHY: Oh, I'm sorry, this is
23 Chris McGaughy.

24 DR. HAMBRIC: Okay. So, a millisecond is
25 typical, and they go even faster for conservatism.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Thank you.

2 DR. HAMBRIC: And that will give you the
3 structure's, once you apply that load to a structure,
4 you will get the impulse response, but, also, the
5 static response. We are more interested in the
6 dynamic terms because they are the limiting terms, as
7 I will talk to you about in a moment.

8 They determine jet shapes using standard
9 thermodynamic analyses, not ANS 58.2.

10 CHAIR POWERS: So, why do you use a
11 thermodynamic analysis? For a real jet, what am I
12 doing? What error do I make in using a thermodynamic
13 analysis instead of a full-blown dynamic, kinetic
14 analysis? I tend to make my jet rounder?

15 DR. HAMBRIC: Compared to like a full-up
16 computational fluid dynamics assessment?

17 CHAIR POWERS: Yes.

18 DR. HAMBRIC: I'm not sure myself.

19 DR. LINDAU: I think what this refers to
20 is determining what the thermodynamic state of the jet
21 is. And then, based upon that, go into certain
22 spreading rates and other things that are determined
23 in the literature.

24 So, it is not that there they are
25 replacing thermodynamics for fluid mechanics. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are just using thermodynamics to determine the state
2 of the jet as it is issuing from the break.

3 CHAIR POWERS: Yes.

4 DR. LINDAU: And then, depending upon the
5 state, there are some rules that are conservative
6 about spreading rates that they will go on.

7 CHAIR POWERS: I would think it is just
8 making it rounder, but I don't know. If I did it for
9 real, it would tend to be a narrower, more ellipsoidal
10 jet, and I make it rounder when I go to thermodynamic
11 bounding analysis, I would just guess. But I honestly
12 don't know.

13 DR. LINDAU: Chris, you can jump in.

14 DR. HAMBRIC: Yes, the main benefit is
15 that, if you look at ANS 58.2, that just assumes a set
16 spreading rate, no matter what the source pressure
17 ratios were. It was clearly inaccurate. So, here
18 they are at least bringing the physics of the source
19 fluid and the receiver fluid into play when they
20 determine the spreading rate.

21 MR. McGAUGHY: Yes, this is Chris McGaughy
22 again.

23 And really, for using a thermodynamic
24 analysis, really, we were just trying to keep a
25 simple-type analysis to do this. Even if we did CFD

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis, for a simple jet, it would still be 2D and
2 you are still assuming that it is a round jet. So, it
3 doesn't really change very much by doing hand
4 calculations to figure out what your jet looks like
5 versus doing CFD for that type of thing.

6 It is really, for us, the important thing
7 is the force coming out of the jet. The diameter of
8 the jet really is just to figure out what you are
9 hitting. And the outer edges of the jet really don't
10 have that much force in them, typically, anyway. So,
11 we are really concerned about the core of the jets
12 during calculations.

13 DR. HAMBRIC: Okay. So, as Chris
14 mentioned, once we have a jet shape, they can
15 determine the targets. They do include a single
16 reflection up to a limiting angle. So that, if a jet
17 hits a wall, reflects off, it can strike another
18 target.

19 And there are two analyses that are
20 conducted once the loads are applied to the structure.

21 One is the static initial impulse, which we have
22 already mentioned. Industry has been doing that for
23 decades.

24 What is new to AREVA's approach is they
25 are now applying the oscillatory loads, the dynamic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loads, pulsating loads, onto the structure. And they
2 do that over certain said distances. For two-phase
3 flows, they go up to 10 diameters for the diameter of
4 the pipe break, and for steam jets, up to 25. That is
5 conservative based on what we have in reports and open
6 literature.

7 The next steps, if the target is lightly
8 constructed, they will protect anything that is
9 lightly constructed with barriers and shields. And
10 the barriers and shields are assessed for their
11 response to the impinging jet as well to ensure they
12 survive.

13 And the next step is probably the biggest
14 one. It looks at really the worst cast that an
15 oscillating jet load can be. And that occurs when
16 resonance appears, when acoustic waves that bounce off
17 the reflected surface reinforce the jet itself and
18 amplify it, sometimes significantly.

19 The community that perhaps has dealt the
20 most with that is short takeoff vertical lift
21 vehicles. They will destroy the launching pads
22 underneath them, just because of the oscillatory loads
23 that are applied to them.

24 The same thing can happen with a jet in a
25 nuclear power plant. The good news is that there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really only certain conditions when that resonance can
2 occur.

3 No. 1, the pressure ratio can't be too
4 great, less than 3.8. So, that means that if you do
5 have a resonance, it is typically going to occur later
6 during blowdown, and AREVA will assess these jets
7 throughout the blowdown process all the way through.

8 Also, the source has to be reasonably
9 close, within five pipe diameters, but the applicant
10 goes further than that. The actual number is in their
11 report. So, they are being conservative again.

12 The next steps are key, and the applicant
13 has, as we mentioned before, taken the route of
14 extreme conservatism, which is fine. So, at
15 resonance, if a resonance occurs, rather than use
16 computational fluid dynamics to assess what the actual
17 pulsating loads are, they are assuming a worst-
18 possible oscillatory load, essentially twice the
19 source pressure, the static source pressure. And that
20 is dramatically higher than any loads we have been
21 able to find in the literature. Again, even though
22 that is inaccurate, it is conservative and certainly
23 acceptable.

24 The next key parameter is what frequencies
25 is the jet loading oscillating at. What they do is,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 based on measurements and simulations performed in the
2 literature, they are computing a minimum jet resonance
3 frequency, the lowest possible frequency that the jet
4 can resonate at for a given break. And they do this
5 for multiple pipe diameters and multiple source
6 velocities.

7 And when they find resonance, they then
8 apply these amplified forcing functions to structures
9 in their plant. When the structures are simple, pipe
10 supports, jet shields, whip restraints, and they can
11 simulate them as essentially single-degree-of-freedom
12 oscillating structures, masses on top of springs, if
13 the resonance frequencies are 40 percent below the jet
14 loading frequency, they are allowed to use a static
15 calculation and a dynamic load factor. That is a
16 standard dynamic analysis approach in the industry.

17 However, if that is not the case, if they
18 have got structures where the resonance frequencies
19 are within 40 percent of the jet frequency, then they
20 do a structural analysis that is a little bit
21 different, depending on whether they have a plate or a
22 shell structure or a beam-like structure. But, in
23 either case, they are looking for all the resonances
24 in their system that might possibly be coincident with
25 the jet frequencies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If a jet frequency is anywhere near a
2 structural resonance, they line them up; they align
3 their jet frequency with their structural frequency to
4 maximize the structure's response to that postulated
5 jet load. That is also certainly conservative.

6 Regarding the amplitude of the structural
7 response, they are using the lowest amping that you
8 will find in the literature for these sorts of
9 problems. That is 1 percent of critical. That will
10 maximize the structural response amplitude.

11 As they do their stress calculations, they
12 ensure that the stress models or finite element models
13 are converged in high-stress regions. That is an
14 important topic. And once they have a converged
15 worst-case oscillating stress, they, then, compare
16 those stresses to various industry standards,
17 depending on the type of structure in the industry or
18 society standard that goes along with that type of
19 structure, ASME, and so on.

20 So, in summary, their jet loading approach
21 is conservative. They consider both the typical
22 static as well as dynamic loads throughout blowdown.
23 They look for resonance conditions. When they find
24 resonance conditions for jets, they apply the worst-
25 possible amplitudes at the worst-possible frequencies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to align with structural resonances. They, then, use
2 a minimum-possible structural loss factor of 1 percent
3 damping. And once they have converged stresses, they
4 assess them against the applicable standards.

5 Further questions?

6 MEMBER SKILLMAN: Approximately how many
7 targets does this effort identify, please?

8 DR. HAMBRIC: We haven't gotten the number
9 of targets, but we did have them give us a list of
10 potential source conditions. So, I would have to
11 defer to AREVA on the possible number of targets.

12 MR. McGAUGHY: I can't say exactly what
13 the number of targets is. We do have a list of
14 terminal end-brakes in our FSAR. Generally, each one
15 of those is going to have a target of some sort. So,
16 that is probably about as good of an answer as I can
17 give you.

18 MEMBER SKILLMAN: Are you communicating
19 tens, hundreds, thousands?

20 MR. McGAUGHY: I would say tens, not
21 hundreds, hopefully, anyway.

22 MEMBER SKILLMAN: Okay. Thank you.

23 MR. MIERNICKI: Okay. Let's move on,
24 then, to the next --

25 CHAIR POWERS: As long as we have got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these experts here, I just have a question. The shock
2 that we are forming here is a steam-driven shock. Is
3 there a literature on this, on these kinds of shock
4 waves?

5 DR. HAMBRIC: The literature that exists
6 is typically on explosions, which we discussed
7 earlier.

8 CHAIR POWERS: Yes. What I am looking for
9 is really steam-driven depressurization shocks.

10 DR. HAMBRIC: If there is, we are not
11 aware of it. The literature that we do have is from a
12 worldwide industry group that looked at explosions
13 within a variety of plants, mostly in Europe, and
14 reported that, yes, indeed, shock waves can destroy
15 structures. And we provided that to the applicant,
16 and all the applicants that we have been reviewing.
17 So, they have that.

18 But it is highly anecdotal. There is not
19 a lot of research-grade data out there.

20 CHAIR POWERS: Yes. I mean, it would be a
21 hard test. It may be hard to do.

22 DR. HAMBRIC: Dangerous.

23 CHAIR POWERS: You know, explosions are
24 easy, but explosive depressurizations are just hard
25 tests to do.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Okay. Thank you.

2 MR. MIERNICKI: Okay. Thanks, everyone.

3 Okay. The next technical topical area of
4 interest is the seismic and structural design. For
5 that presentation, we have Jim Xu from the Structural
6 Engineering Branch.

7 CHAIR POWERS: We've seen him before. We
8 know this guy.

9 (Laughter.)

10 MR. XU: Okay. Good afternoon. As Mike
11 said, my name is Jim Xu. I am a Senior Structural
12 Engineer from the Structural Engineering Branch in
13 NRO.

14 I will brief you on both 3.7 and 3.8
15 pertaining to seismic analysis and a contingent
16 design, as well as designs for other Category I
17 structures and foundations. So, all the structure
18 part is in these two sections.

19 CHAIR POWERS: Jim, I've got you here.
20 I've got to ask a question.

21 (Laughter.)

22 MR. XU: Yes. Before you ask me any
23 questions, let me introduce my experts.

24 CHAIR POWERS: Okay.

25 MR. XU: These are two big sections in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 3, and I have experts/consultants from both
2 NUMARC and the Brookhaven National Laboratories.

3 First of all, let me introduce the one
4 from NUMARC, Dr. David Foster. Please acknowledge
5 yourself.

6 And Dr. Carl Constantino, sitting in the
7 back. I know you know him. He is everywhere.

8 And Mr. Thomas Houston.

9 And from Brookhaven, Mr. Joseph Braverman
10 and Dr. Manuel Miranda.

11 Okay. You're on the slide.

12 MR. TESHAYE: You are going to be asked a
13 question before you start, right? Dr. Powers has a
14 question.

15 CHAIR POWERS: He said he had to get
16 through some stuff first.

17 MR. XU: I've got to get through some
18 stuff.

19 MR. TESHAYE: Oh, okay.

20 CHAIR POWERS: He spent all the time to
21 make this slide. Let him get through it.

22 MR. XU: Yes. I guess before I get into
23 discussion, as the previous presentation mentioned, I
24 went through use the regulations. We use guidance
25 from SRP 3.7 through 8 and the related Regulatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Guides and applicable industry standards to meet the
2 regulation GDC 1, 2, 4, 5, 16, 35, 62. I think that
3 is about it. So, that is the regulatory aspects.

4 So, let's get to technical topics of
5 interest. So, I am going to follow the flow in the
6 SRP format. Okay.

7 This discusses 3.7.1, which is three
8 subjects that relate to design parameters, design
9 ground motion, dampings, and soil profiles.

10 As AREVA has presented, and they also
11 provided the graph for the seismic ground input
12 motion, which consists of three Euro spectrum plus one
13 high-frequency spectrum in one of their potential
14 sites in the eastern U.S.

15 Collectively, the ground input with the
16 multiple spectrum represents a comparable range of
17 site conditions and is consistent with the guidance in
18 SRP 371. Therefore, it is acceptable with staff. We
19 have no open issues with this section. All the issues
20 were resolved. That is the first topic.

21 The second one is the damping used for the
22 structural analysis and, also, used for developing in-
23 structure response spectra. AREVA followed pretty
24 much the Reg Guide 1.61 guidance, except there is an
25 open item that AREVA is expected to demonstrate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the stress level in the structure is adequate for the
2 use of SSE dampings. This is an open item because the
3 design is yet to be complete. They haven't finished
4 the design yet. So, they could not demonstrate that
5 the stress level is appropriate for the damping, the
6 higher damping you had used for the structural
7 analysis.

8 MEMBER SKILLMAN: If I could ask, please?

9 MR. XU: Sure.

10 MEMBER SKILLMAN: For the staff evaluation
11 relative to design ground motion, since this is a
12 design certification to be used anywhere in the
13 country, is there any area, any technical area, in the
14 design ground motion discussion where the staff had
15 reservations, had concerns?

16 MR. XU: In terms of the ground motion
17 itself?

18 MEMBER SKILLMAN: Yes, yes.

19 MR. XU: We compared the ground motion
20 with the Reg Guide 1.60 spectra, and the ground motion
21 spectra shape is accountable to the Reg Guide 1.60
22 and, also, it includes a lot of the potential hard
23 rock sites in the eastern U.S. So, that is all basis
24 for accepting the definition for this CSDRS. We think
25 they pretty much cover a wider range of a potential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 site, yes.

2 MEMBER SKILLMAN: If I interpret your
3 answer, I interpret your answer to be, no, there is
4 not an area where you had concern.

5 MR. XU: I may have had a concern if this
6 is applied to the California coast. I would not do
7 that. But if this plant built in the central/eastern
8 U.S., I think the ground motion input is appropriate.

9 MEMBER SKILLMAN: Well, let's explore that
10 a little bit. If you had concerns that the ground
11 motion may not be enveloping for the West Coast, then
12 why would you be willing to approve a design
13 certification?

14 MR. XU: Well, the regulation requires
15 that the standard design, to demonstrate it is
16 applicable to multiple site conditions. Okay. It
17 doesn't mean it does cover exclusively all site
18 conditions. Okay. I think AREVA has demonstrated
19 that the ground motion they selected are appropriate
20 to multiple site conditions potential for this
21 particular design.

22 MR. TESFAYE: Potential COLA applicant
23 sites.

24 MR. XU: Yes. Yes, but the COLA also
25 needs to demonstrate that the design is applicable to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that site.

2 MEMBER SKILLMAN: Yes, I understand.

3 MR. XU: So, if someone wants to build
4 this plant on the California coast, then that COLA
5 probably has the difficulty to demonstrate that.

6 MEMBER SKILLMAN: I understand. Thank
7 you.

8 MR. XU: Well, now we move to the next
9 slide.

10 MEMBER STETKAR: Again, I am not a seismic
11 guy; I am not a structural guy. On the open item that
12 you have on the cable trays, I read a little bit about
13 that.

14 MR. XU: Yes.

15 MEMBER STETKAR: As I understand it, the
16 damping is also a function of the loading of the cable
17 tray, isn't it? Or is it not? I mean, I need a
18 little education here.

19 MR. XU: Yes, it depends on if the cable
20 tray is empty or full. And I think AREVA has
21 demonstrated through testing that the damping that is
22 selected is appropriate for --

23 MEMBER STETKAR: But if it is a function
24 of the cable tray loading, does it then become a COL
25 information item or ITAAC, or something like that, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 demonstrate an appropriate loading in the cable trays?

2 Because a lot of cables are field-run.

3 MR. XU: I know, yes. Yes, lots of them.

4 But if they are filled, then you can use a higher dam
5 piece. But if it is empty, actually, you can use
6 lower --

7 MEMBER STETKAR: Yes. Okay.

8 MR. XU: It is the other way around.

9 David Foster wants to clarify something.

10 DR. DAVID FOSTER: Hi. I'm David Foster
11 from NUMARC Associates.

12 Is this on?

13 MR. XU: It's not on.

14 DR. DAVID FOSTER: Okay. Can you hear me
15 now?

16 MEMBER STETKAR: As long as the recorder
17 can hear you, that is the most important thing.

18 (Laughter.)

19 I can hear you.

20 DR. DAVID FOSTER: Yes, 15 is the max
21 allowed in the transverse direction. In the FSAR,
22 there is a curve presented such that, for cable trays
23 that are empty -- let's say, when you first build the
24 plant, the tray was empty -- I believe they are using
25 7 percent damping in the transverse direction. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for trays up to 50 percent, I believe the number is 10
2 percent. And then, full trays, they are allowed the
3 15 percent.

4 MEMBER STETKAR: Fifteen percent?

5 DR. DAVID FOSTER: You are correct. For
6 partly-loaded trays, they are not allowed 15 percent.

7 MEMBER STETKAR: Okay. Thanks.

8 MR. XU: Thank you.

9 Okay. The next slide now.

10 Okay, 40, soil profiles. AREVA has
11 included or the EPR has included the soil profiles
12 which cover a wide range of site conditions. AREVA
13 has presented from very soft to very hard rock.

14 To the extent practical -- and that is how
15 we look at the standard design -- therefore, it is
16 acceptable to the staff. I mean, it is up to the COL
17 applicant to demonstrate that the site-specific soil
18 profiles, that will be enveloped by the profiles in
19 the standard design.

20 CHAIR POWERS: The question that I was
21 trying to understand, because I don't know, I don't
22 understand propagation of shear waves through solids,
23 is in their profile they have a fairly dense material,
24 and the shear waves coming through that dense
25 material. And then, it encounters this decrease in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 density, more fluffy material, and the shear wave
2 velocity drops way down.

3 MR. XU: Yes.

4 CHAIR POWERS: And if I am a little
5 gremlin sitting on the shear wave and I am propagating
6 along, what do I see when it comes into that low
7 velocity?

8 MR. XU: Well, it will amplify.

9 CHAIR POWERS: I go up in amplification?

10 MR. XU: Yes.

11 CHAIR POWERS: And so, that gives it the
12 amplification factors?

13 MR. XU: Yes.

14 CHAIR POWERS: Okay. I don't see a change
15 in the frequency. I just see a change in the
16 amplification --

17 MR. XU: The frequency will change as
18 well. It is a functional frequency with respect to
19 soil column.

20 CHAIR POWERS: So, I have basically got a
21 Bernoulli problem, except it is in a solid. I have
22 got to change things because I have got to get the
23 same amount of energy through in the same amount of
24 time.

25 MR. XU: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Okay. Thank you.

2 MR. XU: See how easy it is?

3 CHAIR POWERS: Yes.

4 MR. XU: Now we are through 3.7.1.

5 CHAIR POWERS: These things are easy, but
6 I just have to --

7 MR. XU: Okay. The next slide on 3.7.2,
8 which is the seismic system analysis. It pertains to
9 structural response to seismic motion.

10 For this section, we have five topics.
11 The first deals with the analysis methods. The EPR
12 uses time history analysis, response spectrum, and the
13 complex frequency response methods, which is usually
14 the necessity for soil interaction analysis. Okay.
15 They are consistent with the SRP 3.2.

16 And as a result, all the open issues with
17 respect to the method is resolved. Of course, we will
18 have issues with the modeling aspects. That is the
19 next slide. I know you have a question on that one.

20 Next slide, please.

21 Okay. This slide addresses the procedures
22 used for analytical modeling, which is the finite
23 element models. AREVA presented the evolution of the
24 modeling process in the past few years, going through
25 from surface environment, local mass, stick model, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 embedded stick model, and then to full-blown plus 3D
2 finite element embedded model. Okay.

3 And the reason for using these 3D
4 detailed, the finite element model, is because AREVA
5 included rock high-frequency ground motion input. And
6 the only way to predict the response to the high-
7 frequency input is to have a much finer mesh. So,
8 that is the reason you move from stick model to --

9 CHAIR POWERS: Your mission has to be
10 commensurate with the wave length?

11 MR. XU: The transition of the wave, yes.

12 CHAIR POWERS: Yes.

13 MR. XU: Yes. And normally, you need, for
14 soil, you need at least about four to five elements
15 per wave length.

16 CHAIR POWERS: Okay.

17 MR. XU: It depends on the frequency. If
18 you have very high frequency, the wave length is
19 getting smaller, and the mesh has to be much finer,
20 obviously, not coarse.

21 CHAIR POWERS: Yes. Yes, it gets
22 horrible.

23 MR. XU: Oh, yes. Yes, it could get way
24 out of control, beyond the capability of --

25 CHAIR POWERS: The computational

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 capability.

2 MR. XU: Exactly.

3 CHAIR POWERS: You just flat can't run the
4 calculation?

5 MR. XU: That's right. Well, you could --
6 well, it depends on what --

7 CHAIR POWERS: Oh, we have got a computer
8 at the National Labs that will handle it.

9 MR. XU: Yes, right.

10 CHAIR POWERS: But nobody has it.

11 MR. XU: That's right, yes. Yes, yes.

12 CHAIR POWERS: So, replication is kind of
13 a problem.

14 MR. XU: Yes, yes, especially if you have
15 a much bigger model and you may not be able to -- you
16 may run to the limit of implicit algorithm, of the
17 motion implicit algorithm.

18 CHAIR POWERS: What is a typical noting
19 for one of these high-frequency calculations?

20 MR. XU: I think it is like half a minute.

21 CHAIR POWERS: In half a minute?

22 MR. XU: Yes. It is very, very large. It
23 is very large.

24 Yes, but if you have that many degrees of
25 freedom and if you want one program, the complex

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency response method, which is based in the
2 complex domain, instead of 60 degrees of freedom, you
3 will quadruple the outcome.

4 CHAIR POWERS: Uh-hum.

5 MR. XU: And that is a substantial
6 increase.

7 CHAIR POWERS: Yes. I mean, even just
8 understanding the output becomes a real problem.

9 MR. XU: Exactly. Yes, problematic.

10 CHAIR POWERS: Yes. I mean, you end up
11 having to do these virtual reality things just to read
12 the output on these things.

13 MR. XU: That's right.

14 CHAIR POWERS: I understand. And I am not
15 a believer in that. I think that 90 percent of our
16 reactor safety questions can be answered by a back-of-
17 the-envelope calculation, and if they can't, then you
18 are probably doing it in too much detail.

19 MR. XU: You are, yes. In terms of
20 modeling, this depends on the results we are looking
21 for, right? You know, I mean, that is the objective.
22 What is the result you are looking for?

23 If you are looking for global response,
24 obviously, we can make a much coarser model.

25 CHAIR POWERS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. XU: And if you are looking for a
2 detailed response, you need finer. Or if you look for
3 a local response, you may need a separate model.

4 CHAIR POWERS: Yes. Yes, the subgroup
5 models.

6 MR. XU: That's right, yes.

7 CHAIR POWERS: Yes. One of the questions
8 that I posed to the applicant was that it has these
9 structural models, and they are relatively -- I mean,
10 at least I recognized the names. I have to admit, I
11 have never used either one of them. How do we know
12 they're right?

13 MR. XU: Well, as I said, you start out
14 defining the objective, your scope, what you are
15 looking for. Okay. I mean, if you are looking for a
16 complete behavior failure mode for a pump, then you
17 should go to a detailed model for that pump. And if I
18 am interested in structural response, not interested
19 in the particular failure mode for the pump, I may not
20 include that detail, that level of detail in my
21 structure model, right?

22 CHAIR POWERS: Right.

23 MR. XU: So, I would rather do a separate
24 analysis.

25 CHAIR POWERS: I mean, absolutely.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. XU: But it is a local analysis,
2 right?

3 CHAIR POWERS: Yes, you have got to be
4 careful about that --

5 MR. XU: Exactly.

6 CHAIR POWERS: -- how much you are asking
7 for.

8 MR. XU: Right.

9 CHAIR POWERS: Here we are asking kind of
10 global questions. And so, discounting the frequency
11 problem, which gives us a specification of the
12 loading. But let's take a fairly coarse model, fairly
13 nominal frequencies, you know, a few Hertz kinds of
14 frequencies.

15 How do I know that these structural models
16 are giving me a good answer, a reliable answer? Or
17 maybe a conservative answer? How do I know that?

18 MR. XU: Well, that depends on the type of
19 analysis you want to do. Let's say, if I want to
20 understand the dynamic behavior of the structure --

21 CHAIR POWERS: Yes.

22 MR. XU: -- I have a shear type of
23 structure, right?

24 CHAIR POWERS: Yes.

25 MR. XU: So, I can estimate approximately

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what frequency that structure has, right?

2 CHAIR POWERS: Uh-hum.

3 MR. XU: That is the first thing. I will
4 do a modal analysis first to develop all the relevant
5 frequencies and the node shapes and the mass
6 participations, so that it will give me an idea of the
7 dynamic behavior of that structure before I embark on
8 the very detailed sophisticated model without
9 understanding the underlying --

10 CHAIR POWERS: Okay. So, I can do that.
11 At the crudest level, I can do that by hand.

12 MR. XU: Yes, you could do that. You
13 could do that by hand. And you could use that as a
14 separate check, okay, to ensure that the detailed
15 model is doing what it is supposed to do.

16 There are many different ways of checking
17 the detail, whether the detailed model will do its
18 job. But I wouldn't start it out with a detailed
19 model --

20 CHAIR POWERS: Yes.

21 MR. XU: -- without understanding anything
22 about the underlying structure.

23 CHAIR POWERS: You want to know some sort
24 of physical understanding.

25 MR. XU: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: And I can do that. I mean,
2 I think I can do a beam. I am not sure I can do
3 anything else.

4 MR. XU: Well, you can do a beam, right?
5 A beam is continuous.

6 CHAIR POWERS: Yes.

7 MR. XU: Okay. If I only want to know the
8 first node of that beam, I can model that beam with a
9 lollipop, with one mass, if that is the only thing I
10 am interested in.

11 CHAIR POWERS: That's right.

12 MR. XU: So, that is my objective. But if
13 I am interested in more than that, you know, the
14 third, the fourth node, then I need to go into much
15 detail.

16 Okay. To model to a beam, you can model a
17 beam an infinite number of ways. It all depends on
18 your end objective. What results are you looking for?
19 You have got to define that first.

20 But, once that is defined, then you know
21 what to model because you understand the dynamic
22 behavior first. Right now, for this structure, okay,
23 the only thing I am interested in is the frequency
24 below 10 Hertz. Then, I don't even want to worry what
25 is going to happen beyond 20 Hertz. Why do I need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 worry about that, right?

2 CHAIR POWERS: Yes.

3 MR. XU: That is someone else's problem.
4 That is not my problem. My problem is, as long as I
5 model the structure that would give me a solution with
6 high fidelity for a frequency range below 10 Hertz,
7 that is all I am interested in. So, once I understand
8 that, then I can do my structural model and everything
9 will fall in place.

10 CHAIR POWERS: And the models will
11 predict, they predict some sort of stress level? Or
12 do they actually predict failures?

13 MR. XU: The actual failure has to be --
14 it depends on the criteria. But, I mean, the model
15 only gives you whatever you prescribe, right? You
16 know, if I prescribe the model as a linear behavior,
17 it can go on forever. Okay.

18 CHAIR POWERS: Uh-huh.

19 MR. XU: If I prescribe the material
20 behavior in the nonlinear fashion --

21 CHAIR POWERS: By putting some sort of
22 situation --

23 MR. XU: This thing keeps going, right?

24 CHAIR POWERS: Yes.

25 MR. XU: It is not going to stop until

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 either it runs out of numerical problems or you
2 prescribe something. So, if you want to stop failure,
3 then you have to prescribe what a failure means.

4 CHAIR POWERS: So, do they run these
5 models largely in Hooke's Law limits or do actually
6 put in failure criteria on them?

7 MR. XU: I think for Section 3, the scope
8 is to establish that with demand. So, you don't deal
9 with a failure yet.

10 CHAIR POWERS: Yes.

11 MR. XU: It just establishes whatever
12 load --

13 CHAIR POWERS: They run it like an
14 elastic --

15 MR. XU: Right. If you go to 3.8, then
16 you have to prescribe what constitutes as a failure,
17 and that would be the requirement --

18 CHAIR POWERS: Even if I run it in
19 elastic, I can just look at the output and say, yes,
20 this exceeded my failure criteria.

21 MR. XU: Right. Yes, that will be 3.8.
22 3.8 has to put all the load in place in the load
23 combination and then compute the combined, the demand,
24 and then compare that with the capacity, and to
25 establish that the design, whatever section, with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thickness of the liner --

2 CHAIR POWERS: So, really, the only
3 question comes down to whether I believe or don't
4 believe the constituent relationship that they put in
5 for the elastic properties, the constituent elements
6 of the structure? And none of these constituents are
7 particularly unusual at this level of calculation?

8 MR. XU: That's correct.

9 CHAIR POWERS: Got it. Thank you.

10 MR. XU: Thank you.

11 CHAIR POWERS: That clarifies a lot.

12 MR. XU: Oh, thank you. That's what we
13 are here for.

14 (Laughter.)

15 CHAIR POWERS: That's right. I appreciate
16 it.

17 MR. XU: Okay. We have two open issues,
18 two remaining issues. One deals with whether we look
19 at the model developed by AREVA. We have gone through
20 a very detailed review. Actually, the staff has been
21 looking at every minute difference to try to figure
22 out whether there is something correct or not.

23 So, the two remaining issues, one deals
24 with the connection between the superstructure and the
25 basemat. The superstructure wall is modeled with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 shell type of elements, which in each node you have a
2 60-degree freedom, three translations, three
3 rotational degrees of freedom. And the basemat is
4 modeled with the break elements, which means in each
5 node you have only three translational degrees of
6 freedom.

7 So, whether the connection is modeled
8 adequately to allow the load transfer from
9 superstructure to the basemat, and we have a question
10 to ask the applicant to justify or demonstrate whether
11 the load can transfer from the superstructure to the
12 basemat. So, that is one remaining issue.

13 The second one is AREVA has developed this
14 gigantic, very detailed ANSYS model, their static.
15 Okay. It is to model probably as detailed as possible
16 the nuclear island structures.

17 And then, if you do a different type of
18 analysis, what they do, they take this model, you
19 know, the model appropriate for that type of analysis.

20 And for the soil-structure interaction, they used the
21 program SASSI, which can only allow a certain number
22 of degree of freedom. So, you have to use some
23 simplifications before you can move this model to one
24 using SASSI.

25 So, the second open item is we asked AREVA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to compare the dynamic behavior of the ANSYS model,
2 which is the basis for their SASSI model, so whether
3 they would match, because they made certain
4 simplifications.

5 CHAIR POWERS: In your ideal situation,
6 you know, you have what, six degrees of freedom?

7 MR. XU: Yes.

8 CHAIR POWERS: Three translationals and
9 three rotationals?

10 MR. XU: For the shell, yes, for the
11 shell --

12 CHAIR POWERS: And so, you start dropping
13 those off as you simplify?

14 MR. XU: Right. Yes, because if you
15 connect the plate elements with the break elements,
16 okay, you connect them in modes, but for break
17 elements this can only see the translational because
18 it doesn't recognize rotations.

19 CHAIR POWERS: Yes.

20 MR. XU: It is blind. You couldn't see
21 the freedom. So, the question is whether the basemat
22 modeled across the thickness a sufficient number of
23 the break elements that would allow the transfer of
24 the moments from the superstructure to --

25 CHAIR POWERS: I understand, yes. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. XU: So, that is one issue.

2 CHAIR POWERS: I'm getting it.

3 MR. XU: Yes.

4 CHAIR POWERS: And you go to the
5 simplification because you need more nodes?

6 MR. XU: Right.

7 CHAIR POWERS: Yes.

8 MR. XU: Yes.

9 The second one is compare the SASSI model
10 with ANSYS. I think, so far, the data provided to us
11 have demonstrated that they match, in terms of
12 frequency, they match very well.

13 CHAIR POWERS: Okay.

14 MR. XU: Okay? But we do have some
15 questions on some of the flow response action. There
16 are some peaks that are not matching as good as they
17 should. So, we still have some questions on that.
18 That is an open item.

19 CHAIR POWERS: But matching between codes
20 is really an engineering judgment sort of thing,
21 right?

22 MR. XU: Yes. But if you do analysis in
23 different -- well, even though you use the same
24 elements, say, for example, they all use the plate
25 elements. It depends on the formulation within the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 code.

2 CHAIR POWERS: Sure.

3 MR. XU: Okay? It could be very
4 different. It is just a numerical model. So, you can
5 model different code models differently.

6 I believe the SASSI is using the
7 formulation --

8 CHAIR POWERS: Well, it is like you say,
9 it depends on the question you are answering.

10 MR. XU: That's right.

11 CHAIR POWERS: How you compare two codes,
12 I mean, there is an engineering judgment, but the
13 first question is --

14 MR. XU: Yes, yes.

15 CHAIR POWERS: -- what question am I
16 really asking here?

17 MR. XU: That's right, yes. But we do
18 check. The first thing we want to check is to make
19 sure the two models are dynamically equivalent.

20 CHAIR POWERS: Yes.

21 MR. XU: That is what we want to see.

22 CHAIR POWERS: I understand, yes.

23 MEMBER SKILLMAN: For your first open
24 item --

25 MR. XU: Yes?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: -- the compatibility
2 between the nuclear island mat and the superstructure,
3 what would be the success path for the staff to say
4 this is acceptable?

5 MR. XU: The success path would be if the
6 connections get adequately transferred depending; that
7 is what we are looking for. Obviously, you can
8 transfer shear because both the breaks and the shell
9 elements model the translation of the degree of
10 freedom. So, you can get the shear forces correctly
11 transmitted from the superstructure to the basemat.

12 But we don't know, if we don't look at the
13 details of that connection, whether the moment can be
14 correctly transferred. Because if I just use one
15 break element for the basemat, that basemat cannot
16 take any bending, right, because there is no bending
17 capabilities in it, because across the seconds you
18 have only one break, and the break does not take
19 bending. It will take only translational forces.

20 But if I model across the thickness, for
21 example, if I take four elements or five, okay,
22 collectively, they will be able to take a bending
23 moment, and that is what we are looking for and to
24 make sure. Because the basemat does have bending
25 capabilities. But if you don't model it properly, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 will not be able to capture that behavior.

2 MEMBER SKILLMAN: That load?

3 MR. XU: Yes, that's right. Yes.

4 MEMBER SKILLMAN: Thank you.

5 MR. XU: You're welcome.

6 Okay. I think we are done with this
7 slide.

8 Okay. The next slide discusses soil
9 structure interaction. AREVA used SASSI computer
10 code, and this is a very old code. It is a code
11 originally developed at UC-Berkeley. It is now being
12 used by all applicants for soil structure interaction
13 analysis, considering embedment effect.

14 But there is one method in this code which
15 is called substructure methods. And it was recently
16 identified to produce unconservative seismic response.
17 It depends on the configuration.

18 The issue was originally identified in the
19 seismic analysis for some of the DOE, Department of
20 Energy, facilities. Now, because AREVA has used
21 substructure methods, now this is one other issue they
22 have to resolve.

23 We have two open items. Maybe I will go
24 through the first one first, which is the tendon
25 gallery, because AREVA used the post-tension

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 containment. And the tendon gallery extended below
2 the basemat. The gallery may take most of the load
3 before during the seismic motion. The tendon gallery
4 may take the most below, before the passive pressure
5 on the side is activated, because passive pressure can
6 only be activated in certain deformations. Okay. But
7 before that deformation takes place, most of the load
8 will have to be taken by the tendon gallery because
9 that is the shear key on the bottom. So, that is the
10 issue.

11 I think it is an open item. AREVA will
12 demonstrate the fact that the tendon gallery is
13 actually designed to withstand the seismic load.

14 Okay. The second issue is the issue
15 associated with the subtraction methods. We have had
16 discussions with AREVA on this issue. AREVA has
17 presented an approach for resolving this issue. We
18 think it is promising, but we will see the details
19 when they present us with some preliminary results,
20 and this will be in phase 4. So, they are not going
21 to do that now. The latest schedule is to provide it,
22 this will be done by late October this year.

23 Any questions on this slide?

24 (No response.)

25 Okay. Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This slide addresses interaction between
2 Non-Seismic Category I structures with Seismic
3 Category I structures. For this issue, for this
4 topic, it turned out to be a very difficult issue for
5 one of the non-safety-related structures, which is the
6 nuclear auxiliary building. This building is located
7 in the corner of the nuclear island between the fuel
8 building and the safeguard No. 4, okay, right in the
9 corner there.

10 AREVA has performed the 201 analysis, and
11 I think it has difficulty with respect to justifying
12 the total pressure to withstand the rotational node of
13 the motion. So, this is still an open item. We
14 expect that AREVA will provide a full justification
15 that the NAB will not impact the nuclear island
16 structures. I think that is the only issue we have
17 with 201.

18 CHAIR POWERS: We asked specifically about
19 piping and cabling in the past between structures on
20 different mounts. And the applicant indicated, yes,
21 he was aware and worried about that issue, and I guess
22 you guys also worried about that issue.

23 MR. XU: Yes. All the umbilicals, the
24 things that connect between the buildings, that is the
25 issue we have currently. You know, we review to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ensure that they are not an issue here.

2 And also, I believe there is a COL
3 information item, an ITAAC that they need to worry
4 about.

5 CHAIR POWERS: Yes.

6 MR. XU: The next slide.

7 MEMBER SKILLMAN: Before you go on --

8 MR. XU: Okay.

9 MEMBER SKILLMAN: -- is what is going to
10 be the certified design -- deficient is not the word I
11 want to use, but it tends in the right direction. Is
12 there an inadequacy here because of the spatial
13 difference between the NAB and the access building and
14 the turbine building to the seismic Class 1
15 structures? Is this a weakness in the design?

16 MR. XU: No, it is not a weakness of
17 design. But, you know, when you have a structure that
18 is designed to a certain quality, but you have another
19 structure located in the proximity for it, but there
20 is not a circular structure, it is probably not
21 designed to the same level of standard.

22 So, the issue is, is that structure either
23 too close to this one or in a certain way you have got
24 to make sure that that building is not going to fall
25 all over the safety-related structure to interfere

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with its function. So, that is the issue we always
2 have to address.

3 MEMBER SKILLMAN: I understand that. This
4 is a nested-building problem where you have got
5 different building classifications --

6 MR. XU: Right.

7 MEMBER SKILLMAN: -- that can result in
8 interactions that are adverse to the overall quality
9 of the facility.

10 MR. XU: Right.

11 MEMBER SKILLMAN: I understand --

12 MR. XU: Yes, but we didn't care about the
13 other structure, the non-safety-related one.

14 MEMBER SKILLMAN: As long as it can't take
15 out the safety-related one?

16 MR. XU: Right. As long as the safety-
17 related is protected, but that is the issue here. So,
18 we want to make sure. SRP has three criteria there.
19 Either demonstrate that the sufficient distance
20 exists. We call this what happened to the non-safety-
21 related. It is not going to even touch the safety-
22 related structure. Or they demonstrated that if it is
23 clamped on the safety-related structure, but it will
24 not damage it. It is going to be difficult to do. It
25 is not practical. It is difficult to demonstrate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 aspect.

2 MEMBER SKILLMAN: So, this becomes, if you
3 will, a financial issue for a future licensee, but it
4 is not necessarily a safety design issue?

5 MR. XU: No, it is not safety. Or it is
6 one aspect you have to check in the design. It is one
7 part. You know you design much structure that is
8 safety-related, but I have to worry about where were
9 my neighbors, right? All my neighbors had to behave
10 properly. I have got to have good neighbors, make
11 sure they don't do anything to damage my properties.

12 (Laughter.)

13 MEMBER SKILLMAN: I accept that argument,
14 except where you must have your neighbor in order to
15 operate the facility.

16 MR. XU: Exactly.

17 MEMBER SKILLMAN: That is where it becomes
18 a real complication.

19 MR. XU: But except I don't care what
20 happens to that neighbor.

21 (Laughter.)

22 MEMBER SKILLMAN: Thank you. I
23 understand. Thank you.

24 MR. XU: Stability, the next one is on
25 stability. Well, we have done several standard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 designs already. As you know, the stability analysis
2 is always a difficult aspect to demonstrate for
3 standard design.

4 I think the reason for that is the
5 standard design uses multiple ground motions and a
6 wide range of shapes, and that tends to overpredict
7 the demand, the seismic demand. On the other hand,
8 the design is always conservative. So, in terms of
9 capacity, it is always under-prescribed. It is always
10 for the lower capacity. That is the nature of design.

11 So, as a result of that, the stability is
12 the demand overcapacity. And then, you check whether
13 it is the rock overturned or slag, and then you
14 compare with the criteria prescribed. That is always
15 difficult for the standard design to demonstrate. It
16 would be much easier to demonstrate for any site-
17 specific design or for generic design, but this is a
18 difficult aspect.

19 I just want to point now that part. We
20 did spend a lot of time with applicants to resolve all
21 of the related issues. We don't have any open items
22 on the stability analysis.

23 Okay. We have finished 3.7.2.

24 CHAIR POWERS: Very good. I am going to
25 declare a break between 3.7 and 3.8.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. XU: Okay.

2 CHAIR POWERS: I truthfully enjoy
3 listening to Professor Xu here.

4 (Laughter.)

5 But I think my Committee has an inherent
6 retention problem that needs to be addressed. So, we
7 will recess until three o'clock.

8 CHAIR POWERS: Let's come back into
9 session.

10 The professor will continue his lecture.

11 (Laughter.)

12 MR. XU: Thank you.

13 This slide addresses 3.7.3, which deals
14 with the --

15 MR. TESFAYE: Oh, I thought we were done
16 with this.

17 MR. MIERNICKI: He hasn't touched this
18 slide yet.

19 MR. XU: I didn't talk about this.

20 CHAIR POWERS: Barely, I cut him off and
21 that is just one of my prerogatives, I guess.

22 (Laughter.)

23 MR. TESFAYE: I heard him say 3.8. That's
24 when you stopped him.

25 CHAIR POWERS: Yes. I always learn

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 something when he talks.

2 MR. XU: Okay. This section deals with
3 the subsystem responses from the perspective of
4 seismic demands that would be computing the in-
5 structure response spectrum. Applicants follow the
6 Regulatory Guide 1.122 and the Reg Guide 1.92, which
7 is all they need to do in terms of developing this
8 sort of response spectrum.

9 And we have resolved all the issues in
10 this section. We don't have any remaining issues
11 here.

12 Any questions?

13 (No response.)

14 If no questions, okay, we have finished
15 Section 3.7. Now we go to 3.8, which is the
16 containment design and the design of other Category I
17 structures and foundations.

18 Okay. I lumped 3.8.1 and 3.8.2 together,
19 which deal with concrete containment and 3.8.2 deals
20 with the steel containment. As you see from AREVA's
21 presentation, EPR used the post-tension concrete
22 containment with grouted tendons.

23 For this section, as AREVA presented this
24 part already, Regulation 52.47(c)(1) required the DCD
25 application provide essentially a complete design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The initial review by the staff did not identify any
2 criteria for identification of critical sections.

3 Applicant subsequently developed the
4 detailed methodology, which we believe is the first of
5 its kind. It is very good methods, provides
6 systematic selection criteria for critical sections.

7 The only open item on this slide is the
8 design of critical sections or remain to be completed.

9 So, therefore, the number of critical sections could
10 change. So, if there are no questions, we will move
11 to the next slide.

12 This is an important slide which deals
13 with the design and analysis procedures. We have
14 identified a number of issues with respect to design
15 and analysis procedures.

16 The first bullet deals with the nonlinear
17 finite element model which was originally used for the
18 design of the superstructures. The reason for using
19 this model by the applicant was to account for the
20 uplifting effect, and they also used nonlinear soil
21 scorings. But this is inconsistent with the linear
22 design philosophy. I mean, to this date, I still
23 don't understand what nonlinear design is, right?

24 If I would come for multiple loads from
25 internal and external hazards, if you don't use linear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design, how are you going to combine them?

2 CHAIR POWERS: Yes, you can't do
3 superposition or anything.

4 MR. XU: Exactly.

5 CHAIR POWERS: Yes.

6 MR. XU: That is the basic principle
7 behind --

8 CHAIR POWERS: Yes. Okay. I understand
9 that's a problem.

10 MR. XU: That is going to be a problem.
11 That is why you can use the linear methodology for
12 evaluation purpose or you can use linear methods for
13 design of local phenomenons such as foundation design.

14 You can do that. But superstructure sees a whole
15 different load at different places. You have to use
16 linear methodology because you have to employ a
17 superposition principle.

18 So, again, the second bullet is the
19 100-40-40, which is also based on superposition. You
20 know, it is not applicable to nonlinear analysis.

21 So, applicant originally, when they used
22 the nonlinear finite element model, they tried to
23 modify the 100-40-40 methods, which we don't think is
24 correct.

25 And also, the original design employed the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so-called equivalent static seismic analysis methods
2 with modification factors. Okay. This is also the
3 first-of-a-kind which had never been used before in
4 the design of a nuclear facility. At least I haven't
5 seen it.

6 Okay. And the staff also performed a
7 confirmatory analysis of the reactor building internal
8 structure to demonstrate that the use of this
9 modification factor is inadequate. But, in the end,
10 AREVA changed to a different approach which followed
11 the linear methodology for the superstructure design,
12 that the next bullet is that the superstructure design
13 will be based on a linear model which is consistent
14 with the principle of the superposition, and the
15 basemat model will account for the various nonlinear
16 factors.

17 Uplifting will be an evaluation, because,
18 I mean, you don't rely on uplifting to compute the
19 seismic demands, right? You do a design and you can
20 evaluate that design, whether that will survive the
21 uplifting effect.

22 And for the three-directional load
23 combination from seismic events, AREVA will use SRSS
24 rule, which is the square root of solid squares, for a
25 superstructure model and algebraic summation for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 basemat model.

2 They eliminate 100-40-40 rule, which we
3 still have some questions. This particular load, the
4 combination methods are being addressed by ASC4
5 Working Group. So we are still waiting for some study
6 to be done before we finalize the requirement in ASC4.

7 CHAIR POWERS: Okay.

8 MR. XU: And also, they eliminated the
9 modification methods.

10 Next slide.

11 There are some other technical issues we
12 have identified that I will review. One issue,
13 described in the first bullet, is associated with the
14 evaluation of the containment pressure generated from
15 hydrogen gas and the burn issues.

16 Reg Guide 1.7 I believe is the last
17 guidance, Reg Guide 1.7, asking to demonstrate that
18 the structural analysis be performed to demonstrate
19 ASME service level allowable is not exceeded by the
20 pressure loads generated from 100 percent fuel clad-
21 cooling reaction following the hydrogen burnings.

22 The original analysis by AREVA did not
23 perform the analysis. They simply stated that their
24 design pressure is 72 psi, which is higher than the
25 minimum 34 psi pressure stated in 1.7.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The second bullet says they account for
2 concrete cracking effects, which is one of the
3 uncertainties that needs to be considered in the
4 seismic analysis and analysis for determining the DBA
5 pressure and temperature load, because the concrete
6 will crack. And the question is whether you account
7 for that effect in the design.

8 And the third bullet says the ISI, the in-
9 service inspection program, the original FSAR, Rev. 0,
10 basically says we will use Reg Guide 1.90, but we are
11 going to use different testing schedules and we are
12 not going to do monitoring of non-grouted test
13 tendons.

14 Okay. And also, on this particular
15 subject, we have very limited U.S. experience because
16 there are only two plants that were designed using
17 grouted tendons. One is the Three Mile Island, which
18 was shut down right after it was built, was operated.

19 The second is Robinson. I believe they used on the
20 grouted tendons for the vertical.

21 MEMBER SKILLMAN: Would you explain the
22 first bullet again, please? I thought you said 37
23 pounds, but your slide shows 75 psi for that.

24 MR. XU: Oh, yes, the 37 psi is the
25 pressure that is calculated from the hydrogen due to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 100 percent fuel clad-cooling reaction for the
2 hydrogen burning.

3 MEMBER SKILLMAN: Okay.

4 MR. XU: That is calculated later. In
5 their Rev. 0, they did not do any analysis. They
6 simply stated that the design pressure, which is the
7 62 psi, is greater than 34 psi, minimum requirement
8 stated like at 1.7.

9 MEMBER SKILLMAN: What is the 75 psi on
10 that line?

11 MR. XU: The 75 psi is the pressure
12 calculated from the hydrogen gas. So, that is what
13 they need to demonstrate with that pressure, with the
14 75 psi, the air service level allowable is not
15 exceeded for the liner. For the liner ASME limits for
16 the liner, it is a .03 percent. Okay. For the
17 membrane strain, and for membrane plus bending, it
18 should not exceed 1 percent.

19 MEMBER SKILLMAN: Thank you. I
20 understand.

21 MR. XU: And the last bullet says the lack
22 of design details. AREVA did not provide any of the
23 penetration designs for the containment because they
24 are part of the containment pressure boundary. So, we
25 believe they should be, as a part of the pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 boundary, they should be included in part of the steel
2 containment, that that steel containment addresses,
3 the permutations.

4 Okay. The next slide.

5 The staff evaluation, the first bullet
6 states that AREVA has done, after we identify the
7 issue, AREVA performed nonlinear analysis and
8 basically established the pressure for hydrogen gas is
9 75 psi and demonstrated that the containment liner is
10 within the ASME service level C allowables.

11 And AREVA also performed the additional
12 finite element analysis to account for concrete
13 cracking effects and the seismic demands for
14 containment and, also, for the model that is used to
15 demonstrate the robustness from the DBA pressure and
16 temperature load.

17 For the ISI and the grouted tendon
18 procedures, AREVA is now going to follow Reg Guide
19 1.90 and Reg Guide 1.107 without exceptions.

20 And the last bullet, AREVA has completed
21 the design of the major steel penetrations as a part
22 of containing the pressure boundary.

23 Next slide.

24 This slide addresses the containment
25 internal structures. For containment internal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 structures, we don't have any remaining technical
2 issues except the localized model is not complete for
3 internal structures. That will be complete when the
4 design is finished during phase 4. So, that is an
5 open item.

6 We are satisfied with the global models,
7 which containment includes the internal structure as a
8 part of the global model. But the localized effect
9 will be analyzed with a local model which is not
10 complete yet.

11 Next slide.

12 3.8.4 deals with design for other Category
13 I structures, which all the issues that were raised
14 for containment apply to other categorized structures.

15 So, we did not repeat it here.

16 The only item, the issue, we put it on
17 this slide actually is the one AREVA hasn't addressed
18 yet. This deals with the fuel rack structural
19 analysis design. AREVA covered these aspects in
20 Chapter 9, which is part of tomorrow's presentation.

21 CHAIR POWERS: One of the issues we are
22 running into in connection with Fukushima is that in
23 their spent fuel pools they have for one of the plants
24 some aluminum racks, and they dropped a bunch of
25 concrete in there. Of course, concrete in water, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 leach out the calcium hydroxide. It makes the
2 solution basic.

3 MR. XU: Yes.

4 CHAIR POWERS: And basic solutions and
5 aluminum are basically incompatible with each other.
6 Do we have some more problems here?

7 MR. XU: I don't think that is even within
8 the scope of their rack design for standard or for
9 this. No one addressed that issue.

10 I mean, we do address the accidental drop
11 during operation.

12 CHAIR POWERS: Yes. I mean, that is a
13 design basis consideration.

14 MR. XU: That's right, yes.

15 CHAIR POWERS: I think we are coming down
16 to you just really should not put aluminum in these
17 spent fuel pools, not so much from a DBA
18 consideration, but just because of beyond DBA
19 considerations.

20 MR. XU: Right. I think maybe tomorrow
21 you can ask that question for the Chapter 9.

22 CHAIR POWERS: Yes. Yes, I just kind of
23 feel that somebody will raise the question.

24 MR. XU: That is a good issue. That is a
25 good issue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Yes.

2 MR. XU: But I don't think, you know, even
3 the operating plants don't address that.

4 CHAIR POWERS: Yes. Steel is such
5 wonderful stuff.

6 MR. XU: It is rare. It is probably
7 extremely low probability.

8 CHAIR POWERS: Yes. I mean, quite
9 frankly, I hadn't thought about it until somebody
10 asked me, you know, what happens with all that
11 concrete in there? And I said, oh, everything's fine
12 as along as you don't have aluminum in there. And
13 they went, oh, whoops.

14 (Laughter.)

15 MR. XU: Okay. I mean, we give you the
16 staff evaluation here before you have an opportunity
17 to hear what the applicant will present with respect
18 to spent fuel rack designs.

19 So, I will probably just give you some
20 preview on that. So, what is involved in here is the
21 spent fuel rack is a rectangular-frame-type of a
22 structure with a plates on all sides and the poison
23 plates inside to make the cell tubes which houses the
24 fuel assemblies. And the rack is supported by legs
25 and it is freestanding. It is not anchored. So, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is freestanding and it is submerged in the pool. So,
2 that is the rack.

3 And the challenges with this type of
4 design is it is extremely nonlinear because it is
5 freestanding.

6 CHAIR POWERS: Yes.

7 MR. XU: So, the seismic analysis is
8 difficult because of the high nonlinearity. You can
9 see the sliding, tipping, and all the interaction
10 effects, the full-structure interaction, and the cell
11 wall interaction with the fuel assemblies and the
12 rack-to-rack interactions. It is just all the
13 possible interaction effects had to be conceived of.

14 So, it is very complex. The typical
15 analysis for this type of situation, people use the
16 defined type of computer code to do the explicit
17 algorithm to include all their facts.

18 As we know from others, the issue from
19 other designs, the integrity of fuel assemblies, okay,
20 the applicant will have to demonstrate that the fuel
21 assembly actually maintains the integrity, although it
22 is a proxy. By the design of the rack, the fuel
23 assembly probably should be maintained. But now they
24 have to explicitly demonstrate this, whatever the
25 stress, or stress is not exceeded, or whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 allowables for the fuel assemblies. So, it is
2 complex.

3 And if you move to the next slide, we have
4 looked at the variety of the nonlinear aspects
5 associated with this design. You know, the friction
6 coefficient is selected from .2 to .8, which is
7 typical for other designs as well.

8 CHAIR POWERS: The friction factor is kind
9 of critical for the sliding around.

10 MR. XU: Yes, because at .2, the lower
11 friction will control the sliding. But the upper
12 bound controls the tipping.

13 CHAIR POWERS: Okay. So, damned if you
14 do, damned if you don't sort of thing.

15 (Laughter.)

16 MR. XU: So, you have to consider the
17 entire range. That is why it is a difficult subject,
18 and you have to make different cases.

19 The other design certification will even
20 develop a matrix of what -- which cases.

21 CHAIR POWERS: I mean, there is even more
22 to the issue. If your friction factor is critical,
23 too high or too low, then you have a
24 construction/installation/inspection problem.

25 MR. XU: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Because how do you know
2 that what you actually put in there, indeed, has the
3 friction factor within the critical range?

4 MR. XU: Well, to make sure your design is
5 conservative enough, as long as the friction
6 coefficient is limited within this range, the design
7 allowable will not be exceeded. Okay? But that is
8 very important.

9 I see Joe wants to add something, Joe
10 Braverman from Brookhaven National Laboratory.

11 MR. BRAVERMAN: Yes. Hello.

12 MR. XU: It's on.

13 CHAIR POWERS: You're on.

14 MR. BRAVERMAN: It's on? Okay.

15 Joe Braverman from BNL.

16 To answer your question about the adequacy
17 of the friction coefficient, I believe the applicant's
18 fuel racks from various past submittals have referred
19 to actual test data of stainless steel on stainless
20 steel submerged in water. And surprisingly, the range
21 of the coefficient of friction is very wide. So, the
22 .2 represents the low bound, based on actual tests,
23 and .8 the upper bound.

24 In this case, the applicant also
25 considered an intermediate value of .5, based on staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions. And I think they have even a few cases of
2 randomized coefficient of friction values at different
3 rack legs as well.

4 CHAIR POWERS: Why the range?

5 MR. BRAVERMAN: Excuse me?

6 CHAIR POWERS: Why the range? I mean,
7 stainless is stainless is stainless, except in the
8 area of friction. I mean, 304 is God-awful when it
9 comes to friction.

10 MR. BRAVERMAN: Well, I am not an expert
11 in that area, but I suspect a major factor is how you
12 finish the surface of the stainless steel material. I
13 don't think the water has a factor. It is not clear
14 how much --

15 CHAIR POWERS: Yes, the water wouldn't be
16 important.

17 MR. BRAVERMAN: As far as how much dead
18 weight you have on it, that could be a factor of
19 stainless steel and water, but I suspect that primary
20 factors may be the finish of the surface.

21 CHAIR POWERS: What I know for sure is
22 304, and 304 gall like crazy. The friction factor
23 just goes astronomical on that. And 304 and 447 slide
24 like butter. I mean, they are just really smooth on
25 each other.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, I suspect is an alloy-to-alloy
2 problem, at least one of the factors. I mean, load
3 clearly makes a difference.

4 Interesting. What a problem. Okay.

5 MR. XU: But, in the actual case, it is
6 not going to have a friction coefficient in this wide
7 range. This is a conservative way of doing a standard
8 design because, as I said, the lower bound controls
9 the sliding; the higher bound will be controlled by
10 the tipping.

11 MR. BRAVERMAN: Yes, I'm sorry. This is
12 Joe Braverman again from BNL.

13 What I also meant to say is we don't
14 really need to know the exact coefficient of friction.

15 The fact that they are considering low bound, upper
16 bound, intermediate, and enveloping of the results, in
17 that way I think it is a conservative approach.
18 Wherever the number falls, it should be bounded by
19 these analyses.

20 CHAIR POWERS: Yes. I mean, the question
21 is, because high friction has a problem and low
22 friction has a problem, you need to make sure that,
23 indeed, you are covering the spectra.

24 MR. XU: Just make sure you cover the
25 power curve, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR POWERS: Yes.

2 MR. XU: There is no way out.

3 (Laughter.)

4 MEMBER STETKAR: It is a really intriguing
5 issue.

6 MR. XU: Yes, it is intriguing because
7 there is no way out, unless you do a specific design
8 and you know exactly what the friction coefficient,
9 you know the uncertainty, and you can do it in a
10 range. Otherwise, you have to do it conservatively.
11 So, this is the only way I guess they could do it.

12 The second bullet deals with all the
13 interactions which AREVA had to provide justifications
14 to us. AREVA is also going to demonstrate the
15 tolerance on the gaps is adequately considered.

16 We also haven't seen all the results yet.

17 So, they will provide all the results for various
18 components of the reactor.

19 So, the last three bullets, those three
20 bullets in the next slide are three open items for the
21 rack.

22 Okay. We will go to the next slide. This
23 slide addresses the design of the foundations,
24 Category I foundations.

25 MEMBER SKILLMAN: Let's go back to 54,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just one slide.

2 MR. XU: Okay.

3 MEMBER SKILLMAN: Why isn't there another
4 bullet which is the identification of an action to
5 make sure that the applicant is addressing the
6 interaction between the outermost rack and the pool
7 liner?

8 MR. XU: It should be covered in the first
9 bullets.

10 Okay, Joe will provide the clarification
11 on that.

12 MR. BRAVERMAN: Excuse me? If you could
13 clarify your question, do you mean the outer rack and
14 the pool wall or do you mean beneath the rack leg and
15 the pool floor?

16 MEMBER SKILLMAN: The outermost rack and
17 the stainless steel liner on the wall.

18 MR. XU: The liner on the wall.

19 MR. BRAVERMAN: My understanding -- and
20 maybe AREVA can correct me -- is that they did about
21 15 different analyses with these different
22 permutations like coefficient of friction, different
23 time history sets, different fill of the racks, and
24 then the envelope on the results.

25 I believe, with few exceptions, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 outermost rack did not impact the walls because there
2 was substantial dimensions or gaps between the rack
3 and the wall. They didn't slide that much.

4 There were, I believe, a few cases, but
5 those impact forces were not significant. And even if
6 it did, the liner is backed by concrete. So, unless
7 you have a sharp point, you are not going to likely
8 penetrate the liner.

9 MEMBER SKILLMAN: Does AREVA want to
10 respond to that?

11 MR. GARDNER: We don't really have anybody
12 here today.

13 MEMBER SKILLMAN: Can we talk about it
14 tomorrow?

15 MR. GARDNER: Tomorrow.

16 MEMBER SKILLMAN: Thank you. Good.

17 MR. XU: As I said, you see there the
18 staff evaluation first before you hear from the
19 applicant.

20 MEMBER SKILLMAN: I was concerned that our
21 chance left us this morning.

22 MR. GARDNER: It will be talked about in
23 Chapter 9 tomorrow.

24 MR. XU: Yes, that will be in Chapter 9
25 probably.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: That is no problem. I
2 mean, that's fine.

3 MEMBER SKILLMAN: That's fine. Okay. I'm
4 good.

5 MR. XU: But we will be here. I think in
6 the morning we will be here, if you have any questions
7 from staff.

8 MEMBER SKILLMAN: I would have seen it
9 more addressed in 3.8 as opposed to seeing it in 9,
10 but either is fine, as long as we talk about it.

11 MR. XU: Right. Yes, we thought they
12 would do it in this, but --

13 MEMBER STETKAR: If we had had 9 today,
14 they would have said, well, it's 3.8.

15 (Laughter.)

16 MEMBER SKILLMAN: I want to make sure the
17 train hasn't left the station.

18 CHAIR POWERS: McIntyre is in charge.
19 They do that sort of stuff, yes.

20 (Laughter.)

21 MEMBER SKILLMAN: Thank you. I'm good.
22 Thank you.

23 MR. TESFAYE: For some clarification, the
24 staff addressed this in Chapter 3, but AREVA gave us a
25 technical report that covers all this in Chapter 9.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SKILLMAN: Okay. Then, we will
2 talk about it in 9.

3 MR. XU: Yes, because we are the one who
4 reviewed the structural design for the rack. It is a
5 logistic issue; it is not technical.

6 MEMBER SKILLMAN: Thank you.

7 MR. XU: Yes.

8 CHAIR POWERS: There's lots of questions
9 to ask the applicant.

10 MR. XU: That's right.

11 CHAIR POWERS: We may change this whole
12 thing around.

13 (Laughter.)

14 MR. XU: Okay. For foundation, the first
15 issue is the stability analysis, which we already
16 covered in 3.7 and the coefficient of friction. The
17 sliding was pretty much in the lower bound; .5 is low
18 enough to cover most of the soil slide.

19 And in terms of design, they incorporated
20 tendon gallery as shear key. And also, shear keys are
21 included for EPGB.

22 ESWB has not completed yet design. Okay?

23 And they also make design changes for ESWB because of
24 the stability issue.

25 Okay. Next slide. We have two more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slides to go.

2 Okay. This is a good issue. The design
3 of the foundation needs to account for the load from
4 differential soil settlement and the construction
5 sequences. The soil settlement and construction
6 sequences really are a site-specific issue. But how
7 the standard is designed to account for the load from
8 this fact is a difficult subject.

9 So, there are two issues involved in this.

10 First, the design be conservative enough to account
11 for differential settlement effect.

12 The second is the construction has to be
13 in the minor, to ensure that whatever settlement you
14 see due to the soil differential settlement, would not
15 -- the stresses in the foundation due to the
16 differential settlement at the different stages of
17 construction will not exceed the stresses in the
18 design, the design allowables. Okay. So, there are
19 two parts in there.

20 The standard design was the first aspect,
21 which is the design that accounts for potential
22 differential settlement. And the standard design has
23 to postulate a construction sequence. Okay? And they
24 design conservatively to make sure site-specific
25 differential settlement will not induce the stress in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the foundation that will exceed the design allowables.

2 And that is a challenge.

3 Okay. And the design also has to provide
4 an adequate detailed guidance for the COL as to what
5 the COL will do, the staff, the monitoring programs in
6 place to ensure the design is adequate for the
7 construction.

8 CHAIR POWERS: This seems to be an issue.

9 What you have talked about here is guidance for the
10 COL applicant. I think the staff has some guidance to
11 pass on to the inspection people here. Because what
12 you are raising is an issue of the sequence of
13 construction itself has to be watched fairly closely.

14 MR. XU: Yes, that's right. Yes.

15 CHAIR POWERS: I mean, that is a key
16 insight here.

17 MR. XU: Yes.

18 CHAIR POWERS: I guess we need to figure
19 out a way to flag these things, because it is not
20 clear to me that anybody just setting up an inspection
21 monitoring program would catch that particular issue.

22 MR. XU: Right. That is why in DCD the
23 applicant should provide sufficient details to ensure
24 that you have all the steps and that you have all the
25 information that will be necessary for the COL to make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that call, that during the construction the stresses,
2 the strain will not exceed allowables.

3 CHAIR POWERS: You are sure making a
4 floating nuclear power plant sound a lot more
5 interesting.

6 (Laughter.)

7 McIntyre doesn't even smile. Tears come
8 to his eyes.

9 (Laughter.)

10 MR. XU: So, this is an issue that needs
11 to be addressed both by the DCD application and the
12 COL.

13 CHAIR POWERS: Yes.

14 MR. XU: Okay. So, it is an important
15 issue, an important aspect to ensure the foundation is
16 adequate. So, once you pour the concrete, then you
17 are in deep trouble, right? You don't want that.

18 (Laughter.)

19 CHAIR POWERS: A big, large crack appears.

20 MR. XU: No, no.

21 Manuel Miranda from BNL wants to chime in
22 on that aspect.

23 DR. MIRANDA: Yes, this is Manuel Miranda
24 from BNL.

25 I just wanted to maybe clarify a couple of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things that Jim was expressing.

2 First is in the FSAR there is a postulated
3 construction sequence which is described in terms of
4 steps that were basically assumed in the design in
5 order to generate induced stresses that were taken as
6 loads for their design. That is the first thing.

7 And the second thing is the set of
8 settlement profiles that go along with those
9 construction steps. So, these settlement profiles
10 were incorporated as part of the FSAR, so that the
11 COLA would have them and would be able to use those in
12 order to compare what they are actually getting on the
13 site. So, that is the mechanism that was incorporated
14 in the FSAR. That was as a result of this staff
15 review.

16 CHAIR POWERS: And it is all very good,
17 and I thank you for pointing this out because it is
18 certainly something I would not have caught. I mean,
19 I would have read this sequence, and I said, eh.

20 (Laughter.)

21 MR. XU: The applicant has done a good job
22 in addressing these difficult challenges.

23 CHAIR POWERS: Congratulations to all in
24 that case.

25 MR. XU: And staff's persistence.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 CHAIR POWERS: Quite frankly, good catch,
3 guys. We really appreciate that. That is something I
4 would not have thought of.

5 MR. XU: And this is an important issue.
6 I mean, there is a gap in terms of the guidance to
7 address this issue. There is ASC, one Working Group
8 that will take that challenge to see if there is some
9 requirement that we can prescribe in the standard for
10 this process.

11 MEMBER SKILLMAN: Could we go back to 55
12 for a second, please? On the third and fourth
13 bullets, tendon gallery as shear key for the nuclear
14 island basemat --

15 MR. XU: Yes.

16 MEMBER SKILLMAN: -- and shear key is
17 credited for sliding analysis of the emergency power
18 generation building basemat.

19 MR. XU: Yes.

20 MEMBER SKILLMAN: In the Standard Review
21 Plan, and I suspect in Tier 1, there are factors of
22 safety for sliding and overturning.

23 MR. XU: Yes, 1.1.

24 MEMBER SKILLMAN: Do these two bullets
25 point to a modification in the base design in order to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assure that the factors of safety for sliding and
2 overturning are maintained?

3 MR. XU: Yes, they are credited because
4 they need to meet 1.1, factor of safety.

5 MEMBER SKILLMAN: So, without these --

6 MR. XU: Without that, they may not be
7 able to meet. They have a range of soil conditions.
8 So, for some of the conditions, they may not be able
9 to meet them.

10 MEMBER SKILLMAN: So, these shear keys
11 will be a required design feature in order to meet the
12 Tier 1, sliding and overturning factors of safety?

13 MR. XU: I think it is their design
14 features, yes.

15 MEMBER SKILLMAN: Okay. Thank you.
16 That's all. Thank you.

17 MR. XU: Go to the next slide, please, the
18 last one. Yes, this is the last slide. Okay.

19 This slide addresses the soil pressures on
20 the wall and, also, the varying pressure capacities.
21 AREVA considered the pressure using the SSA analysis
22 because their whole model considered environment. So,
23 that would address the pressure induced on the side.

24 And also, AREVA uses the SC-498 guidance
25 there, requirements, which is the elastic solution,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 which is considered as upper bound in terms of the
2 soil pressures, is the elastic absorption. So, it is
3 considered upper bound.

4 And also, the wall will be designed to the
5 passive pressure capacities, and that is conservative.

6 Okay. But there is an open item because
7 they haven't finished the design yet. for all the
8 structures, for the NI and the non-NI Cat. I
9 structures. So, in terms of bearing pressures and the
10 pressures on the wall, they haven't finalized that
11 yet. The design has yet to be completed.

12 CHAIR POWERS: I am intrigued by your
13 nomenclature, Boussinesq effects.

14 (Laughter.)

15 That is because your loads are on the
16 edges in the oil cans in between? Is that what you
17 are talking about there?

18 MR. XU: Yes.

19 CHAIR POWERS: So, you get a little more
20 deflection in the middle?

21 MR. XU: Right. Yes.

22 CHAIR POWERS: Once again, I come back to
23 floating nuclear power plants.

24 (Laughter.)

25 Has anybody ever thought of that before?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. XU: That's my last slide.

2 CHAIR POWERS: I understand, by the way,
3 that the Russians are trying that again.

4 Are there any more questions on this
5 subject?

6 (No response.)

7 Well, again, for the record, that was an
8 extraordinarily informative presentation and very
9 helpful. Very helpful, indeed.

10 Okay. We are coming to the end of the
11 day's session.

12 MEMBER STETKAR: Dr. Powers?

13 CHAIR POWERS: Yes, sir?

14 MEMBER STETKAR: I have questions on other
15 parts of Chapter 3 that weren't covered.

16 CHAIR POWERS: Tomorrow morning we will go
17 over --

18 MEMBER STETKAR: But, in terms of the
19 staff making sure they have the correct subject matter
20 experts here, I thought it might be useful --

21 CHAIR POWERS: That would be very useful.

22 MEMBER STETKAR: -- to quickly do that.
23 Otherwise, we are going to address them Thursday
24 morning.

25 CHAIR POWERS: No, you are quite correct,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it would be very useful right now --

2 MEMBER STETKAR: Thank you.

3 CHAIR POWERS: -- to expand extensively on
4 that.

5 MEMBER STETKAR: Just to make sure
6 Getachew knows the right people.

7 Dick and I brought up one already that I
8 think you have, this notion of classification of SSCs
9 according to safety-related, important-to-safety,
10 risk-significant, whatever that issue is, that one
11 open item, and how that relates differently perhaps to
12 seismic classification versus analyses that are
13 performed for protection against flooding or wind or
14 other sources of damage.

15 The one that I brought up earlier this
16 morning related to straightline wind loading and the
17 basis for acceptance of a 100-year return interval for
18 straightline wind loading versus what the Reg Guide
19 seems to say is 10-to-the-minus-7 criterion. So,
20 whoever it the wind-loading people would be good for
21 that one.

22 Bear with me until I find the rest of my
23 notes here.

24 External flooding, questions about margins
25 to probable maximum flood level and what a probable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maximum flood might mean; in particular, what the
2 exceedance frequency of a probable maximum flood might
3 be. So, whoever your external flooding folks are.

4 Turbine missiles, the question that I
5 raised with the applicant regarding why this is
6 concluded to be a favorably-oriented plant.

7 And then, the one minor one that I brought
8 up regarding in-service testing of main steam
9 isolation valves, the conclusion that it isn't
10 necessary to check leakage in the reverse direction,
11 because that was a response to an RAI. I guess I
12 don't understand the conclusion on that.

13 I think that is all the major ones that I
14 have. Okay. Thanks.

15 CHAIR POWERS: Any other questions that we
16 should pass on to the staff?

17 MR. TESFAYE: I have a question for
18 clarification on Question No. 2 on straightline wind-
19 loading, the 100 --

20 MEMBER STETKAR: Yes. I don't know if you
21 were here this morning, but let me see if I can
22 clarify.

23 MR. MIERNICKI: Which section of the SER
24 was that in?

25 MEMBER STETKAR: Oh, it is SER 3.3.1.4.1,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is sort of the general section, but it is 3.3.1.

2 And the question is that Reg Guide 1.221
3 for design basis hurricane wind speed cites a return
4 -- it actually cites what is called an exceedance
5 frequency. So, let's talk about exceedance frequency
6 of 10 to the minus 7 events per year, which is
7 consistent with the exceedance frequency for design
8 basis tornadoes. In fact, the applicant has based
9 their tornado wind-loading on a 10-to-the-minus-7
10 exceedance frequency or once in 10-million-year
11 recurrence interval, if you want to think of it that
12 way.

13 However, the design basis straightline
14 wind-loading, which is based on a 3-second gust from a
15 straightline wind, the design basis for this design is
16 derived from an ASCE SEI standard, which basically
17 takes a 50-year recurrence interval, multiplies it by
18 a factor, and says, well, that is equivalent to a 100-
19 year recurrence interval.

20 And the concern is, why are we using a
21 100-year recurrence interval for the design basis?
22 And I have seen arguments made, well, that is a rare
23 event. Well, if the plant operates for 60 years, if
24 it is a once-in-a-hundred-year event, there is a 60
25 percent probability that we are going to exceed that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design basis, which to me is not a rare event. It is
2 sort of a countable event.

3 So, that is sort of the notion of that
4 line of questioning --

5 MR. TESFAYE: No, I got it.

6 MEMBER STETKAR: -- of, are we being
7 consistent here in establishing the straightline wind-
8 loading for this design versus tornado or other parts
9 of the guidance?

10 MR. TESFAYE: Thank you.

11 MR. MIERNICKI: No other questions? Okay.
12 We will try to bring those back first thing in the
13 morning then, if I can track down the staff.

14 MEMBER STETKAR: I just wanted to make
15 sure you had, because you need to go see if you have
16 the right people here, or whether they are even
17 physically here.

18 CHAIR POWERS: Well, that brings the
19 session for today to a close. I thank everyone for
20 extraordinarily good presentations. It kept us right
21 on the edge of our chairs throughout. Most
22 interesting and quite enjoyable, actually.

23 With that, we will recess until tomorrow.

24 I will remind you that our Thursday agenda
25 is a bit disrupted because the members of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Subcommittee have a briefing to attend with the
2 Commission, which somehow outranks us. I don't
3 understand quite why.

4 (Laughter.)

5 MR. TESFAYE: Actually, we are ahead of
6 time. We have completed a day-and-a-half worth of
7 presentation.

8 CHAIR POWERS: Yes. I don't think we are
9 tight, by any means on this.

10 MR. TESFAYE: Yes, yes.

11 CHAIR POWERS: And that is a bit by
12 design, thanks to Ms. Weaver's excellent guidance and
13 suggestions. We would be rudderless without her.

14 So, we will see you all tomorrow morning
15 bright and early and chipper and bright-eyed and
16 bushy-tailed.

17 (Whereupon, the above-entitled matter went
18 off the record at 3:52 p.m.)
19

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
U.S. EPR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, February 22, 2012

Work Order No.: NRC-1468

Pages 1-242

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

+ + + + +

U.S. EPR SUBCOMMITTEE

+ + + + +

WEDNESDAY

FEBRUARY 22, 2012

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Dana A.
Powers, Chairman, presiding.

COMMITTEE MEMBERS PRESENT:

- DANA A. POWERS, Chairman
- CHARLES H. BROWN, JR., Member
- MICHAEL T. RYAN, Member
- STEPHEN P. SCHULTZ, Member
- JOHN STETKAR, Member
- GORDON R. SKILLMAN, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT:

2 KATHY WEAVER, Designated Federal Official

3 JILL CAVERLY, NRO

4 GORDON CURRAN, NRO

5 GREG HACKETT, NRO

6 BRAD HARVEY, NRO

7 PETER HEARN, NRO

8 RAUL HERNANDEZ, NRO

9 JOHN HONCHARIK, NRO

10 JASON HUANG, NRO

11 PETER KANG, NRO

12 MICHAEL MIERNICKI, NRO

13 AMRIT PATEL, NRO

14 HAHN PHAN, NRO

15 THOMAS SCARBROUGH, NRO

16 JOHN SEGALA, NRO

17 GETACHEW TESFAYE, NRO

18
19 ALSO PRESENT:

20 GREG BANKEN, AREVA NP

21 BILL BRACEY, AREVA NP/Transnuclear

22 DAVID FOSTER, NUMARC

23 DARRELL GARDNER, AREVA NP

24 GEORGE IFEBUZO, AREVA NP

25 MIGUEL MANRIQUE, AREVA NP/Transnuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

IAN McINNES, AREVA NP/Transnuclear

BRIAN McINTYRE, AREVA NP

PRAKASH NARAYANAN, AREVA NP/Transnuclear

DENNIS NEWTON, AREVA NP

TODD OSWALD, AREVA NP

NITIN PANDYA, AREVA NP

TIM STACK, AREVA NP

PAVAN THALLAPRAGADA, AREVA NP

DENNIS WILLIFORD, AREVA NP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

| | | |
|----|-----------------------------------------|-----|
| 1 | C-O-N-T-E-N-T-S | |
| 2 | Opening remarks and Objectives | 5 |
| 3 | | |
| 4 | NRC Staff Opening Remarks | 7 |
| 5 | | |
| 6 | U.S. EPR DC Application FSAR Chapter 3, | |
| 7 | Design of Structures, Components, | |
| 8 | Equipment and Systems | |
| 9 | (continued from Day 1) | 8 |
| 10 | | |
| 11 | U.S. EPR DC Application FSAR Chapter 9, | |
| 12 | Auxiliary Systems, Section 9.1, | |
| 13 | Fuel Handling &Storage | 156 |
| 14 | | |
| 15 | | |
| 16 | | |
| 17 | | |
| 18 | | |
| 19 | | |
| 20 | | |
| 21 | | |
| 22 | | |
| 23 | | |
| 24 | | |
| 25 | | |

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

1
2
3 CHAIR POWERS: The meeting will now come
4 to order. This is the second day of our meeting of
5 the Advisory Committee on Reactor Safeguards U.S. EPR
6 Subcommittee. I'm Dana Powers, chairman of the
7 subcommittee.

8 ACRS members in attendance are Steve
9 Schultz. Welcome Steve. This is your first EPR
10 meeting.

11 MEMBER SCHULTZ: This is my first.

12 CHAIR POWERS: Well, we have an excellent
13 group of presenters here and a more than adequate
14 subcommittee so you'll enjoy yourself. I guarantee
15 it. Dick Skillman, John Stetkar, Mike Ryan, Kathy
16 Weaver.

17 Of the ACRS staff and still a designated
18 official for the meeting and Charles Brown is here,
19 even if he is neglected in my opening statement.

20 MS. WEAVER: Sorry I neglected you,
21 Charlie.

22 MEMBER BROWN: Just transparency, that's
23 all it is.

24 CHAIR POWERS: That's right. It's one of
25 those digital things, it's on or off with things like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that.

2 MEMBER BROWN: Nobody sees us electric --

3 CHAIR POWERS: That's right. All of the
4 constraints I talked about yesterday still apply --
5 you were Kathy. We do encourage participation in the
6 meeting, both from the presenters and those in the
7 audience that have something to contribute.

8 However, you are required to identify
9 yourself and speak with sufficient clarity and volume
10 so that you may be readily heard. We request that
11 participants on the bridge line also identify
12 themselves when they speak, and keep their telephone
13 on mute during times when they are just listening.

14 Portions of this meeting may need to be
15 closed to the public in order to protect proprietary
16 interests.

17 I will ask the staff and the applicant to
18 be careful to identify when they need to close the
19 meetings because I will not know, so you need to alert
20 me to that fact. And we will verify that only people
21 with required clearance and the need to know are
22 present.

23 Today we will continue where we left off
24 our discussions yesterday and that's with the latter
25 portions of Chapter 3, where the committee had some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 questions that need to be addressed. And so I will
2 call on Getachew Tesfaye to begin the meeting.

3 MR. TESFAYE: Thank you, Mr. Chairman.
4 Like indicated yesterday, we had provided the
5 background information on EPR Design Certification
6 Phase 3 activities.

7 Yesterday we finished the formal
8 presentation of Chapter 3. And today we will start
9 with the staff responding to the five questions that
10 was asked at the end of the presentation, Mr. Stetkar.

11 And then we proceed with Chapter 9 presentation this
12 morning.

13 CHAIR POWERS: Okay. We're going to go
14 with you guys first on 9?

15 MR. TESFAYE: We're going to go first and
16 then AREVA may want the opportunity to address some of
17 the questions after us on Chapter 3. And then we
18 start with AREVA's Chapter 9 presentation.

19 CHAIR POWERS: Okay. Yes, we're going to
20 have several questions but let's go ahead and get
21 started.

22 MR. TESFAYE: Okay, Mike?

23 MR. MIERNICKI: Okay. This is Mike
24 Miernicki on the Chapter PM for Chapter 3. As
25 Getachew said, we're going to start with responses to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some of the questions that the ACRS had yesterday,
2 five questions particularly. And we're going to try
3 to take them in order so staff can go to other
4 meetings that they have scheduled.

5 CHAIR POWERS: What, you mean they would
6 prefer to be someplace else?

7 MR. MIERNICKI: They actually have some
8 other meetings.

9 CHAIR POWERS: But they could be here with
10 us.

11 MR. MIERNICKI: Well, they may come back
12 after their other meetings.

13 CHAIR POWERS: Oh, I see, grab their
14 coffee and come in here.

15 MR. MIERNICKI: Yes. Okay, the first one
16 we're going to start with, which is a question Mr.
17 Stetkar had, which was related to the design basis
18 wind loading for the EPR and what was described in the
19 SER. We have Grant Harvey to discuss that. That
20 question had to do with design loading and
21 probabilities of light. So, Brad?

22 MR. HARVEY: Okay, yes, my name is Brad
23 Harvey. I'm from the hydrology and meteorological
24 branch with the new Office of New Reactors. And I
25 have handouts -- can we work off of this?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Yes, we can do that.

2 MR. HARVEY: I apologize. I don't think I
3 have enough to go around for everyone in the audience.
4 This came up as a little short notice. I'll wait for
5 the committee members to get their copies.

6 CHAIR POWERS: That's okay, just charge
7 right ahead.

8 MR. HARVEY: Okay. What I'm giving you is
9 a handout from a presentation that was made last
10 August to ACRS Subcommittee meeting on regulatory
11 policy and practices, was in the August time frame and
12 had to do with the subcommittee review of a new Reg
13 Guide 1.221 on design basis hurricane and hurricane
14 missiles.

15 And what I'm trying to show here on this
16 slide is that there are basically two design points
17 when it comes to wind loading, a severe environmental
18 load, and the extreme environmental load.

19 And these definitions are from ACI,
20 American Concrete Institute Standard 349-97, which has
21 been endorsed by Reg Guide 1.142 which describes the
22 accepted methods for design and safety made of
23 concrete structures.

24 And basically there are two wind design
25 points. One is the severe environmental load,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sometimes called the operating basis wind, which is a
2 100-year return period or 10^{-2} per year return
3 frequency.

4 The other one is called an extreme
5 environmental load, otherwise sometimes known as the
6 design basis tornado, and that's been defined in Reg
7 Guide 1.76 as a 10^{-7} per year probability.

8 So we've got two design basis wind loads
9 and basically they're used in different load
10 combination and load factors when you're evaluating
11 the capacity of the SSCs to survive severe winds.

12 If you look at the operating basis wind,
13 you'll see a combination of different load factors,
14 dead loads, live loads, fluid loads, soil loads. But
15 you also see that there's a 1.7 times wind load. So
16 there's a load factor, 1.7.

17 You can look at it again, the definition
18 of a severe environmental load from the ACI standard,
19 it's an environmental load that could infrequently be
20 encountered during the plant life. So it is a load
21 that you can, on occasion, expect to be exceeding.

22 As opposed to an extreme environmental
23 load that is considered credible but highly
24 improbable. So that is a load that you generally
25 would not expect the plant to experience.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So you see for these three environmental
2 loads, the W term there in the last column has got a
3 load factor of 1.7. But if you go down to the extreme
4 environmental load, you have basically somewhat the
5 same combination of loads being considered
6 simultaneously, but without any load factors in front
7 of them.

8 Now this column on the right is not
9 necessarily what the EPR is designed to. But it is
10 what's load combination, load factors that are from
11 the ACI standard.

12 So the operating basis for wind load, I
13 understand is 145 miles an hour for the EPR, which is
14 basically a Category 3 storm, if you look at the ASCE
15 standard. And the 10^{-7} per year wind speed with
16 tornadoes is 230 miles an hour.

17 MEMBER STETKAR: I'm not a structural
18 engineer by any way, shape or form, you said that the
19 EPR is not necessarily designed to the wind loading
20 combinations in that right hand column, is that --

21 MR. HARVEY: Yes, that was --

22 MEMBER STETKAR: Do you know, do they
23 apply these factors?

24 MR. HARVEY: I'll have to leave that to my
25 Chapter 3 cohorts.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I mean my question was,
2 since I don't have a sense of how these load factors
3 apply in practice, if they were designed to this, I
4 was going to ask what would the equivalent wind speed
5 be if the factor, including the factor.

6 In other words, how does that 145 mile per
7 hour wind scale-up, accounting for the 1.7 load
8 factor? It's the square of the speed.

9 MR. HARVEY: Yes, mathematically.

10 MEMBER STETKAR: And this were, so I
11 didn't do that so I don't know what --

12 MR. HARVEY: I confess, I haven't done
13 that before but --

14 MEMBER STETKAR: Not a lot. It sounds
15 like it would be about 155 or 60, I assume.

16 MR. HARVEY: No, I think it would be
17 higher than that.

18 MEMBER STETKAR: Would it be higher?

19 MR. HARVEY: I think it would be higher
20 than that.

21 MEMBER STETKAR: I didn't know. I didn't
22 do the math. But if they didn't design it to this
23 then I'm not sure what --

24 MR. HARVEY: Well, I think it's also
25 designed to an extreme environmental role.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It is, but only a certain
2 set of buildings. That's my concern, is the rest of
3 the buildings, is my understanding, the design to the,
4 let's call it the 145 with something wind right now.
5 And since I don't know where every piece of equipment
6 and electrical cable is routed in the power plant.

7 My concern was what margins do we have for
8 damage to structures that may not contain "safety-
9 related" equipment and cables, that may contain
10 equipment and cables that could be important to risk,
11 just because I don't know where they are.

12 So I'm interested in what sort of margin
13 do we have given that 145 mile per hour starting
14 point, if you want to call it that, with a nominal
15 100-year return period. And that all goes into what
16 factors they've applied on the loading and how the
17 analysis was actually done.

18 MR. HARVEY: Yes, I'm going to pretend
19 there's a Chapter 3 so I don't pretend to know that
20 for sure. But I do know for the design basis tornado,
21 you are taking into consideration structures by that.

22 MEMBER STETKAR: They did and then they
23 took into considerations the impacts, but only from
24 the perspective of protecting the Class 1 structures,
25 not for essentially pardoning the non-Class 1

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structures.

2 MR. HARVEY: Right. I do not have an
3 answer for you. That's not really in my --

4 MEMBER STETKAR: But this helps at least
5 to give some confidence that there are margins for
6 that, as you characterized, an operating basis load,
7 so that even if it does have a once in 100-year
8 reference period. Or it, as I had mentioned
9 yesterday, that translates into a 60 percent
10 probability of exceeding that wind over a nominal 60
11 or lifetime of the plant.

12 Even with that there's still some margin.
13 Now it's a matter of understanding in their design
14 what that margin is and how does it translate into an
15 expected reference interval, expected concurrence
16 frequency.

17 CHAIR POWERS: Well, I find this
18 exceptionally confusing. This just has not helped me
19 at all. I must be missing something. For the
20 operating basis, we put a lot of factors in front of a
21 bunch of terms, which presumably give us margin. And
22 for the design basis, we don't.

23 Some of those terms, I presume are
24 constants. Dead loads, I presume don't change and
25 whatnot. But then some of them do. And we introduce

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a new factor into the design basis, a T naught factor
2 and we replace W with W sub t.

3 And when I go to the next page, I learn
4 that WT equals W sub p, except when it doesn't. WT
5 then equals W sub w, plus a half of W sub p plus W sub
6 m, which suggests to me that W sub w plus W sub m
7 equals one-half W sub p, which makes no sense when I
8 look at the definition.

9 I can't imagine that there's any
10 relationship between the two. So could you help me
11 understand what I'm looking at here? What is the wind
12 load associated with the design basis tornado?

13 MR. HARVEY: The second page here shows
14 you, you're looking at, I believe both the two
15 equation shown as taking the more severe of the two.
16 Or making sure you can withstand both. So the first
17 one, WT equals WP is a change in pressure associated
18 with a tornado passage.

19 CHAIR POWERS: Yes, that's what it says.

20 MR. HARVEY: Okay, so we've got certain
21 rooms that if they're not designed to be vented, to
22 reduce the difference in pressure between the
23 atmosphere and the room, then they should be able to
24 withstand that pressure change.

25 CHAIR POWERS: Okay. I believe that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What is the wind pressure difference for 10^{-7} tornado,
2 and how would one ever determine that?

3 MR. HARVEY: It's a site parameter.

4 CHAIR POWERS: How could anybody possibly
5 determine a 10^{-7} tornado?

6 MR. HARVEY: Well, we have a Reg Guide on
7 that and the NUREG looking at a statistical --

8 CHAIR POWERS: I'm sure you do. I'm still
9 wondering how could one possibly determine, it's three
10 orders of magnitude extrapolation from any database
11 you could possibly have.

12 MR. HARVEY: The way that it's done is
13 it's two-fold. Number one, we looked at the
14 probability of a strike at any given structure
15 facility point, typically that may be, you look at it
16 for a given year, the area was covered by tornado
17 strikes, dividing by the size of the area of concern.

18 And typically that's maybe 10^{-4} per year
19 probability, typically throughout the United States,
20 certain areas are higher. And then once you have that
21 tornado strike, then you look at the 10^{-30} wind speed
22 that would have occurred.

23 And you see a combination of the two, is
24 how you come to the 10^{-7} . So there is a database of
25 50, 60, 1,000 tornadoes that have occurred since 1950

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through 2004 or '05, which was used in the NUREG to
2 come up with the statistics for that wind speed.

3 MEMBER STETKAR: The ten to the minus, you
4 can actually compute 10^{-7} , according to the NUREG,
5 which it basically overlays geometries, 10^{-7} strike
6 probabilities for high winds, depending on how you do
7 the math, whether you use exceedance curves or things
8 like that from 50 years worth of data, even within a
9 reasonable area. That's possible to do.

10 It's not possible to do for some sites in
11 more tornado-prone areas. It's a little more
12 difficult. It's really difficult to compute 10^{-7}
13 straight line wind exceedance frequencies. That's
14 much, much, much, much, much more different,
15 difficult.

16 And that's some of the reason for my
17 concern about, because you do apply in the NUREG
18 Guide, you know, a 10^{-7} hurricane wind exceedance
19 frequency, we had some discussions regarding that with
20 the Reg Guide.

21 The fundamental problem is that a 10^{-7} -
22 type screening criteria is applied for a lot of
23 things, not every external hazard these days.

24 And when you see exceedance frequencies on
25 the order of once in 100 years, which is substantially

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 above that 10^{-7} threshold, then you start to think
2 about what could be damaged by those winds. And what
3 kind of margin do you have for that damage.

4 And you either get the square root of 1.7,
5 it comes out to 189 miles per hour, which is a pretty
6 substantial wind. But I'm not a structural engineer
7 and I don't know what they did.

8 At least from my perspective it helped me
9 understand a little bit more about the types of
10 margins that may be put into the design for these
11 operating basis means, that's helped a bit. I'd like
12 to understand a little bit better what EPR did with
13 their design. And I think perhaps somebody, who had
14 somebody standing up there who might help with that.

15 MR. OSWALD: Good morning, this is Todd
16 Oswald from AREVA. We do use the ACI 349 load
17 combinations. I thought I heard some discussion that
18 we may not be using them.

19 MR. HARVEY: I don't know what you used or
20 didn't use.

21 MR. OSWALD: Okay, right. I just want to
22 make it clear that we are using the ACI 349 load
23 combinations and we do apply the load factors in
24 concrete design.

25 MEMBER STETKAR: Todd, could you back out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for me because as I said, I'm not a structural
2 engineer. Without the load factors, what is the
3 equivalent wind speed that those buildings were
4 designed to? In other words, if there weren't the
5 load factors applied?

6 MR. OSWALD: Well, in the operating basis,
7 it is that 145 mile an hour wind. And then we add the
8 load factor, the 1.7.

9 MEMBER STETKAR: But the 1.7 is not a
10 direct scale on the wind speed is it?

11 MR. OSWALD: No. It's on the pressures.

12 MEMBER STETKAR: It's on the pressures.
13 So just for my help, if you didn't -- how to explain
14 this -- what is the equivalent wind speed for your
15 design if you didn't have the load factors applied?
16 Follow what I'm asking? In other words, if the
17 equation had no load factors applied, you have a
18 design?

19 MR. OSWALD: Correct.

20 MEMBER STETKAR: I mean you have the
21 design that's based on those load factors. Can you
22 back out the equivalent wind speed for that design,
23 just the basic wind load?

24 MR. OSWALD: Yes, but the wind loading is
25 a function of the square. The velocity, I could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably work backwards and --

2 MEMBER STETKAR: That's what --

3 MR. OSWALD: But the basic wind speed is
4 145 and then we use the 1.7 on top of that. So I
5 could go back and work for a few minutes and come up
6 with a --

7 MEMBER STETKAR: Yes, that's what I'm
8 asking. If you could do that, that would help a
9 little bit because it would --

10 MALE PARTICIPANT: Use .15 also.

11 MEMBER STETKAR: That's why I'm asking and
12 I don't know which loading is the driving force. So
13 if you could kind of go back through your calculations
14 and back out an equivalent, just direct wind speed
15 load.

16 MR. OSWALD: Okay.

17 MEMBER STETKAR: That would help me, at
18 least, understand a little bit of the design margin
19 above this 145 mile per hour wind speed, which is a,
20 you know, a calculated one in a 100-year return
21 period. And if there's quite a bit margin, that'll
22 help me at least understand, in regard to the design.

23 MR. OSWALD: Right.

24 MEMBER STETKAR: Again, if you can't do it
25 today, fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. OSWALD: Right, I understand.

2 MEMBER STETKAR: We're here tomorrow
3 morning, if you can't do it by tomorrow morning, I'll
4 defer to Dr. Powers here as the Subcommittee chairman,
5 that we can revisit it at another meeting.

6 MR. OSWALD: Okay, all right.

7 MEMBER STETKAR: Thanks. Is that okay,
8 Dan?

9 CHAIR POWERS: Yes, and then you can
10 explain to me what in the world is going on here.
11 This is basically opaque to me. Please continue.

12 MEMBER STETKAR: At least we're not
13 talking about floods.

14 CHAIR POWERS: Oh, you say floods are more
15 difficult? I want to float this nuclear plant.

16 MEMBER SCHULTZ: But Brad, on Page 2 of
17 the presentation you mentioned that the combined
18 tornado load, a factor --

19 MEMBER STETKAR: Brad, just be careful
20 that you're --

21 MEMBER SCHULTZ: -- are governed by the
22 two equations. And the approach would be to take the
23 maximum --

24 MR. HARVEY: Yes, make sure, yes.

25 MEMBER SCHULTZ: -- for the total tornado

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 load, which it generally governs, of those two
2 equations?

3 MR. HARVEY: I would suspect the second
4 but I don't know for sure. I would have to ask the
5 structural people if they can give a more definitive
6 answer.

7 MEMBER STETKAR: The key here, Steve, you
8 weren't here yesterday, I don't want to prejudice
9 anything, but I understand what they do with a Class 1
10 and the design of those are always dominant. I'm not
11 sure which of the two equations are dominant or
12 control the loading. But they're determined by the
13 tornado wind loading which is 230 miles per hour and
14 that's a really good tornado.

15 MEMBER SCHULTZ: That's the first
16 consideration in --

17 MEMBER STETKAR: So in terms of the
18 certified design bounding sites in the U.S., but
19 tornado loading, which always dominates straight line
20 wind loading on Category I structures, you're okay.

21 The problem is there aren't a lot of
22 Category I structures. There's a lot of non-Category
23 I structures that make the auxiliary building, that
24 waste building which is from a real safety
25 perspective, probably isn't all that important,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 turbine building, don't know what's in the switchgear
2 building, stuff like that.

3 MEMBER SCHULTZ: I understand what you're
4 looking for.

5 MEMBER STETKAR: And there I'm not sure
6 where we'll have the margins because they don't have
7 to account for the tornado wind loadings on those,
8 except for structure interactions, but those are
9 fairly easy to demonstrate, not claim to damage the
10 Category I.

11 DR. FOSTER: You are designing --

12 MEMBER STETKAR: If you have something,
13 you actually have to go on the record here.

14 DR. FOSTER: David Foster, consultant to
15 the NRC. In the FSAR, AREVA has committed to design
16 the NAB for the full tornado load.

17 And the access building, turbine building,
18 it's a conceptual commitment in the FSAR, that they
19 also will be designed for the full tornado load. But
20 the COLA has to confirm that the access building and
21 turbine building will not interact, either under
22 seismic or tornado loads that the seismic Category I
23 structure.

24 MEMBER STETKAR: But from what I, in fact,
25 I asked earlier about that yesterday. And my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 understanding is those structures are designed --
2 AREVA will have to help me here -- are designed for
3 the tornado load only to the extent that tornado
4 loading will not cause structure/structure
5 interactions.

6 So for example, if the NAB, let's pick an
7 example, in fact, in the FSAR, they also had the
8 turbine building in there. If the NAB is hit with a
9 230 mile per hour tornado, will the NAB survive?

10 DR. FOSTER: You are correct. The NAB has
11 two requirements in the FSAR. One is that it will
12 have the equivalent, I don't know if I've got the
13 words exactly correct, but equivalent factor safety or
14 designed to the same standards as a seismic Category I
15 structure for a tornado. So for a tornado load, it
16 has to be designed to take the full tornado load.

17 Secondly, AREVA said there could be either
18 sliding or uplift, and for that they have to verify
19 that there will be no interaction with a seismic
20 Category I structure.

21 So first, for structural integrity it has
22 to be designed for the full tornado load. And
23 secondly, they have to verify that there's no
24 interaction, due to the tornado wind on the NAB that
25 would cause an interaction with a seismic Category I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 structure.

2 MEMBER STETKAR: Is that also true of the
3 turbine building?

4 DR. FOSTER: For the turbine building and
5 access building, as far as design requirements go, the
6 conceptual information in the FSAR, is that they will
7 be designed as if they were seismic Category I
8 structures for tornado load.

9 MEMBER STETKAR: Yes, see I excerpted a
10 response to an RAI that basically says that.

11 DR. FOSTER: Yes.

12 MEMBER STETKAR: You know, July 29, 2010
13 response to RAI 384, question 030302-5, the applicant
14 stated that the NAB, nuclear auxiliary building, ACB,
15 access building and TB, turbine building would be
16 analyzed and designed using Reg Guide 1.76, tornado
17 wind characteristics. And would be designed to the
18 codes and standards associated with seismic Category I
19 structures, so that the margin of safety is equivalent
20 to that of a seismic Category I structure.

21 And I was pretty happy with that except
22 that I asked AREVA about this yesterday and perhaps I
23 misinterpreted it, but I thought that they said that
24 that's only for building/building interactions.

25 Well, let me just ask, is your turbine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 building designed to withstand a 230 mile per hour
2 tornado wind loading without structural damage?

3 MR. OSWALD: This is Tom Oswald with
4 AREVA. Let me clarify yesterday, the structural
5 design is per the Nuclear Safety Codes, and load
6 combinations, and the design loading values.

7 We do that because of the potential for
8 structural interaction. I think where the confusion
9 is coming in, yesterday we were talking about the
10 nuclear auxiliary building and the components in there
11 would be designed per Reg Guide 1.143.

12 So all of the items that are rad waste,
13 you know, contain rad waste material would meet the
14 requirements of Reg Guide 1.143, which is essentially
15 one-half the SSE. But because of structural
16 interaction, the structural design will be per ACI
17 349, AISC N690, and all the associated load
18 combinations.

19 So that's the only way we can show the,
20 right now, the same margin of safety, is to go with
21 the Nuclear Safety Codes.

22 MEMBER STETKAR: I'm sorry. I'm not a
23 structural engineer --

24 MR. HARVEY: Can I, is it okay if I leave?

25 MEMBER STETKAR: Yes, and thanks a lot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm neither a structural engineer nor an attorney. So
2 I'm mostly interested in, if by hit, the nuclear
3 auxiliary building, since you want to focus on that
4 first, with a 230 mile per hour tornado, will that
5 building have any structural damage?

6 MR. OSWALD: No. Todd Oswald, it will be
7 an elastic response --

8 MEMBER STETKAR: Thank you.

9 MR. OSWALD: -- for the nuclear case.

10 MEMBER STETKAR: That's good. How about
11 the turbine building?

12 MR. OSWALD: It will also be an elastic
13 response for the Nuclear Safety related codes. It
14 will not be damaged.

15 MEMBER STETKAR: Okay, thanks. Thank you.
16 That helps. If you can back out those equivalent
17 wind loads, I'd appreciate it, the equivalent wind
18 speed. But that helps a lot. I'm sorry, Dan.

19 CHAIR POWERS: That's fine.

20 MEMBER STETKAR: I'm being dense.

21 CHAIR POWERS: You're dense? I don't
22 understand it at all. It helped you. It just
23 confused me. Well, the last statement --

24 MEMBER STETKAR: Oh, that's right.

25 CHAIR POWERS: The statements are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confidence builders at least.

2 MEMBER STETKAR: That's right. I get to
3 write the letter, don't I?

4 CHAIR POWERS: Yes you do. Please
5 continue.

6 MR. MIERNICKI: Okay. The second question
7 we'd like to address was the external flooding
8 question, the margin to the probable maximum flood
9 level and how that is used by the staff. And with me
10 here we have Greg Hackett and Jill Caverly to address
11 that question.

12 MR. HACKETT: Greg Hackett, again. The
13 chief of the hydrology and meteorology branch. I'm
14 not really sure who asked the question, but if you
15 could clarify for me the specifics of your concern,
16 maybe it will help me respond in a more appropriate
17 way?

18 MEMBER STETKAR: Yes, what I'm trying to
19 understand is margins and how we understand those
20 margins, kind of in the context of the same discussion
21 we just had on winds.

22 We design plants based on probabilistic
23 seismic hazard curves, based on a certain ground
24 acceleration at a certain annual frequency, or
25 exceedance frequency. We have criteria for tornado

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wind loads that are based on a 10^{-7} recurrence interval
2 for a tornado of a certain severity.

3 We design plants according to straight
4 line wind loading, which was the discussion we were
5 just having about a nominal 100-year recurrence
6 interval with some margins applied.

7 For external flooding, all I know is that
8 the elevation of something called a probable maximum
9 flood is one foot below finished grade. And we had
10 some discussion yesterday about finished grade versus
11 thresholds. But there's some margin there.

12 The question is what is the frequency of
13 the probable maximum flood? Is it a once in ten-year
14 event? Is it a once in a 100-year event? Is it a
15 once in 10,000-year event, a once in 10 million-year
16 event? What is it?

17 MS. CAVERLY: Well, although it starts
18 with probable in the title -- Jill Caverly, I'm
19 hydrologist in Greg's branch, Jill Caverly, C-A-V-E-R-
20 L-Y.

21 It's a deterministic approach. And it's
22 based on a method that was developed by a group of
23 federal agencies in the 1970s. They were updated in
24 the 1970s, but it's been an ongoing approach.

25 It's endorsed by the Army Corps of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Engineers and the NOAA. And it's an approach to
2 develop a deterministic maximum flood based on
3 hydrometeorological parameters.

4 So it would be, you know, the amount of
5 moisture in a water column in a given area. And it's
6 also based on historical events. So all of this
7 information together provides us with a value of a
8 rainfall curve. And using that, we developed what we
9 think is the largest event possible in a given
10 geographic area. So there's not a probability
11 associated with it.

12 That's in part because probability in the
13 meteorological sense, there's not a lot of data to
14 support a probabilistic approach in developing a storm
15 of that magnitude right now. There are agencies that
16 are trying to go that direction, but we just don't
17 have that sort of information.

18 MEMBER STETKAR: I submit that we do it
19 quite extensively in the seismic area.

20 MS. CAVERLY: Yes.

21 MR. HACKETT: We understand that but we do
22 it deterministically.

23 MEMBER STETKAR: Okay, that helps a little
24 bit. And I understand, at least for the design
25 certification, that it in some sense is an interesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 question at this stage of the game.

2 Because the design certification simply
3 sets a level. It's up to the COL applicant to justify
4 that the site-specific meteorology, and hydrology, and
5 dam failures, and whatever else can cause an external
6 flood will not produce an elevation above that level.

7 I'm just trying to understand, from a
8 certified design perspective, what fraction of the
9 sites in the United States might be prone to floods
10 that could exceed this level. Follow me? If it's
11 something like 50 percent of the sites, which I doubt
12 --

13 MS. CAVERLY: Well, let me just clarify --

14 MEMBER STETKAR: -- then there would be a
15 question about have they specified that margin
16 appropriately in the certification process.

17 MS. CAVERLY: And I should clarify, when I
18 was speaking before, I was talking about a probable
19 maximum precipitation approach. And so that would be
20 the rainfall that input into a system.

21 Then you have to translate that rainfall
22 into a flood. So then there's a hydraulic modeling
23 approach that you would look at to develop an
24 elevation of a flood.

25 And presumably this is the most extreme

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 event that we will see at a site, which is the PMP,
2 would translate it using very conservative parameters.

3 The PMF flood is the most extreme flood that we will
4 see at a given site, at a location that we're
5 analyzing.

6 MEMBER STETKAR: Since it's only
7 precipitation, doesn't it account for dam failures or
8 dam over the top, and the event kind of stuff? Would
9 we consider it --

10 MR. HACKETT: We're starting to get down a
11 different line of questioning. But at the end of the
12 day we look at all "flood causing mechanisms." So it
13 is precipitation, dam failure, you know, a dam failure
14 coincident with a seismic event, the PMF. And through
15 that process, tried to establish the design basis
16 flood for the site and end site, and then correlating
17 that back to the design certification.

18 We don't do an extensive review at the
19 design cert phase with respect to, the safety
20 philosophy is to evaluate where protection is going to
21 be provided for systems, structures, components
22 according to safety.

23 And then take that parameter, if you will,
24 and see if that parameter envelopes any site
25 characteristic that then is established through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis in that particular site, in that particular
2 watershed. And, of course, they're all different.

3 And if, in fact, the site is not dry
4 necessarily, right, then flood protection measures, at
5 some acceptable level, would have to be provided. And
6 that's from a design philosophy, from a safety
7 philosophy, right.

8 Whether it's above that one foot elevation
9 or below it, if it's above it, you still have to
10 provide some protection. And that doesn't mean that
11 if the designer comes in and says the PMF would be one
12 foot below site plant grade, it doesn't mean that the
13 SSCs are one foot above. They could be higher.

14 At the end of the day we still have to go
15 through the assessment and say given all that we know,
16 and if you would go back and look at some of the, they
17 call them the HMRs, you go back and get the reports.

18 As the years have gone by, since the
19 beginning of the evolution of life and plants, that
20 data information has become more robust. It's updated
21 and then you can take that information and apply it.

22 And as you'll see in the coming years,
23 months, that information is going to be applied to the
24 2.1 recommendations under the Fukushima stuff.
25 Because we have now newer information and we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 more, better techniques than we had when we first
2 started doing these analyses.

3 MEMBER STETKAR: Yes, that helps. And
4 then I realize, as I said, that some of this
5 discussion, obviously is more pertinent to the COL
6 because it is a very, very site-specific issue.

7 For the purposes of the design
8 certification, I was only trying to understand a bit
9 of the notion of, is there a frequency sense to the
10 probable maximum flood? And what sort of margin do we
11 have in the certified design, on sort of a frequency
12 of exceedance notion?

13 In the same way that we think of the
14 certified design of margins for frequency of
15 exceedance, applied tornadoes, straight line winds,
16 seismic events and so forth. It's sort of a different
17 --

18 MR. HACKETT: Even at this stage of this
19 particular design review, and I haven't looked at it
20 in great detail, as that design continues to evolve,
21 trying to understand where the SSCs are going to be
22 located.

23 If you don't know where they're all
24 located right now, conceptually, because I don't think
25 design is 100 percent, that margin that you're asking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for is also involved at some level.

2 But again, it becomes very critical at the
3 COL stage to understand how you would decide it. And
4 if you look at various applicants, they can make
5 changes to those designs, ever so slightly, or in a
6 nuance sense.

7 It changes what those elevations are. So
8 even in that sense, right, you'll see a change in how
9 the design and licensing basis is applied for a
10 particular applicant at any particular site.

11 MEMBER STETKAR: Okay, thanks. That
12 helps.

13 CHAIR POWERS: We also have to get to that
14 other meeting. Apparently it has something to do
15 with external events.

16 MR. MIERNICKI: Thank you very much.
17 Okay, next question I wanted to address is the one
18 with respect to 2513, with respect to the turbine
19 orientation of relative, the EPR turbine orientation
20 relative to the central servicewater buildings. And
21 to address that, we have John Honcharik from the
22 component integrity branch.

23 MR. HONCHARIK: Good morning. My name is
24 John Honcharik and I guess, as Mike said, if two out
25 of the four emergency servicewater buildings are in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the load trajectory path of the turbine building, and
2 basically the question is how could that be, I guess
3 considered, maybe for orientation. That's a very good
4 question. I also asked --

5 MEMBER STETKAR: One for three is not bad.

6 MR. HONCHARIK: I also asked that question
7 in RAI and the, basically even though those two are in
8 the load trajectory path, they're two that are not.
9 And each of those two are sufficient to have a safe
10 shutdown of the reactor.

11 MEMBER STETKAR: John, let me interrupt
12 because I read that in the SER. It's my
13 understanding, we've had some discussions about this
14 with the applicant. This plant is actually, from a
15 design basis perspective, four 50 percent capacity
16 trains. So a single train doesn't have adequate
17 capacity to shut down the plant, you need two.

18 In fact, the PRA has identified, not only
19 that it's based on two, and it has identified some
20 subtle asymmetries because of requirements to cross-
21 connect, at least electric power supplies, and I can't
22 remember whether it's cooling or ventilation.

23 I think it's chilled water supplies, that
24 not all four divisions are actually equal. Some
25 combinations of divisions are more important from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 risk. So the statement in the SER that any one train
2 can safely shut down the plant seems at odds with the
3 safety analysis and, in fact, with the PRA, which gave
4 me some pause to thought.

5 MR. HONCHARIK: Okay, yes that's something
6 new, because basically that was AREVA's response and
7 they even sent me to the chapter in the EPR, their
8 safety evaluation, safety analysis report, where
9 basically it said that redundant safety systems, one
10 of each safeguard will physically separate into four
11 divisions, okay. And they go on.

12 MEMBER STETKAR: That's true.

13 MR. HONCHARIK: And then say with four
14 safety divisions, one division can be out of service
15 for maintenance. And one division can fail to
16 operate, while the other two remaining divisions are
17 available to perform the necessary safety function,
18 even if one of the two remaining becomes inoperable
19 during an initiating event. So based on that, that's
20 what I was basing it on. So if what you say is
21 different --

22 MEMBER STETKAR: Tim, can you help?

23 MR. STACK: Yes I can. Tim Stack from
24 AREVA. A few things on this event in particular. In
25 general, it takes two safety safeguards trains to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 achieve cold shutdown.

2 When we look at these events and you look
3 at the turbine missile trajectory issues, basically
4 the initiating event is going to be a turbine
5 generator trip. When we look at it, it will not
6 generate a LOCA. It will not generate a feed bind --

7 MEMBER STETKAR: I'm sorry. It looks like
8 a really big steam line break outside containment.
9 It's not a turbine trip.

10 MR. STACK: And it will be --

11 MEMBER STETKAR: Turbine didn't trip.

12 MR. STACK: And it will be isolated though
13 by the MSIV closure --

14 MEMBER STETKAR: If they close.

15 MR. STACK: If they close, that's correct.

16 When we sit and we look at the event though, to keep
17 the plant hot and stable, we really only require one
18 division to keep the plant hot and stable. One of the
19 four to keep the plant hot and stable. To take it
20 cold, you require two.

21 MEMBER STETKAR: Okay, that helps a little
22 bit. However, I come back to the notion that the
23 guidelines in Reg Guide 1.115 -- if I'm in the right,
24 yes, I'm in the right Reg Guide -- are basically
25 screening criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They're screening criteria that are
2 applied on frequencies that have been concluded
3 through some sort of process as providing an adequate
4 margin of safety, without the need to do a detailed
5 analysis of the actual, the real turbine missile
6 ejection, the real probability of striking a
7 particular target, the real damage to the target.

8 And in a risk assessment sequence, an
9 evolution-type process, the sequences could evolve out
10 of each of those possible damage scenarios.

11 Essentially it's a way to say that if you
12 have a favorably oriented turbine, meaning according
13 to the Reg Guide, the missile is ejected out of the
14 appropriate angles, can not hit any safety-related
15 equipment.

16 Then all you need to do is justify that
17 your turbine is good enough to meet a 10^{-4} event per
18 year missile ejection frequency, looking at events
19 that could cause over speed, failure of the turbine
20 stop valve controls, all that other kind of stuff,
21 mechanical failures of the rotor, probabilistic
22 fracture mechanics of the raw materials, and so forth
23 that goes into those analyses.

24 If it's an unfavorable oriented turbine,
25 and the Reg Guide's pretty clear, it says no essential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equipment is within that foot path. Then you're
2 allowed to show, or if it's -- I'm babbling too
3 quickly -- if it's unfavorably oriented then you have
4 to show a factor of ten better margin of safety on the
5 ejection of those missiles.

6 You don't have to do anything else. You
7 don't have to qualitatively justify what the scenarios
8 might be or where you might need to go. It just says
9 you need to justify 10^{-5} .

10 People have been doing this at numerous
11 plants for many years. In my opinion, if you want to
12 make arguments about the types of scenarios that can
13 evolve from different damage conditions, the
14 likelihoods of those scenarios, that's fine, that's a
15 probabilistic analysis. You can do that. People have
16 done that.

17 They typically don't do it qualitatively,
18 with questions about what might be required out of how
19 many divisions that maybe remain, but are undamaged by
20 a particular missile strike.

21 And that's my whole question here is the
22 Reg Guide, at least Rev 2 of the Reg Guide, because of
23 this issue, is very explicit. It's say no safety-
24 related equipment is within that foot print.

25 MR. HONCHARIK: But I think part of it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, I think in the SRP there is a statement in there
2 that says basically, that all or almost all, because I
3 think they realize that if there are redundant
4 systems, not all of them. As long as citizens are
5 available for safe shutdown --

6 MEMBER STETKAR: I've got a plant that has
7 two trains. Is one train almost all?

8 MR. HONCHARIK: Well, if it's --

9 MEMBER STETKAR: Three trains. Is one,
10 South Texas that's three trains.

11 MR. HONCHARIK: But if it's capable of
12 shutting down the reactor. And also, in Rev 2 of the
13 Reg Guide, in the Appendix, you know, we do have in
14 there what structures and components should be
15 protected and part of it is systems, or portions of
16 systems, considering a single failure that are
17 required or obtained for safe shutdown.

18 MEMBER STETKAR: Yes, in fact, AREVA
19 pointed me to the words in the Reg Guide this morning.

20 I didn't look at the words in the Reg Guide, I tend
21 to look at the, I'm sorry the SRP, which is not
22 consistent with the Reg Guide.

23 MR. HONCHARIK: Well, I think the newer
24 version is somewhat consistent.

25 MEMBER STETKAR: You know, somewhat? I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sorry.

2 MR. HONCHARIK: With that inclusion of the
3 Appendix A, about the systems, considering a single
4 failure, so I think that's trying to highlight that
5 it's a single failure. So if you do have well, trains
6 --

7 MR. GARDNER: John, this is Darrell
8 Gardner. I just want to add from an AREVA
9 perspective, that Reg Guide also talked about
10 essential and I think that's the key word, is that
11 those additional analysis you were speaking of were in
12 the context of essential systems.

13 In our response to the SER and to the RAI
14 was, is that only two of those were essential. The
15 other two in the path were not essential under that
16 guidance.

17 MEMBER STETKAR: Right. We'll have to, I
18 think, Dan I'll defer to you here but I think from a
19 subcommittee perspective, instead of taking up more
20 time on this, I think we understand what was done.

21 We just have to decide what we recommend,
22 we'll probably discuss this during the full committee,
23 I would imagine. I don't know where you're at. I'm
24 at a quandary here. I'm not personally inclined to
25 imply that certified design has a problem with turbine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 missiles in terms of safety.

2 I am trying to imply the fact that they
3 should not be given a pass at 10^{-4} turbine missile
4 ejection frequency. Because my understanding of the
5 Reg Guide is that they should satisfy a 10^{-5} turbine
6 missile ejection frequency.

7 Or perform appropriate analyses to justify
8 if their frequency is higher than 10^{-5} , why their
9 damage to safety-related, essential, whatever words
10 you want to use, which is another question we're going
11 to be getting into here.

12 The combination of the missile ejection
13 frequency, the strike probability, and the condition
14 of the damage probability remains less than 10^{-7} .
15 Those are analyses. If they can do those analyses to
16 show that for all the missile ejection trajectories
17 and possible strike targets, they still can satisfy
18 the basic premise, that's fine.

19 MR. HONCHARIK: But I think --

20 MEMBER STETKAR: Or so that the turbine
21 missile ejection frequency is less than 10^{-5} which some
22 plants have to do.

23 MR. HONCHARIK: Right, but I think the
24 basis premise was that you protect systems,
25 structures, and components that are essential for safe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shutdown.

2 So if you have other things that can make
3 up for those systems, if you don't need for a safe
4 shutdown, then even if they are in that path, it still
5 would be considered favorable because the whole point
6 of it, I think is to insure the safe shutdown.

7 MEMBER STETKAR: Usually essential
8 servicewater and decent generators are pretty
9 important to safe shutdown. Two of the diesel
10 generator buildings, the corners of them are within
11 the foot path also. Well, they're the ends of the
12 buildings, I don't know what --

13 MR. HONCHARIK: Right, and those are the
14 fuel tanks.

15 MEMBER STETKAR: Okay.

16 MR. HONCHARIK: But the other two aren't.

17 MEMBER STETKAR: That's right.

18 MR HONCHARIK: Yes.

19 MEMBER STETKAR: If this were the South
20 Texas plant that has three trains and they had one
21 train within the footprint and two other trains
22 available, what turbine missile ejection frequency
23 would be required?

24 MR. HONCHARIK: Well, I'm not sure what
25 each train is capable --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Because you need to do an
2 assessment of the possible damage to see what the
3 actual functional requirements are.

4 CHAIR POWERS: Okay, I think we understand
5 where you stand on that. Let's move on.

6 MR. MIERNICKI: Okay, the next question
7 for the staff to address was relative to the in-
8 service testing of the MSIV. And there was a question
9 regarding what the leakage criteria was, or back-
10 leakage through the MSIV was considered. And for
11 that, responding to that, we have Tom Scarbrough, also
12 from the component integrity branch.

13 MR. SCARBROUGH: Good morning. This is
14 discussed in Section 10.3 of EPR FSAR. And these
15 valves are double-disk gate valves, these main steam
16 isolation valves.

17 And by the requirements in the FSAR, they
18 are required to be capable of closing against 1,320
19 psid in either direction. So they have that
20 requirement as part of their design requirements.

21 And it also specifies that the valve
22 supplier leak test these valves in both the forward
23 and reverse flow directions. So they're required to
24 do that with that pressure.

25 And then, as part of the periodic testing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they are listed in the IC table for a leakage testing
2 on a two-year interval, right. And how they are
3 described is, they actually pressurize the cavity
4 between the disks.

5 And so they'll pressurize it and then
6 they'll, what you can do is you can monitor the
7 leakage and decay over time. So they're actually
8 testing the seam and surfaces on both sides of the
9 valve out. And so that's how they do that.

10 MEMBER STETKAR: Okay, thanks Tom.
11 Because again, I was reading in the FSAR or I'm sorry,
12 in the SER -- you may want to check, I don't know
13 whether you did this or someone else.

14 In Section 3.9.6.4.2.2, there's a summary
15 of an RAI response and what got my attention was it
16 said the applicant indicated failure of the MSIVs to
17 isolate the reverse flow direction does not result in
18 or increase the severity of any credible event.

19 The applicant stated the MSIVs are not
20 required to isolate in the reverse flow direction.
21 And they are leak tested only in the forward flow
22 direction. And that's what got my attention about
23 this reverse flow.

24 Now from what you described, for the way
25 they do the test and indeed, if that's the way they do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the IST, indeed they are testing that valve in the
2 reverse flow direction also, which is fine with me if
3 that's what they're actually committing to. It's just
4 a matter of straightening out the justification here
5 in the SER.

6 MR. SCARBROUGH: Yes, we'll take a look at
7 it --

8 MEMBER STETKAR: Revise it, why, what,
9 their --

10 MR. SCARBROUGH: You want to give me the
11 number again?

12 MEMBER STETKAR: Yes, it's 3.9.6.4.2.2,
13 that's the SER section. And it refers to a response
14 to RAI 49, question 03.09.06-5. So you can go look up
15 the rest that are in there. Thanks, I'm good with
16 that.

17 MR. SCARBROUGH: Okay. We'll fix that.

18 MEMBER STETKAR: If they actually do
19 perform the test the way you described it --

20 MR. SCARBROUGH: But it's in the --

21 MEMBER STETKAR: It doesn't make any
22 difference what the words say here. They're doing the
23 test.

24 MR. SCARBROUGH: Right.

25 MEMBER STETKAR: Because it's clear that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they do need to isolate reverse flow for a blowdown
2 event.

3 MR. SCARBROUGH: Yes and it's clear in the
4 record, so I will check and make sure the language is
5 correct.

6 MEMBER STETKAR: Thank you.

7 MR. MIERNICKI: Okay, and the last
8 question that we have jogged down for the staff to
9 address was related to how the non-safety-related
10 components, that are risk significant, are dealt with
11 and the guidance to applicants with respect to that
12 whole general area.

13 And with that, I think we had Hahn Phan is
14 going to address that -- yes, here he is. And Hahn
15 Phan is with the POA branch.

16 MR. PHAN: Good morning gentlemen. My
17 name is Hahn Phan, elite reviewer of PRA Chapter 19,
18 and Section 17.44, Reliability Assurance Programs.

19 The reliability assurance programs of
20 Section 17.4 captures safety-related and non-safety-
21 related risk significant SSC. The quality control of
22 10 CFR Part 50 Appendix B, Quality Assurance Programs
23 applied to all safety-related SSC, that were becoming
24 to be risk significant.

25 Non-safety-related SSC that are committed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to be risk significant as subjected to the quality
2 controls stated in the SRP Section 17.5 Part V,
3 entitled Non-Safety-Related SSC Quality Controls. So
4 am I answer your question or any additional --

5 MEMBER STETKAR: No.

6 MR. PHAN: Okay.

7 MEMBER STETKAR: The concern was in, and I
8 was trying to understand the staff's philosophy, if
9 you will, in Section 3.2.1 of the SER and 3.2.2 of the
10 SER, there are just quite a bit of discussion about
11 the topic of quality group classification and seismic
12 classification of equipment that is variously termed.

13 I understand what safety-related equipment
14 is. Other terms that appear are equipment important
15 to safety, and the term non-safety-related risk
16 significant SSCs that are important to safety. That's
17 another kind of long term.

18 I think the important to safety, and
19 there's a discussion that the universe of things that
20 are important to safety is largely then the subset of
21 safety-related equipment. Is that right? Am I
22 interpreting that correctly, that safety-related
23 equipment is a subset of the SSCs that are "important
24 to safety?"

25 MR. PHAN: Yes. I am here to answer your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions from PRA's perspective. In PRA space, we
2 only use two terms, safety significant and risk
3 significant.

4 However, the term important to safety,
5 we've been discussing among the staff. So at this
6 point I don't have the clear answer to your question,
7 how to define that term.

8 MEMBER STETKAR: Let's just focus, and I
9 recognize the words are fluid and Dick, very well,
10 highlighted that yesterday. It's important to
11 understand what the words mean. So let's get away
12 from the words. There is a D-RAP list?

13 MR. PHAN: Yes.

14 MEMBER STETKAR: The D-RAP list has
15 numerical criteria, at least from the PRA perspective,
16 there are also subjective criteria for populating the
17 D-RAP list. But there are clear numerical criteria
18 for populating that D-RAP list. So let's just talk
19 about the non-safety-related equipment that's in the
20 D-RAP list.

21 MR. PHAN: Yes

22 MEMBER STETKAR: Because that is, as you
23 state, a numerically definable set of things. There
24 will be a list. There is a D-RAP list.

25 From the perspective of seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 classifications, which is my understanding of several
2 of these questions, and quality group classifications,
3 what is the staff's concern regarding the equipment on
4 the D-RAP list?

5 I honestly couldn't quite understand what
6 the genesis, or the intended endpoint would probably
7 be better, for the questions and kind of the ongoing
8 discussion, as I understand it, I think that there is
9 an open item sort of in this general idea.

10 I'm trying to understand what's being
11 negotiated by that open item. Is it the seismic
12 classification quality group classifications for, in
13 particular the equipment on the D-RAP list? Or is it
14 something broader than that or narrower?

15 MR. PHAN: Right now it is broader than
16 that because in the D-RAP list the staff identifies
17 systems that we believe are important to the plant.
18 And the list is finalized by the panel, not by PRAs or
19 any others.

20 But that includes qualitative and
21 quantitative assessment. So for us right now, we
22 could group by systems level, not just at the
23 component level. So for us, when we include, we
24 include the entire systems, doesn't matter that the
25 seismic qualified components are not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Oh, okay. That is an
2 issue obviously, because we've had some discussions
3 about this in the past, that the quality of the PRA at
4 the design certification stage may not be adequate to,
5 from the PRA part of that process, determine very
6 precisely the risk significance of an individual
7 component.

8 I'm looking at a particular motor operated
9 valve let's say, determining whether the Fussell-
10 Vesely importance of that valve is .0049 or .0051 --

11 MR. PHAN: Yes.

12 MEMBER STETKAR: -- requires perhaps a
13 level of detail and scope in the PRA that may not be
14 developed in the design certification stage.

15 So at least from the PRA perspective,
16 identifying the individual components, which I think
17 I'm hearing your concern as far as quality for that
18 motor operated valve or seismic classification for
19 that motor operated valve, is quite difficult. Okay.

20 I don't know. There is an open item on
21 this. I'm not sure how it will progress. The second,
22 kind of a related question is sort of my, I understand
23 now a bit more of kind of your concern.

24 The second question though was, that if
25 this issue is pertinent to seismic classification and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 quality group assignments, why is the staff not
2 concerned, in the same sense, for protection against
3 things like flooding and other damage sources?

4 For example, if I read the SER with
5 regards to internal flooding protection or pipe
6 failures, in those areas it is very explicitly
7 restricted to only safety-related equipment.

8 There are no questions in there that say
9 well, what about jets from high-energy piping that
10 might affect important to safety equipment rather than
11 only safety-related equipment. What about internal
12 flooding that might affect, or external flooding, that
13 might affect important to safety equipment, not just
14 safety-related. It's strictly focused on safety-
15 related.

16 So in that sense, I'm a bit concerned from
17 a sense of consistency, that if we're having these
18 very, very detailed discussions about seismic and
19 quality group classification on the one hand and not,
20 for other hazards, are we as an agency being
21 consistent.

22 MR. PHAN: Yes. Actually you see from EP
23 RPI, these bottom PIs, especially in the flooding PIs,
24 when EPR assumed that any piping failures would take
25 out entire locations, that includes pipe whip or jet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 impingements.

2 So with that, all the components in the
3 locations assumed to be failed. So that's why we not
4 take to a next step on details of the modelings of the
5 flooding in that sample. So the seismic
6 qualification, for example, is not specifically
7 addressed in the PI.

8 MEMBER STETKAR: Right, right. Okay,
9 Dan, I think in the interest of time, they do have an
10 open item on this sort of issue related to the seismic
11 stuff. I guess the best thing to do is just to see
12 how that plays out.

13 CHAIR POWERS: Yes, we'll sort of flag it.

14 MEMBER STETKAR: Yes, the other stuff
15 about the flooding, and jet impingements, and all
16 those types of things are, in my mind we need to get
17 some consistency on those. But I think it's better to
18 wait to see how this open item plays out. But thanks,
19 I at least better understand the concerns related
20 specifically to the seismic and quality group
21 questions.

22 MEMBER SKILLMAN: I would like to weigh in
23 to this for a minute or two, please. The terms
24 safety-related, important to safety, non-safety-
25 related, risk significant, safety significant, seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 one, seismic two, conventional seismic seem to me to
2 be not the terms that, unless clarified, will leave
3 the design certification, and future users of the
4 design certification, approximately where the industry
5 is right now.

6 When the operating plants are trying to
7 figure out yes, we know that seismic one is a risk
8 significant, is it important to safety? And I would
9 just offer this discussion has been going on since Reg
10 Guides 126 and 129 were published in the early '70s.

11 The NSSS members dealt with. The
12 operators are dealing with it even today, for some of
13 those older plants. And as I suggested yesterday, my
14 recommendation is that there be a lexicon that
15 clarifies what these terms mean.

16 And more importantly what those terms
17 apply to. I think if that type of lexicon or matrix
18 were provided, then John's issue would be resolved.
19 My concern about ambiguity and clarity would be
20 resolved. But I think that the design certification
21 would be more robust. Thank you.

22 MR. PHAN: Thank you.

23 MR. MIERNICKI: Okay. And with that, I
24 believe we've addressed all, hopefully these questions
25 from yesterday.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: We had at least two other
2 questions.

3 MR. MIERNICKI: Okay.

4 MR. TESFAYE: Todd Oswald has something.

5 MR. OSWALD: Mr. Chairman, Todd Oswald
6 with AREVA. Mr. Stetgar, we, in fact, calculated the
7 wind velocity. If you take the factors that we apply
8 to our wind loads for concrete design, you come up
9 essentially a factor of approximately 1.95 on the
10 design loads itself, being the pressure.

11 And that back calculates to a wind
12 velocity, a multiplier of about 1.4 onto the basic
13 wind speed. So our equivalent wind velocity, if you
14 might call it, would be about 202, 203 miles an hour.

15 MEMBER STETKAR: Thank you.

16 MR. MIERNICKI: I think the other
17 questions --

18 CHAIR POWERS: In 3.9.4, the applicant
19 indicated that they had tested the CRDM, control rod
20 drive mechanism for seismic conditions in Europe. And
21 that they had shared the testing data with the staff.

22 And the question was, did the staff review the test
23 or just the data? That is, they look at the test
24 procedure and things like that.

25 MR. MIERNICKI: Okay, we'll have to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back.

2 CHAIR POWERS: Right. That's fine. On
3 Section 3.11, Post-LOCA Environmental Conditions, we
4 raised the question of the testing was done with
5 radiation and steam and temperatures separated.

6 The staff has found synergisms between
7 steam and radiation have certainly come up. And they
8 come to the floor strongly in connection with the
9 Fukushima environment. The question is why is that
10 acceptable testing for environmental qualification.

11 The other question was that the
12 environmental qualification does not recognize acid
13 formation. We were told that the plant does not use
14 chlorinated hydrocarbon insulation on its cables.

15 But that still leaves open the issue of
16 nitric acid formation in the environments. So the
17 question is why is environmental testing without acid
18 formation acceptable?

19 MR. TESFAYE: Yes, we're not ready to
20 respond to that today.

21 CHAIR POWERS: That's fine.

22 MR. TESFAYE: Do you want to take some of
23 these questions, Darrell?

24 MR. GARDNER: I think we had, Tim, you
25 want to come up? I think we had at least one that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could respond to, Dr. Powers. I think several of the
2 ones were answered by the staff today or by dialogue.

3 We had one more question though.

4 MR. STACK: This is Tim Stack from AREVA.

5 Yesterday we had questions from John Stetkar related
6 to questions on internal flooding of the reactor
7 buildings, and whether we had any safety-related SSCs
8 located below the flood level, versus the SER saying
9 that we had no safety-related SSCs required to
10 mitigate the accident located below the flood level.
11 And basically, which was correct.

12 And based on our current design of the
13 U.S. EPR, there are no safety-related SSCs that are
14 located below the flood level inside the reactor
15 building.

16 However, since we have not completed a
17 detailed design yet, we have taken a COL item that
18 establishes a requirement that they'll perform a
19 flooding evaluation and confirm that there are no
20 safety-related SSCs below the flood level.

21 If that evaluation determines that there
22 are one or more safety-related SSCs that are, in fact,
23 required to mitigate the accident and they're located
24 below the flood level, then that equipment will have
25 to be designed accordingly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Thanks. But at least if
2 the --

3 MR. STACK: There's a COL item, correct.

4 MEMBER STETKAR: Yes. But for the
5 certified design, the answer is no?

6 MR. STACK: That is correct.

7 MEMBER STETKAR: Thanks. Thank you very
8 much.

9 DR. GARDNER: Dr. Powers, I'd suggest
10 giving the time we might consider a break before we
11 start Chapter 9?

12 CHAIR POWERS: Is that convenient for you?

13 DR. GARDNER: I'm sorry?

14 CHAIR POWERS: That's convenient for you?
15 Fine, we will recess until 10:00.

16 (Whereupon, the meeting in the foregoing
17 matter went off the record at 9:46 a.m. and went back
18 on the record at 10:02 a.m.)

19 CHAIR POWERS: I'm going to come back into
20 session. Darrell, it's your show.

21 Did you want to give an introduction to
22 this?

23 MR. TEFAYE: No. I've given that --

24 CHAIR POWERS: All right, we're moving on
25 to fuel handling here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TESFAYE: Yes.

2 CHAIR POWERS: We had so much fun in
3 Chapter 3, we'll move now to, what is this, Chapter 9?

4 MR. GARDNER: 9.1. This is a follow-on
5 from my --

6 CHAIR POWERS: Yes, this is the one part
7 we haven't done.

8 MR. GARDNER: Today's our discussion, be
9 it an overview of Section 9.1. We provided the rest
10 of the material in Chapter 9 to the Subcommittee on
11 November 14th.

12 Our presentation today will provide an
13 overview of the fuel storage and handling systems
14 including the spent fuel cask transfer facility, fuel
15 racks and associated analysis, fuel pool cooling
16 system and the heavy load handling system.

17 AREVA's presentation for this subcommittee
18 is nonproprietary. However, as we discussed earlier,
19 portions of the material that AREVA has used to
20 support the fuel rack analysis are contained within a
21 proprietary technical report submitted to the staff
22 for review.

23 Should member questions involve material
24 that AREVA considers proprietary, we would request
25 that this session be closed, and I would remind our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 presenters that it's our responsibility to identify
2 that.

3 CHAIR POWERS: And do not rely on me. Do
4 any of you guys use things like class guides,
5 classification guides and things like that? Okay,
6 poor guys.

7 MR. GARDNER: So our presenters today will
8 be Pavan Thallapragada, and he'll be supported by
9 Nitin Pandya for our initial presentation. And we'll
10 bring up our team from AREVA Transnuclear, Ian
11 McInnes, and we have other presenters that I'll
12 introduce when the time comes.

13 So with that I'll turn it over to Pavan.

14 MR. THALLAPRAGADA: Good morning. My name
15 is Pavan Thallapragada. I've been a supervisory
16 engineer in the comparative analysis group at AREVA.
17 I've worked with AREVA for about ten and a half years
18 now. I've been involved with in one capacity or the
19 other with various aspects of the fuel handling and
20 storage system. And Nitin Pandya, on my left, is our
21 subject matter expert on the fuel storage and handling
22 systems.

23 (Off the record comments)

24 MR. THALLAPRAGADA: The fuel storage and
25 handling system for the U.S. EPR is very typical to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 any PWR plant. It essentially provides for receiving
2 and handling new fuel assemblies, load and remove fuel
3 assemblies from the reactor vessel, store spent fuel
4 assemblies and remove the spent fuel assemblies from
5 the plant.

6 And this is a layout of the system. On
7 the right hand side is the reactor building, and on my
8 left hand side is the fuel building. The fuel storage
9 pool is the middle of the left hand side of the slide.

10 There's a fuel transfer pool which connects to the
11 reactor building to transport the fuel assemblies to
12 and fro from the reactor building.

13 There's the cask loading pool, the top
14 right corner. There's a new storage fuel area on the
15 left hand side to that. There are two gates between
16 the cask loading pool and the fuel transfer pool in
17 the spent fuel pool.

18 The spent fuel cask transfer facility,
19 this design is unique to the U.S. EPR. It has evolved
20 from similar designs in Europe, especially France.
21 This is really the only part of the fuel handling and
22 storage system which is a little bit different from
23 what is currently in the U.S. operating plants.

24 The design basis for the handling system,
25 the new and spent fuel storage racks, the transfer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tube, the isolation devices and expansion joints, the
2 cask loading pit penetration assembly, the spent fuel
3 cask transfer machine, the spent fuel cask transfer
4 facility fluid and pneumatic systems are the safety
5 related and designed to seismic Category 1 components
6 in this system.

7 The overall design of the fuel handling
8 system conforms to the requirements of GDCs 1, 2, 5,
9 61 and 62. The design is based on the guidance in
10 ANSI/ANS 57.1, design requirements for light water,
11 the actual fuel handling systems, to essentially
12 prevent based on prevention of criticality, protection
13 from just physical damage to the fuel assemblies and
14 radiological protection.

15 All the next few slides, they will
16 describe the spent fuel cask transfer facility. This
17 slide essentially shows the fuel building layout. We
18 have Slide 9. And Slide 10 is the fuel building
19 section. The green rectangles essentially represent
20 the fuel assemblies. The left hand side, blue, bottom
21 corner, blue structure is the spent fuel cask transfer
22 facility and the spent fuel cask transfer machine
23 itself. And what we later on describe as the loading
24 hall is essentially looked at it in that general area.

25 And the spent fuel cask transfer facility

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 primarily consists of three major components, the
2 spent fuel cask transfer machine, the cask loading
3 penetration assembly, the spent fuel cask transfer
4 facility fluid and pneumatic systems.

5 The facility operates at four stations,
6 the lifting station which is outside the fuel
7 building. There are three stations within the fuel
8 building in the loading hall which are the handling
9 opening station, the biological lid handling station
10 and the penetration station.

11 The spent fuel cask transfer machine
12 itself is a trolley which moves on rails. Its main
13 purpose is to carry the cask in a vertical position
14 between the lifting station and the three work
15 stations in the loading hall.

16 The safety related function of the machine
17 is when it is during cask loading it provides
18 essentially the support, structural support to ensure
19 the spent fuel pool fluid boundary remains intact at
20 all conditions including during and after a seismic
21 event. Next slide, please.

22 This is a sketch, I'm on Slide 13, this is
23 a sketch of the spent fuel cask transfer machine. On
24 the top as indicated in blue color are the penetration
25 docking devices. On my left is the elevator.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 On the right hand side is the biological
2 lid support. The green rectangle in the middle
3 represents the cask location. And the two gray
4 rectangles roughly in the middle of the structure are
5 the lateral guiding devices and the anti-seismic
6 locking devices.

7 There are two sets of train units at the
8 top and the bottom which hold the cask. And on this
9 Slide 14, we have a picture on my left hand side of a
10 spent fuel cask transfer machine. And on the right
11 hand side is the exploded view of the two major
12 components of the machine.

13 MEMBER STETKAR: In the, back to the
14 photograph, please. As I read it, there are lateral
15 locking devices or some sort of support on the machine
16 to provide lateral stability under seismic events.

17 Are those on this photograph about, could
18 you point those out on this photograph so that I don't
19 assume what they are?

20 MR. PANDYA: Yes. These are the ones.
21 These two, one and two.

22 MEMBER STETKAR: Okay.

23 MR. PANDYA: And actually this is the
24 point where it is hooked up to the guiding rails.

25 MEMBER STETKAR: Okay, so this photograph

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is taken with the machine in whatever the position is
2 where you take the bottom cover off.

3 MR. PANDYA: That is right. There's a
4 front wheel.

5 MEMBER STETKAR: If it's directly under
6 the loading pit it would be toward us with those --

7 MR. PANDYA: Yes.

8 (Crosstalk)

9 MEMBER STETKAR: Thank you.

10 MR. PANDYA: Very good.

11 MR. THALLAPRAGADA: Next slide, please.

12 The penetration assembly, the cask loading penetration
13 assembly provides a leak tight connection within the
14 cask loading pit and the internal cavity of the cask.

15 It essentially consists of an upper cover,
16 which is really at the bottom of the cask loading pit.

17 The penetration assembly itself with various
18 piece/parts in it, and the lower cover at the lower
19 end of the penetration.

20 This is a picture of the penetration
21 assembly when it's essentially connected to the cask.
22 I'm on Slide 16. The lower pink structure represents
23 the cask. The top pink rectangle is the cover. The
24 bellows are the screen-like structures.

25 CHAIR POWERS: Those are part of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transfer or are they part of the pool assembly?

2 MR. THALLAPRAGADA: The bellows are part
3 of the penetration assembly. They're part of the
4 building.

5 CHAIR POWERS: So they're there all the
6 time?

7 MR. THALLAPRAGADA: Yes, sir.

8 CHAIR POWERS: They're stainless steel?

9 MR. PANDYA: Yes. And these two are the
10 stainless steel bellows with a double barrier. So
11 there are two barriers in the bellows.

12 CHAIR POWERS: So it's a double barrier
13 shielded?

14 MR. THALLAPRAGADA: There are two bellows
15 essentially, two stainless bellows.

16 CHAIR POWERS: But is the outer part
17 shielded?

18 MR. PANDYA: Actually not the outer part,
19 but the inner part is being protected from any kind of
20 drop from above. So when these bellows are not in use
21 they will be compressed backwards or in a position at
22 the upper level, and when you want to use it those
23 will be pulled down with a docking mechanism. Outer
24 one, outer side is not that much protruded when they
25 are just resting, so they're not protected.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: What does this look like?
2 I mean this shows the cask in place if you're loading
3 it. What's the configuration of this during normal
4 operation when the bottom cover, the bottom plate is
5 in place? Do you have a diagram that shows that?
6 Where does the bottom cover fit on this thing?

7 MR. THALLAPRAGADA: These are essentially
8 the bellows, right?

9 MEMBER STETKAR: Right.

10 MR. THALLAPRAGADA: And when there's no
11 cask being loaded, during normal conditions, the
12 bellows essentially are compressed. They go back
13 essentially in here. The upper cover is closed and
14 there's a bottom cover here.

15 MEMBER STETKAR: At that location?

16 MR. THALLAPRAGADA: At that location.

17 MEMBER STETKAR: Okay.

18 MR. THALLAPRAGADA: So the bellows are
19 compressed. They are sandwiched essentially.

20 MEMBER STETKAR: Got you. That's sort of
21 the way I understood it, but I wanted to make sure
22 that I had the geometry correct. Thanks.

23 MEMBER SCHULTZ: And the bellows are a
24 assembly. There's two sets of bellows, is that what I
25 heard?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANDYA: No, actually there is a one-
2 bellow assembly with a dual wall.

3 MEMBER SCHULTZ: Dual wall?

4 MR. PANDYA: Yes, two walls. Assembly
5 will be only one.

6 MEMBER SKILLMAN: Where is this design in
7 use today and what is its operating experience?

8 MR. THALLAPRAGADA: The design is in use
9 in 16 plants in Europe. All the N4 plants in France
10 have this design and the later versions of the P4
11 plants all have this design, have this spent fuel cask
12 transfer facility, this under cask loading pit kind of
13 design in operation.

14 MR. GARDNER: Since, I'm going to start at
15 mid-80s?

16 MR. THALLAPRAGADA: Mid-80s is when the
17 earliest thing, I think Cattenon was the earliest
18 plant that was certified there, licensed there with
19 200 years of operating experiences worth.

20 MEMBER SKILLMAN: And what has the
21 experience been relative to connection and
22 disconnection linkage, and experience on fatigue on
23 the bellows seals?

24 MR. THALLAPRAGADA: From what we know
25 there haven't been any instances of fatigue on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bellows themselves. I think there was one instance
2 where there was a slight misalignment of the cask, and
3 there was one other instance where there was thermal
4 expansion of water and some of the water essentially
5 seeped out. I think that is the operating experience
6 that we have.

7 MR. PANDYA: And I think right here I
8 would like to add something more to that on your
9 question about that misalignment of the bellows and
10 all. Those have not been occurred during the cask
11 loading operation has been started so that will not
12 have any concern on the safety of fuel assembly or
13 personnel in or around. Those were at the time of
14 connecting the cask to the bottom penetration.

15 So during that process some misalignment
16 occurred, but at that time no cask loading operation
17 was started, no upper cover of this loading pit was
18 open. Everything was fine, I mean.

19 MEMBER SKILLMAN: Thank you. Let me ask
20 another question, please. On your Slide 6, if there
21 were to be a catastrophic leak, how much of the fuel
22 pool would be emptied through the opening and what are
23 the flooding consequences down where the carriage
24 rails are?

25 MR. PANDYA: This loading penetration

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whole assembly is a safety related component. And
2 that is being designed as seismic Category 1, safety
3 related component. So catastrophic failure of any
4 component as penetration assembly, I would think it's
5 a beyond design basis accident.

6 MR. GARDNER: But if it occurred, we have
7 looked at that and I think you can --

8 MEMBER SKILLMAN: Yes.

9 MR. GARDNER: The level, you're asking
10 where does the level drop to.

11 MEMBER SKILLMAN: Yes, how much shielding
12 do we lose out of the pool and what is the internal
13 flooding consequence, no matter how well it's
14 designed, if it leaks?

15 MR. PANDYA: Okay, got you.

16 MEMBER SKILLMAN: What happens?

17 MR. PANDYA: Okay, let me show you the
18 section, we have diagram which will give you more idea
19 about the level of the gates which separates the cask
20 loading piece.

21 MEMBER SKILLMAN: Your Slide 10 is the
22 best one.

23 MR. PANDYA: Okay, thank you. Yes, that's
24 got it, yes. This is the section view of the spent
25 fuel and the loading pit, and these are the gates

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 separating both of these two areas.

2 If suppose there is a catastrophic failure
3 of the bellow penetration assembly, then the water
4 start pouring through a very big hole but eventually
5 it will go up to this bottom of the gate level. So at
6 this level it will stop.

7 MEMBER STETKAR: What's that elevation
8 relative to the top of the --

9 MR. PANDYA: This is above the fuel
10 assembly, and I believe it's around, I'm not exactly
11 sure, but a little bit around one foot on top of the
12 fuel assembly.

13 MEMBER STETKAR: It was two and a half
14 feet in the FSAR.

15 (Crosstalk)

16 MR. THALLAPRAGADA: It's two and a half
17 feet, yes.

18 MEMBER STETKAR: So you can drain the fuel
19 pool either through the cask loading pit or through
20 the reactor fuel transfer canal if there was some leak
21 in the other direction, down to two and a half feet
22 above the active fuel?

23 MR. PANDYA: Exact. But --

24 MR. THALLAPRAGADA: We are talking about a
25 scenario where the cask loading is happening

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 essentially, and the gates are open only when there is
2 cask loading. There are two gates between the cask
3 loading pit and the spent fuel pool.

4 So during normal circumstances when there
5 is no cask loading, the two gates essentially prevent
6 any kind of, even if the assembly were to fail for
7 some reason.

8 MEMBER BROWN: I'm trying to understand.
9 Where are the two gates?

10 MR. PANDYA: At this location. The other
11 two gates, one is --

12 MEMBER BROWN: There's two there?

13 MR. PANDYA: Yes. And I can show you the
14 plant view. This is one gate which is a slot gate, I
15 mean lifted by the crane up and down, and this is the
16 swivel gate which is opened manually by handwheel
17 cranking.

18 MEMBER STETKAR: You mentioned one thing I
19 didn't see. The slot gate, it's not a motor operated
20 gate. It's lifted, it's a crane --

21 MR. PANDYA: By crane, yes.

22 MEMBER STETKAR: It's by the fuel building
23 crane?

24 MR. PANDYA: Yes.

25 MEMBER STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANDYA: In the case of any beyond
2 design with this catastrophic failure of the bellow
3 penetration assembly, one can very well close this
4 gates which is a manual cranking, which is seismic
5 Category 1 component.

6 MEMBER STETKAR: Manual cranking, human
7 being manual cranking?

8 MR. PANDYA: Yes.

9 MEMBER STETKAR: Can a human being
10 actually crank that gate closed against the water
11 forces that would be going through that tube?

12 MR. PANDYA: Yes, absolutely, because
13 these gears are designed and they have very a good
14 gearing mechanism.

15 MEMBER STETKAR: Well, under static
16 conditions. But if you have water flowing through
17 that space, I guess once it gets out into the flow
18 stream, the flow stream will tend to help it, but
19 getting it there might not be all that easy.

20 MR. PANDYA: I note your concern, yes.
21 But --

22 MEMBER STETKAR: I guess if you have a
23 design basis really big guy at the plant.

24 MEMBER SKILLMAN: If this unforgiving
25 event were to occur, what is the consequence of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 internal flooding?

2 MR. GARDNER: There's no safety related
3 equipment down there, right?

4 MR. THALLAPRAGADA: There is no safety
5 related equipment down there. And then when then the
6 flooding occurs --

7 MEMBER SKILLMAN: Are there safety related
8 people down there?

9 MR. GARDNER: Yes.

10 MR. THALLAPRAGADA: No, not in the loading
11 hall.

12 MEMBER SKILLMAN: Underneath? Now what
13 I'm envisioning is a catastrophic failure for whatever
14 reason. I salute your design, it seems dandy. But
15 let's just assume that the seal fails or the mechanics
16 fail, and now I've got 2,000 gallons a minute running
17 out of the slot into that underlying area. Where does
18 that water go? What is the internal flooding
19 consequence, please?

20 MR. PANDYA: Okay. I would like to
21 mention that the down below area from the loading pit,
22 they have a very well designed flow drainage system.
23 And the drainage pipes exist in the loading hall area.
24 Let me show this section view. And so water pouring
25 into the floor in this area --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Yes.

2 MR. PANDYA: This is the area which has a
3 nice drainage system. So in case of a leakage from
4 this penetration this drainage system is capable of
5 taking away the water. That is one thing.

6 Second thing, this leakage from the seal
7 only when the total failure of the seal will give a
8 leakage rate of one can utilize that number. Those
9 leakage rate is not that big values.

10 MR. THALLAPRAGADA: We looked at cases
11 where our design, beyond design basis, even cases
12 where there is failure in the seal itself. Okay, we
13 did not consider really the whole penetration upper
14 cover and lower cover dropping off.

15 But we calculated that there was what,
16 eight hours, if I remember right, for the spent fuel
17 pool to lose inventory up to the level of the gates,
18 at the bottom of the gates. And our calculations
19 ensure that any operator actions to close the gate
20 would take most about half an hour or so, so there's
21 plenty of time from losing inventory from the spent
22 fuel pool point of view.

23 And as Nitin pointed out, there are drains
24 in the bottom which essentially would take the water
25 away from the loading hall, but the loading hall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 itself is not full of water.

2 MEMBER SKILLMAN: Where would that water
3 go?

4 MR. PANDYA: Drainage system, I don't know
5 where it leads to finally.

6 MR. GARDNER: We can get an answer for you
7 before --

8 MEMBER SKILLMAN: Yes, I would like an
9 answer to that. The design seems to be robust. It
10 sounds like you're using the right words relative to
11 its quality level and its safety significance. But I
12 have an aversion to losing my shield on fuel. I have
13 an aversion to losing coolant on fuel. And I have an
14 aversion to drowning innocent people.

15 (Crosstalk)

16 MR. GARDNER: There's no personnel, I mean
17 maybe you want to speak of personnel.

18 MR. PANDYA: Yes, as far as operating
19 personnel are concerned, this facilities are remotely
20 operated from especially designed control room. So no
21 operator will be below this loading hall or the
22 loading pit when this cask loading process is going
23 on. So there won't be any person moving in this area.
24 They will be in the control room.

25 MEMBER SKILLMAN: Well, I have this other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 idea that they're in the process of using this fairly
2 complicated piece of equipment and the equipment isn't
3 functioning precisely as they anticipate that it will,
4 and some capable mechanic, he or she goes down to
5 adjust it, adjust a valve or to adjust an actuator,
6 and now I do have a person who is at risk.

7 MR. THALLAPRAGADA: Yes, that scenario --

8 (Crosstalk)

9 MR. PANDYA: You're right.

10 MR. GARDNER: You would anticipate that
11 before you took that kind of an operation where
12 something wasn't, that you would not be moving any
13 fuel and those gates would be closed. In other words,
14 you wouldn't intentionally create a scenario of
15 performing maintenance that would give you that kind
16 of a --

17
18 (Crosstalk)

19 MEMBER SKILLMAN: Okay, and if you were to
20 close the gate in that circumstance, I think what
21 you've done is you've limited the inventory, but you
22 still have a hydrostatic head that is significant and
23 you can get a very substantial leak.

24 MR. GARDNER: And certainly I think
25 depending on, as you well know your maintenance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 procedures would consider it a hazard and determine
2 whether they would pump that pit dry before they
3 performed that activity from a personnel safety
4 standpoint.

5 MEMBER SKILLMAN: Well, I would like to
6 know where the water goes, if there is a catastrophic
7 failure. I understand cranking the swing door closed.
8 My hunch is that that might be false comfort. With a
9 large enough leak I think one would see that pool
10 level begin to drop rapidly. And one might say, gee
11 whiz, we just couldn't catch up to it.

12 MR. GARDNER: But I think we would want to
13 emphasize again that we don't see credible scenarios
14 that an entire penetration assembly fails. It's a
15 passive component certainly built to all the standards
16 that we've talked about.

17 With the seals, we have looked at a
18 catastrophic beyond design basis failure of those
19 seals, and you get the times that he spoke of earlier
20 which are in the range of eight hours. So the amount
21 of water moving through there we're going to talk
22 about in some later slides here. The rate is not as
23 high as you would, it's not that high.

24 MEMBER SKILLMAN: Thank you.

25 MR. PANDYA: You're welcome.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Want me to go? The cover,
2 that's where you're talking about the seals, the
3 little rings on the cover that's sitting up there?
4 That's got to be open obviously to put the stuff down
5 in.

6 MR. PANDYA: Yes.

7 MEMBER BROWN: Through the transfer
8 channel there.

9 MR. PANDYA: Yes.

10 MEMBER BROWN: How is it moved? I mean
11 you said it was a static. I heard you say that a
12 minute, it's a static. Is it a lever arm? Is it
13 sliding? I mean I presume it's a rotating lever arm
14 type thing.

15 (Off the record comments)

16 MR. THALLAPRAGADA: I'm sorry, the
17 presentation is in two parts and we are trying to
18 figure out, can you go to the other part of the
19 presentation, please?

20 MEMBER BROWN: I'm trying to figure out,
21 and a little bit of Dick's question about how does
22 that fail? I mean you've looked at the seals but the
23 idea is that cover has to be moved somehow. So that's
24 an interesting looking set of pulleys and ropes or
25 chains or whatever those are. Is that what I get out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of that?

2 MR. PANDYA: Yes, that's correct. This is
3 the hoist here. This hoist will lift the cover up and
4 down.

5 MEMBER BROWN: So that's done when it's
6 full of water? Or is that done --

7 MR. PANDYA: Yes.

8 MEMBER BROWN: Is that cavity always
9 filled with water?

10 MR. PANDYA: No, actually the cavity does
11 not remain full with water, but we have a way to store
12 the water to facilitate operating --

13 MEMBER BROWN: Okay. The point I'm just
14 trying to figure out, when you want to go from moving
15 stuff from the spent fuel pool and now go put it in
16 the casks, you fill that cavity up?

17 MR. GARDNER: Yes.

18 MEMBER BROWN: So the cover's closed?

19 MR. PANDYA: Yes.

20 MEMBER BROWN: Then you open up the cover
21 after you've got the cask and everything put with the
22 bellows and all that, and all the water pours into
23 the, water's got to get, it's a big hole. Where does
24 the --

25 MR. THALLAPRAGADA: No, no, no. The cask

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gets filled so there's no pouring of the water.

2 MEMBER BROWN: The cask is filled with
3 what?

4 MR. THALLAPRAGADA: Yes, with water.

5 MEMBER BROWN: Well, that's what I mean.
6 It comes down in the bellows area.

7 (Crosstalk)

8 MEMBER BROWN: It's brought in filled with
9 water?

10 MR. GARDNER: It's pumped in. It's a
11 connection that pumps water in before you open the,
12 into the bellows. So there's a connection that fills
13 the cask before you open the cover.

14 MEMBER BROWN: So it's filled up to the
15 bottom of the cover?

16 MR. GARDNER: Yes.

17 MR. PANDYA: And when there's a pressure
18 equalization on both side, at that time only this
19 upper cover is allowed to get open.

20 MEMBER STETKAR: Otherwise, it's pretty
21 heavy on water. It's got to be a pretty stout hoist.

22 (Crosstalk)

23 MEMBER BROWN: That's why I was trying to
24 figure out how this operated. I mean I got lost in
25 the beginning. I'm not a spent fuel pool, I came out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the Naval and Nuclear program. We don't do any of
2 this stuff, take the whole core out and put a whole
3 new one in.

4 CHAIR POWERS: Or sink the submarine, one
5 or the other.

6 MEMBER BROWN: So I mean --

7 CHAIR POWERS: Whichever is easiest.

8 MEMBER BROWN: I finally figured out you
9 were talking about now the tail end after you've
10 finished and the fuel's cooled, and now you want to
11 put it in casks and haul it away somewhere, and I kind
12 of got lost in the transition. So now I was trying to
13 understand the pictures. This is a better picture.

14 I still share my colleague's concern with
15 having a giant hole in the bottom and doing everything
16 from the bottom side. It just seems to be
17 counterintuitive to, you're just kind of setting
18 yourself up for having a problem, that's all,
19 regardless of the 200 years worth of marvelous
20 experience in 14 plants, which means about eight years
21 per plant or nine years or something like that. Is
22 that right, 14?

23 MR. THALLAPRAGADA: Today it's 15 years.

24 MEMBER BROWN: Okay. All right, you
25 answered my question. Regardless of what my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conclusions are, there's another, I'm sorry, Dick for
2 interrupting you, if I did.

3 MEMBER SKILLMAN: Thank you, I'm fine.
4 I'm good.

5 MEMBER STETKAR: I have a couple more, and
6 this is not the right slide. If you go back to the,
7 you know, the original presentation where you showed
8 the cask loading hall and the machine, I wanted to
9 follow up a little bit on Dick's question.

10 MR. GARDNER: Slide 14?

11 MEMBER STETKAR: I guess.

12 MR. PANDYA: That's Slide 14, okay?

13 MEMBER STETKAR: No. That might have been
14 the one. You had one that showed the cask loading
15 hall. It actually doesn't make too much difference as
16 far as that particular slide. Slide 10 is good
17 enough.

18 MR. PANDYA: Okay.

19 MEMBER STETKAR: Something that Dick was
20 asking about, I want to follow up on a little more
21 specifically. All of the fuel pool cooling and
22 makeups are located at the bottom elevation of the
23 fuel building, is that correct?

24 Just nod your head yes, it is correct.
25 They are located at the bottom elevation of the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 building.

2 MR. PANDYA: I believe they are. I
3 believe --

4 (Crosstalk)

5 MEMBER STETKAR: The question is, and you
6 know where they are, they're at the bottom. Trust me
7 on this, I found the rooms. Can water from the cask
8 loading hall find its way down to those rooms?

9 MR. PANDYA: Please repeat your question.

10 MEMBER STETKAR: And don't talk about
11 design basis drainage. It's just, can water from the
12 cask loading hall find its way down to the basement of
13 the building where the fuel pool cooling pumps and
14 makeup pump, purification pumps are located?

15 MR. PANDYA: I believe that can if we
16 don't have a nice and good design flow drainage
17 system.

18 MEMBER STETKAR: So it's the cask loading
19 hall is not somehow hermetically isolated from the
20 rest of the building?

21 MR. PANDYA: Yes, not from other part of
22 the building down below.

23 MEMBER STETKAR: Okay. My question arose,
24 I was concerned about internal flooding, which is
25 Dick's concern, draining the pool, the cask loading

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hall question about the hall itself. The bottom of
2 the hall pretty obviously is at grade level because
3 you have to get this big monster thing in and out of
4 the building.

5 MR. PANDYA: Yes.

6 MEMBER STETKAR: I'm assuming the building
7 has some sort of door on it.

8 MR. PANDYA: Yes, that's absolutely right.

9 MEMBER STETKAR: Is this thing, I don't
10 know whether it's specifics of the design, is this
11 basically a rail, you said it's a rail mount?

12 MR. PANDYA: Yes, it is a rail mount.

13 MEMBER STETKAR: So it comes out of the
14 building on rails. How do you seal that door from
15 external flooding?

16 MR. PANDYA: Actually that door is a
17 shielding door which provides also the shielding and
18 it provides a robust structure for external missiles
19 impact and all that kind of stuff just like building,
20 spent fuel building.

21 MEMBER STETKAR: Is it water tight?

22 MR. THALLAPRAGADA: Yes, it is.

23 MEMBER STETKAR: How do you seal little
24 rails to being water tight?

25 MR. THALLAPRAGADA: The rails are removed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Yes, that will explain it. The rails are removable
2 essentially as part of the preparation of the cask
3 loading. You open the door, put those rails on,
4 machine comes in. And after it's done --

5 MEMBER STETKAR: You can do it that way.

6 MR. PANDYA: Yes.

7 MEMBER STETKAR: Okay, thank you. That
8 doesn't solve the internal flooding but it does answer
9 my question about the external flooding. Thank you.

10 MR. PANDYA: You're welcome.

11 MEMBER STETKAR: I had another one. Are
12 you going to talk about the calculated leakage rate
13 through the seals?

14 MR. THALLAPRAGADA: Yes. At one of the
15 later presentations we have.

16 MEMBER STETKAR: I'll let you get to that
17 then, thanks.

18 MR. THALLAPRAGADA: We have a couple of
19 those scenarios discussed.

20 MEMBER STETKAR: Thank you.

21 (Off the record comments)

22 MR. THALLAPRAGADA: Essentially we are at
23 Slide 17.

24 MEMBER STETKAR: I'm sorry. I did have
25 one more. The visual aids help some of these things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So if you could show your slide, it's just I might as
2 well get these out of the way while we have the visual
3 aids in place. Your Slide 16 that shows the bellows.
4 There.

5 As I understand the operation, the cask,
6 the machine comes in to some intermediate location
7 before it gets to the actual under the bellows
8 location.

9 MR. THALLAPRAGADA: Yes.

10 MEMBER STETKAR: At that point the bottom
11 cover is removed and it's put over into a little
12 storage area, as best as I could understand.

13 MR. THALLAPRAGADA: That's correct.

14 MEMBER STETKAR: And then you move the
15 machine into, you know, into its index position and
16 complete the hookup and open up the top cover and what
17 not.

18 MR. THALLAPRAGADA: That is correct.

19 MEMBER STETKAR: Is there anything that
20 prevents, are there interlocks such that I cannot
21 remove the bottom cover unless the top cover, the pink
22 cover here, is closed?

23 Suppose it was open, suppose it was
24 partially open, and my big guy goes in there and
25 starts to remove the bottom cover and a lot of water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 starts pouring out. Is there anything to prevent me
2 from opening the bottom cover with the top cover not
3 being fully closed and sealed?

4 MR. PANDYA: Yes. Actually this bottom
5 cover is opened and closed manually.

6 MEMBER STETKAR: That's why I said my big
7 guy.

8 MR. PANDYA: Yes. And then it will be
9 open only when this interspace is empty. So operator
10 will get a clearance. It is in the operating
11 procedure when the cask transfer facility is being
12 used. Last time after that this area will be drained
13 and everything will be sealed and there's a bottom
14 cover placed.

15 Now again, after next year when you want
16 to go for cask loading process, the bottom cover will
17 be manually opened. So at that time there's no
18 chances of anything, water left out over here. And at
19 the same time, this bottom cover has a drainage line
20 connector to that one.

21 So if at all there's any water left out,
22 all the seepage can go through this drainage line of
23 the bottom cover and it will be drained through the
24 drainage system. And at that time this upper cover is
25 already in a closed position from the previous cask

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 transfer facility loading operation at the end.

2 MR. GARDNER: There's also a position
3 indication on the top cover, right?

4 MR. PANDYA: Yes. Actually this top cover
5 has a position indication that it is closed or open
6 like that but not the bottom cover.

7 MEMBER STETKAR: I understand all that.
8 I'm just trying to understand if there are any
9 provisions of the design other than relying on, you
10 know, operators following the correct procedures.

11 (Crosstalk)

12 MEMBER STETKAR: If that top cover, yes,
13 but I mean if the top cover --

14 (Crosstalk)

15 MR. GARDNER: There's leak detection
16 between the seals, right, so --

17 (Crosstalk)

18 MR. GARDNER: -- the position indication,
19 you would have leak detection between, past that seal.

20 MEMBER STETKAR: That might be --

21 MEMBER BROWN: You mean the two little
22 black dots between the two little black dots all the
23 way around the --

24 MR. PANDYA: Yes, that's right. These are
25 seals, these black dots. And this interspace of these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 seals are being pressurized with the compressed air
2 and that pressure will be monitored. So if at all
3 there is any seal leakage or seepage, you will come to
4 know because of this air pressure failure into the
5 system. So that way the seals are monitored for the
6 leakage.

7 MEMBER STETKAR: Okay, thanks.

8 MR. PANDYA: And that is also with the
9 case with the bottom cover. There are two seals at
10 the bottom cover also.

11 MEMBER BROWN: Is that all you had, John?

12 MEMBER STETKAR: Yes.

13 MEMBER BROWN: You said that when there's
14 no cask in there that bellows is compressed up against
15 the top, did I hear you say that or does it maintain
16 itself in this position?

17 MR. THALLAPRAGADA: No, it is compressed
18 up.

19 MEMBER BROWN: So it's squashed.

20 MR. PANDYA: Yes, compressed.

21 MEMBER STETKAR: And there's a bottom
22 cover, Charlie.

23 MEMBER BROWN: Yes. No, and there's a
24 bottom cover that's shown by those two little bottom
25 seals, I would imagine. Although do the little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 docking flanges go up with the bellows, those little
2 orange things?

3 MR. THALLAPRAGADA: Yes, the docking
4 flange is part of the bellows.

5 MEMBER BROWN: So that gets pushed up and
6 then there's a cover where those two little black dots
7 are?

8 MR. THALLAPRAGADA: That is correct.

9 MR. GARDNER: Can you speak to the
10 movement, the amount of squishing, well that's not
11 very much.

12 MEMBER BROWN: Let me ask one --

13 MR. PANDYA: The docking mechanism, yes.

14 MR. GARDNER: How much it moves --

15 MR. PANDYA: Yes. I can talk about this
16 docking mechanism. This is that orange one and this
17 at the operating mechanism screws, so when you want to
18 take this bellows upward after completing the cask
19 loading operation, this mechanism will have a motor
20 and position indicator, and all you do is start
21 pushing this bellows upward up to this point on both
22 sides.

23 MEMBER BROWN: Okay, those screws don't
24 look long enough to do that.

25 MR. THALLAPRAGADA: It's an artistic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 representation.

2 MEMBER BROWN: So the screws really go all
3 the way up so that --

4 MR. THALLAPRAGADA: The screws do go up,
5 it goes all the way up in there. Yes, it does.

6 MEMBER BROWN: Okay, but the fixed
7 position is at the bottom where the drive unit is, so
8 the screws push this whole docking flange up and then
9 you manually put on the bottom cover?

10 MR. THALLAPRAGADA: Yes, that is correct.

11 MEMBER BROWN: The bellows, does that get
12 tested for how many times you can squash it and
13 unsquash it?

14 MR. PANDYA: Yes, that's correct.
15 Actually we have a design requirement going to be
16 provided that this mechanism will conservatively
17 operate like I said, 60 times in a year, very
18 conservatively. So for fatigue evaluation that number
19 will be used and bellow cycles will be taken into
20 account in the bellow design.

21 MEMBER BROWN: Is the bellows design a
22 continuous design or is it a welded bellows?

23 MR. PANDYA: These are very large bellows,
24 so it will see weld joints in its fabrication.

25 MEMBER BROWN: It will see what?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANDYA: Welding joints, welding.

2 MEMBER BROWN: Welded, okay. So each
3 little section or some sections of them are welded
4 circumferentially?

5 MR. PANDYA: No, not each section, but two
6 half circle will be joined together.

7 MEMBER BROWN: Okay, this way.

8 MR. PANDYA: Yes, this way, like that.

9 MEMBER BROWN: And so you have a vertical
10 weld that puts the two half cylinders together.

11 MR. PANDYA: Yes, I got you. But bellows
12 will be designed as for standards and all and it will
13 be designed for fatigue, considering number of cycles
14 is required to be the minimum operational.

15 MEMBER BROWN: So 60 per year times 60
16 years?

17 MR. PANDYA: Yes, that's correct, like
18 that.

19 (Crosstalk)

20 MR. GARDNER: But you're not doing this
21 every year.

22 MEMBER BROWN: No, I understand that. I
23 just was doing the math. I can still do that
24 sometimes. Okay, thank you.

25 MR. PANDYA: Yes, and you're welcome.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Actually, I would like to add that this bellows, this
2 is a picture representation as for I want to say this
3 bellows are not elongating this much. This is too
4 long, I mean too --

5 MEMBER BROWN: How long is the elongation?

6 MR. PANDYA: I wish I could actually we
7 knew that, but I can give you, with some time, after -
8 -

9 (Crosstalk)

10 MEMBER BROWN: It's not five feet.

11 MR. PANDYA: No, no.

12 MEMBER BROWN: It's a few inches?

13 MR. PANDYA: A few inches, that's good.
14 It will be less than one foot, yes.

15 MEMBER BROWN: Okay.

16 CHAIR POWERS: The problem, historically,
17 with these kinds of bellows is that with any kind of
18 chloride contamination they corrode and they're very
19 hard to inspect, the corrosion. I mean you're
20 handling it with leak detection, but that's the
21 problem with double bellows is you can't hardly
22 inspect them very easily for corrosion.

23 MR. PANDYA: About this inspection of the
24 bellows, as I mentioned there are two walls and in
25 between these two walls this cavity is maintained

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressurized. So that pressure drop due to any leakage
2 of the bellows or any cracking the bellows, you will
3 come to know up front. So that is one of the
4 mechanism. And in the initial design these bellows
5 would be hydrostatically tested.

6 MR. THALLAPRAGADA: And before each
7 loading operation essentially the bellows are tested,
8 right?

9 MR. PANDYA: Yes, that's correct.

10 MR. THALLAPRAGADA: Slide 17, the fluid
11 and pneumatic systems are located on the spent fuel
12 cask transfer machine and in the fuel building.
13 They're essentially used for filling, draining and
14 drying the cask on the penetration. They also provide
15 compressed air for the pneumatic devices and the seal
16 leakage protection system.

17 The cask itself is not part of the design
18 certification scope, and we have a seal item that will
19 provide a spent fuel cask design that is acceptable
20 for use with this facility prior to initial fuel
21 loading.

22 MEMBER SKILLMAN: I understand that the
23 cask is not part of the design certification, but I
24 would ask whether the seal and sealing mechanism is
25 part of the design certification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. THALLAPRAGADA: It is.

2 MEMBER SKILLMAN: It is? Thank you.

3 MR. THALLAPRAGADA: We can go to the next
4 presentation. Go to the first slide, please.

5 Essentially I have a few more slides which
6 describe the operation of this facility. This slide
7 describes, essentially shows the lifting station which
8 is outside the fuel building.

9 Here the cask would typically come on a
10 trailer in a horizontal position, a gantry crane would
11 hoist it up into a vertical position and place it on
12 the machine itself. And the machine is, using a
13 tractor is essentially pushed up toward into the fuel
14 building, right.

15 This is the general view of the fuel
16 building, the loading hall and the three stations.
17 The first station is the handling opening station.
18 The second station is the biological lid handling
19 station, and the third is the penetration station.

20 MEMBER BROWN: What's the number five
21 thing? That little squiggly, rotating worm gear-like
22 looking?

23 MR. THALLAPRAGADA: Yes, number five is
24 essentially at the biological lid handling station.
25 That is the device which grabs the biological lid on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 top of the cask and pulls it up.

2 MEMBER BROWN: That's the intermediate
3 position that you were talking about?

4 MR. THALLAPRAGADA: Yes.

5 MEMBER STETKAR: That's where they take
6 the top off the cask and remove the bottom cover from
7 the bellows area and kind of slide it over.

8 MEMBER BROWN: Then move the cask over
9 underneath?

10 MR. THALLAPRAGADA: When the machine
11 enters the loading hall it's under the handling
12 opening station. That is the first station.

13 MEMBER BROWN: That's a non-watered space?

14 MR. PANDYA: Yes.

15 MR. THALLAPRAGADA: Yes, at that point
16 essentially the machine is hooked up electrically to
17 the fuel building and the fluid and the air circuits
18 out were connected to the machine and the fuel
19 building. And then it moves to the biological lid
20 handling station.

21 At that point two operations, two major
22 operations. One, the bottom cover of the penetration
23 is removed and placed on the elevator. And the
24 biological lid itself is removed and pulled up into
25 the recess in the ceiling, if you will.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Then the transfer machine moves to the
2 third location which is under the penetration station.

3 The biological lid is lowered onto the platform, and
4 at that point essentially the docking mechanism comes
5 into play, the bellows are pulled down, machine is
6 start.

7 Leak tightness tests are performed. Well,
8 then the upper cover is open. The cask loading
9 starts, the assemblies come through the gate, are
10 placed in the cask and the process essentially goes in
11 the reverse order after the loading is done.

12 MEMBER BROWN: The total sealing force on
13 the cover when it's closed is just a hydrostatic bed
14 above --

15 MR. PANDYA: Yes, that is that.

16 MEMBER BROWN: -- above it? That provides
17 --

18 MR. PANDYA: And the weight of the cover
19 itself. It is a huge cover.

20 MEMBER SKILLMAN: This cask transports a
21 single fuel assembly for operation? Is this a single
22 fuel assembly?

23 MR. THALLAPRAGADA: The cask itself?

24 MEMBER SKILLMAN: Yes.

25 MR. THALLAPRAGADA: No, a single fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assembly is transported at any point from the spent
2 fuel pool into the cask. But the cask itself can hold
3 multiple fuel assemblies.

4 MEMBER SKILLMAN: So for off-loading, this
5 is a one per fuel assembly operation, the sealing, the
6 inserting, the unsealing and the movement?

7 MR. THALLAPRAGADA: I'm sorry, I did not
8 explain properly then. The cask, once it's docked
9 under the penetration pit, you essentially pull a fuel
10 assembly, load it into the cask, the machine goes
11 back, loads onto the fuel assembly, goes back --

12 MEMBER BROWN: From the spent fuel pool --

13 MR. THALLAPRAGADA: From the spent fuel
14 pool into the cask --

15 (Crosstalk)

16 MR. THALLAPRAGADA: Depending upon the
17 cask design, it's multiple number of fuel assemblies.
18 The sealing and unsealing happens for every cask, full
19 cask --

20 (Crosstalk)

21 MEMBER BROWN: Thank you.

22 MEMBER RYAN: Is it always a full cask
23 campaign or do you do partial movements or what's the
24 plan? I mean I know you have a --

25 MR. PANDYA: Actually the plan is to lower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the cask if full, but there is no restriction we can -
2 -

3 MEMBER RYAN: I understand, yes. But I
4 mean your plan is to fill up a cask and move that load
5 of fuel --

6 MR. PANDYA: And then move it, yes.

7 MEMBER RYAN: -- wherever you're going to
8 move it to at one time. All right. Thanks.

9 MEMBER BROWN: So the hole is big enough
10 to bring some number of fuel assemblies one at a time.

11 (Crosstalk)

12 MEMBER BROWN: And place them in different
13 locations --

14 (Crosstalk)

15 MEMBER BROWN: -- within the cask?

16 MALE PARTICIPANT: Yes, it's all pretty
17 standard stuff.

18 MR. THALLAPRAGADA: Yes, there's a rack
19 within the cask. That is --

20 MEMBER RYAN: What's the provision if you
21 get a fuel element to hang up while you're loading it
22 in the cask, particularly if it's the last one?
23 Because it will hang up in the fuel rack sometimes.
24 How do you deal with that?

25 MEMBER BROWN: You're talking about being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stuck in the cask partway in and partway out?

2 MEMBER RYAN: Hung up, yes, stuck. Can't
3 get it in, can't get it out.

4 MEMBER BROWN: It's ugly.

5 MEMBER RYAN: Have you thought through
6 things like that?

7 MR. THALLAPRAGADA: If we have a cask of
8 fuel assemblies stuck in the cask --

9 MR. TESFAYE: That's an open item in the
10 staff study evaluation, so they're addressing that.

11 MEMBER RYAN: Okay, we'll hear about that
12 a little later I guess.

13 MR. TESFAYE: Yes.

14 MEMBER RYAN: Thank you.

15 MEMBER SKILLMAN: We've experienced bowing
16 over and over again, significant bowing, not just a
17 couple of mils, but fuel assemblies that are actually
18 bowed by an inch or an inch and a half. And getting
19 them in the storage rack or a transfer cask becomes a
20 very great challenge.

21 MR. THALLAPRAGADA: What I'm just guessing
22 is the bowing, you would know about the bowing when
23 you are pulling it of the storage racks --

24 (Crosstalk)

25 MEMBER SKILLMAN: As you were trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pull it out.

2 (Crosstalk)

3 MR. THALLAPRAGADA: Before you tried to
4 put it in the cask you would know it.

5 MEMBER SKILLMAN: You know it's bowed.

6 MR. THALLAPRAGADA: Yes.

7 MEMBER SKILLMAN: So you do know it's
8 bowed, yes. Thank you.

9 MEMBER STETKAR: The good news is you
10 hoist it out of there then.

11 MEMBER SKILLMAN: You hoist it out of
12 there. The bad news is you might not be able to put
13 it anywhere because you ripped all the side sheets
14 off.

15 MEMBER STETKAR: I suspect the load cells,
16 or that's what they invented load cells for.

17 MEMBER RYAN: So I guess just to follow
18 up, we'll hear a little bit more later on about
19 recovery from off-normal events, the fuel loading and
20 unloading in the system?

21 MR. TESFAYE: Yes.

22 MALE PARTICIPANT: It's still under
23 review.

24 MEMBER RYAN: If it's under review, that's
25 fine. But we'll maybe capture that on the agenda

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 first down the line. Routine operations with casks
2 are routine, but the non-routine operations are really
3 not routine at all. Thank you.

4 MR. PANDYA: This essentially concludes
5 our presentation on the --

6 MR. GARDNER: I think we've answered his
7 question though from earlier about the operating
8 experience.

9 MEMBER SKILLMAN: You did, thank you.

10 MEMBER STETKAR: You said you were going
11 to talk about leakage rates from the seals. Is that
12 still later?

13 MR. THALLAPRAGADA: Yes, it's still later.

14 Yes.

15 MEMBER BROWN: Talk about what, John?
16 Leakage rates, you said?

17 MEMBER STETKAR: From the seals, they'll
18 get to it.

19 MR. GARDNER: So we have a presentation on
20 the racks, so we'll come back and do that.

21 CHAIR POWERS: I'm not sure whether we're
22 going to discuss it here, but I will caution you that
23 when you discuss this in front of the full committee
24 whenever that is that you will get fairly closely
25 interrogated on the instrumentation you have in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 spent fuel pool for measuring level. And so you want
2 to probably plan to explicitly address that. You can
3 understand why you might get fairly closely
4 interrogated on that.

5 MR. THALLAPRAGADA: Yes.

6 MEMBER BROWN: Should we interrogate them
7 now?

8 CHAIR POWERS: Well, I hope they'll touch
9 on it.

10 MEMBER BROWN: At some point that was,
11 there's a lot more --

12 MR. GARDNER: Yes, we're going to talk
13 about it in the --

14 MR. THALLAPRAGADA: We have a couple of
15 other presentations where we talk about the --

16 CHAIR POWERS: I am not as fanatical as
17 some members on the ACRS on this. I consider the best
18 level of instrumentation for the spent fuel pool a
19 pair of eyeballs.

20 MEMBER BROWN: You're not supposed to give
21 away the --

22 MEMBER STETKAR: Just as long as you've
23 got enough water to shield the eyeballs so you can
24 see.

25 CHAIR POWERS: I don't really worry about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that because it's not going to be me, I guarantee you.

2 MR. TESFAYE: Let's move on to the next
3 one.

4 MR. GARDNER: Just a few minutes to change
5 out our reviewers here.

6 CHAIR POWERS: Okay, that's fine. Well,
7 thank you both very much, gentlemen. That's quite an
8 intriguing system and it sounds like you've thought
9 very carefully about it.

10 Do you guys have to operate it? The first
11 time through maybe?

12 (Off the record comments)

13 MR. MCINNES: Okay, good morning, Mr.
14 Chairman, members of the committee. My name is Ian
15 McInnes. I'm the Transnuclear project engineer for
16 the design of the racks. I'm a licensed civil
17 engineer, and as such I'm assisted by Miguel Manrique.

18 Miguel is a seismic expert, and if we get into any
19 seismic questions we'll be depending upon him.

20 Transnuclear is a wholly owned subsidiary
21 of AREVA, so although I keep using the term
22 "Transnuclear," we are part of the AREVA family.

23 I've been working in the nuclear power
24 industry since 1967. My first nuclear job was design
25 and development of concrete reactor vessels in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 England, and pre-stressed vessels which sort of went
2 the way of the dinosaur.

3 MEMBER STETKAR: They're still operating.

4 MR. MCINNES: They're still operating and
5 doing a fantastic job. Designer of various reactor
6 buildings, I've also done a lot of hydrodynamic loads
7 on the Mark I, Mark III containment structures after
8 all the hassles in the '70s with GE.

9 And for the past 17 or 18 years I've been
10 designing various dry storage transportation systems
11 for Transnuclear. And if you look at one of our dry
12 storage systems, they look remarkably alike, we have
13 baskets or fuel racks inside our containments.

14 So with that introduction, what I'd like
15 to do is give you a brief introduction to the fuel
16 racks that were developed by Transnuclear for the EPR
17 for the new fuel vault in the spent fuel pool.

18 This covers an overview of our design
19 philosophy, a discussion of the neutron absorbing
20 materials, followed by a summary of the features of
21 the analysis that we think are unique to this
22 particular design and may be of interest to the
23 committee.

24 Okay, the fuel racks we're presenting here
25 today represent a new design for Part 50 and Part 52,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but are based on almost 40 years of work that
2 Transnuclear has been performing in the design,
3 building and operation of both transportation and dry
4 storage systems, the spent fuel assemblies under Part
5 71 and Part 72 in the U.S. and in Europe.

6 Major difference between the storage and
7 transportation cask internals, or our baskets as we
8 call them, and the fuel racks is the baskets are round
9 and supported by the cask or the canister shell, while
10 the racks are normally square or rectangular and
11 supported by the spent fuel pool floor and sometimes
12 the walls.

13 In both cases we need to consider similar
14 loads for the similar problems to resolve structural,
15 thermal and criticality issues. The basic loading
16 operations for dry storage and for the spent fuel are
17 the same. Fitting a fuel assembly into a square hole
18 as I heard referred to a minute ago, whether it's
19 bowed, twisted or warped presents the same issues.

20 We face the same criticality in cooling
21 concerns, and we have to deal with these both in wet
22 and dry conditions plus the possible problems caused
23 during removal of water from the cask during vacuum
24 drying.

25 All of this allows us to produce a rack

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design that meets the regulatory requirements and at
2 the same time uses the latest analytical techniques to
3 ensure the safety of workers and the public.

4 As shown by this figure, the rack modules
5 are designed as free-standing, independent,
6 rectangular structures which vary in size as required
7 to produce the maximum storage capacity in any given
8 spent fuel pool. The maximum size of a module is also
9 governed by the shipping requirements whether by truck
10 or rail, by the available cranes, lay-down space and
11 hatch sizes in the plant.

12 The rack modules presented here are
13 designed so that the external structural steel frame
14 carries all of the primary structural loads such as
15 the seismic handling, fuel insertion and withdrawal
16 and those due to postulated accident events such as
17 dropped fuel assembly. The actual fuel compartments,
18 or tubes, or formed by an extruded aluminum alloy
19 which provides superior criticality control and holds
20 tolerances better than the equivalent stainless steel
21 tubes.

22 Each fuel compartment is surrounded on all
23 four sides with a sheet of poison material which is
24 fabricated from metal matrix composite or MMC. MMCs
25 have been licensed for use in dry storage and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 transportation for about ten years and in spent fuel
2 pools for more than five years, and are available from
3 a number of different suppliers.

4 CHAIR POWERS: What's our experience on
5 the corrosion of those materials?

6 MR. MCINNES: Can we leave that question
7 for a minute until I get to it?

8 CHAIR POWERS: You bet.

9 MR. MCINNES: I'll try and answer it, but
10 --

11 CHAIR POWERS: Do you know what the alloy
12 is by the way?

13 MR. MCINNES: It varies. The alloy is
14 1100, with some manufacturers, 5000, 6000.

15 CHAIR POWERS: Okay. It just depends on
16 what they like to use.

17 MR. MCINNES: It depends what they like to
18 use and it depends what's being developed.

19 CHAIR POWERS: Yes, the customer's always
20 right on this thing. That's fine. It won't make much
21 difference when we get to the corrosion area.

22 MR. MCINNES: Okay, we have an answer to
23 your question.

24 CHAIR POWERS: Good.

25 MR. MCINNES: In order to meet the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements of fresh fuel, freshly discharged fuel
2 and cold fuel, Transnuclear has developed two
3 different rack structures commonly referred to as
4 Region 1 and Region 2.

5 The Region 1 racks are a medium density
6 rack which include a flux trap around each fuel
7 assembly to maintain criticality and cooling of the
8 fuel assemblies. Each of the compartments is
9 surrounded by poison sheets arranged in an egg crate
10 type structure ensuring that there's a water gap plus
11 two layers of poison between any individual assembly.

12 The geometry of the fuel compartments is
13 ensured by an external steel frame which goes around
14 the outside, plus the use of internal stainless steel
15 supports at intermediate levels within the module.

16 The Region 2 or higher density racks are
17 constructed with a similar external steel frame, but
18 in this case what we do is we take the tubes
19 themselves, place the poison between them and then
20 compact them into a very tight array. And what this
21 does is it produces a very tightly packed structure
22 which is flexible, but at the same time able to resist
23 all the applied loads.

24 The modules incorporate adjustable feet to
25 ensure uniform loading on the pool floor and the feet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are arranged in such a way that they don't interfere
2 with the pool leak chase system. We don't want a foot
3 sitting on top of a leak chase.

4 Each module is free standing, does not
5 depend upon the adjacent modules or the pool walls for
6 any support. And the new fuel storage racks are
7 Region 1 type racks which are supported vertically on
8 the feet. They sit on the floor. And then what we do
9 is we hold them at the top and bottom so that we hold
10 them against the concrete so that there's no seismic
11 amplification just by sitting on the floor and being
12 free standing.

13 CHAIR POWERS: I thought the pool was
14 completely lined. You said --

15 MR. MCINNES: No, no. This is the new
16 fuel vault. The new fuel vault itself is just a very
17 small area.

18 CHAIR POWERS: Okay.

19 MEMBER SKILLMAN: Please speak for a
20 minute about precision in the rack design from cell to
21 cell, and here's the root of my question. We found in
22 industry unless the bridge and trolley alignment is
23 precise for the dead-center cell, the fuel assembly
24 can be raked as it's being withdrawn from the cell.
25 That can lead to later potential clad degradation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 where one has actually abraded the clad or bumped the
2 spacer grid to where there's now an etch that becomes
3 a failure location for the fuel pin.

4 What feature is in the rack to ensure that
5 from cell to cell there is precision, that the rows
6 are aligned accurately in the X and Y axes, and that
7 when the racks are placed adjacent to one another the
8 spacing is such that the rack and trolley plumb is
9 accurate?

10 MR. MCINNES: Okay, as far as the Region 2
11 racks it's a really easy answer. There's a stainless
12 steel frame at the top and bottom. It's a welded
13 structure that maintains the squareness of the whole
14 rack that keeps the fuel tubes aligned within a very
15 small tolerance.

16 MEMBER SKILLMAN: Approximately what
17 tolerance is that?

18 MR. MCINNES: Probably a 30-second vintage
19 or something like that.

20 MEMBER SKILLMAN: Okay, thank you.

21 MR. MCINNES: The Region 1 racks are a
22 little more difficult because of the flux traps, but
23 it's basically the same way. There's a stainless
24 steel grid that's set up. The only difference is that
25 there's parallel plates that are about an inch and a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 quarter apart. And then the tubes themselves are
2 within that area.

3 Again the tolerance on that, within a
4 sixteenth of an inch for the fabrication. So within a
5 rack assembly the tolerances are very tight. They
6 have to be in order to keep the whole thing square.

7 Now the bigger question is between the
8 adjacent rack modules. In that case there is a
9 possibility of slight misplacement, but our racks, the
10 way they're arranged in the pool here, in the EPR,
11 spent fuel pool, there's a nominal half-inch gap
12 between the base of the modules.

13 MEMBER SKILLMAN: Is that one-half inch
14 spacing accommodated by a change in dimension from the
15 outer edge so that when the racks are aligned there is
16 a clear space from one rack to the next?

17 MR. MCINNES: Yes. The intention is that
18 the half inch is an allowance for tolerances in the
19 fabrication of the base plate. The rack modules
20 themselves have a slight projection all the way around
21 the edge of the stainless steel frame.

22 MEMBER SKILLMAN: Can you go back to that?
23 Go back one more, back to the picture.

24 MEMBER SKILLMAN: Around the base here
25 there's about a half-inch projection of the stainless

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 steel all the way around to allow for tolerances in
2 the fabrication of the rack itself. Then to allow for
3 the tolerances in the cutting of that plate when we
4 put it in the pool, we have another as I said, a
5 nominal half-inch gap between the different modules to
6 try and allow for the fact that you can place all the
7 racks modules in a straight line.

8 So that when you're placing the -- go back
9 to Slide 29. Just keep going.

10 (Off the record comments)

11 MR. MCINNES: When we're placing the
12 racks, we're placing one rack module, you place the
13 others based on, make sure that they finish up in a
14 straight line. So the original placement in the pool
15 is a geometrical placement to keep the alignment for
16 your fuel machines. Because as you say, you don't
17 want them twisted.

18 MEMBER SKILLMAN: So from my first rack to
19 my second rack, if I cross the bridge between the two
20 racks is the center-to-center geometry identical?

21 MR. MCINNES: The center-to-center, this
22 one from here to here is not identical. It changes.

23 MEMBER SKILLMAN: It changes. How is that
24 accommodated in your alignment for bridge and trolley?

25 MR. MCINNES: That I don't know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay, it's sufficient
2 for right now. I've made my point. But the real
3 issue is assuring that the racks are vertical, that
4 they're symmetrical and that we are not raking fuel
5 assemblies when we're withdrawing and inserting such
6 that we're introducing future fuel failures.

7 MR. MCINNES: The vertical alignment is
8 the feet. The feet are adjustable to make sure that
9 any misalignment on the floor is taken care of.

10 MEMBER SKILLMAN: How do you adjust the
11 vertical element in your last rack?

12 MR. MCINNES: Very carefully.

13 MEMBER SKILLMAN: Down there?

14 MR. MCINNES: They're adjustable from the
15 surface.

16 MEMBER SKILLMAN: Oh, they are, okay.

17 MR. MCINNES: So you would hopefully have
18 a survey of the pool floor so that you would do a
19 rough alignment before it went into the pool, but the
20 final alignment would be done from the top of the
21 rack.

22 MEMBER SKILLMAN: Thank you.

23 MR. GARDNER: I think maybe your
24 question's also related to indexing of the machine
25 itself, and which is maybe a different person than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Ian. If you'd like for us to bring somebody up to
2 address the indexing for the machine --

3 MEMBER SKILLMAN: At some point I would,
4 because if this part of the design is done properly
5 then future fuel failures can be reduced or perhaps
6 eliminated at least from a handling issue.

7 MR. PANDYA: I am Nitin Pandya from AREVA.
8 I am doing the design of this spent fuel machine.
9 And after the conception of the plant, the coordinates
10 of each individual rack will be measured and it will
11 be fit into the software program of the spent fuel
12 machine.

13 So the spent fuel machine instrumentation
14 and control have all the ready made coordinates for
15 each and every rack locations. And the machine will
16 be, automatically will go and stop at that particular
17 center line with some minor tolerance, and then only
18 the shop will be allowed to lower the fuel assembly
19 or lift the assembly at that particular coordinate.
20 So all the coordinates of this rack will be measured
21 once they are installed in position in the spent fuel
22 pool and fit into the software of the spent fuel
23 machine.

24 MEMBER SKILLMAN: Okay, thank you.

25 MR. PANDYA: You're welcome.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MCINNES: This slide basically just
2 shows the arrangement of the modules in the spent fuel
3 pool. There are five Region 1 racks which are on the
4 right hand side of the slide, and then there are 12
5 Region 2 racks on the left hand side. As configured,
6 the racks provide basically a ten-year storage
7 capacity with space for a full core offload at the end
8 of the ten years.

9 So the newer fuel racks are not shown
10 here, but one of the slides earlier that Pavan showed
11 had the new fuel vault just adjacent to the fuel pool
12 and there are two Region 1 racks, small Region 1 racks
13 in that vault.

14 Okay, Slide 30, and hopefully the next two
15 slides will answer your question on the MMC. The
16 fixed poison used in the racks is as I said an
17 aluminum based metal matrix composite or MMC. The
18 material consists of a fine boron carbide particles in
19 a non-porous aluminum alloy matrix.

20 MMCs are presently available from four
21 manufacturers who each use a slightly different base
22 material. One manufacturer uses an 1100 series
23 aluminum with a slight addition of titanium, but both
24 5000 and 6000 series based materials have been used.

25 Transnuclear's specification for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 procurement of MMC specifically excludes copper
2 containing alloys of aluminum due to their poor
3 corrosion performance.

4 Our experience in this material, we're
5 over 14 years in developing, testing, supplying MMCs
6 for dry storage. We began with what we call a TN-68
7 dry storage cask which was licensed by the NRC for
8 Part 72 in May of 2000.

9 And Transnuclear has been very active in
10 the development of ASTM C 1671, which is the standard
11 for practice and qualification for boron materials.
12 This standard was adapted to the environmental
13 conditions for wet storage and is the basis for
14 Transnuclear specification for qualifying candidate
15 MMCs and testing them in production.

16 Ongoing corrosion testing indicates that
17 special surface treatment or cleaning may be necessary
18 to prevent pitting initiation that iron particles that
19 the boron carbide abrades from the plate rollers.
20 Transnuclear specification stipulates that any surface
21 processing that is necessary to achieve acceptable
22 results from the qualification testing must be
23 documented and duplicated in the production. So that
24 if you qualify it one way you have to make sure you
25 continue that all the way through the production.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The NRC has also approved MMCs for wet
2 storage for the Curtiss Wright NETCO SNAP-IN rack
3 inserts that have been incorporated.

4 MEMBER SKILLMAN: Let's talk a minute
5 about the chemistry here.

6 MR. MCINNES: Okay.

7 MEMBER SKILLMAN: You bring a irradiated
8 fuel assembly over that's been three cycles in the
9 reactor and it is one of the bowed assemblies. It's
10 black as can be and it's at end of life.

11 But what it brings with it is this
12 metallic coating that is whatever has wasted from the
13 reactor coolant system pressure boundary. It's iron,
14 it's boron, it's --

15 CHAIR POWERS: Manganese, cobalt.

16 MEMBER SKILLMAN: Thank you. So now I've
17 put this getter, or this battery next to my aluminum
18 matrix. What research has been done or what data does
19 one have to confirm that I haven't created an
20 electronic cell so that I'm degrading the poison on
21 which I'm depending to provide its subcriticality?

22 MR. MCINNES: Okay, I'm looking backwards.

23 We have a couple of technical guys in the background,
24 but I don't think we have an answer to that question.

25 I think we have to get back to you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: I'd like to put that on
2 the record. Aluminum and boron to me is a battery,
3 and here we're introducing another metal. We're
4 introducing whatever has come out of the reactor
5 cooling system and there's nothing we can do to
6 prevent that from coming.

7 And so now I may have several different
8 couples, the result of which may be degradation of the
9 poison upon which I depend or the structure. So I'd
10 like to understand this a little more clearly, please.

11 MR. MCINNES: Okay.

12 MR. BRACEY: And if I may, I'm Bill Bracey
13 from Transnuclear. I think I can perhaps at least
14 give some partial answer at least. There's a lot of
15 experience with using aluminum based neutron absorbers
16 in spent fuel pools already, and that's mostly with a
17 particle, Boral, which is chemically similar to what
18 we're proposing but is different because it's porous,
19 and it has had some problems originating from that
20 porosity, mainly water getting into the pores and then
21 causing blisters to form. The products we have here
22 are not porous so they're really not subject to those
23 problems.

24 There's been no evidence to my knowledge
25 of significant chemical deterioration or galvanic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 deterioration of the Boral products that have been
2 used since the mid-1980s in storage, despite the fact
3 that they're coupled directly with stainless steel
4 tubes in most of the racks that have been used up
5 until now.

6 In our designs, because we're using
7 aluminum tubes we actually have a really large
8 aluminum surface that's in contact that is sandwiching
9 this metal matrix composite and providing enough
10 surface area that they kind of, whatever battery is
11 formed is actually fairly weak because it's diffused
12 over such a large surface area.

13 The other thing when we looked into this
14 whole question of using aluminum, we looked a lot at
15 the experience at Savannah River and storing aluminum
16 clad spent fuel, mostly a research reactor or military
17 type fuel. And their experience was there that they
18 had a fair amount of pitting, but of significant
19 problems I would say with pitting in the early 1990s,
20 which were entirely resolved by just cleaning the
21 water up and getting themselves down to below 25 parts
22 per million of chloride, which is actually very high
23 by standards of commercial reactors.

24 So we're fairly confident that the
25 maintaining the water chemistry at the levels that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 required in current spent fuel pool practice and in
2 the EPR specification will really resolve the problems
3 that you've raised.

4 CHAIR POWERS: Savannah River does not
5 have the crud problem that Dick brought up. They
6 don't have that kind of chemistry in their water, so
7 that experience probably really is not useful to
8 address this stuff.

9 MR. BRACEY: Well, I said it was a partial
10 answer.

11 CHAIR POWERS: The question that's arisen
12 in the aftermath of the Fukushima actually has to do
13 with your seismic issues that break concrete, drop it
14 into the pool and then your pool starts running basic
15 and you get a corrosion there. That's a little
16 different than the question you've addressed here.

17 MR. MCINNES: Are you asking a separate
18 question about concrete in the pool?

19 CHAIR POWERS: Yes.

20 MEMBER STETKAR: You weren't here yet.
21 Were you here yesterday? This got punted to you.

22 CHAIR POWERS: Probably because you
23 weren't here. They said oh, this guy will answer any
24 --

25 MR. GARDNER: We will be talking about a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 beyond design basis --

2 MR. MCINNES: You're way beyond design
3 basis. But first of all, if you've got a significant
4 amount of concrete in the pool I think that the basic
5 or the reaction between the concrete and the aluminum
6 would be the least of your problems.

7 CHAIR POWERS: Right now it's a big
8 problem in one of the units at Fukushima. I can't
9 remember if it was 1 or 2.

10 MR. MCINNES: I'm not trying to downplay
11 it. It would be a problem that would have to be
12 resolved, but I think it would be a minor problem in
13 the overall list of problems that would be each solved
14 at the time.

15 As far as, the source of the concrete
16 would have to be I would guess the roof of the
17 building seeing as that's the only thing that is
18 anywhere near. If the roof came down you've probably
19 got a year or so in the pool of the concrete before
20 they would start getting, pulling concrete out.

21 CHAIR POWERS: I honestly don't know.

22 MR. MCINNES: Well, I don't know either.
23 But, you know, on speculating you'd be pulling big
24 chunks --

25 CHAIR POWERS: It's not days, we know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that. I mean the problem is not big chunks. Actually
2 the problem is small chunks because they leach so much
3 faster.

4 MR. BRACEY: If I may just poke into this
5 again, is there evidence that there would be
6 sufficient alkalinity to overcome the acid of the
7 boric acid in the pool or the acidity that occurs just
8 from, even if you don't have borated water generally
9 you've got carbon dioxide absorption, so even in a BWR
10 pool it's generally at the somewhat acidic condition.

11 CHAIR POWERS: First thing that happens,
12 all the carbon dioxide gets precipitated as calcium
13 carbonate. Okay, so you kind of lose that mechanism.
14 You get a little acidification on the radiolysis.

15 I mean the calcium hydroxide's creating a
16 nice pH 10 local environment and so we're getting
17 corrosion of aluminum rack. Now theirs are literally
18 aluminum rack.

19 MR. MCINNES: I don't know. We'd have to
20 find the answer.

21 MR. GARDNER: I don't think we have
22 anything else to say other than --

23 CHAIR POWERS: Well, I mean the answer's
24 pretty much what you said is, well yes, you've got a
25 problem but you've got time to address it, need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 figure out what you're going to address it. We've
2 probably got bigger issues. I mean everything you
3 said is absolutely true.

4 MR. MCINNES: It's not something that's
5 going to cause direct failure immediately. It's going
6 to be a long term process and you've got --

7 CHAIR POWERS: Yes, and the only question
8 is what we mean by long term, whether it's months or
9 years, and I don't know the answer to that. Clearly,
10 the boron carbide aluminum composite is most at risk,
11 because I would assume that would corrode most
12 readily. But I don't even know that for a fact. I've
13 never run, I mean I've done a lot of work with boron
14 carbide dispersed aluminum but never to look at it
15 corrupted.

16 Incidentally, do you know if these guys
17 are making this composite by extrusion or are they
18 using fixotropic melting processes for --

19 MR. MCINNES: I think they do it both
20 ways.

21 CHAIR POWERS: Fixotropic is cool.

22 MR. BRACEY: Again, I can answer that.
23 The reason I'm coming up and talking about this is
24 I've been mostly the one who has been involved in
25 developing these materials for dry storage.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The materials are made by powder
2 metallurgical processes, which we're generally getting
3 away from extrusion. We're doing powder metallurgical
4 processes which are then followed directly by rolling.

5 We are doing it by low pressure.

6 Doing some work with some new people now
7 who are doing a kind of low pressure intrusion process
8 of molten aluminum into a bed of boron carbide. We're
9 working with one particular company which adds
10 titanium to the aluminum, is doing that as a molten,
11 direct chill casting process. The titanium is added
12 in order to prevent the aluminum from reacting with
13 the boron carbide.

14 (Crosstalk)

15 MR. BRACEY: So there's a little series of
16 different processes which have been developed. I mean
17 the materials started becoming commercialized in the
18 late '90s primarily based upon powder metallurgical
19 processes, but people keep coming up with new things.

20 And that's one of the reasons why we
21 specified, rather than specifying a particular method
22 we've specified a means of qualifying materials, a
23 series of qualification tests including corrosion
24 testing, and focusing on pitting particularly because
25 it's a main problem of aluminum corrosion. General

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 corrosion is not really what we anticipate as a
2 failure mechanism.

3 And also we've specified a series of
4 manufacturing testing methods, again so we can
5 generically apply them to anyone who comes up with a
6 reasonably good method of producing the material.

7 MR. MCINNES: Okay. Partially to answer
8 the questions you have been asked is that one of the
9 things we're proposing or we have in the technical
10 report is a program to put a series of coupons into
11 the pool.

12 And the program would consist of a coupon
13 tree, which would be a piece of pipe or something like
14 that onto which we would attach a bunch of coupons,
15 and these coupons would be retrieved over a period of
16 the life of the plant. And on the slide there's a
17 suggested retrieval time.

18 Coupons are typically taken from the
19 production material, and we completely measure them
20 and characterize them before they're immersed in the
21 pool. And we take a matching coupon, in other words
22 we have a bunch of coupons, we split them in half.

23 Half of them go into a dry storage so that
24 we can compare the results of the exposure to the pool
25 with the experience of dry storage to make sure any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 degradation is determined as it happens.

2 The other thing we do is we make sure that
3 the coupon tree is placed as close to the hottest fuel
4 as we can within reason about moving it around. We
5 don't think there's any irradiation problems with the
6 material, but it's moved around the pool so that it's
7 always in the radiologically warmest spot.

8 CHAIR POWERS: There are certainly
9 conditions where warm is not the worst corrosion
10 environment. I'm just trying to think if that were to
11 affect this material. Nothing comes to mind.

12 MR. MCINNES: When I say warm, it's not
13 the temperature, it's the irradiation minerals in the
14 pool. So the pool temperature would be roughly the
15 same uniform all the way across. There would be very
16 little temperature difference, but it's put in the
17 radiologically hottest spot we can find just in case
18 there's some irradiation damage that's occurring.

19 CHAIR POWERS: Well, you rack your brain
20 trying to figure out how, but yes, I guess it could.
21 Okay.

22 MEMBER SKILLMAN: I'd like to commend you
23 for that thought. The challenge that it may be just
24 as important to put the coupon where the oxide layer
25 on the fuel assembly is the greatest. Because that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can be where the chemistry in the cell or in a group
2 of cells is most seriously different from the greater
3 area or the greater volume of the spent fuel pool
4 water.

5 And so I think for this program to have
6 real meaning, the coupons need to be where the
7 radiation level is high but also where there is, if
8 you will, susceptibility of the coupon to whatever the
9 adverse chemistry may be from that irradiated fuel
10 assembly.

11 MR. MCINNES: Yes.

12 MEMBER SKILLMAN: So I think the program
13 needs to reflect not just being in a high radiological
14 area, it needs to reflect proximity to a fuel
15 assembly that is significantly crudded.

16 MR. GARDNER: Okay.

17 MEMBER SKILLMAN: Thank you.

18 MR. MCINNES: Okay, the last part of our
19 portion of this presentation just describes the
20 important features of the criticality, structural,
21 seismic and thermal analysis that we've performed.
22 And the only part of this that I want to address is
23 those parts that we think are different.

24 There's a whole bunch of analysis that
25 you've seen time after time for many different fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 racks. I'm just going to accept that that's a
2 standard method and go on.

3 Okay, criticality analysis. First of all,
4 I'll say I'm a civil engineer so I'm going to tell you
5 all about criticality analysis from a civil point of
6 view.

7 MALE PARTICIPANT: Very dangerous.

8 MR. MCINNES: Separate criticality
9 analyses were performed for the Region 1, Region 2 and
10 the new storage vault rack modules, and also to
11 evaluate the effect of interfaces between the Region 1
12 and the Region 2 modules. So we did a whole series of
13 criticality analyses.

14 The criticality analysis for the medium
15 density Region 1 racks was performed using the worst
16 case of pure water in the pool, and while the Region 2
17 analysis was done with burnup credit and credit for
18 the minimum soluble boron loading in the pool. So the
19 Region 1 analysis is pure water, Region 2 is taking
20 credit for the burnup credit and for the boron. Next
21 slide.

22 Okay, at the time the rack analysis was
23 being performed, the NRC Interim Staff Guidance or ISG
24 DSS 2010-01 was still in the process of being issued.

25 And the methodology used in the Region 2 analysis was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 based on the burnup methodology developed by
2 Transnuclear to meet the requirements of 10 CFR 71.

3 The criticality analysis methodology
4 presented in the FSAR and the TN technical report
5 incorporates all of the requirements of the ISG. The
6 advantages of the methodology that the TN has used
7 include that in previous spent fuel analyses the
8 depletion in criticality code biases and uncertainties
9 were combined in a single analysis since integral
10 methods were used for that analysis.

11 The methodology we used separates the
12 biases and uncertainties associated with depletion and
13 criticality codes and ensures that the results are
14 conservative that they develop separately.

15 The use of the isotopic assay dated to
16 benchmark the depletion codes has not been performed
17 for the typical spent fuel full criticality analysis
18 presented in the past, so utilizing this method
19 ensures that the biases and uncertainties are properly
20 characterized and well understood and conservative.

21 The criticality codes were typically
22 benchmarked to fresh fuel critical experiments and in
23 some cases to the reactor cycle data from the
24 commercial reactor criticals.

25 The French HDC experiments documented in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 NUREG-6979 are representative of burnt fuel assemblies
2 with a similar actinide composition in the spent fuel
3 pool environment.

4 And in summary, the methodology presented
5 by Transnuclear is more conservative than typical fuel
6 rack and produces, we think, a very conservative
7 result. So if we move on to the next slide, the
8 critical --

9 CHAIR POWERS: It's your last line on that
10 previous slide.

11 MEMBER SCHULTZ: What is the variety of
12 misload configurations which are evaluated?

13 MR. MCINNES: Okay, I need to get our
14 criticality expert up here. Prakash?

15 MR. NARAYANAN: Hi, I'm Prakash Narayanan,
16 and I'm the manager for nuclear analysis for
17 Transnuclear. The variety of misload configurations
18 that describe the postulated mislocation or
19 mispositioning of fuel assemblies where the misload of
20 fuel assemblies, if I want to call that, is a fuel
21 assembly that is fresh 5,8 percent fuel, and the
22 positions include space between the rack modules,
23 space in a position where a fresh fuel assembly is not
24 supposed to go into a Region 2.

25 CHAIR POWERS: I mean that's the answer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was looking for yes, you looked at a fresh assembly
2 and brought it around in all the conceivable places
3 somebody should put it.

4 MR. NARAYANAN: Yes.

5 CHAIR POWERS: Great.

6 MR. MCINNES: Okay, on Slide 35, the
7 previous fuel rack calculations have assumed 100
8 percent credit for boron loading. However, in
9 procuring this design, TN adopted the NRC requirements
10 of Part 71 and Part 72, because that's what we've been
11 working with for many, many years, and assumed a 90
12 percent credit for the boron.

13 In addition, when we procure the poison
14 sheets we impose a statistical methodology on the
15 boron loading on acceptance testing to ensure that we
16 have a probability of a 95 percent confidence. All of
17 this makes sure that we have a 15 percent higher boron
18 content than what we actually have in our analysis.

19 Also in existing fuel rack designs, the
20 spent fuel pool burnup credit analyses are performed
21 using the lattice physics codes for both depletion and
22 criticality.

23 Our methodology is based entirely on the
24 scale methodology with extensive benchmarking, which
25 results in a much better understanding of the physics

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and a better determination of the true margins
2 available.

3 And if you have questions we'll call
4 Prakash back up again.

5 CHAIR POWERS: What's your standard
6 analysis?

7 MR. MCINNES: Okay, structural and seismic
8 analysis criteria. The structural design of the rack
9 modules follows the guidance and criteria presented in
10 NUREG-0800 Section 3.8.4 Appendix D. And this
11 Appendix provides guidance on the applicable codes,
12 standards, loads, load combinations, analysis
13 procedures and acceptance criteria.

14 Following this guidance, the racks are
15 designed, fabricated and examined in accordance with
16 the requirements of Section 3 ASME Code Subsection N
17 and for Class 3 structures.

18 MEMBER SKILLMAN: If I could ask, please,
19 how do you apply these codes to the aluminum
20 components in those racks?

21 MR. MCINNES: We don't. The aluminum
22 components are not the main load carrying components.
23 The stainless steel frame is carrying all the loads.

24 MEMBER SKILLMAN: Okay, thank you.

25 MR. MCINNES: In particular, the seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation of the racks used an analysis methodology
2 that represents a significant advance over the
3 simplified mass model approach that has been used for
4 racks in the past.

5 The methodology adopted by TN removes many
6 of the assumptions and/or approximations that had to
7 be made in a lumped mass approach and explicitly
8 captures the important parameters affecting the
9 seismic response such as 3D effects, fluid coupling
10 and multi-rack interactions.

11 As we talked about earlier, the racks are
12 free standing and submerged in the spent fuel pool.
13 And the seismic responses are a function of the
14 dynamic interaction with the neighboring racks or
15 adjacent pool walls due to the hydrodynamic coupling
16 that takes place because of the water in the gaps
17 between the racks. Under seismic accelerations the
18 racks could undergo relative sliding and/or rocking on
19 the pool floor potentially developing rack-to-rack,
20 rack-to-floor impact and must be accounted for in the
21 design.

22 This largely nonlinear problem is best
23 suited to a code like LS-DYNA which has been used
24 extensively in solving many impact type and fluid
25 interaction problems in the past.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The input to the seismic models is in the
2 form of generic U.S. EPR response spectra for the
3 spent fuel building which were broadened as required
4 by Reg Guide 1.22 and amplified to account for
5 potential changes in the spectra. The envelope
6 spectra was then used as a basis for developing the
7 input time histories.

8 As required by NUREG-0800 Section 3.7.1,
9 five sets of time histories were developed and applied
10 to the full pool model shown in the bottom left hand
11 figure here. What we show here is the 17 rack modules
12 that are in the pool.

13 What the picture doesn't show is all the
14 water and the pool walls and everything else around it
15 which are all in the model. On the right hand side,
16 basically it's just an extract from one of the time
17 histories, shows the water sloshing at the surface due
18 to the effect of the earthquake. So that's just a
19 snapshot in time of what the water surface --

20 MEMBER SKILLMAN: Ian, what does the
21 coloration mean on the faces of the fuel of the 17
22 assemblies? Looks like there are three racks that
23 are, if you will, to the lower right, two racks to the
24 lower left. There appears to be an imprint of color.

25 Is that a contact pressure or a contact --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MANRIQUE: Kind of. It's what we call
2 volume fractions. That means that water has been
3 squeezed out of that area. And so the coloration
4 means that is less water in that volume of in that
5 gap.

6 MR. MCINNES: The reason it's only on
7 these three in here is that there's no core wall in
8 this area.

9 MEMBER SKILLMAN: I see. So that's the
10 squeezing out of water if the rack contacts the wall.

11 MR. MANRIQUE: No, it's not contacting the
12 wall, but as the rack is moving towards it.

13 MEMBER SKILLMAN: Towards the wall.

14 MR. MANRIQUE: Right.

15 MEMBER SKILLMAN: So that's a reduction in
16 mass. Thank you, I understand. Thank you.

17 MR. MCINNES: Okay, go the next slide,
18 please.

19 CHAIR POWERS: In your sloshing modeling,
20 how critical is sloshing in the analysis?

21 MR. MANRIQUE: Sloshing is not very
22 critical as far as the racks is concerned. The racks
23 are pretty deep in the pool. It's more a concern as
24 far as the wall design of the pool. But that's in
25 effect the rack behavior.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Well, the question of
2 course is how do you know that it's cracked, because
3 sloshing is a difficult analysis to do.

4 MR. MANRIQUE: Right. And that's one of
5 the features of the LS-DYNA code, it's able to model
6 fluids pretty well, and in this case basically
7 anything above the surface of the water we have a mesh
8 of void at the beginning of the analysis. And when
9 the analysis starts, as the water starts moving it
10 fills up into that void mesh and that's --

11 CHAIR POWERS: So you just mesh up the
12 void and it presumes to give you an answer. The
13 question is, how good is the answer?

14 MR. MANRIQUE: Well, we've validated the
15 code against, you know, standards. We have done a
16 number of validation and mitigation problems including
17 the effect of the sloshing against the ASCE 498
18 standard, for example. It has provisions for design
19 of seismic related structures.

20 CHAIR POWERS: Most of the tests that I
21 know of, and I don't make a hobby out of collecting
22 the tests on sloshing, most of them I know of are for
23 relatively small volumes of water compared to the
24 spent fuel pool.

25 And my perception, accurate or not, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that sloshing becomes more extreme as the body of
2 water that's set in motion gets bigger. And so I
3 always wonder about how well these codes are doing on
4 the sloshing part.

5 MR. MANRIQUE: Well, like I said, we've
6 made comparisons with, you know, hand calculated
7 solutions or standard solutions that are in the
8 industry and we get pretty good matching in terms of
9 response.

10 MR. MCINNES: As far as the racks are
11 concerned it's not critical.

12 MR. MANRIQUE: Yes, I mean for the racks
13 it doesn't affect it because the racks are way
14 submerged.

15 MEMBER SCHULTZ: So that's what you're
16 seeing here with regard to the modeling around the
17 racks down below, that there's some hydrodynamic
18 forces but they're not significant or considerable.

19 MR. MANRIQUE: As far as the sloshing is
20 concerned or you're talking about --

21 MEMBER SCHULTZ: As far as this model is
22 concerned you're not only doing the sloshing but
23 you're doing the hydrodynamics around the racks too.

24 MR. MANRIQUE: Oh yes, all the
25 hydrodynamics. The coupling of the water in the gaps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in between racks and between racks and the walls and
2 all that is accounted for.

3 MR. MCINNES: The sloshing is really the
4 secondary effect. We're not concerned about the
5 sloshing. We were more concerned about the effect on
6 the racks than we were about the sloshing.

7 MEMBER SCHULTZ: Down below.

8 MR. MCINNES: Right.

9 MEMBER SCHULTZ: But as you've done the
10 sloshing calculations for the pool, is there anything
11 significant that's been derived from that calculation?
12 Because this is a fairly high level of detail
13 calculation that's being done.

14 Is there any result that's been shown to
15 be dramatically different than what has been assumed
16 in the past with regard to the spent fuel pool
17 structure?

18 MR. MANRIQUE: Yes, like I said, the
19 benchmarkings that we have done with the, they used
20 the methods in ASCE standards, for example, are
21 consistent with what we are getting on this analysis.

22 MEMBER SCHULTZ: So nothing is
23 dramatically different than what's been experienced
24 with other codes previously?

25 MR. MANRIQUE: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: What I can tell you is that
2 we've had reports that during the recent Fukushima
3 accident from some of the adjacent plants, not
4 Fukushima itself, but they observed wave heights of as
5 much as a meter on the pool.

6 We were particularly interested in the
7 question of sloshing water out, and so far we have not
8 found any real significant evidence of that but some
9 very substantial waves apparently were formed.

10 MR. MANRIQUE: I mean we are seeing here,
11 this slide captures the time of maximum sloshing, and
12 if I remember correctly this is, yes, maybe around
13 four feet, four or five feet.

14 CHAIR POWERS: Four feet?

15 MR. MANRIQUE: Yes.

16 CHAIR POWERS: Substantial. Interesting.

17 MR. MCINNES: It's substantial, but it
18 doesn't appear to go over the top of the pool.

19 CHAIR POWERS: And that's consistent with
20 what we found at both Japanese earthquake, the 2006
21 and the one at Fukushima. A lot of slosh but not much
22 water loss as far as we could tell. Please continue.

23 MR. MCINNES: Okay, next slide. Okay,
24 what this shows is just a basic overview of the LS-
25 DYNA whole pool model, and basically the model

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 accounts for the rack-to-rack and rack-to-pool
2 structural hydrodynamic coupling, the effects of the
3 structural nonlinearities and interactions due to
4 pool-to-rack rocking with the sliding plus the
5 potential impacts between racks and between racks and
6 the pool structure.

7 And I gather there was a question
8 yesterday about impact on the walls.

9 MEMBER SKILLMAN: Yes.

10 MR. MCINNES: The basic answer is that as
11 far as our model is concerned there is no impact on
12 the walls.

13 MEMBER SKILLMAN: How is that assured?

14 MR. MCINNES: How is it assured?

15 MEMBER SKILLMAN: If you were to say that
16 the friction factor is great enough to prevent the
17 rack from translating so it can't hit the wall, I can
18 understand that. But it seems like it's a guess.

19 MR. MCINNES: We did a whole range --

20 MR. MANRIQUE: I mean our analysis was
21 done with, for a number of coefficient frictions from
22 0.2 to 0.8, and some others in some cases random
23 values of some computed values like 0.5. And for all
24 these cases, what we found is that the displacement of
25 the rack is less than the gap that exists between the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rack and the wall. So from that we can assume that
2 there is no impact on the liner of the fuel pool.

3 MEMBER SKILLMAN: How is that conclusion
4 affected by whether the rack is full of fuel
5 assemblies or not full of fuel assemblies?

6 MR. MANRIQUE: We've done analysis,
7 sensitivity analysis, other analysis with partially
8 loaded racks of different configurations, so that was
9 also looked into.

10 MEMBER SKILLMAN: Thank you.

11 MR. MCINNES: So basically that question
12 accounts for most of the slide. You know, the results
13 from the multi-pool model were taken so that we
14 identified the most heavily stressed modules, and we
15 took the results from the whole pool model and applied
16 them to an individual model, a highly detailed model
17 of the rack itself so that we could do a detail and
18 find an element analysis of the rack to just general
19 what the stresses were. So there's two models here.
20 There's an LS-DYNA rack model and then there's a
21 finite element model.

22 Okay, and finally is the thermal hydraulic
23 analysis. The thermal design follows the guidance and
24 criteria presented in the standard review plan of
25 NUREG-0800, and a position for review and acceptance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of spent fuel storage and handling applications.

2 Conservative methodologies were applied
3 including the heat lost to the pool walls and the pool
4 surface was ignored. The dropped fuel assembly
5 assumed across the rack at the worst possible
6 location.

7 Offloaded fuel was assumed to be placed in
8 contiguous rack cells to get the maximum heat in any
9 particular area of the pool. The maximum fuel
10 cladding temperature considers the axial peaking
11 factor and ratio of maximum to average decay heat
12 within an offload.

13 And the slide itself basically just gives
14 you the parameters that we used for the analysis, the
15 120-degree pool temperature for partial full core
16 offloads, minimum water depth of 23 feet. The maximum
17 temperature, bulk water temperature of 140, assuming
18 the loss of one active cooling train and maintaining
19 the peak fuel cladding temperature below the local
20 saturation temperature of 240 degrees.

21 MEMBER STETKAR: Ian, I know you qualified
22 yourself as a structural engineer, and I'm not a
23 thermal hydraulics guy either.

24 MR. MCINNES: But I have an answer for
25 you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: If I'm drained down to
2 the bottom of the slots, so I start out at two and a
3 half feet or whatever it is above the top of the
4 active fuel and lose all pool cooling, do you have any
5 sense of the time to start boiling in the pool from
6 those conditions, and the time to drain off until they
7 start to uncover fuel and get fuel damage? Has
8 anybody looked at that?

9 MR. MCINNES: Well, we have the gentleman
10 that did all our thermal analysis. I'm not sure
11 whether he can answer that question or not.

12 Greg, do you have a --

13 MR. BANKEN: Yes, my name is Greg Banken,
14 AREVA Thermal. And what we looked at was boiling time
15 with the minimum water level in it, the 23 feet. And
16 I'd have to look a little bit to find the number, but
17 I believe at full core offload, you know, we just
18 completed a full core offload, I think we had
19 something on the order of four hours to boiling.

20 Now if we're talking about fuel that's
21 residual fuel and has been allowed to cool for several
22 months in the pool, then the amount of heat is
23 substantially less. But then again we've got much
24 less water, so that particular time frame hasn't been
25 calculated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay, I'm sort of
2 interested in that. It's 4.3 hours in the FSAR for
3 the start to boil from your conditions.

4 MEMBER BROWN: John, is that the point
5 where it's drained down to the level of the gates?
6 That was your question?

7 MEMBER STETKAR: Are you talking about the
8 cooling trains being, not operating.

9 MEMBER BROWN: Okay. I was going to ask
10 that.

11 MEMBER STETKAR: I'm looking at margins
12 here, time margins.

13 (Crosstalk)

14 MEMBER STETKAR: I'm looking at time
15 margins in terms of --

16 (Crosstalk)

17 MEMBER BROWN: Okay, so the water's down
18 to where the gates are, none of the cooling trays are
19 operational. How long to boiling --

20 MEMBER STETKAR: How long to heat up to
21 boiling and how long to boil off to --

22 MEMBER BROWN: Roughly four hours plus
23 change.

24 MEMBER STETKAR: No, no, no. It's much
25 less than four hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, I thought you just
2 said 4.2 hours.

3 MEMBER STETKAR: If I start 23 feet, other
4 than 23 feet above --

5 MEMBER BROWN: With the full 23 feet above
6 --

7 MEMBER STETKAR: Well, it's minimum tech
8 specs level.

9 MEMBER BROWN: Oh, I'm reading the view
10 graph up there. That's the minimum.

11 MEMBER STETKAR: Starting from that 23
12 feet it's 4.3 hours under, you know, full core
13 offload.

14 MR. BANKEN: Fresh offload, yes.

15 MEMBER STETKAR: Fresh offload.

16 MEMBER BROWN: With no cooling systems.

17 MR. BANKEN: Right.

18 MR. HERNANDEZ: Excuse me, I want to add
19 something. My name is Raul Hernandez. I'm the
20 reviewer for the spent fuel pool for balance of plant.

21 Like you mentioned before this would be a
22 beyond design basis event that so we haven't asked for
23 the time to boil on a situation like that. The spent
24 fuel pool cooling system wouldn't be operating because
25 this is the below the minimum level for, in our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pressure head for the spent fuel pool cooling system
2 to be operating.

3 But this plant is designed with safety
4 related makeup from seismic Class 1 tanks and safety
5 related power.

6 MEMBER STETKAR: I understand.

7 MR. HERNANDEZ: No, no, what I'm trying to
8 say is --

9 MEMBER STETKAR: Get it on the record, but
10 yes.

11 MR. HERNANDEZ: One of the questions that
12 we've asked even though this is a beyond design event,
13 is the manual actions to isolate any possible leakage.

14 That is one of the open items that we have that are
15 in --

16 MEMBER STETKAR: Yes.

17 MR. HERNANDEZ: -- 1.4, it's what are the
18 manual actions that can be taken, what are measures
19 can be taken to isolate any leakage throughout the
20 different positions that the fuel assembly can be in,
21 because we've got several gates. So depending on
22 where the fuel assembly is in the path to the cask,
23 you could be blocking one or the other of the gates or
24 of the lifts.

25 MEMBER STETKAR: Well, and the problem is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have no idea. Until this morning I thought that
2 perhaps the, whatever they call it, the swivel gate
3 was motor operated and you could operate it remotely.

4 If it's the big guy that has to locally manually
5 operate it, dose rates are going to be pretty high
6 there.

7 MR. HERNANDEZ: That swivel gate, it is
8 motor operated but it has a manual feature that you
9 can --

10 MEMBER STETKAR: It is motor operated?

11 MR. HERNANDEZ: Yes, the swivel gate is a
12 motor operated gate that has a manual feature.

13 MR. PANDYA: No, actually --

14 MEMBER STETKAR: At the microphone, this
15 is sort of important.

16 MR. PANDYA: Yes, sure. No, my impression
17 is that this swivel gate is manually operated.

18 MEMBER STETKAR: When you say manually I
19 think manually, mechanically. Somebody turning it on.

20 MEMBER BROWN: You're talking the swivel
21 gate between the --

22 MEMBER STETKAR: Between the pool
23 sections.

24 MEMBER BROWN: Okay, not the one that goes
25 up and down for the dry, this is for the movement from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 over to that facility.

2 MEMBER STETKAR: I mean the cask loading
3 pool or the transfer pool.

4 MR. SEGALA: This is John Segala from the
5 staff. We took a trip to the Cattenon plant in
6 France, and their design there had a motor operator
7 and a manual backup. So --

8 MEMBER STETKAR: We need to understand
9 what it is here because --

10 MR. SEGALA: -- I'm not sure that we
11 appreciated a difference here.

12 MEMBER STETKAR: Yes, part of the reason
13 for my question, you know, the luxury we have is we
14 don't necessarily have to stay within the design
15 basis, licensing, single failure stuff. You're right,
16 if you drain down that far you have lost the spent
17 fuel pool cooling systems because they take suction
18 well, well, well above that elevation.

19 So the question then becomes either
20 isolation or makeup capability, how is it provided,
21 remotely, locally, time to boiling, time to boil off.

22 And if it's local mechanical manual actions, you
23 know, what are the dose rates in those areas for the
24 people doing those local mechanics? So that's all
25 kind of the reason I'm asking these.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Crosstalk)

2 MR. HERNANDEZ: Open items that we have
3 out there, you know, is basically describe which
4 equipment do you need, which are safety related, which
5 are backed up by safety related power, what manual
6 actions are you crediting, and time, how much time are
7 you crediting for those? That's one of the open items
8 that we still have up there.

9 MEMBER STETKAR: Anyway with respect to
10 AREVA, I'd still be interested in those heat up and
11 boil off times even, you know, if you haven't asked
12 them, just for my own sort of edification.

13 MR. PANDYA: And we'll take an action to
14 confirm that whether those are really manual or motor
15 operated.

16 MEMBER STETKAR: That would be really
17 useful, because I wrote down manual with a little
18 exclamation point here.

19 MR. MCINNES: This slide just shows the
20 thermal model that was used for the modeling. The
21 main features of it are just the 2.2 million mesh
22 elements which is comparable or larger than most
23 recent spent fuel pool analytical efforts.

24 And the model includes the flow pressure
25 loss through the fuel assemblies based on detailed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 modeling and measured data, and the flow between the
2 individual racks and between the racks and the pool
3 surface.

4 So that pretty much concludes the
5 Transnuclear part of the presentation.

6 CHAIR POWERS: I suspect that now is as
7 good a time as any to break for lunch. So why don't
8 we recess until 1:00 for a midday repast.

9 MEMBER BROWN: I had one question before
10 we do that and it was back on Slide 16. That was your
11 picture of the cask and the bellows picture. It was
12 in the previous thing.

13 MEMBER STETKAR: They're going to come
14 back to seal leakage if you're going to ask about
15 that.

16 MEMBER BROWN: Oh, they are?

17 MEMBER STETKAR: Yes. There's a later --

18 MEMBER BROWN: Of the cover and as well as
19 the plate that they put on underneath?

20 MEMBER STETKAR: It's a general topic of
21 seal leakage. I looked ahead. They're going to talk
22 about that --

23 (Crosstalk)

24 MEMBER BROWN: Okay, then I'll wait until
25 then. That's fine, I won't forget the question. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 may already have it.

2 MEMBER STETKAR: I have one anyway, so --

3 MEMBER BROWN: This is an electrical guy
4 that thinks of a mechanical question every now and
5 then.

6 CHAIR POWERS: We shall exact a penalty if
7 you keep us from lunch anymore, Charlie.

8 MALE PARTICIPANT: Motion to adjourn.

9 CHAIR POWERS: All right, we will recess.

10 (Whereupon, the foregoing matter went off
11 the record at 12:03 p.m. and went back on the record
12 at 1:01 p.m.)

13

14

15

16

17

18

19

20

21

22 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

23 1:01 p.m.

24 CHAIR POWERS: Let's come back into
25 session. And we're continuing our discussion of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 9.1. And Darrell, it's your show.

2 MR. GARDNER: Very well. We're going keep
3 going with fuel pool cooling and purification system.

4 And George Ifebuzo will be our AREVA guy making the
5 presentation.

6 MR. IFEBUZO: Good afternoon, my name is
7 George Ifebuzo, the AREVA NP. Again, involved with
8 the fuel pool cooling purification system for three
9 years. And my background is Chemical Engineer.

10 CHAIR POWERS: All right. Now we're going
11 to get some deep skin here. Where did you get this
12 Chemical Engineering degree?

13 MR. IFEBUZO: From the University of
14 Massachusetts, at Lowell.

15 MEMBER STETKAR: A real school, wow.

16 CHAIR POWERS: Two guys on your side
17 already, wow.

18 MEMBER STETKAR: People's better now than
19 engineers.

20 MEMBER BROWN: You're in trouble now, I'll
21 just give you a heads up.

22 MR. IFEBUZO: All right. I'm here to
23 present an overview of the fuel pool cooling
24 purification system. The system pretty much consists
25 of two separate and independent subsystems. The fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pool and the fuel pool purification system.

2 The required safety function of the system
3 is to cool and cover the spent fuel assemblies with
4 water during all storage conditions. What this does
5 is just to remove the decay heat from the spent fuel
6 pool and provide radiation shielding.

7 The U.S.EPR design conforms to the
8 guidance and requirements provided in SRP 9.1.3 and
9 Reg Guide 1.13 for safety related spent fuel cooling
10 system design. This is lightly different from most
11 operating plants which have the non-safety related
12 fuel pool cooling system design.

13 The system is also designed to prevent the
14 inadvertent draining of the pool below ten feet above
15 the top of the actual fuel assembly. The first
16 subsystem, the fuel cooling system is designed to
17 remove decay heat from the spent fuel pool. And to
18 maintain the pool at less than 140 degrees Fahrenheit.

19 And this temperature is considering fuel cool-off
20 load with single failing.

21 Without single fail the temperature is
22 kept at 120 degrees. The system consists of two spent
23 fuel cooling train which are installed on opposite
24 sides of the fuel building. The separation on either
25 side of the building limits physical effects of an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 internal hazard to just one train.

2 Each train consists of two pumps in
3 parallel and the heat exchanger. The components are
4 powered by separate electrical divisions of emergency
5 AC power. They are also designed with alternate feed
6 provision. And are backed by emergency generators.

7 The next subsystem, which is the fuel pool
8 purification system.

9 MEMBER SKILLMAN: George, please, before
10 you proceed. Back to your previous slide. The
11 location of these pumps relative to internal flooding.

12 Should the seal for the fuel cask have an upset
13 condition? Where are the pumps and their motors
14 located, please?

15 MR. IFEBUZO: They are located at the
16 lower part of the building. We would have to look at
17 the allowances as part of the previous presentation.
18 And probably address that issue later.

19 MEMBER SKILLMAN: Thank you, George.

20 MEMBER STETKAR: George, are there any
21 local power supplies for these things or are they just
22 powered from the buses?

23 MR. IFEBUZO: No local motor control
24 centers for valves. The fuel pool purification
25 subsystem provides containment isolation of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactor. Pool purification supply return lines.

2 It also provides filtration and surface
3 skimming of the reactor pools, the fuel pools and in
4 containment refueling, storage tank. And this removes
5 radioactive material and product impurities.

6 The system also provides water transfer
7 capabilities between these pool compartments. The
8 purification system, the purification loop consists of
9 two parallel purification pumps. One ion exchanger
10 and two filters.

11 MEMBER SKILLMAN: George, how is the ion
12 exchange media selected for this application?

13 MR. IFEBUZO: We use resin materials in
14 the ion exchanger for the purification.

15 MEMBER SKILLMAN: When you say selection,
16 what do you mean? Is it the same that you would use
17 for the letdown for purification for and cooling? Or
18 is this a different resin?

19 MR. IFEBUZO: I believe they are the same
20 but I would have to confirm that.

21 MEMBER SKILLMAN: Yes, I'd like to find
22 out, please. Thank you.

23 CHAIR POWERS: Is this a cation exchange?

24 MR. IFEBUZO: Correct.

25 CHAIR POWERS: So you're not doing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anion purification at all? How do you keep the
2 chloride out?

3 MR. IFEBUZO: I will look into that as
4 well.

5 MEMBER STETKAR: I think it's a standard
6 mixed bed.

7 MEMBER SKILLMAN: Yes, I think it's one to
8 one mixed bed, is what I suspect it is.

9 MEMBER STETKAR: He said it's cation

10 MR. NEWTON: We'll find out.

11 MR. IFEBUZO: Your questons was how do yu
12 keep the chloride out?

13 CHAIR POWERS: Yes. How do you keep the
14 chloride out if you're just having a cation ion
15 exchange resin?

16 MEMBER SCHULTZ: And we were told earlier
17 that chloride was a problem for this system, since
18 it's stainless steel and aluminum.

19 MR. IFEBUZO: I'll have to get back to you
20 on that.

21 MEMBER SCHULTZ: George could you
22 elaborate on the third bullet. The water transfer
23 capability between the various sections of the pool.

24 MR. IFEBUZO: Okay. So we use the
25 purification pumps to transfer water between the pool

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 compartments. We can transfer water from the transit
2 pit to the cask loading pit. We could transfer water
3 from the IWST to any of the reactor building
4 compartments. So the purification pumps in this
5 system provides that capability.

6 MEMBER SCHULTZ: Thank you.

7 MEMBER STETKAR: George, I was going to
8 ask this later, but since it looks like you can handle
9 it. The purification loop has bottom suction from
10 the reactor building pools, the cask loading, what
11 ever you call it. Cask loading pool and the reactor
12 building transfer pool. It doesn't have a bottom
13 suction from the actual spent fuel section of the
14 spent fuel pool.

15 MR. IFEBUZO: That's right.

16 MEMBER STETKAR: Is the purification loop
17 normally in operation when you're either bringing fuel
18 from the reactor into the spent pool fuel? Or
19 transferring fuel out through the cask loading pool?
20 And those are the only suction, those are the bottom
21 suction from there.

22 Are those normally aligned and open when
23 you're moving fuel? It's kind of an operational
24 question, but there's a basis for my question. A
25 design basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. IFEBUZO: I believe most of the
2 purification is done before. However there is a
3 surface skimming done during fuel handling to keep the
4 water clear. But typically purification is done as
5 needed.

6 MEMBER STETKAR: So are the bottom
7 suction simply for water transfer? In the transfer
8 pit and the cask loading pit?

9 MR. IFEBUZO: That's correct. They are
10 for purification and water transfer as well.

11 MEMBER STETKAR: Water transfer I can
12 understand, it's question of will they be open for
13 purification when they're actually moving the fuel?

14 MR. IFEBUZO: I will have to look into
15 that.

16 MEMBER STETKAR: The reason I ask is, they
17 are six inch lines and they're seismically qualified up
18 to the first isolation valve. Which is a local manual
19 mechanical, not manual push a button. Mechanical
20 valve. If you get a seismic event when the system is
21 in service and that line is open it's going to be
22 really really difficult for any human being to close
23 that valve. Presuming it's in the compartment that is
24 now filling with water through a broken six inch line.

25 So there were questions, there were RAI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions about seismic capability of the fuel pool
2 purification system. And it's not seismically
3 qualified. Is that correct? Except for the stubs
4 that come up to that first manual isolation valve.

5 That's one of the reasons why I'm kind of
6 interested under what conditions will it actually be
7 in service. And with those valves open.

8 MR. IFEBUZO: Okay.

9 MEMBER STETKAR: If you're done taking
10 notes another question. I looked at the flow drawing
11 in the FSAR and there are connections from the fuel
12 pool purification system to the what I call the normal
13 plant. Forgot what it's name is, the normal plant
14 purification system, the CVCS system. The KBE of
15 whatever the heck it's called.

16 Does the normal purification system
17 include deborating demineralizers, that you can place
18 into service to remove boron from the reactor coolant
19 system?

20 MR. IFEBUZO: Sorry, can you repeat that
21 question again?

22 MEMBER STETKAR: Does the normal, let me
23 make sure I get the right name of the --

24 MR. IFEBUZO: The CVCS system?

25 MEMBER STETKAR: Yes, the CVCS system,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 let's call it that. It's three letter distinction is
2 KBE, but CVCS. Does that system include deborating,
3 demineralizes that you can specifically use to remove
4 boron from the reactor coolant system?

5 A lot of plants. Well I don't know, I
6 don't want to presume anything. I used to be an
7 operator of a plant and we had demineralizers that we
8 cut in at the end of core life to actually remove
9 boron. You know so we didn't have to just dilute the
10 heck out of the system.

11 But I don't know whether this design
12 actually has that. The reason I'm asking is there was
13 a question that was raised by the staff about
14 potential removal of boron from the spent fuel pool
15 water.

16 And the response focused strictly on the
17 amount of pure water makeup to dilute that boron
18 inventory down to whatever nominal concentration it
19 needs to be.

20 The question came to mind, are there other
21 ways that we can remove boron. So first of all, part
22 A is are there boron removal demineralizes, ion
23 exchangers that this system could be aligned to.
24 Could it be aligned to it and how much boron could I
25 take out? Presuming I've got clean resins in there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I just start shooting this stuff through. Until
2 the resins saturate.

3 I mean you might not be able to do it even
4 if you have them. But that's a measure of capacity of
5 the demineralizers and that sort of thing.

6 MR. IFEBUZO: Well, that's part of
7 operation before we run the system. We saturate the
8 mixed bed ion exchangers with, we get the boron
9 concentration up to what the pool concentration is to
10 avoid the resins taking out boron from the pool
11 inventory.

12 There are no other systems that you could
13 connect this system to to actually deplete the boron
14 concentration in there.

15 MEMBER STETKAR: In the spent fuel pool?
16 The CVCS system doesn't have that capability?

17 MR. IFEBUZO: The CVCS system has a
18 similar ion exchanger. But we don't use that ion
19 exchanger for purifying the spent fuel pool.

20 MEMBER STETKAR: Normally you don't. I'm
21 just looking for things that actually can be
22 connected. Well, the primary question, I understand
23 normal demineralizers, ion exchangers and how they are
24 operated. The question is, first of all does the
25 design have explicitly a set of demineralizers or ion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 exchangers that are for the express purpose of
2 removing boron from the primary coolant system.

3 I mean if the answer is no, I don't care.

4 If the answer is yes, then even if it's misaligned
5 for some reason to connect those. If they saturate
6 and still can't get these fuel pool boron
7 concentrations down below what's it's minimal is, then
8 I don't care.

9 MR. IFEBUZO: I would have to look at the
10 CVCS specific design to confirm that.

11 MEMBER STETKAR: Okay. Thanks.

12 MR. IFEBUZO: The next system, which is
13 part of the fuel pool purification system is the spent
14 fuel makeup system. Other system provides makeup
15 water without using a spent fuel makeup pump to
16 provide makeup water from the transfer pit or the cast
17 loading pit to the spent fuel pool.

18 And this pump is backed by emergency
19 diesel power. And the components of the design are
20 Seismic I, Group C. As far as supplemental makeup
21 spent fuel makeup capabilities we have the
22 demineralized water system, which provides normal
23 makeup to compensate for evaporation.

24 We also have a backup water source from
25 the fire water distribution system. The RWST is also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a potential source of water for spent fuel makeup as
2 well. We also have spent fuel pool spray coolant flow
3 which is provided, these are generated back sump
4 pumps. And lastly we have good provided makeup water
5 from external sources as well.

6 MEMBER STETKAR: Are those manually
7 connected sources be connected outside of the fuel
8 building floor, operating floor? Or are the
9 connections located on the operating floor? They talk
10 about, you know, fire hoses and makeup water flow from
11 an external water source. Are those, I don't know
12 what that is.

13 MR. IFEBUZO: Well, the makeup from the
14 fire water distribution system, that connection is
15 right above the spent fuel pool.

16 MEMBER STETKAR: Somebody's got to go in
17 there and do that?

18 MR. IFEBUZO: Or makeup from the fire
19 water system we have a dedicated connection right
20 above the spent fuel pool. That actually you could
21 open the valve manually and transfer water to the
22 spent fuel pool.

23 MEMBER STETKAR: Okay. Thank you.

24 MR. IFEBUZO: So that concludes my
25 presentation, are there any other questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Do you have any questions
2 for the speaker? Means Dennis is up.

3 MR. NEWTON: Yes, my name is Dennis
4 Newton, I'm a supervisor for Nuclear Islands system
5 engineering group at AREVA. And I have over 35 years
6 in experience in design, operation and testing of
7 nuclear power plants.

8 The following slides will address
9 draindown prevention features at the plant. Leak
10 detection features and will provide three hypothetical
11 drain down scenarios.

12 The US EPR has the following draindown
13 prevention features. Regarding earthquakes all the
14 fluid retaining components of seismic category one.
15 The fuel building and the reactor building, the pool
16 liners and the suport structures. They are all
17 seismic category one.

18 Including the reactor pressure vessel
19 refueling cavity ring, there's already been some
20 discussion about that. The fuel building and reg
21 building pool drain pipes, I know you'd ask about
22 those. And the drain pipes and their isolation valves
23 are all seismic category one. So essentially you have
24 a fluid boundary that's all seismic category one. So
25 there's nothing in theory break if you have an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 earthquake event.

2 Regarding syphon draining, the spent fuel
3 pool, the purification system, the supply and the
4 return pipes are, they're all located at least 20 feet
5 above the fuel. And they all have siphon breakers.

6 And I think this might have been a
7 question that you had asked earlier. The purification
8 system takes suction from that higher elevation and
9 returns it at higher elevation. And the drain lines
10 at the bottom of the pool at the pit, and the bottom
11 of the transfer pool. They are normally isolated and
12 they are only used if your going to be draining those
13 pits.

14 MEMBER STETKAR: They're not used to align
15 purification while the pits are in service?

16 MR. NEWTON: Right, that's correct.

17 MEMBER STETKAR: Okay. Thanks.

18 MR. NEWTON: Regarding flexible joints.
19 If we have a flexible joints we usually have two seals
20 and you can monitor for leakage going in between the
21 seals. The examples are the baffles that were
22 discussed earlier in the penetration assembly.

23 We have The baffles that come down and
24 that is pressurized between the two baffle plates.
25 And you monitor the pressure there to see if you get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 any leakage. The same thing for the O-ring seal that
2 you have, say at the boundary between the cask and the
3 penetration assembly that pressurizing between there,
4 so you can monitor for leakage.

5 Regarding gate openings, both gates have a
6 slot valve and a swivel valve. We talked about that
7 before, and they're both category one. Regarding the
8 spent fuel cast transfer facility. The penetration
9 assembly that comes down, any piping that goes into
10 that, it's Seismic Class I after the first after the
11 first manual valve.

12 If we have any valve that are normally
13 open, then there will be two of them. And they're
14 safety related and they are solenoid and they require
15 power to remain open so if they lose power, they
16 close.

17 Regarding draindown detection features. I
18 guess I mentioned earlier, leakage is monitored
19 between, we have double barriers. Like I mentioned
20 the baffles and the seals.

21 Level sensors, they are provided in each
22 compartment or each area of the fuel building. And
23 the reactor building pools that can be
24 compartmentalized. For each compartment there's two
25 narrow range, there's one wide range. And there's one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 local detector.

2 Now the spent fuel compartment is a little
3 bit different, where that has two wide range and two
4 narrow range and there are both 1E. And all of the
5 detectors, except for the local ones of course are
6 monitored measured in the main control room.

7 MEMBER SKILLMAN: Dennis, please explain a
8 little more about your first bullet. Leakage
9 monitoring suggests something or some one is one
10 watch. Either an electronic device is keeping track
11 of rate or decay or some parameter. Or somebody is
12 looking at the parameter. What do you mean by leakage
13 monitoring between double leakage barriers?

14 MR. NEWTON: These examples we were
15 talking about before. We have these baffles. Do you
16 want to explain those?

17 MR. PANDYA: I'm Nitin Pandya from AREVA
18 NP and about this leakage monitoring there reduces in
19 the spaces being pressurized by compressed air. And
20 this pressure we have been monitoring maybe a pressure
21 transmitter and it will send a signal to the control
22 room. So whenever the pressure reduces the
23 transmitter will give the signal.

24 MEMBER SKILLMAN: This is a constantly
25 monitored parameter?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANDYA: Yes, this is a constantly
2 monitored parameter. This pressure monitoring. But
3 it is more important when we are doing the mainly the
4 cast loading process.

5 MEMBER SKILLMAN: So when you are not
6 loading the cast is this still a monitored parameter?

7 MR. PANDYA: That is a sort of grey area.
8 Again we decided if the plant operator wants to
9 monitor it, as we know these gates remain closed. If
10 we do not do anything like cast loading in the
11 loading, then the gates will remain closed all the
12 time. Then how valuable it is to keep this pressure
13 between the inter gasket monitoring, that I think has
14 to be through the UT and ET.

15 MR. GARDNER: Let me add too, I think,
16 Mr. Skillman, I think that would be dependant on
17 whether you have water in this pit or not. If the pit
18 were dry there would be no need to monitor for the
19 seal.

20 MR. PANDYA: So you can decide not to
21 monitor then somebody may decide that we still need to
22 monitor.

23 MEMBER SKILLMAN: What other double
24 leakage barriers are there besides the bellows?

25 MR. PANDYA: In the penetration assembly,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all are double barrier. Like bellows are double
2 barrier. There is a double seal, then there is a
3 double cover upper and lower cover. Through the
4 penetration and then there's a double gate.

5 All are double, and also the pipeline is
6 connected with the cask or to the penetration, they
7 have double insulation. So fuels boundary are double.

8 MEMBER SKILLMAN: Which of these need to
9 be monitored during normal power operation?

10 MR. PANDYA: During normal power
11 operation, if the cask loading process is not going
12 on. The penetration of upper and lower cover will
13 remain shut. Both these gates will remain shut.
14 Loading features will remain isolated from the spent
15 fuel pool. It may have water, may not have water. If
16 it has water then some monitoring may come into
17 picture, but otherwise it's not needed.

18 MEMBER SKILLMAN: It's not needed. Thank
19 you.

20 MR. PANDYA: It's not needed, yes. It's
21 not a must.

22 MEMBER STETKAR: Dennis, just to make
23 sure. You mentioned the fuel pool has wide range.
24 I'm assuming wide range goes all the way down to the
25 top of active fuel at least.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. NEWTON: I don't know the exact range.
2 Do you know the exact range or the wide range level
3 of the wide range level detectors?

4 MR. IFEBUZO: We have wide range
5 monitoring in the pools.

6 MEMBER STETKAR: Well, you know, I worked
7 in a plant, we had what they called wide range
8 monitoring but it was just wider than the narrow one.
9 It wasn't full range.

10 MEMBER STETKAR: We can check on that.

11 CHAIR POWERS: You're probably going to
12 get to do it no matter what. Somebody someplace is
13 going to want wide range from the top of the pool to
14 the floor.

15 MEMBER STETKAR: Certainly at least to the
16 top of the fuel. But to the floor would be even
17 better.

18 CHAIR POWERS: Well, they're going to want
19 it. Whether it's better or not. Like I say the best
20 level detector I know of for the spent fuel pool are
21 two eyeballs.

22 MR. NEWTON: I'm sure the pools that they
23 can drain all the way down to the bottom.

24 CHAIR POWERS: Continue, please.

25 MR. NEWTON: The drain isolation valves,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're talking about the drain lines. If it's bigger
2 than two inches there are two manual valves. They're
3 not motor operated, so if they're manual if they're
4 closed, they're closed. And they all have position
5 indicators that are in the control room. So the
6 operators know whether or not those valves are open or
7 closed.

8 Then the next item is the leakage from the
9 fuel building pool liner, it's collected and it's
10 monitored. So we can detect any leakage through the
11 liner in the pool.

12 CHAIR POWERS: I was going to ask at the
13 end of your presentation, how in the workd are you
14 going to get this pool to leak tritiated water into
15 the ground water? But you beat me to it.

16 MR. NEWTON: Yes, I mean the pool's way
17 up, so there's numerous levels of the building that
18 it has to pass down through before it can get there.

19 CHAIR POWERS: Yes, water's good at
20 passing down. Tell me about this liner leakage
21 business.

22 MR. NEWTON: Yes. The water that is
23 collected from the leakage it is sent to the nuclear
24 island drain and vent system, so it is collected. It
25 is not allowed to go to the ground.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: What basically, it's not a
2 good idea to let it go to the ground, contrary to the
3 way I was going to phrase my question. So between the
4 liner and the concrete we've got some sort of channels
5 there?

6 MR. NEWTON: Yes, we have channels and
7 they are positioned behind where the wells are in the
8 liner.

9 CHAIR POWERS: Yes, and they're sloped
10 downwards or something like this?

11 MR. NEWTON: The final design of it is
12 going to depend on what the liner looks like. But the
13 going in plan is to have a channel behind each of the
14 wells in the liner. And yes it will be sloped so it
15 can drain.

16 MEMBER STETKAR: Is there some special
17 design feature that can ensure that those lines are
18 open? We had some experience showing that people have
19 a lot of drain lines and when you go in and actually
20 boroscope them they look like not so much drain.

21 CHAIR POWERS: More like plugs.

22 MEMBER STETKAR: More like plugs, yes.

23 MR. NEWTON: Yes, they are going to be
24 designed so they can be flushed.

25 MEMBER STETKAR: So you will have, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reason I was asking you in the context of design, not
2 operation was either some sort of active flushing or
3 pneumatic pressurization or something.

4 MR. NEWTON: Yes, something there to keep
5 boron plugs from being in the channels.

6 CHAIR POWERS: I guess we have had
7 concerns about corrosion in those areas as well,
8 haven't we?

9 MEMBER STETKAR: There has been, yes.

10 MEMBER BROWN: Before you leave that,
11 somebody mentioned a minute ago that this thing has
12 fuel control has two water level indicators and two
13 temperature indicators?

14 MR. NEWTON: I didn't mention temperature.

15 MEMBER BROWN: Well, somebody did,
16 somebody was talking about instrumentation. So I went
17 off and look in 9136 and I was trying to find where
18 that was listed and I couldn't see it. It just says
19 you're going to level and temperature, it doesn't say
20 how many.

21 And I've looked in the drawing and I
22 couldn't see any even listed on the drawing. So I was
23 kind of wondering where the requirements were for
24 those. Like where they go?

25 MR. NEWTON: I think the drawing that's in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the FSAR, it had like a lollipop with something on it.

2 MR. IFEBUZO: Yes, that's the way we'd
3 indicate it.

4 MR. NEWTON: But if you look at the system
5 description for the document it gets into much more
6 detail.

7 MEMBER BROWN: System description, what do
8 you mean, the technical report of some kind, not the
9 FSAR?

10 MR. NEWTON: Right, not the FSAR.

11 MEMBER BROWN: Well, it wasn't even
12 referenced. So I mean, there's no reference, at least
13 in that section as to where any other technically
14 document that might be used in terms of developing the
15 design.

16 In other words what are the ranges of
17 them, what's the configuration? What type of
18 indicator do you desire. There doesn't seem to be,
19 I'd really like to know where that is and have that
20 described.

21 MEMBER STETKAR: We'll take an action to
22 go look for that.

23 MEMBER BROWN: Okay.

24 MR. NEWTON: Obviously we don't have every
25 design detail in the FSAR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Oh, I understand that, you
2 don't have any design detail on the protection system
3 and the FSAR's either. You have to go to all these
4 other technical reports.

5 MEMBER STETKAR: Wrong people, to talk to
6 about that.

7 MEMBER BROWN: No, I'm just poking at
8 them. It's the same disease and I don't have any
9 problem but at least there the DCD references the
10 other documents and tells you where to go look. Here
11 I was unable, it might be in there but I was unable to
12 find it.

13 MR. NEWTON: We'll track it down.

14 MEMBER BROWN: Okay. Thank you.

15 MR. NEWTON: Mediation. We have three
16 hypothetical draindown scenarios. To give a sort of
17 feel of magnitude for what we have here. These are
18 all beyond basis. Design basis accident is dropping a
19 fuel assembly. We're pretty well protected for that.

20 The first one is those double seals that
21 we had talked about earlier. It's assuming that both
22 seals fail, and the seals that fail are the ones
23 between the cask and the penetration assembly.

24 So we assumed both of those failed. The
25 cask loading pit gateway is open to allow the transit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the fuel assembly. And there's a fuel assembly in
2 the pit. Now we don't assume any makeup water,
3 however we can get 400 gpm from the purification
4 system.

5 Now the purification system takes suction
6 from the IRWST. You probably saw are connection with
7 the CDCS. And the leak that we came up with was a 390
8 BTM, miraculously it's just below 400 BTM. But we
9 assumed we have both seals failed so it's 360 degrees
10 all the way around.

11 MEMBER STETKAR: That's simply the orifice
12 flow through that. It's just as if they weren't
13 there.

14 MR. NEWTON: Right, it's just as if they
15 weren't there. We used a .35 millimeters, which is
16 actually the seal up on the cover. The seals down
17 between the cask and the penetration assembly actually
18 wouldn't be squished, it's metal to metal contact.

19 And for 390 gpm the water level in the
20 spent fuel pool would decrease about one foot in 30
21 minutes. So the operator has adequate time to move
22 the fuel assembly out of the cask loading pit and over
23 into the spent fuel pit. And get that swivel gate
24 closed.

25 CHAIR POWERS: Of course, Dr. Ryan asked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you what happens if he can't get pull it down?

2 MR. NEWTON: Well, there is the cover
3 plate, that could also be closed. If he can't get the
4 swivel gate closed, there's always the option of
5 getting the slot gate. If you have a crane, lower
6 that into place.

7 MR. GARDNER: I think his question was if
8 the assembly was physically stuck halfway in the cast.
9 But we're talking about if the assembly were in the
10 pit in transit. Not stuck halfway in or out.

11 CHAIR POWERS: I see no reason not to have
12 it stuck.

13 MEMBER RYAN: Not having it stuck is a
14 much better thing than having it stuck.

15 CHAIR POWERS: If they're going to make
16 them a bad day we might as well make it a really bad
17 day.

18 MEMBER RYAN: That kind of highlights
19 were we can't do much with it. That's kind of a bad
20 day at the plant so I was curious how you thought
21 about that.

22 MR. GARDNER: Of course we're showing here
23 that we could just keep it there with water over it.

24 MR. NEWTON: You mean just keep pumping in
25 makeup water.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SCHULTZ: And when you're loading
2 the cast, I misunderstood perhaps, I thought when you
3 were loading the cask you move some assemblies into
4 the cask loading pool.

5 MR. NEWTON: One at a time, use a
6 manipulating crane, you pick up a fuel assembly, move
7 it into the pit and lower it down into the cask. And
8 we're all straight.

9 MEMBER SKILLMAN: We're still waiting to
10 hear where that water goes, okay? The internal
11 flowing, we want to know where it goes please.

12 MR. NEWTON: Water does go into the
13 refueling hall. The flooding analysis assumes a six
14 inch pipe break at penetration. So it might be about
15 3,000 gpm, that's what the flooding analysis assumes
16 it can accommodate. It all goes into the drains,
17 which goes to the nuclear island drain and vent
18 system.

19 MEMBER SKILLMAN: Well, at that flow rate
20 your nuclear island drain event system is going to
21 fill up very quickly.

22 MR. NEWTON: I don't know about the rest
23 of the analysis.

24 MEMBER SKILLMAN: I'd like to pursue this.
25 Let's really find out what happens if there is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 malfunction. Let's take the one that Dr. Ryan points
2 to. You've got a fuel assembly that's halfway in and
3 halfway out. There are normally a quarter of a
4 million of R per hour.

5 Okay. They're screaming and now you've
6 got a water leak and now you've got a mechanical
7 device that in all candor, quite difficult to
8 approach. This scenario is one I think deserves some
9 reasonable consideration. Because there are some
10 profound safety issues associated with this.

11 MR. NEWTON: Last bullet, assuming
12 absolutely nothing is done it will take over eight
13 hours, maybe closer to 11 hours for all the water to
14 go down to the top of that weir. So just a feel for
15 the magnitude of how slow it drains down.

16 MEMBER STETKAR: Through those seals.

17 MR. NEWTON: Yes. We can go on to the
18 next line. The next scenario, it assumes a crack in
19 two pipes, one in the penetration assembly and one in
20 the drain.

21 (Off microphone discussion)

22 MR. NEWTON: Okay. Anyway we assume a
23 crack in two pipes, one pipe is the six inch drain
24 coming off the bottom of the pit. And the other one
25 is a two inch pipe going to the penetration assembly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's the pipe that's used for venting, draining the
2 penetration assembly itself.

3 And the leak rate we've got from those two
4 cracks, the combined leak rate is 75 gpm.

5 MEMBER STETKAR: That's a crack.

6 MR. NEWTON: And the rest of the scenario
7 is similar to the first scenario.

8 MR. GARDNER: Is your crack equivalent to
9 the full six inches?

10 MR. NEWTON: No. The crack is based on
11 Branch Technical Edition 3-4. For a moderate energy
12 pipe break, pipe fracture.

13 Okay, the next slide is inadvertent
14 opening of a reactor building pool drain valve.
15 There's an eight inch common header. That's the
16 biggest drain pipe we could find.

17 And we assume that the isolation valves
18 are open on that, along with, you have to have two
19 other drain lines open that are six inches. And that
20 will drain about 5,000 gpm, and it will go to the
21 IRWST and of course you have your ECCS system that can
22 pump that back in until you're able to do something.

23 And the pool will drop about seven and a
24 half feet in thirty minutes. If you have a fuel
25 assembly in the transfer pit, if you lay it down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 horizontally it will provide 12 feet of water over it.

2 And that is my last slide.

3 CHAIR POWERS: You still didn't give me
4 any tritiated water on the ground. You're just not
5 trying Dennis, that's all there is to it. Any other
6 questions on this area?

7 MEMBER BROWN: Just one, the spent fuel
8 pool makeup capability, where is that controlled from?
9 Is that a local operation or can it be operated from
10 the main control room?

11 MR. IFEBUZO: The pumps are started and
12 stopped from the control room but you have to manually
13 open the valves.

14 MEMBER BROWN: Okay.

15 MR. IFEBUZO: I mean, not manually,
16 physically you go put your body on it. Just like
17 opening a faucet in your kitchen. Slightly bigger
18 valve.

19 MEMBER BROWN: Okay. Thank you.

20 CHAIR POWERS: We're going to do heavy
21 stuff now. We'll move on to heavy load handling and
22 Rick Parler.

23 (Off microphone discussion)

24 MR. PARLER: My name is Rick Parler, I'm
25 an advisory engineer with the AREVA NP. With a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 background in civil. And today I'll be addressing the
2 overhead heavy load handling system. This
3 presentation provides information on the design
4 methods used by AREVA to ensure safe handling of heavy
5 loads.

6 We begin with a definition, a heavy load
7 is defined as a load the weight of which is greater
8 than the combined weight of a single spent fuel
9 assembly and it's handling tool. And for the U.S.EPR
10 that value is greater than or equal to 1,730 pounds.

11 The AREVA design meets the NRC guidance
12 specified in NUREG 0612 which discusses the control of
13 heavy loads at nuclear power plants. Also with regard
14 to single failure proof cranes, that guidance provided
15 by NUREG 0554.

16 The industry standards that are used that
17 implements this guidance are those ASME NOG-1 which
18 provides the rules for construction of overhead and
19 gantry cranes. And ASME NUM-1 which provide the rules
20 for construction of cranes, monorails and hoists of
21 the underhung type.

22 For handling heavy loads during the final
23 operational phase AREVA will make use of either a Type
24 1 or a Type 2 crane. The definitions of Type 1 or
25 Type 2 are provided here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Type 1 is designed to handle a critical
2 load. It's designed to remain in place and support
3 the critical load during and after a seismic event.
4 The crane does not have to be operational after the
5 event. And it also incorporates single failure proof
6 features.

7 The Type 2 crane is not used to handle a
8 critical load. It's designed to remain in place with
9 or without the load during a seismic event. It need
10 not support the load or remain operational after the
11 event and single failure proof features are not
12 required.

13 Where single failure proof designs are
14 used the hoists load path components are designed such
15 that any credible failure of a single component will
16 not result in a loss of the capability to stop and
17 hold the critical load.

18 And the critical load is defined as any
19 load who's uncontrolled movement or release could
20 adversely affect safety related systems required for
21 unit safety. Or could result in potential offsite
22 exposure in excess of established limits.

23 The U.S.EPR has four single failure proof
24 cranes and those are the Polar crane, the fuel
25 building auxiliary crane. The fuel building upper

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 penetration cover hoist, and the fuel cask biological
2 lid handling hoist.

3 The Polar crane is used to during outages,
4 it handles items such as the closure head. The upper
5 and lower internals. The stud tensioning machine,
6 cover slabs, things of that nature.

7 The auxiliary crane in the fuel building
8 is used to handle fuel containers, fuel gates and
9 other miscellaneous loads. And the upper penetration
10 cover hoist and biological lid handling hoist, I
11 believe we have talked about previously, in Section
12 9.1.4. Those are used with the fuel cask transfer
13 facility.

14 Those two hoists are stationery hoists,
15 meaning they are dedicated for that one operation,
16 there is no bridging or trolley necessary for those
17 two hoists.

18 For a Type 1 single fail proof design, the
19 design focuses on those components which are located
20 between the source of the load and the energy holding
21 the load. This would be the attachment point, the
22 hook to the load. The hook and then lower load block,
23 upper block, the geartrain transmission and holding
24 brakes.

25 And the single failure proof design is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 accomplished by the use of dual or redundant
2 components and or by doubling the design factors.

3 When Type 2 cranes are used to handle
4 heavy loads they'll be used either for lifts or
5 equipment not required to perform a safety function
6 during an outage condition. For example they will
7 make use of stops and air locks to prevent the load
8 from going over safety related equipment. And they
9 will also in some cases be designed, the equipment or
10 components will be evaluated for the effects of a load
11 drop.

12 So the design and use of the cranes in
13 this manner will provide a safe and reliable heavy
14 load handling capabilities for the U.S.EPR

15 There is one COL item regarding heavy
16 loads, and that being the applicant that references
17 the U.S.EPR design will provide site specific
18 information on the heavy load handling program.

19 Which includes a commitment to the
20 procedures for heavy load lifts near irradiated fuel
21 or shut down equipment. And will also provide crane
22 operator training and qualification. Basically the
23 items that are required for compliance with the NUREG
24 0612.

25 Do you have any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Yes, have single failure
2 proof cranes been used in the European designs?

3 MR. PARLER: Yes.

4 MEMBER SKILLMAN: And is this design
5 certification design a copy of those designs?

6 MR. PARLER: As far as the equipment
7 layouts it is. But as far as the method by which the
8 design is performed it will be done to the ASME
9 standards.

10 MEMBER SKILLMAN: By and large what you're
11 depending on is doubling the factors in order to give
12 design margin?

13 MR. PARLER: Doubling factors or providing
14 redundant components points.

15 MEMBER SKILLMAN: Okay. Thank you.

16 MR. GARDNER: Okay, Dr. Powers that
17 concludes our presentation on Chapter 9.1.

18 CHAIR POWERS: Do you have any more
19 questions for the applicant? Then I guess we'll move
20 on. Thank you very much.

21 MR. TESFAYE: Dr. Powers, before the staff
22 presents Section 9.1, would it be possible to answer
23 two of your questions from this morning?

24 CHAIR POWERS: Absolutely.

25 MR. TESFAYE: Okay. Those questions are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the CRDM system and equipment qualification acidic
2 environment.

3 MR. MIERNICKI: I'm Mike Miernicki, a
4 Chapter 3 PM, and with me I have Jason Huang who is
5 with the general mechanics branch. And Jason is the
6 technical reviewer for Section 394. And the question
7 from this morning was with respect to the CRDM
8 testing. Whether the staff had missed the test
9 results, the drop test results or audited the results.

10 So Jason has the audit information with him, he can
11 speak to that.

12 MR. HUANG: Okay. So on April 9th, 2009
13 the staff performed an audit to review the prototype
14 testing program. To determine the mechanical adequacy
15 of the CRDM. And during the audit the applicant
16 provided the prototype testing results for the CRDS
17 design.

18 Which consists of performance, stability
19 and endurance testing. And the performance test
20 results verify the adequacy of the performance of the
21 equipment. In the range of temperature, pressure and
22 full conditions. The stability test result ensured
23 proper functioning is achieved over time. And this
24 also included full height drop tests.

25 The endurance test results quantified the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 number of steps during which no appreciable damage
2 possibly altering the mechanical behavior is expected.

3 And these were performed up to nine million steps.
4 And the staff determined the test results were
5 acceptable.

6 And in the followup we requested that they
7 provide the basis for the 60 year design life. And
8 the applicant responded by providing us the test
9 results from the endurance test, which confirmed the
10 nine million tests.

11 CHAIR POWERS: Okay. If I recall the
12 question also included the question of did you assess
13 that the test design was sufficient or did you just
14 look at the results of the tests?

15 MR. MIERNICKI: We looked at their test
16 results for the prototype testing. And we also
17 reviewed their procedures. And audited a number of
18 documents they had, the KOPRA facility had the, during
19 the audit we reviewed the drop times that were
20 recorded during the stability test.

21 And we also looked at the report for the
22 performance tests and their test specifications and
23 the analysis for the design loadings.

24 MEMBER SKILLMAN: Let me ask this please.
25 To what extent did you review the most adverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 geometry between the upper internals, the control rod
2 guide tubes and the weldments to the upper end
3 fitting?

4 This is where the rod is fully withdrawn
5 but the internals are off, displaced by 30 thousands
6 of an inch. Where the tip of the rod must now find
7 it's way through a very small displacement. As the
8 rod continues to insert that friction factor begins to
9 impede flight time.

10 So my question is really about the
11 precision of the test and the accuracy of the flight
12 time given that there could be some displacement
13 between the upper internals and the upper end fitting?

14 MR. HUANG: Okay. Are you referring to a
15 test that's normally performed on the control rod
16 drives?

17 MEMBER SKILLMAN: I'm talking about a
18 realistic view of the manufacturing tolerances so that
19 when the upper internals are placed on the fuel
20 assemblies there are certainties of flight times will
21 be achieved.

22 MR. HUANG: I'll have to get back to you
23 on that.

24 MEMBER SKILLMAN: I'd like you to do that
25 please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MIERNICKI: AREVA, can you answer
2 that, if that was part of the testing we.

3 (Off microphone discussion)

4 MR. STACK: Let us look into that.

5 MEMBER SKILLMAN: Thank you.

6 MR. MIERNICKI: Jason's operating under a
7 disadvantage here because he wasn't a part of that.
8 So it wasn't something we can recollect, we'd have to
9 visit some other people.

10 MEMBER SKILLMAN: It would be the control
11 rod drive line misalignment study. And this is for
12 the internals and manufacturing tolerances is
13 aggregate intolerance to compromise flight time. And
14 it can only be caught if it's manufactured properly
15 the first time.

16 MR. MIERNICKI: Any other questions in
17 that area? Okay. Thanks, Jason. Okay, and the
18 second question we'd like to address was related to
19 equipment qualification. It was concerning the nitric
20 acid formation in the containment after large break
21 LOCA and potentially in a high rad environment there
22 might be nitric acid formation.

23 And whether that was considered by the
24 staff and if not why was it okay not to consider that
25 potential. So Peter Kang from the instrument control,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electrical branch is going to address that.

2 MR. KANG: Yesterday during the 311
3 environmental qualification presentation that Dr.
4 Powers asked us why is the chemical effects of the
5 nitric acid was not considered. And asked staff why
6 it is acceptable.

7 Addressing 10 CFR 49, which is environment
8 qualification of electrical equipment. And the FSAR,
9 Section 311 of FSAR requires all components which will
10 be located in a harsh environment, such as inside of
11 containment, should be performed it's function for all
12 anticipated environmental conditions. During and
13 following the design basis event.

14 Which design basis event is defined as
15 abnormal operations and including post and accident
16 conditions and anticipated operational occurrences and
17 the design base. So that's how we define it. And
18 also basically it's in 5049, rule identify's
19 environmental condition as, temperatures, pressures,
20 humidity and aging of the radiations. And it also
21 includes chemical effects.

22 So during our staff review of Section 311,
23 our staff had the similar questions. Concerns and
24 asked the questions on the chemical effects. Because
25 in their program chemical effects was all identified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as not applicable or none.

2 So subsequent telephone call with the
3 applicants and they indicated chemical spray was not
4 used before mitigating design basis by event.
5 Therefore the chemical effect was not considered as a
6 environment conditions. Equipment has to be
7 qualified.

8 So the conversation was on and on and the
9 staff asked what about the core spray? Which is sit
10 on top of containment and AREVA's answer was core
11 spray system was used only, it's not only non class 1E
12 system, it's also used during, only for severe
13 accident cases.

14 So if it is only used for, it's not used
15 for design basis of event AREVA explained a chemical
16 effect is not considered one of environmental
17 conditions that they should consider for equipment
18 qualifications.

19 So that chemically in fact it was not
20 considered. So only chemical effects in the 311 was
21 discussed was a containment sump area which requires
22 maintaining pH level of 7.0, which is neutral, or
23 higher by using a trisodium phosphate basket.

24 So on this basis nitric acid was not
25 considered as an environmental condition that requires

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to equipment needs to be qualified for environmental
2 qualifications.

3 CHAIR POWERS: Well, then the question
4 remains, why not? There's going to be nitric acid,
5 it's going to be every place.

6 MR. KANG: Well, it's basically inside of
7 containment by accidental environment but there was no
8 moisture. Which is the sprays, containment spray is
9 not used so not like any other normal plans.

10 CHAIR POWERS: DBA is flow down of a
11 pressurized vessel in the containment which takes you
12 up to the design basis pressure and steam. You've got
13 lots and lots of water vapor I presume.

14 MR. KANG: Okay. So to neutralizing that
15 using a sodium phosphate basket.

16 CHAIR POWERS: It keeps your sump. But
17 the problem is what about all your electrical
18 equipment, any kind of equipment in the containment
19 that's going to be exposed to this nitric acid vapor
20 that's being created by radiolysis. I believe the
21 staff uses about a megared per hour as their DBA dose
22 rate in the containment.

23 MR. KANG: But we are talking about that
24 during post accident before and after design basis of
25 accident which could be very --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: You got 30 days.

2 MR. KANG: Yes, 30 days.

3 CHAIR POWERS: You got lots of time, so
4 you start off, for the first 24 hours I think it's
5 something like a megared per hour. And then it drops
6 off after a while to about two tenths of a megared per
7 hour.

8 MR. KANG: Right.

9 CHAIR POWERS: So you're generating
10 throughout this you've got a G-value for nitric acid
11 formation roughly .21 molecules per hundred electron
12 volts, something like that. So you've got a lot of
13 electron volts going into the atmosphere. You're
14 making nitric acid. And I just suspect that that's
15 not too good for anything electronic.

16 MR. KANG: So that's the explanation for
17 what we had, we received it from applicant's so that
18 was our basis for chemically effects. In fact they
19 have not considered any chemical effects.

20 CHAIR POWERS: One of the things that a
21 little bit surprised me is that none of their cable
22 insulations seemed to have polyvinyl chloride in it.
23 And so they get no HCl coming off due to the
24 radiolysis of the cable insulation and the post DBA
25 environment. Is that some area you've looked at?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KANG: Basically like yesterday was
2 discussed the PVC, which is HCl, hydrochloride
3 generation because we are not using PCV cables inside
4 of containment. That element is quite a bit.

5 CHAIR POWERS: Yes, that's big help if you
6 don't have any.

7 MR. KANG: Yes, and also Hypalon cables
8 and all that and those silicon EPR silicon based on
9 the cables we aren't expecting too much generation of
10 the hydrogen chloride generations.

11 CHAIR POWERS: Yes, if you don't have any
12 chloride in there's not going to be any HCl. That you
13 can be fairly confident of.

14 MR. KANG: Yes.

15 CHAIR POWERS: We have to be very careful
16 because manufacturers aren't too good about telling
17 you what's actually in those cables. But if you don't
18 have it you don't have. But you do have nitric acid,
19 that's unavoidable because you've got nitrogen in the
20 air. Okay. Thank you.

21 (Off the record comments)

22 You ready to go?

23 MR. TEFAYE: Yes.

24 CHAIR POWERS: Let's do it to it.

25 MR. HEARN: My name is Peter Hearn, I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Chapter 9 PM, we'd like to present the
2 presentation for the FSAR the Chapter 9.1 fuel storage
3 and handling. The staff review team consisted from
4 the technical staff of Chris Van Wert, Amrit Patel.

5 And the reactor systems branch Raul
6 Hernandez and Gordon Curran. From the balance of
7 plan branch. And Jim Xu from the structural
8 engineering branch. The lead PM is Getachew and I'm
9 the Chapter PM.

10 During the review this next slide shows in
11 each section the number of questions and open items.
12 During the review of 9.1 there were 182 questions
13 asked and 34 open items resulted.

14 The following 11 slides list the open
15 items, the 34 open items. Number and brief
16 description of the subject matter of the open item.
17 And all told there were 34.

18 That brings us to 9.1.1 reactor systems
19 and is Amrit Patel to give that presentation.

20 MR. PATEL: Good afternoon, my name is
21 Amrit Patel. I'm from the office of new reactors and
22 the reactor systems branch. I've been with the branch
23 for three years now. I recently graduated from the
24 NSPDP program. And before that graduated from the
25 University of Florida with degrees in nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 engineering, a Bachelors and a Masters.

2 All right. So I'm going to be speaking to
3 Section 9.1.1 which is the criticality safety of new
4 and spent fuel storage. Basically the applicable
5 regulatory requirements are found in 10 CFR
6 50.68(b) (2) (3) and (4). (b) (2) and (b) (3) cover dry
7 fuel storage requirements. (b) (4) covers requirements
8 in the fuel pool when soluble boron credit is taken
9 both for borated and unborated cases.

10 So this is basically the high level view
11 of the areas covered by the staff. I want to take
12 time to focus, in this discussion, on the boron credit
13 analysis. Most of the staff review actually due to
14 the complexity that this adds to the analysis it ended
15 up being a concentrated toward burnup credit, so I
16 just wanted to speak mainly toward that. And I also
17 wanted to pull out the criticality code validation,
18 which I'll speak to on the next slide.

19 So basically there is two parts to this
20 calculation. There is a depletion calculation and a
21 criticality calculation. And the staff is basically
22 focusing on the depletion side on the operating
23 parameters in ensuing that all the operating
24 parameters were conservatively modeled.

25 In addition to that is the actual profile

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 making sure that a limiting profile was actually used.

2 CHAIR POWERS: The definition of
3 conservative here is a little confusing, it's tricky.

4 MR. PATEL: Yes, here we're talking about
5 with respect to reactivity in the fuel pool. So we
6 want to look at parameters, look at soluble boron
7 concentration or fuel moderated temperature. And see
8 how that effects reactivity in this spent fuel pool.
9 So we're looking at those kind of parameters.

10 CHAIR POWERS: But I mean, in the
11 depletion calculation and the whole profile
12 calculation, it's tricky to define what you mean by
13 conservative.

14 MR. PATEL: It's not tricky, there's a lot
15 of wiggle room, you can do a lot with it.

16 CHAIR POWERS: Just defining what is
17 conservative is kind of tricky.

18 MR. PATEL: Yes, exactly how many, where
19 you put the note edges, right. So the second part is
20 the criticality calculation and we're really focused
21 on the co-evaluation here since we're talking about
22 spent fuel.

23 And as AREVA noted they're using HTC data
24 which is highly applicable in this scenario when we
25 are modeling spent fuel storage. So overall pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 happy about that. Also I just noted some of the NUREG
2 guidance that we used to help with the burnup credit
3 review.

4 This is just an overview of the
5 confirmatory calculation performed by the staff. And
6 at this time I just want to focus on the last two
7 bullet points which deals with verification of the
8 burnup and enrichment loading curve. That's part of
9 tech specs actually.

10 Basically we did two calculations a 1D, a
11 simplified point depletion calculation and then a 2D
12 calculation, a bit more rigorous. And actually both
13 results in terms of comparing the burnup loading
14 curves compared very favorably. So that basically
15 gave us assurance that these calculations are being
16 performed correctly by the applicant.

17 MEMBER SCHULTZ: So you did a set of
18 basically confirmatory calculations, in their
19 presentation they indicated they used the Scale Suite
20 2. But they didn't use exactly the same one.

21 MR. PATEL: Right, this is a newer version
22 actually and they have more advanced capabilities.
23 This side is just one of the open items of interest to
24 the staff. And it's regarding the selection of
25 limiting burnup profiles.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's not the application in the depletion
2 analysis, but it's really the screening of the
3 limiting burnup profile. So there is some kind of
4 data base or set of profiles that cover all types of
5 fuel assemblies.

6 And I think the question here from the
7 staff is the screening criteria actually giving us
8 limiting burnup profile. So that's not really clear
9 to the staff so we just want to make sure that that's
10 being done properly.

11 CHAIR POWERS: So your first bullet up
12 there says what the whole problem is in doing this
13 burnup credit is that everything backwards. The ends
14 are more important than the middle and things like
15 that. It's really tricky, I mean it's hard to get
16 your mind to wrap around that. Interesting, acute
17 problem.

18 MR. PATEL: That's my final slide so if
19 there are any questions.

20 MEMBER SCHULTZ: So is the question here
21 associated with the way in which the final profiles
22 were established? That is establishing the proper
23 conservatism associated with it. Once the
24 calculations are done, that's straightforward. You
25 get response and answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PATEL: Right.

2 MEMBER SCHULTZ: But then you've got to
3 series of profiles that you can combine in certain
4 ways and then you need to establish a conservative
5 approach to find the burnup credit.

6 MR. PATEL: Right, it's not so much the
7 combination, how they're putting the profile together.

8 It's more just the raw selection of the profile. So
9 they have some kind of data base of profiles based on
10 various locations and different points in cycle.

11 So the question is out of all of these
12 potential profiles are they actually identifying a
13 limiting one for different cases in the spent fuel
14 pool.

15 MEMBER SCHULTZ: And so that remains an
16 open item now to determine whether it's being done
17 properly.

18 MR. PATEL: Right.

19 MEMBER SCHULTZ: And the applicant's
20 providing you additional information related to that
21 determination.

22 MR. PATEL: Right.

23 MEMBER SCHULTZ: But in terms of the
24 methodology and the approach you're comfortable with
25 the calculations that are given.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PATEL: Correct.

2 MEMBER SCHULTZ: The determination of the
3 final credit based upon the cluster of information
4 that has been developed and combined.

5 CHAIR POWERS: That's one of the things
6 that I think at some future full committee meeting, is
7 just presenting this confirmatory methodology to the
8 full ACRS. Because I think they have not had a
9 briefing in some time about the upgraded scale suite
10 and I'm sure that they haven't been through a burnup
11 credit calculation.

12 We might want to give that some thought.
13 We can break into the committee's schedule to give a
14 45 minute precisely on this calculation. Not so much
15 for the EPR as it is for discussing the methodology
16 available for the staff to do these kinds of
17 confirmatory calculations.

18 We can get together and chat about this at
19 some time. It's not going to happen immediately I
20 know, from looking at the schedule. But at some time
21 it might be useful because this is different than what
22 we're actually used to.

23 And we do have an update in the scale
24 suite from what any of the members would be used to.
25 So it might be worthwhile to have someone come in and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 just chat a little bit about it.

2 MR. TESFAYE: You have also suggested that
3 we present this spent fuel cask loading system to the
4 full committee.

5 CHAIR POWERS: I think that when we get to
6 that we'll have to spend a little time, both you and
7 the applicant are going to have to spend a little time
8 on this system. Because it's a little bit different
9 than what you might think of.

10 MR. TESFAYE: Sure.

11 CHAIR POWERS: Well, when we got to moving
12 that chapter into the full committee, it's not next on
13 our list. But if we do it in May we have to be a
14 little more strategic on how we do that exactly. I
15 haven't thought about it very much.

16 But one thing we can think about it doing
17 is ask them for a half an hour, or 45 minutes just
18 devoted to that. And then another block of time for
19 the general chapters, which so much more general
20 discussion and not so much in depth.

21 Just because that system is so different
22 than what they're probably use to and what they
23 anticipate. And the nice thing about that is you've
24 got a lot of visual stuff so they can get their arms
25 around it without a lot of hand waving and things like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that.

2 So we might want to talk about that, I
3 think that's more of a applicant problem than it is a
4 staff problem. Because it's more descriptions that
5 they're aware of what it is.

6 I mean I don't think, I don't forecast a
7 great number of questions that you haven't already
8 heard. But it strikes me that it's one that they
9 really ought to see because they've really never seen
10 it before, right? And it's more like educating and
11 training the ACRS. And what the staff has available.

12 And it looks like you have a pretty good
13 command of that calculational method and this could be
14 a nice example of where you've done that. But you'd
15 have to dress it up with a little bit of explanation
16 of what the suite is and a few graphs and things like
17 that.

18 We'll talk about that, because I'm not
19 sure when we can do it, it's really tough getting on
20 the ACRS schedule right now.

21 MEMBER SCHULTZ: It would be nice to have
22 an answer to this question that you're working on
23 right now. If you feel that that's a good answer then
24 maybe we ought to talk about it. It would be a good
25 example of the challenges that are being faced. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 may be the opportunity to move forward with burnup
2 credit of this type.

3 CHAIR POWERS: Yes, it's something for us
4 to think about.

5 MR. TESFAYE: Thank you.

6 CHAIR POWERS: And Kathy you might find
7 out about that. The handling system and what we can
8 do, and I guess we're targeting May?

9 (Off microphone comments)

10 MS. WEAVER: Yes, we'll work on it, and do
11 like you said, possibly use a half hour for it.

12 CHAIR POWERS: Rather than trying to make
13 it as part of the general block of chapters that we're
14 moving forward just make it a separate item. Is that
15 okay with you guys? You've got a pretty good story
16 put together there. We'll have to tailor it a little
17 bit for the full committee meeting.

18 MS. WEAVER: So you would want like two
19 hours, half for the chapters and half for the --

20 CHAIR POWERS: No, I want two hours for
21 the chapters and I want another 45 minutes for just
22 this, I'm going to be greedy. And I think it's just
23 their story, because I think the only thing we're
24 asking to do is just explain that. What does it look
25 like, what is it going to do for you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What you see is the good things and what
2 you want to spend a lot of time on.

3 MEMBER SKILLMAN: I'd like to ask Amrit a
4 questions please. I understand the concept of burnup
5 credit, depleted fuel is not as reactive as new fuel.

6 MR. PATEL: Right.

7 MEMBER SKILLMAN: But the instant I pull
8 rods on my first full core, if I have a problem in I
9 want in some cases to unload that entire core. And
10 that means that my boron concentration in my spent
11 fuel pool must be appropriate for the 5 weight percent
12 if that's what I've loaded in my batch for my first
13 core.

14 So can you please lead me through how one
15 might discuss burnup credit when my maximum hold down
16 requirement is when I've had to discharge my first
17 full core or subsequent core with the bulk of my
18 discharge shield assemblies are gently irradiated, but
19 irradiated non the less. But they are not depleted
20 by any amount.

21 MR. PATEL: Okay. So you're just saying
22 how is burnup credit treated on essentially fresh fuel
23 assemblies?

24 MEMBER SKILLMAN: Where ever that might be
25 in a fuel cycle, or in the life of the plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PATEL: I'm trying to understand a
2 little bit better exactly.

3 MEMBER SKILLMAN: Say, I'm on cycle four.

4 MR. PATEL: Okay.

5 MEMBER SKILLMAN: I've got a third of a
6 brand new core. It's hot as can be, 5 weight percent.
7 I've only run it for 26 days. And I have a reactor
8 cooling system leak where I really choose to defuel
9 because my PRA tells me that is my least risk
10 condition for the plant.

11 MR. PATEL: Okay.

12 MEMBER SKILLMAN: So now I'm unloading
13 perhaps the entire core, but there's been burnup
14 credit applied which would suggest that maybe I don't
15 need as much boron in that pool as one might otherwise
16 expect.

17 MR. PATEL: Right, the boron in the pool
18 is fixed, based on the analysis percented by the
19 applicant. So they define, that's not changed.
20 That's a constant level of boron in the pool. I think
21 to answer your question. I mentioned the burnup in
22 the loading curve, it's part of the technical
23 psecificatons. And that curve tells you the minumum
24 amount of burnup that's required to place a fuel
25 bundle in a region two storage slot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Alternatively if they could meet that they
2 would have to come up with some other way to off load
3 that fuel. Maybe they would have to put it in the
4 fresh fuel region, in region one.

5 So there's things that can be done. But
6 the boron in the pool is fixed and you essentially
7 they would turn to the burnup loading curve
8 essentially in tech specs.

9 MEMBER SKILLMAN: Let me ask one more
10 question please. Will takes credit for burnup require
11 in addition to the core operating limits report that
12 the applicant has to provide at the beginning of each
13 new fuel cycle?

14 MR. PATEL: So would they have to updatre
15 that, is that what you're saying?

16 MEMBER SKILLMAN: To relaod you have to
17 have a cooler, that part of the reload. Is taking
18 credit for burnup an add on to that?

19 MR. PATEL: No, that's not in pool that's
20 actually part of the technical specifications. So the
21 analysis that's presented by the applicant is intended
22 to bounding for all conditions. So all applications
23 of burnup credit should be covered by the base line
24 burnup loading curve in technical specifications.

25 So the cooler would not be affected by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anything. So the technical specification on the
2 minimal soluble boron requirement and also the burnup
3 loading curve.

4 MEMBER SKILLMAN: Thank you.

5 MR. TESHAYE: Ready?

6 CHAIR POWERS: Yes.

7 MR. TESHAYE: Thank you.

8 MR. HEARN: Our next presentation will be
9 on new and spent fuel storage and fuel pool cooling
10 and purification systems. And Raul Hernandez is the
11 presenter.

12 MR. HERNANDEZ: Hi, my name is Raul
13 Hernandez, I've been with the NRC for over ten years.

14 Most of them I would say has been in the either NRR
15 or NRO. And I've been the reviewer for spent fuel
16 pool and the spent fuel pool coolant system for the
17 EPR, USABWR and AP1000, the DCDs and the COLAs.

18 I will be presenting the review for the
19 new fuel storage facility and the spent fuel storage
20 facility. The new fuel is a dry storage approximately
21 ten feet deep and with enough capacity for 120 fuel
22 assemblies.

23 The spent fuel pool is forty seven feet
24 deep, 3 inches, with capacity for 1,247 assemblies.
25 And the single function of the spend fuel pool is to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maintain the fuel, store it safe and subcritical under
2 all anticipated operational and accident conditions.
3 And also to limit outside exposure in the event of
4 release of radioactive material.

5 These are pretty typical designs nothing
6 really too complicated about the new or the spent
7 fuel, with the exceptions of the interactions with the
8 spent fuel cask loading facility.

9 The fuel building protects the new fuel
10 and spent fuel storage against natural phenomena. And
11 external and internal generated missiles. The spent
12 fuel pool, as mentioned before has several sources of
13 makeup water, including seismic class one makeup water
14 that are safety related.

15 The spent fuel pool liner is assigned with
16 a leak detection system that the applicant described
17 earlier. And it's sized such that it is that we will
18 be able to inspect it and make sure that the leak
19 chase channels are open and are not blocked.

20 Some of those seismic designs that the
21 staff looked at in order to make sure, to prevent
22 drain down events were that the spent fuel pool walls,
23 liners, the fuel transfer canal and the gates between
24 the spent fuel pool and the spent fuel cask transfer
25 facility are seismic class one.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 9.1.2 does not discuss the
2 situation when the spent fuel cask transfer facility
3 is in operation. The relation of drain down
4 prevention when that facility is in operation I'll
5 present that when we talk about Section 9.1.4 in a
6 little bit.

7 MEMBER SKILLMAN: May I ask you please to
8 go back to 23, slide 23.

9 MR. HERNANDEZ: Yes.

10 MEMBER SKILLMAN: The third bullet. Fuel
11 building protects the new fuel storage facility and
12 the spent fuel storage facility against natural
13 phenomena and external missiles. I spent quite a bit
14 of time at a plant where our limiting external missile
15 was a basically a Buick. Coming over the fence as a
16 result of a tornado. I'm serious.

17 If I interpret that bullet the way I think
18 it is intended to be interpreted the roof will prevent
19 that event from occurring. Is that how I should
20 interpret that?

21 MR. HERNANDEZ: The roof prevents, not the
22 roof. The spent fuel pool building, the walls of the
23 building protect the spent fuel pool walls which are
24 the safety related components. Which is to maintain
25 inventory in the spent fuel pool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SKILLMAN: I got the walls, now I'm
2 talking about the roof.

3 MR. HERNANDEZ: No, it wouldn't protect
4 you from something like that. The function here is to
5 maintain water here in the spent fuel pool if
6 something falls in. It doesn't impact the safety or
7 function of maintaining water and protecting your
8 fuel, maintaining cool. Which is the function here.

9 MEMBER SKILLMAN: So the way it protects
10 me with that external missile is it just catches the
11 Buick and the Buick sinks in the pool?

12 MR. HERNANDEZ: It protects the walls of
13 the pool so you don't crack or lose inventory.

14 MEMBER SKILLMAN: But you're not talking
15 about a situation where a Buick or a telephone pole
16 comes in and impacts the fuel?

17 MR. HERNANDEZ: No.

18 MEMBER SKILLMAN: You're just talking
19 about the water.

20 MR. HERNANDEZ: Yes.

21 MR. GARDNER: Darrell Gardener, one
22 comment, this structure is one of the hardened
23 structures for the aircraft impact. So I think the
24 Buick is not going to be a problem.

25 MEMBER SKILLMAN: Darrell, thanks I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not trying to be funny, I was serious about my
2 question.

3 MR. HERNANDEZ: Yes, and I understand but
4 from the EOP stand, from the 9.1.2 review standpoint
5 we are looking only at the inventory, so I didn't want
6 to stretch my review to something that I wasn't sure.

7 MEMBER SKILLMAN: And I was concerned
8 about the fuel. Darrel's answered that question
9 nicely. Darrel, thank you.

10 MR. HERNANDEZ: We had two open items,
11 this is the most, one of the most significant ones is
12 that the applicant in Section 9.1.2 states that, and
13 they stated here before, the gates are always closed
14 when the spent fuel cask transfer facility is not in
15 operation.

16 And the staff is asking the applicant to
17 justify what this no tech special regulatory
18 constraints on the gates to make sure that that is the
19 case.

20 For Section 9.1.3, which is the spent fuel
21 pool coolant system. The spent fuel pool cooling
22 system is composed of two subsystems. One is a safety
23 related cooling portion of it and the non-safety
24 purification system.

25 The safety functions of the spent fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pool cooling system are to remove the decay heat from
2 the pool, prevent spent fuel pool draindown. Drain
3 below the level required for radiation shielding.

4 This is different from the 9.1.2 which is
5 maintaining spent fuel pool. Spent fuel pool provides
6 special makeup for normal evaporative losses and
7 seismic category one makeup and isolation of the non
8 safety related portions from the safety related
9 portions.

10 There is nothing too complicated about
11 this system, we have a an open item in this system.
12 Dealing with the location of the anti-siphon devices.
13 And we're asking the applicant to clarify the
14 elevation of the anti-siphon devices.

15 MEMBER STETKAR: I've got a question, I
16 stumbled over something as I was reading the SER.
17 I've got a question about why aren't there any tech
18 specs on the fuel pool cooling system since it's a
19 safety related system? And in the SER where it says
20 regards to the RAI 87 in question in 9.1.3-9

21 The response further stated the fuel pool
22 cooling system is not a structure system or component.

23 This part of the primary success path then which
24 functions or actions are mitigated to design basis
25 accident or transient that either assumes the failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of or presents a challenge to the integrity of the
2 fission product barrier.

3 Neither the U.S.EPR specific or generic
4 probabilistic risk assessments, PRAs, nor operating
5 experience have shown that the fuel pool cooling
6 system to be significant to public health and safety.

7 Therefore the applicant concluded that no
8 limiting conditions for operation are applicable. The
9 FPCS reviewed this response and finds that it conforms
10 to NUREG 1431 and standard technical specifications
11 Westinghouse plants.

12 I just wanted to read that to get it into
13 the record. So you basically concluded that because
14 there isn't a design basis accident for the fuel pool.

15 Because the PRA's didn't show the fuel pool as being
16 risk significant and because there aren't any generic
17 tech specs on fuel pool cooling it's okay not to have
18 tech specs, is that correct?

19 MR. HERNANDEZ: Yes.

20 MEMBER STETKAR: Okay. Since I'm a PRA
21 guy I got curious about this because I'm not aware of
22 any PRA's that have actually modeled fuel pool
23 cooling. So I decided to take a look at the EPR. And
24 you know, they don't model it either. So it's not
25 surprising that it's not a contributor to risk. If

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you don't put it in the PRA it's contribution is
2 precisely zero.

3 It's not a contributor because it's not
4 modeled. They specifically excluded the plant
5 operating states when that system is operating.
6 Unless I've missed something and believe me, I've
7 looked for it.

8 So I'm curious about this statement that
9 relies on the U.S.EPR PRA to justify that the risk is
10 small. Because it not only doesn't quantify it it
11 explicitly excludes the only configuration when this
12 system is operating. From their low power and shut
13 down part of their PRA.

14 So if you use the PRA as justification
15 you're on thin ice.

16 MR. HERNANDEZ: No, I am not a PRA person,
17 I didn't review of the PRA portion I based my response
18 on the fact that it wasn't part of the design basis
19 event. It was not a typical tech spec that we've seen
20 before. So this would be a unique case and I didn't
21 have the basis for making that.

22 MEMBER STETKAR: I'm glad to hear you
23 didn't rely on a PRA, I'm curious then from AREVA's
24 standpoint, apparently in your response to the RAI,
25 you cited the PRA as a basis for not showing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant risk. Could you tell me precisely where
2 in the PRA you've quantified the reliability of the
3 fuel pool cooling system?

4 MR. GARDNER: John, I think we can look
5 into your comment. I think maybe a better answer to
6 that question would have been there's four criteria in
7 5036, one of those being risk significance. And I
8 think that was the purpose of our answer was to
9 address the fourth criteria and the PRA had not
10 identified any risks significance for the system.

11 MEMBER STETKAR: If it's not in the PRA
12 it's risk significance is precisely zero. If it's in
13 the PRA, and you can point me to where it is and where
14 it's quantified at 10 to the minus 30th or something
15 like that. I just couldn't find it.

16 MR. GARDNER: We can go look up a little
17 bit better answer but that was, like I say, the nature
18 of the nature of the response was directed toward that
19 fourth criteria in 5037.

20 MEMBER STETKAR: Okay. Thanks.

21 MR. HERNANDEZ: Any other question on the
22 spent fuel pool cooling systems?

23 CHAIR POWERS: Thank you. I think at this
24 point it would be useful to take a break for, let's be
25 generous, go to 3 o'clock, shall we?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Whereupon, the foregoing matter went off
2 the record at 2:42 p.m. and went back on the record at
3 2:59 p.m.)

4 CHAIR POWERS: Okay. Let's come back into
5 session. Let's see. Raul, we're done with you,
6 right?

7 MR. HERNANDEZ: Temporarily.

8 MR. HEARN: Temporarily.

9 MR. CURRAN: He's coming back.

10 CHAIR POWERS: You're coming back. Good.
11 We enjoyed your first version, and we'll enjoy your
12 second. But we're going to turn to Gordon now, right?

13 MR. HEARN: Yes, next slide. So for fuel
14 cool pooling, fuel handling system and overhead heavy
15 loads handling systems, from Gordan Curran, the
16 presenter, and he'll be assisted by Raul Hernandez.

17 MR. CURRAN: Hi. I'm Gordan Curran and I
18 went to school, well I'm the technical reviewer for
19 the fuel handling system. I've been in the industry
20 for 11 years. And I've been with the NRC for three.
21 I went to School at Washington State University, with
22 a Bachelor's in Mechanical Engineering.

23 CHAIR POWERS: Washington State in
24 Spokane?

25 MR. CURRAN: Close, it's just south of it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in Pullman.

2 CHAIR POWERS: Pullman, I'm sorry.

3 MR. CURRAN: Yes. Nobody's ever heard of
4 it.

5 CHAIR POWERS: Believe it or not, my
6 mother did teacher training out of Pullman. And for a
7 while I lived across the border in Moscow.

8 MR. CURRAN: Oh, yes, yes, yes. Very
9 familiar with that. Okay.

10 CHAIR POWERS: Great place to be from.

11 MR. CURRAN: Okay. The fuel handling
12 system for AREVA is in basically two parts. You have
13 the fuel handling system, which is the typical fuel
14 handling design, with the spent fuel elevator and
15 fueling machine, the spent fuel handling machine.

16 And then they have the unique, the cask
17 transfer facility, which contains the spent fuel cask
18 transfer machine and the penetration assembly, which
19 is already been discussed. Some of the stuff might be
20 redundant to what was done --

21 CHAIR POWERS: That's okay.

22 MR. CURRAN: -- before. But I'll try to
23 skip through a lot of that. As I said, this unique
24 design hasn't be licensed or used in the U.S. And
25 it's used over in France.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So the staff, not knowing any information
2 about this, we took a MDEP trip over to the Cattenon
3 plant in France, which is in Thionville, which is very
4 close to Pullman in terms of size.

5 This right here is a configuration, which
6 we've seen this before. It has, you can see the spent
7 fuel transfer machine in orange underneath. And you
8 can see it attached to the penetration at this point
9 with the penetration lid open, which is a little
10 circular thing.

11 And then you have a cask pit. This
12 rectangular opening at the front of the pit, that's
13 actually the connection from the spent fuel pool to
14 the cask pit. And you can see on the right that it
15 has the spent fuel in the loading pit.

16 And then it has the double gates that, the
17 double seismic gates, in between the two. One of
18 them's the slide gate and one's the slomo (phonetic)
19 gate, although they look like slide gates in that
20 picture. Three items that --

21 Well this is a new design, and it's a
22 unique design. So we really didn't have an SRP that
23 was applicable to it. So we used a 9.1.4, which is
24 for the fuel handling. And we reviewed it in
25 accordance with GDC-2 and 61.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I don't intend to go through all the open
2 items. But I'll just go through a couple of key ones
3 and some key challenges that we had. And the key
4 challenges that we had in the review were the natural
5 phenomena protection drain down, and the test program.

6 Some of the items in the natural
7 phenomenon that we saw that were positive, if we go
8 back to the picture you can see some of it. One is
9 that it operates in the fuel billing, so natural
10 phenomenon are really, you have an airplane that can't
11 crash into it. So it's protected from missiles,
12 except for earthquake.

13 The transfer machine and the penetration
14 assembly are Seismic 1 components. We'll go back to
15 the picture, and you can see how it runs on rails, how
16 they indicate it.

17 And then it has side rails in the walls,
18 on the two walls. And it's actually, from when we saw
19 it in France, it's actually a really tight fit in
20 there. And those lateral guides are probably not more
21 than a foot off the walls. And it's stuck in there
22 pretty tight.

23 I mean, even the penetration, the distance
24 between the top of the machine and the ceiling is
25 pretty, well that's a tight fit too. Actually the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 penetration assembly's actually recessed into the
2 ceiling just to give you more clearance. And when you
3 lift up the biological lid, it actually recesses, or
4 goes into a recess. So that it's pretty flat on top.

5 What else was I going to say?

6 MALE PARTICIPANT: Seismic restraints?

7 MR. CURRAN: Along the wall, thank you,
8 along the rails and the sides, the lateral guides,
9 there's actually seismic restraints. And there are
10 pins that go into them.

11 And they're like, installed on top of the
12 rails. Well they are in France. The rails, and pins
13 actually go out of the transfer machine into these
14 corbels (phonetic), I think they're called.

15 Or something like that they call them over
16 there. And keep it from lateral movement. Plus it
17 has the brakes on the bottom of it, which will keep
18 you from moving as well. It's pretty durable.

19 Let's see. And then the penetration
20 assembly is actually connected to the transfer machine
21 with four irreversible screws. It's really hard to
22 explain this penetration assembly unless you see it or
23 visualize it.

24 But it actually has four screws that are -
25 - It has the circular penetration through it, but then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it has these, I can't explain it. It has these pieces
2 that come out of the penetration.

3 It's not circular. It's actually like a
4 criss-cross sort of a design. And it has four bolts
5 that go up into each one of these. So when it comes
6 down, it comes down evenly. And it comes down a tight
7 fit. And so it comes with an even force across the
8 connection to the cask.

9 And then the hoist and the trolleys have
10 some single failure features and interlocks and
11 controls, which they had talked about. And there's no
12 personnel that are allowed in the facility during
13 operation.

14 There's actually, you have the loading
15 hall, and then you have a door. And it has a valve
16 room, which separates the control room from the valve
17 -- The valve room's in between the control room and
18 the hall.

19 So there's some good distance there. And
20 they have monitors there that they can visualize
21 everything that goes on in there. And then they have
22 control panels.

23 CHAIR POWERS: So what happens if I am
24 done with a transfer, I start to withdraw the machine,
25 and something breaks? How do I get in and fix it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CURRAN: You would --

2 MR. HERNANDEZ: At that time, you would
3 stop the fuel transfer.

4 CHAIR POWERS: No, I'm done with that.
5 I'm withdrawing the machine, and it breaks.

6 MR. CURRAN: What do you mean by
7 withdrawing the machine? Is it disconnect --

8 CHAIR POWERS: I'm bringing it back out
9 the rails --

10 MR. CURRAN: -- or pushing back out?

11 CHAIR POWERS: Yes. And it just stops.
12 Now what do I do?

13 MR. CURRAN: If it's before the biological
14 lid is put in, so it's between the penetration and
15 moving the biological lid --

16 CHAIR POWERS: Okay.

17 MR. CURRAN: There's an open item actually
18 right now. So based on what kind of event would make
19 it necessary for personnel to actually go into the
20 room. And that's an open item at this point.

21 CHAIR POWERS: Okay. So you guys have
22 thought of everything I can think of. you don't need
23 me.

24 MR. CURRAN: Because all the questions
25 you're asking, we had at the beginning of this review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 too.

2 CHAIR POWERS: So you don't really need
3 me. You guys did it all yourself.

4 MR. CURRAN: Oh, no, no, no.

5 MR. HERNANDEZ: It's always good to have a
6 fresh perspective.

7 CHAIR POWERS: Listen to these guys
8 sucking up here. Nice try, it didn't work.

9 MR. CURRAN: The open items we have for
10 this is to describe the interlocks, provide the single
11 failure per features. Since this is not ordinarily a
12 single failure per crane, it's pretty much details.
13 You go to NOG-1.

14 But these are some unique components. The
15 single failure features aren't directly applicable, so
16 we need to know some of that. And then the next one
17 is drain down protection. And Raul's going to do
18 this.

19 MR. HERNANDEZ: Yes. As we know, this
20 facility connects directly to a spent fuel pool. So
21 drain down is a particularly important issue that we
22 need to address.

23 And one of the first features that we
24 looked at it, there are fluid retaining components.
25 Make sure they're all, the fluid retaining components

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 were classified as Seismic Class 1. And several of
2 them has a dual boundary, like it was mentioned
3 before.

4 Another feature that we looked was the
5 fuel drop analysis. If during fuel movement you could
6 drop the fuel assembly at any point. What impact
7 could this have on the facility?

8 And all the surfaces that could be
9 impacted by dropped fuel are designed to withstand the
10 impact of such without breaking and causing a drain
11 down event. There is a cover plate protecting the
12 buffer plate, which was described before. And it's
13 not shown in any of the drawings.

14 Now if I could mention that, in addition
15 to the fluid retaining components being Seismic Class
16 1, also all the supporting components, like the
17 irreversible screws that holds the whole penetration
18 assembly down during a seismic event, the actual
19 trolley itself, it's anchored to the walls.

20 The brakes are enabled on the wheels of
21 the trolley. We also reviewed to make sure that those
22 loads were evaluated, what the impact on the walls, on
23 the floor, or on the ceiling is going to be. Because
24 it's a low clearance, you know, it's really tight
25 there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So make sure that all those impacts have
2 been evaluated. Also we can mention that we, they
3 have dual seals on certain places, and leak detection.

4 This leak detection is used during the fuel movement,
5 and also once the lid is closed to make sure it's
6 still leak tight, sealed.

7 This, the cask loading pit on top of the
8 penetration assembly, can be dry or full of water
9 during the normal operation of the plant. So it's not
10 restricted, it could be either way. That's why it's
11 important that we have a seal, leak detection, on
12 those lids.

13 It's also good to mention that the two
14 gates separating the spent fuel pool and the spent
15 fuel cask transfer facility are Seismic Class 1. The
16 upper lip is Seismic Class 1. The bottom lip, the
17 flange, the bottom of that is also Seismic Class 1.
18 So it's pretty robust from that point of view.

19 The staff still has several open items
20 dealing with drain down prevention. And one of them,
21 as mentioned before, is interlocks. The interlocks
22 are real important. We rely on the gates to prevent
23 inadvertent drain down and make sure that it's not
24 open.

25 So we still have questions about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 controls of the gates. When can they be opened? How
2 this interlocks interact with the gates? And how
3 reliable are they? So there are still several open
4 items dealing with this. Question?

5 MEMBER SKILLMAN: The information that we
6 received a couple of hours ago is that the maximum gap
7 is .35 millimeters should the O-rings not set
8 properly. And that .35 millimeters yields an
9 approximate 390 gallon a minute leak rate. What
10 attention has the staff given to where those 390
11 gallons a minute go?

12 MR. HERNANDEZ: That's still under
13 evaluation.

14 MEMBER SKILLMAN: When will we hear about
15 that, Raul?

16 MR. HERNANDEZ: Well we still have open
17 items out. We haven't received responses to all of
18 them.

19 MEMBER SKILLMAN: And that's one of them?

20 MR. HERNANDEZ: If I'm not mistaken, yes,
21 that's one of the open items that we still have out.

22 MEMBER SKILLMAN: If you're not mistaken.
23 Is there, or isn't there plates?

24 MR. CURRAN: Where the water goes?

25 MEMBER SKILLMAN: I'm talking internal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flooding. Where does that water go?

2 MR. HERNANDEZ: Internal flooding that's
3 evaluated in a different section. That is not 9.1.3,
4 9.1.2. So I need to double check that.

5 MEMBER SKILLMAN: I'd like to know where
6 that 390 gallons a minute are going. MR.

7 TESFAYE: We'll take a look at the existing open items
8 in Chapter 9, and in Chapter 3, under flooding. And
9 that's not included, we'll come back and update you
10 tomorrow.

11 MEMBER STETKAR: It's not in Chapter 3.
12 Because in Chapter 3 it discusses wind loadings on the
13 building and stuff like that. Chapter 3 is sort of
14 silent on flooding in the fuel building. Just to, I
15 mean, you can go look at it, but it was --

16 MR. TESFAYE: No, no. I will take the
17 action to see if an existing RAI covers that.
18 Otherwise we'll probably generate an RAI on this.

19 MR. HERNANDEZ: The drain down event is
20 still under evaluation in, we still need to understand
21 this information about the .3 millimeter. This was
22 also just fresh to us. We haven't received that yet.

23 We know about the 390 gallons. We still
24 have questions about the time to stop the drain down,
25 whether a perimeter is going to be created for that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what operator actions are needed, what's automatic?

2 We still have a review in this. It's kind
3 of, it's been a complicated review, like we've
4 mentioned before, because of the lack of
5 straightforward guidance on this.

6 MEMBER SKILLMAN: Okay. Getachew, I heard
7 you say you will take a look. And if there's not an
8 item there, you will place an item there.

9 MR. TESFAYE: Yes, absolutely.

10 MEMBER SKILLMAN: Okay. Thank you.

11 MR. CURRAN: Just to share with you, in
12 France the configuration that they have. They have
13 drains probably 20 drains on the floor. There's quite
14 a bit of them. And then they have the, which they
15 said is a leak tight door, and that goes to the
16 outside. And it's a good size door.

17 And there's also an entrance way on the
18 side that comes from the control room. And there's a
19 valve room there, and then the control room's on the
20 other side. There's a door there, but I don't know.
21 That's just the configuration that we saw in France.

22 MEMBER SKILLMAN: Well I'll look forward
23 to your answer. I have this nightmare of a machine
24 that's stuck, operators that in one instant they're up
25 to their ankles, and now they're up to their knees,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and now they're up to their hips. And the hydrostatic
2 pressure may prevent them from opening a door.

3 I lived through a ship that burned at sea.

4 And that was the exact scenario. We couldn't get
5 out, because the doors were flooded. And here is a
6 situation where you could have a very highly
7 irradiated fuel assembly stuck with a leak, water at
8 your hips or higher, trying to figure out, what do we
9 do now? So I think that there are some issues that
10 need to be looked at.

11 MR. HERNANDEZ: That's why we still have
12 so many open items in this particular issue. And we
13 are participating with the applicant, in some back and
14 forth conversations trying to understand the
15 particular design.

16 MEMBER SKILLMAN: Thank. you.

17 MR. CURRAN: Okay. The third item that I
18 had was the test program. And this is sort of
19 complicated. The only way that they have to get, they
20 don't have a heavy load --

21 MEMBER STETKAR: Gordon, before you do
22 this. Something just popped up. And it's not, I
23 mean, it's generally fuel handled. I couldn't find a
24 drawing, and I looked but I couldn't find one, of the
25 fuel transfer tube, from the containment to the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pool. Does that, and I meant to ask AREVA and I
2 forgot. Does that have a drain line from it?

3 MR. CURRAN: What do you mean?

4 MEMBER STETKAR: They usually do, but --

5 MR. CURRAN: You'd have to ask them. I'm
6 not sure.

7 MR. PANDYA: No, actually, no.

8 MEMBER STETKAR: There's no drain line?

9 MR. PANDYA: No, that's correct. I'm
10 Nitin Pandaya from AREVA. The transfer tube does not
11 have any drain pipes.

12 MEMBER STETKAR: No drain? Okay.

13 MR. PANDYA: No. No drain in this
14 facility.

15 MEMBER STETKAR: You just drain that when
16 you drain, it's at the bottom of the cavity?

17 MR. PANDYA: Yes.

18 MEMBER STETKAR: I mean, it drains when
19 you drain the --

20 MR. PANDYA: Absolutely.

21 MEMBER STETKAR: -- cavity? Okay. Fine.
22 Thanks.

23 MR. PANDYA: Okay.

24 MR. CURRAN: That's Seismic Class 1 --

25 MEMBER STETKAR: Yes. I know. I thought

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 --

2 MR. CURRAN: -- with the gates also
3 Seismic Class 1.

4 MEMBER STETKAR: I've seen a different
5 design that had a fairly decent size drain line from
6 it. Thanks.

7 MR. CURRAN: Sure. The test program, the
8 EPR, the only way they have to get fuel out of the
9 pool would be through this opening. They don't have a
10 heavy load handling crane that's capable of lifting
11 casks.

12 So the intial test program is related to
13 proof of capability that they could actually remove
14 fuel when the plant starts up. The applicant needs to
15 define testing that needs to be done prior to start up
16 and prior to use, since the use might be ten years
17 down the road.

18 They had proposed having the initial test
19 program at first time of use. But what that does is,
20 you have no proof that they can actually remove fuel
21 at start up. So we went back and we asked them to
22 provide us the testing that that is done prior to
23 start up and prior to use.

24 This COL item is related more to when a
25 cask is available. Currently the design, well they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 restricted from what they can actually load to those
2 casks based on the size of the penetration.

3 So the cask has to be a certified design
4 and available, and can connect to this facility before
5 we will give them a license. So they gave us, or they
6 proposed the COL item that they'll provide the cask
7 prior to use.

8 But then they, again, they don't have any
9 proof that they can connect the certified cask to the
10 facility to offload fuel at plant start up. So they
11 need to come up with a COL item, or some sort of
12 proof, so that we know at start up that they can
13 connect a U.S. certified designed cask to this, and
14 remove fuel. That's what it comes down to.

15 MEMBER RYAN: So you're really saying,
16 they don't start up without it?

17 MR. CURRAN: Yes.

18 MR. TEFAYE: They can't load fuel --

19 MR. CURRAN: We're talking about the cask
20 --

21 MEMBER RYAN: They can't load fuel, right.

22 MR. TEFAYE: They can't load fuel.

23 MR. HERNANDEZ: We're trying to make sure
24 that it's the same as for any other site.

25 MEMBER RYAN: We just want to be clear.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HERNANDEZ: Can use an approved design
2 to offload fuel, they should demonstrate a similar
3 capability.

4 MR. CURRAN: Now the cask itself doesn't
5 need to be on site at start up. You just, if you show
6 the capability that you can --

7 MEMBER STETKAR: You have a crane. In
8 other designs you have to have a crane that can --

9 MR. CURRAN: Exactly.

10 MEMBER STETKAR: -- lift the cask. And
11 you have to have a place to put it, and all that kind
12 of stuff.

13 MR. HERNANDEZ: The challenge here is that
14 it is not clear that a cask exists that can connect
15 with that particular, well there is no cask approved
16 in the U.S. that can physically connect with that
17 facility. So that's the purpose of the COL action
18 items, to make sure that one exists at the time of
19 fuel load.

20 MEMBER RYAN: Thank you.

21 MEMBER SKILLMAN: Is there a back up? If
22 that option is not available, is there another way to
23 discharge irradiated fuel safely?

24 MR. CURRAN: That hasn't been discussed.
25 But my personal opinion, no.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: So the only way out is
2 through a hole in the bottom of the pit?

3 MR. CURRAN: Unless they can come up with
4 some contraption, a smaller cask or, that would be
5 within their fuel building crane capacity --

6 MR. HERNANDEZ: No other method has been
7 proposed for the staff to review.

8 MR. CURRAN: They can't put it in the top.
9 They don't know the, their crane doesn't have the --

10 MEMBER STETKAR: The crane isn't, the fuel
11 building crane dosen't have the capacity to --

12 MR. CURRAN: Exactly.

13 MEMBER STETKAR: Oh, is that right?

14 MR. CURRAN: That's why I say they could
15 have some smaller cask if they make it. I don't know.
16 But switch it out one fuel element or something like
17 that, that would be within the capacity. But I don't
18 know the details, if you could actually do that.

19 MR. HERNANDEZ: No alternative have been
20 proposed for the staff to review. So we don't know.

21 MR. CURRAN: Thank you.

22 MEMBER STETKAR: This also sounds like,
23 well I mean, we'll see how it plays out.

24 MR. CURRAN: Okay. And then operating
25 procedures and training, they need to commit to prior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to plant start up. Because if they train them when
2 they get this cask, 15 years down the road, then they
3 haven't shown that they can operate this and offload
4 it at the time of start up.

5 And also ITAAC. ITAAC have not been
6 provided for the fuel transfer, or the cask handling
7 facility. So they need to provide that as well. And
8 that's an open item. Those are all open items.

9 In addition, we have numerous, or open,
10 items on the structural design of the facility. We
11 have this one. And there's maybe a handful more.

12 They haven't provided responses back to
13 the structural capability, and how structure will
14 withstand the loads of this design. And that is all I
15 have. Any questions?

16 CHAIR POWERS: Well that's enough. The
17 last one was a real zinger. We end with a bang, sir.

18 MR. HEARN: The staff finds that the 182
19 questions and 34 remaining open items to the use of
20 public readings, and all this in conference rooms,
21 AREVA and the staff have a general common
22 understanding of these requirements that must be
23 satisfied.

24 The staff includes the resolution that the
25 34 open items is manageable within the planned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 schedule. Upon resolving the open items, the Chapter
2 9, U.S. EPR/SAR will provide sufficient information to
3 assist the COL applicant in constructing U.S. EPR that
4 satisfies the requirement of 10 CFR, Part 52.

5 MEMBER SKILLMAN: What is the connection
6 between your second sentence, 42 remaining open items,
7 and about the fifth sentence --

8 MR. HEARN: That's a typo. It should be
9 34.

10 MEMBER SKILLMAN: Yes, sir. Thank you.

11 MR. TESFAYE: I thought I caught that.

12 CHAIR POWERS: Any other questions to
13 pose?

14 MEMBER RYAN: No, sir.

15 CHAIR POWERS: No?

16 MEMBER BROWN: You really don't want me
17 to. No, I don't have any.

18 CHAIR POWERS: Everybody's happy? I think
19 we're done for the day.

20 MR. GARDNER: Dr. Powers, we're prepared
21 to present on Chapter 4, if you're prepared to look.
22 I have it right here.

23 CHAIR POWERS: I think we're not. I think
24 we'll start again tomorrow. I think you've saturated
25 us. So let's recess for the day and start again

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tomorrow.

2 (Whereupon, the meeting in the above-

3 entitled matter was adjourned at 3:25 p.m.)

4

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
U.S. EPR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, February 23, 2012

Work Order No.: NRC-1468

Pages 1-105

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 U.S. EPR SUBCOMMITTEE

8 + + + + +

9 THURSDAY

10 FEBRUARY 23, 2012

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B3, 11545 Rockville Pike, at 8:30 a.m., Dana A.
17 Powers, Chairman, presiding.

18 COMMITTEE MEMBERS PRESENT:

19 DANA A. POWERS, Chairman

20 J. SAM ARMIJO, Member

21 CHARLES H. BROWN, JR., Member

22 MICHAEL T. RYAN, Member

23 STEPHEN P. SCHULTZ, Member

24 JOHN STETKAR, Member

25 GORDON R. SKILLMAN, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NRC STAFF PRESENT:

KATHY WEAVER, Designated Federal Official

MANAS CHAKRAVORTY, NRO

TANYA FORD, NRO

ANNE-MARIE GRADY, NRO

TERRY JACKSON, NRO

DAVID JAFFE, NRO

ANDREA KEIM, NRO

DANIEL MILLS, NRO

GETACHEW TESFAYE, NRO

ALSO PRESENT:

JOHN CONCKLIN, AREVA NP

DAVID FOSTER, NUMARC

DARRELL GARDNER, AREVA NP

WALLACE PONDER, AREVA NP

TIM STACK, AREVA NP

CHARLES W. TALLY, AREVA NP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1

2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

OPENING REMARKS AND OBJECTIVES 4

NRC STAFF OPENING COMMENTS 5

U.S. EPR DC APPLICATION FSAR CHAPTER 14 8

CRDMs 9

AREVA - U.S. EPR DC APPLICATION FSAR CHAPTER 14 ... 10

NRC - U.S. EPR DC SER WITH OPEN ITEMS 42

SUBCOMMITTEE DISCUSSION 91

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P R O C E E D I N G S

8:30 a.m.

CHAIR POWERS: Meeting will now come to order. This is the third day of our three day meeting of the Advisory Committee on Reactor Safeguards, U.S. EPR Subcommittee. My notes say it's the last day of that Subcommittee, but I assure you it is not.

I'm Dana Powers, Chairman of the Subcommittee. We have in attendance at the meeting the Chairman of the ACRS, Mr. Armijo. Mr. Armijo, do you have any opening comments you would care to bless the Committee with.

MEMBER ARMIJO: Just go ahead.

MEMBER STETKAR: Carry on.

CHAIR POWERS: Carry on.

We also have in attendance ACRS Members Steve Schultz, Dick Skillman, John Stetkar, Mike Ryan and the ever-esteemable Charles H. Brown, Jr.

MEMBER BROWN: You're maximizing the entertainment value that I bring to this table.

CHAIR POWERS: I could not even approach the entertainment value you bring to this table.

All participants at the meeting should first identify themselves and speak with sufficient clarity and volume so they may be readily heard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We request that participants on the bridge
2 line identify themselves when they speak and keep
3 their telephone on mute during times when they are
4 just listening.

5 Portions of this meeting may need to be
6 closed to the public to protect the proprietary
7 interests. I'm asking the NRC staff and the applicant
8 to identify the need for closing the meeting before we
9 enter such discussions and to verify that only people
10 with required clearance and need to know are present.

11 We are embarking today on initial test
12 program and ITAAC in the SER. That's Chapter 14 called
13 Verification Programs.

14 Do any of the members have opening
15 comments they would care to make on this topic?

16 We may also do some catchup on items from
17 earlier in the week.

18 If we have no opening comments, then I
19 will call on Getachew Tesfaye to give us an opening
20 comment.

21 MR. TESFAYE: Thank you, Mr. Chairman.

22 It's been a little over two years since we
23 started Phase III Presentation to the Subcommittee,
24 and today's our last day --

25 CHAIR POWERS: Time flies when you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 having fun, doesn't it?

2 MR. TESHAYE: Yes.

3 CHAIR POWERS: I'm having fun, maybe
4 you're not.

5 MR. TESHAYE: But the Subcommittee is not
6 done yet. When we close open items in Phase IV, and
7 there's Phase V of course. But we really appreciate
8 the flexibility you give us to bring these chapters
9 sometimes in sections, and that's been extremely
10 helpful.

11 CHAIR POWERS: I was extremely suspicious
12 of doing it this way, but I have to say, and I think
13 it's all to the good work everybody has done, both
14 staff and applicant, I think it's worked out just
15 fine. I have not had any troubles with the somewhat
16 disjointed nature or the material. But it only works
17 out because you guys do such a great job.

18 MR. TESHAYE: Thank you.

19 CHAIR POWERS: And if you didn't, then it
20 would just be chaos, I'm afraid. So we have to be
21 very careful about doing this piecemeal sort of thing.

22 MR. TESHAYE: Yes. We're done now.
23 Hopefully, Phase V will be a lot smoother --

24 CHAIR POWERS: I think so.

25 MR. TESHAYE: -- and not in piecemeal.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: I think so. I think that's
2 true. And, of course, the general philosophy of
3 trying to iron out the contentious points to the best
4 you can before you come to the Committee, that's the
5 only way this works. And so I really appreciate it.
6 I mean, all concerned have been involved in that and
7 it's a testimony to you guys that it worked at all.

8 MR. TESFAYE: Okay. And in addition to
9 closing out some of the questions you raised this
10 week, I think we're going to bring up the Chapter 7
11 that we presented back in November. We're going to
12 have some discussion.

13 CHAIR POWERS: Yes. We'll chat about that
14 and see what we want to do on that. My predilection
15 right now right now is that if we can't resolve it,
16 just leave it as an open item --

17 MR. TESFAYE: It is. That's what we intend
18 to do.

19 CHAIR POWERS: -- and move on, not hang
20 things up on that.

21 MR. TESFAYE: Yes. We've discussed the
22 content of that RAI that we leave as an open item in
23 Phase IV. So --

24 CHAIR POWERS: Yes, I mean I think that's
25 the way to do it is just let's keep the dynamic going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and not get hung up on that. And, hopefully, it will
2 be resolved in Phase IV and we can pursue it at the
3 maximum of our endurance.

4 MR. TESHAYE: Thank you.

5 CHAIR POWERS: Darrell, it's your show.

6 MR. GARDNER: Very good.

7 Of course, I thought Getachew's comments
8 we're certainly excited to reach this milestone in
9 this process. It's been a long productive road, I
10 think we've been pretty successful.

11 Our presentation today on Chapter 14 will
12 provide an overview of the verification programs,
13 including the initial testing program and AREVA's
14 approach and methodology for developing inspection
15 tests analyses and acceptance criteria for ITAAC.

16 I've provided a specific presentation this
17 morning on Section 14.1 since that's an introductory
18 discussion. Now the presentation materials for the
19 test program on ITAAC are at an overview level as it
20 was not practical to provide specific presentations
21 for every test description or for every ITAAC that's
22 within the Design Certification and associated
23 material. However, we are prepared to address
24 Members' questions and comments on any portions of
25 that material.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Today's presentation will be provided by
2 Charles Tally with additional technical support from
3 John Concklin and Wallace Ponder.

4 I would ask the Subcommittee's patience,
5 however. We have one item from yesterday Mr. Stack
6 would like to address regarding the CRDMs.

7 MR. STACK: Thank you, Darrell. This is
8 Tim Stack from AREVA.

9 We had a question yesterday talking about
10 the CRDM testing with regards to misalignment. And
11 back in April of 2009 AREVA entered an RAI, it was RAI
12 95, it was question 03.09.04-1 bravo and foxtrot that
13 was looking at CRDM testing. As part of that test
14 program we looked at what degree of performance should
15 the CRDMs be during earthquake conditions, in
16 particular where we looked at static deflections of
17 the top of the pressure housing in the CRDM as much as
18 100 millimeters and we looked at oscillating
19 deflections in midpoints of the pressure housings of
20 about upwards to 15 millimeters. And we looked at the
21 drop times. Those tests showed that we had basically a
22 negligible impact on the drop times which are really
23 simulating misalignment and the effects on the drop
24 times.

25 What I would ask is if there are further

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 questions on that topic, we would like to submit that
2 as our response to that at this point. If Mr.
3 Skillman would like to look at that and see if that
4 satisfies his need, that would be very good.

5 MEMBER SKILLMAN: Tim, thank you very
6 much.

7 That response satisfied my concern. I
8 recognized when Tim introduced this information to me
9 yesterday, this had been looked at by the Committee
10 previously, and I have no further questions. And I
11 thank you for following up. I'm satisfied that you've
12 answered my questions.

13 Thank you.

14 MR. GARDNER: Okay. With that, then I
15 will turn it over to Mr. Tally.

16 MR. TALLY: Good morning. My name is
17 Charles Tally. And my official actual job title is
18 Manager of Engineering Integration. I am the Regional
19 Deputy for Project Integration on a global basis for
20 AREVA.

21 After some time in the nuclear Navy I
22 joined B&W back in 1976 in time to actually
23 participate in some of the start-up testing that was
24 still going on at some of the B&W plants.

25 So, I've been in engineering my whole

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 career, and I'm pleased to be here to talk about
2 Chapter 14.

3 John Concklin to my right is my subject
4 matter expert for ITAAC and Wallace Ponder for the
5 start-up and test program. With that, we'll just take
6 the plunge.

7 The Table of Contents for Chapter 14 is
8 basically three subsections. As Darrell mentioned,
9 14.1 is essentially just a brief introduction to
10 what's in 14.2 and 14.3. Not much to comment on
11 there.

12 So, we get into 14.2, the initial test
13 program. Our test program follows Reg. Guide 1.68 Rev
14 3 for scope and the specifics of implementation. It
15 includes testing of unique EPR design features,
16 transient performance to be able to demonstrate that
17 the plant can meet its performance criteria as well as
18 operate within the safety limits. And it's noted here
19 that the actual conduct of the test program will be
20 the responsibility of the COL applicant.

21 We applied the standard definitions for
22 the initial test program in regard to the phasing of
23 this, in regard to construction, pre-operational
24 testing and the start-up testing. There are no
25 exceptions here. The only thing that we wanted to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point out that is an exception, there is one, has to
2 do with the calibration of instrumentation which
3 traditionally with all analog systems took place in
4 the construction phase after that equipment was
5 completely installed. Given the DCS complexities, it
6 will most likely be later in the overall construction
7 program process when the complete systems will be
8 available to do complete string calibrations for these
9 systems. So, this is a detail that will be worked out
10 I'm certain, I'm sure by the COL applicant, but we
11 recognize that there is this, I'll say nontraditional
12 need that's been identified by a contemporary plant.

13 MEMBER SKILLMAN: Charles, is this the way
14 the ITAAC is satisfied in the European plants?

15 MR. TALLY: It this the way --

16 MEMBER STETKAR: I think Europeans don't
17 have ITAAC.

18 MEMBER SKILLMAN: Well, how do they test?
19 Do they --

20 MR. TALLY: Well actually, OL3 right now,
21 they're very late in their construction. Essentially
22 all physical construction is done and yet -- and the
23 last thing that's actually going to be installed in
24 the plant in an integrated way is the I&C system.

25 They've had some difficulties in their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 engineering and pretesting of that I&C system that had
2 contributed to that. But I think still the lesson is
3 there that the DCS has got to be intact in the plant
4 before you can start doing some of these overall
5 integrated checkouts of the I&C system.

6 MEMBER STETKAR: But, Charles, a more
7 relevant example would be Britain where they are doing
8 something akin to the Design Certification process for
9 the EPR. How is the whole notion of pre-operational
10 testing calibration satisfied in that process? I'm
11 not as familiar with -- I'm familiar with the general
12 process, but not with the details. Are there
13 something in the British licensing that are akin to
14 ITAAC coming out of their -- you know, the equivalent
15 of their certification process; it's not quite as
16 formal as what we're doing here.

17 MR. TALLY: Can you answer that question,
18 gentlemen?

19 MR. CONCKLIN: I don't know how to answer
20 that question.

21 MEMBER STETKAR: Because, I know France
22 and Finland don't quite have that same framework. But
23 Britain kind of does.

24 MR. TALLY: But I'll be honest with you,
25 for the UK EPR I'd be surprised if they're far enough

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 along to actually have considered that. I mean, they
2 might have knowledge --

3 MEMBER STETKAR: Well, they're pretty far
4 along in whatever they call it, the --

5 MR. TESFAYE: GDA.

6 MEMBER STETKAR: GDA. Thanks. They're
7 pretty far along in that process I thought.

8 MR. GARDNER: We'll look into that if you
9 would like?

10 MEMBER STETKAR: You know, if you answer
11 Dick's question, you know generic Europe isn't good.
12 You know, your example from Finland probably isn't
13 good.

14 MR. GARDNER: Right.

15 MEMBER STETKAR: But UK kind of general
16 process parallels ours to some extent.

17 MR. GARDNER: And would the question be in
18 relation to this issue we're identifying here where
19 the plan would be to defer that instrumentation
20 calibration until the pre-op phase versus the
21 traditional construction phase?

22 MEMBER SKILLMAN: My question was whether
23 or not there's experience that might cause us to
24 rethink how this sequence is undertaken.

25 MR. GARDNER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: And so I'm kind of the
2 mind that if there's a lesson out there that we've
3 learned that makes the plant safer, let's copy that,
4 let's duplicate it.

5 MR. GARDNER: Yes.

6 MEMBER SKILLMAN: I understand the logic
7 from the digital perspective, but I was just curious
8 whether or not there is some information that we could
9 say "Hey, we see how they're doing it over in this
10 country or that county, and that makes sense, and
11 that's the basis for our being resolved to do it that
12 way on the EPR in the first COL in this country. So,
13 I don't have a further action, but that was helpful.

14 MEMBER BROWN: Now I've got one other
15 question. I mean, I find it -- I mean, I did in fact
16 work in systems like this and never had -- and just
17 assuming analog and digital for calibration, you're
18 calibrating instruments is about zero. So, what I'm
19 gathering out of your comments is that the system is
20 so complex in Finland that they can't get it to work.

21 MR. TALLY: Well, no, I didn't mean to
22 imply that. It's just that transmitters and --

23 MEMBER BROWN: Well, let me --
24 transmitters feed analog to digital converters and
25 those digital converters then feed the entire DCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system. And you can't do system checkouts at all once
2 you complete a construction of a system or whatever,
3 unless you've got some type of instrumentation.

4 MR. TALLY: Right.

5 MEMBER BROWN: And I don't know where --
6 I'm just not familiar enough with the commercial to
7 know where you do that system checkouts, whether it's
8 in the construction phase or in the pre-operational
9 phase. Seems to me it would be in the construction
10 phase I would think, at least the initial calibration
11 and setups to make sure water is flowing through pipes
12 and valves come on, and indications you have pressure
13 and temperature and other types of indications
14 available so that your operations of those systems can
15 then be monitored and then tested.

16 And so, but attributing it to the
17 difficulty of the digital to analog interface doesn't
18 bear any relevance to what's going on

19 MR. GARDNER: Can I give it a shot?

20 MEMBER BROWN: You can give it a shot.
21 You're already going to keep digging.

22 MR. GARDNER: I think that initially what
23 we understand is initial construction testing where
24 there's construction inspections on the installation
25 of equipment is not any different, but some I'll say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calibrations and the literal definition that used for
2 digital I&C systems, they need the system intact to
3 hook up these test computers that work from the --
4 they go back out through the loops. So that total loop
5 calibration that needs to be done would be done when
6 the systems are intact.

7 So there's pieces that I would agree, that
8 can be done along the way that would still be done,
9 but--

10 MEMBER BROWN: I understand the
11 integrated. I mean, I understand getting everything
12 like that. But I mean you're hooking up a detector and
13 putting your pressure detector and putting your test--
14 you know, pointing them up and pointing them down to
15 get them to go throughout the range making sure that
16 output goes off to a digital -- an analog or digital
17 converter and then making sure you have the
18 appropriate outputs out of that that it feeds the
19 equipment. I'm trying to remember after then a few
20 months, a couple of months since I've looked at your
21 alls total bus layout, which we had considerable
22 discussions on back in November.

23 Analog, if you go with an analog system,
24 you still got to get the outputs off to the
25 instrumentation so you can see it. So there's wires, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bus, whatever it is. It's be what it'll be, but I'd
2 get a little bit disturbed when people start saying
3 "Gee, because it's digital we can't do it." And it's
4 really not because it's digital, it's because you've
5 designed a system that doesn't allow you to do it
6 because of the way you've constructed it to get your
7 information out to the rest of your system. So, it's
8 not because it's digital. It's because of the design
9 of the system.

10 MR. TALLY: Well, I think --

11 MEMBER BROWN: Make it more complex. If
12 you can make it less complex, and then you don't have
13 that problem. That's a little bit of a message,
14 subliminal maybe, but still a message.

15 MR. TALLY: To answer your question, I
16 believe that we view what's going to happen in
17 construction the same way you do. It's just that the
18 integrated system operation that requires a lot of
19 instrumentation which is required in pre-operational
20 testing for the actual operation of this system,
21 really can't be done until the overall integrated
22 system is all there. And that's when the final check
23 out of a lot of those systems will take place.

24 MEMBER BROWN: Okay.

25 MR. TALLY: We don't operate the systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actually in the construction phase. I mean, that
2 flushing and draining and flowing, that kind of stuff.

3 MEMBER BROWN: I understand that. I
4 understand. I just was looking for a little bit of an
5 answer and you gave me that part, you all did. Okay.

6 MR. TALLY: Any other questions?

7 Okay. So in the pre-operational test phase
8 of this overall evolution we'll be demonstrating that
9 we have functionality of the SSCs prior to fuel load.

10 We'll be exercising the technical specifications and
11 surveillance procedures to ensure that those are all
12 appropriate and work.

13 We'll be exercising the EOPS and giving
14 the operators critical experience necessary so that
15 when the plant actually goes into commercial service,
16 they'll be familiar with how the plant responds and
17 that kind of thing.

18 We've just included this just to give a
19 feel for the scope. This is how we have for the EPR
20 grouped systems in the plant. The FSAR is laid out
21 this way.

22 We'll just note that pre-op testing
23 includes hot functional tests near the bottom of this
24 list. And just maybe are noteworthy that there are 173
25 individual test abstracts that are included in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FSAR in Section 14.2 that cover all of this.

2 The start up objectives in the next phase,
3 actually after fuel load, are:

4 To establish that we can safely load fuel
5 and establish initial criticality;

6 Perform with our physics testing, and;

7 Go through our normal power ascension and
8 along the way complete a wide variety of operational
9 and transient tests that you would never be able to
10 demonstrate without having the reactor power.

11 Testing scope. There's nothing here
12 that's atypical for what you might see in any other
13 PWR. Just noted here that in our FSAR we got 39 tests
14 that describe abstracts for various and sundry tests
15 that occur along this trajectory.

16 We've included this overhead. It's a
17 somewhat of an anomaly in way to call these all unique
18 because several of these features in EPR are only
19 evolutionary in regard to how they're applied in our
20 particular design. They're not necessarily
21 fundamentally unique to the EPR in the concept for
22 functionality or the general organization of it.

23 The thing that may be somewhat unique in
24 regard to how the plant has been designed is the
25 partial trip feature which is noted as the last item

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on this list, which is an important feature in order
2 to demonstrate all the maneuverability in transient
3 upset robustness that we've tried to design into the
4 EPR.

5 Slide 10 shows a representative list of
6 the events that will be specifically tested during the
7 ITP. Certainly not comprehensive, but representative.

8 There is some information in your slide
9 deck that basically just highlights what the primary
10 objective of each of these tests are. I don't think
11 there's anything here that, again, is atypical of a
12 typical PWR start-up or what you would expect to see
13 in the scope. And there's nothing that is peculiar in
14 regard to the EPR other than the size of the plant
15 that we would draw attention to.

16 The last item is the one that we thought
17 might be worth just discussing briefly, the island
18 mode of operation. So, we'll just go to that, if that
19 would be acceptable.

20 MEMBER STETKAR: Charles, before you do
21 that, I'm sorry.

22 MR. TALLY: Yes.

23 MEMBER STETKAR: I'm kind of in a fog here
24 a little bit. I'd like to say I read every single
25 test procedure in 14, but I don't like to lie, so I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 didn't.

2 Back on the previous slide, No. 9, where
3 you talk about the RCP standstill --

4 MR. TALLY: Seal.

5 MEMBER STETKAR: Standstill seal test,
6 could you summarize what you're going to do with that?

7 Are you actually going to turn off all cooling and
8 let the system sit there hot and pressurized and
9 verify no leakage from the standstill seal?

10 MR. TALLY: That is correct. It was made
11 to be tested.

12 Wallace, can you answer specific questions
13 about the technical parameters?

14 MR. PONDER: I'm not sure how long, but
15 we're going to do it during hot functional.

16 MEMBER STETKAR: Sure, obviously.

17 MR. PONDER: We go down and make sure that
18 the RCPs have stopped.

19 MEMBER STETKAR: Yes.

20 MR. PONDER: And then we close the seal
21 and open drains and verify that we're not getting
22 backflow through the seal.

23 MEMBER STETKAR: Okay. That's sort of
24 initially, but you know the purpose of the thing is to
25 have no leakage under no cooling at temperature and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure for some period of time. So, I was curious
2 whether you're just going to verify that you got no
3 leakage for, you know 30 seconds and that was success
4 or whether you were going to let it sit there and cook
5 for 24 hours or something like that for a functional
6 test of the design of the piece of equipment.

7 MR. PONDER: I'll have to look it up.
8 It's Test 161.

9 MEMBER STETKAR: Okay.

10 MR. PONDER: And I'll see how long we
11 leave it.

12 MEMBER STETKAR: In the interest of time,
13 why don't you go on with the -- if you can find it,
14 that would be good. I'll see if I can find -- is it
15 summarzied in 14.2?

16 MR. PONDER: The test abstracts.

17 MEMBER STETKAR: Test abstract.

18 MR. PONDER: We'll come back to that.

19 MEMBER STETKAR: Yes, come back to it, and
20 we'll go on. Because the loss of offsite power is
21 interesting.

22 MR. TALLY: So Test 227 is the loss of
23 offsite power with auxiliary load supplied in the
24 island mode. And the test objective is noted here.
25 Essentially the way this test is executed is that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 deliberately opened the switchyard output breakers
2 which normally would supply to your incoming or
3 outgoing grid lines and demonstrate that the
4 electrical transient can be sustained on the
5 electrical buses within the plant to satisfactorily
6 respond, and then that the plant can run back from
7 what essentially is going to be probably a 90 percent
8 load rejection maintaining the RCS within parameters,
9 pressure and temperature so that it doesn't trip.
10 Pressure rod drop effectively will reduce the power to
11 allow the power to then be run on back to about 20 to
12 25 percent.

13 So, it's a very dynamic event, a lot of
14 interest in it. We're fully anticipating that this
15 test is going to be run at OL3 and Flamanville, and
16 Taishan. So, before the first U.S. plant starts up
17 there should be a lot of experience with this to help
18 iron out any issues if there are any.

19 Now, this does require a high degree of
20 tuning, and not only tuning for the NSSS support
21 auxiliaries and all that, but also that the electrical
22 system and all the relaying and selective tripping
23 functions be set up properly so that you don't lose
24 buses that you're not supposed to lose and wind up
25 with a more serious event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Charles, does that last
2 bullet suggest that the main steam safety valves do
3 not actuate?

4 MR. CONCKLIN: That's the plan.

5 MEMBER SKILLMAN: That's the plan?

6 CHAIR POWERS: You raise an interesting--

7 MEMBER STETKAR: That's turbine bypass, so
8 it's kind of important on this.

9 CHAIR POWERS: You raise an interesting
10 question of how many of the tests that you anticipate
11 doing, what also have been done at the other EPRs
12 which are slightly different, but close enough for
13 this purpose as a prior to when you anticipate without
14 knowing exactly the conduct of the test in the United
15 States.

16 MR. TALLY: Are you asking a question?

17 CHAIR POWERS: Yes. I was asking how many
18 of them?

19 MR. TALLY: How many of them?

20 CHAIR POWERS: I mean, are other people
21 doing the whole panoply or are them some subset of
22 them, or --

23 MR. TALLY: Our European EPR people have
24 told us that the plans are for this test to be run at
25 all three of those other sites.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR POWERS: This particular one? How
2 about all the others?

3 MR. TALLY: Yes. I don't know about --
4 it's hard to say.

5 And the other thing I think is noteworthy,
6 is this will probably be the last test that will be
7 run. And, you know you saw the initial list that I
8 put up. There are a lot of very dynamic events there
9 including load rejections, separations from the grid
10 you know before we actually get into this. So,
11 typically in a plant start-up you wind up doing tuning
12 and adjustments to get things dialed in. Hopefully by
13 the time we get to this test things will be solid
14 enough that we will be able to execute it
15 successfully.

16 CHAIR POWERS: That crosses my mind that
17 in the aftermath of Fukushima there's going to be lots
18 of things discussed --

19 MR. TALLY: Yes.

20 CHAIR POWERS: -- about the capabilities
21 that they want the plants to have, probably exceeding
22 the design basis per se. And I'm wondering in
23 thinking about your test program if you've tried to
24 anticipate what the Commission might think plants
25 should be able to do and factor those into your test

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 program?

2 MR. TALLY: The answer to that is not for
3 the EPR. AREVA does have an active effort in progress
4 in regard to what's going to be imposed on the
5 operating fleet. I think things like that on mode of
6 operation may be viewed as more critical going forward
7 to preserve the overall grid, you know in the event of
8 a large conflagration. But we haven't deliberately
9 tried to factor into this test program yet anything
10 that may come out of --

11 CHAIR POWERS: Well, it's been speculative
12 at this point, to be sure, and whatnot. But it may
13 not be ignorable at this point either.

14 MR. GARDNER: I'd just say we're
15 developing those plans now with discussions with the
16 staff, some beginning next week. So the key word is
17 not yet.

18 CHAIR POWERS: Yes. I'm, glad to hear
19 that. Because, I mean I can't give you any advice.
20 But I know they're talking about all kinds of things
21 they want plants to be able to do, and in fact plants
22 ought to be able to do. But, who knows?

23 MR. GARDNER: Yes.

24 MR. TALLY: Yes. Well, you know if you
25 have a serious external event that takes out your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 switchyard, you know you're not going to be able to
2 operate like this anyway.

3 CHAIR POWERS: Yes.

4 MR. TALLY: So, I mean, it'll just be
5 dependent on what kind of an external event you
6 actually have that limits operations.

7 CHAIR POWERS: Yes. One of the problems
8 that people get very focused on particular external
9 events, and the fact is that particular external event
10 probably will never occur. It will be some different
11 external event with different characteristics that we
12 are unable to anticipate.

13 MR. TALLY: Right.

14 Well, if there are no other questions,
15 we'll go on to Slide 17.

16 The COL applicant is the one that's
17 responsible for the implementation of the ITP.
18 According to the SER, we will have a role in that, the
19 vendor will have a role in that in regard to the test
20 panel, that we'll be reviewing the test procedures and
21 the results of those. But within the scope of that
22 they will be required to provide the organizational
23 structures, the requirements, qualifications, detail
24 of the test program schedule and evaluate and
25 proscribe how tests will be approved, results will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluated, et cetera.

2 And with that, that's the conclusion of
3 the review of the initial test program. Any other
4 questions before we --

5 MEMBER SKILLMAN: Any chance you've found
6 an answer to 161, please?

7 MR. PONDER: I did not include a time
8 limit. I said "within design limits." Let's see, the
9 RCPs can be secured one at a time at hot zero power
10 conditions and the RCP sealed package including the
11 stand still seal can be verified to limit RCS within--
12 leakage within design limits.

13 MEMBER SKILLMAN: Thank you. Thanks.

14 MEMBER BROWN: Okay. I have one follow-on
15 question since you're going through the lists of
16 tests. We've had considerable discussion under the
17 I&C rule in terms of the importance of the watchdog
18 timer to ensuring that if the break processors lock up
19 in any division, that in fact it generates a reactor
20 trip signal as it articulated to supposedly do in the
21 SER and its associated documents. Is there a test
22 that's part of this pre-operational test program that
23 confirms that it ensures that the watchdog timer
24 actually experiences a timeout -- I don't know how you
25 do it. I'm not a designer. But to make sure that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 does get executed and that it does result in an
2 appropriate trip of its associated reactive trip
3 device in, you know two out of four chain of
4 operations?

5 I'd like to say I tried to find that. I
6 got the note to go look for that. I just now thought
7 of it.

8 MR. TALLY: I don't know. Do we have that
9 level of detail that's in here?

10 MR. PONDER: It's a fair amount, but I'd
11 have to --

12 MR. GARDNER: Maybe we can ask and give
13 him an opportunity --

14 MEMBER BROWN: No. It don't need to be
15 answered now. It can even be answered later in terms
16 of our subsequent discussions relative to the
17 performance and the further clarifications of the
18 operations of the watchdog timer. It's just that it is
19 a critical key and since it operates on a division-by-
20 division basis, you know they're supposed to be
21 totally separated from each other, but it would be
22 good to verify it. So I'd like to at some point
23 later, we don't have to deal with it right now. But
24 somehow list now to ask that question later as part of
25 our overall discussion as a resolve to where we go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with the watchdog timer discussions and clarifications
2 and get a picture of what they look like.

3 MR. GARDNER: Okay.

4 MEMBER SKILLMAN: I would like to ask
5 Wallace about the pressurizer surge line test for
6 thermal stratification and its connected design
7 elements.

8 MR. PONDER: Yes.

9 MEMBER SKILLMAN: Could you give us just a
10 glance of what this test really does?

11 MR. PONDER: What we're trying to do is
12 verify that it has a continuous slug and we know
13 there'll be some cycling. But what we're really
14 worried about is a high number of cycles with
15 something phenomenal like thermal strapping; we
16 should not have that.

17 MEMBER SKILLMAN: So the design limits in
18 this context are the fatigue limits on the --

19 MR. PONDER: The fatigue --

20 MEMBER SKILLMAN: -- sections of the metal
21 or the T -- or the connection to the pressurizer, that
22 type thing?

23 MR. PONDER: That's correct.

24 MEMBER SKILLMAN: So it's really connected
25 to the fatigue limits for the ASME code analysis?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PONDER: Yes.

2 MEMBER SKILLMAN: So this then becomes an
3 cycle counting?

4 MR. PONDER: Cycle -- we want to make sure
5 that we're only acquiring counts when the system is
6 started up and shutdown, that we're not acquiring
7 counts in steady states.

8 MEMBER SKILLMAN: Okay. Thank you. Thank
9 you.

10 MR. TALLY: Anything else on ITP? All
11 right.

12 The outline of the material that we're
13 going to go through for Chapter 14.3 in regard to
14 Certified Design Material ITAAC is on this overhead.
15 We'll walk through this subchapter section at a time.

16 Section 14.3 Tier 2 provides the selection
17 criteria and the methods that are used to develop the
18 Tier 1 material. There are two types. The Certified
19 Design Material, which is essentially brief system
20 description type requirements. And it's noteworthy to
21 point out that the Tier 1 material is always dry from
22 Tier 2 material. That there's no new information
23 that's developed from Tier 1.

24 There are five chapters that are described
25 in the FSAR for what's in Tier 1. They're outlined

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. We're going to go through these one at a time.

2 We need to point out that the Design
3 Certification provides interface requirements to the
4 COLA and the COLA provides the ITAAC for emergency
5 planning and the site-specific portions of a facility
6 that will be licensed by the applicant, the COL
7 applicant.

8 This provides kind of a pictorial of how
9 ITAAC are developed for the COLA applicant. You'll
10 note here in the middle of the page that the FSAR
11 develops DC ITAAC that have to be satisfied by the COL
12 applicant. At the same time, the DC effort identifies
13 interface requirements for systems that are
14 incompletely described in the Design Certification
15 package. In other words, we may have requirements for
16 something like that. Essentially service water:
17 There's a large part of that system that may be
18 embedded in the scope of the DC, but when we go out to
19 something that's site-specific and the COL applicant
20 has got to satisfy those interface requirements. So
21 these feed into the COL ITAAC COLA action, so to
22 speak, as well.

23 And then in addition to that any site-
24 specific systems where there are significant design
25 features that inherently bear on safety have also got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to be identified in the same way we would for the DC--
2 the COLA applicant has got to do for his scope. That
3 is the last piece that feeds into the COLA ITAAC
4 collection that ultimately then will have to be closed
5 out by the COLA applicant who is constructing the
6 plant.

7 The introduction of Tier 2 Section 14.3.1
8 basically provides the backdrop infrastructure for the
9 definition of the rest of the material that's
10 discussed in 14.3. You actually get into the meat and
11 potatoes when we get into the second section of this
12 chapter, which is the system-based design descriptions
13 in ITAAC. This is where you'll find the bulk of the
14 ITAAC that are derived for the plant. As noted here
15 again, this is all coming from Tier 2 material and is
16 the basis for the Certified Design phase as well as
17 the content and format for the actual ITAAC
18 themselves.

19 We included here just a listing of, again,
20 the grouping the way it appears in EPR FSAR for the
21 overall structure of what you would find in the ITAAC.

22 If you pull out the actual ITAAC, they're organized
23 and grouped in this fashion.

24 Do now we want to talk just briefly about
25 the selection process for what lines up being included

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in ITAAC. In other words, how did we get to this
2 significant body of work that we call our ITAAC?

3 There are two fundamental processes. This
4 is consistent with what's defined in the SRP for 14.3.

5 Essentially, we go through an assessments of SSCs to
6 determine what has some safety significance and at the
7 same time in parallel go through a series of
8 evaluations of analytical pieces of work that support
9 the overall plant design to identify any key design
10 parameters that are noteworthy and should be addressed
11 with ITAAC. These two collectively are then rolled
12 into the Tier 1 commitment and we have ITAAC developed
13 for them. We'll have some examples here just shortly
14 in regard to what these look like.

15 So these SSCs are reviewed based on their
16 classification, safety classification and function.
17 And the thing that's important to find out here is
18 that in ITAAC we're not verifying a function, we're
19 verifying a design feature that supports that
20 function. So, you know the ITAAC tend to be extremely
21 specific with regard to a measurable measurement that
22 needs to be demonstrated at the time that the plant is
23 actually constructed.

24 An example here is shown on the second
25 bullet where we would have an ITAAC that would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 demonstrate or confirm the existence of piping and
2 other equipment that's necessary to be able to provide
3 a safety function in this particular case.

4 Note that on the third bullet that there
5 would not be an ITAAC for a lot of the ancillary
6 equipment that you would find typically in a fluid
7 system that would be there for, you know the normal
8 operation, maintenance and that sort of thing. So the
9 key here is what's really essential to demonstrating
10 that the function will be able to be provided that is
11 critical. The functions are defined in the CDM.

12 The analyses that are reviewed are
13 consistent also with the guidance in the SRP. We've
14 put them up here. You can see what had to be culled
15 through to determine what was noteworthy here that
16 needed to find its way into ITAAC. And, of course,
17 this has been a very interactive process for the staff
18 reviewers who sometimes have had differing views in
19 regard to not only this portion, but some of the other
20 systems, SSCs, in regard to what really ought to be
21 included and what was the appropriate way to phrase or
22 status what the ITAAC will be. It's been a little bit
23 of a -- it's been a lot of a learning process, very --
24 very interactive.

25 CHAIR POWERS: It will continue to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interactive.

2 MR. TALLY: That's right.

3 So in other words, to summarize here
4 again, the SSC features that are provided to meet
5 various functional requirements are discussed in the
6 Tier 2 material. There's nothing in Tier 1 that
7 points to in a direct reference way, Tier 2. So Tier
8 1 is self-contained.

9 Here's another example both for our system
10 and structure. If you looking at the functional
11 requirement, you would say, for instance, that the
12 LHSI provides core cooling for large-break loss of
13 coolant accident. But rather than find something that
14 includes that functional statement in ITAAC, what you
15 would find is that there exists LHS piping runs from
16 the IRWST to the reactor coolant system of the IRWST
17 necessary pump and heat exchanger that would provide
18 that function. So these are discrete: You can go
19 touch, feel, confirm that this equipment is there.

20 At the same time the analytical reviews,
21 for instance in this case Chapter 15, would say that
22 in order for this function to actually be satisfied,
23 you've got to be able to deliver fluid from this
24 system at a certain minimum flow rate. So you will
25 find also in ITAAC something like the third bullet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there under the systems example that would confirm
2 that the system would deliver that flow under those
3 conditions that would exist for the event.

4 So there is a performance-based ITAAC and
5 then there's a physical features-based ITAAC that in
6 concert demonstrate that you would be able to satisfy
7 the overall function.

8 The structural example is perhaps a little
9 bit simpler, you know where to provide some inherent
10 features such as radiation protection or flooding, or
11 whatever, you may have a wall that's got certain
12 dimensional to it that you would confirm after
13 construction is there with that minimal wall
14 thickness. So there are quite a few ITAAC that are in
15 our submittal that go along those lines as well.

16 The system design description that's
17 included in Chapter 2 is what we refer to as a
18 Certified Design Material. The only thing we wanted
19 to highlight here is the recognition that the
20 Certified Design Material is in effect for the life of
21 the plant, and whereas as we'll point out here
22 shortly, you know at the conclusion or close-out of
23 the ITAAC those features then become controllable by
24 the licensee through other processes.

25 MEMBER SKILLMAN: Charles, you made the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 distinction on Slide 31 that the design material in
2 Tier 2. Isn't it accurate to communicate that both
3 Tier 1 and Tier 2 are certified, but Tier 2 material
4 requires a departure that's been evaluated by the
5 staff at the plant, whereas Tier 1 is really a license
6 change and requires regulatory action?

7 It's all certified, but the difference
8 between Tier 1 and Tier 2 is Tier 2 can be changed by
9 the licensee with a 50.59-like process, whereas Tier 1
10 is an actual license amendment?

11 MR. CONCKLIN: This is really just quoting
12 words out of the SRP where they use the term
13 "Certified Design Material." It's not meant to infer
14 what's the totality of the Design Certification.

15 MEMBER SKILLMAN: Okay.

16 MR. CONCKLIN: So the Certified Design
17 Material, the point of that is that's in effect for
18 the life of the facility and the other stuff can be
19 changed, as you say. That is correct.

20 MEMBER SKILLMAN: I agree with that.
21 Perhaps I jumped in haste. What I was trying to do
22 was to discern why you choose the word "Tier 2" in
23 referring to the first bullet. I think all the
24 material is certified, but Tier 1 can be changed with
25 one process, Tier 2 can be changed with a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 process. Departures are required.

2 MR. CONCKLIN: We would agree.

3 MEMBER SKILLMAN: Thank you. Okay. Thank
4 you.

5 MR. TESFAYE: That's correct.

6 MEMBER SKILLMAN: Okay.

7 MR. TALLY: Slide 32 basically is just to
8 highlight that, you know ITAAC are consistent with
9 what's in the Certified Design Material. And as I
10 mentioned earlier, the Certified Design Material, if
11 you're not familiar with it is essentially a system
12 description by system that actually includes
13 functional requirements.

14 The ITAAC must be satisfied with closure
15 justification. This process, which will be
16 interesting for the COL applicant, I'm sure. And as
17 noted here, the third bullet, you know the ITAAC
18 expire after the closure process has been completed.

19 Slide 33 is just another review of the
20 format and content of ITAAC. We comply with this. No
21 issues here.

22 Now we get into Chapter 3. This is the
23 nonsystem-based design description of ITAAC. The SRP
24 provides a suggested list of topics. These tend to
25 be, what do you call them, transfers types of issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in a plant. They don't necessarily line up with a
2 single system very cleanly. And as you can see from
3 this list, you know the Reliability Assurance Program
4 and the factors and things like that are in fact
5 transfers with regard to their scope.

6 While AREVA was going through this overall
7 evaluation and developing our Tier 1 material we also
8 added topics from the list that you can see that's
9 included here in the realm of security: Containment
10 isolation, plant cable and et cetera.

11 The Certified Design Material in ITAAC or
12 Chapter 3 follow the same approach as the system-based
13 CBM in ITAAC or Chapter 2.

14 Chapter 4 actually gets into these
15 interface requirements that we discussed earlier in
16 regard to what the COL applicant is going to have to
17 address. It's incumbent upon the Design Certification
18 provider to identify these interface requirements. I
19 don't know that there's any more that needs to be said
20 about this.

21 And the last chapter has to do with site
22 parameters. These are essentially site parameters that
23 were assumed in the Design Certification that the COLA
24 applicant has then got to confirm, he satisfies for
25 his particular site that he's going to be licensing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The last section has to do with the nine
2 acceptance criteria. Here again, we've used a site
3 interpretation definition of DAC that's in the SRP. I
4 don't think there's anything unusual here to comment
5 on either. Closure processes for DAC are noted at the
6 bottom of this overhead.

7 Here again, this will be the COLA
8 applicant that will be dealing with these.

9 The last overhead, the next overhead, just
10 points out that for the U.S. EPR we're only applying
11 DAC in two areas for piping design and human factors
12 engineering.

13 And that concludes the overview of the
14 14.3, the Certified Design Material in ITAAC.

15 MR. GARDNER: Dr. Powers, if there are no
16 questions, then we'll turn it over to the staff for
17 their portion of the presentation.

18 CHAIR POWERS: Do we have any other
19 questions in this area?

20 Thank you very much. You're done.

21 MR. GARDNER: Thank you.

22 CHAIR POWERS: Tanya.

23 MR. TESFAYE: And we are ready. Dave
24 Jaffe, who is the Chapter PM for Chapter 14 will lead
25 this discussion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Okay.

2 MR. JAFFE: Good morning. My name is Dave
3 Jaffe. It's an honor to be here this morning with the
4 Subcommittee to discuss the staff's evaluation of
5 Chapter 14.

6 I received my Bachelor of Science degree
7 from Clarkson University and my Master's in
8 Engineering Science from Rensselaer Polytechnic while
9 dinosaurs roamed the earth.

10 MEMBER STETKAR: But from real schools
11 that turned out real engineers.

12 MR. JAFFE: Absolutely.

13 I am in my 35th year with the NRC staff,
14 and I have ten years experience elsewhere in the
15 industry, mostly in licensing project management.

16 Currently I'm assigned in Licensing Branch
17 1 in DNRL. And I'm lead for Chapter 14 review.

18 Next slide, please.

19 The subject material in Chapter 14 is, of
20 course as AREVA's pointed out, is divided between the
21 initial plant test program in 14.2 and then ITAAC in
22 14.3.

23 14.2 is a fairly cohesive evaluation under
24 the purview of the Quality Assurance Branch. And
25 Andrea Keim will present items that we hope are of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interest to the Subcommittee in 14.2.

2 14.3 is a number of inputs from virtually
3 every branch across the design spectrum that are
4 involved with ITAAC. So 14.3 is rather an assemblage
5 of other inputs. And the names below Andrea Keim are
6 the various disciplines.

7 Next slide, please.

8 Getachew Tesfaye, as you know, is the Lead
9 Project Manager for the U.S. EPR --

10 MR. TESHAYE: You're capturing that.

11 MR. JAFFE: Yes. Yes, he seems to kind of
12 show up from time-to-time. I don't understand why, but
13 he's here. Okay.

14 Tanya Ford is Co-Project Manager with me
15 on Chapter 14. And for the purposes of this
16 presentation and of the staff's review, Tanya had --
17 excuse me. I had 14.2, Tanya had 14.3 as Project
18 Managers.

19 Next slide, please.

20 We provided some statistics here for you
21 as to the number of questions and status of OIs. I'm
22 sure you've seen this before.

23 Next slide, please.

24 And again. Next slide.

25 Okay. We had a total of 33 open items, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of course not all of these are of equal import. And
2 we don't want to bring you things that you would not
3 find interesting.

4 However, next slide. We did corral a
5 number of items that we'd like you to hear about.
6 Andrea Keim will present information about open items
7 in 14.2. Tanya Ford is going to present information
8 in 14.3.1 which normally is not much of a topic for
9 us, but there are some important crosscutting issues
10 here including inspectability that we think you should
11 listen to.

12 Manas Chakravorty will talk a little bit
13 about open items in structural and systems
14 engineering. And Daniel Mills will talk about issues
15 in I&C.

16 We have experts in the other areas that
17 are available to you should you be interested to hear
18 about these other areas of review.

19 Tanya Ford will now -- oh, I'm sorry.
20 Andrea Keim, please.

21 MR. KEIM: Hi. Thanks for having me.

22 My name is Andrea Keim. I received a
23 Bachelor's and Master's degree from Stevens Institute
24 of Technology in Materials and Metallurgical
25 Engineering.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR POWERS: We got some new engineers.

2 MR. KEIM: I've been here with the Agency
3 for about 16 years. Currently, I'm working in the
4 Quality Assurance Branch in NRO. My boss is Karrie
5 Kavanaugh.

6 I appreciate this opportunity to brief the
7 ACRS Subcommittee on the status of the review for
8 Chapter 14.2 of the initial plant test program on the
9 EPR design.

10 This has been a multi-year review
11 involving a broad number of staff and multiple
12 disciplines. So we also had a lot of people; I've had
13 I think 14 different reviewers provide me some small
14 input or review and checklists -- not checklist,
15 scratch checklist. And checking and verifying the
16 data in their chapter reviews to confirm what is in
17 the initial plant test program.

18 So, approximately 18 staff personnel have
19 provided the 163 RAIs. At this time we have six open
20 items that are currently being reviewed by the staff,
21 and we have the information that is provided by their
22 applicant that are being resolved, hopefully shortly.

23 As they finish the chapters, we'll be able to close
24 out the open items on those six.

25 There's one open item that we are still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 waiting for a response from the applicant, and that is
2 on Question 14.2; that's the one that's showing on the
3 screen. And it's related to the radiation monitoring
4 system. The staff noticed some inconsistencies and
5 asked for some clarification. These systems are
6 important for ensuring proper operation of automatic
7 control functions upon detection of higher
8 radioactivity levels.

9 Once the staff reviews the applicant's
10 response, the staff should be able to close out this
11 item.

12 At this time there aren't really any high
13 level outstanding issues that are being discussed for
14 14.2 beyond the level of details and some
15 inconsistencies between the chapters and the test
16 abstract acceptance criteria that are being resolved
17 through the RAI process.

18 So if there's no questions, I can hand
19 this over to Tanya Ford.

20 MEMBER STETKAR: If there's no questions.
21 Unfortunately, there is one. I want to follow-up a
22 little bit with you regarding my question to the
23 applicant about the success criteria for Test 161.
24 And I couldn't find any questions regarding that test,
25 so apparently you were happy with at least the summary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 information in the FSAR. But I point you to SER
2 section 9.3.4.4.1. And in that section of the SER
3 there's a discussion regarding the performance of the
4 standstill seals. And without quoting a whole lot of
5 text, it basically says -- this is discussing station
6 blackout, loss of all seal coolant.

7 "Approximately ten minutes into the SBO
8 event the RCS pump seals fail which adds about 100
9 gallons per minute RCS leakage rate to the to the
10 initial leakage rate. Around 15 minutes into the
11 event standstill seal system reduces the leakage rate
12 to two gpm for the duration of the eight hour coping
13 period. When the RCS leakage rate is integrated over
14 the eight hour coping period, the total leakage is
15 approximately 7,510 gallons, approximately."

16 And that, you know was the basis for
17 resolving the RAI. In my mind that's acceptance
18 criteria for the performance of the standstill seals;
19 namely a leakage rate and an integrated leakage over
20 an eight hour coping period at high pressure with the
21 no cooling. And I was curious whether or not indeed
22 their test will verify this?

23 And I'm particularly interested, Fukushima
24 aside, this standstill seal package as I understand it
25 has not yet been installed in any other operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant. It is indeed a new design for, in particular,
2 the U.S. EPR. So we don't have any operating
3 experience. We don't have any other test experience
4 on this particular type of seal. So, I was curious
5 why you haven't followed up on that test.

6 MR. KEIM: It sounds like something we
7 should follow-up to make sure that we get consistency
8 between the chapters --

9 MEMBER STETKAR: Yes. I mean all they said
10 when I asked them is that it would meet the acceptance
11 criteria, but I wasn't quite sure in their mind what
12 that meant. And in my mind, this is an excerpt from
13 the SER. It's not from the FSAR; I couldn't find
14 these words in the FSAR. But there appears to be some
15 closure that needs to be made regarding what indeed
16 are the functional performance acceptance criteria for
17 those seals and how that will be verified through the
18 start-up functional testing part.

19 MR. KEIM: So that may need -- in 14.2
20 from the test abstract back to the --

21 MEMBER STETKAR: Yes. I didn't know
22 whether you had any discussions. Granted, the test
23 abstracts or test abstracts, but --

24 MR. JAFFE: I took a quick look at 161,
25 and I didn't find any hold times.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: There aren't any, and in
2 fact quite honestly when I was skimming through things
3 I didn't even link 161 as related to kind of
4 performance testing of the standstill seals.

5 MR. JAFFE: There's probably a level of
6 detail, you know that's --

7 MEMBER STETKAR: And at this stage I don't
8 know how much detail you go into those types of
9 issues, typically. But --

10 MR. KEIM: Sometimes the more the better,
11 sometimes the less the better. So you give it a
12 little bit of possibility --

13 MEMBER STETKAR: It's sometimes easier to
14 get the discussion, you know on the table already.

15 So, that's the only I had whether you had
16 any discussions relating to that issue.

17 MR. KEIM: We can take that back and maybe
18 look into maybe adding another RAI --

19 MR. JAFFE: Yes.

20 MR. KEIM: -- to try and get a little
21 more detail.

22 MR. TESFAYE: We'll get back to, maybe
23 today, and see what we have.

24 MEMBER STETKAR: Probably not today. I
25 won't be here this afternoon. So that might give you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some wiggle room.

2 MR. TESFAYE: Oh, okay.

3 MR. JAFFE: We'll take it, in any event.

4 Thank you.

5 MEMBER STETKAR: Thanks.

6 You're here.

7 MR. STACK: This is Tim Stack again from
8 AREVA.

9 And when we talk about the initial test
10 program, one of the other things to keep in mind is
11 separately from that there's a qualification test
12 program for the equipment that typically will do an
13 eight hour run on the standstill seal for whatever the
14 required duration is; eight hours, or whatever the
15 number turns out to be. And similarly, like on the
16 watchdog timers you do a functional test and
17 demonstrate the functional testing before you ship it
18 from the factory that, you know when the watchdog
19 timer times out, it flips the reactor.

20 So everything that you have in the initial
21 test program isn't necessarily tests. There are many
22 tests that are performed in qualification just like we
23 talked about in the CRMs earlier. So you need to keep
24 it in mind that the tests will be done, they may not
25 all appear in the ITP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes, I understand that,
2 Tim. The reason I brought it up was we kind of raised
3 this issue when we were going through our -- I don't
4 remember whether it was Chapter 5 or Chapter 9. I have
5 notes in both of those chapters here to myself. And
6 all my notes say is you were going to get back to us
7 on what sort of acceptance testing you were going to
8 do. So --

9 MR. STACK: And we drafted a response.

10 MEMBER BROWN: Let me make one comment
11 relative to your last -- if you read the DCD and the
12 rest of the documents, it doesn't really tell you
13 where the reactor trip devices themselves are located.

14 Are they part of the cabinet itself, are they located
15 closer to actual actuators that they have to control?

16 The other thing is you obviously tested in
17 the qualification test program, but at some point you
18 got to make sure it does something in the plant. In
19 other words, are the wires hooked up? Are they hooked
20 up to the right place? So you got to have something
21 that verifies your overall as opposed to just an
22 inspection.

23 And the only reason I say that I've seen
24 people do inspections. Somebody put the wrong wire
25 marker on. All of a sudden the wire doesn't go from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 point A to point B, it goes from point A to point D
2 and you do not get the desired end result. So, a
3 final integrated test which shows that you actually --
4 it gets your end result in my mind is an important
5 aspect of that pre-operational test program.

6 So, I just wanted to provide that as an
7 amplification on your comment. I understand the
8 qualification part. They'll obviously see -- no, I'm
9 not going to say that. Theoretically, that should be
10 tested.

11 MR. STACK: Okay. Thank you.

12 MEMBER BROWN: All right.

13 MR. JAFFE: All right. Good.

14 Tanya?

15 MS. FORD: All right. Good morning.

16 My name is Tanya Ford. I am Project
17 Manager and I assisted Mr. Jaffe in coordinating the
18 staff's review for Chapter 14 of the U.S. EPR Design
19 Certification application.

20 This morning I'd like to discuss some of
21 the generic concerns identified by the staff for
22 Chapter 14 which were issued to the applicant in RAIs.

23 Sorry, I have to get use to working my
24 slides and reading.

25 In RAI 182 Question 14.3-10 the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 raised various concerns regarding ITAAC including
2 inconsistencies with ITAAC wording in interpretations,
3 technical adequacy of ITAAC. definitions used in ITAAC
4 wording and ITAAC inspectability issues.

5 One example of these generic concerns was
6 the applicant's definition of the term "as-built."
7 The staff has worked with NEI and endorses the
8 definition as-built in NEI document 08-01 Revision 4.

9 This document establishes guidance on the accepted
10 definition of the term of the term as-built and how to
11 interpret this term when it is used in ITAAC. The
12 applicant has since adopted the NEI 08-01 Revision 4
13 definition and the staff considers this generic issue
14 to be resolved. However, after reviewing the
15 applicant's complete response to RAI 182, the staff
16 determined that the response was insufficient in
17 addressing all of the staff's generic concerns, and
18 therefore the staff issued follow-up RAI 469 Question
19 14.03-16 to address the remaining concerns that have
20 not been resolved.

21 So as a follow-up, RAI 469 contained some
22 of the same generic issues including specificity in
23 ITAAC wording, improper use and omission of as-built
24 terminology in ITAAC, and ITAAC inspectability issues.

25 As noted, the staff is still in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 process of reviewing the applicant's response to RAI
2 469 and has already provided the applicant some
3 feedback regarding its response. Some quick examples
4 of feedback that has already been provided to the
5 applicant include:

6 Lack of specificity. So for example, in
7 the SER there are several instances where the ITAAC
8 requirement simply states that an analysis be
9 performed. The staff's issue was that there is no
10 specificity as to whether this analysis is to be based
11 on the design phase or after construction. So, by
12 saying analysis only and not providing this
13 specificity at either the design phase or after
14 construction, this leaves ambiguity in when the
15 analysis is to be performed. So the staff has informed
16 AREVA that this level of detail needs to be included
17 and so that they should look throughout the ITAAC and
18 provide this specificity wherever an analysis is
19 required to be performed.

20 Another example is the lack of inspections
21 of analysis. So the staff noted that in several cases
22 there are analyses that are required to be based on
23 the as-built conditions. There also needs to be an
24 inspection associated with this ITAAC to verify that
25 the work was completed according to the applicable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specifications of the analysis. So therefore, the
2 staff informed AREVA to take a look at all of its
3 ITAAC to determine where there is a need to add an
4 appropriate inspection to correspond with the ITAAC
5 analysis.

6 Quickly, next slide.

7 An issue with ASME code related ITAAC.
8 The staff just identified that all ASME code related
9 ITAAC should be consistent throughout all of the ITAAC
10 sections. So this means if an ASME code related ITAAC
11 appears in different ITAAC chapters, the wording
12 should be consistent in each reference throughout
13 ITAAC to avoid confusion.

14 With omission of as-built terminology, the
15 staff noticed that in several instances the term "as-
16 built" was removed from ITAAC wording when in some
17 instances it should not have been. So the staff noted
18 that if the requirement is to be performed after
19 construction has been completed, then this terminology
20 should be added back into the ITAAC wording to provide
21 this level of specificity.

22 And one last example, next slide, is for
23 severe accident ITAAC. The staff has requested that
24 the applicant add ITAAC for specific nonsafety-related
25 equipment. AREVA quotes from SRP Section 14.3 that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 only the existence of the feature needs to be verified
2 by ITAAC. This argument relates to the SRP Section
3 14.3 guidance that the level of design detail need
4 only be commensurate with the significance of safety
5 functions. However, the SRP also suggests that a
6 graded approach be used, specifically how to address
7 specific nonsafety-related criteria for inclusion in
8 Tier 1 such as severe accident, ATWS and fire
9 protection.

10 The staff believes that additional severe
11 accident ITAAC need to be included or selected safety
12 significant, but nonsafety-related equipment. An
13 example of this would be the hydrogen monitoring
14 system which measures the hydrogen concentration in
15 containment during and after the accident.

16 And the staff was also issued a specific
17 RAI on severe accident ITAAC in Section 14.3.11

18 CHAIR POWERS: This particular item would
19 seem to relate closely to my question I posed earlier.

20 We can anticipate that there may be additional
21 requirements stemming from the post-Fukushima fallout.

22 Are you keeping your finger on the pulse there to
23 understand what those might be as they relate to this
24 application?

25 MS. FORD: Yes, the staff is. And we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Anne-Marie Grady who is actually the second core
2 reviewer for Section 14.3.11. And I believe that is
3 where the additional RAI stemmed from. So they
4 brought it out of RAI 469, which was generic, and made
5 a specific severe accident ITAAC. I don't know, Anne-
6 Marie, did you need to add anything to that? Okay.

7 CHAIR POWERS: Give us any insight on
8 what's going to be required?

9 MS. FORD: Yes, I don't think that we have
10 that information ready yet.

11 MEMBER STETKAR: Tanya, you've
12 characterized this on the slide as severe accident
13 ITAAC because severe accidents have a connotation that
14 may be different to different people. Is this really
15 restricted to severe accidents? The examples that
16 you've listed here, I know what ATWS, I know what fire
17 protection, I know what station blackout is, I know
18 what hydrogen monitoring is. But does it expand more
19 broadly into that list of risk significant systems
20 that are on the D-RAP list, which may not necessarily
21 be severe accident-related. They may be core damage
22 prevention, if you will, or is the concern strictly
23 related to what I understand as severe accident
24 issues?

25 MS. FORD: Let me ask Anne-Marie to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 address that.

2 MEMBER STETKAR: I'm just trying to
3 understand the scope of this RAI in terms of --

4 MS. FORD: Right.

5 MEMBER STETKAR: -- how it reaches out
6 into nonsafety-related things throughout.

7 MS. FORD: Exactly.

8 MS. GRADY: Yes. This is Anne-Marie Grady
9 from the Containment Systems Branch.

10 And I can't speak to the D-RAP list at
11 all. But there are pieces of equipment that are in our
12 view safety significant, individually identified. And
13 because they're not safety-related, they have been for
14 that reason only not included in the ITAAC. And we
15 have on a case-by-case basis identified certain
16 equipment we think is safety significant and should be
17 ITAAC'd. It's not a generic ITAAC with all -- it
18 couldn't require the severe accident case-by-case
19 basis.

20 And ITACC'd -- the open item, the RAI that
21 I wrote related to the hydrogen monitoring system for
22 high range monitors for hydrogen.

23 MEMBER STETKAR: Thank you. That helps,
24 but I guess in my mind it's a bit troubling because
25 you used the term systems that you think should be on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this list. And I guess it raises a question in my
2 mind as far as the type of process that you use to
3 draw those conclusions about why specific things are
4 on your list and why specific things are not on your
5 list when, indeed, there is a process that's been
6 applied in this plant as part of the Design
7 Certification to create a list of things at least from
8 -- it's partly risk-informed, but it's also this
9 expert panel, you know reviewing the whole plant in
10 the context of things that could be important. That
11 list happens to include the hydrogen monitoring
12 system, but it also includes other things.

13 So, I was curious about, you know how you
14 make your determination of what you think should be on
15 this list and why you're asking questions about those
16 specific things and whether there's a kind of
17 consistent process here.

18 MS. FORD: Right.

19 MEMBER STETKAR: And I guess it's
20 troubling if you hear the people saying, you know
21 you're asking these questions but you're not familiar
22 with the D-RAP list, because I thought that that was
23 one of the purposes of that whole Reliability
24 Assurance Program was to identify nonsafety-related
25 things that are related to safety and risk.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. FORD: Well, I think that this will be
2 an item that we'll take back and --

3 MEMBER STETKAR: I'm not necessarily
4 inferring, by the way, that --

5 MS. FORD: Right. Exactly.

6 MEMBER STETKAR: -- everything on the D-
7 RAP list ought to be.

8 MS. FORD: Exactly.

9 MEMBER STETKAR: It bears to the
10 applicant. I'm just basically asking a question about
11 what sort of process did the staff use --

12 MS. FORD: Right.

13 MEMBER STETKAR: -- to focus in on things
14 under this particular RAI.

15 MS. FORD: And that will be the exact
16 things that we would get back to you.

17 MEMBER STETKAR: Thanks.

18 MS. FORD: Yes.

19 These are just some of the staff's generic
20 concerns and issues that still need to be resolved.
21 So, as you can see, RAI 469 Question 14.03-16 is still
22 being tracked as an open item to resolve the staff's
23 remaining ITAAC concerns.

24 At this time, this concludes my discussion
25 regarding the staff generic ITAAC concerns. And I will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 take that one item back with me to get back to you
2 with a more complete answer about the process.

3 MEMBER STETKAR: Yes. I mean, I'd like to
4 understand a little bit more about why specific items
5 are of concern.

6 MS. FORD: Yes. No problem. Yes. Thank
7 you.

8 MR. JAFFE: I'd like to introduce Manas
9 Chakravorty and Dave Foster.

10 I apologize that we don't have proper name
11 signs for them. Can you see their names properly?

12 MR. CHAKRAVORTY: Good morning. My name
13 is Manas Chakravorty, and I'm in the Structural
14 Engineering Branch of NRO. And I have been in the
15 nuclear industry for more than probably 35/40 years.
16 Since I actually graduated. And I was in the optic
17 engineer company first and then went to utility, then
18 into operating and operated the plants and then
19 eventually came back to being a regulator.

20 And with me I have also got David Foster.
21 We also worked way back then, 30 years back designing
22 Beaver Valley containment structure.

23 MR. FOSTER: We've known each other a long
24 time.

25 MEMBER STETKAR: You guys responsible for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the --

2 MR. CHAKRAVORTY: No, no, no. The
3 structural design.

4 Let me give you a little bit brief
5 overview of what we did in 14.3.2 on our structural
6 ITAACs. Using building structures of the new
7 checklist that is in the SRP our structure we've
8 included TL1 system-based design descriptions of ITAAC
9 Section 2.1. On structures giving these specific
10 features we used the ITAAC tables for verification.

11 Our primary focus was on the verification
12 of the Design Basis loads, key building dimensions,
13 cubicle pressurization and protections from internal
14 and external hazards and internal flood, containment
15 pressure testing and also seismic interaction effects.

16 So based on that we looked at those ITAACs
17 that are provided in those sections and also reviewed
18 the Certified Design information section that is in
19 the Tier 1 2.1. And verified that the attributes,
20 that the features that is necessary in the ITAAC list
21 is appropriately represented.

22 Now we did have about -- I don't know what
23 is the total number of RAIs, but correctly we had nine
24 RAIs which are open, we're getting responses and being
25 resolved. As an example, a number of the times that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we listed two of the RAIs here on the slide and on the
2 number 14 Slide, RAI 386, 14.3.02-45. It really
3 involves verification of features for internal missile
4 barriers. So we requested the applicant that they
5 identify these missile barriers areas including those
6 inside the reactor building because we were not sure
7 whether everything in the reactor building has been
8 looked at.

9 And also the three dimensions, that issue
10 should be there.

11 Now the applicant did provide some
12 information in ITAACs for fire and internal flood
13 protection, but they didn't provide anything for
14 missile barriers. So we still do have that RAI open
15 and we'll be reviewing it.

16 The other issue is the basis for treating
17 U.S. EPR containment structures as a non-prototype
18 during a structural integrity test. When we looked at
19 the RAI they didn't have any requirements for strained
20 measurements, which is normally required for a
21 prototype structure integrity test as per ASME
22 Division 2, I think Article 6,000. When we asked that
23 question to the applicant, applicant indicated that it
24 is non-prototype containment. So we asked that that's
25 good, but we need some information on that non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 prototype for us to compare and make an evaluation
2 that it is okay to be a prototype or non-prototype
3 containment. So those are the kind of things that we
4 have looked at, and this is what is presented.

5 Now, you have any questions, any other
6 issues, you know I'm happy to respond. We have Dr.
7 Foster here and he has looked at it in great detail.

8 MEMBER SKILLMAN: How would you resolve
9 this if the EPR design is prototypical, but the
10 requirement is that you test to a prototype and this
11 is not a prototype, how do you resolve this?

12 MR. CHAKRAVORTY: Well, prototype is the
13 first time that you do it. And they do have to have
14 test data, okay. In other words, they have to have
15 the kind of containment that they have tested before,
16 you know as well as the reinforced concrete, was it a
17 pre-stressed concrete, you know what kind of
18 dimensions it had. And we need to verify those numbers
19 -- you know information for us, you know to determine
20 whether they are were tested properly.

21 And like, we have a 62 psig pressure, you
22 know what pressure it was tested. So we have to have
23 all this information before we could decide that it is
24 a non-prototype containment in U.S. EPR. We don't
25 know. We don't have the information.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MEMBER STETKAR: But have they identify
2 the referenced containment that they're --

3 MR. CHAKRAVORTY: Not yet. We haven't
4 seen it.

5 MEMBER SKILLMAN: Okay.

6 MR. CHAKRAVORTY: But we just asked the
7 question. So we're expecting some information.

8 MEMBER SKILLMAN: Thank you.

9 MR. CHAKRAVORTY: Thank you very much.

10 MR. JAFFE: I'd like to introduce Mr.
11 Daniel Mills from the I&C Branch who will discuss the
12 I&C effort.

13 MR. MILLS: Good morning. I'm Daniel
14 Mills. I work for Terry Jackson in Instrumentation and
15 Controls and Electrical Engineering Branch in DE.

16 I've been with the NRC for about 4½
17 years.

18 I am a recent graduate from the Nuclear
19 Safety Professional Development Program.

20 I graduated from Ohio State University
21 with a Bachelor's degree and a Master's degree in
22 Mechanical Engineering and a Master's degree in
23 Nuclear Engineering with a research focus on
24 instrumentation and control systems.

25 Our review, the staff's review consistent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the Standard Review Plan 14.3.5 Instrumentation
2 and Control ITAAC proceeded in parallel with the
3 review of Chapter 7. So, you may have noted that we
4 have several pointers to sections of Chapter 7 where
5 we have some discussion of evaluation of the ITAACs.

6 I'm going to go ahead and go through the
7 four. I guess a correction to one of the previous
8 slides, we actually have four open items for 14.3.5.9,
9 not five as was shown. And these four as shown on
10 this slide starting with RAI 506 Question 14.3.5.27,
11 this deals with design description and ITAAC
12 verification items dealing with the safety information
13 and control system safety functions.

14 Question 14.3.5.30 deals with ITAAC
15 verification of safety functions of the priority and
16 actuator control system.

17 Question 14.3.5.39 deals with -- there are
18 several systems where ITAAC items verifying single
19 failure protection were not included. And this
20 question requests that the applicant address that.

21 And Question 14.3.5.41 deals with the
22 self-test functionality of the safety automation
23 system.

24 And I'm happy to take any questions if you
25 have them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: I guess, especially in this
2 area, it's not clear to me how one decides when you
3 have to test something after it's installed and when
4 it's adequate to test it as the equipment
5 qualification aspect. How is that decision made?

6 MR. MILLS: Decision made as to whether to
7 include functional testing versus -- meaning initial
8 test program type versus --

9 MEMBER BROWN: Factor acceptance test.

10 MR. MILLS: -- factor acceptance testing?

11 MEMBER BROWN: At least, I think that's
12 what he's referring to --

13 CHAIR POWERS: Yes.

14 MEMBER BROWN: You got a factor acceptance
15 test qualification program and then you have whatever
16 is done subsequent to delivery of that equipment after
17 it's completed its factor acceptance test.

18 CHAIR POWERS: And we've already said the
19 delaying a lot of this because we need the entire
20 integrated systems. So I assume the entire integrated
21 system must have some impact on this. I mean --

22 MEMBER BROWN: Well I try to pull on that
23 a little bit. I think part of it is that the way
24 their integrated system operates its not discrete sets
25 of wires going from each and every thing. There's an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 integrated bus, a distributed bus system that sends
2 information around and you have to have that entire --
3 correct me if I'm wrong. But you have to have that
4 entire integrated bus system set up and tested to see
5 if all the data's getting on it and it's going where
6 it's supposed to go.. Because all you've got is a
7 bunch of boxes and then you've got fiber optic buses
8 and then run -- or transmitting data through all the
9 distributed systems.

10 CHAIR POWERS: I think I understand that,
11 and that's what leads to the question to use --

12 MEMBER BROWN: I'm not disagreeing.

13 CHAIR POWERS: I mean, how good is it?
14 Suppose that the box has been tested up one side and
15 down the other, but if I don't have it pinned to the
16 whole thing, how will I know that it works?

17 MR. MILLS: Well, obviously the idea with
18 this is to get to the same place, to have insurance
19 that the systems are going to function in combination.

20 I'm not sure how to address your question.
21 I think I'd have to give it some --

22 CHAIR POWERS: I don't even know how to
23 pose the question very well, so --

24 MR. MILLS: Let me throw it to Terry.

25 MR. JACKSON: This is Terry Jackson. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chief of the I&C Branch in the review.

2 There's a series of tests and so forth
3 that are performed on the I&C systems and they start
4 off, basically, as a unit test and start off with
5 individual small functions and enter at the factor of
6 negatives all the way up to factor acceptance testing
7 where the whole I&C system is integrated and tested at
8 the factory.

9 Then it's shipped to the site and
10 installed at the site and there's a site acceptance
11 test that's performed when it's performed at the site.

12 So that ensures that it's not going to be the same
13 full scope as to factor acceptance test as we
14 understand, but it will be sufficient tests to verify
15 that the system has been integrated into the plant
16 appropriately. But then there's other tests too that
17 are associated with some of the mechanical systems.
18 Just for example, like I think that's reason why it's
19 taken a little bit longer to get it a response on the
20 questions for these safety information control system
21 and the party actuator control system because a lot of
22 those tests are associated with mechanical systems and
23 so not necessarily specific I&C tests but it's the
24 integrated test with I&C and the mechanical system.

25 CHAIR POWERS: So that the values the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 criterion is interfaced with a mechanical system and
2 then you test -- what I'm trying to understand is
3 there is a fairly comprehensive what we will call at
4 the factory test; where it takes place is not
5 important here. And then there is some more limited
6 testing once it's installed. And what I'm trying to
7 understand is how do I decide what tests not to do
8 once it's installed.

9 MR. JACKSON: Our expectations that the
10 tests, that the integrated tests would test the
11 interface. The interfacing requirements. So, for
12 example the I&C system is going to have system
13 requirements that come down from the plant, mechanical
14 system or nuclear system. And so those requirements
15 should be tested in those integrated tests.

16 There are other more detailed level
17 requirements for the I&C system itself that would
18 probably be tested at the factory but not necessarily
19 at the plant.

20 MEMBER BROWN: Terry, let me ask the
21 question a little bit, slightly differently. If you
22 look at that -- during the I&C presentation which I'll
23 check there was this overall big top level block
24 diagram with PIC, SIC, SETS, MAX; I lost track of the
25 acronyms. There were dozens of little boxes will all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 kinds of little acronyms on them that all fed with
2 arrows going all kinds of places and a couple of big
3 buses where all this --you know, it said all of it
4 goes onto these things and this goes over here, and
5 then this goes up there, and all these back and forth.

6 Is that all for divisions, all PACs, SAX -- the whole
7 main control room setup, is that all -- every
8 component, every box set up at the factory and then
9 integrated all that information and all those
10 communications integrated at the factory or not? Yes
11 or no.

12 MR. JACKSON: I'll let AREVA verify the
13 answer, but our understanding is, yes, it is a full
14 integrated --

15 MEMBER BROWN: So the whole main control
16 room control panel, the bus where all the stuff goes
17 up will be put together at the factory. Every one of
18 these, I'll just pick a couple of these: The safety
19 information control system dotted line area, the
20 priority and actuator control dotted line area, all
21 oaf those things will be put together in every box
22 that's involved? Every box that's involved will be
23 hooked up hooked up in that integrated test at the
24 factory, and I'm waiting for AREVA to shake their head
25 up and down?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TALLY: This is Charley Tally from
2 AREVA.

3 I'm hesitant to answer yes unequivocally.

4 MEMBER BROWN: I bet you are, because I
5 don't believe -- I would not believe it. Now that's
6 not a negative or I'm not trying to cast aspersions.
7 That's a very extensive test.

8 MR. TALLY: Yes.

9 MEMBER BROWN: And that is the basis I
10 think for Dr. Powers' question of how this whole thing
11 -- where do you draw that differentiation. In my
12 mind, rightly or wrongly, there's a set of what I call
13 individual piece part performance requirements.

14 MR. TALLY: No.

15 MEMBER BROWN: In other words you got
16 detectors -- no, at the factory. Well, let me finish.
17 No. You're demonstrating the plant has to demonstrate
18 accuracies, performances, response times for certain
19 pieces so that you meet the overall performance
20 requirements of the analyses and other type things for
21 demonstrating plant performance. Those types of
22 things, I would think, are not going to be done at the
23 site. They would have to be demonstrated at the
24 factory. You've got to show that when I put a range
25 of inputs in from a detector into the system, I get a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 range of outputs that are within some minor
2 uncertainty or accuracy band and you have nice well
3 calibrated instrumentation to prove that.

4 Now, how far you go after that is where it
5 gets mushy and what then has to be done at the site.
6 And I think that's the point, correct me if I'm,
7 Dana, did I kind of --

8 CHAIR POWERS: No, I think you --

9 MEMBER BROWN: -- touch or expand on what
10 you were trying to get to?

11 CHAIR POWERS: I think -- I mean my
12 conundrum is understanding the basis for making that
13 decision. I think you've articulated it much better
14 than I could.

15 MEMBER BROWN: Because the end --

16 CHAIR POWERS: You may even understand the
17 answer better than I do.

18 MEMBER BROWN: That's been one of my
19 concerns with these because my past experience with
20 levels of complexity and this level of integration
21 when we did this, and I can say this without any --
22 violating any confidential type security type issues,
23 is that we took every Vendor's design, brought it into
24 one of the laboratories, every piece of equipment,
25 every detector input for the first unit, you know for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the prototype setup and we integrated it and made sure
2 that all communicated and provided the proper inputs,
3 the range data, all your digital data that went around
4 and everything else, we confirmed. And we actually
5 even hooked up a complete plant simulator where you
6 could actually control it as if you have an operator
7 in the place and made sure the same response, you
8 could run all your procedures and everything else.
9 They're not going to do that at the factory. I could
10 bet the ranch that they're not going to do that.

11 MR. TALLY: We'll take an action item to
12 clarify what's in acceptance testing.

13 MEMBER BROWN: The way we could get
14 through this is to have you guys say how do you
15 envision this and separate qualifications, factory
16 acceptance tests and what is the level of overall
17 integration tests that are performed and how are they
18 defined in the ITAAC? Because it's not obvious in
19 looking at the ITAAC in how that's done.

20 MR. TALLY: Yes. I would just comment
21 that the check out of the OL3 I&C system --

22 MEMBER BROWN: I have no -- OL3 is the
23 Finnish?

24 MR. TALLY: Yes.

25 MEMBER BROWN: Okay. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TALLY: That setup is just as you have
2 described in regard to a complete plant simulator
3 that's been --

4 MEMBER BROWN: At the factory?

5 MR. TALLY: --put together -- that is
6 interfaced with all of the actual cabinetry. And I
7 believe it is a extremely comprehensive integrated
8 test.

9 MEMBER BROWN: But it's the same as this
10 one.

11 MR. TALLY: We'll take an action item to--

12 MEMBER BROWN: But it's not the same as
13 this one. Your design is not the same totally as that
14 one is.

15 MR. STACK: So, again, we will take the
16 action look at the scope of the factory acceptance
17 test and the scope of the on-site testing.

18 MEMBER BROWN: Okay. A good question,
19 Dana. Thank you. It'll be interesting to hear the
20 answer.

21 CHAIR POWERS: I'm as much interested in
22 the philosophy behind as I am the specifics. In fact,
23 the specifics only make it so I can understand the
24 philosophy.

25 MEMBER BROWN: Well, there's another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 aspect of this, is that because we separated the
2 design part of this and because of the level of
3 integration, is how does the NRC ensure that their
4 inspectors win their own site and they are doing
5 whatever integrated tests they do; how do they make
6 judgments? I mean, it's a decision we've had before
7 at the level --

8 CHAIR POWERS: Yes. I have to admit that I
9 put great big stars and circled on my notes when the
10 terms "inspectability" came up in the presentation by
11 the staff.

12 MEMBER BROWN: Yes.

13 CHAIR POWERS: Because I think that is
14 going to be one of the crucial things to understand
15 about this plant. Because, I mean quite frankly it is
16 a unique plant and it is -- there are lots of things
17 in this plant. When you have trains there are lots of
18 things. And so inspection and monitoring becomes a
19 challenge. And it strikes, as much as I hate to admit
20 it, one of the great virtues of PRA is that it tells
21 us what things work at.

22 MEMBER STETKAR: Can you make sure we get
23 this transcript embossed in gold? I want it on my
24 wall.

25 CHAIR POWERS: I have said this before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that the bottom line. coordinated frequency is easily
2 one of the most useless numbers that I can think of.
3 Risk achievement worth, risk reduction worth, Fussell-
4 Vesely is an incredibly useful things.

5 MEMBER STETKAR: I'm not arguing with you
6 on that statement.

7 MEMBER RYAN: I still take it with a grain
8 of salt.

9 MEMBER STETKAR: I still want the --

10 CHAIR POWERS: Some day we're going to
11 solve that. I trust a guy with a lot of experience
12 with the PRA.

13 MR. JAFFE: That completes the staff
14 presentation.

15 CHAIR POWERS: My goodness.

16 MR. JAFFE: Thank you.

17 CHAIR POWERS: Thank you.

18 MR. TESFAYE: Dr. Powers, this gives us a
19 segue to go to that hardware watchdog thing the IRA
20 created --

21 CHAIR POWERS: Fantastic. Let's do it.
22 The digital I&C guys are off to -- and speaking
23 therefore in the unknown tongue.

24 MEMBER BROWN: But I would suspect he
25 didn't know what tongue I was speaking. Don't take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that the wrong way.

2 CHAIR POWERS: Don't feel bad about it,
3 Terry. I haven't understood him in all the years he's
4 been on the Committee.

5 MR. TESFAYE: Dr. Powers, as I suggested
6 earlier, what we're going to do with this is issue an
7 RAI. It's going to be tracked as an open item and
8 we'll be closing Phase IV and we'll describe the
9 content of what the RAI is.

10 MEMBER BROWN: We may have thrown a little
11 bit of extra stuff here to cover in the RAI as well.

12 CHAIR POWERS: Yes. The general philosophy
13 of moving this into Phase IV I have absolutely no
14 trouble with it. Does anybody else have any objection
15 to doing this? No, I think that's perfectly fair.
16 Philosophically I have no objection to that.

17 MR. TESFAYE: Thank you.

18 MR. JAFFE: I mean, I don't detect any
19 objection. It doesn't really matter whether I have an
20 objection, but I don't think the ACRS has a whole has
21 any objection to moving this into Phase IV for
22 resolution.

23 MR. TESFAYE: We do have some Phase IV
24 RAIs.

25 CHAIR POWERS: Name a few --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TESHAYE: Fukushima issue, for example
2 will be a Phase IV activity, so this fits in right in
3 there.

4 CHAIR POWERS: Yes. absolutely.

5 MR. TESHAYE: So, let's go ahead.

6 CHAIR POWERS: Sure. Welcome back.

7 MR. JACKSON: Again, Terry Jackson, I'm
8 the Chief of the I&C Branch and Office of New
9 Reactors. I've been doing that job for about four
10 years now, and before then it was resident, Senior
11 Resident at Diablo Canyon. And before that Research,
12 I&C Engineer here at the NRC. And before that I got a
13 Bachelor's in Computer Engineering, Master's in
14 Electrical Engineering.

15 We reported specific questions from
16 Charlie, and this was in regards to the watchdog
17 timer. And since the AREVA design, specifically the
18 actuation logic unit or call it ALU becomes the
19 building logic for reactor trip and ESF actuation.
20 The question came is if these micro processor systems,
21 if they receive corrupt data from say one division it
22 gets transferred to all divisions and it could lock up
23 the voting processors, what kind of mechanism is there
24 to be able to ensure reactor trip?

25 So, the staff had, of course from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience with AP1000 had already looked at that in
2 the EPR design, and we addressed it. But I think the
3 issue was is that the description between the FSAR and
4 then the technical reports, because it's in about four
5 different documents, the description, the design and
6 then in some cases there are some terminology that's
7 different between their documents as well. So Charlie
8 asked if there was a way that we could get
9 clarification to this.

10 So basically what the staff -- the
11 information that we gave is basically the information
12 that we have addressed. So what we plan on doing is
13 issuing a Phase IV RAI to AREVA, and it's basically
14 asking for a description, a better description that's
15 concise in one location and describes how the watchdog
16 timer, which is the device used to trip -- to perform
17 the reactor trip if the processors locked up; to give
18 a better description of how that operation actually
19 occurs as a watchdog timer interface with other
20 processor aspects, including software, hardware. And
21 so that it's more clear as to how the watchdog timer
22 actually perform if the processors were to lock up.

23 So, I didn't have a chance to talk to
24 Charlie about the draft question. I wrote it up and
25 stuff, but I hope I captured his question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, to the more
2 integrated as opposed to a piecemeal, because right
3 now it's kind of scattered around. It took me a day
4 and a half just getting all the various parts from the
5 various people together to try to look to see if it
6 made any sense. And there was some ambiguities and
7 some things that weren't clear of how the interrupts
8 and/or "hardware or hardwired signals" were actually
9 in between first and second timeouts, how those worked
10 together and things like that. So just a more
11 integrated look at how that whole operation is
12 performed.

13 And that was the thrust of my questions
14 for you.

15 MR. JACKSON: So that's basically what our
16 plan was to address that particular issue, was to
17 address it in our Phase IV review.

18 MEMBER BROWN: Yes. Related to Dr.
19 Powers' question a little while ago, I remember from
20 one of the previous projects that reviewed where the
21 system wasn't quite as integrated, distributed as this
22 one is. There were, I hate to use this word, DAC
23 which actually said you actually go do such-and-such
24 and then you demonstrate the acceptance criteria was
25 this happened or that happened. And within the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 context of this project, there are none, which I'm
2 happy with. There's not DAC for this. But yet the
3 question arises how do we make sure once we get all
4 these things hooked up in the plant at the site that
5 in fact some of these functions that we rely on to
6 ensure that we've got a fully independent state
7 system, how do they actually work on an integrated
8 basis? And do we get a trip when we expect it to?

9 MR. JACKSON: Right.

10 MEMBER BROWN: And that's an aspect of
11 this that I would think would be --

12 MR. JACKSON: I can talk a little bit
13 about what we plan on doing. Well, specifically with
14 the EPR design I think and some of the earlier designs
15 where DAC was used, when we did the EPR review I think
16 the desire both for the NRC and for the applicant was
17 to avoid DAC if we could. So --

18 MEMBER BROWN: I'm not asking for DAC.
19 I'm just looking for --mostly put in and installed in
20 the site that there's a test -- part of the test
21 program demonstrates with all the various aspects when
22 you have a trip, you're going to get an overpower, you
23 got pressure, you got temperatures; whatever the
24 protection functions are that have to operate, you
25 ought to demonstrate that you actually generate a trip

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 because of the distributed nature and the overall
2 integrated nature. You want to make sure everything's
3 hooked up and the data is where it is.

4 And I'm remembering once circumstances the
5 last thing I heard this thing, this similar system
6 being hooked up at a particular plant, they ended up
7 getting to some power level before they found they did
8 not have any indication from some critical protection
9 function, or they had the wires hooked up wrong, which
10 is -- and you know it raised the real question is what
11 the quality of the inspection process on the actual
12 installation drums.

13 MEMBER STETKAR: Charlie, let me ask you.

14 I hate to get into these discussions in these
15 meetings. But it's probably worthwhile given the
16 timing here.

17 You repeatedly mention your concerns, and
18 the reason I bring it up is it may influence the way
19 the RAIs were in the context of tripping the reactor,
20 which is an important function certainly, but it's
21 only one of the functions of this distributed
22 safeguards actuation system.

23 Another function is, indeed, actuating
24 safeguards. Things like starting injection 00

25 MEMBER BROWN: I've meant to encompass

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that in --

2 MEMBER STETKAR: Okay. Be careful when you
3 use "trip," because that tends to get translated into
4 the reactor --

5 MEMBER BROWN: The reactor --

6 MEMBER STETKAR: Shutdown the reactor,
7 insert the control rods which may be easier to
8 demonstrate because --

9 MEMBER BROWN: No, I appreciate that.

10 MEMBER STETKAR: than the safeguards
11 actuation function --

12 MEMBER BROWN: Yes, I appreciate that.

13 MEMBER STETKAR: -- which is energized to
14 actuate kind of different --

15 MEMBER BROWN: Exactly right.

16 MR. JACKSON: I think maybe to address the
17 issue about reactor trip and ESF if a processor, say a
18 single processor fails, then the watchdog timer is
19 there to put it into the safe state. So for a reactor
20 trip, the safe state is to send the reactor trip
21 signal.

22 For ESF it's to fail as is, so it won't
23 actuate --

24 MEMBER STETKAR: We know that.

25 MR. JACKSON: -- it won't actuate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It won't actuate.

2 MR. JACKSON: Right. Now the other part
3 about the design is that the design has a diverse
4 actuation system as well. So --

5 MEMBER BROWN: That still doesn't say you
6 shouldn't test the primary actuation systems --

7 MR. JACKSON: Right.

8 MEMBER BROWN: -- that it performs all of
9 its functions.

10 MR. JACKSON: Right.

11 MEMBER BROWN: And you can demonstrate in
12 your test program that they all respond when they're
13 being asked for it.

14 MR. JACKSON: Right. And that wasn't an
15 answer to your first question. It was more I think
16 responding to --

17 MEMBER STETKAR: Because I understand
18 certainly how the system works. But I wanted to
19 forestall any ambiguity in terms of terminology --

20 MEMBER BROWN: Well, I agree with you.

21 MEMBER STETKAR: -- when we come back, you
22 issue the RAI, there's an answer and it's all focused
23 on control rods.

24 MEMBER BROWN: Yes. That's not my intent.

25 MEMBER STETKAR: And my intent was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 forestall any questions about the other functions.

2 MEMBER BROWN: The intent was to ensure
3 all safety functions demonstrate that they will,
4 whether they're ESF or whether they're reactor trip,
5 that they all perform their function and actuate the
6 devices when they are called upon based on a simulated
7 or some type of signal during the pre-operational test
8 program.

9 MR. JACKSON: So in response to Charles'
10 question, the staff does have guidance in the area to
11 perform a site acceptance test. So that -- and the
12 intent of the site acceptance test is to verify:

13 (1) That the system is connected properly so
14 you don't have a situations like we had at the Des
15 Moines site.

16 MEMBER BROWN: Yes.

17 MR. JACKSON: The other purpose of the
18 site acceptance site is that when you're doing the
19 design, the I&C design is well known over here, you
20 know in a particular silo, but eventually you've got
21 to integrate them. So that the integrated test and
22 site acceptance test is to verify that the assumptions
23 that you had in your design with how the mechanical
24 systems are going to interface with it are in fact
25 true. So that's where, you know if you're doing the,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say, reactor trip test it's actually singleway and
2 single from the sensor through to the reactor trip
3 mechanism itself and the rods drop. So that's the
4 kind of test that we would expect at the site as well
5 as like ESF tests that you test from, you get the
6 single light signal from the sensor itself but it goes
7 through the I&C system and actually starts the pumps,
8 moves valves and things like that. So, that's the
9 staff's expectations for doing these types of site
10 acceptance test and the --

11 MEMBER BROWN: But the COL has to develop
12 those tests, isn't that correct?

13 MR. JACKSON: Right, right

14 MEMBER BROWN: I'm trying to remember. At
15 this time those aren't specified, if I remember in the
16 ITAAC. That's an overall thing that's done as part of
17 the COL, I would have imagined. I don't know that for
18 sure. I just don't remember.

19 MR. JACKSON: I don't have the actual
20 ITAAC with me, but some ITAAC --

21 MEMBER BROWN: If you can point them out
22 to us, that would be useful. I just know that
23 somebody's got to do something.

24 MR. JACKSON: What I wanted to say is part
25 of one of them in EPR that's installation has. So I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not exactly sure of the wording because I don't have
2 the ITAAC in front of me, but that's the intent.

3 MEMBER BROWN: Okay. Well, the purpose of
4 my comments was to amplify to make sure that we
5 covered something and you've had a better
6 understanding of my somewhat cryptic. I've tried to
7 make it a page, it turned out to be four pages or five
8 by the time I wrote it up. But at least I've tried to
9 provide the background so you knew what the stuff I
10 referred to.

11 MR. JACKSON: Yes. And I think we
12 understand where the question was coming from with
13 regards to --

14 MEMBER BROWN: Okay. Thank you.

15 And thank you, John, for making sure --

16 MR. TESHAYE: Thank you, Terry.

17 Dr. Powers, I have one more item to close
18 if I may.

19 CHAIR POWERS: Yes.

20 MR. TESHAYE: Yesterday I took action to
21 Dr. Skillman's question on the drainage in the spent
22 fuel storage facility.

23 CHAIR POWERS: Yes.

24 MR. TESHAYE: We had requested this in RAI
25 9.1.4-18. We asked AREVA what it was leaking from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spent fuel storage process -- where it goes. And they
2 told us it goes into the nuclear island drain and vent
3 system. Now they didn't tell us what the capacity of
4 this drain system is. But in Section 9.3.3 it says
5 "the floor drains in the nuclear island drain system
6 has the capacity to have committed the maximum
7 expected flow rate from a rupture of the largest water
8 pipe in the nuclear fuel storage facility. The flow
9 drain systems are gravity fed to building sump because
10 there are no drain connection on the plane header high
11 in the elevation than the NFSF flow drains, but flow
12 is prevented.

13 Now the only question I have on this is we
14 don't if this largest pipe bounds the water that could
15 potentially be coming out of the flow. So we have an
16 existing RAI similar to that, and I'm trying to get an
17 answer as part of that RAI question.

18 MEMBER SKILLMAN: Getachew, I appreciate
19 that. I looked at the RAIs also and did not see one
20 that would address the concern I had about the leakage
21 from a, if you will, a failure of that seal.

22 MR. TESFAYE: Yes.

23 MEMBER SKILLMAN: So I'll ask you to
24 persevere and just get an answer to this question.

25 MR. TESFAYE: Yes. Absolutely.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: The floor drains might
2 be mighty fine for 40, 50, 120 gallons per minute.
3 But if we were to get a 400 or 500, 800 gallon a
4 minute leak, my hunch is that we would have water
5 standing on the floor.

6 MR. TESHAYE: We'll submit a supplemental
7 RAI to get that particular question answered.

8 MEMBER SKILLMAN: Thank you, Cetachew.

9 MR. TESHAYE: Yes. Thank you.

10 CHAIR POWERS: We have -- I guess we're
11 done with these three chapters, right?

12 MR. TESHAYE: Yes.

13 CHAIR POWERS: And our intention is to
14 move them to the full Committee in May right now, is
15 that correct?

16 MR. TESHAYE: Yes.

17 CHAIR POWERS: Okay. So we'll have a
18 presentation for the full Committee in March? In
19 April we'll get presentation from the COLA. And so now
20 we want to do something in May.

21 I think from my perspective the advice I
22 can give you, the difficulty is that that gives us a
23 very short period of time relative to the volume of
24 material. I suspect they will give us two hours.

25 MS. WEAVER: But you want an additional 45

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minutes?

2 CHAIR POWERS: And I want an additional 45
3 minutes on a specific topic, but that's --

4 MR. TESFAYE: Not for the March one.
5 You're talking about the May ==-

6 CHAIR POWERS: May, yes.

7 But, I mean, two hours sounds like
8 forever, but it's not to cover this material.
9 Especially because many of the members are going to be
10 less than current on what the APR design is. There's
11 an obligation from the -- of the design, and that
12 falls on the applicant to do that, I think. And so
13 you have to be relatively terse in this material.

14 What I can say is that you can be
15 especially terse on the spent fuel pool if we indeed
16 get the 45 minutes to discuss that because they'll be
17 able to cover a lot of things there.

18 I suspect there will be a lot of interest
19 in the ITAAC and like that, just because there always
20 is. And I would think I speak very much
21 philosophically about it. I mean, you have to kind of
22 outline your general approach, but I would speak much
23 more philosophically there. And certainly want to
24 acquaint them of the limited use you're making of DAC.

25 Sadly, it's one of the -- particularly interested in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 how you use DAC.

2 For the staff presentation I would
3 generally recommend not emphasizing the number of OIs
4 you had at the beginning and now how many you have
5 remaining, I would emphasize what you have remaining.

6 And again, I would always emphasize where
7 you have done independent analysis. Where you can
8 speak to the issues of what you've forecast or what
9 you're thinking about on Fukushima related outcomes is
10 always useful. You may not be able to do anything
11 there, but if things we're forecasting or concerned
12 about, you might want to share that with the ACRS just
13 to get some feedback from them. Whether you're doing
14 anything with it or not, what you're thinking about
15 and with respect to other plants of EPR design around
16 the world that are being done, it's also useful. You
17 know, what you know and what you think about and what
18 you think you can derive from that; that's always kind
19 of useful for them to know what you're doing in that
20 area. But again, it's such a terse period of time.
21 You're not going to be able to go plunging into a lot
22 of detail. You're going to be very synoptic.

23 And we'll try -- the ACRS Chairman and I
24 will both try to emphasize that what we're doing is
25 moving a set of chapters from Phase III to Phase IV

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 here. And so this is an interim view that's being
2 taken and not a final word. That will give you a
3 little bit of freedom to say however there's more on
4 this and stay tuned.

5 MEMBER STETKAR: Could I float something?

6 CHAIR POWERS: Absolutely.

7 MEMBER STETKAR: Think about Chapter 3.
8 There's, obviously, a heck of a lot of stuff in
9 Chapter 3 and knowing things that the Committee has
10 expressed an interest in the past, it's they're
11 interested in what's different about this plant, which
12 is why Dana highlighted the cast issue.

13 I think that it would be useful to make
14 sure that the full Committee members understand the
15 scope and what you've done in terms of the certified
16 structures; the nuclear island, the diesel buildings
17 and their cooling water buildings versus the remaining
18 structures on the site and how you address potential
19 interactions either from seismic loading. You know,
20 we got into this wind loading thing, and things like
21 that. So that the Committee understands sort of what
22 is in the Certified Design, what's immediately
23 adjacent to the Certified Design and how you try to
24 address those structural notions. I think that might
25 be worthwhile, you know in terms of things to focus

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on.

2 Dana, does that --

3 CHAIR POWERS: Yes. I think it's always
4 absolutely true that the Committee as a whole is going
5 to be most interested in those things that are
6 different, unique, innovative and --

7 MEMBER STETKAR: I mean, there isn't
8 anything innovative there, it's just an understanding
9 of the Committee to get their hands on what level of
10 analysis and what level of qualifications has been
11 done for what issues at that level of the structures.

12 CHAIR POWERS: I'll ask the Committee if
13 they can provide any advice? This is a very difficult
14 chore for both the staff and the applicant because
15 it's an interim piece, it's part of the whole, it's
16 necessarily somewhat out of context, and it's a very
17 crunch period of time. So any advice we can give them
18 to kind of help them through this and at the same --
19 and the other challenge that we face is it's very easy
20 to make a kind of a crunch presentation to get the
21 ACRS Members that have not been day-to-day involved in
22 this confused or misled and things like that.

23 So, I'll ask the other Members, do you
24 have any advice to pass on?

25 MEMBER ARMIJO: Well, in the testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 program, you know it's a mind-boggling list of tests.

2 CHAIR POWERS: Yes.

3 MEMBER ARMIJO: And, you know I think in
4 terms of graphic representation, here's the plants,
5 here's the other tests, here are a couple of areas
6 that we'd like to focus on and describe our approach.
7 That would help I think a lot.

8 CHAIR POWERS: Yes. I think the philosophy
9 of the approach, and like you say anything that's
10 graphical --

11 MEMBER ARMIJO: Makes it a lot easier
12 than--

13 CHAIR POWERS: -- makes it a lot more
14 comprehensible. Because they're not interested at
15 this stage in the specifics. They're interested in the
16 generalities.

17 MEMBER SKILLMAN: Yes. I think information
18 that explains and defends how fuel is brought into the
19 plant and how spent fuel is discharged from the plant
20 through a hole in the floor, why that's acceptable--

21 CHAIR POWERS: Well, what I'm going to try
22 to get out of P&P is more of an information briefing
23 specifically on that system.

24 MEMBER SKILLMAN: On that system.

25 CHAIR POWERS: Because it's unique and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because they already have photographic -- I mean, I
2 don't think they have to work to put that presentation
3 together, I think they already have it. And that they
4 can present as a whole and probably deal with that
5 treat it somewhat cursorily in their actual --

6 MEMBER STETKAR: The more graphics -- you
7 know, as I understand we had a little bit of
8 discussion yesterday, some of the stuff -- I don't
9 know where you cross the line into proprietary
10 photographs of systems that are already installed over
11 in France. But the more photographs of actual
12 installations to give the Members a feel of size,
13 geometry, you know notion of how the thing actually
14 works along the stages of the processes, an scales of
15 things. You know, we talked about that little graphic
16 about the fact that the bellows probably aren't --
17 they might not even be this big in the real world,
18 would help an awful lot.

19 I recognize our meetings are fully open so
20 you need that trademark, but --

21 CHAIR POWERS: Similar for the staff they
22 had wonderful presentations where they had a couple of
23 plots that said okay here's what we independently
24 calculated and this was your big points. So to the
25 extent you have that, do that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And it also communicates to the ACRS what
2 the staff thinks a critical issue is. If they've done
3 an independent analysis, then obviously they think
4 that's fairly important to -- a completely independent
5 analysis.

6 Quite frankly, these charts that you put
7 up that said okay, well going in we had 650 open items
8 and now we're down to 12 don't help the ACRS very
9 much. Where you can say we have 13 open items, here
10 are the two that we think are really important, that
11 helps a lot.

12 MR. TESFAYE: That's what we did to the
13 first Committee meeting. And that's what I plan to
14 do.

15 CHAIR POWERS: Yes. Come in and say look
16 I've got 12 open items here, five of them are
17 formalities, I'm not going to go into them. Here are
18 two that I think we're going to pay a lot of attention
19 to.

20 Similarly, here we've got an open item on
21 watchdog timers. Here's the problem. We're going to
22 resolve that in Phase IV. And it'll all be
23 straightened out, but here's conceptually what the
24 issue is, here's what we're doing about it.

25 MEMBER BROWN: Well we're not doing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 watchdog timers in May.

2 CHAIR POWERS: It's actually being done in
3 March.

4 MEMBER BROWN: Yes, because Chapter 7 is
5 being done in March.

6 CHAIR POWERS: March.

7 MEMBER BROWN: And that'll be just the two
8 hours. So I was trying to separate. When you threw
9 that one in, that kind of threw me for a loop here.

10 CHAIR POWERS: Very easy to throw for a
11 loop.

12 MEMBER BROWN: Yes.

13 CHAIR POWERS: I used it as an example.

14 MEMBER BROWN: Yes. Yes.

15 MEMBER STETKAR: Dana, in that sense one
16 thing also kind of -- you guys have some experience
17 presenting to the full Committee. Less emphasizes on
18 we met this paragraph of Reg. Guide 1.2.3.4 standard
19 and .7 versus technical issue and how it's being
20 addressed; the latter is better.

21 CHAIR POWERS: Yes. Yes.

22 Okay. Any other? Steve, do you have any?

23 MEMBER SCHULTZ: Well, I would just
24 emphasize what you had said, perhaps in order of
25 importance for the applicant as well as the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The focus for the full Committee being the discussion
2 of where the U.S. EPR stands in relationship to the
3 EPR fleet and information that is going to be derived
4 from what is being constructed and delivered. I would
5 expect the applicant would take the lead there, but if
6 the staff can also address that issue, that would be
7 important.

8 And I would expect the staff to be taking
9 a lead with respect to Fukushima items that will have
10 been further developed by the time May rolls around.
11 It will be very high on the list of questions that the
12 full Committee may have.

13 CHAIR POWERS: You can almost count
14 they're going to ask you a Fukushima question.

15 MR. TESFAYE: We'll be ready.

16 CHAIR POWERS: What did you say?

17 MR. TESFAYE: We'll be ready.

18 CHAIR POWERS: Okay, yes. And the answer
19 may be we haven't done anything on this yet. But you
20 can anticipate the questions are going to come down.

21 You can anticipate in the spent fuel pool
22 to get questions on instrumentation.

23 Other than that, I can't --

24 MEMBER RYAN: Nothing else, the spent fuel
25 pool and the fuel handling I think are the two issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: Yes. And I really think
2 it'll be quite useful to before we go into the actual
3 chapters to give what amounts to an information
4 briefing on the spent fuel handlings.

5 MEMBER STETKAR: I'd almost do it after in
6 terms of scheduling because I would suspect that we
7 could eat up, unless you're really vigorous in terms
8 of cutting them off at 2:45, we could spend easily an
9 hour and a half talking about that interesting system.
10 That's a matter of how you orchestrate the thing.

11 MS. WEAVER: Would you want to split it
12 up? Do chapter review of the two hours and then have
13 an information briefing?

14 CHAIR POWERS: I want to do the
15 information briefing first.

16 MS. WEAVER: Okay.

17 CHAIR POWERS: And I have been running
18 ACRS meetings for 18 years. I suspect I can follow the
19 schedule. I have a vague sense that maybe I know how
20 to do that. Yes, I think it's fairly finite, and we
21 did it in about 45 minutes with us for which you
22 actually presented as opposed to us going off on
23 tangents and things like that. And I think it's
24 doable since it's an information briefing and not
25 something that we're going to --don't you, Sam?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yes, I think it's needed.
2 I think it's needed for people who haven't been to all
3 your Subcommittee meetings.

4 CHAIR POWERS: And you weren't here, but
5 it's a very unique -- it is a unique system. And
6 somewhat counterintuitive.

7 MEMBER SKILLMAN: And if the staff and
8 AREVA have some one liners that address, one might
9 say, the obvious failure issues, but I could say
10 here's how we address that and here's how we address
11 that, I think that it will go quite smoothly.

12 CHAIR POWERS: Well, I think the failure
13 issues and things like that I would tend to move that
14 into the chapter discussions and be more here's what
15 it looks like, here's what it's doing, here's why we
16 like it, here's the experience in other countries with
17 it. You know, really an information briefing sort of
18 thing. And then they'll give the regulatory aspects
19 of it during the chapters itself.

20 MEMBER ARMIJO: Yes.

21 CHAIR POWERS: Okay. As always, I'm
22 available if you have questions on how to help you put
23 together the presentations and whatnot. And similarly,
24 if you need help from me to try to avoid rough spots,
25 let me know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And as with all the Members, they're here
2 to offer their advice. It is exactly worth exactly
3 what you pay for it.

4 Anything else?

5 MS. WEAVER: Just I'll go over the
6 chapters, so long as we're all on the same page that's
7 going to be in March. That's Chapter 6, 7, portions of
8 Chapter 6, all of Chapter 7, all of Chapter 11, all
9 of Chapter 13, portions of Chapter 15. No GSI-191.
10 All of Chapter 16 and all of Chapter 18, which is
11 Human Factors. Okay. If you have any questions, you
12 can give me a call.

13 CHAIR POWERS: That's a lot. Okay.

14 Again, they won't give us more than two
15 hours for the combined presentation.

16 MS. WEAVER: So that's what you're on the
17 schedule for.

18 CHAIR POWERS: And I mean, they'll never
19 give us more than two hours. But again, we'll try to
20 do a preface that says our objective here is more of a
21 progress report than it is anything final. We're just
22 moving from Phase III to Phase IV and we're reporting
23 on status here.

24 Unavoidably, the applicant is going to
25 have to remind them of what the plant looks like. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean, it just takes out of your time, but you still
2 got to do it. And consequently you have to be much
3 more summary and everything else.

4 Then with the staff it's very useful to
5 know where you stand, where you think you're going and
6 where you've done independent analyses to substantiate
7 your findings. It's just very useful.

8 Okay. No other point?

9 Gentlemen, I thank you all very much for a
10 very interesting set of meetings.

11 MR. TESFAYE: Thank you.

12 CHAIR POWERS: I kind of somewhat dreaded
13 coming here for these meetings. My eyes rolled at
14 Chapter 3. I thoroughly enjoyed the Chapter 4
15 presentations. Loved the stuff on the spent fuel.
16 Even enjoyed the ITAAC presentations.

17 I thank you all for what you've done. I
18 congratulate you on all your hard work.

19 And emphasize again the only way this
20 works is because you guys is putting in a quality
21 product, even though they're piecemeal, they're
22 quality products and the work behind it shows. I know
23 you're doing it, the applicant especially is doing it,
24 belabored by having Sloan on your case all the time,
25 even though she doesn't show up. And I know that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 held you back some, but you've done well. And the
2 staff has really done a bang up job.

3 And we are adjourned.

4 (Whereupon, at 10:50 a.m. the Subcommittee
5 meeting was adjourned.)

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



**Presentation to ACRS
U.S. EPR Subcommittee
Design Certification
Application
FSAR Tier 2 Chapter 3**

February 21, 2012



Chapter 3 ACRS Meeting Outline

| Section | Presenter |
|---------------------------------------------------------------------------------------------------|------------------|
| 3.1 Compliance with Nuclear Regulatory Commission General Design Criteria. | D. Gardner |
| 3.2 Classification of Structures, Systems, and Components | D. Newton |
| 3.3 Wind and Tornado Loadings | T. Oswald |
| 3.4 Water Level (Flood) Design | T. Oswald |
| 3.5 Missile Protection | T. Oswald |
| 3.7 Seismic Design | T. Oswald |
| 3.8 Design of Category I Structures | T. Oswald |
| 3.6 Protection Against Dynamic Effects Associated with Postulated Rupture of Piping | C. McGaughy |
| 3.9 Mechanical Systems and Components Piping | C. McGaughy |
| 3.12 ASME Code Class 1, 2, and 3 Piping Systems, Piping Components, and their Associated Supports | C. McGaughy |

Chapter 3 ACRS Meeting Outline

| Section | Presenter |
|-------------------------------------------------------------------------------|-------------|
| 3.13 Threaded Fasteners (ASME Code Class 1, 2, and 3) | C. McGaughy |
| 3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment | N. Burstein |
| 3.11 Environmental Qualification of Mechanical and Electrical Equipment | N. Burstein |

Section 3.1 - Compliance with Nuclear Regulatory Commission General Design Criteria



- ▶ U.S. EPR conforms to the GDC in 10 CFR 50, Appendix A
- ▶ Section 3.1 provides a comparison of the U.S. EPR design to the NRC GDC and refers to specific FSAR sections for further discussion of the criteria
- ▶ The COL applicant will identify the site-specific QA Program Plan that demonstrates compliance with GDC 1



Section 3.2 - Classification of Structures, Systems, and Components

Dennis Newton



Section 3.2 - Classification of Structures, Systems, and Components

▶ The U.S. EPR safety classification methodology uses the following designations:

◆ Safety-Related (S)

- SSCs that meet the definition of safety-related in 10 CFR 50.2

◆ Supplemented Grade (NS-AQ)

- SSCs that do not meet the safety-related definition in 10 CFR 50.2, but have a licensing requirement or commitment based on an NRC regulation or guidance. For example:
 - RCP oil collection tanks - addressed in RG 1.189 “Fire Protection Program for Nuclear Power Plants”
 - Station blackout diesel generators - addressed in RG 1.155 “Station Blackout”
 - Liquid waste storage tanks - addressed in RG 1.143 “Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed In Light-water-cooled Nuclear Power Plants”

◆ Non-safety-related (NS)

- SSCs that do not meet safety related definition in 10 CFR 50.2 and have no licensing requirement or commitment (e.g., main feed water heater)

Section 3.2 - Classification of Structures, Systems, and Components

▶ Section 3.2.1 - Seismic Classifications

- ◆ Based on RG 1.29, RG 1.143, and SRP 3.2.1
- ◆ Seismic Category I: (I)
 - SSC remains functional during and following an SSE
 - Safety-related SSCs
- ◆ Seismic Category II: (II)
 - SSCs whose failure could degrade performance of Seismic Category I SSC during or following an SSE
 - Could cause incapacitating injury to main control room occupant during or following an SSE
- ◆ Radwaste Seismic (RS)
 - Radioactive waste management SSCs that are classified as RW-IIa (high hazard) per RG 1.143 (designed to 1/2 SSE)
- ◆ Conventional Seismic (CS)
 - Commercial codes apply seismic design criteria
 - Radioactive waste management SSCs that are classified as RW-IIb (hazardous) and RW-IIc per RG 1.143
- ◆ Non-Seismic (NSC)
 - SSCs that are not subject to any seismic design criteria

Section 3.2 - Classification of Structures, Systems, and Components

▶ Section 3.2.2 - Quality Group Classifications

- ◆ Based on RG 1.26 and SRP 3.2.2
- ◆ Applies to pressure-retaining components
 - Includes components and supports such as pressure vessels, heat exchanges, pumps, piping and valves
 - Excludes structures, electrical components and instrumentation
- ◆ Quality Group A
 - Components of reactor coolant pressure boundary and their supports (e.g., reactor pressure vessel and pressurizer)
- ◆ Quality Group B
 - Components and their supports (including core support structures) as identified in RG 1.26 and SRP Section 3.2.2, Table A-1 (e.g., medium head safety injection pump)
- ◆ Quality Group C
 - Components and their supports not included in Quality Groups A and B as identified in RG 1.26 and SRP Section 3.2.2, Table A-1 (e.g., component cooling water pump)
- ◆ Quality Group D
 - Non safety-related pressure-retaining portions and supports for other systems that contain or may contain radioactive material (e.g., spent fuel coolant purification system filter)
 - Supplemented grade components and their supports (e.g., RCP oil collection tank)
- ◆ Quality Group E
 - Components and their supports that do not meet the definition of Quality Groups A through D (e.g., condensate system isolation valve)

Section 3.2 - Classification of Structures, Systems, and Components

- ▶ Safety, seismic, and quality group classifications are shown in U.S. FSAR Tier 2, Table 3.2.2-1
- ▶ A COL applicant will identify site-specific SSC


Sections 3.3, 3.4, 3.5, 3.7. and 3.8

Todd Oswald



Chapter 3

U.S. EPR Structures



Section 3.3 – Wind and Tornado Loadings

- ▶ Section 3.3 describes the basis used in the U.S. EPR design for wind and tornado loading
- ▶ Basic Wind Design
 - ◆ ASCE/SEI Standard 7-05, “Minimum Design Loads for Buildings and Other Structures”
 - Basic Wind Speed 145 mph in open terrain (includes hurricane)
 - Exposure Category C
 - Importance factor 1.15
 - ◆ ASCE paper 3269, “Wind Forces on Structures”
 - External pressure coefficients for distribution of wind pressures on round structures
- ▶ Tornado Wind Design
 - ◆ Seismic Category I and II structures are designed to resist tornado loadings per R.G. 1.76
 - ◆ Radwaste Seismic Structures are designed to resist tornado wind loadings per R.G. 1.143
 - ◆ Tornado Wind Parameters (R.G. 1.76, Region 1)
 - Tornado Wind Speed- 230 mph wind (184 mph rotational, 46 mph translational)
 - Radius of maximum rotational speed -150 ft.
- ▶ COL information items are identified for applicants to reconcile wind and tornado parameters and ensure wind and tornado loads will not affect the ability of any structure to perform its intended safety function

Section 3.4 – Water Level (Flood) Design

- ▶ Section 3.4 describes the basis used in the U.S. EPR design for flood
- ▶ Seismic Category I structures are designed for the effects of flooding
- ▶ Internal Flood Protection
 - ◆ Physical Separation
 - Strategy is to limit flood damage to one division
 - SB, EPGB, ESWB physical separation of divisions for flooding
 - FB separated into 2 divisions
 - Division walls below grade- No doors, no unsealed penetrations
 - Watertight doors between divisions above grade
 - ◆ Reactor Building and Annulus have no divisional flood separation
 - Reactor Building layout such that water flows to IRWST
 - No components required to function below flood level
- ▶ External Flood Protection
 - ◆ U.S. EPR uses a “Dry Site” concept → Site platform level (grade level) is arranged above the maximum level of the design basis flood
 - U.S. EPR FSAR requires grade level to be at least 1 foot above the maximum design basis flood (or tsunami) level
 - Maximum groundwater elevation is 3.3 ft below finished grade
 - Finished grade slopes away from Seismic Category I structures
- ▶ COL applicants are required to determine the probable maximum flood, probable maximum precipitation, evaluate seiche and other hydrologic conditions per RG 1.159 and 1.102

Section 3.5 – Missile Protection

- ▶ Section 3.5 describes the approach to protect safety related SSCs from externally and internally generated missiles
- ▶ Missiles are non-credible if the risk is less than 1×10^{-7}
 - ◆ Risk is probability of missile occurrence x probability of impact x probability of significant damage
- ▶ Missile Sources
 - ◆ Internal
 - High energy fluid systems
 - Rotating equipment
 - Postulated pipe ruptures
 - ◆ External
 - Turbine Missiles
 - Tornado Generated Missiles – Region I missile spectrum in Table 2 of R.G. 1.76
- ▶ Protection Strategy
 - ◆ Location in a missile resistant structure
 - ◆ Separating redundant systems from missile path or range of the missile
 - ◆ Local shields and barriers
 - ◆ Design to withstand impact of missiles
 - ◆ Design features to prevent the generation of missiles
 - ◆ Orienting missile sources to prevent strike on safety-related equipment
- ▶ COL information items are identified for the applicant to evaluate any site specific missiles

Section 3.7 – Seismic Design


- ▶ Describes the seismic analysis methods for designing structures, systems and components to withstand the effects of the CSDRS (Certified Seismic Design Response Spectra or SSE for Standard Design)
- ▶ 3.7.1 Seismic Design
- ▶ 3.7.2 Seismic System Analysis
- ▶ 3.7.3 Seismic Subsystem Analysis
- ▶ 3.7.4 Seismic Instrumentation

Section 3.7.1 – Seismic Design Parameters

- ▶ Section 3.7.1 describes the vibratory ground motion and site conditions assumed for the U.S. EPR standard design
- ▶ CSDRS
 - ◆ The U.S. EPR CSDRS is based on individual sets of 3 control motions developed for hard, medium and soft soil conditions anchored at 0.3g PGA. In addition, a high frequency control motion is added anchored at a 0.21g horizontal PGA and a 0.18g vertical PGA
 - ◆ Hard, soft, and medium control motions meet 10 CFR 50 Appendix S requirements
 - ◆ CSDRS are modified to account for structure-soil-structure interaction effects for the buildings not on the Nuclear Island Common Basemat
 - ◆ Time histories meet NUREG/CR-6728 criteria
- ▶ The COL applicant is required to reconcile with the seismic design parameters


Section 3.7.1 – Seismic Design Parameters

Input Control Motions (CSDRS)



Section 3.7.1 – Seismic Design Parameters

CSDRS Comparison with 10 CFR 50 App. S and R.G. 1.60



REV 003



Section 3.7.1 – Seismic Design Parameters



▶ Soil Profiles

- ◆ The U.S. EPR seismic analysis considers 8 soil profiles, including high frequency soil profiles
- ◆ Each soil profile is associated with one of the control motions (hard, medium, soft, high frequency)

▶ Damping

- ◆ Damping based on R.G. 1.61, Rev. 1

Section 3.7.1 – Seismic Design Parameters


Soil Profiles

| Soil Case No. | Seismic Control Motion Applied | Soil Profile (Half-space or Layered) | Shear Wave Velocity of Soil ¹ Below Elevation -38 ft, 10-1/2 inches (-11.85 m) | Shear Wave Velocity of Soil ¹ Above Elevation -38 ft, 10-1/2 inches (-11.85 m) |
|---------------|--------------------------------|-----------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|
| 4ue | EUR Medium | Half-space | 3937 ft/s | 3937 ft/s |
| 5ae | EUR Hard | Half-space | 13,123 ft/s | 13,123 ft/s |
| 1n5ae | EUR Hard | 38 ft uniform layer followed by stiffer soil half-space | 6601 ft/s | 700 ft/s |
| 1n2ue | EUR Soft | 38 ft uniform layer followed by linear gradient within a 100 ft layer over a half-space | 820 ft/s to 1640 ft/s | 700 ft/s |
| 2sn4ue | EUR Medium | 87 ft uniform layer over a half-space | 1640 ft/s to 3937 ft/s | 1640 ft/s |
| hfub | HF | 300 ft layer of varying shear wave velocities | 8143 ft/s to 11,759 ft/s | 1408 ft/s to 2817 ft/s |
| hflb | HF | 300 ft layer of varying shear wave velocities | 5427 ft/s to 7838 ft/s | 470 ft/s to 719 ft/s |
| hfbe | HF | 300 ft layer of varying shear wave velocities | 6647 ft/s to 9600 ft/s | 578 ft/s to 908 ft/s |

1. Shear wave velocities of soil profiles are strain-compatible.

Section 3.7.1 – Seismic Design Parameters

5 Standard Soil Profiles




REV003
03EPR0400 T2


Section 3.7.2 – Seismic System Analysis

- ▶ Section 3.7.2 provides seismic analysis details for Seismic Category I, II, and Radwaste Seismic structures
- ▶ Seismic Category I
 - ◆ NI Common Basemat (Reactor Bldg, Safeguard Bldgs 1-4, Fuel Building, associated shield structures, and Vent Stack)
 - ◆ Essential Service Water Buildings (1-4)
 - ◆ Emergency Power Generation Buildings (1/2, 3/4)
- ▶ Seismic Category II
 - ◆ Nuclear Auxiliary Building
 - ◆ Access Bldg [Site Specific Structure]
 - ◆ Turbine Bldg/Switchgear Building [Site Specific Structure]
- ▶ Radwaste Seismic
 - ◆ Radwaste Building
 - ◆ Nuclear Auxiliary Building
- ▶ COL applicant to address the seismic design requirements for other site specific structures


Evolution of U.S. EPR Nuclear Island SSI Model



Surface-Founded Stick on Rigid Basemat



Embedded Stick on Rigid Basemat



Embedded Finite Element Model

Section 3.7.2 – Seismic System Analysis SC I Structures

► Seismic Models

- ◆ Dynamic 3D finite element models are used to determine the seismic response of the SC I structures
- ◆ Embedded effects are modeled
- ◆ Both cracked and un-cracked concrete properties are considered
- ◆ The NI Common Basemat seismic model includes stick models of the NAB and RCS to capture their influence on the NI Common Basemat seismic response and provide input for the seismic design of the NAB and RCS

► Seismic Analysis

- ◆ A soil structure interaction analysis is performed using the MTR/SASSI computer code for each of the control motion and soil profile combinations for each of the SC I structures
- ◆ In-structure response spectra and zero period accelerations are generated for design of SSCs
- ◆ Structure to soil to structure interaction effects are considered for SC I and II structures not on the Nuclear Island Common Basemat

Section 3.7.2 – Seismic System Analysis

SC II and Radwaste Seismic

▶ SC II Structures (NAB, AB, TB/Swgr)

◆ Analyzed and Designed to SC I Criteria

- Construction materials, testing and examination is to conventional standards
- AB and TB/Swgr Criteria are conceptual in U.S. EPR

◆ The AB & TB/Swgr are analyzed and designed to the Site Specific SSE by the COL applicant

◆ Gap between structures is evaluated to ensure the SC II structure will not impair the function of any SC I structure

- COL Applicant are required to confirm adequate gaps for Site Specific Structures

▶ Radwaste Seismic (RWB and NAB)

◆ RWB and NAB are designed in accordance with RG 1.143 Category RW-IIa

Section 3.7.3 – Seismic Subsystem Analysis



- ▶ Section 3.7.3 describes seismic analysis methodologies for standard plant subsystems including-
 - ◆ HVAC duct
 - ◆ Cable tray
 - ◆ Conduit and tubing distribution systems
 - ◆ Equipment and component supports
 - ◆ Platforms and support frame structures
 - ◆ Buried piping and conduits
 - ◆ Yard structures
 - ◆ Atmospheric tanks

Section 3.7.3 – Seismic Subsystem Analysis


- ▶ Seismic Category I subsystems are designed to withstand the CSDRS and maintain the capability to perform their safety functions
 - ◆ Methods used for analysis include response spectrum method, time history method, or equivalent static load method
- ▶ Operating Basis Earthquake (OBE)
 - ◆ OBE is not explicitly considered in design per SECY 93-087, “Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs.”
 - The exceptions for elimination of OBE identified in SECY 93-087 are considered
- ▶ COL applicants are required provide the method of analysis for site specific subsystems

Section 3.7.4 – Seismic Instrumentation

- ▶ Section 3.7.4 describes requirements for seismic instrumentation to ensure the plant features important to safety can be evaluated promptly following an earthquake
- ▶ Instrumentation conforms to R.G. 1.12, Rev. 2
 - ◆ Instrumentation components are qualified to IEEE-344-2004
- ▶ Pre-earthquake planning and post-earthquake actions conform to R.G. 1.166
 - ◆ Exceedance Criteria are per EPRI reports NP-6695 and NP-5930
 - ◆ Cumulative Absolute Velocity (CAV) is calculated in accordance with EPRI TR-100082
- ▶ Restart requirements following an earthquake conform to R.G. 1.167
- ▶ COL applicant required to establish location of free-field sensors

Section 3.8 – Design of Category I Structures

- ▶ Section 3.8 describes information on the design of SC I Structures
- ▶ 3.8.1 Concrete Containment
- ▶ 3.8.2 Steel Containment
- ▶ 3.8.3 Concrete and Steel Internal Structures of Concrete Containment
- ▶ 3.8.4 Other Seismic Category I Structures
- ▶ 3.8.5 Foundations




Section 3.8.1 – Concrete Containment

- ▶ Section 3.8.1 describes the post tensioned reinforced concrete containment structure
- ▶ The containment is shielded by a reinforced concrete shield building designed for protection against missiles, including a large commercial aircraft
- ▶ Design meets the requirements of ASME Section III, Division 2
- ▶ A steel liner plate is provided
- ▶ The containment uses a grouted tendon design
 - ◆ ISI fully compliant with R.G. 1.90
 - ◆ Grout control per R.G. 1.107
- ▶ Designed for normal loads, severe environmental loads, extreme environmental loads, and abnormal loads (e.g., combustible gas per 10 CFR 50.44)
- ▶ Containment design pressure is 62 psig
- ▶ The COL applicant will verify that the site specific loads are enveloped by the U.S. EPR design

Section 3.8.1 – Concrete Containment

Finite Element Model of Containment



Section 3.8.2 – Steel Containment


- ▶ Section 3.8.2 describes the steel components of the post tensioned reinforced concrete containment structure
- ▶ For the U.S. EPR, this applies to major containment penetrations and portions of penetrations not backed by structural concrete that are intended to resist pressure
- ▶ Penetrations include
 - ◆ Equipment hatch
 - ◆ Dedicated spare penetration
 - ◆ Airlocks
 - ◆ Construction opening
 - ◆ Pipe penetration sleeves
 - ◆ Electrical penetration sleeves
 - ◆ Fuel transfer tube sleeve
- ▶ Meets the requirements of ASME Section III, Div 1, Subsection NE
- ▶ Designed for service loads, factored loads, and other loads

Section 3.8.3 – Concrete and Steel Internal Structures of Concrete Containment

- ▶ Section 3.8.3 describes the reinforced concrete walls and floors, steel framing members, and other concrete and steel structural elements that are located within the concrete containment structure
- ▶ Major internal structures include
 - ◆ Reactor vessel support structure and reactor cavity
 - ◆ Steam generator support structures
 - ◆ Reactor coolant pump support structures
 - ◆ Pressurizer support structure
 - ◆ Operating floor and intermediate floors
 - ◆ Secondary shield walls
 - ◆ Refueling canal walls
 - ◆ Polar crane support structure
 - ◆ Internal structures basemat
 - ◆ IRWST
 - ◆ Core melt retention area

Section 3.8.3 – Concrete and Steel Internal Structures of Concrete Containment

- ▶ Meets the requirements of ACI-349 and AISC/ANSI N690
- ▶ Designed for normal loads, severe environmental loads, extreme environmental loads, and abnormal loads (e.g., high energy pipe break)
- ▶ The COL applicant will verify that the site specific loads are enveloped by the U.S. EPR design



Finite Element Model of
Reactor Building Internal
Structures

Section 3.8.4 – Other Seismic Category I Structures

- ▶ Section 3.8.4 describes the other SC I structures on the Nuclear Island Common Basemat and SC I structures located away from it
- ▶ Other SC I Structures include
 - ◆ Reactor Shield Building and Annulus (on Common Basemat)
 - ◆ Fuel Building and Fuel Building Shield (on Common Basemat)
 - ◆ Safeguard Buildings 1 thru 4 (on Common Basemat)
 - ◆ Vent Stack (on Fuel Building Roof)
 - ◆ Emergency Power Generating Buildings 1/2 and 3/4
 - ◆ Essential Service Water Buildings 1 thru 4
 - ◆ Distribution system supports in above structures
 - ◆ Platforms and miscellaneous structures in above structures
 - ◆ Buried conduit and duct banks (COL Scope)
 - ◆ Buried pipe and pipe ducts (COL Scope)


Section 3.8.4 – Other Seismic Category I Structures



- ▶ Meets the requirements of ACI-349 and AISC/ANSI N690
- ▶ No masonry walls are used in U.S. EPR SC I structures
- ▶ Designed for normal loads, severe environmental loads, extreme environmental loads, and abnormal loads (e.g., high energy pipe break)
- ▶ The COL applicant will verify that the site specific loads are enveloped by the U.S. EPR design

Section 3.8.5 – Foundations

- ▶ Section 3.8.5 describes the Seismic Category I structure foundations
- ▶ The SC I Structure Foundations include
 - ◆ The Nuclear Island Common Basemat Structure foundation basemat
 - ◆ The EPGB foundation basemat
 - ◆ The ESWB foundation basemat
- ▶ Meets the requirements of ACI-349 and ASME Section III, Div. 2
- ▶ Stability (i.e., sliding and overturning) is checked per SRP 3.8.5
- ▶ Designed for normal loads, severe environmental loads, extreme environmental loads, and abnormal loads
- ▶ The COL applicant will verify that the site specific loads, such as settlement are enveloped by the U.S. EPR design



**Nuclear Island Common
Basemat Foundation**

Section 3.8 – Design of Category I Structures

- ▶ Critical Sections identified to demonstrate essentially complete design per requirements of 10 CFR 52.47(c)
- ▶ Three-tiered critical section selection methodology
 - ◆ Qualitative criterion
 - SC I structures that perform a safety-critical function such as a barrier to radioactive release
 - ◆ Quantitative criterion
 - Selected through a thorough numerical analysis of the NI FE analysis results
 - Intended to identify sections that are highly stressed, but not chosen under the qualitative criterion
 - ◆ Supplementary criterion
 - Intended to capture critical sections not screened by the other two criteria
 - Based on engineering judgment
 - Necessary to obtain an adequate representation of typical structural elements

Sections 3.6, 3.9, 3.12, 3.13

Chris McGaughy



Section 3.6 - Protection Against Dynamic Effects Associated with Postulated Rupture of Piping



- ▶ Section 3.6.1 - Plant Design for Protection Against Postulated Piping Failures in Fluid Systems Outside of Containment
- ▶ Section 3.6.2 - Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping
- ▶ Section 3.6.3 Leak-Before-Break (LBB) Evaluation Procedures

Section 3.6.1 - Plant Design for Protection Against Postulated Piping Failures in Fluid Systems Outside of Containment

- ▶ Design of protection for essential systems against postulated pipe rupture is per the SRP and BTP 3-3:
 - ◆ In the event of a high- or moderate-energy pipe rupture within the plant, protection is provided so that the essential systems and components are not adversely impacted by the effects of postulated piping failure
- ▶ A combination of redundancy and separation is utilized:
 - ◆ Four redundant safety trains for many essential systems
 - ◆ Protection of essential systems is also achieved by physically separating them from other high- and moderate-energy lines through:
 - Distance
 - Intervening structures or barriers
 - Protective enclosures for essential systems/components
 - Enclosures around high- or moderate-energy piping that could damage essential system piping after a rupture

Section 3.6.2 - Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

- ▶ Ruptures in high- and moderate- energy piping inside and outside containment are located per SRP (BTP 3-4) requirements:
 - ◆ Circumferential and longitudinal breaks, and leakage cracks in high-energy lines
 - ◆ Leakage cracks in moderate-energy lines

- ▶ Pipe whip analysis of ruptured pipe follows the guidance of the SRP with consideration of:
 - ◆ Location of pipe whip hinges
 - ◆ Non-linear properties of pipe whip restraints
 - ◆ Pipe rebound

Section 3.6.2 - Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

▶ Jet Impingement Effects

- ◆ Technical Report ANP-10318P: AREVA NP proprietary methodology for calculating external loading effects on essential SSC due to jet impingement, including unsteadiness, jet resonance and jet reflection effects
- ◆ Methodology is independent of ANSI/ANS 58.2
- ◆ A flow chart of the methodology is provided in Figure 03.06.02-33-1 of RAI 354, Supplement 29

▶ Blast Effects

- ◆ Ruptures in lines containing steam are capable of generating blast waves
- ◆ Steam lines inside containment are qualified for LBB; therefore, they are not evaluated for blast potential
- ◆ Steam lines outside of containment have been evaluated to identify essential SSC susceptible to blast from their rupture and it was determined that essential SSC in safeguard buildings are subject to blast loading

Section 3.6.3 – Leak-Before-Break Evaluation Procedures

- ▶ LBB methodology is used to demonstrate that the probability of pipe rupture is extremely low for a given piping system; therefore, consideration of dynamic effects of pipe ruptures can be eliminated
- ▶ The methods and criteria to evaluate LBB are consistent with the guidance in NUREG-1061, Volume 3, and SRP 3.6.3:
 - ◆ Leak rate analysis considers leakage crack sizes with recommended margin of 10 on leak detection capability
 - ◆ Detailed flaw stability analysis considers safety margin of two on leakage crack size
- ▶ LBB methodology is applied to the following high energy piping systems:
 - ◆ Main coolant loop (MCL) piping (hot legs, crossover legs, and cold legs)
 - ◆ Pressurizer surge line (SL)
 - ◆ Main steam line (MSL) piping inside containment
- ▶ LBB results are in the form of “Allowable Load Limit” (ALL) diagrams
 - ◆ If applied loading points lie within the ALL window, LBB is justified
- ▶ Critical location is the SL dissimilar metal welds (DMW)
 - ◆ Material properties of the DMW established via FEA

Section 3.6.3 - Leak-Before-Break Evaluation Procedures

▶ Leakage Detection

- ◆ Leak rates of 5.0 gpm for the MCL and SL and 1.0 gpm for MSL were used for determining the leakage flaw sizes - provides a factor of ten to the actual plant leakage detection system capabilities
- ◆ RCPB leakage detection conforms to the sensitivity and response times recommended in RG 1.45, Revision 1, described in FSAR Section 5.2.5
- ◆ MSL Leakage Detection:
 - Primary method is local humidity detection system
 - Secondary method is containment sump level
 - Containment air cooler condensate flow and containment atmosphere pressure, temperature, and humidity also provide an indication of possible MSL leakage

Section 3.9 - Mechanical Systems and Components



- ▶ Section 3.9.1 - Special Topics for Mechanical Components
- ▶ Section 3.9.2 - Dynamic Testing and Analysis of Systems, Components, and Equipment
- ▶ Section 3.9.3 - ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures
- ▶ Section 3.9.4 – Control Rod Drive System
- ▶ Section 3.9.5 - Reactor Pressure Vessel Internals
- ▶ Section 3.9.6 - Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints

Section 3.9.1 - Special Topics for Mechanical Components

- ▶ Design Transients:
 - ◆ Pressure, temperature and flow transients for normal, upset, emergency, faulted and test conditions are described and design cycles are based on 60 year plant life
- ▶ Computer programs used in the structural, stress and fatigue analysis of piping, components, supports and component internals are listed in Section 3.9.1
- ▶ Experimental stress analysis methods are not used
- ▶ Section 3.9.3 describes the analytical methods used to evaluate stresses for Seismic Category I systems and components subjected to faulted condition loading

Section 3.9.2 - Dynamic Testing and Analysis of Systems, Components, and Equipment

- ▶ Describes the general startup functional tests and the vibration and dynamic analyses to be performed on specified high-energy and moderate-energy piping and the associated piping supports and restraints, and on reactor internals to verify they meet structural and functional requirements
- ▶ U.S. EPR conforms to RG 1.20 R3 with the following exceptions:
 - ◆ Vibration program for steam generator internals not required since PWR SG upper internals are not subject to excessive vibration
 - ◆ Vibration for the condensate system will be measured during start-up testing using hand-held vibration monitors rather than fixed instrumentation
- ▶ U.S. EPR RPV internals are classified as prototype per guidance of RG 1.20 R3
- ▶ The comprehensive vibration assessment program for reactor internals is described in Technical Report ANP-10306P (AREVA Proprietary) and conforms to the guidance of RG 1.20 R3

Section 3.9.3 - ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures



- ▶ Structural design and stress/fatigue analysis of pressure-retaining components, component supports, and core support structures is in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Division 1 and applicable GDC
 - ◆ Effects of RCS environment on component fatigue are considered
- ▶ Structural design of piping and pipe supports is described in Topical Report ANP-10264NP-A, “U.S. EPR Piping Analysis and Pipe Support Design” - modeling techniques, analysis methods and acceptance criteria for ASME Class 1, 2 and 3 piping
- ▶ The functional design and qualification of safety-related pumps, valves, and snubbers is performed in accordance with ASME QME-1-2007

Section 3.9.4 – Control Rod Drive System (CRDS)



- ▶ The CRDS includes the CRDM and the RCCA
- ▶ The CRDM is an electromagnetic jack design and is mounted on top of the RPV head - based on a proven design that has been in use for over 30 years
- ▶ Design of CRDS is in accordance with the ASME Boiler and Pressure Vessel Code (Section II – Materials, Section III – Class 1 construction rules)
- ▶ To confirm the mechanical adequacy of the CRDS, a prototype testing program was created that integrates the CRDM and appurtenances, the CRDM drive rod, the CRGA, the RCCA, and the fuel assembly:
 - ◆ Functionality testing at simulated operating conditions
 - ◆ Endurance (wear) testing
 - ◆ Drop testing

Section 3.9.5 - Reactor Pressure Vessel Internals

▶ RPV Internals:

- ◆ Upper and lower internals
- ◆ Classified as Core Support Structures or Internal Structures

▶ Core Support Structures:

- ◆ Class CS per ASME Boiler and Pressure Vessel Code, Section III, Division 1, Subsection NG
- ◆ Design, analysis, fabrication, and non-destructive examination is in accordance with Subsection NG

▶ Internal Structures:

- ◆ Designated as internal structures in accordance with ASME Code, Section III, Subsection NG-1122
- ◆ Design meets the guidelines of Subsection NG Article NG-3000

Section 3.9.6 - Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints

- ▶ Describes the functional design and qualification provisions and IST programs for safety-related pumps, valves, and dynamic restraints (snubbers)
- ▶ Section 3.9.6 fully describes the functional design, qualification, and IST programs for the U.S. EPR
- ▶ IST of safety-related pumps, valves and snubbers is performed in accordance with 10 CFR 50.55a(f), the 2004 edition of the ASME OM Code, and the guidance in RG 1.192, and NUREG-1482, Revision 1
- ▶ The functional design and qualification of safety-related pumps, valves, and snubbers is performed in accordance with ASME QME-1-2007, as endorsed in RG 1.100, Rev. 3
- ▶ System design allows full flow testing of pumps and valves under the IST program
- ▶ The U.S. EPR design incorporates provisions to permit safety-related check valves to be tested for performance in both the forward and reverse flow directions

Section 3.9.6 - Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints

- ▶ IST of safety-related MOVs also incorporates the guidance of:
 - ◆ GL 96-05 which supersedes GL 89-10
 - ◆ Joint Owners Group (JOG) MOV Periodic Verification
 - ◆ ASME Code Case OMN-1, as accepted by the NRC with conditions in RG 1.192
- ▶ IST of POVs, other than MOVs, incorporates the guidance of:
 - ◆ Regulatory Issue Summary 2000-03 (incorporates the lessons learned from MOV analysis and tests in response to GL 96-05)
 - ◆ GL 89-10
 - ◆ JOG AOV program
- ▶ A list of pumps included in the IST program is provided in U.S. EPR FSAR Tier 2, Table 3.9.6-1 and a list of valves included in the IST program is provided in U.S. EPR FSAR Tier 2, Table 3.9.6-2
- ▶ Visual examination of snubbers will be performed in accordance with Code Case OMN-13 as accepted by the NRC in RG 1.192


Section 3.12 - ASME Code Class 1, 2, and 3 Piping Systems, Piping Components, and their Associated Supports

- ▶ Addresses the design of the piping systems and piping supports
- ▶ AREVA NP Topical Report ANP-10264NP-A contains the details regarding design of safety related piping and addresses the interaction of non-seismic piping with Seismic Category I piping
- ▶ Piping design addresses thermal stratification:
 - ◆ The pressurizer SL is continuously sloped from the pressurizer to the hot leg and there is continuous flow from the pressurizer to the hot leg, both of which act to minimize thermal stratification
 - ◆ The main nozzle and the adjacent feedwater line are sloped downward from the SG and there is continuous flow, both of which act to minimize thermal stratification during normal operations
 - ◆ To assess for stratification, the COL applicant will monitor temperatures during the first fuel cycle of initial plant operation to verify that the design transients are representative of actual plant operations
- ▶ The effects of reactor coolant environment, using the methodology described in RG 1.207, are considered when performing fatigue analyses for Class 1 piping and components

Section 3.13 - Threaded Fasteners (ASME Code Class 1, 2, and 3)

- ▶ Class 1, 2 and 3 pressure boundary threaded fasteners are designed in accordance with ASME B&PV Code Section III, Subsection NB, NC and ND, respectively
 - ◆ Ferritic Class 1 fasteners also meet 10 CFR 50, Appendix G, fracture toughness requirements
- ▶ Selection and testing of bolting material is per the SRP (ASME B&PV Code, Section III, Subsections NCA and NB/NC/ND)
 - ◆ Material and testing of the RV closure stud bolting conforms to RG 1.65
- ▶ Lubricants for the U.S. EPR are selected in accordance with the guidance provided in NUREG-1339
- ▶ Inservice inspection of ASME Class 1, Class 2, and Class 3 threaded fasteners is performed in accordance with ASME Section XI

Section 3.10 - Seismic and Dynamic Qualification of Mechanical and Electrical Equipment



Section 3.11 - Environmental Qualification of Mechanical and Electrical Equipment

Nissen Burstein



Section 3.10 - Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

- ▶ Provides the requirements for seismic and dynamic qualification of mechanical, electrical, and I&C equipment
- ▶ Seismic qualification is performed by test, analysis, or a combination of test and analysis
- ▶ Seismic qualification in accordance with IEEE 344-2004 and ASME QME-1-2007, as endorsed by RG 1.100, Revision 3
- ▶ Seismic qualification based on experience, per Section 10 of IEEE Std 344-2004, is not utilized for the U.S. EPR
- ▶ Electrical and mechanical equipment for the U.S. EPR is qualified for the SSE as defined in Section 3.7.1, with low-level effects considered via five OBEs, as noted in Section 3.7.3.2, also in accordance with IEEE 344
- ▶ The U.S. EPR FSAR provides a list of electrical and I&C equipment that is being seismically qualified in accordance with IEEE Std 344

Section 3.10 - Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

- ▶ An SQDP is developed for each equipment (or equipment class) to document the qualification results that establish the seismic capability of the equipment. A sample SQDP format is included in Attachment F to Appendix 3D
- ▶ The seismic qualification procedures for mechanical and electrical equipment are described in more detail in Attachment E to Appendix 3D
- ▶ A COL applicant will identify any site-specific components that need to be added to the equipment list in Table 3.10-1

Section 3.11 - Environmental Qualification of Mechanical and Electrical Equipment

- ▶ Provides the U.S. EPR approach to the EQ of equipment and identifies the equipment that is within the scope of 10 CFR 50.49 including I&C and certain post-accident monitoring (PAM) equipment
- ▶ Equipment in the scope of the EQ program is qualified based on the guidelines provided in IEEE Std 323-1974 as endorsed by RG 1.89 and related standards shown in U.S. EPR FSAR Tier 2, Table 3.11-4
- ▶ The environmental conditions include anticipated operational occurrences and normal, accident and post-accident environments due to DBE
- ▶ U.S. EPR FSAR includes a detailed listing by equipment tag number of electrical and I&C equipment located in an environmental harsh or radiation harsh environment that require qualification
- ▶ A new service condition for plant equipment (especially for digital I&C systems) is EMC, from the standpoint of susceptibility and emissions

Section 3.11 - Environmental Qualification of Mechanical and Electrical Equipment

- ▶ PAM equipment is also environmentally qualified in accordance with RG 1.97
- ▶ Section 3.11.2.2 demonstrates that the U.S. EPR approach to qualification of mechanical equipment is in accordance with SRP 3.11 and GDC 4
 - ◆ Mechanical pressure boundary components qualified by virtue of the application of an ASME Boiler and Pressure Vessel stamp
 - ◆ Components that contain mechanical non-metallic or consumable parts that require EQ (i.e., classification C/NM) are qualified in accordance with App QR-B to ASME QME-1-2007
 - ◆ Qualification maintained via preventive and surveillance maintenance, and periodic testing
- ▶ The summaries and results of qualification tests for electrical equipment and components are documented in the EQDP. An EQDP sample format is provided in Appendix 3D
- ▶ A COL applicant that references the U. S. EPR design certification will identify site-specific components that need to be added to the environmental qualification list in Table 3.11-1

Acronyms

| Acronym | Definition |
|---------|-------------------------------------------|
| AB | Access Building |
| ACH | Aircraft Hazard |
| ALL | Allowable Load Limit |
| ANS | American Nuclear Society |
| ANSI | American National Standards Institute |
| AOV | Air Operated Valve |
| ASME | American Society of Mechanical Engineers |
| ATWS | Anticipated Transient Without Scram |
| B&PV | Boiler and Pressure Vessel |
| BTP | Branch Technical Position |
| CAV | Cumulative Absolute Velocity |
| CFR | Code of Federal Regulations |
| CRDM | Control Rod Drive Mechanism |
| COL | Combined License |
| CRDS | Control Rod Drive System |
| CRGA | Control Rod Guide Assembly |
| CS | Conventional Seismic |
| CSDRS | Certified Seismic Design Response Spectra |
| CVCS | Chemical and Volume Control System |
| DBE | Design Basis Event |
| DMW | Dissimilar Metal Weld |
| ECCS | Emergency Core Cooling System |
| EDG | Emergency Diesel Generator |
| EMC | Electromagnetic Compatibility |
| EPGP | Emergency Power Generating Building |

Acronyms

| Acronym | Definition |
|---------|---------------------------------------------------|
| EQ | Environmental Qualification |
| EQDP | Equipment Qualification Data Packages |
| ESWB | Essential Service Water Building |
| FB | Fuel Building |
| FEA | Finite Element Analysis |
| GDC | General Design Criteria |
| GL | Generic Letter |
| I&C | Instrumentation and Controls |
| IEEE | Institute of Electrical and Electronics Engineers |
| IRWST | In-Containment Refueling Water Storage Tank |
| ISI | Inservice Inspection |
| IST | Inservice Testing |
| JOG | Joint Owners Group |
| LBB | Leak-Before-Break |
| MCL | Main Coolant Loop |
| MOV | Motor Operated Valve |
| MSL | Main Steam Line |
| NAB | Nuclear Auxiliary Building |
| NI | Nuclear Island |
| NRC | Nuclear Regulatory Commission |
| NS | Non- Seismic |
| OBE | Operating Basis Earthquake |
| PAM | Post-Accident Monitoring |
| PGA | Peak Ground Acceleration |
| PMF | Probable Maximum Flood |

Acronyms

| Acronym | Definition |
|----------------|-----------------------------------------|
| PMP | Probable Maximum Precipitation |
| POV | Power Operated Valve |
| PWR | Pressurized Water Reactor |
| PWSCC | Primary Water Stress Corrosion Cracking |
| QA | Quality Assurance |
| RAI | Request for Additional Information |
| RCCA | Rod Cluster Control Assembly |
| RB | Reactor Building |
| RCPB | Reactor Coolant Pressure Boundary |
| RCS | Reactor Coolant System |
| RG | Regulatory Guide |
| RHR | Residual Heat Removal |
| RPV | Reactor Pressure Vessel |
| RS | Radwaste Seismic |
| RWB | Radwaste Building |
| SB | Safeguard Building |
| SG | Steam Generator |
| SL | Surge Line |
| SQDP | Seismic Qualification Data Package |
| SRP | Standard Review Plan |
| SSC | Structures, Systems and Components |
| SSE | Safe Shutdown Earthquake |
| TB | Turbine Building |



Presentation to the ACRS Subcommittee

AREVA U.S. EPR Design Certification Application Review

Safety Evaluation Report with Open Items

**Chapter 3: Design of Structures,
Components, Equipment and Systems**

February 21-22, 2012

Staff Review Team

- **Technical Staff**
 - ♦ **Tech Reviewer: Richard McNally**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Yuken Wong**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Manas Chakravorty**
Branch Name: Structural Engineering -2
 - ♦ **Tech Reviewer: Chang-Yang Li**
Branch Name: Balance of Plant and Technical Specifications
 - ♦ **Tech Reviewer: John Honcharik**
Branch Name: Component Integrity
 - ♦ **Tech Reviewer: Seshagiri Tammara**
Branch Name: Radiation Protection and Accident Consequences
 - ♦ **Tech Reviewer: Raul Hernandez**
Branch Name: Balance of Plant and Fire Protection

Staff Review Team

- **Technical Staff**
 - ♦ **Tech Reviewer: Renee Li**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Eric Reichelt**
Branch Name: Component Integrity
 - ♦ **Tech Reviewer: Sarah Tabatabai**
Branch Name: Geosciences and Geotechnical Engineering -1
 - ♦ **Tech Reviewer: Jim Xu**
Branch Name: Structural Engineering -2
 - ♦ **Tech Reviewer: Cheng-Ih Wu**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Terri Spicher**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Tuan Le**
Branch Name: Engineering Mechanics

Staff Review Team

- **Technical Staff**
 - ♦ **Tech Reviewer: Thomas Scarbrough**
Branch Name: Component Integrity
 - ♦ **Tech Reviewer: Pei Yei Chen**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Peter Kang**
Branch Name: Instrument and Controls and Electrical Engineering
 - ♦ **Tech Reviewer: Robert Hsu**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Jim Strnisha**
Branch Name: Component Integrity
 - ♦ **Tech Reviewer: Jason Huang**
Branch Name: Engineering Mechanics
 - ♦ **Tech Reviewer: Sardar Ahmed**
Branch Name: Engineering Mechanics

Staff Review Team

- **Technical Staff**
 - ♦ **Tech Reviewer: Angelo Stubbs**
Branch Name: Balance of Plant and Fire Protection
 - ♦ **Tech Reviewer: Abdul Kazi**
Branch Name: Structural Engineering - 2

 - ♦ **Project Managers**
 - ♦ **Lead PM: Getachew Tesfaye**
 - ♦ **Chapter PM: Michael Miernicki**
 - ♦ **PM : Phyllis Clark**

Overview of DCA – Chapter 3

| SRP Section/Application Section | | No. of Questions | Status Number of OI |
|---------------------------------|----------------------------------------------------------------------------------------------|------------------|------------------------|
| 3.2 | Classification of Structures, Systems, and Components | 33 | 8 |
| 3.3 | Wind and Tornado Loadings | 10 | 1 |
| 3.4 | Water Level (Flood) Design | 28 | 1 |
| 3.5 | Missile Protection | 17 | 0 |
| 3.6 | Protection Against Dynamic Effects Associated with Postulated Rupture of Piping | 83 | 3 |
| 3.7 | Seismic Design | 153 | 8 |
| 3.8 | Design of Category I Structures | 153 | 13 |
| 3.9 | Mechanical Systems and Components | 251 | 33 |
| 3.10 | Seismic and Dynamic Qualification of Mechanical and Electrical Equipment | 31 | 0 |
| 3.11 | Environmental Qualification of Mechanical and Electrical Equipment | 40 | 1 |
| 3.12 | ASME Code Class 1, 2, and 3 Piping Systems, Piping Components, and their Associated Supports | 25 | 0 |
| 3.13 | Threaded Fasteners (ASME Code Class 1, 2, and 3) | 4 | 0 |
| Totals | | 828 | 68 |

Description of Open Items

- RAI 420, Question No. 03.02.01-12: Requests clarification on how the terms “safety related” and “important to safety” are applied to satisfy the seismic and quality group clarification requirements of GDC 2.
- RAI 510, Question No. 03.02.01-19: Requests that the applicant describe the basis for classification of the Passive Autocatalytic Recombiners as Seismic Category II.
- RAI 72, Question No. 03.02.02-6: Verification via audit of design documents regarding quality group classifications of important to safety SSCs.
- RAI 420, Question No. 03.02.02-7: Requests that the applicant review classification Table 3.2.2-1 and identify those additional risk-significant SSCs that should apply the 10 CFR Part 50, Appendix B program or similar special treatment .
- RAI 420, Question No. 03.02.02-8: Requests that the applicant identify the special treatment, or if not yet developed, revise FSAR Tier 2, Section 3.2.2 to reference the D-RAP or other process to ensure the integrity and reliability assumed in the PRA and identify when special treatment requirements are to be identified.

Description of Open Items

- RAI 420 , Question No. 03.02.02-11: Requests an update the figures included in Tier 1 to be consistent with Tier 2 figures in terms of level of detail for ASME classifications.
- RAI 435, Question No. 03.02.02-12: Requests that that the applicant clarify in the FSAR how compliance with GDC 1 for non-safety-related SSC's that are important to safety is accomplished or identify where this methodology is described.
- RAI 504, Question No. 03.02.02-14: Requests clarification on why the refueling cavity seal/ring is not considered a structural or pressure-retaining component and describe the extent that codes and standards are applied to its design.
- RAI 508, Question No. 03.03.01-5: Requests that the applicant add wind loads to the list of external event design basis loads for Seismic Category I structures to ITAAC tables of FSAR Tier 1, Section 2.1. (resolved)
- RAI 377, Question No. 03.04.01-13: Requests that the applicant identify in FSAR a new COL Information Item to provide a maintenance program for water resistant door seals.(resolved)

Description of Open Items

- RAI 533, Question No. 03.06.01-13: Requests the applicant to revise COL information items 3.6-1 and 3.6-1 to remove the reference to the reconciliation of deviations between the as-built configuration and the as-design analysis since this activity is addressed in an existing ITAAC.
- RAI 354, Question No. 03.06.02-35: Requests the applicant to provide a description of the evaluation approach to be used to account for dynamic loads caused by pipe rupture blast waves.
- RAI 467, Question No. 03.06.03-28: Requests the applicant to revise FSAR Tier 2 Section 3.6.3 figures to provide allowable load limit (ALL) diagrams.
- RAI 370, Question No. 03.07.01-27: Requests justification for the use of RG 1.61 SSE structural damping values in the generation of Nuclear Island in-structure response spectra.
- RAI 370, Question No. 03.07.02-64: Requests applicant to demonstrate that the Nuclear Auxiliary Building does not impair the structural integrity of a Seismic Category I structure during an SSE event.

Description of Open Items

- RAI 371, Question No. 03.07.02-66: Requests verification that the tendon gallery of the Reactor Building, which acts as a shear key during and SSE event, has stresses within design code limits. Also requests verification that the modeling of the NI mat/superstructure interface in SASSI model is an accurate representation of the actual building stiffness at this location.
- RAI 371, Question No. 03.07.02-67: Requests dynamic compatibility be demonstrated between the NI SASSI finite element model used for soil-structure interaction analysis and the NI ANSYS finite element model used for structural design.
- RAI 489, Question No. 03.07.02-75: Requests the applicant to demonstrate that the SASSI computer code subtraction method of analysis provides seismic responses that are equal to or greater than those obtained when using the SASSI computer code direct method of analysis.
- RAI 508, Question No. 03.07.03-41: Requests that the applicant provide the basis of strain criteria for buried piping. (resolved)
- RAI 381, Question No. 03.07.04-6: Requests the applicant to address the requirements of RG 1.12 and RG 1.166 regarding the installation of free field seismic sensors. (resolved)

Description of Open Items

- RAI 400, Question No. 03.07.04-7: Requests the applicant to provide the correct Tier 1 section information which describes the location of the seismic monitoring system equipment. (resolved)
- RAI 155, Question No. 03.08.01-24: Tracks the review of design configuration details for critical sections, as described in FSAR Tier 2, Appendix 3E, “Design Details and Critical Sections for Safety-Related Category I Structures.
- RAI 306, Question No. 03.08.01-39: Requests the applicant to address testing requirements in ASME Code Subarticle CC-3542(b) to validate concrete prestress losses due to friction assumed in design of RCB.
- RAI 306, Question No. 03.08.01-40: : Requests information regarding analysis methodology for localized abnormal loads (e.g., sub-compartment pressure loads, pipe break loads, local flood loads) applied to RBIS, not included in global FE model of the NI, as described in FSAR Tier 2, Appendix 3E, “Design Details and Critical Sections for Safety-Related Category I Structures.”

Description of Open Items

- RAI 155, Question No. 03.08.04-6: Tracks the review of the actual design of the selected critical sections, as described in FSAR Tier 2, Appendix 3E, “Design Details and Critical Sections for Safety-Related Category I Structures.
- RAI 445, Question No. 03.08.04-15, Review of Spent Fuel Racks: Requests information regarding dimensional gaps, evaluation of erection tolerances, and description of auxiliary crane handling of spent fuel assemblies, as described in Report TN-Rack.0101 and FSAR Tier 2 Chapter 9.
- RAI 445, Question No. 03.08.04-17, Review of Spent Fuel Racks: Requests updated results of stress analysis in Report TN-Rack.0101.
- RAI 445, Question No. 03.08.04-19, Review of Spent Fuel Racks: Requests: additional analyses which model fuel assemblies discretely and additional values of friction coefficient between racks and concrete floor of the spent fuel pool.

Description of Open Items

- RAI 445, Question No. 03.08.04-20, Review of Spent Fuel Racks: Requests information to demonstrate adequacy of seismic response spectra used as input to fuel rack analyses; requests stress evaluation for additional rack components; requests additional evaluation of stress analyses for critical racks.
- RAI 445, Question No. 03.08.04-21, Review of Spent Fuel Racks: Requests buckling evaluation; requests information to demonstrate adequacy of spent fuel assemblies for thermal and mechanical properties when stored in spent fuel pool; requests seismic qualification of racks in NFS area.
- RAI 445, Question No. 03.08.04-26, Review of Spent Fuel Racks: Requests results of additional bounding stress analysis assuming different boundary conditions of support legs.
- RAI 445, Question No. 03.08.04-27, Review of Spent Fuel Racks: Requests results of additional bounding thermal analysis assuming different cases of hot and cold cells.
- RAI 376, Question No. 03.08.05-28: Requests static and dynamic soil bearing pressures under basemat and dynamic soil pressures on sidewalls and shear key (tendon gallery) for the NI.

Description of Open Items

- RAI 376, Question No. 03.08.05-31: Requests information to demonstrate stability against sliding in accordance with SRP 3.8.5 for ESWB; requests static and dynamic soil bearing pressures under basemat and dynamic soil pressures on sidewalls and shear keys for ESWB and EPGB; requests additional information pertaining to seismic analysis and seismic response of the ESWB.
- RAI 179, Question No. 03.09.01-2: Requests applicant to provide a list of all computer programs used for generating hydraulic forcing functions and performing structural analysis. (resolved)
- RAI 458, Question No. 03.09.01-13: Requests the applicant to demonstrate the conservatism in the utilization of the weighted average Fen method, described in NUREG/CR-6909, in performing fatigue analysis for Class 1 piping and components. (resolved)
- RAI 458, Question No. 03.09.01-14: Requests that the applicant provide the benchmark justification for the local thermal stratification stress calculation. (resolved)
- RAI 458, Question No. 03.09.01-15: Requests that the applicant provide validation for the utilization of the RESPECT computer program that generates the response spectrum from an acceleration time history for piping analysis. (resolved)

Description of Open Items

- RAI 407, Question No. 03.09.02-69: Requests additional design details of the core barrel flange, hold down spring, heavy reflector and flow distribution device. (resolved)
- RAI 407, Question No. 03.09.02-71: Requests that the applicant describe how manufacturing tolerances (e.g. reactor vessel ID) are addressed in the analysis. (resolved)
- RAI 422, Question No. 03.09.02-87: Requests the applicant to discuss how the reactor internals comprehensive vibration assessment program addresses the SRP provisions on vibration prediction, adverse flow effects, bias errors and uncertainties. (resolved)
- RAI 422, Question No. 03.09.02-99: Requests the applicant to provided justification for not including the loop acoustics in the lower internals numerical model. (resolved)
- RAI 422, Question No. 03.09.02-100: Requests the applicant to provide the anticipated frequency range and amplitude of the loop acoustic source and the basis of the estimates. (resolved)

Description of Open Items

- RAI 422, Question No. 03.09.02-101: Requests the applicant to justify not including the loop acoustics in the upper internals numerical model. (resolved)
- RAI 422, Question No. 03.09.02-103: Requests the applicant to explain why the additional fuel assembly mass will not impact the lower internals structural frequency and the justification for performing the hot functional test without the core installed. (resolved)
- RAI 422, Question No. 03.09.02-104: Requests additional information on the calculation method of viscous damping over a frequency band. (resolved)
- RAI 422, Question No. 03.09.02-107: Requests details of the flow-induced vibration analysis and measurement evaluation of the heavy reflector tie rods. (resolved)
- RAI 422, Question No. 03.09.02-108: Requests the applicant to discuss the method for combining bias errors and uncertainties and the effect of these on the overall stress and vibration response of the reactor internals.

Description of Open Items

- RAI 422, Question No. 03.09.02-112: Requests the applicant to discuss the application of frequency bias and uncertainty in the core barrel finite element analysis prediction and the lower internals small scale model setup details (resolved)
- RAI 422, Question No. 03.09.02-114: Requests details on the primary forcing function, inlet jets, reactor vessel downcomer and lower support plate to determine if the lower internals scale model pressure measurement is acceptable (resolved)
- RAI 422, Question No. 03.09.02-119: Requests the applicant to reconcile the discrepancies for the lower internals scale model test frequency results tabulated in the Comprehensive Vibration Assessment Program Technical Report ANP-10306P Section 4.2.4 (resolved)
- RAI 467, Question No. 03.09.02-161: Requests additional details on the FA finite element model to ensure that the FA loads are properly represented in the reactor internals isolated model under SSE and LOCA.
- RAI 503, Question No. 03.09.02-168: Requests the applicant to provide the list of all reactor internals components included or exclude in the reactor internals isolated model, and the design methodology of these components for SSE and LOCA events.

Description of Open Items

- RAI 508, Question No. 03.09.02-169: Requests the applicant to discuss the reactor vessel upper internals CFD models and the ROMEO tests which address the CFD model validation and the grid size sensitivity.
- RAI 522, Question No. 03.09.02-170: Requests documentation of the responses for Questions 03.09.02-68, 74, 88, 96, 113, 117, 122, 123, 144, and 150 in the FSAR or Technical Report ANP-10306P.
- RAI 404, Question No. 03.09.03-24: Requests that the applicant make available for audit, the ASME design specifications for all risk-significant mechanical components.
- RAI 404, Question No. 03.09.03-25: Requests that the applicant make available for audit, the design specifications for all ASME Code Class 1, 2, and 3 components and supports.
- RAI, 503, Question No. 03.9.03-26: Requests the applicant to revise FSAR Tier 2 Section 3.9.3 tables to provide the service load combinations for design pipe breaks.

Description of Open Items

- RAI 510, Question No. 03.09.05-28: Requests the applicant to provide, and include in the FSAR, more information regarding the relevant flow induced vibration analyses of the in-core instrumentation supporting structures.
- RAI 510, Question No. 03.09.05-29: Requests the applicant to provide information about the design arrangement of the upper vessel internals and an evaluation of the potential effects of flow induced vibration and vortex shedding. (resolved)
- RAI 510, Question No. 03.09.05-30: Requests the applicant to revise the FSAR to provide design details associated with the inside of the control rod guide assemblies. (resolved)
- RAI 522, Question No. 03.09.05-31: Requests the applicant to include in the FSAR the figure which illustrates various clearances in the design of the core barrel radial support keys.
- RAI 381, Question No. 03.09.06-15: Requests the applicant to revise FSAR to specify use of ASME QME-1-2007 as accepted in RG 1.100 (Rev 3) for functional design and qualification of pumps, valves, and dynamic restraints (or describe the functional design and qualification process).

Description of Open Items

- RAI 381, Question No. 03.09.06-16: Requests that applicant clarify the reference in FSAR to ASME OM Code IST requirements for demonstrating design-basis capability of pumps and valves. (resolved)
- RAI 381, Question No. 03.09.06-17: Requests the applicant to specify in FSAR : MOV testing frequency, periodic testing of power operated valves (other than MOV's), and that AOV testing program attributes will be applied to other POV's where applicable. (resolved)
- RAI 381, Question No. 03.09.06-18: Requests the applicant to clarify several provisions for functional design, qualification, and IST for pumps, valves, and dynamic restraints, including FSAR Tier 2 Table 3.9.6-2. (not included in SER) (resolved)
- RAI 381, Question No. 03.09.06-19: Requests the applicant to confirm the IST provisions for specific valves listed in FSAR Tier 2 Table 3.9.6-2. (not included in SER)
- RAI 249, Question No. 03.11-14: Requests that the applicant provide updated temperature and pressure curves shown on FSAR Tier 2, Appendix 3D, Figures 3D-1 through 3D-2.

Technical Topics of Interest

Section 3.6.2 - Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

Key Regulations and Review Guidance

- GDC 4
- SRP Sections: 3.6.2 including BTP 3-4 and 3.6.1 including BTP 3-3
- Industry Standards: ANSI/ANS 58.2 (portions no longer acceptable)
 - Technical journal articles and reports
- 10 CFR 50.47(b)(1) - ITAAC

Technical Topics of Interest

Section 3.6.2 (continued)

SER Items of Interest

- Criteria used to define pipe break and crack locations and configurations
- Evaluation of jet impingement and pipe whip effects
Potential nonconservative assessments of the jet impingement loads due to inaccuracies and omissions in ANS 58.2 identified by
 - ACRS (Wallis-ADAMS ML 050830344, Ransom- ADAMS ML 050830341)

Technical Topics of Interest

Section 3.6.2 (continued)

RAIs 03.06.02-6 through 03.06.02-13 and their associated supplemental RAIs address inaccuracies and omissions in ANSI/ANS 58.2

- Effects of blast waves
- Jet expansion modeling
- Jet pressure distribution
- Jet dynamic loading and structural dynamic response including potential feedback amplification of blowdown force and jet resonance effects

Technical Topics of Interest

Section 3.6.2 (continued)

RAIs Status Summary:

- For jet dynamic effects, the staff found applicant's jet impingement assessments are conservative. However, their final documentation is pending, and remains a confirmatory item.
- For blast wave, the applicant is examining their plant design along with potential blast wave assessment. The blast wave issue remains an open item.

Technical Topics of Interest

Section 3.6.2 (continued)

Actual postulated HELBs have:

- A powerful initial blast wave, particularly in enclosed spaces
- Jets that:
 - have plumes which depend strongly on source fluid properties, and properties in the external fluid region
 - Have spatial pressure distributions that vary throughout the plume
 - are dynamic, with strongly oscillating pressure fields

Technical Topics of Interest

Section 3.6.2 (continued)

To address Open Item 03.06.02-35 (blast wave effects), the applicant will:

- Examine the EPR plant layout to determine regions which must be assessed for blast wave effects
 - So far, it appears that only steam line ruptures are capable of generating blast waves
- Pursue software which assesses the time-varying loads induced by blast waves on target SSCs
 - To be validated against data in existing literature
 - Will consider effects of mesh discretization, time step size, and model inputs

Technical Topics of Interest

Section 3.6.2 (continued)

To address jet dynamic loading the applicant is:

- Referencing a technical report in their FSAR – “Pipe rupture external loading effects on US-EPR Essential Structures, Systems, and Components,” ANP-10318P
- Including a summary of their procedure in FSAR Tier 2, Section 3.6.2.4.1

The updates and report are not yet finalized, and remain a Confirmatory Item

Technical Topics of Interest

Section 3.6.2 (continued)

In their technical report and FSAR, the applicant:

- Provides a detailed, conservative procedure for assessing the dynamic response of SSCs and barriers/shields to oscillatory jet loads
- For a given break:
 - Source flow parameters are determined throughout the blowdown process using thermal-hydraulic codes such as RELAP and CRAFT2
 - Jet shapes are determined using thermodynamic analyses
 - Target SSCs are identified, including single jet reflections
 - Static initial impulses are applied to all target SSCs
 - Dynamic loads are applied to all SSCs within acceptable distances for two-phase and steam jets per the technical report

Technical Topics of Interest

Section 3.6.2 (continued)

In their technical report, the applicant (continued):

- Commits to protecting all lightly constructed SSCs
- Assesses the potential for resonance within an impinging jet:
 - Pressure ratio between source and ambient fluids must be less than 3.8 per literature (will occur in later stages of blowdown)
 - Source must be within 5 pipe diameters of target per literature (applicant assumes a greater distance for conservatism)
- In cases of resonance:
 - Computes bounding, worst-case oscillatory loads
 - Dramatically higher than loads cited in literature - conservative
 - Computes minimum jet resonance frequencies for given breaks

Technical Topics of Interest

Section 3.6.2 (continued)

In their technical report, the applicant (continued):

- In cases of resonance:
 - Simple structures (pipe supports, whip restraints, jet shields) with resonance frequencies 40% below the jet loading frequency are evaluated using static calculations and dynamic load factors (DLFs)
 - All other structural modal responses with contributions up to a minimum of 500 Hz (plates/shells) and 95% of the peak modal response (beams) are assessed with FE stress modeling
 - Conservatively assumes all modal frequencies are coincident with jet frequency
 - Assumes damping 1% of critical
 - Stress convergence assured via convergence studies
 - Stresses evaluated against applicable standards

Technical Topics of Interest

Section 3.6.2 (continued)

The applicant's jet loading approach is conservative:

- Static and dynamic loads are considered throughout blowdown
- Dynamic loads, in case of resonance, are worst-case
 - In amplitude
 - In matching loading and structural modal frequencies
- Structural response will be converged, and uses conservative 1% damping
- Stresses assessed against applicable standards

Technical Topics of Interest

Section 3.6.3

Leak-Before-Break (LBB) Design

Overview

- LBB is part of piping design acceptance criteria (DAC)
- Use of LBB in DC applications
- Use of LBB for ALWRs discussed in SECY-93-087
- LBB review for EPR addressed PWSCC lessons learned

Technical Topics of Interest

Section 3.6.3

Leak-Before-Break (LBB) Design

Presentation Outline

- Regulatory approach for reviewing leak-before-break (LBB) methodology
- Confirmatory Analysis of Leak-Rate Prediction Procedures
- Confirmatory Analysis of Flaw Stability Analyses Procedures in the Allowable Load Limit (ALL) Diagram
- Overall Conclusions on LBB

Regulatory Requirements and Acceptance Criteria

- 10 CFR Part 50, Appendix A, GDC 4, “Environmental and dynamic effects design bases” states “....However, dynamic effects associated with postulated pipe ruptures in nuclear power units may be excluded from the design basis when analyses reviewed and approved by the Commission demonstrate that the probability of fluid system piping rupture is extremely low with the design basis for the piping...”

- Safety margins for LBB analysis procedure
 - ♦ 10 on leak rate
 - ♦ 2 on crack size

Staff's Review of EPR LBB Methodology

Allowable Load Limit (ALL) methodology was used to bound LBB criteria

- Water hammer, corrosion, creep, fatigue, erosion, environmental conditions, and indirect sources are extremely low causes of pipe rupture
- Deterministic fracture mechanics evaluation has been completed and approved by the staff
- Leak detection systems are sufficiently reliable, redundant, diverse and sensitive, and that margin exists to detect the through-wall flaw used in the deterministic fracture mechanics evaluation


Technical Topics of Interest

Section 3.6.3

Leak-Before-Break (LBB) Design

Review of Critical Technical Issues

Confirmatory Analysis of Leak-Rate Prediction Procedure



Technical Topics of Interest

Section 3.6.3

Leak-Before-Break (LBB) Design




United States Nuclear Regulatory Commission

Protecting People and the Environment

Review of Critical Technical Issues

Confirmatory Analysis of ALL Diagram for Surge-Line Case



Overall Conclusions on LBB

- The staff evaluation concludes on a design specific and piping system specific basis that the acceptance criteria are satisfied, and, therefore, that dynamic effects of pipe rupture may be eliminated from design consideration
- There is one Open Item on Section 3.6.3 LBB Analyses - RAI 467, Question 03.06.02-28

Technical Topics of Interest

Section 3.7.1-Seismic

Design Parameters

Design Ground Motion

- Design Ground Motion is defined by three European Utilities Requirements (EUR) spectra representing soft, medium and hard soil sites plus an additional spectra representing a rock site.
- EUR spectra envelopes RG 1.60 spectra at all frequencies above 3.5 Hz (horiz.) and 0.65 Hz (vert.). The rock spectra envelopes RG 1.60 spectra at frequencies between 18 Hz to 70 Hz.
- Staff Evaluation: The response of Seismic Category I (SC I) structures is based on seismic input covering a broad frequency range. The staff finds the input spectra to be acceptable.

Percentage of Critical Damping Values

- Damping values follow RG 1.61 values except damping values for cable trays in the transverse direction which use 15% damping. Staff accepted 15 percent damping on the basis of testing done on tray systems which demonstrated damping values of 20% and higher.
- Development of in-structure response spectra for the Nuclear Island (NI) used RG 1.61 SSE structural damping instead of OBE damping.
 - ♦ Staff Evaluation: Additional information is needed regarding the state of stress in the NI to justify the used of SSE damping.
 - ♦ **Open Item:** RAI 370, Question 03.07.01-27 requested stress levels be provided which support the use of SSE structural damping.

Technical Topics of Interest

Section 3.7.1-Seismic

Design Parameters

Supporting Media for Seismic Category I Structures

- Multiple soil profiles used for seismic analysis of SC I structures
- Strain compatible shear wave velocities range from 700 ft./s to 9600 ft./s
- Most profiles include variation of properties with depth of soil
- Staff Evaluation: Soil profiles provide a broad range of properties for determining design loads/ISRS and are acceptable.

Technical Topics of Interest

3.7.2-Seismic System Analysis

Seismic Analysis Methods

- Includes time history analysis, response spectrum, and complex frequency response methods.
- Complex frequency response used for seismic analysis of SC I structures and the Nuclear Auxiliary Building (NAB).
- Response spectrum method is used for slab analysis of the NAB and for the vent stack (SC1).
- Time history used to develop seismic loads on mat and for stability analysis of NAB.
- Staff Evaluation: Methods used are appropriate and acceptable

Technical Topics of Interest

3.7.2-Seismic System Analysis

Procedures Used for Analytic Modeling

- Finite element models (FEMs) are used to represent dynamic behavior of SC I structures
- Staff Evaluation:
- Staff asked for verification that modeling of the NI mat/superstructure interface was an accurate representation of the actual building stiffness
- **Open Item:** RAI 371, Question No. 03.07.02-66(b) requested demonstration of modeling compatibility at the NI mat/superstructure interface
- Staff asked for demonstration of dynamic compatibility between SASSI FEM of the NI and ANSYS FEM upon which the SASSI model is based.
- **Open Item:** RAI 371, Question 03.07.02-67 requested comparison of dynamic responses between SASSI model and ANSYS model

Technical Topics of Interest

3.7.2-Seismic System Analysis

Soil Structure Interaction

- Seismic analysis of SC I structures is performed using the subtraction method option of the SASSI computer code
- Dynamic models account for the embedment of each structure.
- Structure-soil-structure interaction effects due to NI seismic response are included in the analysis of structures not supported on the NI common basemat.
- Staff Evaluation:
 - ♦ The tendon gallery extends below the bottom of the NI common basemat and acts as a shear key during a seismic event.
 - ♦ **Open Item:-**RAI 371, Question No. 03.07.02-66 requested it be confirmed that stresses within the shear key meet code allowables.
 - ♦ Questions have been raised by the Defense Nuclear Safety Board regarding the use of the subtraction method for SSI analysis.
 - ♦ **Open Item:-**RAI 489, Question No. 03.07.02-75 requested a demonstration that the subtraction method provides results that are comparable to, or exceed, the results using the direct method of analysis.

Technical Topics of Interest

3.7.2-Seismic System Analysis

Interaction of Non-SC I Structures with SC I Structures

- Non-SC I structures which could interact with SC I structures are the NAB, Access Building (AB) and the Turbine Building (TB)
- Design of the AB and TB are the responsibility of the COL applicant
- COL applicant must demonstrate the seismic response of AB and TB will not impair the ability of SC I SSC's to perform their design basis safety functions
- NAB is designed to have the same seismic margin of safety as that of a SC I structure. Sliding or uplift is allowed providing there is no interaction with an adjacent SC I structure.
- Staff Evaluation:
 - ♦ Requirements for the AB and TB are acceptable to the staff
 - ♦ Regarding the NAB, the staff is waiting for the results of an NAB seismic analysis which needs to demonstrate there is no interaction between the NAB and adjacent SC I structures
 - ♦ **Open Item:** RAI 370, Question No. 03.07.02-64 requested the results of the stability analysis for the NAB

Technical Topics of Interest

3.7.2-Seismic System Analysis

Determination of Dynamic Stability of SC I Structures

- Seismic demands for SC I structures are determined from the SASSI SSI analysis
- Hydrodynamic forces and vertical seismic response is included in the stability evaluation
- Restoring forces include the dead weight of a structure and passive side-wall soil pressures
- The review of computed factor's of safety against sliding and overturning is covered in Section 3.8.
- Staff Evaluation: The methods used for stability analysis are acceptable to the staff

Technical Topics of Interest

3.7.3-Seismic Subsystem Analysis

- Methods of analysis include response spectrum, time history and equivalent static load methods.
- Response spectra development meets RG 1.122 guidance
- Three directions of earthquake motion are considered in accordance with RG 1.92
- Analysis of above ground tanks meets the guidance of SRP 3.7.3
- Staff Evaluation: Methods for subsystem analysis meet RG's and SRP acceptance criteria and are acceptable to the staff.

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.1 and 3.8.2 Containment – “Critical Sections”

- Initial staff review found no documented criteria for identification of critical sections (applicable to all 3.8 sections)
- Applicant developed detailed methodology for selection of critical sections
- Screening of all Cat. I structures based on complementary three-tiered criteria
 - ◆ Qualitative: selects safety-critical sections
 - ◆ Quantitative: numerical algorithm selects most highly stressed sections
 - ◆ Supplemental: engineering judgment to select sufficiently representative sections
- List of critical sections provided
- Staff Evaluation
 - ◆ Acceptable systematic methodology results in appropriate combination of safety-critical, highly stressed, and different types of sections of Cat. I structures within NI and beyond NI
- Open Items
 - ◆ Design of critical sections remains to be completed

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.1 and 3.8.2 Containment – Design and Analysis Procedures

- Issues regarding design and analysis procedures arising from initial review (applicable to all 3.8 sections)
 - ◆ Nonlinear FE model of NI (uplift of basemat, trilinear soil springs) inconsistent with code-based linear design process
 - ◆ 100-40-40 directional combination method for seismic loads not applicable to nonlinear analysis
 - ◆ Unjustified equivalent-static seismic analysis method with “modification factors” less than 1.0
 - ◆ Staff confirmatory seismic analysis of RBIS demonstrated that the method of analysis (3rd bullet above) is not acceptable
- Staff Evaluation - Applicant made acceptable modifications to design/analysis procedures
 - ◆ Superstructure design based on linear model
 - ◆ Basemat model (nonlinear uplift, linear soil springs, time-history seismic analysis)
 - ◆ 3-directional seismic loads combined with SRSS rule (superstructure model) and algebraic summation (basemat model)
 - ◆ Eliminated 100-40-40 rule and “modification factors”

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.1 and 3.8.2 Containment – Other technical issues

- Inadequate evaluation of RCB integrity for hydrogen generation/burn event (75 psi, greater than design pressure 62 psi)
- Concrete cracking effects not adequately accounted for in determining seismic loads and DBA temperature/pressure loads
- ISI program for RCB grouted post-tensioning system inconsistent with RG 1.90 (different pressure test schedule, no force-monitoring of ungrouted test tendons, limited U.S. NPP experience)
- Lack of design details for RCB major steel penetrations
 - ◆ airlocks
 - ◆ equipment hatch
 - ◆ construction opening
 - ◆ fuel transfer tube

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.1 and 3.8.2 Containment – Resolution of other technical issues

- Staff Evaluation
 - ◆ Additional nonlinear FE analyses of RCB (including steel penetrations) demonstrated integrity for hydrogen generation/burn event
 - ◆ Additional FE analyses with explicit modeling of concrete cracking demonstrated seismic loads conservative and RCB design sufficiently robust for possible DBA pressure/temperature force redistributions
 - ◆ Design RCB grouted post-tensioning system follows ASME Code, RG 1.90 (ISI program), and RG 1.107 (grouting procedures) without exceptions
 - ◆ Applicant completed design of RCB major steel penetrations

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.3 Containment Internal Structures

- RBIS structure not physically anchored to RCB but included in global FE model of NI (appropriate modeling of global loads and load transfer)
- RBIS sub-models used in analysis/design for localized abnormal loads
- Initial review identified incomplete evaluation of
 - ◆ RBIS seismic overturning stability
 - ◆ Integrity of liner plate from potential RBIS uplift/rocking/impact
- Nonlinear FE analysis of RBIS demonstrated minimal uplift, bearing pressures on surrounding RCB within code limits, and demonstrated integrity of liner plate (minimal strains)
- Open Item
 - ◆ Staff review of analysis methodology for localized abnormal loads to be completed during review of critical section design

Technical Topics of Interest

3.8 Design of Cat. I Structures



United States Nuclear Regulatory Commission

Protecting People and the Environment

3.8.4 Other Cat. I Structures

Review of Fuel Rack Structural Analysis and Design (Technical Report TN-Rack.0101)

- Spent fuel racks
 - Free standing, submerged in spent fuel pool
 - Aluminum cell tube assembly supported vertically by a bottom base plate with legs and horizontally by a stainless steel frame
 - 17 racks: range between 7x8 to 10x9 tubes per rack
- New fuel racks
 - Laterally braced to NFS vault structure, not submerged in water
 - 2 racks: 7x8 and 8x8 tubes per rack
- Challenges in seismic analysis of spent fuel racks due to highly nonlinear response
 - Sliding, tipping, impact with spent fuel pool walls and floor, impact between racks
 - Fluid-structure interaction
 - Friction between rack legs and spent fuel pool floor
 - Fuel assemblies may rattle inside tubes and impact tube walls
 - Series of LS-DYNA analyses with whole pool multi-rack model (all racks) and individual rack model (used for design)

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.4 Other Cat. I Structures

Review of Fuel Rack Structural Analysis and Design (Cont.)

- **Staff Evaluation**

- ♦ Seismic analyses adequately account for range of base friction coefficients between 0.2 and 0.8
- ♦ Whole pool multi-rack model did not account for interaction between fuel assemblies, water, and tube cell walls
 - Justification needed to demonstrate adequacy of representing fuel assemblies and water inside tube cells by simply lumping the fuel assembly and water mass onto the tube cell walls
- ♦ Effects of tolerances on gaps (e.g., rack to rack and rack to wall) in the seismic analyses were not considered
 - Gap tolerances affect magnitude of hydrodynamic coupling between components and impact forces
- ♦ Stress results for some key structural elements (e.g., aluminum cell tubes, support legs, and rack corner angles) were not provided

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.4 Other Cat. I Structures

Review of Fuel Rack Structural Analysis and Design (Cont.)

- **Open Items**

- ♦ Applicant will modify whole pool multi-rack model to include a simplified representation of the fuel assembly inside the tube cells with water and an additional analysis will be performed for comparison with the existing approach
- ♦ Applicant will perform additional study to evaluate the effects of variation in gaps between components on the seismic response of the racks
- ♦ Applicant will provide additional stress results for key structural components

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.5 Foundations of Cat. I Structures – Seismic Sliding/Overturning Stability Analysis of NI, EPGB, and ESWB

- Methodology for stability analysis described in Sect. 3.7 discussion
- Coefficient of friction limited to 0.5 for sliding
- Incorporated tendon gallery as shear key for NI basemat
- Shear keys credited for sliding analysis of EPGB basemat
- Increased dimensions of ESWB basemat to satisfy stability criteria
- Time-dependent Factors of Safety found to be equal to or greater than 1.1
- Staff Evaluation
 - ◆ Stability evaluation acceptable for NI and EPGB
- Open Items
 - ◆ Stability analysis of ESWB remains to be completed

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.5 Foundations of Cat. I Structures – Differential Soil Settlements and Construction Sequence

- Design of Cat. I foundations needs to account for loads induced by construction sequence and differential soil settlements
- Applicant developed acceptable design criteria and guidance for COL applicants to ensure loads induced by site-specific conditions are bounded by those postulated in the generic design (pre and post-construction phases)
- Postulated construction sequence and soil conditions determine induced loads considered in design (added as separate load cases)
- Detailed guidance for COL applicants
 - ◆ Settlement profiles at different construction and post-construction phases added to FSAR
 - ◆ Specific guidance for COL applicants to estimate site-specific settlement profiles (based on site-specific soil conditions and actual construction sequence) and compare with settlement profiles in FSAR
 - ◆ COL applicants to implement settlement monitoring program

Technical Topics of Interest

3.8 Design of Cat. I Structures

3.8.5 Foundations of Cat. I Structures - Resolution of other technical issues

- Applicant adequately considered seismic soil pressures on sidewalls
 - ◆ SSI analysis
 - ◆ ASCE 4-98 (Wood's elastic solution)
 - ◆ passive pressure capacity of the soil
- Applicant will evaluate soil bearing pressures under basemats to capture Boussinesq effects (stiffer edges, softer interior)
- Open Items
 - ◆ Static and dynamic soil bearing pressures under basemats and dynamic soil pressures on sidewalls and shear keys for NI, ESWB, and EPGB remains to be completed

ACRONYMS



United States Nuclear Regulatory Commission

Protecting People and the Environment

- AB - Access Building
- ALWR - Advanced Light Water Reactor
- ANS - American Nuclear Society
- AOV - Air Operated Valve
- ASCE - American Society of Civil Engineers
- ASME - American Society of Mechanical Engineers
- ASTM - American Society for Testing and Materials
- BTP - Branch Technical Position
- CFD - Computational Fluid Dynamics
- COL - Combined License
- DAC - Design Acceptance Criteria
- DBA - Design-Basis Accident
- D-RAP - Design Reliability Assurance Program
- EPGB - Emergency Power Generating Buildings
- ESWB - Essential Service Water Buildings
- FE - Finite Element
- FSAR - Final Safety Analysis Report
- GDC - General Design Criteria
- HELB - High Energy Line Break
- ISI - Inservice Inspection
- ISRS - Instructure Response Spectra
- IST - Inservice Testing

ACRONYMS



United States Nuclear Regulatory Commission

Protecting People and the Environment

- ITAAC - Inspections, Tests, Analyses, and Acceptance Criteria
- LOCA - Loss of Coolant Accident
- MOV - Motor Operated Valve
- NAB - Nuclear Auxiliary Building
- NFS - New Fuel Storage
- NI - Nuclear Island
- NPP - Nuclear Power Plant
- OBE - Operating Basis Earthquake
- OM - Operations and Maintenance
- PRA - Probabilistic Risk Assessment
- PWSCC - Primary Water Stress Corrosion Cracking
- QME - Qualification of Active Mechanical Equipment
- RAI - Request for Additional Information
- RBIS - Reactor Building Internal Structures
- RCB - Reactor Containment Building
- RG - Regulatory Guide
- SASSI - Structural Analysis Software System Interface
- SER - Safety Evaluation Report
- SSC- Structures, Systems, and Components
- SSE - Safe Shutdown Earthquake


Backup

Technical Topics of Interest

Section 3.6.2 (backup)

ANS 58.2 Standard

- Ignores initial blast waves
- Treats all jets as:
 - ♦ Having uniform plume expansion shapes
 - Non expanding incompressible plume remains constant with distance from source;
 - Compressible plume expands at 10 degree half angle
 - Expanding plume has rapid expansion until 'asymptotic plane' (where pressure is assumed to be atmospheric), and 10 degree expansion angle afterward
 - ♦ Having simplified spatial pressure distributions along the plume, with peak pressures at the centerline
 - ♦ Static (except for rise time at beginning of postulated HELB)



Technical Topics of Interest

Section 3.6.2 (backup)

Blast Waves:


- Short duration transient pressure waves which may be analyzed separately from the ensuing jets
- NEA/CSNI/R (95) 11: Knowledge Base for Emergency Core Cooling System Recirculation Reliability (Feb 1996) repeatedly cites blast waves have caused significant damage in several large scale reactor LOCA tests

Technical Topics of Interest

Section 3.6.2 (backup)

Jet Plumes:

- For high source pressure/external pressure ratios
 - ♦ similar to those at the beginning of a HELB
 - ♦ In this example, a shock wave appears at about 10 L/D (plume distance/jet opening diameter)
 - Not considered in ANS 58.2, which assumes static, and simplified pressure distribution



Schlieren photograph of a jet of air issuing from an axially symmetric convergent nozzle. The Mach number at the exit from the nozzle is unity. The pressure at the exit is 105 times the outside pressure. (Courtesy of NASA Langley Research Center, Va.)


From Wallis and originally from Owczarek

Technical Topics of Interest

Section 3.6.2 (backup)

Jet Plumes:

- For low source pressure/external pressure ratios
 - ♦ Similar to conditions at the end of a HELB blowdown
 - ♦ Jets can travel a long distance near end of blowdown
 - ♦ Note multiple shock wave patterns in cross section
- Conclusion: jet plumes vary significantly throughout a HELB blowdown



Diamond wave patterns from an axisymmetric free jet (similar to the exhaust from a rocket engine). Taken from E. S. Love, C. E. Grigsby, L. P. Lee, and M. J. Woodling, "Experimental and Theoretical Studies of Axisymmetric Free Jets," NASA Tech. Report No. TR R-6, 1959. W is the wavelength of the first diamond.


From Wallis, and originally from Anderson

Technical Topics of Interest

Section 3.6.2 (backup)

Jet Loading:

- Pressures impinging on surfaces are dynamic
 - ♦ Dynamic pressures oscillate about the mean impingement pressure at discrete frequencies
 - ♦ To date, dynamic pressures have been ignored in HELB assessments which use ANS 58.2




From Isozaki and Miyazono, Nuc. Eng. & Des., 96 (1986), based on Japan AERI sponsored measurements

Technical Topics of Interest

Section 3.6.2 (backup)

Jet Loading:

- Dynamic pressures can also be amplified by factors of 2-3 (or perhaps more) when at resonance
 - Resonance occurs when flow speed and distance from the jet opening align at key frequencies fd/U (varies between about 0.3 and 0.5)
 - Literature indicates significant resonance only occurs for $L/D < 10$



From Ho and Nosseir, J. Fluid Mech., 105 (1981), Dynamics of an impinging jet: The feedback phenomenon

Technical Topics of Interest

Section 3.6.2 (backup)

Jet Loading:


- Structures can be damaged significantly by dynamic loading, particularly when structural resonances are aligned with the loading frequency(s)

Technical Topics of Interest

Section 3.6.2 (backup)

Selected Technical Journal Articles and Reports:

- Wallis, G., “The ANSI/ANS Standard 58.2-1988: Two-Phase Jet Model,” ADAMS ML050830344, (15 Sep 2004)
- Ransom, V., “Comments on GSI-191 models for debris generation,” ADAMS ML050830341, (15 Sep 2004)
- NEA/CSNI/R (95) 11: “Knowledge Base for Emergency Core Cooling System Recirculation Reliability” (Feb 1996)
- Joint Reactor Safety Experiments in the Marviken Power Station, Sweden, Summary Report: The Marviken Full Scale Jet Impingement Tests, 4th Series, Sponsored by numerous international organizations including the US-NRC, (March 1982)
- Ho and Nosseir, J. Fluid Mech., 105, “Dynamics of an impinging jet: The feedback phenomenon” (1981)
- 1. Isozaki and Miyazono, Nuc. Eng. & Des., 96, “Experimental study of jet discharging test results under BWR and PWR loss of coolant accident conditions” (1986)




**Presentation to ACRS
U.S. EPR Subcommittee
Design Certification
Application
FSAR Tier 2 Section 9.1
Fuel Storage and Handling**

February 22, 2012



Section 9.1 ACRS Meeting Outline

| Topic | Presenter |
|-------------------------------------------------------------------------------------------------------------------|------------------|
| Overview of U.S. EPR Fuel Storage and Handling System (Section 9.1.1) | P. Thallapragada |
| Spent Fuel Cask Transfer Facility (Section 9.1.4) | P. Thallapragada |
| Overview of Fuel Racks (Sections 9.1.1 and 9.1.2) | I. McInnes |
| Fuel Pool Cooling and Purification System (Section 9.1.3) | G. Ifebuzo |
| Prevention and Mitigation of Fuel Building and Reactor Building Pool Drain Down (Sections 9.1.2, 9.1.3 and 9.1.4) | D. Newton |
| Overhead Heavy Load Handling System (Section 9.1.5) | R. Parler |




Section 9.1.1 Overview of U.S. EPR Fuel Storage and Handling System

Pavan Thallapragada




Overview of the Fuel Storage and Handling System




Similar to Current PWR Operating Plants

Overview of the Fuel Storage and Handling System



Under Pit Spent Fuel Cask Transfer Facility



Design is Unique to the U.S. EPR


Design Bases

- ▶ The following major components are safety-related and designed to Seismic Category I requirements:
 - ◆ New and spent fuel storage racks
 - ◆ Transfer tube, isolation devices and expansion joints
 - ◆ Cask loading pit (CLP) penetration assembly
 - ◆ Spent Fuel Cask Transfer Machine (SFCTM)
 - ◆ Spent Fuel Cask Transfer Facility (SFCTF) fluid and pneumatic systems, up to isolation devices
- ▶ The design of the fuel handling system conforms to the requirements of GDC 2, 5, 61 and 62.
- ▶ Fuel handling components are designed based on ANSI/ANS 57.1, “Design Requirements for Light Water Reactor Fuel Handling Systems.”
 - ◆ Prevention of criticality, protection from physical damage to the fuel assemblies and radiological protection


Section 9.1.4 Spent Fuel Cask Transfer Facility

Pavan Thallapragada

Fuel Building Layout



Fuel Building Section



Spent Fuel Cask Transfer Facility Overview

- ▶ **The SFCTF primarily consists of :**
 - ◆ SFCTM
 - ◆ CLP penetration assembly
 - ◆ SFCTF fluid and pneumatic systems

- ▶ **Operations are conducted at the following stations:**
 - ◆ Lifting station
 - ◆ Handling opening station
 - ◆ Biological lid handling station
 - ◆ Penetration station


SFCTM Description

▶ **The SFCTM is a trolley which moves on rails**

- ◆ **Main purpose is to carry the cask in vertical position between the lifting station and the three workstations in the loading hall.**

▶ **Safety-related function:**

- ◆ **During cask loading, the SFCTM serves as part of the cask loading pit fluid boundary structural support when the cask is docked with the cask loading pit penetration to prevent draining the spent fuel pool (SFP), including during and following a Safe Shutdown Earthquake (SSE).**




SFCTM



Penetration Assembly

- ▶ **The CLP penetration assembly provides a leaktight connection between the cask loading pit and the internal cavity of the cask. It consists of an upper cover at the bottom of the cask loading pit, the penetration, and a lower cover at the lower end of the penetration.**
- ▶ **The CLP penetration assembly connects the internal cavity of the spent fuel cask to the cask loading pit during loading operations so that spent fuel can be loaded into the cask.**
- ▶ **Safety-related function:**
 - ◆ **The CLP penetration assembly serves as part of the cask loading pit fluid boundary to prevent draining the SFP, including during and following a Safe Shutdown Earthquake (SSE).**

Penetration Assembly – Leak Tight Interfaces



SFCTF Fluid and Pneumatic Systems

- ▶ SFCTF fluid and pneumatic systems are located on the SFCTM and in the Fuel Building
 - ◆ Used for filling, draining and drying the cask and the penetration.
 - ◆ Also provide compressed air for pneumatic devices and seal leakage detection.
- ▶ Safety-related function:
 - ◆ During cask loading, the fluid and pneumatic systems serve as part of the cask loading pit fluid boundary to prevent draining the SFP, including during and following a Safe Shutdown Earthquake (SSE).

Spent Fuel Cask


- ▶ **Not within the scope of design certification.**
- ▶ **The COL applicant will provide a spent fuel cask design acceptable for use with the SFCTF prior to initial fuel loading operations.**

SFCTF Operations

Pavan Thallapragada



Placement of the Cask on the SFCTM



Lifting Station
(Outside Fuel Building)




SFCTM

*Not in Design Certification Scope

Moving of SFCTM to Fuel Building Loading Hall



General View of SFCTF Stations in the Fuel Building



SFCTF Operating Advantages and History

- ▶ **The U.S. EPR SFCTF design concept differs from cask loading facilities in U.S. operating fleet; however, the design has evolved from similar facilities in Europe.**
- ▶ **The design was developed in Europe to achieve the following advantages:**
 - ◆ **Preclude a cask-drop accident during lifting that could damage the building, stored fuel, or safety-related equipment.**
 - ◆ **Limit ionizing radiation exposure to plant personnel during cask loading.**
 - ◆ **Limit contamination of exterior cask surfaces.**
 - ◆ **Reduce cask loading time.**
 - ◆ **Reduce effluent and low-level radioactive waste during the cask loading operation.**
- ▶ **Similar SFCTF installed in several P4 and N4 series plants in France and Tihange 2 and 3 in Belgium.**
 - ◆ **It is estimated that about 1,000 loading operations have been successfully performed at French nuclear power plants.**

Sections 9.1.1 and 9.1.2 Overview of Fuel Racks

Ian McInnes

Overview of Fuel Racks


- ▶ Fuel rack design basis
- ▶ Neutron absorber materials
- ▶ Analytical methodology

Design Basis of Fuel Racks

- ▶ Fuel rack modules are based on existing 10 CFR Part 71 transportation and 10 CFR Part 72 dry storage technology
- ▶ TN has been designing and building fuel storage components for 40+ years
- ▶ TN experience includes the fabrication, loading and operation of 740+ dry storage canisters (over 27,000 fuel assemblies)
- ▶ Operational experience includes wet and dry loading of fuel directly applicable to the SFP and new fuel storage racks

Fuel Rack Design

- ▶ Fuel rack modules have rectangular modular construction
- ▶ Loads carried by welded stainless steel frame
- ▶ Fuel compartments are extruded aluminum tubes
- ▶ Poison material is an aluminum metal matrix composite (MMC), which has been in use in wet and dry fuel storage for >5 years




Fuel Rack Design

- ▶ Region 1 cells are formed by MMC neutron absorber material assembled in an egg-crate arrangement to form flux traps contained by an external steel frame and internal straps.
- ▶ Region 2 cells are formed by flat sheets of MMC sandwiched between fuel tubes and contained within a steel frame.
- ▶ Rack design is modular with adjustable feet, optimized to maximize capacity in SFP and New Fuel Storage Facility (NFSF).
 - ◆ In the SFP, rack modules are free standing and not anchored to adjacent modules, pool walls or floor.
 - ◆ In NFSF, rack module details are the same as Region 1, except they are anchored/restrained laterally at the top and bottom to the new fuel vault walls.

SFP Region 1 and 2 Racks

- ▶ SFP configuration has 5 Region 1 and 12 Region 2 rack modules.
- ▶ Racks provide a 10 year storage capacity plus a full core off-load reserve.
- ▶ NFSF contains 2 Region 1 Type modules.



Neutron Absorber Materials

- ▶ MMC is used as the neutron absorbing material for the racks.
- ▶ MMC consists of boron carbide in aluminum or aluminum alloy matrix with no polymer or organic components.
- ▶ TN obtained NRC approval of TN-68 cask for storage (10 CFR 72) and transportation (10 CFR 71) in 2000/2001, which uses MMC as a fixed poison.

Surveillance Program for Neutron Absorber Materials

- ▶ A coupon surveillance program is proposed to monitor MMC performance over life of racks to verify MMC integrity
 - ◆ Coupons are taken from the same production lot as that used for the construction of racks
 - ◆ Prior to immersion in the SFP, coupons are characterized by measuring thickness and B-10 areal density for comparison with subsequent measurements
 - ◆ At least one archive specimen is retained but not immersed in the SFP for later comparison with the irradiated coupons
 - ◆ The coupons are located adjacent to hottest fuel assembly in either an empty fuel compartment in Region 2 or in a space between rack modules
 - ◆ At approximately 2, 4, 6, 8, 10, 15, 20, 25, 30, 40, 50 and 60 years from commissioning, at least one coupon is removed, measured, visually examined, and B-10 areal density measured to monitor any changes in physical properties of the MMC

Safety Analyses Performed for the Rack Design

- ▶ Criticality Analyses
- ▶ Structural/Seismic Analyses
- ▶ Thermal Hydraulic Analyses

Criticality Analysis Criteria

- ▶ **For the rack modules, including the new fuel dry storage racks, sub-criticality is maintained using a combination of flux traps, favorable geometry and fixed poison loading.**
- ▶ **Credit for fuel assembly irradiation (burnup credit), and credit for soluble boron loading in the SFP, are included in the criticality analysis.**

Burnup Credit Methodology

- ▶ Methodology meets the requirements of the latest staff guidance per Interim Staff Guidance (ISG) DSS-ISG-2010-01, Revision 0
 - ◆ Depletion and criticality code bias and uncertainty are accounted for separately
 - ◆ Benchmarking of depletion codes to isotopic assay measurements was performed to justify the use of isotopic concentrations in burn-up credit analysis
 - ◆ Criticality code benchmarks also include burned assembly configurations from NUREG/CR-6979
- ▶ A variety of mis-load configurations are evaluated to determine soluble boron requirements

Criticality Analysis: Computer Codes

- ▶ Criticality calculations conservatively credit 90% of specified minimum B-10 areal density, and inspection statistics during acceptance testing provide minimum B-10 content with 95% probability at 95% confidence
- ▶ Criticality analysis employs the following Codes:
 - ◆ SCALE-4.4 computer code package for burnup credit analysis
 - ◆ 44 Group ENDF/B-V Cross Section Library
 - ◆ SAS2H/ORIGEN-S modules for Depletion Analyses
 - ◆ CSAS25 Module with KENO V(a) for Criticality Analyses
 - ◆ USLSTATS code for upper subcritical limit calculations

Structural/Seismic Analysis Criteria

- ▶ Racks are designed to Seismic Category I requirements and meet the stress limits of ASME BPVC Section III, Division I, Subsection NF-Supports, Class 3.
- ▶ Design, fabrication, and examination of racks are performed in accordance with guidance from NF-3000 (Design), NF-4000 (fabrication) and NF-5000 (examination) of ASME BPVC, Section III, Division I, Subsection NF-Supports, Class 3.
- ▶ Seismic modeling approach represents a significant advance over simplified lumped mass type approaches as it removes many of necessary assumptions/ approximations and explicitly captures 3D effects, fluid coupling, and multi-rack interaction effects.


Seismic Analysis

► Seismic Analysis Model uses LS-DYNA Code

- ◆ Seismic input spectra are based on generic U.S. EPR inputs, broadened by +/- 20% and amplified by 15%.
- ◆ Five (5) sets of time histories were generated from the seismic spectra in accordance with regulatory requirements in Section 3.7.1 of NUREG 0800.
- ◆ Full pool finite element model (FEM) includes 17 individual rack modules and the entire pool water volume is explicitly modeled.



**LS-DYNA full
Pool Model**



**Snapshot of
Pool Sloshing**

Whole Pool Multi-Rack LS-DYNA Model

- ▶ The whole pool multi-rack model accounts for the following phenomena:
 - ◆ Hydrodynamic coupling between adjacent rack modules and between the racks and the pool structure
 - ◆ Structural nonlinearities due to rack sliding and rocking and impacting each other, global rack-to-rack and rack-to-pool interaction effects
 - ◆ Effect of partially loaded racks
- ▶ The water in the gaps between neighboring rack modules, between racks and adjacent pool walls, and above the racks is explicitly modeled to evaluate the effect of fluid pressures on the racks.
- ▶ Non linear multiple time history dynamic analyses is performed for different coefficients of friction between rack feet and pool floor.
- ▶ Results from whole pool model are used for stress evaluation using separate detailed FEM for the governing rack modules.


Thermal Hydraulic Analysis Criteria

- ▶ Maximum SFP bulk water temperature of 120°F for partial and full core offloads with normal active cooling trains available.
- ▶ Maintain minimum water depth above fuel assembly of 23 feet under all conditions.
- ▶ Maximum SFP bulk water temperature of 140°F for partial and full core offloads assuming loss of one active cooling train.
- ▶ Maintain peak fuel cladding temperature below local saturation temperature (240°F).


Thermal Hydraulic Analysis Model

► Full pool model developed using NRC accepted CFD FLUENT Code


- ◆ Detailed model uses over 2.2 million meshes.
- ◆ Pressure drops and fluid structure interactions accounted for.
- ◆ Analysis covers full and partially loaded rack including full core offload.



Temperature Profile



Velocity Distribution



Section 9.1.3 Fuel Pool Cooling and Purification System (FPCPS)

George Ifebuzo

Design Overview of the FPCPS

- ▶ The FPCPS consists of two separate and independent sub-systems:
 - ◆ Fuel Pool Cooling System (FPCS)
 - ◆ Fuel Pool Purification System (FPPS)
- ▶ The required safety-related function is to cool and cover the spent fuel assemblies with water during all storage conditions.
- ▶ FPCPS conforms with guidance and requirements provided in SRP 9.1.3 and RG 1.13 for safety-related spent fuel cooling system design.
- ▶ Designed such that the SFP cannot be inadvertently drained below 10 feet above the top of the active fuel.

Design Overview of the FPCS

- ▶ Removes decay heat from the SFP and maintains $SFP \leq 140^{\circ}F$ (full core offload with single failure).
- ▶ Consists of two SFP cooling trains installed on opposite sides of the Fuel Building – separation limits physical effects of an internal hazard to one train
 - ◆ Each train consists of 2 pumps (in parallel) and 1 heat exchanger
 - ◆ Powered by a separate electrical division of 480V emergency AC power system (Divisions 1 & 4)
 - ◆ Designed with alternate feed provision (Divisions 2 & 3)
 - ◆ Backed by Emergency Diesel Generators (EDGs)

Design Overview of the FPPS

- ▶ Provides containment isolation of the reactor pool purification supply and return lines (safety-related function).
- ▶ Provides filtration and surface skimming of RB pools, FB pools and IRWST to remove radioactive materials, corrosion products and impurities.
- ▶ Provides water transfer capability for the RB pools, FB pools, and the IRWST.
- ▶ Purification loop consists of two parallel purification pumps, one ion-exchanger, and two filters.

Spent Fuel Pool Makeup

▶ SFP Makeup System

- ◆ Makeup water source (~50,000 gallons) contained in transfer compartment or cask loading pit (both Seismic Category I)
- ◆ SFP makeup pump backed by EDGs

▶ Supplemental SFP makeup capability

- ◆ Demineralized water distribution system provides normal makeup to compensate for evaporation
- ◆ Fire water distribution system (600,000 gallons) provides makeup via FB hose station
 - Supply hose station
 - 100% diesel-driven pump provides water flow during SBO conditions
- ◆ IRWST (500,000 gallons) provides borated water makeup (Seismic Category I water source)
- ◆ SFP spray cooling flow provided by two EDG backed sump pumps
- ◆ Makeup water flow from external water source

Sections 9.1.2, 9.1.3 and 9.1.4 Prevention and Mitigation of Fuel Building and Reactor Building Pool Drain Down

Dennis Newton

Drain Down Prevention and Mitigation

▶ Drain Down Prevention Features

- ◆ **FB and RB Pool liners and support structures are Seismic Category I**
 - Includes RPV Refueling Cavity Ring
- ◆ **FB and RB Pool drain pipes and their isolation valves are manual, Quality Group C and Seismic Category I**
 - FB Pool spent fuel storage compartment has no drain pipe
 - Drain lines greater than 2 inch have two isolation valves
- ◆ **FB Pool FPCPS supply and return pipes**
 - Located at least 20 feet above the top of fuel
 - Have siphon breakers
- ◆ **SFCTF Penetration Assembly has double seals and double bellows**
 - Bellows protected from mechanical damage
- ◆ **FB Pool compartment gateways isolated by both a swivel and a slot gate**
 - Bottom of gateways is 2.5 feet above top of fuel
 - Swivel and slot gate are Seismic Category I
- ◆ **SFCTF Penetration Assembly piping/valves are Quality Group C and Seismic Category I**
 - To first normally closed valve
 - To second normally open valve

Drain Down Prevention and Mitigation

▶ Drain Down Detection Features

- ◆ **Leakage monitoring/testing between double leakage barriers**
 - (e.g., between SFCTF Penetration Assembly seals and bellows)
- ◆ **Level sensors provided in all FB and RB Pool compartments**
 - FB Pool spent fuel storage compartment has Class 1E level instrumentation, which alarms in Main Control Room
- ◆ **Drain isolation valves have position indication in Control Room**
- ◆ **Leakage from FB Pool liner is collected and monitored**

Drain Down Prevention and Mitigation

▶ Mitigation – SFCTF Penetration Assembly Double Seal Failure

- ◆ **Seals are located between Penetration Assembly and the Spent Fuel Cask**
- ◆ **Assumptions**
 - Both seals assumed to fail (two passive failures)
 - Cask loading pit gateway open to the FB Pool spent fuel storage compartment
 - Fuel assembly in cask loading pit compartment
 - No makeup water provided
 - However, make-up water at 400 gpm is available via the IRWST and the SFP purification pump
- ◆ **Leak flow rate is approximately 390 gpm**
- ◆ **Fuel assembly can be moved to FB Pool spent fuel storage compartment and cask loading pit swivel gate closed within 30 minutes**
 - Level decrease is about 1 foot in 30 minutes
- ◆ **If leak is not isolated, maximum FB Pool spent fuel compartment drain down is to bottom of gateway and takes 8 hours**
 - Bottom of gateway is 2.5 feet above top of fuel assemblies

Drain Down Prevention and Mitigation

▶ Mitigation – Cask Loading Pit Pipe Failure

- ◆ 6 inch drain and 2 inch penetration assembly pipe cracks
- ◆ Same as double seal failure event except
 - leak rate approximately 75 gpm (combined leak rate)
 - drain down to bottom of gateway and takes >24 hours

Drain Down Prevention and Mitigation

▶ Mitigation – Inadvertent Opening RB Pool Drain Valves

- ◆ Assumes two 6 inch drain valves and 8 inch drain header valve inadvertently opened
- ◆ Assumes no makeup water, however,
 - MHSI pump can provide 600 gpm
 - LPI pump can provide 2200 gpm
 - FPCP pump can provide 400 gpm
 - Suction from IRWST
- ◆ Drain water flows to the IRWST
- ◆ Drain rate about 5000 gpm
- ◆ RB Pool level drops about 7.5 feet in 30 minutes
- ◆ Fuel assembly can be returned to core, fuel transfer pit or a drain valve closed within 30 minutes
- ◆ If RB Pool allowed to completely drain
 - Approx. 13 ft. of water remains above the fuel in reactor vessel
 - Approx. 12 ft. of water remains above any horizontal fuel assembly in transfer pit

Section 9.1.5

Overhead Heavy Load Handling System

Rick Parler

Overhead Heavy Load Handling System

- ▶ A heavy load is defined as a load the weight of which is greater than the combined weight of a single spent fuel assembly and its handling tool.
- ▶ For the U.S. EPR, the weight of a heavy load is ≥ 1730 lbs.
- ▶ Heavy load handling requirements and guidance:
 - ◆ NUREG-0612, “Control of Heavy Loads at Nuclear Power Plants”
 - ◆ NUREG-0554, “Single-Failure-Proof Cranes for Nuclear Power Plants”
 - ◆ ASME NOG-1, “Rules for Construction of Overhead and Gantry Cranes (Top Running Bridge, Multiple Girder)”
 - ◆ ASME NUM-1, “Rules for Construction of Cranes, Monorails, and Hoists (With Bridge or Trolley or Hoist of the Underhung Type)”

Overhead Heavy Load Handling System

▶ Cranes that handle heavy loads are designed as Type I or Type II

◆ Type I

- Designed to handle a critical load
- Designed to remain in place and support the critical load during and after a seismic event
- Does not have to be operational after the event
- Incorporates single-failure-proof features

◆ Type II

- Not used to handle a critical load
- Designed to remain in place with or without the load during a seismic event
- Need not support the load or remain operational after the event
- Single-failure-proof features are not required

Overhead Heavy Load Handling System

▶ Type I – Single-failure-proof design


- ◆ Hoist load path components designed such that any credible failure of a single component will not result in the loss of capability to stop and hold the critical load
- ◆ Critical load – any load whose uncontrolled movement or release could adversely affect safety-related systems required for unit safety or could result in potential offsite exposures in excess of established limits
- ◆ U.S. EPR has 4 single failure proof cranes:
 - Reactor Building polar crane
 - Fuel Building auxiliary crane
 - Fuel Building upper penetration cover hoist
 - Fuel cask biological lid handling hoist

Overhead Heavy Load Handling System

▶ Type I – Single-failure-proof design

- ◆ Critical items for single-failure-proof design are those components located between the load and the source of energy holding the load
 - Hook
 - Wire rope
 - Load blocks
 - Gear train
 - Brakes
- ◆ Design for single-failure-proof is accomplished by use of dual/redundant components and/or doubling the design factors

Overhead Heavy Load Handling System



▶ Type II Cranes

- ◆ Used for lifts over equipment not required to perform a safety function (outage conditions)
- ◆ Makes use of stops and interlocks preventing load handling over safety related equipment
- ◆ Equipment / components are evaluated for the effects of load drop

COL Information Items

- ▶ **A COL applicant will provide site-specific information on the heavy load handling program, including a commitment to procedures for heavy load lifts in the vicinity of irradiated fuel or safe shutdown equipment, and crane operator training and qualification.**

Acronyms and Abbreviations

| | |
|---------------|---------------------------------------------|
| ▶ ANS | American Nuclear Society |
| ▶ ANSI | American National Standards Institute |
| ▶ ASME | American Society Mechanical Engineers |
| ▶ BPVC | Boiler and Pressure Vessel Code |
| ▶ CFD | Computational Fluid Dynamics |
| ▶ CLP | Cask Loading Pit |
| ▶ COL or COLA | Combined Operating License (Applicant) |
| ▶ EDG | Emergency Diesel Generator |
| ▶ FB | Fuel Building |
| ▶ FEM | Finite Element Method |
| ▶ FPCPS | Fuel Pool Cooling and Purification System |
| ▶ FPCS | Fuel Pool Cooling System |
| ▶ FPPS | Fuel Pool Purification System |
| ▶ IRWST | In-Containment Refueling Water Storage Tank |
| ▶ ISG | Interim Staff Guidance |
| ▶ LPI | Low Pressure Injection |

Acronyms and Abbreviations

| | |
|----------------|------------------------------------------|
| ▶ MHSI | Medium Head Safety Injection |
| ▶ MMC | Metal Matrix Composite |
| ▶ NFSF | New Fuel Storage Facility |
| ▶ RB | Reactor Building |
| ▶ SBO | Station Blackout |
| ▶ SFCTF | Spent Fuel Cask Transfer Facility |
| ▶ SFCTM | Spent Fuel Cask Transfer Machine |
| ▶ SFP | Spent Fuel Pool |
| ▶ SRP | Standard Review Plan (NUREG-0800) |
| ▶ SSE | Safe Shutdown Earthquake |



Presentation to the ACRS Subcommittee

AREVA EPR Design Certification Application Review

Safety Evaluation Report with Open Items

Chapter 9.1: Fuel Storage and Handling

February 22, 2012

Staff Review Team

- **Technical Staff**

- ♦ **Tech Reviewer Name: Chris Van Wert**
Branch Name: Reactor Systems
- ♦ **Tech Reviewer Name: Amrit Patel**
Branch Name: Reactor Systems
- ♦ **Tech Reviewer Name: Raul Hernandez**
Branch Name: Balance of Plant
- ♦ **Tech Reviewer Name: Gordon Curran**
Branch Name: Balance of Plant
- ♦ **Tech Reviewer Name: Jim Xu**
Branch Name: Structural Engineering

- **Project Managers**

- ♦ Lead PM Name: Getachew Tesfaye
- ♦ Chapter PM Name: Peter Hearn

Overview of DCA

| SRP Section/Application Section | | No. of Questions | Status |
|---------------------------------|---------------------------------------------------------------|------------------|--------------|
| | | | Number of OI |
| 9.1.1 | Criticality Safety of New and Spent Fuel Storage and Handling | 63 | 10 |
| 9.1.2 | New and Spent Fuel Storage | 41 | 2 |
| 9.1.3 | Fuel Pool Cooling and Purification System | 15 | 2 |
| 9.1.4 | Fuel Handling System | 39 | 19 |
| 9.1.5 | Overhead Heavy Load Handling System | 24 | 1 |
| Totals | | 182 | 34 |

Ch 9.1 OPEN ITEMS

1. RAI 513, Question 09.01.01-53: The applicant needs to provide additional information regarding the neglect of uncertainty quantities including, but not limited to, fuel enrichment and fuel rod pitch.
2. RAI 538, Question 09.01.01-63: The applicant needs to correct an error identified in Footnote (2) of TN-Rack 0101, Table 5-26 which shows a value of 0.5 when 0.05 is intended.
3. RAI 513, Question 09.01.01-56: Additional information is needed to demonstrate that the method for identifying the limiting 36-node burnup-dependent profile can actually produce the most limiting profiles.
4. RAI 513, Question 09.01.01-54: Assurance is needed that the uncertainty will be calculated and that it will be conservatively applied with respect to assembly loading in the SFP.
5. RAI 513, Question 09.01.01-57: Justification should be provided to demonstrate that no significant rack dimensional changes would occur as a result of the horizontal drop accident.

Ch 9.1 OPEN ITEMS

6. RAI 513, Question 09.01.01-58: Issue #5 remains an open item until further clarification is provided regarding placement of fuel assemblies next to fuel storage racks during normal operations.
7. RAI 513, Question 09.01.01-59: The staff notes that there appears to be enough distance to ensure that system reactivity is unaffected by having an assembly in the new fuel elevator for this accident condition, but the applicant needs to either verify that this scenario is not possible or provide an analysis that demonstrates that the minimum soluble boron requirement of 1100 ppm is unaffected.
8. RAI 513, Question 09.01.01-60: Although 1800 pcm provides substantial margin, additional staff review has led the staff to question whether the assumption of five percent initially enriched fuel is limiting for the all-cell portion of Region 2 during an accident. A lower burnup would have a less top peaked fission density which could interact more strongly with the fresh fuel assembly and therefore additional analysis should be performed at lower burnups along the spent fuel loading curve to verify that the 1100 ppm minimum soluble boron limit remains appropriate.

Ch 9.1 OPEN ITEMS

9. RAI 513, Question 09.01.01-61: The applicant does not explain the methodology for maintaining and controlling a minimum of 37 percent B-10 enrichment in the boric acid storage tank.
10. RAI 513, Question 09.01.01-62: The applicant is required to justify the verification of the proper B-10 enrichment for this operation.
11. RAI 526, Question 09.01.02-40: The staff requested that the applicant update FSAR Tier 2, Section 9.1.2 to include the justification of how the seismic classification of the SFCTF is credited to prevent a SFP draindown.
12. RAI 526, Question 09.01.02-41: The staff requested that the applicant justify the absence of a Technical Specification or a license condition that would require at least two of the seismic barriers to be in place while there is no cask attached to the SFCTFS.

Ch 9.1 OPEN ITEMS

13. RAI 526, Question 09.01.03-14: The staff requested that the applicant update FSAR Tier 2, Section 9.1.3 to address the impact on the SFP of an SSE while the SFCTF is in operation.
14. RAI 526, Question 09.01.03-15: The staff requested that the applicant clarify FSAR Tier 2, Section 9.1.3 to indicate the seismic criteria of all the piping and valves that connect with the SFP, and to indicate the elevation of any non-seismic pipe and of its anti-siphon device.
15. RAI 525, Question 09.01.04-21 The staff requested that the applicant clearly define which components are designed to NOG-1 as a single failure proof hoist.
16. RAI 525, Question 09.01.04-29: the staff requested that the applicant provide the following:
 - a. Description of overall dimensions, structural elements (beams, girders, trusses, plates, etc.) and their connections for the SFCTM and the penetration assembly, including sketches.
 - b. Description of the anti-seismic locking devices including their connections with the SFCTM and the structural walls (provide sketches).
 - c. Overall dimensions and structural description of the loading hall (concrete walls and slabs) including sketches.

Ch 9.1 OPEN ITEMS

17. RAI 525, Question 09.01.04-30: The staff requested that the applicant provide the following:
- Description of how specific provisions of ASME NOG-1-2004 are applied to the structural design of the SFCTM.
 - Description of how the Seismic Category I requirements for the SFCTM would be met through the Code provisions.
18. RAI 525, Question 09.01.04-31: The staff requested that the applicant provide the following:
- Description of how specific provisions of ANSI/ANS-57.2-1983 are applied to the design of the fuel assembly; if other codes and standards are referenced for technical requirements, provide a description of the extent to which other codes and standards are applied to the structural design/analysis of the penetration assembly.
 - Description of how the Seismic Category I requirements for the penetration assembly to maintain the leak-tight fluid boundary during and following an SSE would be met through the provisions ANSI/ANS-57.2-1983.
 - Description of how the standard is used to design the various seals to ensure the leaktight fluid boundary of the penetration assembly during and following an SSE, as well as an accident drop of fuel assembly.

Ch 9.1 OPEN ITEMS

19. RAI 525, Question 09.01.04-34: The staff requested that the applicant provide the following:
- Description of the design/analysis procedures and results used for the SFCTM and penetration assembly.
 - Description of the computer models used to establish that the design of the SFCTM and the penetration assembly meet the seismic Category I requirements.
 - Description of how various connections are modeled such as the lateral supports to the SFCTM with concrete walls through the anti-seismic locking devices and the vertical support at the base, as well as the interfaces between the SFCTM and the penetration assembly to ensure the leak tightness during an SSE event.
 - Description of the design/analysis procedures and results used for the loading hall and cast loading pit structures.
20. RAI 525, Question 09.01.04-35: The staff requested that the applicant provide the description of the analysis/design procedures used for the design of the anchors to ensure adequate structural support for the SFCTM when subject to the SSE loads

Ch 9.1 OPEN ITEMS

21. RAI 525, Question 09.01.04-36: The staff requested that the applicant provide the description of applicable acceptance limits in terms of allowable stresses, strains, deformation and other design criteria for the SFCTM, penetration assembly components, seals, and loading hall and cask loading pit structures.
22. RAI 525, Question 09.01.04-37: The staff requested that the applicant provide the following:
- Description of materials used for the SFCTM, penetration assembly components, seals, and loading hall and cask loading pit structures.
 - Description of quality control procedures in place to ensure adequate designs.
 - Description of special construction techniques, if used.
23. RAI 525, Question 09.01.04-38: The staff requested that the applicant provide the following:
- Whether these safety devices and seals are seismically qualified, and to what codes and standards these will be qualified against.
 - Whether any tests will be performed to demonstrate the safety performance of the SFCTF during the normal operation and under SSE loads.

Ch 9.1 OPEN ITEMS

24. RAI 525, Question 09.01.04-21, The staff requested that the applicant define in the FSAR which components and portions of the NOG-1 code are “applicable” or credited as single failure proof.
25. RAI 525, Question 09.01.04-22: The staff requested that the applicant describe any mechanical stops or electric interlocks included with the equipment to prevent movement in an unsafe manner in the FSAR. In addition, the staff requested that the applicant describe how Table 09.01.04-15-6 items provided in the response will be monitored and controlled (i.e., physical limitations, procedurally, etc.) and justify not including this table in the FSAR.
26. RAI 525, Question 09.01.04-23: The staff requested that the applicant identify what abnormal conditions would require an operator to enter the cask loading hall during cask loading operation.

Ch 9.1 OPEN ITEMS

- 27.RAI 525, Question 09.01.04-24: The staff requested that the applicant justify how it intends to credit manual actions of potentially failed equipment to the recovery from the SSE with suspended fuel assembly; also justify the safe use of the FHM, which is Seismic Category II, after the SSE.
- 28.RAI 525, Question 09.01.04-25, the staff requested that the applicant review all components for consistency between classifications in FSAR Tier 1 and FSAR Tier 2 to ensure consistency. The staff also requested that the applicant provide ITAAC for the SFCTF and address the inconsistency
29. RAI 525, Question 09.01.04-26: The staff requested that the applicant address the guidelines of SRP Section 9.1.5.III.3 for safe movement of cask and heavy loads and movement of heavy loads during the SFCTF operation.

Ch 9.1 OPEN ITEMS

30. RAI 534, Question 09.01.04-39: GDC 61 states in part that the design of the fuel storage and handling systems shall have suitable shielding for radiation protection and appropriate containment, confinement, and filtering systems. Sufficient shielding provides protection for workers from the spent fuel so that regulatory limits are not exceeded and overexposures do not occur.
- a. Provide additional information identifying which SFCTF fluid system valves are closed to stop water loss.
 - b. Provide more information on the path the contaminated water takes, whether this water receives treatment before discharging to the environment, and how this minimizes contamination.
 - c. The applicant provided several examples of design features that demonstrate compliance with the requirements of 10 CFR 20.1406 for the SFCTF. Revise chapter 12 of the FSAR to include these features.
 - d. Because welding is required to ensure leak-tightness of the cask, and because the welding work itself can contribute significant occupational dose to the cask loading process, revise the FSAR to describe where and how welding occurs during the cask closing operations. In addition, clarify which lid or cover is welded versus which one may be bolted, and whether the welding or bolting of lids/covers is manual, automatic or remotely operated from the SFCTF.
 - e. Provide in the FSAR the location of radiation monitors around the SFCTF (in the loading hall).
 - f. Table 9.1.4-15-6 has as an interlock the requirement that the iodine extracting ventilation be operable prior to using the SFCTF. Revise the FSAR to include this information, with a description of how this requirement will be implemented.

Ch 9.1 OPEN ITEMS

31. RAI 513, Question 09.01.04-20: the staff requested AREVA to address operating experience considerations associated with refueling cavity seals :
- a. the staff requests the applicant to justify in the FSAR the verification and monitoring of this TS without alarmed level instrumentation in the reactor cavity, and the absence of reactor cavity water level instrumentation that provides level indication and alarm for abnormal conditions (low level and rate of change) both locally and in the main control room.
 - b. The staff requests the applicant to include in FSAR Section 9.1.4.3 a description of the essential elements of the procedures or to make this a commitment for a COL information item. The essential elements should consider directing the COL applicants to establish and implement procedures responding to pool drain down events, performing periodic maintenance and inspection of the cavity ring and other seals in accordance with vendor recommendations, and monitoring cavity leakage.
 - c. The staff requests the applicant to explain in the FSAR the protective measures and design features credited to ensure the movement of core components do not damage the reactor cavity ring. In addition, for illustrative purposes, this figured should be added to the FSAR.
 - d. Because there is no cover plate for protection of the cavity ring and no leak detection of the cavity ring, the staff requests the applicant to provide the analysis that demonstrates a dropped fuel assembly will not result in a leak greater than makeup capability.

Ch 9.1 OPEN ITEMS

32. RAI 525, Question 09.01.04-27: The staff requested that the applicant clearly state what testing will be performed prior to use of the SFCTF.

33. RAI 525, Question 09.01.04-28: The staff requested that the applicant revise the COL information item and interface requirements. The COL information item should instruct the COL applicant to identify an NRC approved cask and demonstrate that the cask can be safely connected to the certified SFCTF and remove spent fuel from the SFP prior to initial fuel load and plant startup.

34. RAI 530, Question 09.01.05-24: The staff requested that the applicant provide in the FSAR the weight of each of the major heavy loads lifted by the FB auxiliary crane, the heavy loads normally handled, the weights of the loads, and the hoist capacities of the SFCTF.



Presentation to the ACRS Subcommittee

Section 9.1.1
Amrit Patel
Reactor Systems Branch

Regulatory Requirements for Section 9.1.1

10CFR50.68(b) in lieu of 10CFR50.68(a)

- ♦ **10CFR50.68(b)(2)** – fresh fuel storage (NFSV)
 - ♦ $k\text{-eff} < 0.95$ at 95/95 when flooded w/ unborated water
- ♦ **10CFR50.68(b)(3)** – optimum moderation (NFSV)
 - ♦ $k\text{-eff} < 0.98$ at 95/95 when filled w/ with low-density hydrogenous fluid
- ♦ **10CFR50.68(b)(4)** – soluble boron credit (fuel pool)
 - ♦ If credit for soluble boron taken,
 - ♦ $k\text{-eff} < 0.95$ at 95/95 when flooded w/ borated water
 - ♦ $k\text{-eff} < 1$ at 95/95 when flooded w/ unborated water

Technical Review Overview

- ◆ Normal & accident conditions for fuel storage
- ◆ Burnup credit
- ◆ Fuel handling considerations
- ◆ Selection of design basis assembly
- ◆ Storage rack design
- ◆ Uncertainty analysis
- ◆ Computer code applicability
- ◆ Criticality code validation

Burnup Credit Review

- ◆ Depletion analysis:
 - ◆ Operating parameters
 - ◆ Limiting axial profile determination
 - ◆ Screening method used
 - ◆ Fuel nodalization for depletion calculation
 - ◆ Depletion uncertainty
- ◆ Criticality code validation:
 - ◆ International Handbook of Evaluated Criticality Safety Benchmark Experiments (IHECSBE) and Commercial Reactor Critical (CRC) data
 - ◆ Staff requested addition of Haut Taux de Combustion (HTC) data
- ◆ NUREG guidance:
 - ◆ NUREG/CR-6801 (Axial profile)
 - ◆ NUREG/CR-6979 (HTC data)
 - ◆ NUREG/CR-6665 (Depletion modeling parameters)
 - ◆ NUREG/CR-6951 (Use of CRC data)

Staff Confirmatory Runs

- ◆ SCALE/TSUNAMI-IP – Criticality experiment applicability to U.S. EPR design
 - ◆ Correlation coefficient calculations
- ◆ USLSTATS – Criticality code validation
 - ◆ Verification of calculated bias and bias uncertainty
- ◆ SCALE/STARBUCS – 1-D nodal depletion
 - ◆ Full burnup and enrichment loading curve verification
- ◆ SCALE/TRITON – 2-D nodal depletion
 - ◆ Burnup and enrichment loading curve verification

Open Items of Interest

Section 9.1.1 – Criticality Safety of New and Spent Fuel Storage and Handling

Limiting burnup profiles

The burnup profile assumed in the criticality analysis is a major factor in determining the reactivity state of the fuel in the SFP. The applicant uses a procedure to create a composite burnup profile through a screening process that was not clear to the staff.

Staff Evaluation

- ♦ The reactivity contribution from the axial ends of the fuel increases with fuel burnup since they are depleted to a lesser extent during operation. The staff is concerned that the applicant's screening process may not result in the identification of limiting burnup profiles with respect to the important axial ends. When determining limiting burnup profiles, weighting toward the axial ends should be considered.

Open Item

- ♦ RAI 513, Question 09.01.01-56 asks for additional information demonstrating that the method for identifying limiting burnup-dependent profiles, can actually produce the most limiting profiles.



Presentation to the ACRS Subcommittee

Section 9.1.2 and 9.1.3

Raul Hernandez

Balance of Plant Branch

9.1.2 New and Spent Fuel Storage

- NFSF – 18’ deep dry storage facility with capacity for 120 fuel assemblies
- SFSF – 47’ 3” deep wet storage facility with capacity for 1247 assemblies
- FB protects the NFSF and the SFSF against natural phenomena and internal or external missiles
- Seismic Category I emergency water makeup system and backup water source

9.1.2 New and Spent Fuel Storage

- SFSF liner leak detection system
- Seismic design prevents pool draindown
 - ◆ SFP walls,
 - ◆ SFP liner,
 - ◆ fuel transfer canal,
 - ◆ Gates between the SFCTF and the SFSF

9.1.2 Open Items

- Open Item 9.1.2 – 41
 - ◆ Staff requested the applicant to justify why there is no regulatory control over the gates credited to prevent SFSF draindown

9.1.3 Fuel Pool Cooling and Purification System

- FPCPS consists of the following separate and independent subsystems:
 - ◆ Fuel pool cooling system (FPCS)
 - ◆ Fuel pool purification system (FPPS)
- FPCPS safety related functions:
 - ◆ SFP decay heat removal
 - ◆ Prevention of pool draindown below the required level for shielding and FPCS operation
 - ◆ SFP makeup to compensate for normal SFP evaporation for up to seven days
 - ◆ Seismic Category I back-up water source for SFP makeup.
 - ◆ Provides isolation of non-safety related piping from the Safety related portions

9.1.3 Open Items

- Open Item 9.1.3-15
 - ♦ The staff requested that the applicant clarify FSAR Tier 2, Section 9.1.3 to indicate the elevation of any non-seismic SF/SF connection and of the anti-siphon devices



Presentation to the ACRS Subcommittee

Section 9.1.4 and 9.1.5

Gordon Curran

Balance of Plant Branch

Fuel Handling System

The fuel handling system (FHS) provides for handling of fuel assemblies from the time new fuel assemblies are received at the plant site until the spent fuel assemblies are stored in the spent fuel pool and removed through the spent fuel cask transfer facility.



Fuel handling system (FHS)

- ♦ Typical design: The main pieces of equipment used for fuel handling operations are the refueling machine, fuel transfer tube facility, new fuel elevator, spent fuel machine, and fuel storage racks

Spent Fuel Cask transfer facility (SFCTF)

- ♦ Unique Design to US: The main pieces of equipment in the SFCTF are the spent fuel cask transfer machine (SFCTM) for movement of the spent fuel cask within the loading hall of the Fuel Building and a penetration assembly for connection of the spent fuel cask to the cask loading pit

Spent Fuel cask transfer facility (SFCTF)



FR008 T2

Technical Topics of Interest

Section 9.1.4 – Fuel handling System

Key review challenges of unique SFCTF:

- Natural Phenomena protection
- Draindown prevention
- Test program

Technical Topics of Interest

Section 9.1.4 – Fuel handling System

Natural Phenomena protection

Natural Phenomena protection features of SFCTF (GDC 2):

- Operates with FB and protected from natural phenomena (except earthquakes)
- Seismic Category I components (SFCTM, penetration assembly)
- SFCTM rails, lateral guides and anti-seismic device
- Penetration assembly is connected with irreversible screws
- Hoists and trolley include single failure proof features
- Interlocks and controls

Open Items

- Define which interlocks provided, single failure proof features, capacities and special tools

Technical Topics of Interest

Section 9.1.4 – Fuel handling System

Draindown prevention

Draindown prevention (GDC 2, 61)

Staff review:

- Fluid retaining components are Seismic Category I
- Exposed fluid retaining surfaces are design to withstand the impact of a drop assembly
- SSCs credited to support draindown prevention are design as Seismic Category I
- Redundant seals with leak detection at interfaces

Open Item 9.1.4-21 and 22

- Describe mechanical stops or electric interlocks

Technical Topics of Interest

Section 9.1.4 – Fuel handling System

Test program

Test Program concern for SFCTF:

The staff needs assurance that the facility has the capability to remove spent fuel once fuel is loaded. Initial cask loading operations may occur many years after plant startup.

- Initial test program
- Col items
- Operating procedures and training
- ITAAC

Open Items

- Define ITP, ITAAC, COL Item and commit to operating procedures

Technical Topics of Interest

Section 9.1.4 – Fuel handling System

Structural Integrity

Key Open Item RAI 525, Question 09.01.04-29

The spent fuel cask transfer facility (SFCTF) includes two pieces of mechanical equipment which are 1) spent fuel transfer machine (SFCTM) and penetration assembly, to ensure safe transfer of spent fuel assemblies from the spent fuel pool into the spent fuel cask. US EPR FSAR Revision 4 Interim, Section 9.1.4.2 (August 31, 2011, Response to RAI 385) provides detailed description of the functional features of the SFCTF and stated that both pieces of the SFCTF equipment be designed as Seismic Category I. However, insufficient information is provided regarding the structural aspects of the SFCTF design. To facilitate the structural review of the SFCTF design, the applicant is requested to provided the following :

- a. Description of overall dimensions, structural elements (beams, girders, trusses, plates, etc.) and their connections for the SFCTM and the penetration assembly, including sketches.
- b. Description of the anti-seismic locking devices including their connections with the SFCTM and the structural walls (provide sketches).

Staff Findings


- The Staff conducted a review and evaluation of the U.S. EPR FSAR, which generated 182 Questions, with 42 remaining as Open Items. Through the use of public meetings, audits and conference calls the open items have been defined and the staff and AREVA have arrived at a common understanding of the requirements that must be satisfied. Presently the staff concludes that resolution of the 34 open items is manageable within the planned schedule. Upon resolving the open items, the Chapter 9.1 U.S. EPR FSAR will provide sufficient information to assist the COL applicant in constructing a U.S. EPR that satisfies the requirements of 10 CFR Part 52.
- Questions?

Presentation to ACRS U.S. EPR Subcommittee Ch. 14 - Verification Programs


Charles W. Tally

**Regional Deputy for Project
Integration and Design Support**

Rockville, Md. February 23, 2012




Chapter 14 Contents



- ▶ **Section 14.1 – Specific Information to be addressed for the Initial Plant Test Program**
- ▶ **Section 14.2 – Initial Plant Test Program For Safety Analysis Reports**
- ▶ **Section 14.3 – Inspections, Tests, Analyses and Acceptance Criteria, and Tier 1**


Section 14.2 – Overview



▶ Section 14.2 – Initial Test Program (ITP) For Safety Analysis Reports

- ◆ U.S. EPR ITP is based on regulatory guidance contained in Regulatory Guide (RG) 1.68 Revision 3.
- ◆ Includes testing of unique EPR design features.
- ◆ Includes transient tests that demonstrate the ability to handle significant plant perturbations.
- ◆ Conduct of test program is responsibility of COL Applicant

Section 14.2 - Definitions



▶ Construction Testing Phase

- ◆ NOT within scope of ITP in FSAR Section 14.2.
- ◆ U.S. EPR final calibration of instrumentation has been relocated from construction testing phase, testing phase described in RG 1.68, to preoperational test phase due to digital interfaces.


▶ Preoperational Testing Phase

- ◆ Begins after completion of construction testing and completes prior to fuel load.

▶ Startup Testing Phase


- ◆ Begins after completion of preoperational testing and completes with moisture carryover or ultimate heat sink testing (whichever occurs last).

Section 14.2 – Preoperational Testing Objectives




- ▶ **Demonstrate structures, systems, and components (SSC) functionality prior to fuel load.**
- ▶ **Exercise and evaluate technical specification surveillance procedures.**
- ▶ **Exercise and evaluate emergency operating procedures.**
- ▶ **Provide permanent plant operating staff experience and “on-the-job” training.**

Section 14.2 – Preoperational Testing Scope




- ▶ **NSSS Support Systems**
- ▶ **Front Line Safety Systems**
- ▶ **Engineered Components**
- ▶ **Civil Components and Systems**
- ▶ **Distributed Utilities**
- ▶ **General Supply Systems**
- ▶ **Power Conversion Systems**
- ▶ **Heating Ventilation and Air Conditioning Systems**
- ▶ **Auxiliary Systems**
- ▶ **Electrical Systems**
- ▶ **I&C Systems**
- ▶ **I&C Functions**
- ▶ **Hot Functional Tests (HFT)**
- ▶ **Individual tests are described in FSAR Section 14.2.12 (173 tests)**

Section 14.2 - Startup Testing Objectives




- ▶ **Achieve an orderly and safe initial fuel load and initial criticality.**
- ▶ **Perform initial heatup and low power physics testing (LPPT).**
- ▶ **Perform orderly safe power ascension.**
- ▶ **Complete testing of SSC functionality that can not be tested without reactor power.**

Section 14.2 – Startup Testing Scope




- ▶ **Initial fuel loading and pre-critical tests**
- ▶ **Initial criticality and low power tests**
- ▶ **Power ascension tests (per RG 1.68)**
 - ◆ **5% reactor power plateau**
 - ◆ **≥10% reactor power plateau**
 - ◆ **25% reactor power plateau**
 - ◆ **50% reactor power plateau**
 - ◆ **75% reactor power plateau**
 - ◆ **≥98% reactor power plateau**
- ▶ **Individual tests are described in FSAR Section 14.2.12 (49 tests)**

Section 14.2 – Unique Features Testing



- ▶ **Control rod drive mechanism (CRDM)**
- ▶ **Control rod position indication**
- ▶ **Fixed self-powered neutron detectors (SPNDs), fabricated from Cobalt-59**
- ▶ **Movable incore neutron measurement “aeroball” system used to calibrate the SPNDs**
- ▶ **Measurement of U.S. EPR “heavy neutron reflector” reactor internals vibration (RG 1.20)**
- ▶ **Natural circulation of the RCS**
- ▶ **Reactor coolant pump standstill seal, designed to isolate the RCP seal in response to SBO event**
- ▶ **Pressurizer surge line test to verify that thermal stratification is within design limits**
- ▶ **Partial trip feature to immediately reduce reactor power to $\leq 50\%$ reactor power and turbine bypass/condenser capacity $\geq 50\%$ reactor power**

Section 14.2 – Transient Testing



- ▶ **Pre-Core Safety Injection Initiated at HZP**
- ▶ **Natural Circulation**
- ▶ **Total Loss of Offsite Power (LOOP)**
- ▶ **Load Swings**
- ▶ **Remote Shutdown Station Checkout**
- ▶ **Loss of Feedwater Pump**
- ▶ **Trip of Generator Main Breaker**
- ▶ **Load Follow**
- ▶ **Turbine-Generator Load Rejection**
- ▶ **LOOP with Plant Auxiliary Loads Supplied in Island Mode**

Section 14.2 – Transient Testing (Continued)

▶ Test #177 - Pre-Core Safety Injection Initiated at HZP

◆ Verifies automatic RCS depressurization using main steam relief train and establishing intermediate head safety injection during HFT.


- Rapid depressurization of steam generators (SGs) is accomplished by rapid cooldown using main steam relief train.
- RCS is cooled and depressurized simultaneously with the SGs.
- Medium head safety injection system injects into RCS and is controlled without filling the pressurizer solid.

▶ Test #196 – Natural Circulation

◆ Verifies that plant establishes natural circulation in the steam generators that is sufficient to remove decay heat.

- Performed at $\leq 5\%$ reactor power.
- Initiates a loss of power to all RCPs.
- Injects boron until shutdown margin is achieved.
- Verifies boron mixing occurred during natural circulation.
- Plant response is monitored for at least 30 minutes without restoring power to RCPs.

Section 14.2 – Transient Testing (Continued)




▶ Test #198 – Total Loss of Offsite Power

- ◆ Verifies ability to stabilize plant at HZP conditions following loss of power to non-safety-related busses.
 - Performed at 10% reactor power.
 - Initiates a turbine-generator trip combined with a simultaneous loss of power to all RCPs (initiates reactor trip).
 - Plant response , especially emergency feedwater, is monitored for at least 30 minutes without restoring power to RCPs.

▶ Test #200 – Load Swings

- ◆ Verifies plant automatic control response to positive and negative step load changes.
 - Performed at 25%, 50%, 75%, and $\geq 98\%$ reactor power.
 - Step turbine load changes are performed with plant controls in automatic, as close to instantaneous as possible, that are as challenging as possible without violating fuel warranty limits.

Section 14.2 – Transient Testing (Continued)




▶ Test #211 - Remote Shutdown Station Checkout

- ◆ Verify ability to perform reactor trip and control a plant cooldown from the remote shutdown station using emergency feedwater.
 - Performed at 25% reactor power.
 - Plant controls are transferred from the MCR to the remote shutdown station, where reactor trip is initiated from outside of MCR.
 - Plant is initially cooled down to hot shutdown and subsequently cooled down to cold standby.

▶ Test #217 – Loss of Feedwater Pump

- ◆ Verify plant response to loss of one of three operating feedwater pumps.
 - Performed at 75% reactor power.
 - Verifies start of standby feedwater pump and response of automatic feedwater controls during the transient.
 - Steam generator levels should remain within normal operating bands during the transient.

Section 14.2 – Transient Testing (Continued)




▶ Test #219 – Trip of Generator Main Breaker

- ◆ **Verify ability of feedwater systems to remove decay heat after reactor trip and loss of all RCPs.**
 - RG 1.68 expected response can be obtained by simultaneously tripping all RCPs (initiates a reactor and turbine-generator trip).
 - Performed at $\geq 98\%$ reactor power.

▶ Test #220 – Load Follow

- ◆ **Verifies plant automatic control response to positive and negative gradual load changes without operator intervention.**
 - Performed at 25%, 50%, 75%, and $\geq 98\%$ reactor power plateaus.
 - Step turbine load changes are performed with plant controls in automatic.
 - Power reduction of 10% during one hour period without operator intervention.
 - Power stabilized for two hours without operator intervention.
 - Power increase of 10% during one hour period without operator intervention.

Section 14.2 – Transient Testing (Continued)




▶ Test #221 – Turbine-Generator Load Rejection

◆ Verifies that the U.S. EPR can power non-safety loads, including RCPs, if the turbine-generator output breakers open and offsite power remains energized.

- Performed at $\geq 98\%$ reactor power.
- Turbine-Generator trip occurs due to loss of all load.
- RCPs remain in-service
- Reactor remains critical.
- Reactor experiences a partial trip and automatic power reduction to $\leq 50\%$ reactor power.
- Main steam that is not used by the turbine-generator is automatically dumped into the main condenser to match T_{avg} – Reactor Power limits.
- Reactor operators restore rod sequence and overlap to Technical Specification limits.
- Reactor power is automatically reduced to 25%.
- Main steam is automatically dumped into the main condenser to match T_{avg} – Reactor Power limits.
- Reactor operators reduce power manually to prepare for turbine-generator synchronization or HZP maintenance conditions.

Section 14.2 – Transient Testing (Continued)




▶ **Test #227 – Loss of Offsite Power with Plant Auxiliary Loads Supplied in “Island Mode”**

◆ **Verifies that the U.S. EPR can power safety and non-safety loads in “island mode” if offsite power is lost, and be able to operate in this mode until the offsite grid is reenergized.**

- Performed at $\geq 98\%$ reactor power.
- Reactor remains critical.
- RCPs remain in-service with power supplied by the U.S. EPR turbine-generator.
- Reactor experiences a partial trip and immediate power reduction to $\leq 50\%$ reactor power.
- Reactor operators restore rod sequence and overlap to technical specification limits.
- Reactor power is automatically reduced to 25%.
- Main steam that is not used by the turbine-generator is automatically dumped into the main condenser to match T_{avg} – Reactor Power limits.


Section 14.2 – Conduct of Test Program



▶ A COL applicant referencing the U.S. EPR FSAR will provide:


- ◆ **A description of ITP administration**
 - Organizational structure
 - Position requirements
- ◆ **Test program schedule and sequence**
- ◆ **Program to ensure that test results are adequately reviewed**
- ◆ **Program that maintains completed test records**
- ◆ **Test procedures, developed from FSAR test abstracts and design limits**
 - Site-specific design
 - Reference design

Chapter 14.3 Outline




- ▶ **14.3 Overview**
- ▶ **14.3.1 Introduction**
- ▶ **14.3.2 System Based Design Descriptions and ITAAC**
- ▶ **14.3.3 Non-system Based Design Descriptions and ITAAC**
- ▶ **14.3.4 Interface Requirements**
- ▶ **14.3.5 Site Parameters**
- ▶ **14.3.6 Design Acceptance Criteria**

Section 14.3 Overview



- ▶ **Section 14.3 of Tier 2 provides the selection criteria and methods used to develop Tier 1**
- ▶ **Tier 1 contains two types of material**
 - ◆ **Certified Design Material (CDM), and**
 - ◆ **Inspection, Tests, Analyses and Acceptance Criteria (ITAAC).**
- ▶ **Tier 1 material is derived from Tier 2 material**


Section 14.3 Overview



▶ Consistent with SRP 14.3 Tier 1 has five chapters

- ◆ Introduction
- ◆ System-based design descriptions and ITAAC
- ◆ Non-system-based design descriptions and ITAAC
- ◆ Interface requirements
- ◆ Site parameters



Section 14.3 Overview- Relationship to COL




► Relationship to COL ITAAC

- ◆ Design Certification (DC) provides interface requirements determined to be safety significant (to support certified portion)
- ◆ COL provides ITAAC for emergency planning and site-specific portions of the facility

Section 14.3 Overview- Relationship to COL




Tier 2 Section 14.3.1 Introduction



► Describes the content of Tier 1 section 1.0


- ◆ Definitions
- ◆ General Provisions
- ◆ Figures Legend
- ◆ List of Abbreviations and Acronyms

Tier 2 Section 14.3.2 System-Based Design Descriptions and ITAAC



- ▶ **Section 14.3.2 is consistent with SRP 14.3**
- ▶ **Tier 1 material is derived from Tier 2 material**
- ▶ **Describes the content and format of Tier 1 Certified Design Material (CDM)**
- ▶ **Describes the content and format of the Tier 1 ITAAC**

Organization of Tier 1 – Chapter 2




- ▶ **2.1 Structures**
- ▶ **2.2 Nuclear Island Systems**
- ▶ **2.3 Severe Accident Systems**
- ▶ **2.4 Instrumentation and Control Systems**
- ▶ **2.5 Electrical Power**
- ▶ **2.6 HVAC Systems**
- ▶ **2.7 Support Systems**
- ▶ **2.8 Steam and Power Conversion Systems**
- ▶ **2.9 Radioactive Waste Management Systems**
- ▶ **2.10 Other Systems**

14.3.2- Selection Process


▶ The selection processes are consistent with SRP 14.3

▶ Two processes used

- ◆ System/Structure/Component (SSC) inclusion based on safety classification
- ◆ Inclusion based on analysis review




14.3.2 - Selection Process (cont'd)




- ▶ **SSCs are reviewed based on classification and function**
 - ◆ **Include features that are directly required to provide the safety-significant function**
 - ◆ **Include primary safety injection flow path piping and equipment required to provide that function**
 - ◆ **Exclude manual valves that are not credited or features provided solely for equipment protection (e.g., system pressure relief valves, vent and drain piping and valves)**

14.3.2 - Selection Process (cont'd)




- ▶ **Analyses are reviewed to identify key performance features and parameters that should be verified**
- ▶ **List of analyses addressed is consistent with SRP 14.3**
 - ◆ **Design Basis Accident Analyses (Chapter 15)**
 - ◆ **Radiation Protection Analyses (Chapter 12)**
 - ◆ **Fire Protection Analyses (Chapter 9.5)**
 - ◆ **Flooding Analyses (Chapter 3)**
 - ◆ **Anticipated Transient Without Scram (ATWS) (Chapter 15)**
 - ◆ **Probabilistic Risk Analysis and Severe Accident (Chapter 19)**
 - ◆ **Unresolved Safety Issues, Generic Safety Issues & TMI Action Items (Chapter 1)**

ITAAC – Features Verification



- ▶ **Systems/Structures/Components (SSC) features provided to meet various functional requirements are discussed in Tier 2.**
- ▶ **Tier 1 verifies the existence of the feature without regard to its purpose described in Tier 2.**

14.3.2 - ITAAC Verify Plant Features




▶ Systems Example

- ◆ Functions Approach (T2): Low Head Safety Injection (LHSI) provides core cooling for large break loss of coolant accident
- ◆ Features Approach (T1): LHSI piping runs from the IRWST, to the reactor coolant system via a pump and heat exchanger
- ◆ Features Approach (T1): LHSI supplies water at x gpm to RCS

▶ Structures Example


- ◆ Functions Approach (T2): The wall between rooms X and Y provides radiation protection (and/or flooding and/or structural support and/or ..)
- ◆ Features Approach (T1): The wall between rooms X and Y is 18” thick.

14.3.2 –System Design Description




- ▶ **The system design description is the certified design material**
- ▶ **Certified design material is in effect for the life of the facility**

14.3.2 - ITAAC



- ▶ **ITAAC are consistent with the certified design material**
- ▶ **Must be satisfied with closure justification submitted to NRC and approved to support 52.103g finding prior to loading fuel**
- ▶ **ITAAC expire following the 52.103g finding**


14.3.2 – ITAAC Format and Content



- ▶ ITAAC content and format are consistent with SRP 14.3


| Commitment | Inspections, Tests, Analyses (ITA) | Acceptance Criteria |
|--------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| The wording in the SDD that describes the feature to be verified. | The specific method the licensee will use to verify that the feature described has been provided. | A description of the acceptance criteria to be satisfied by the ITA. |

Tier 2 Section 14.3.3 Non-System-Based Design Descriptions and ITAAC




- ▶ Tier 1 Chapter 3 addresses non-system-based topics
- ▶ SRP 14.3 provides a suggested list of topics for Chapter 3
 - ◆ Reliability Assurance Program
 - ◆ Initial Test Program
 - ◆ Human Factors Engineering
 - ◆ Pipe Break Hazards
- ▶ Additional Chapter 3 topics developed during the course of the review
 - ◆ Security
 - ◆ Containment Isolation
 - ◆ Plant Cabling
 - ◆ Accident Monitoring Instrumentation
 - ◆ Seismic SSC Interaction
- ▶ The CDM and ITAAC In Chapter 3 follow same approach as system-based CDM and ITAAC in Chapter 2 of Tier 1.

Tier 2 Section 14.3.4 Interface Requirements




- ▶ **Tier 1 Chapter 4 addresses interface requirements**
- ▶ **Safety-significant items to be met by site-specific plant features to satisfy commitments in the certified design**
 - ◆ **Not to be confused with ITAAC developed by the COL applicant that support the COL**
- ▶ **Provides the requirement or a reference to where the requirement exists**
 - ◆ **For example - 4.11 Power Transmission (Main Generator, Main Transformer, Protection & Synchronization) is provided in Section 2.5.6 of Tier 1**

Tier 2 Section 14.3.5 Site Parameters




- ▶ **Tier 1 Chapter 5 addresses safety-significant site parameters**
- ▶ **List of parameters developed based on precedent of prior certified designs and SRP 2.0 (Referenced in SRP 14.3)**
 - ◆ **Examples: Rainfall, snow loads, temperatures, soil properties**
- ▶ **Safety- significant site parameters are to be satisfied by the COL Application, therefore no ITAAC are required.**

Tier 2 Section 14.3.6 Design Acceptance Criteria




- ▶ **Section 14.3.6 provides additional explanation on the use of Design Acceptance Criteria (DAC) in Tier 1 for the U.S. EPR**
- ▶ **Design Acceptance Criteria – Definition**
 - ◆ “A set of prescribed limits, parameters, procedures, and attributes upon which the NRC relies, in a limited number of technical areas, in making a final safety determination to support a design certification.”
- ▶ **Design Acceptance Criteria – Closure processes**
 - ◆ Amendment to DC
 - ◆ COL Application
 - ◆ After COL is issued with DAC. Closeout follows same process as ITAAC.

U.S. EPR DAC



- ▶ **Due to the state of completion of the U.S. EPR design, DAC exist in only two areas as opposed to the four areas listed in SRP 14.3**
- ▶ **SRP 14.3 indicates that DAC may be appropriate on the subjects of: piping design, human factors, digital I&C design, and radiation shielding**
- ▶ **U.S. EPR DAC exist for only two areas: piping design, and human factors engineering**

Acronyms



- ▶ **ATWS** **Anticipated Transient Without Scram**
- ▶ **CDM** **Certified Design Material**
- ▶ **COL** **Combined License**
- ▶ **CRDM** **Control Rod Drive Mechanism**
- ▶ **DAC** **Design Acceptance Criteria**
- ▶ **DC** **Design Certification**
- ▶ **FSAR** **Final Safety Analysis Report**
- ▶ **I&C** **Instrumentation and Controls**
- ▶ **IRWST** **In-Containment Refueling Water Storage Tank**
- ▶ **ITA** **Inspections, Tests and Analyses**
- ▶ **ITAAC** **Inspections, Tests, Analyses and Acceptance Criteria**
- ▶ **ITP** **Initial Test Program**
- ▶ **HFT** **Hot Functional Tests**
- ▶ **HZP** **Hot Zero Power**

Acronyms (cont'd)

- ▶ **LHSI** Low Head Safety Injection
- ▶ **LOOP** Loss of Offsite Power
- ▶ **LPPT** Low Power Physics Testing
- ▶ **MCR** Main Control Room
- ▶ **NSSS** Nuclear Steam Supply System
- ▶ **RCP** Reactor Coolant Pump
- ▶ **RCS** Reactor Coolant System
- ▶ **RG** Regulatory Guide
- ▶ **SPND** Self Powered Neutron Detector
- ▶ **SG** Steam Generator
- ▶ **SBO** Station Blackout
- ▶ **SRP** Standard Review Plan (NUREG-0800)
- ▶ **SSC** Structures, Systems and Components
- ▶ **TMI** Three Mile Island



Presentation to the ACRS Subcommittee

AREVA EPR Design Certification Application Review

Safety Evaluation Report with Open Items

Chapter 14: Verification Programs

February 22-23, 2012

Staff Review Team

- **Technical Staff**

- ♦ **Tech Reviewer Name: Andrea Keim**
Branch Name: Quality Assurance
- ♦ **Tech Reviewer Name: Manas Chakravorty**
Branch Name: Structural Engineering
- ♦ **Tech Reviewer Name: Yiu Law**
Branch Name: Engineering Mechanics
- ♦ **Tech Reviewer Name: John Budzynski**
Branch Name: Reactor Systems
- ♦ **Tech Reviewer Name: Daniel Mills**
Branch Name: Instrumentation, Controls and Electrical Engineering
- ♦ **Tech Reviewer Name: Peter Kang**
Branch Name: Instrumentation, Controls and Electrical Engineering
- ♦ **Tech Reviewer Name: Tarico Sweat**
Branch Name: Balance of Plant

(Staff Review Team Continued)

- ♦ **Tech Reviewer Name:** Jean-Claude Dehmel
Branch Name: Radiation Protection
 - ♦ **Tech Reviewer Name:** James Bongarra
Branch Name: Operator Licensing
 - ♦ **Tech Reviewer Name:** Anne-Marie Grady
Branch Name: Containment and Ventilation
-
- **Project Managers**
 - ♦ Lead PM Name: Getachew Tesfaye
 - ♦ Chapter PM Name: David Jaffe with Tanya Ford

Overview of DCA

| SRP Section/Application Section | | No. of Questions | Status Number of OI |
|---------------------------------|-------------------------------------------------------|------------------|------------------------|
| 14.1 | Specific Information for IPT | 2 | 0 |
| 14.2 | Initial Plant Test Program | 163 | 7 |
| 14.3 | Inspections, Tests, Analyses, and Acceptance Criteria | - | - |
| 14.3.1 | Selection Criteria | 3 | 1 |
| 14.3.2 | Structural and Systems Engineering | 61 | 9 |
| 14.3.3 | Piping Systems and Components | 51 | 4 |

(Overview of DCA Continued)

| SRP Section/Application Section | | No. of Questions | Number of OI |
|----------------------------------------|------------------------------|-------------------------|---------------------|
| 14.3.4 | Reactor Systems | 4 | 0 |
| 14.3.5 | Instrumentation and Controls | 42 | 5 |
| 14.3.6 | Electrical Systems | 34 | 0 |
| 14.3.7 | Plant Systems | 38 | 0 |
| 14.3.8 | Radiation Protection | 3 | 2 |
| 14.3.9 | Human Factors Engineering | 19 | 3 |

(Overview of DCA Continued)

| SRP Section/Application Section | | No. of Questions | Status Number of OI |
|----------------------------------------|----------------------------------------|-------------------------|--------------------------------|
| 14.3.10 | Emergency Planning (Plant-specific) | - | - |
| 14.3.11 | Containment Systems | 5 | 1 |
| 14.3.12 | Physical Security Hardware | 58 | 1 |
| | TOTAL | 475 | 33 |

Presentations

| <u>Presenter</u> | <u>Section</u> | | | | <i>ment</i> |
|----------------------------|----------------|--|--|--|-------------|
| Andrea Keim | 14.2 | | | | |
| Tanya Ford | 14.3.1 | | | | |
| Manas Chakravorty | 14.3.2 | | | | |
| Yiu Law | 14.3.3 | | | | |
| John Budzynski | 14.3.4 | | | | |
| Daniel Mills | 14.3.5 | | | | |
| Peter Kang | 14.3.6 | | | | |
| Tarico Sweat | 14.3.7 | | | | |
| Jean-Claude Dehmel | 14.3.8 | | | | |
| James Bongarra | 14.3.9 | | | | |
| Ann-Marie Grady | 14.3.11 | | | | |
| Red----Presentation | | | | | |
| Black----Available | | | | | |

14.2 – Initial Plant Test Program

Significant Open Item

RAI 527, Question 14.02-163, based on a review of FSAR, Tier 2, Revision 3, Section 14.2.12 and the FSAR mark-up provided in responses to RAI 386, Questions 14.02-151, 14.02-152, 14.02-156, 14.02-158, and 14.02-159, the staff identified a number of inconsistencies in the descriptions of test methods and acceptance criteria for radiation monitoring systems listed in FSAR Tier 2, Sections 14.2.12, 12.3, 11.5.3, 11.5.4, 11.2, 9.4.3, and 9.2.4. The staff's review indicates that the test methods and acceptance criteria do not refer to each system's specific radiation monitor tag numbers in confirming the proper operation of automatic control functions (e.g., isolation or diversion) upon detecting high radioactivity activity levels and departures in process or discharge flow rates, or proper operation of backflow preventers for systems that are not equipped with radiation monitoring instrumentation.

14.3.1 – Selection Criteria

Significant Open Items

RAI 182

- In RAI 182, Question 14.03-10, the staff raised various concerns regarding ITAAC including:
 - ♦ Inconsistencies with ITAAC wording and interpretations
 - ♦ Technical adequacy of ITAAC
 - ♦ Definitions used in ITAAC wording
 - ♦ ITAAC inspectability issues
- The staff reviewed the applicant’s response to RAI 182 and determined the response insufficient in addressing all of the staff’s concerns.
- Follow-up RAI 469, Question 14.03-16 was issued to resolve the remaining concerns that had not been addressed.

(Significant Open Items Continued)

RAI 469

- In RAI 469, Question 14.03-16, the staff requested the applicant to address the remaining ITAAC issues identified by the staff including:
 - ♦ Specificity in ITAAC wording
 - ♦ Improper use and omission of “as-built” terminology in ITAAC
 - ♦ ITAAC inspectability issues
- The staff is still in the process of reviewing the applicant’s draft response to RAI 469 and has provided some feedback to the applicant regarding its response.

(Significant Open Items Continued)

RAI 469 (cont.)

- **Examples of feedback provided to the applicant included:**
 - ♦ ***Lack of specificity*** – There are several instances where the ITAAC requirement simply states that an analysis be performed. However, there's no specificity as to whether this analysis is based on the design or construction of the plant. By saying analysis only and not providing which type, leaves ambiguity in when the analysis is to be performed. AREVA needs to specify this level of detail throughout all of the ITAAC where an analysis is required
 - ♦ ***Inspections of analyses*** – If an analysis is to be based on as-built conditions, there also needs to be an inspection associated with this ITAAC to verify that the work was completed according to the applicable specifications.

(Significant Open Items Continued)

RAI 469 (cont.)

- ♦ **ASME Code related ITAAC** – All ASME Code ITAAC should be consistent throughout all of the ITAAC sections. Therefore, even if an ASME Code related ITAAC appears in different ITAAC Chapters, the wording should be consistent in each reference throughout ITAAC.
- ♦ **Omission of “as-built” terminology** – In several instances the term “as-built” was removed from the ITAAC wording when in some instances it should not have been. If the requirement is to be performed after construction has been completed, then this terminology should be added back to the ITAAC wording for specificity.

(Significant Open Items Continued)

RAI 469 (cont.)

- ♦ **Severe Accident ITAAC** - AREVA quotes from SRP Section 14.3 that “only the existence of the feature needs to be verified by ITAAC.” This argument relates to the Section 14.3 guidance that the level of design detail need only be commensurate with the significance of the safety functions. However, the SRP also suggests that a “graded approach” be used; specifically how to address “specific non-safety-related criteria for inclusion in Tier 1 such as severe accident, ATWS, and fire protection.” The staff believes that additional severe accident ITAAC need to be included for selected safety significant, but non-safety-related equipment (e.g., the Hydrogen Monitoring System which measures the hydrogen concentration in containment during and after the accident).
- **RAI 469, Question 14.03-16, is being tracked as an open item to resolve the staff’s remaining ITAAC concerns.**

14.3.2 - Structural and Systems Engineering Significant Open Items

- RAI 386, Question No. 14.03.02-45: Requested that the applicant address whether all barriers providing protection against the dynamic effects of missiles and pipe breaks had been identified in FSAR Tier 1, Section 2.1 and requested that the applicant include the key dimensions for these barriers. The applicant's response resulted in follow-up RAI 527, Question 14.03.02-57 which noted that barrier dimensions had not been provided and requested that analysis, inspection and acceptance criteria (ITAAC) for internal missiles barriers be included in FSAR Tier 1, Section 2.1 ITAAC tables.
- RAI 386, Question No. 14.03.02-51: Requested that the applicant address the ASME III, Division 2 Code requirements regarding the need to measure strains during the structural integrity test of prototype containments. The applicant's response stated that the containment was not a prototype, but did not provide the basis for its position. This resulted in follow-up RAI 527, Question 14.03.02-59 which asked that specific comparisons between tested prototypes and the EPR containment be provided to support the applicant's position that the EPR containment did not require strain measurements.

14.3.5 - Instrumentation and Controls

Significant Open Items

- RAI 506, Question 14.03.05-27: Requested that the applicant to address how ITAAC describes the Safety Information and Control System (SICS) safety functions and how the safety functions are verified.
- RAI 506, Question 14.03.05-30: Requested that the applicant address how ITAAC verifies the safety functions of the Priority and Actuator Control System (PACS.)
- RAI 506, Question 14.03.05-39: Requested that the applicant explain why single-failure protection ITAAC were not included for some safety-related systems.
- RAI 506, Question 14.03.05-41: Requested that the applicant address how ITAAC describes the self test functionality of the Safety Automation System (SAS) and how this functionality is verified.