



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

May 24, 2012

10 CFR 50.4  
10 CFR 50.55a

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Unit 2  
Facility Operating License No. DPR-52  
NRC Docket No. 50-260

**Subject: American Society of Mechanical Engineers, Section XI Code, Inservice Inspection Program for the Unit 2 Third Ten-Year Inspection Interval, Request for Relief 2-ISI-28**

**Reference:** Letter from the Tennessee Valley Authority to the Nuclear Regulatory Commission, "American Society of Mechanical Engineers Section XI, Inservice Inspection, System Pressure Test, Containment Inspection, and Repair and Replacement Programs – Owner's Activity Report for Cycle 16 Operation," dated July 6, 2011

In accordance with 10 CFR 50.55a(g)(5)(iii), the Tennessee Valley Authority (TVA) is requesting relief from weld examination coverage requirements specified in the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 1995 Edition, 1996 Addenda as amended by 10 CFR 50.55a(b)(2)(xv)(A)(2), for one full penetration weld due to access limitations caused by design. This relief is requested for the Browns Ferry Nuclear Plant (BFN) Unit 2 Third Ten-Year Inspection Interval which began May 25, 2001 and ended May 24, 2011.

Specifically, this request for relief addresses one reactor pressure vessel nozzle-to-vessel (head) full penetration weld and nozzle inside radius section. Ultrasonic examinations were performed on the accessible areas of this weld to the maximum extent practical given the design configuration of the weld. The enclosure to this letter contains the BFN Unit 2, Request for Relief 2-ISI-28, for NRC review and approval.

A047  
NRR


U.S. Nuclear Regulatory Commission  
Page 2  
May 24, 2012

This request for relief is consistent with the BFN Unit 2 Request for Relief 2-ISI-6 and 2-ISI-13 submitted by TVA letter dated May 24, 2002. The NRC approved this request by letter dated April 3, 2003.

TVA requests approval of this request for relief within one year from the date of this letter.

There are no new regulatory commitments contained in this letter. If you have any questions, please contact Tom Hess at (423) 751-3487.

Respectfully,



J.W. Shea  
Manager, Corporate Nuclear Licensing

Enclosure: Browns Ferry Nuclear Plant, Unit 2, American Society of Mechanical Engineers, Section XI Code Inservice Inspection Program, Third Ten-Year Inspection Interval, Request for Relief 2-ISI-28

cc (Enclosure):

NRC Regional Administrator - Region II  
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant

**Enclosure**

**Tennessee Valley Authority  
Browns Ferry Nuclear Plant  
Unit 2**

**American Society of Mechanical Engineers,  
Section XI Code Inservice Inspection Program,  
Third Ten-Year Inspection Interval**

**Request for Relief 2-ISI-28**

---

(See Attached)

## Enclosure

### Tennessee Valley Authority Browns Ferry Nuclear Plant Unit 2

### American Society of Mechanical Engineers, Section XI Code Inservice Inspection Program, Third Ten-Year Inspection Interval

### Request for Relief 2-ISI-28

---

#### **Executive Summary:**

In accordance with 10 CFR 50.55a(g)(5)(iii), the Tennessee Valley Authority (TVA) is requesting relief from weld examination coverage requirements specified in the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI for the N10 Reactor Pressure Vessel (RPV) nozzle-to-vessel full penetration weld and inside radius section ultrasonic (UT) examination performed during the Unit 2 Cycle 16 Refueling Outage in the Third period of the Third Ten-year interval.

The design configuration of the N10 RPV nozzle-to-vessel weld precludes a 100 percent UT examination of the required volume for the full penetration weld of the nozzle listed in the Table of this enclosure. This examination limitation occurs when the ASME Section XI, 2001 Edition, in accordance with 10 CFR 50.55a(b)(2)(xxiv) and, as amended by Sections 10 CFR 50.55a(b)(2)(xv)(B) through 10 CFR 50.55a(b)(2)(xv)(G), and 10 CFR 50.55a(b)(2)(xvi)(A), examination requirements are applied in areas of components constructed and fabricated to early plant designs. Based on a construction permit date prior to January 1, 1971, BFN is exempt from meeting certain provisions of the ASME Code requirements for examination access, to the extent practical, within the limitations of design, geometry, and materials of construction of the components in accordance with 10 CFR 50.55a(g)(4).

A UT examination was performed on the accessible areas to the maximum extent practical given the physical limitations of the subject weld. The subject weld was examined with the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the Performance Demonstration Initiative (PDI) Program, as required by 10 CFR 50.55a(g)(4), and 10 CFR 50.55a(g)(6)(ii)(C).

TVA concludes that performance of a UT examination of essentially 100 percent of the RPV nozzle-to-vessel full penetration weld and inside radius would be impractical. The performance of the UT examination of the subject weld and inside radius to the maximum extent practical provides an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the weld and nozzle. Therefore, pursuant to 10 CFR 50.55a(g)(5)(iii), TVA requests that relief be granted for the BFN Unit 2 third Ten-Year inspection interval.

This relief is requested for the Browns Ferry Nuclear Plant (BFN) Unit 2 Third Ten-Year Inspection Interval which began May 25, 2001 and ended May 24, 2011.

**Unit:** Browns Ferry Nuclear Plant, Unit 2

**System:** Reactor Pressure Vessel (RPV), System 329

**ASME Code Components Affected:** One (1) RPV Nozzle-to-vessel full penetration weld and inside radius as listed in the Table of this enclosure.

**ASME Code Class:** ASME Code Class 1 (Equivalent)

**Section XI Edition:** 1995 Edition, 1996 Addenda in accordance with 10 CFR 50.55a(b)(2)(xxiv) and, as amended by Sections 10 CFR 50.55a(b)(2)(xv)(B) through 10 CFR 50.55a(b)(2)(xv)(G), and 10 CFR 50.55a(b)(2)(xvi)(A), by following the Electric Power Research Institute's (EPRI) Performance Demonstration Initiative (PDI) processes.

**Code Table:** IWB-2500-1

**Code Examination Category:** B-D, "Full Penetration Welds of Nozzles in Vessels"

**Code Examination Item Number:** B3.90, "Reactor Vessel Nozzle-to-Vessel Welds" and B3.100, "Nozzle Inside Radius Section"

**Code Requirement:** ASME Section XI, Table IWB-2500-1, Examination Category B-D, Item No. B3.90 and B3.100 requires a volumetric examination of essentially 100 percent of the weld and adjacent base material and inside radius as depicted in Figure IWB-2500-7(a).

**Code Requirements from Which Relief Is Requested:** Relief is requested from the requirement of ASME Section XI Code, Table IWB-2500-1, Examination Category B-D, Item No. B3.90 and B3.100 to perform essentially 100 percent volumetric examination of the weld and adjacent base material.

**List of Components Associated with this Request for Relief:** Nozzle-to-Vessel Weld N10-NV and N10-IR nozzle inside radius section.

**Reason for Request:** The approximately 2-inch Standby Liquid Control (SLC) nozzle is designed with an integral socket to which the boron injection piping is welded. The Standby Liquid Control nozzle is located in the bottom head of the reactor pressure vessel in an area that is inaccessible for examination from inside of the vessel. The design configuration of the RPV nozzle-to-vessel (N10-NV) weld area precludes a UT examination of essentially 100 percent of the required volume. The component design configuration limits UT examination coverage of the weld to the percentages listed in the Table of this enclosure.

**Proposed Alternative and Basis for Use:** In lieu of the ASME Code required essentially 100 percent volume UT examination, on the nozzle to vessel weld and inside radius section, TVA proposes a UT examination of accessible areas to the maximum extent practical given the component design configuration of the RPV nozzle-to-vessel weld.

**Justification for Granting Relief:** The design configuration of the subject nozzle-to-vessel weld (N10-NV), precludes UT examination of essentially 100 percent of the required examination volume. The inside radius section socket is welded to piping which injects boron. In order to examine the weld in accordance with the ASME Code requirements the RPV would require extensive design modifications. The physical arrangement of the nozzle-to-vessel weld precludes UT examination from the nozzle side. The limitations are inherent to the barrel-type nozzle-to-vessel weld design. The subject weld was examined with the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the Performance Demonstration Initiative (PDI) Program, in accordance with the requirements of the 2001 Edition, in accordance with 10 CFR 50.55a(b)(2)(xxiv) and, as amended by Sections 10 CFR 50.55a(b)(2)(xv)(B) through 10 CFR 50.55a(b)(2)(xv)(G), and 10 CFR 50.55a(b)(2)(xvi)(A), by following the Electric Power Research Institute's (EPRI) PDI processes.

Radiographic examination as an alternate volumetric examination method was determined to be impractical due to the radiological concerns and accessibility to the inside surface of the RPV to place radiographic film. The additional ASME Code coverage gained by radiography is impractical when weighed against the radiological concerns.

Therefore, TVA concludes that performing a UT examination of essentially 100 percent of the nozzle-to-vessel full penetration weld and inside radius section would be impractical. Further, it would also be impractical to perform other volumetric examinations (i.e., radiography) which may increase examination coverage.

A maximum extent practical UT examination of the subject areas and a visual (VT-2) examination of the nozzle area performed each refueling outage in conjunction with the Class 1 System Leakage Test provides an acceptable level of quality and safety. TVA concludes that significant degradation, if present, would be detected during a UT examination performed to the maximum extent practical of the subject weld. The inside radius section socket is welded to piping which injects boron at locations removed from the nozzle thus eliminating any thermal stratification possibility at the nozzle inside radius section. A VT-2 examination of the nozzle area, performed at each refueling outage in conjunction with the Class 1 System Leakage Test will provide for detection of flaws when they are small and can be repaired prior to the SLC nozzle losing the ability to perform its intended function. As a result, reasonable assurance of operational readiness of the subject weld and inside radius section is provided.

Therefore, pursuant to 10 CFR 50.55a(g)(5)(iii), TVA requests that relief be granted for the BFN Unit 2 third Ten-Year ISI inspection interval.

**Implementation Schedule:**

This request for relief is applicable to the third Ten-Year ISI inspection interval for BFN Unit 2 which began May 25, 2001 and ended May 24, 2011. The weld and inside radius section described above is listed in the Table of this enclosure. The weld and inside radius section was examined during the third period (Cycle 16 - Spring 2011) of the third Ten-Year inspection interval.

**Precedent:**

This request for relief is consistent with BFN Unit 2 Request for Relief 2-ISI-6 and 2-ISI-13 submitted by TVA letters dated May 24, 2002 and February 14, 2003. The NRC approved these requests by letter dated April 3, 2003.

**Attachments:**

**Sketch (Attachment A):**

SK-B2202

**Examination Reports (Attachment B):**

Examination Report 2-TVA-N10-NS

Examination Report 2-TVA-N10-IR

Table


Weld Number / (System)	Nominal Pipe Size (NPS)	ISI Drawing Number	Examination Coverage Percent	Unit / Cycle Inspection Performed	Comments
N10-NV / Standby Liquid Control (SLC)	~2"	SK-B2022	86.2%	2/16  (Spring 2011)	Nozzle to vessel weld (SLC Nozzle) examined using a 50 degree shear wave mode and a 60 degree longitudinal wave mode. The examination was conducted from the vessel outside diameter surface. Scanning was restricted due to nozzle configuration. This weld was examined using PDI qualified personnel, procedures, and equipment. The coverage claimed is 86.2%.
N10-IR / (SLC)	~2"	SK-B2022	90%	2/16  (Spring 2011)	Nozzle to vessel weld (SLC Nozzle Inside Radius) examined using a 65 and 70 degree shear wave mode. The examination was conducted from the vessel outside diameter surface. Scanning was restricted due to nozzle configuration. This weld was examined using PDI qualified personnel, procedures, and equipment. The coverage claimed is 90%.



# Attachment A

Inservice Inspection Drawing /Sketch

Sketch SK - B2022



REFERENCE B&W DRAWING NO. 122859E-8 (DETAIL B)  
AND NO. 151963E-0

SKETCH RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	INIT	APPROVED	INIT
0	9-15-92	M. McLAVERTY	K. TROTTER	[Signature]	R. HOOPER	[Signature]

PURPOSE

NOTE: THIS SKETCH IS FOR ISI PROGRAM USE ONLY AND SHALL NOT BE USED FOR FABRICATION/INSTALLATION.

DE DWG NO. A00-5306	PROJECT BROWNS FERRY 2	TITLE WELD DETAIL DIFFERENTIAL PRESSURE AND LIQUID CONTROL NOZZLE N10	SKETCH NO. SK-B2022
------------------------	---------------------------	--	------------------------

# Attachment B

## Weld Examination Reports

Examination Report 2-TVA-N10-NS  
Examination Report 2-TVA-N10-IR

VE-11-019 000150

~~000149~~

*Sub  
0/2/11*



**BROWNS FERRY NUCLEAR U2R16  
REACTOR VESSEL NOZZLE AND CLOSURE HEAD ULTRASONIC EXAMINATIONS  
- FINAL REPORT -**

**SECTION 10**

**N10 NOZZLE-TO-VESSEL WELD  
EXAMINATION DATA**

**This section contains RV N10 Nozzle-To-Vessel Weld UT examination data.**

VE-11-019

000151

000150  
~~000150~~

	<b>Ultrasonic Examination Summary</b> <b>Nozzle to Vessel Welds</b>			Report No.:	2-TVA-N10-NS
				Component ID:	N10-NV
				Work Document:	2-SI-4.6G

Customer:	TVA	Code Category:	B-D	System:	RPV (N10)
Site / Unit:	BFN 2	Code Item:	B3.90	Material:	CS (Clad)
Outage:	U2R16	Code Class:	1	ISO / Drawing(s):	122858 E / SK-B2022

Description:	Nozzle to Shell weld	EPRI Model No.:	IR-2003-31
--------------	----------------------	-----------------	------------

Procedure:	N-UT-78, Rev 0005 (with PDI-UT-6, Rev G).
Title:	PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Welds PDI-UT-6.

Procedure:	54-ISI-850, Rev 007.
Title:	Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (inner 15%).

Calibration Sheets	Exam Data Sheets	Coverage Work Sheets	Coverage Diagrams	Indication Data Sheets	Indication Plot Sheets
CS-01	EDS-01	*See Comments	CDS-01	N/A	N/A
CS-02			CDS-02		
CS-03					

Exam Results:	No Recordable Indications	Exam Volume Coverage Obtained:	86.2%
---------------	---------------------------	--------------------------------	-------

Examiner: Edward P. Mazyck

In accordance with UT Procedure N-UT-78, Rev 0005, with PDI-UT-6, Rev G, and EPRI Model No. IR-2003-31, a 60° axial and circumferential examination was performed from the vessel surface. The radial exam volume includes 100% of the component thickness and the 60° circumferential examination covers the outer 85% of the component thickness.

In accordance with UT Procedure 54-ISI-850-007 and EPRI Model No. IR-2003-31, a 50° Shear wave circumferential exam was performed from the vessel surface. This examination covers the inner 15% of the examination volume.

N10 Axial Scan Modeling Parameters					
Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP
60° Long.	0	2.84	15.38	0.14	12.03





N10 Circumferential Scan Modeling Parameters					
Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP
50° Shear	±(13 to 40)	7.05	8.91	8.20	9.60
60° Long.	±(12 to 90)	2.83	10.26	0.14	10.32

This ultrasonic examination was performed in accordance with the criteria of 10CFR 50.55a (b) (2) (xv) (G) and the minimum coverage requirements of 10CFR 50.55a (b) (2) (xv) (K) was achieved to the maximum extent possible.

This examination was performed using the alternative examination volume defined in Code Case N-613-1 which reduces the area to be examined per IWB-2500-7 (a) and (b) to the weld plus a 1/8" on each side.

This examination satisfies the requirements of ASME Sec. XI 2001 Edition with 2003 Addenda for Appendix VIII, Category B-D, for item number B3.90, figure number IWB 2500-7(a) exam volume, and was performed using ASME Sec XI, Appendix VIII qualified personnel, procedures, and equipment as amended by the Final Rule.

Exam Coverage = 74.6% Circumferential coverage + 97.9% Axial coverage = 86.2% Total Coverage.

Personnel	Name	Signature	Level	Date
Prepared By:	Edward P. Mazyck		II	03-10-2011
AREVA Review:	Paul S. Anderson		III	03-13-2011
Customer:	MATT WELCH		III	3/13/11
ANII:	Samuel Floral			3/24/11

VE-11-019

000152

2/13/11  
000151

## RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-NV

Cal. Sheet No.: CS-01

Report No.: 2-TVA-N10 NS

### Customer Information

Utility: TVA

Site: Browns Ferry

Unit: 2

### Procedure Information

Procedure Number: 54-ISI-850

Rev.: 007

Procedure Title: Manual Ultrasonic Examination BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: KBA	Block Serial No.: BF-18
Model: USN 58Lsw	Model: 892-600	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 01TPCH	Block Thickness ("): 6.125
Range: 12.0"	Nominal Angle (°): 50	Cal. Reflector Type: ID Notch
Velocity (in/uSec): 0.1230	Measured Angle (°): 50	Cal. Reflector Size ("): 0.250
Delay (uSec): 28.1028	Frequency (MHz): 2.25	Cal. Reflector Depth ("): 0.253
Frequency (MHz): 2.25	Mode: Shear	Miscellaneous Information
Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off	No. of Elements: 1	Cable Type: RG-174
Rectify: Fullwave	Element Size: 0.5" X 1.0"	Cable Length ("): 12
Pulse Width (ns): 220	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: N/A	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: Single	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): N/A	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

### Calibration / Verification Information

Calibration Responses				Calibration Time / Date	
Response ("): 9.42	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 45.0	Amp (%): 80	Initial Cal.: 0920 / 03-10-2011	
Verification Responses				Final Cal.: 1505 / 03-10-2011	
Block No.: 6564	Reflector(s): 2" & 5"		Cal. Verification: 1218 / 03-10-2011		
Response ("): 2	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 20.8	Amp (%): 80	Cal. Verification: N/A	
Response ("): 5	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 20.8	Amp (%): 28	Cal. Verification: N/A	

Comments:

Examiner: Edward P. Mazyck

Level: II

Examiner: N/A

Level:

Sign:

Date: 03-10-2011

Sign:

Date:

AREVA Review: Paul S Anderson

Level: III

Date: 03-13-2011

Sign:

VE-11-019 *gub s/m*  
 000153 ~~000152~~



**RPV MANUAL ULTRASONIC  
 CALIBRATION DATA SHEET**

Component ID: N10-NV    Cal. Sheet No.: CS-02    Report No.: 2-TVA-N10 NS

**Customer Information**

Utility: TVA    Site: Browns Ferry    Unit: 2

**Procedure Information**

Procedure Number: N-UT-78    Rev.: 0005  
 Procedure Title: PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Vessel Welds  
 PDI-UT-6

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: RTD	Block Serial No.: BF-18
Model: USN 58Lsw	Model: TRL2-Aust	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 06-755	Block Thickness ("): 6.125
Range: 6.0"	Nominal Angle (°): 60	Cal. Reflector Type: 1/4 T-SDH
Velocity (in/uSec): 0.2300	Measured Angle (°): 61	Cal. Reflector Size ("): 5/16 SDH
Delay (uSec): 15.6234	Frequency (MHz): 2.0	Cal. Reflector Depth ("): 1.5
Frequency (MHz): 2 - 25	Mode: Longitudinal	Miscellaneous Information
Dual: <input checked="" type="checkbox"/> On <input type="checkbox"/> Off	No. of Elements: 2	Cable Type: RG-174
Rectify: Fullwave	Element Size: 2(24 X 42)mm 1/4 λ	Cable Length ("): 12
Pulse Width (ns): 250	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: FD ~ 2.70"	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: D-SBS	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): 3°	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

**Calibration / Verification Information**

Calibration Responses				Calibration Time / Date	
Response ("): 3.152	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 47.8	Amp (%): 80	Initial Cal.: 0910 / 03-10-2011	
Verification Responses				Final Cal.: 1455 / 03-10-2011	
Block No.: 6564	Reflector(s): 2" Radius			Cal. Verification: 1004 / 03-10-2011	
Response ("): 2.1	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 33.0	Amp (%): 80	Cal. Verification: N/A	
Response ("): N/A	<input type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): N/A	Amp (%): N/A	Cal. Verification: N/A	

Comments:  
 Zone 1

Examiner: Edward P. Mazyck Sign: <i>Edward P. Mazyck</i>	Level: II Date: 03-10-2011	Examiner: N/A Sign:	Level: Date:
AREVA Review: Paul S Anderson Sign: <i>Paul S Anderson</i>	Level: III	Date: 03-13-2011	

VE-11-019 2/28/13/14  
000154 ~~000153~~



**RPV MANUAL ULTRASONIC  
CALIBRATION DATA SHEET**

Component ID: N10-NV    Cal. Sheet No.: CS-03    Report No.: 2-TVA-N10 NS

**Customer Information**

Utility: TVA    Site: Browns Ferry    Unit: 2

**Procedure Information**

Procedure Number: N-UT-78    Rev.: 0005  
Procedure Title: PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Vessel Welds PDI-UT-8

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: RTD	Block Serial No.: BF-18
Model: USN 58Lsw	Model: TRL2-Aust	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 06-755	Block Thickness ("): 6.125
Range: 18.0"	Nominal Angle (°): 60	Cal. Reflector Type: ID Notch
Velocity (in/uSec): 0.2300	Measured Angle (°): 61	Cal. Reflector Size ("): 0.250
Delay (uSec): 15.6234	Frequency (MHz): 2.0	Cal. Reflector Depth ("): 0.253
Frequency (MHz): 2 - 25	Mode: Longitudinal	<b>Miscellaneous Information</b>
Dual: <input checked="" type="checkbox"/> On <input type="checkbox"/> Off	No. of Elements: 2	Cable Type: RG-174
Rectify: Fullwave	Element Size: 2(24 X 42)mm 1/4 λ	Cable Length ("): 12
Pulse Width (ns): 250	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: FD ~ 2.70"	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: D-SBS	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): 3°	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

**Calibration / Verification Information**

Calibration Responses				Calibration Time / Date
Response ("): 12.54	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 58.6	Amp (%): 80	Initial Cal.: 0912 / 03-10-2011
Verification Responses				Final Cal.: 1457 / 03-10-2011
Block No.: 6564	Reflector(s): 2" Radius			Cal. Verification: 1110 / 03-10-2011
Response ("): 2.1	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 33.0	Amp (%): 80	Cal. Verification: N/A
Response ("):	<input type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB):	Amp (%):	Cal. Verification: N/A

Comments:  
Zone 2

Examiner: Edward P. Mazyck    Level: II    Examiner:    Level:  
Sign: *Edward P. Mazyck*    Date: 03-10-2011    Sign:    Date:

AREVA Review: Paul S Anderson    Level: III    Date: 03-13-2011  
Sign: *Paul S Anderson*





# UT EXAMINATION DATA SHEET

Nozzle to Shell

Report No.: 2-TVA-N10-NS

Exam Data Sheet No.: EDS-01

Customer Information				Component Information					
Utility: TVA		Plant: Browns Ferry		Unit: 2		Weld ID: N10 NV			
Procedure / Model Information				Exam Surface: Vessel O.D.					
Proc. No.: 54-ISI-850		Rev.: 007		Material: Carbon Steel (Clad)					
Proc. No.: N-UT-78 / PDI-UT-6		Rev.: 0005 / G		Configuration: Nozzle to Shell					
Table's 1 and 2: PDI-UT-6		Rev.: 15		System: RPV					
Modeling Report No.: (EPRI) IR-2003-31				Surface Condition: Smooth					
Examination Information									
L <sub>o</sub> Location: Nozzle Top Dead Center					W <sub>o</sub> Location: Nozzle Boss (RNozzle)				
Exam Start Date: 03-10-2011			Exam Start Time: 1005		Component Temp.: 96°		Thermometer Serial No.: VH-11836		
Exam End Date: 03-10-2011			Exam End Time: 1255		Couplant Type: Ultragel II		Couplant Batch No.: 10325 B		
Search Unit	Scan Surface			Examination Skew Angles	Cal Sheet No.	Exam Sensitivity	Recordable Indications	Limitations	Notes:
	Blend Radius	Nozzle Boss	Vessel						
50° Shear			X	±(13° to 40°)	CS-01	63.0	No	CDS-02	
60° RL			X	±(12° to 90°) (0°)	CS-02	65.8	No	CDS-01 / 02	Zone-1
80° RL			X	±(12° to 90°) (0°)	CS-03	68.6	No	CDS-01 / 02	Zone-2
<b>Notes:</b> Scans performed as directed by EPRI Model Report No.: IR-2003 31. Performed both axial and circumferential weld examinations using 60°RL.									
Examiner: Edward P. Mazyck Sign: <i>[Signature]</i>			Level: II Date: 03-10-2011		Examiner: N/A Sign:			Level: Date:	
AREVA Review: Paul S. Anderson Sign: <i>[Signature]</i>			Level: III Date: 03-13-2011						

VE-11-019  
 000155  
 2011/03/13  
 000154



# UT Coverage Data Sheet

Report No.: 2-TVA-N10-NS

Coverage Data Sheet No.: CDS-01

## Customer Information

Utility: TVA

Plant: Browns Ferry


Unit: 2

## Component Information

Weld ID: N10-NV

Configuration: Nozzle to Shell

### Axial Examination Coverage



#### Axial Examination Coverage

Total examination Area = 18.80 in<sup>2</sup>

Area of Circ. Limitation = 0.4 in<sup>2</sup>

% of Area Examined =

Total Area Inspected / Total Area =

Total Examination Coverage =

$$18.40 \text{ in}^2 / 18.80 \text{ in}^2 = 97.9\%$$

VE-11-019  
000156-000155  
shs/m  
gud



# UT Coverage Data Sheet

Report No.: 2-TVA-N10-NS

Coverage Data Sheet No.: CDS-02

## Customer Information

Utility: TVA

Plant: Browns Ferry


Unit: 2

Weld ID: N10-NV

## Component Information

Configuration: Nozzle to Shell

### Circumferential Examination Coverage








VE-M-019 000157

000156

000158

VE-11-019

		<b>Ultrasonic Examination Summary</b> <b>Nozzle to Vessel Welds</b>			Report No.:	
					2-TVA-N10-NS	
					Component ID:	
		N10-NV		Work Document:		
		2-SI-4.6G				
Customer:	TVA	Code Category:	B-D	System:	RPV (N10)	
Site / Unit:	BFN 2	Code Item:	B3.90	Material:	CS (Clad)	
Outage:	U2R16	Code Class:	1	ISO / Drawing(s):	122858 E / SK-B2022	
Description:	Nozzle to Shell weld			EPRI Model No.:	IR-2003-31	
Procedure:	N-UT-78, Rev 0005 (with PDI-UT-6, Rev G).					
Title:	PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Welds PDI-UT-6.					
Procedure:	54-ISI-850, Rev 007.					
Title:	Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (inner 15%).					
Calibration Sheets	Exam Data Sheets	Coverage Work Sheets	Coverage Diagrams	Indication Data Sheets	Indication Plot Sheets	
CS-01	EDS-01	*See Comments	CDS-01	N/A	N/A	
CS-02			CDS-02			
CS-03						
Results:	No Recordable Indications			Exam Volume Coverage Obtained:	86.2%	
<p>Examiner: Edward P. Mazyck</p> <p>In accordance with UT Procedure N-UT-78, Rev 0005, with PDI-UT-6, Rev G, and EPRI Model No. IR-2003-31, a 60° axial and circumferential examination was performed from the vessel surface. The radial exam volume includes 100% of the component thickness and the 60° circumferential examination covers the outer 85% of the component thickness.</p> <p>In accordance with UT Procedure 54-ISI-850-007 and EPRI Model No. IR-2003-31, a 50° Shear wave circumferential exam was performed from the vessel surface. This examination covers the inner 15% of the examination volume.</p>						
<b>N10 Axial Scan Modeling Parameters</b>						
Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP	
60° Long.	0	2.84	15.38	0.14	12.03	
<b>N10 Circumferential Scan Modeling Parameters</b>						
Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP	
50° Shear	±(13 to 40)	7.05	8.91	8.20	9.60	
60° Long.	±(12 to 90)	2.83	10.26	0.14	10.32	
<p>This ultrasonic examination was performed in accordance with the criteria of 10CFR 50.55a (b) (2) (xv) (G) and the minimum coverage requirements of 10CFR 50.55a (b) (2) (xv) (K) was achieved to the maximum extent possible.</p> <p>This examination was performed using the alternative examination volume defined in Code Case N-613-1 which reduces the area to be examined per IWB-2500-7 (a) and (b) to the weld plus a ½" on each side.</p> <p>This examination satisfies the requirements of ASME Sec. XI 2001 Edition with 2003 Addenda for Appendix VIII, Category B-D, for item number B3.90, figure number IWB 2500-7(a) exam volume, and was performed using ASME Sec XI, Appendix VIII qualified personnel, procedures, and equipment as amended by the Final Rule.</p> <p>Exam Coverage = 74.6% Circumferential coverage + 97.9% Axial coverage = 86.2% Total Coverage.</p>						
Personnel	Name	Signature	Level	Date		
Prepared By:	Edward P. Mazyck		II	03-10-2011		
AREVA Review:	Paul S. Anderson		III	03-13-2011		
Customer:	MATT WELCH		III	3/15/11		
ANII:	Samuel Floral			3/21/11		

000159

VE-11-019



## RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-NV

Cal. Sheet No.: CS-01

Report No.: 2-TVA-N10 NS

### Customer Information

Utility: TVA

Site: Browns Ferry

Unit: 2

### Procedure Information

Procedure Number: 54-ISI-850

Rev.: 007

Procedure Title: Manual Ultrasonic Examination BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)

Manufacturer / Model / Serial	Block Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: KBA	Block Serial No.: BF-18
Model: USN 58Lsw	Model: 892-600	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 01TPCH	Block Thickness ("): 6.125
Range: 12.0"	Nominal Angle (°): 50	Cal. Reflector Type: ID Notch
Velocity (in/uSec): 0.1230	Measured Angle (°): 50	Cal. Reflector Size ("): 0.250
Delay (uSec): 28.1028	Frequency (MHz): 2.25	Cal. Reflector Depth ("): 0.253
Frequency (MHz): 2.25	Mode: Shear	<b>Miscellaneous Information</b>
Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off	No. of Elements: 1	Cable Type: RG-174
Rectify: Fullwave	Element Size: 0.5" X 1.0"	Cable Length ('): 12
Pulse Width (ns): 220	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: N/A	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: Single	Couplant Batch No.: 10325 B
Pulser / Energy: Square	Squint Angle (°): N/A	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

### Calibration / Verification Information

Calibration Responses				Calibration Time / Date
Response ("): 9.42	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 45.0	Amp (%): 80	Initial Cal.: 0920 / 03-10-2011
Verification Responses				Final Cal.: 1505 / 03-10-2011
Block No.: 6564	Reflector(s): 2" & 5"			Cal. Verification: 1218 / 03-10-2011
Response ("): 2	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 20.8	Amp (%): 80	Cal. Verification: N/A
Response ("): 5	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 20.8	Amp (%): 28	Cal. Verification: N/A

Comments:

Examiner: Edward P. Mazyck

Level: II

Examiner: N/A

Level:

Sign:

Date: 03-10-2011

Sign:

Date:

AREVA Review: Paul S Anderson

Level: III

Date: 03-13-2011

Sign:

000160

VE-11-019



# RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-NV

Cal. Sheet No.: CS-02

Report No.: 2-TVA-N10 NS

## Customer Information

Utility: TVA

Site: Browns Ferry

Unit: 2

## Procedure Information

Procedure Number: N-UT-78

Rev.: 0005

Procedure Title: PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Vessel Welds  
PDI-UT-6

UT

Equipment Information

Reference / Cal. Block Info

Manufacturer: Krautkramer

Manufacturer: RTD

Block Serial No.: BF-18

Model: USN 58Lsw

Model: TRL2-Aust

Block Material: CS / Clad

Serial Number: 01C3M3

Serial No.: 06-755

Block Thickness ("): 6.125

Range: 6.0"

Nominal Angle (°): 60

Cal. Reflector Type: ¼ T-SDH

Velocity (in/uSec): 0.2300

Measured Angle (°): 61

Cal. Reflector Size ("): 5/16 SDH

Delay (uSec): 15.6234

Frequency (MHz): 2.0

Cal. Reflector Depth ("): 1.5

Frequency (MHz): 2 - 25

Mode: Longitudinal

## Miscellaneous Information

Dual:  On  Off

No. of Elements: 2

Cable Type: RG-174

Rectify: Fullwave

Element Size: 2(24 X 42)mm ¼ λ

Cable Length ('): 12

Pulse Width (ns): 250

Element Shape: Rectangle

Intermediate Connectors: 0

Reject (%): 0

Focusing: FD ~ 2.70"

Couplant Type: Ultragel II

PRF / PRR Mode: AutoHigh

Search Unit Configuration: D-SBS

Couplant Batch No.: 10325 B

Pulsar / Energy: Square

Squint Angle (°): 3°

Thermometer S/N: VH-11836

Voltage (V): 450

Wedge Radius: N/A

Cal. Block Temp (° F): 76

Damping (Ω): 500

Wedge Skew: N/A

## Calibration / Verification Information

### Calibration Responses

### Calibration Time / Date

Response ("): 3.152

 MP  Depth

Gain (dB): 47.8

Amp (%): 80

Initial Cal.: 0910 / 03-10-2011

### Verification Responses

Final Cal.: 1455 / 03-10-2011

Block No.: 6564

Reflector(s): 2" Radius

Cal. Verification: 1004 / 03-10-2011

Response ("): 2.1

 MP  Depth

Gain (dB): 33.0

Amp (%): 80

Cal. Verification: N/A

Response ("): N/A

 MP  Depth

Gain (dB): N/A

Amp (%): N/A

Cal. Verification: N/A

Comments:

Zone 1

Examiner: Edward P. Mazyck

Level: II

Examiner: N/A

Level:

Sign:

Date: 03-10-2011

Sign:

Date:

AREVA Review: Paul S Anderson

Level: III

Date: 03-13-2011

Sign:

000161

VE-11-019



# RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-NV

Cal. Sheet No.: CS-03

Report No.: 2-TVA-N10 NS

Customer: [REDACTED]

Utility: TVA

Site: Browns Ferry

Unit: 2

Procedure Information

Procedure Number: N-UT-78

Rev.: 0005

Procedure Title: PDI Generic Procedure for the Manual Ultrasonic Examination of Reactor Pressure Vessel Welds  
PDI-UT-6

Manufacturer Information	Block / Unit Information	References / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: RTD	Block Serial No.: BF-18
Model: USN 58Lsw	Model: TRL2-Aust	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 06-755	Block Thickness ("): 6.125
Range: 18.0"	Nominal Angle (°): 60	Cal. Reflector Type: ID Notch
Velocity (in/uSec): 0.2300	Measured Angle (°): 61	Cal. Reflector Size ("): 0.250
Delay (uSec): 15.6234	Frequency (MHz): 2.0	Cal. Reflector Depth ("): 0.253
Frequency (MHz): 2 - 25	Mode: Longitudinal	Simultaneous Information
Dual: <input checked="" type="checkbox"/> On <input type="checkbox"/> Off	No. of Elements: 2	Cable Type: RG-174
Rectify: Fullwave	Element Size: 2(24 X 42)mm ¼ λ	Cable Length ('): 12
Pulse Width (ns): 250	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: FD ~ 2.70"	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: D-SBS	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): 3°	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

Calibration / Verification Information

Calibration Responses				Calibration Time / Date	
Response ("): 12.54	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 58.6	Amp (%): 80	Initial Cal.: 0912 / 03-10-2011	
Verification Responses				Final Cal.: 1457 / 03-10-2011	
Block No.: 6564	Reflector(s): 2" Radius		Cal. Verification: 1110 / 03-10-2011		
Response ("): 2.1	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 33.0	Amp (%): 80	Cal. Verification: N/A	
Response ("): [REDACTED]	<input type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): [REDACTED]	Amp (%): [REDACTED]	Cal. Verification: N/A	

Comments:  
Zone 2

Examiner: Edward P. Mazyck

Level: II

Examiner:

Level:

Sign: *Edward P. Mazyck*

Date: 03-10-2011

Sign:

Date:

AREVA Review: Paul S Anderson

Level: III

Date: 03-13-2011

Sign: *Paul S Anderson*



# UT EXAMINATION DATA SHEET

Nozzle to Shell

Report No.: 2-TVA-N10-NS

Exam Data Sheet No.: EDS-01

Utility: TVA	Plant: Browns Ferry	Unit: 2	Weld ID: N10 NV
Exam Surface: Vessel O.D.			Material: Carbon Steel (Clad)
Proc. No.: 54-ISI-850	Rev.: 007		Configuration: Nozzle to Shell
Proc. No.: N-UT-78 / PDI-UT-6	Rev.: 0005 / G		System: RPV
Table's 1 and 2: PDI-UT-6	Rev.: 15		Surface Condition: Smooth
Modeling Report No.: (EPRI) IR-2003-31			

<b>Examination Information</b>	
L <sub>0</sub> Location: Nozzle Top Dead Center	W <sub>0</sub> Location: Nozzle Boss (RNozzle)
Exam Start Date: 03-10-2011	Exam Start Time: 1005
Exam End Date: 03-10-2011	Exam End Time: 1255
Component Temp.: 96°	Thermometer Serial No.: VH-11836
Couplant Type: Ultragel II	Couplant Batch No.: 10325 B

Search Unit	Scan Surface			Examination Skew Angles	Cal Sheet No.	Exam Sensitivity	Recordable Indications	Limitations	Notes:
	Blend Radius	Nozzle Boss	Vessel						
50° Shear			X	±(13° to 40°)	CS-01	63.0	No	CDS-02	
60° RL			X	±(12° to 90°) (0°)	CS-02	65.8	No	CDS-01 / 02	Zone-1
60° RL			X	±(12° to 90°) (0°)	CS-03	68.6	No	CDS-01 / 02	Zone-2

**Notes:**  
 Scans performed as directed by EPRI Model Report No.: IR-2003 31.  
 Performed both axial and circumferential weld examinations using 60°RL.

Examiner: Edward P. Mazyck Sign: <i>Edward P. Mazyck</i>	Level: II	Date: 03-10-2011	Examiner: N/A Sign:	Level:	Date:
AREVA Review: Paul S. Anderson Sign: <i>Paul S. Anderson</i>	Level: III	Date: 03-13-2011			

000162 VE-11-019





# UT Coverage Data Sheet

Report No.: 2-TVA-N10-NS

Coverage Data Sheet No.: CDS-01

## Customer Information

Utility: TVA

Plant: Browns Ferry


Unit: 2

## Component Information

Weld ID: N10-NV

Configuration: Nozzle to Shell

### Axial Examination Coverage



#### Axial Examination Coverage

Total examination Area = 18.80 in<sup>2</sup>

Area of Circ. Limitation = 0.4 in<sup>2</sup>

% of Area Examined =

Total Area Inspected / Total Area =

Total Examination Coverage =

$$18.40 \text{ in}^2 / 18.80 \text{ in}^2 = 97.9\%$$

000163 VE-11-019



# UT Coverage Data Sheet

Report No.: 2-TVA-N10-NS

Coverage Data Sheet No.: CDS-02

## Customer Information

Utility: TVA

Plant: Browns Ferry


Unit: 2

Weld ID: N10-NV

## Component Information

Configuration: Nozzle to Shell

### Circumferential Examination Coverage



000164 VE-11-019




**BROWNS FERRY NUCLEAR U2R16  
REACTOR VESSEL NOZZLE AND CLOSURE HEAD ULTRASONIC EXAMINATIONS  
- FINAL REPORT -**

**SECTION 11**

**N10 NOZZLE INNER RADIUS REGION  
EXAMINATION DATA**

**This section contains RV N10 Inner Radius Region UT examination data.**

	<b>Ultrasonic Examination Summary</b> <b>Inner Radius</b>			Report No.:	2-TVA-N10-IR
				Component ID:	N10-IR
				Work Document:	2-SI-4.6G
Customer:	TVA	Code Category:	B-D	System:	RPV (N10)
Site / Unit:	BFN 2	Code Item:	B3.100	Material:	CS (Clad)
Outage:	U2R16	Code Class:	1	ISO / Drawing(s):	122858 E / SK-B2022
Description:	Nozzle Inside Radius Section			EPRJ Model No.:	IR-2004-43
Procedure:	54-ISI-850, Rev 007				
Title:	Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (inner 15%).				

Calibration Sheets	Exam Data Sheets	Coverage Work Sheets	Coverage Diagrams	Indication Data Sheets	Indication Plot Sheets
CS-01	EDS-01	See Note 1	N/A	N/A	N/A
CS-02					





**Exam Results:** No Recordable Indications      **Exam Volume Coverage Obtained:** 90%

In accordance with UT Procedure 54-ISI-850-007 and EPRJ Model No. IR-2004-43, a 65° and 70° Shear wave Inner Radius examinations were performed from the vessel O.D. surface.

Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP
65° / Shear	±(1 to 10)	13.85"	15.54"	14.14"	16.07"
70° / Shear	±(2 to 23)	2.94"	15.54"	2.30"	16.07"


(1) Reference EPRJ Report IR-2004-43 for exam volume and coverage.

This examination satisfies the requirements of ASME Sec. XI 2001 Edition with 2003 Addenda for Appendix VIII, Category B-D, for item number B3.100, figure number IWB 2500-7(a) exam volume, and was performed using ASME Sec XI, Appendix VIII qualified personnel, procedures, and equipment as amended by the Final Rule.

Personnel	Name	Signature	Level	Date
Prepared By:	Edward P. Mazyck		II	03-10-2011
AREVA Review:	Paul S. Anderson		III	03-13-2011
Customer:	MATT WELCH		III	3/15/11
ANII:	Sam Howard			3/21/11

VE-11-020

000167

		<b>RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET</b>			
		<b>Component ID: N10-IR</b>		<b>Cal. Sheet No.: CS-01</b>	<b>Report No.: 2-TVA-N10-IR</b>
<b>Customer Information</b>					
<b>Utility: TVA</b>		<b>Site: Browns Ferry</b>		<b>Unit: 2</b>	
<b>Procedure Information</b>					
<b>Procedure Number: 54-ISI-850</b>			<b>Rev.: 007</b>		
<b>Procedure Title: Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)</b>					
<b>UT Instrument Information</b>		<b>Search Unit Information</b>		<b>Reference / Cal. Block Info</b>	
<b>Manufacturer: Krautkramer</b>		<b>Manufacturer: KBA</b>		<b>Block Serial No.: BF-18</b>	
<b>Model: USN 58Lsw</b>		<b>Model: 892-600</b>		<b>Block Material: CS / Clad</b>	
<b>Serial Number: 01C3M3</b>		<b>Serial No.: 01TPCJ</b>		<b>Block Thickness ("): 6.125</b>	
<b>Range: 18.0"</b>		<b>Nominal Angle (°): 65</b>		<b>Cal. Reflector Type: ID Notch</b>	
<b>Velocity (in/uSec): 0.1230</b>		<b>Measured Angle (°): 65</b>		<b>Cal. Reflector Size ("): 0.250</b>	
<b>Delay (uSec): 14.7300</b>		<b>Frequency (MHz): 2.25</b>		<b>Cal. Reflector Depth ("): 0.253</b>	
<b>Frequency (MHz): 2.25</b>		<b>Mode: Shear</b>		<b>Miscellaneous Information</b>	
<b>Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off</b>		<b>No. of Elements: 1</b>		<b>Cable Type: RG-174</b>	
<b>Rectify: Fullwave</b>		<b>Element Size: 0.5" X 1.0"</b>		<b>Cable Length ("): 12</b>	
<b>Pulse Width (ns): 220</b>		<b>Element Shape: Rectangle</b>		<b>Intermediate Connectors: 0</b>	
<b>Reject (%): 0</b>		<b>Focusing: N/A</b>		<b>Couplant Type: Ultragel II</b>	
<b>PRF / PRR Mode: AutoHigh</b>		<b>Search Unit Configuration: Single</b>		<b>Couplant Batch No.: 10325 B</b>	
<b>Pulsar / Energy: Square</b>		<b>Squint Angle (°): N/A</b>		<b>Thermometer S/N: VH-11836</b>	
<b>Voltage (V): 450</b>		<b>Wedge Radius: N/A</b>		<b>Cal. Block Temp (° F): 76</b>	
<b>Damping (Ω): 500</b>		<b>Wedge Skew: N/A</b>			
<b>Calibration / Verification Information</b>					
<b>Calibration Responses</b>				<b>Calibration Time / Date</b>	
<b>Response ("): 13.77</b>		<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	<b>Gain (dB): 53.0</b>	<b>Amp (%): 80</b>	<b>Initial Cal.: 0930 / 03-10-2011</b>
<b>Verification Responses</b>				<b>Final Cal.: 1508 / 03-10-2011</b>	
<b>Block No.: 6564</b>		<b>Reflector(s): 2" &amp; 5"</b>		<b>Cal. Verification: 1256 / 03-10-2011</b>	
<b>Response ("): 2"</b>		<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	<b>Gain (dB): 18.8</b>	<b>Amp (%): 80</b>	<b>Cal. Verification: N/A</b>
<b>Response ("): 5"</b>		<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	<b>Gain (dB): 18.8</b>	<b>Amp (%): 28</b>	<b>Cal. Verification: N/A</b>
<b>Comments:</b> Min. MP = 14.14" Max MP = 16.07"					
<b>Examiner: Edward P. Mazyck</b> Sign: <i>Edward P. Mazyck</i>		<b>Level: II</b> <b>Date: 03-10-2011</b>	<b>Examiner: N/A</b> Sign:		<b>Level:</b> <b>Date:</b>
<b>AREVA Review: Dan Langenfeld</b> Sign: <i>Dan Langenfeld</i>		<b>Level: III</b>		<b>Date: 03-13-2011</b>	



**RPV MANUAL ULTRASONIC  
CALIBRATION DATA SHEET**

Component ID: N10-IR      Cal. Sheet No.: CS-02      Report No.: 2-TVA-N10-IR

**Customer Information**

Utility: TVA      Site: Browns Ferry      Unit: 2

**Procedure Information**

Procedure Number: 54-ISI-850      Rev.: 007

Procedure Title: Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: KBA	Block Serial No.: BF-18
Model: USN 58Lsw	Model: 892-600	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 01C4NX	Block Thickness ("): 6.125
Range: 18.0"	Nominal Angle (°): 70	Cal. Reflector Type: 3/4 T-SDH
Velocity (in/uSec): 0.1230	Measured Angle (°): 70	Cal. Reflector Size ("): 5/16 DIA.
Delay (uSec): 14.0400	Frequency (MHz): 2.25	Cal. Reflector Depth ("): 4.375
Frequency (MHz): 2.25	Mode: Shear	Miscellaneous Information
Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off	No. of Elements: 1	Cable Type: RG-174
Rectify: Fullwave	Element Size: 0.5" X 1.0"	Cable Length ("): 12
Pulse Width (ns): 220	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: N/A	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: Single	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): N/A	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

**Calibration / Verification Information**

Calibration Responses				Calibration Time / Date
Response ("): 12.79	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 54.4	Amp (%): 80	Initial Cal.: 0925 / 03-10-2011
Verification Responses				Final Cal.: 1508 / 03-10-2011
Block No.: 6564	Reflector(s): 2" & 5"			Cal. Verification: 1336 / 03-10-2011
Response ("): 2"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 25.5	Amp (%): 80	Cal. Verification: N/A
Response ("): 5"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 25.5	Amp (%): 40	Cal. Verification: N/A

Comments:  
Min. MP = 2.30"  
Max MP = 16.07"

Examiner: Edward P. Mazyck      Level: II      Examiner: N/A      Level:  
Sign: *Edward P. Mazyck*      Date: 03-10-2011      Sign:      Date:

AREVA Review: Dan Langenfeld      Level: III      Date: 03-13-2011  
Sign: *Dan Langenfeld*



# UT EXAMINATION DATA SHEET

Nozzle Inner Radius

Report No.: 2-TVA-N10-IR

Exam Data Sheet No.: EDS-01

Customer Information			Component Information		
Utility: TVA	Plant: Browns Ferry	Unit: 2	Weld ID: N10 IR	System: RPV	
Procedure / Model Information			Exam Surface: Vessel O.D.	Surface Condition: Smooth	
Proc. No.: 54-ISI-850	Rev.: 007		Material: Carbon Steel (Clad)		
Modeling Report No.: (EPRI) IR-2004-43			Configuration: Inner Radius		

Examination Information					
L <sub>o</sub> Location: Nozzle Top Dead Center			W <sub>o</sub> Location: Nozzle Boss (RNozzle)		
Exam Start Date: 03-10-2011	Exam Start Time: 1258	Component Temp.: 96°	Thermometer Serial No.: VH-11836		
Exam End Date: 03-10-2011	Exam End Time: 1430	Couplant Type: Ultragel II	Couplant Batch No.: 10325 B		

Search Unit	Scan Surface			Examination Skew Angles	Cal Sheet No.	Exam Sensitivity	Recordable Indications	Limitations	Notes:
	Blend Radius	Nozzle Boss	Vessel						
65° Shear			X	±(1 to 10)°	CS-01	65.0	No	None	
70° Shear			X	±(2 to 23)°	CS-02	66.4	No	None	

Notes: Scans performed as directed by EPRI Model Report No.: IR-2004 43.

Summary of Detection Modeling Parameters – IR-2004-43					
Metal Path		Beam angle at flaw		Maximum Misorientation Angle	% Coverage
Min	Max	Min	Max		
2.30	16.07	40	90	18°	90

Examiner: Edward P. Mazyck Sign: <i>Edward P. Mazyck</i>	Level: II	Date: 03-10-2011	Examiner: N/A Sign:	Level:	Date:
AREVA Review: Dan Langenfeld Sign: <i>Dan Langenfeld</i>	Level: III	Date: 03-13-2011			

000170 VE-11-020

	<b>Ultrasonic Examination Summary</b>  <b>Inner Radius</b>		Report No.:	2-TVA-N10-IR
			Component ID:	N10-IR
			Work Document:	2-SI-4.6G

Customer:	TVA	Code Category:	B-D	System:	RPV (N10)
Site / Unit:	BFN 2	Code Item:	B3.100	Material:	CS (Clad)
Outage:	U2R16	Code Class:	1	ISO / Drawing(s):	122858 E / SK-B2022
Description:	Nozzle Inside Radius Section			EPRI Model No.:	IR-2004-43
Procedure:	54-ISI-850, Rev 007				
Title:	Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (inner 15%).				

Calibration Sheets	Exam Data Sheets	Coverage Work Sheets	Coverage Diagrams	Indication Data Sheets	Indication Plot Sheets
CS-01	EDS-01	See Note 1	N/A	N/A	N/A
CS-02					






Exam Results:	No Recordable Indications	Exam Volume Coverage Obtained:	90%
---------------	---------------------------	--------------------------------	-----

In accordance with UT Procedure 54-ISI-850-007 and EPRI Model No. IR-2004-43, a 65° and 70° Shear wave Inner Radius examinations were performed from the vessel O.D. surface.

Probe Angle / Mode	Probe Skew	Min R	Max R	Min MP	Max MP
65° / Shear	±(1 to 10)	13.85"	15.54"	14.14"	16.07"
70° / Shear	±(2 to 23)	2.94"	15.54"	2.30"	16.07"

(1) Reference EPRI Report IR-2004-43 for exam volume and coverage.

This examination satisfies the requirements of ASME Sec. XI 2001 Edition with 2003 Addenda for Appendix VIII, Category B-D, for item number B3.100, figure number IWB 2500-7(a) exam volume, and was performed using ASME Sec XI, Appendix VIII qualified personnel, procedures, and equipment as amended by the Final Rule.

Personnel	Name	Signature	Level	Date
Prepared By:	Edward P. Mazyck		II	03-10-2011
AREVA Review:	Paul S. Anderson		III	03-13-2011
Customer:	MATT WELCH		III	3/15/11
ANII:				3/21/11



000171 VE-11-20



## RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-IR

Cal. Sheet No.: CS-01

Report No.: 2-TVA-N10-IR

### Customer Information

Utility: TVA

Site: Browns Ferry

Unit: 2

### Procedure Information

Procedure Number: 54-ISI-850

Rev.: 007

Procedure Title: Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: KBA	Block Serial No.: BF-18
Model: USN 58Lsw	Model: 892-600	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 01TPCJ	Block Thickness ("): 6.125
Range: 18.0"	Nominal Angle (°): 65	Cal. Reflector Type: ID Notch
Velocity (in/uSec): 0.1230	Measured Angle (°): 65	Cal. Reflector Size ("): 0.250
Delay (uSec): 14.7300	Frequency (MHz): 2.25	Cal. Reflector Depth ("): 0.253
Frequency (MHz): 2.25	Mode: Shear	Miscellaneous Information
Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off	No. of Elements: 1	Cable Type: RG-174
Rectify: Fullwave	Element Size: 0.5" X 1.0"	Cable Length ('): 12
Pulse Width (ns): 220	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: N/A	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: Single	Couplant Batch No.: 10325 B
Pulser / Energy: Square	Squint Angle (°): N/A	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

### Calibration / Verification Information

Calibration Responses				Calibration Time / Date	
Response ("): 13.77	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 53.0	Amp (%): 80	Initial Cal.: 0930 / 03-10-2011	
Verification Responses				Final Cal.: 1508 / 03-10-2011	
Block No.: 6564	Reflector(s): 2" & 5"			Cal. Verification: 1256 / 03-10-2011	
Response ("): 2"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 18.8	Amp (%): 80	Cal. Verification: N/A	
Response ("): 5"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 18.8	Amp (%): 28	Cal. Verification: N/A	

**Comments:**

Min. MP = 14.14"  
Max MP = 16.07"

Examiner: Edward P. Mazyck

Level: II

Examiner: N/A

Level:

Sign: *Edward P. Mazyck*

Date: 03-10-2011

Sign:

Date:

AREVA Review: Dan Langenfeld

Level: III

Date: 03-13-2011

Sign: *Dan Langenfeld*

000172 VE-11-20



## RPV MANUAL ULTRASONIC CALIBRATION DATA SHEET

Component ID: N10-IR

Cal. Sheet No.: CS-02

Report No.: 2-TVA-N10-IR

### Customer Information

Utility: TVA

Site: Browns Ferry

Unit: 2

### Procedure Information

Procedure Number: 54-ISI-850

Rev.: 007

Procedure Title: Manual Ultrasonic Examination of BWR Reactor Vessel Nozzle Inner Radius Regions and Nozzle to Shell Welds (Inner 15%)

UT Instrument Information	Search Unit Information	Reference / Cal. Block Info
Manufacturer: Krautkramer	Manufacturer: KBA	Block Serial No.: BF-18
Model: USN 58Lsw	Model: 892-600	Block Material: CS / Clad
Serial Number: 01C3M3	Serial No.: 01C4NX	Block Thickness ("): 6.125
Range: 18.0"	Nominal Angle (°): 70	Cal. Reflector Type: ¼ T-SDH
Velocity (in/uSec): 0.1230	Measured Angle (°): 70	Cal. Reflector Size ("): 5/16 DIA.
Delay (uSec): 14.0400	Frequency (MHz): 2.25	Cal. Reflector Depth ("): 4.375
Frequency (MHz): 2.25	Mode: Shear	Miscellaneous Information
Dual: <input type="checkbox"/> On <input checked="" type="checkbox"/> Off	No. of Elements: 1	Cable Type: RG-174
Rectify: Fullwave	Element Size: 0.5" X 1.0"	Cable Length ('): 12
Pulse Width (ns): 220	Element Shape: Rectangle	Intermediate Connectors: 0
Reject (%): 0	Focusing: N/A	Couplant Type: Ultragel II
PRF / PRR Mode: AutoHigh	Search Unit Configuration: Single	Couplant Batch No.: 10325 B
Pulsar / Energy: Square	Squint Angle (°): N/A	Thermometer S/N: VH-11836
Voltage (V): 450	Wedge Radius: N/A	Cal. Block Temp (° F): 76
Damping (Ω): 500	Wedge Skew: N/A	

### Calibration / Verification Information

Calibration Responses				Calibration Time / Date	
Response ("): 12.79	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 54.4	Amp (%): 80	Initial Cal.: 0925 / 03-10-2011	
Verification Responses				Final Cal.: 1508 / 03-10-2011	
Block No.: 6564	Reflector(s): 2" & 5"			Cal. Verification: 1336 / 03-10-2011	
Response ("): 2"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 25.5	Amp (%): 80	Cal. Verification: N/A	
Response ("): 5"	<input checked="" type="checkbox"/> MP <input type="checkbox"/> Depth	Gain (dB): 25.5	Amp (%): 40	Cal. Verification: N/A	

**Comments:**

Min. MP = 2.30"

Max MP = 16.07"

Examiner: Edward P. Mazyck

Level: II

Examiner: N/A

Level:

Sign: *Edward P. Mazyck*

Date: 03-10-2011

Sign:

Date:

AREVA Review: Dan Langenfeld

Level: III

Date: 03-13-2011

Sign: *Dan Langenfeld*



# UT EXAMINATION DATA SHEET

Nozzle Inner Radius

Report No.: 2-TVA-N10-IR

Exam Data Sheet No.: EDS-01

Customer Information				Component Information																															
Utility: TVA		Plant: Browns Ferry		Unit: 2		Weld ID: N10 IR		System: RPV																											
Procedure / Model Information				Exam Surface: Vessel O.D.		Surface Condition: Smooth																													
Proc. No.: 54-ISI-850			Rev.: 007	Material: Carbon Steel (Clad)																															
Modeling Report No.: (EPRI) IR-2004-43				Configuration: Inner Radius																															
Examination Information																																			
L <sub>0</sub> Location: Nozzle Top Dead Center					W <sub>0</sub> Location: Nozzle Boss (RNozzle)																														
Exam Start Date: 03-10-2011			Exam Start Time: 1258		Component Temp.: 96°		Thermometer Serial No.: VH-11836																												
Exam End Date: 03-10-2011			Exam End Time: 1430		Couplant Type: Ultragel II		Couplant Batch No.: 10325 B																												
Search Unit	Scan Surface			Examination Skew Angles	Cal Sheet No.	Exam Sensitivity	Recordable Indications	Limitations	Notes:																										
	Blend Radius	Nozzle Boss	Vessel																																
65° Shear			X	±(1 to 10)°	CS-01	65.0	No	None																											
70° Shear			X	±(2 to 23)°	CS-02	66.4	No	None																											
<b>Notes:</b> Scans performed as directed by EPRI Model Report No.: IR-2004 43.																																			
<table border="1" style="margin: auto;"> <thead> <tr> <th colspan="6">Summary of Detection Modeling Parameters – IR-2004-43</th> </tr> <tr> <th colspan="2">Metal Path</th> <th colspan="2">Beam angle at flaw</th> <th colspan="2">Maximum Misorientation Angle</th> <th rowspan="2">% Coverage</th> </tr> <tr> <th>Min</th> <th>Max</th> <th>Min</th> <th>Max</th> <th colspan="2"></th> </tr> </thead> <tbody> <tr> <td>2.30</td> <td>16.07</td> <td>40</td> <td>90</td> <td colspan="2">18°</td> <td>90</td> </tr> </tbody> </table>										Summary of Detection Modeling Parameters – IR-2004-43						Metal Path		Beam angle at flaw		Maximum Misorientation Angle		% Coverage	Min	Max	Min	Max			2.30	16.07	40	90	18°		90
Summary of Detection Modeling Parameters – IR-2004-43																																			
Metal Path		Beam angle at flaw		Maximum Misorientation Angle		% Coverage																													
Min	Max	Min	Max																																
2.30	16.07	40	90	18°		90																													
Examiner: Edward P. Mazyck			Level: II	Date: 03-10-2011		Examiner: N/A			Level:	Date:																									
Sign: <i>Edward P. Mazyck</i>						Sign:																													
AREVA Review: Dan Langenfeld			Level: III	Date: 03-13-2011																															
Sign: <i>Dan Langenfeld</i>																																			

000173 VE-11-20