



GE Nuclear Energy

# GERIS 2000 Examination Summary Sheet

4492

**Project:** TVA, Browns Ferry Nuclear Plant, Unit 3

**System:** Reactor Pressure Vessel

**Weld ID:** C-2-3

**ASME Code Category:** B-A

**Calibration Sheets:** C-004 AND C-003 CMT 1/25/94

**Supporting Data:** Examination Data Sheets E-08-00 thru E-08-26, Indication Data Sheets 08-001 thru 08-110, Indication Evaluation Sheets, Screen Prints, Exam Patch Location Map, Exam Coverage Plots and GERIS 2000 Setup Records.

## Examination Summary

The ultrasonic examination of weld C-2-3 resulted in two (2) recorded indications that exceed the allowable standards of IWB-3500, ASME Section XI, 1986 Edition, No Addenda.

The ASME Section XI required examination volume was examined with the GERIS 2000 System from the RPV inside surface utilizing Procedure No. GE-UT-700, Rev. 2. This examination was limited due to the core spray downcomers and surveillance specimen brackets. The total examination coverage was calculated to be 80%.

The GERIS 2000 utilizes an array of search units arranged to effectively examine the weld and adjacent base material parallel and perpendicular to the weld axis in two directions. The transducer package consisted of 0° longitudinal, 45° and 60° shear wave, and 70° refracted longitudinal (RL) wave search units.

The two (2) unacceptable indications were recorded and sized in accordance with GE-UT-700, Rev. 2 and GE-UT-701, Rev. 2 with the results tabulated below:

Ind. No.	Oriented	Type	X Pos	Y Pos	Z Pos	"S"	T wall	Length	T Meas	a/l	% a/t Calculated	% a/t Allowed
08-026	circ.	subsurface	198.50"	392.42"	1.77"	1.56"	.41"	1.50"	6.60"	.137	3.11	2.79
08-067	circ.	subsurface	558.25"	392.85"	1.65"	1.47"	.37"	1.50"	6.55"	.123	2.82	2.68

Indication 08-026 was sized with 60° shear wave channel 11 utilizing the PATT technique. This indication was also recorded with 70°RL channel 3 as 08-023 and seen with 45° shear wave channel 7.

Indication 08-067 was sized with 70°RL channel 3 utilizing the PATT technique. This indication was also recorded with 45° shear wave channel 7 as 08-073 and seen with 60° shear wave channel 11.

The GERIS 2000 also recorded indications with the 0° weld metal scans, 70°RL, 45° and 60° shear wave scans that were evaluated and found to be acceptable per the referencing Code section.

No manual supplemental examination was performed from the RPV outside surface due to access restrictions.

Fabrication records and previous examination results were reviewed prior to the completion of this examination summary.

GERIS Analyst: *Leisa Kimball*

GE Reviewer: *R.O. Forman*

LEVEL: *III* DATE: *12-19-93*

LEVEL: *II* DATE: *12-20-93*


UTILITY Review: *28W Woody*

ANII Review:

TITLE: *#* DATE: *1/26/94*

TITLE: *Albert Todd* DATE: *7/12/94*





Indication No. 08-067

Flaw "X" location 558.25"  
 Flaw "Y" location 392.85"  
 Flaw Thruwall .37"  
 Flaw Length 1.50"  
 "I" Measured 6.55"

Nominal Clad T = 3/16"  
 Nominal Base Metal T = 6 3/8"

This indication confirmed with channels 7 and 11

1 00003  
 3 OF 276

R 1154

GE NUCLEAR ENERGY	BROWNS FERRY UNIT 3	WELD C-2-3 Ind. 08-067	SCALE: NONE	DWG. BF3C231	REV. 0
-------------------	---------------------	------------------------	-------------	--------------	--------



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Exam Data Sheet:** C-003 and C-004

**Procedure No.:** GE-UT-700  
**Revision No.:** 2  
**FRR No.:** N/A

Patch	Data Sh.	Date	Start	Stop	Min X	Max X	Min Y	Max Y	Disk No.	Examiner
BF-073	E-08-01	10/23/93	1119	1135	30.75	53.00	378.00	390.00	91A	ROF
BF-074	E-08-02	9/30/93	1619	1650	78.75	124.00	378.00	390.00	13A	ROF
BF-075	E-08-03	10/2/93	0300	0328	124.25	170.00	378.00	390.00	13A	JCG
BF-076	E-08-04	10/2/93	0406	0435	170.25	216.00	378.00	390.00	13A	JCG
BF-077	E-08-05	10/2/93	0840	0902	216.25	250.25	378.00	390.00	13A	ROF
BF-078	E-08-06	10/23/93	1152	1226	275.50	321.25	378.00	390.00	91A	ROF
BF-079	E-08-07	10/23/93	1407	1433	321.50	363.50	378.00	390.00	91A	ROF
BF-080	E-08-08	10/23/93	1306	1336	425.00	470.75	378.00	390.00	91A	ROF
BF-081	E-08-09	10/23/93	1450	1518	471.00	516.75	378.00	390.00	91A	ROF
BF-082	E-08-10	10/23/93	1533	1608	517.00	562.75	378.00	390.00	91B	ROF
BF-083	E-08-11	10/23/93	1623	1651	563.00	608.75	378.00	390.00	91B	ROF
BF-084	E-08-12	10/23/93	1709	1733	609.00	644.50	378.00	390.00	91B	ROF
BF-085	E-08-13	10/23/93	1746	1817	669.50	715.50	378.00	390.00	91B	ROF
BF-086	E-08-14	10/23/93	1829	1858	715.50	757.50	378.00	390.00	92A	ROF
BF-061	E-08-15	10/25/93	2205	2308	29.00	58.00	382.50	405.75	95A	JCG
BF-062	E-08-16	10/26/93	0003	0201	73.25	133.00	382.50	405.75	95B	JCG
BF-063	E-08-17	10/26/93	0341	0540	133.25	193.00	382.50	405.75	96A	JCG
BF-064	E-08-18	10/26/93	0551	0813	193.25	255.25	382.50	405.75	96B	JCG/ROF
BF-065	E-08-19	10/26/93	0858	1057	270.50	330.25	382.50	405.75	97A	ROF
BF-066	E-08-20	10/26/93	1105	1228	330.50	367.50	382.50	405.75	97B	ROF
BF-067	E-08-21	10/26/93	1413	1609	424.00	479.75	382.50	405.75	100A	ROF
BF-068	E-08-22	10/26/93	1614	1814	480.00	539.75	382.50	405.75	100B	ROF
BF-069	E-08-23	10/26/93	1826	2027	540.00	599.75	382.50	405.75	101A	ROF/JCG
BF-070	E-08-24	10/26/93	2043	2223	600.00	649.50	382.50	405.75	102A	JCG
BF-071	E-08-25	10/27/93	0016	0215	664.50	724.50	382.50	405.75	102B	JCG
BF-072	E-08-26	10/27/93	0230	0345	724.50	760.50	382.50	405.75	101B	JCG

Comments: N/A

**Limitations:** BF-061, BF-066, BF-067, BF-072, BF-073, BF-079, BF-080 and BF-086 limited due to the Core Spray Downcomers.  
 BF-061, BF-062, BF-064, BF-065, BF-070, BF-071, BF-073, BF-074, BF-077, BF-078, BF-084 and BF-085 limited due to the Surveillance Specimen Brackets.

Analyst: Debra Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-20-93





GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-003

Exam Data Sheet No.: E-08-01  
 Patch ID: BF-073  
 Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Leusa Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-003

**Exam Data Sheet No.:** E-08-02  
**Patch ID:** BF-074  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** N/A

**Data Sheet Codes:** G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
**Indication Codes:** 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

**Analyst:** DeeDee Kimball  
**Level:** III      **Date:** 12-18-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-03  
Patch ID: BF-075  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Leesa Kimball

Reviewed By: R.O. Fournier

Level: III Date: 12-18-93

Level: II Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-04  
Patch ID: BF-076  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Deena Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

00008

R1154



**GE Nuclear Energy**

## GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-003

Exam Data Sheet No.: E-08-05  
 Patch ID: BF-077  
 Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Deerua Kimball  
 Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-18-93

R 1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-06  
Patch ID: BF-078  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	2	08-001	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jeena Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-07  
Patch ID: BF-079  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Debra Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93

R 1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-003

**Exam Data Sheet No.:** E-08-08  
**Patch ID:** BF-080  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Deeresa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

\* 00012



R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-09  
Patch ID: BF-081  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Deena Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-003

Exam Data Sheet No.: E-08-10  
 Patch ID: BF-082  
 Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Quessa Kimball

Reviewed By: R. O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-11  
Patch ID: BF-083  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jessica Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-12  
Patch ID: BF-084  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	5	* G-109	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: 5 = Typical non-relevant reflector pattern due to clad surface.  
\* (Print only)

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jessie Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-003

Exam Data Sheet No.: E-08-13  
Patch ID: BF-085  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	5	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: 5 = Typical non-relevant reflector pattern due to clad surface.  
(similar to G-109)

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Joanna Kimball  
Level: III Date: 12-18-93

Reviewed By: CF M5  
Level: III Date: 1/25/94

R1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-003

**Exam Data Sheet No.:** E-08-14  
**Patch ID:** BF-086  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	5	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** 5 = Typical non-relevant reflector pattern due to clad surface.  
(similar to G-109)

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Quessa Kimball  
Level: III Date: 12-18-93

Reviewed By: Cl M5  
Level: III Date: 1/25/94

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-15  
Patch ID: BF-061  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-002	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1	08-003	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-004	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Aeresa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
Patch ID: BF-062  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-005	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-006	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-007	08-008	08-009	08-010	08-011
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-012	08-013	08-014	08-015	08-016
				08-017	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Quessa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93





GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-17  
Patch ID: BF-063  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	1	08-018	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-019	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-020	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-021	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~


Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jessica Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

B1154



# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-18  
**Patch ID:** BF-064  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	1	08-022	~	~	~	~
2	0 WM	N/A	*	~	~	~	~	~
3	70 RL	0 UP	1	08-023	08-024	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-025	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-026	08-027	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** \* Indication 08-022 also seen with ch. 2.

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Debra Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Foorman  
 Level: II Date: 12-18-93



# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-19  
**Patch ID:** BF-065  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-028	08-033	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-035	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	3	08-038	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1, 3	08-039	08-040	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1, 3	08-041	08-042	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1, 3	08-043	08-044	08-045	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** N/A

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: *Debra Kimball*  
 Level: III      Date: 12-18-93

Reviewed By: *R.O. Forman*  
 Level: II      Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-003

**Exam Data Sheet No.:** E-08-06  
**Patch ID:** BF-078  
**Ind. Data Sheet No.:** 08-001

**Indication:** 08-001      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
50.2%	296.60	~	~	~	~	384.05	11.60	~	~	~	~	~
68.7%	296.85	~	~	383.80	11.86	384.05	11.60	~	~	~	~	~
77.9%	297.10	~	~	383.55	12.03	383.80	11.81	384.05	11.60	~	~	~
50.2%	297.35	~	~	~	~	383.80	11.86	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** OD surface indication. No apparent tip signals.  
 Thruwall size was determined by the ASME 50% method.  
 +1.09 dB above notch sensitivity.  
 This indication also seen with Ch. 7 at below recordable levels.  
 (Could not max indication due to end of scan.)  
 TW = 0.22      L = 0.75      S = 0.00

Analyst: Debra Kimball  
Level: III      Date: 12-18-93

Reviewed By: R.D. Foman  
Level: II      Date: 12-18-93

R1154



**GE Nuclear Energy**

**GERIS 2000 Indication  
Evaluation Sheet**

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-078

**Exam Data Sheet No.:** E-08-06  
**Ind. Data Sheet No.:** 08-001  
**Indication:** 08-001

**Flaw Thruwall Dimension** = 0.22  
**Flaw Length "l"** = 0.75  
**Separation with clad "S"** = N/A  
**Surface Separation "S"** = 0.00

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.67	4.24 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.67	Allowed 0.00

a = 0.215  
a/l value = 0.287  
Y = 0.000

Flaw is Surface

Allowed a/t = 3.67%  
a/t = 3.37%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-15  
Patch ID: BF-061  
Ind. Data Sheet No.: 08-002

Indication: 08-002

Channel: 5

Angle: 70

Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
26.9%	28.90	~	~	~	~	394.30	18.64	~	~	~	~	~
22.3%	29.15	~	~	~	~	394.30	18.64	~	~	~	~	~
20.9%	29.40	~	~	~	~	394.30	18.80	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Debra Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-15  
Patch ID: BF-061  
Ind. Data Sheet No.: 08-003

Indication: 08-003

Channel: 9

Angle: 45

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
32.4%	30.50	~	~	397.75	7.19	398.25	7.56	399.00	8.13	~	~	~
19.6%	30.75	~	~	398.00	7.37	398.25	7.56	398.50	7.75	~	~	~
13.5%	31.00	~	~	~	~	398.25	7.56	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.283          L = 0.5          S = 1.11

Analyst: Deesa Kimball  
Level: III          Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II          Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-061

**Exam Data Sheet No.:** E-08-15  
**Ind. Data Sheet No.:** 08-003  
**Indication:** 08-003

**Flaw Thruwall Dimension =** 0.28  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** N/A  
**Surface Separation "S" =** 1.11

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.63	4.20 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.63	Allowed 4.20

a = 0.142  
 a/l value = 0.283  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.20%  
 a/t = 2.22%

**Comments:**

---



---



---



---



R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-15  
 Patch ID: BF-061  
 Ind. Data Sheet No.: 08-004

Indication: 08-004      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
16.3%	38.50	~	~	395.00	3.02	395.50	3.40	396.00	3.96	~	~	~
22.3%	38.75	~	~	395.00	3.02	395.50	3.47	396.25	4.20	~	~	~
17.3%	39.00	~	~	395.00	3.02	395.50	3.50	396.25	4.25	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

TW = 0.46      L = 0.5      S = 1.51      w/clad

Analyst: Deesa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-18-93

Level: II      Date: 12-10-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-061

**Exam Data Sheet No.:** E-08-15  
**Ind. Data Sheet No.:** 08-004  
**Indication:** 08-004

**Flaw Thruwall Dimension =** 0.46  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 1.51  
**Surface Separation "S" =** 1.32

**T nominal =** 6.38  
**Clad T nominal =** 0.19  
**% of Allowable:** 0.52

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	5.12	6.88 Y
0.50	5.20	7.6	~	~
			Allowed	Allowed
			5.12	6.88

a = 0.230  
 a/l value = 0.460  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 6.88%  
 a/t = 3.61%

**Comments:**

---



---



---



---



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-16  
**Patch ID:** BF-062  
**Ind. Data Sheet No.:** 08-005

**Indication:** 08-005

**Channel:** 5

**Angle:** 70

**Direction:** 180

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	TOF	Min Y	TOF	Y	TOF	Max Y	TOF	Max Y	TOF	
28.6%	85.65	~	~	~	~	395.30	27.44	~	~	~	~	~
30.4%	85.90	~	~	~	~	395.30	27.20	~	~	~	~	~
22.3%	86.15	~	~	~	~	395.30	27.36	~	~	~	~	~
11.9%	86.40	~	~	~	~	395.30	27.28	~	~	~	~	~
20.1%	86.65	~	~	~	~	395.55	29.04	~	~	~	~	~
30.4%	86.90	~	~	~	~	395.30	26.72	~	~	~	~	~
60.6%	87.15	~	~	~	~	395.30	26.72	~	~	~	~	~
68.7%	87.40	~	~	~	~	395.30	26.80	~	~	~	~	~
22.3%	87.65	~	~	~	~	395.30	26.88	~	~	~	~	~
13.5%	87.90	~	~	~	~	395.30	27.36	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 11 (08-009) and Ch. 13 (08-013).  
 Thruwall size was determined by the PATT technique.

TW = 0.09                      L = 2.5                      S = 1.134      w/clad

Analyst: Jessie Kimball  
 Level: III                      Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II                      Date: 12-18-93

B1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-062

Exam Data Sheet No.: E-08-16  
Ind. Data Sheet No.: 08-005  
Indication: 08-005

Flaw Thruwall Dimension = 0.09  
Flaw Length "l" = 2.50  
Separation with clad "S" = 1.13  
Surface Separation "S" = 0.94

T nominal = 6.38  
Clad T nominal = 0.19  
% of Allowable: 0.35

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	1.90	2.00 Y
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 1.90	Allowed 2.00

a = 0.045  
a/l value = 0.018  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.00%  
a/t = 0.71%

Comments:

---



---



---



---

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-16  
**Patch ID:** BF-062  
**Ind. Data Sheet No.:** 08-006

**Indication:** 08-006

**Channel:** 7

**Angle:** 45

**Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
17.3%	105.35	~	~	388.75	4.63	389.25	4.23	389.50	4.05	~	~	~
11.9%	105.60	~	~	388.75	4.83	389.00	4.42	389.50	4.05	~	~	~
6.8%	105.85	~	~	~	~	389.25	4.23	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

---

TW = 0.311      L = 0.75      S = 2.84      w/clad

**Analyst:** Deresa Kimball  
**Level:** III      **Date:** 12-18-93

**Reviewed By:** R.O. Foman  
**Level:** II      **Date:** 12-18-93



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-062

**Exam Data Sheet No.:** E-08-16  
**Ind. Data Sheet No.:** 08-006  
**Indication:** 08-006

**Flaw Thruwall Dimension =** 0.31  
**Flaw Length "l" =** 0.75  
**Separation with clad "S" =** 2.84  
**Surface Separation "S" =** 2.65

**T nominal =** 6.38  
**Clad T nominal =** 0.19  
**% of Allowable:** 0.72

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.87	3.37 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
		Allowed	Allowed	
		2.87	3.37	

a = 0.156  
 a/l value = 0.207  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.37%  
 a/t = 2.44%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
 Patch ID: BF-062  
 Ind. Data Sheet No.: 08-007

Indication: 08-007 Channel: 11 Angle: 60 Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
39.1%	85.50	390.25	3.06	~	~	390.50	2.84	~	~	391.00	2.39	~
60.6%	85.75	390.00	3.31	390.25	3.05	390.50	2.84	390.75	2.61	391.25	2.33	~
34.5%	86.00	390.25	3.06	~	~	390.50	2.82	~	~	391.00	2.39	~
25.2%	86.25	~	~	~	~	390.75	2.62	~	~	390.50	2.84	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: This indication also seen with Ch. 13 (see 08-012).  
 Thruwall size was determined by the ASME 50% method.

TW = 0.22 L = 0.75 S = 1.31 w/clad

Analyst: Alesia Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-18-93

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-062

**Exam Data Sheet No.:** E-08-16  
**Ind. Data Sheet No.:** 08-007  
**Indication:** 08-007

**Flaw Thruwall Dimension** = 0.22  
**Flaw Length "l"** = 0.75  
**Separation with clad "S"** = 1.31  
**Surface Separation "S"** = 1.12

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.48	2.87 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.48	2.87

a = 0.110  
a/l value = 0.147  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.87%  
a/t = 1.72%

**Comments:**

---



---



---



---





GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-16

Patch ID: BF-062

Ind. Data Sheet No.: 08-008

Indication: 08-008

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
32.4%	105.50	-	-	-	-	388.00	5.17	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.  
 Flaw length of 0.25" assigned for single increment indications.

---

TW = 0.5      L = 0.25      S = 2.335 w/clad

Analyst: Jessica Kimball  
 Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-062

**Exam Data Sheet No.:** E-08-16  
**Ind. Data Sheet No.:** 08-008  
**Indication:** 08-008

**Flaw Thruwall Dimension =** 0.50  
**Flaw Length "l" =** 0.25  
**Separation with clad "S" =** 2.34  
**Surface Separation "S" =** 2.15

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.250  
 a/l value = 0.500  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
 a/t = 3.92%

**Comments:**  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
Patch ID: BF-062  
Ind. Data Sheet No.: 08-009

Indication: 08-009

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
26.9%	86.75	391.25	2.17	~	~	391.50	1.98	~	~	~	~	~
30.4%	87.00	391.25	2.19	~	~	391.50	2.00	~	~	~	~	~
34.5%	87.25	391.00	2.43	~	~	391.50	1.98	~	~	~	~	~
25.2%	87.50	391.25	2.13	~	~	391.50	1.90	~	~	391.75	1.68	~
23.7%	87.75	390.50	2.20	~	~	390.75	2.60	~	~	391.00	2.39	~
16.3%	88.00	~	~	~	~	390.75	2.55	~	~	~	~	~
15.3%	88.25	~	~	~	~	391.25	2.10	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	Lost
28.6%	88.75	391.00	2.39	~	~	391.50	1.93	~	~	~	~	~
34.5%	89.00	390.75	2.60	~	~	391.25	2.15	~	~	391.75	1.68	~
34.5%	89.25	390.75	2.62	~	~	391.25	2.15	~	~	391.75	1.77	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Same indication recorded with Ch. 5 (08-005) and Ch. 13 (08-013).  
Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510.

TW = 0          L = 2.5          S = 0.99          w/clad

Analyst: Debra Kimball  
Level: III          Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II          Date: 12-24-93  
REV 11-10-93



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-16  
**Patch ID:** BF-062  
**Ind. Data Sheet No.:** 08-010

**Indication:** 08-010

**Channel:** 11

**Angle:** 60

**Direction:** 0

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	MP	Min Y	MP	Y	MP	Max Y	MP	Max Y	MP	
41.6%	91.75	391.25	1.86	~	~	391.75	1.37	~	~	~	~	~
30.4%	92.00	391.25	1.86	~	~	391.50	1.64	~	~	391.75	1.59	~
44.3%	92.25	391.25	1.84	~	~	391.75	1.33	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	Lost
7.7%	93.50	~	~	~	~	390.50	2.39	~	~	~	~	~
13.5%	93.25	~	~	~	~	390.25	2.62	~	~	~	~	~
10.5%	93.50	~	~	~	~	391.00	2.37	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
 Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0                      L = 1.75                      S = 0.598                      w/clad

**Analyst:** Jessica Kimball  
**Level:** III                      **Date:** 12-18-93

**Reviewed By:** R.O. Forman  
**Level:** II                      **Date:** 12-18-93

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
 Patch ID: BF-062  
 Ind. Data Sheet No.: 08-011

Indication: 08-011      Channel: 11      Angle: 60      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
16.3%	94.50	~	~	~	~	390.50	3.15	~	~	~	~	~
16.3%	94.75	~	~	~	~	390.75	2.68	~	~	~	~	~
20.9%	95.00	390.50	2.88	~	~	390.75	2.66	~	~	391.00	2.41	~
16.3%	95.25	~	~	~	~	390.75	2.62	~	~	~	~	~
18.5%	95.50	~	~	~	~	391.50	1.96	~	~	~	~	~
26.9%	95.75	390.00	3.31	~	~	391.50	1.96	~	~	~	~	~
22.3%	96.00	390.25	3.09	~	~	390.50	2.83	~	~	390.75	2.61	~
11.9%	96.25	~	~	~	~	390.25	3.28	~	~	~	~	~
25.2%	96.50	~	~	~	~	390.25	3.31	~	~	391.50	2.32	~
47.2%	96.75	390.50	2.72	~	~	391.70	1.68	~	~	392.25	1.41	~
53.5%	97.00	390.50	2.78	~	~	391.50	1.93	391.75	1.68	392.00	1.57	~
44.3%	97.25	391.00	2.60	~	~	391.50	1.92	~	~	392.00	1.55	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Same indication recorded with Ch. 13 (08-015).  
 Thruwall size was determined by the ASME 50% method.

TW= 0.13      L = 2.75      S = 0.90      w/clad

Analyst: C. Deesa Kimball  
 Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-18-93

B1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-062

Exam Data Sheet No.: E-08-16  
Ind. Data Sheet No.: 08-011  
Indication: 08-011

Flaw Thruwall Dimension = 0.13  
Flaw Length "l" = 2.75  
Separation with clad "S" = 0.90  
Surface Separation "S" = 0.71

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	1.90	2.00 Y
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			1.90	2.00

a = 0.063  
a/l value = 0.023  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.00%  
a/t = 0.98%

Comments:

---



---



---



---



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
Patch ID: BF-062  
Ind. Data Sheet No.: 08-012

Indication: 08-012      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
19.6%	85.75	~	~	~	~	394.50	2.27	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
This indication also seen with Ch. 11 (see 08-007).  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: *Jessie Kimball*  
Level: III      Date: 12-18-93

Reviewed By: *R.O. Forman*  
Level: II      Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
Patch ID: BF-062  
Ind. Data Sheet No.: 08-013

Indication: 08-013      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
44.3%	86.75	393.75	1.65	~	~	394.00	1.73	~	~	395.00	2.87	~
44.3%	87.00	~	~	~	~	394.00	1.65	~	~	395.25	3.12	~
57.0%	87.25	394.00	1.61	394.00	1.65	394.25	1.90	394.50	2.13	396.00	3.71	~
50.2%	87.50	394.00	1.65	~	~	394.25	1.91	~	~	394.75	2.54	~
19.6%	87.75	~	~	~	~	394.00	1.76	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Same indication recorded with Ch. 5 (08-005) and Ch. 11 (08-009).  
Thruwall size was determined by the ASME 50% method.

TW = 0.24      L = 1.00      S = 0.83      w/clad

Analyst: Chessa Kimball

Reviewed By: R.O. Fomen

Level: III      Date: 12-18-93

Level: II      Date: 12-18-93



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-062

**Exam Data Sheet No.:** E-08-16  
**Ind. Data Sheet No.:** 08-013  
**Indication:** 08-013

**Flaw Thruwall Dimension =** 0.24  
**Flaw Length "l" =** 1.00  
**Separation with clad "S" =** 0.83  
**Surface Separation "S" =** 0.64

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.32	2.66 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.32	2.66

a = 0.120  
 a/l value = 0.120  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.66%  
 a/t = 1.88%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weid ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
Patch ID: BF-062  
Ind. Data Sheet No.: 08-014

Indication: 08-014 Channel: 13 Angle: 60 Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
32.4%	94.50	394.25	2.32	~	~	394.50	2.61	~	~	395.75	3.64	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the Reg.Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00 L = 0.25 S = 1.31 w/clad

Analyst: Alesia Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93

81154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-16  
**Patch ID:** BF-062  
**Ind. Data Sheet No.:** 08-015

**Indication:** 08-015

**Channel:** 13

**Angle:** 60

**Direction:** 180

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	MP	Min Y	MP	Y	MP	Max Y	MP	Max Y	MP	
19.6%	96.50	~	~	~	~	395.00	2.94	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen with Ch. 11 (see 08-011).  
 Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Deesa Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-18-93

R1154



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-16  
 Patch ID: BF-062  
 Ind. Data Sheet No.: 08-016

Indication: 08-016      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
19.6%	113.25	~	~	394.50	3.57	395.25	4.26	396.00	4.93	~	~	~
22.3%	113.50	~	~	394.75	3.86	395.50	4.48	396.25	5.19	~	~	~
11.2%	113.75	~	~	~	~	395.50	4.71	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

TW = 0.44      L = 0.50      S = 2.02      w/clad

Analyst: Deesa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-18-93

Level: II      Date: 12-18-93



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

81154

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-062

**Exam Data Sheet No.:** E-08-16  
**Ind. Data Sheet No.:** 08-016  
**Indication:** 08-016

**Flaw Thruwall Dimension =** 0.44  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 2.02  
**Surface Separation "S" =** 1.83

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	5.08	6.52 Y
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			5.08	6.52

a = 0.220  
a/l value = 0.440  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 6.52%  
a/t = 3.45%

**Comments:**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

R1154



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-16  
**Patch ID:** BF-062  
**Ind. Data Sheet No.:** 08-017

**Indication:** 08-017      **Channel:** 13      **Angle:** 60      **Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
25.2%	122.25	~	~	394.50	3.60	395.25	4.30	395.75	4.71	~	~	~
25.2%	122.50	~	~	394.50	3.68	395.75	4.73	396.25	5.19	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW= 0.48      L = 0.25      S = 1.91      w/clad

Analyst: C. Quera Kimball  
Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-062

Exam Data Sheet No.: E-08-16  
Ind. Data Sheet No.: 08-017  
Indication: 08-017

Flaw Thruwall Dimension = 0.48  
Flaw Length "I" = 0.25  
Separation with clad "S" = 1.91  
Surface Separation "S" = 1.72

T nominal = 6.38  
Clad T nominal = 0.19  
% of Allowable: 0.49

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.240  
a/l value = 0.500  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
a/t = 3.76%

Comments:

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-17  
Patch ID: BF-063  
Ind. Data Sheet No.: 08-018

Indication: 08-018

Channel: 2

Angle: 0

Direction: 90

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
175.6%	392.25	~	~	171.60	1.08	172.85	1.03	174.10	1.12	~	~	~
68.7%	392.50	~	~	173.35	1.10	173.60	1.14	174.10	1.12	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: This indication evaluated as a laminar reflector and is acceptable in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: Deeisa Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93



R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-17  
Patch ID: BF-063  
Ind. Data Sheet No.: 08-019

Indication: 08-019

Channel: 5

Angle: 70

Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
11.9%	137.90	~	~	~	~	394.80	22.88	~	~	~	~	~
26.9%	138.15	~	~	~	~	394.80	23.04	~	~	~	~	~
22.3%	138.40	~	~	~	~	394.80	23.04	~	~	~	~	~
28.6%	138.65	~	~	~	~	394.80	23.04	~	~	~	~	~
16.3%	138.90	~	~	~	~	394.55	20.40	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Debra Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-17  
 Patch ID: BF-063  
 Ind. Data Sheet No.: 08-020

Indication: 08-020      Channel: 7      Angle: 45      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	136.10	~	~	~	~	390.75	2.30	~	~	~	~	~
18.5%	136.35	~	~	~	~	390.75	2.30	~	~	~	~	~
17.3%	136.60	~	~	~	~	390.75	2.36	~	~	~	~	~
20.9%	136.85	~	~	~	~	391.00	2.14	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.

Indication has no determinable throughwall dimension and is acceptable to IWB-3510-1.

Analyst: Ceresa Kimball  
 Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-17  
**Patch ID:** BF-063  
**Ind. Data Sheet No.:** 08-021

**Indication:** 08-021

**Channel:** 11

**Angle:** 60

**Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
18.5%	162.00	~	~	~	~	388.50	4.41	~	~	~	~	~
20.9%	162.25	388.50	4.41	~	~	389.25	3.75	~	~	389.50	3.53	~
20.9%	162.50	388.00	4.86	~	~	389.75	3.31	~	~	390.25	2.83	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
 Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00      L = 0.50      S = 1.66      w/clad

**Analyst:** Leresa Kimball  
**Level:** III      **Date:** 12-18-93

**Reviewed By:** R.O. Freeman  
**Level:** II      **Date:** 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-18

Patch ID: BF-064

Ind. Data Sheet No.: 08-022

Indication: 08-022

Channel: 1

Angle: 0

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
82.9%	246.15	~	~	392.00	1.32	392.50	1.32	392.75	1.32	~	~	~
106.4%	246.40	~	~	392.25	1.32	392.50	1.32	392.75	1.30	~	~	~
94.0%	246.65	~	~	~	~	392.50	1.30	392.75	1.30	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen with Ch. 2.  
This indication evaluated as a laminar reflector and is acceptable  
in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: Geneva Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II Date: 12-18-93



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-18  
**Patch ID:** BF-064  
**Ind. Data Sheet No.:** 08-023

**Indication:** 08-023

**Channel:** 3

**Angle:** 70

**Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
39.1%	197.75	~	~	~	~	389.20	31.36	~	~	~	~	~
39.1%	198.00	~	~	~	~	388.45	36.96	~	~	~	~	~
36.7%	198.25	~	~	~	~	388.45	36.80	~	~	~	~	~
30.4%	198.50	~	~	~	~	388.45	36.80	~	~	~	~	~
34.5%	198.75	~	~	~	~	388.45	36.96	~	~	~	~	~
11.9%	199.00	~	~	~	~	388.45	36.80	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen on Ch. 11 (see 08-026).  
Thruwall size was determined by the PATT technique.

TW = 0.48                  L = 1.50                  S = 1.71          w/clad

Analyst: Alesia Kimball

Reviewed By: R.O. Forman

Level: III                  Date: 12-18-93

Level: II                  Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-064

**Exam Data Sheet No.:** E-08-18  
**Ind. Data Sheet No.:** 08-023  
**Indication:** 08-023

**Flaw Thruwall Dimension =** 0.48  
**Flaw Length "I" =** 1.50  
**Separation with clad "S" =** 1.71  
**Surface Separation "S" =** 1.52

**T measured =** 6.60  
**Clad T nominal =** 0.19

Flaw is unacceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.57	2.99 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.57	2.99

a = 0.242  
 a/l value = 0.161  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.99%  
 a/t = 3.66%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-18

Patch ID: BF-064

Ind. Data Sheet No.: 08-024

Indication: 08-024

Channel: 3

Angle: 70

Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
14.4%	232.75	~	~	~	~	388.70	33.20	~	~	~	~	~
28.6%	233.00	~	~	~	~	388.95	31.12	~	~	~	~	~
36.7%	233.25	~	~	~	~	389.20	28.96	~	~	~	~	~
18.5%	233.50	~	~	~	~	388.95	30.00	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.

Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Ceresa Kimball

Reviewed By: R.O. Foman

Level: III Date: 12-18-93

Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-18  
Patch ID: BF-064  
Ind. Data Sheet No.: 08-025

Indication: 08-025

Channel: 7

Angle: 45

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
44.3%	240.10	391.25	2.14	~	~	391.50	1.96	~	~	392.00	1.55	~
32.4%	240.35	391.25	2.09	~	~	391.50	1.96	~	~	391.75	1.68	~
19.6%	240.60	~	~	~	~	391.50	1.96	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.

Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00      L = 0.50      S = 1.39      w/clad

Analyst: Jessica Kimball  
Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-18-93



R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-18  
 Patch ID: BF-064  
 Ind. Data Sheet No.: 08-026

Indication: 08-026

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
26.9%	197.75	389.00	3.90	~	~	389.25	3.64	~	~	389.50	3.42	~
36.7%	198.00	388.75	4.12	~	~	389.25	3.64	~	~	390.00	2.97	~
32.4%	198.25	388.75	4.11	~	~	389.25	3.65	~	~	390.00	2.97	~
26.9%	198.50	389.00	3.87	~	~	390.00	2.97	~	~	390.25	2.70	~
44.3%	198.75	388.75	4.13	~	~	389.75	3.19	~	~	390.25	2.76	~
30.4%	199.00	389.50	3.38	~	~	390.00	3.02	~	~	390.25	2.72	~
26.9%	199.25	~	~	~	~	389.75	3.19	~	~	390.25	2.78	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen with Ch. 3 (see 08-023) and Ch. 7 (not recorded due to less than ASME DAC levels with no apparent tip signals).  
 Thruwall size was determined by the PATT technique.

TW = 0.41      L = 1.50      S = 1.75      w/clad

Analyst: Louisa Kimball  
 Level: III      Date: 12-18-93

Reviewed By: R.O. Furman  
 Level: II      Date: 12-18-93



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
 Weld ID: C-2-3  
 Patch: BF-064

Exam Data Sheet No.: E-08-18  
 Ind. Data Sheet No.: 08-026  
 Indication: 08-026

Flaw Thruwall Dimension = 0.41  
 Flaw Length "l" = 1.50  
 Separation with clad "S" = 1.75  
 Surface Separation "S" = 1.56

T measured = 6.60  
 Clad T nominal = 0.19

Flaw is unacceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.42	2.79 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.42	Allowed 2.79

a = 0.205  
 a/l value = 0.137  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.79%  
 a/t = 3.11%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-18  
 Patch ID: BF-064  
 Ind. Data Sheet No.: 08-027

Indication: 08-027      Channel: 11      Angle: 60      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
28.6%	211.75	~	~	389.00	4.80	389.50	4.37	390.75	3.26	~	~	~
16.3%	212.00	~	~	389.25	4.59	390.50	3.45	390.75	3.23	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the SPOT technique.

TW = 0.40      L = 0.25      S = 1.99      w/clad

Analyst: *Doussa Kimball*  
 Level: III      Date: 12-18-93

Reviewed By: *R.O. Forman*  
 Level: II      Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-064

Exam Data Sheet No.: E-08-18  
Ind. Data Sheet No.: 08-027  
Indication: 08-027

Flaw Thruwall Dimension = 0.40  
Flaw Length "I" = 0.25  
Separation with clad "S" = 1.99  
Surface Separation "S" = 1.80

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.200  
a/l value = 0.500  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
a/t = 3.13%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-19  
Patch ID: BF-065  
Ind. Data Sheet No.: 08-028

Indication: 08-028 to 08-032 Channel: 3

Angle: 70

Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
13.5%	272.00	~	~	~	~	390.20	20.40	~	~	~	~	08-028
47.2%	272.25	~	~	~	~	389.95	24.24	~	~	~	~	08-028
50.2%	272.50	~	~	~	~	389.95	24.32	~	~	~	~	08-028
36.7%	272.75	~	~	~	~	389.95	24.08	~	~	~	~	08-028
~	~	~	~	~	~	~	~	~	~	~	~	~
11.2%	278.25	~	~	~	~	389.95	24.72	~	~	~	~	08-029
15.3%	278.50	~	~	~	~	389.95	24.32	~	~	~	~	08-029
328.5%	278.75	~	~	~	~	389.95	24.08	~	~	~	~	08-029
18.5%	279.00	~	~	~	~	389.95	23.52	~	~	~	~	08-029
~	~	~	~	~	~	~	~	~	~	~	~	~
14.4%	280.00	~	~	~	~	389.95	23.36	~	~	~	~	08-030
20.9%	280.25	~	~	~	~	389.95	23.36	~	~	~	~	08-030
19.6%	280.50	~	~	~	~	389.95	23.44	~	~	~	~	08-030
~	~	~	~	~	~	~	~	~	~	~	~	~
16.3%	281.75	~	~	~	~	389.95	23.68	~	~	~	~	08-031
26.9%	282.00	~	~	~	~	389.95	23.44	~	~	~	~	08-031
15.3%	282.25	~	~	~	~	389.95	23.68	~	~	~	~	08-031
9.3%	282.50	~	~	~	~	389.95	23.68	~	~	~	~	08-031
~	~	~	~	~	~	~	~	~	~	~	~	~
11.9%	287.00	~	~	~	~	389.70	27.20	~	~	~	~	08-032
16.3%	287.25	~	~	~	~	389.95	24.88	~	~	~	~	08-032
23.7%	287.50	~	~	~	~	389.95	24.88	~	~	~	~	08-032
12.7%	287.75	~	~	~	~	389.95	24.88	~	~	~	~	08-032
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.

Indications have no determinable thruwall and are acceptable to IWB-3510-1.

Analyst: Debra Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Fournier  
Level: II Date: 12-18-93

R1154



**GE Nuclear Energy**

**GERIS 2000 Indication Data Sheet**

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-19  
**Patch ID:** BF-065  
**Ind. Data Sheet No.:** 08-033

**Indication:** 08-033, 08-034    **Channel:** 3    **Angle:** 70    **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
28.6%	292.00	~	~	~	~	389.95	24.88	~	~	~	~	08-033
34.5%	292.25	~	~	~	~	389.95	24.72	~	~	~	~	08-033
22.3%	292.50	~	~	~	~	389.95	24.72	~	~	~	~	08-033
~	~	~	~	~	~	~	~	~	~	~	~	~
13.5%	311.00	~	~	~	~	389.45	27.36	~	~	~	~	08-034
17.3%	311.25	~	~	~	~	389.45	27.36	~	~	~	~	08-034
23.7%	311.50	~	~	~	~	390.20	21.44	~	~	~	~	08-034
9.9%	311.75	~	~	~	~	390.20	22.00	~	~	~	~	08-034
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indications have no determinable thruwall and are acceptable to IWB-3510-1.

**Analyst:** Deresa Kimball  
**Level:** III    **Date:** 12-18-93

**Reviewed By:** R.O. Forman  
**Level:** II    **Date:** 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-19  
Patch ID: BF-065  
Ind. Data Sheet No.: 08-035

Indication: 08-035 to 08-037 Channel: 5

Angle: 70

Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
19.6%	272.15	~	~	~	~	394.55	27.28	~	~	~	~	08-035
19.6%	272.40	~	~	~	~	395.05	31.04	~	~	~	~	08-035
17.3%	272.65	~	~	~	~	395.05	31.12	~	~	~	~	08-035
13.5%	272.90	~	~	~	~	394.30	16.16	~	~	~	~	08-035
~	~	~	~	~	~	~	~	~	~	~	~	~
26.9%	280.15	~	~	~	~	395.50	31.04	~	~	~	~	08-036
15.3%	280.40	~	~	~	~	395.05	31.36	~	~	~	~	08-036
~	~	~	~	~	~	~	~	~	~	~	~	~
47.2%	282.15	~	~	~	~	394.55	26.48	~	~	~	~	08-037
34.5%	282.40	~	~	~	~	394.55	26.96	~	~	~	~	08-037
28.9%	282.65	~	~	~	~	394.55	27.04	~	~	~	~	08-037
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indications have no determinable thruwall and are acceptable to IWB-3510-1.

Analyst: Jessica Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-18-93



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-19

Patch ID: BF-065

Ind. Data Sheet No.: 08-038

Indication: 08-038

Channel: 7

Angle: 45

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
53.5%	296.60	~	~	~	~	386.25	10.25	~	~	~	~	~
94.0%	298.85	~	~	386.00	10.46	386.50	10.06	387.00	9.66	~	~	~
106.4%	297.10	~	~	385.75	10.65	386.50	10.06	387.00	9.68	~	~	~
100.0%	297.35	~	~	385.75	10.65	386.50	9.95	387.00	9.68	~	~	~
57.0%	297.60	~	~	386.00	10.44	386.50	10.06	386.75	9.87	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Same indication recorded with Ch. 9 (08-040), Ch. 11 (08-042) and 13 (08-045).

This indication also seen with Ch. 10 at below recordable levels.

OD surface geometry.

7.07 dB below Notch sensitivity.

Analyst: Ceresa Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-18-93



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3

**Weld ID:** C-2-3

**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-19

**Patch ID:** BF-065

**Ind. Data Sheet No.:** 08-039

**Indication:** 08-039

**Channel:** 9

**Angle:** 45

**Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
25.2%	290.25	~	~	395.75	4.37	396.00	4.56	396.25	4.72	~	~	~
32.4%	290.50	~	~	395.50	4.18	395.75	4.37	396.25	4.74	~	~	~
36.7%	290.75	~	~	395.25	3.97	395.75	4.32	396.25	4.69	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 11 (08-041) and Ch. 13 (08-043).  
 Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

TW = 0.34      L = 0.50      S = 2.89      w/clad

Analyst: Deesa Kimball

Reviewed By: R.O. Foman

Level: III      Date: 12-18-93

Level: II      Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-065

**Exam Data Sheet No.:** E-08-19  
**Ind. Data Sheet No.:** 08-039  
**Indication:** 08-039

**Flaw Thruwall Dimension =** 0.34  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 2.89  
**Surface Separation "S" =** 2.70

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	4.28	4.96 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 4.28	Allowed 4.96

a = 0.170  
a/l value = 0.340  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.96%  
a/t = 2.66%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-19  
Patch ID: BF-065  
Ind. Data Sheet No.: 08-040

Indication: 08-040 Channel: 9 Angle: 45 Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
50.2%	296.75	~	~	~	~	399.25	9.25	~	~	~	~	~
77.9%	297.00	~	~	399.00	9.07	399.25	9.22	399.75	9.66	~	~	~
77.9%	297.25	~	~	399.00	9.09	399.25	9.25	399.75	9.66	~	~	~
77.9%	297.50	~	~	399.00	9.07	399.25	9.25	399.75	9.66	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication also recorded with Ch. 7 (08-038), Ch. 11 (08-042) and Ch. 13 (08-045).  
 This indication also seen with Ch. 10 below recordable levels.  
 OD surface geometry.  
 9.79 dB below Notch sensitivity.

Analyst: Jessica Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Foman  
 Level: II Date: 12-18-93

WPK 7-5-95



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-19

Patch ID: BF-065

Ind. Data Sheet No.: 08-041

Indication: 08-041

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
18.5%	290.50	~	~	388.75	5.63	389.00	5.41	389.50	5.00	~	~	~
30.4%	290.75	~	~	387.75	6.50	389.25	5.15	389.50	4.97	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 9 (08-039) and Ch. 13 (08-043).  
Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.38      L = 0.25      S = 2.39      w/clad

Analyst: Jessica Kimball

Reviewed By: R.O. Farman

Level: III      Date: 12-18-93

Level: II      Date: 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-065

**Exam Data Sheet No.:** E-08-19  
**Ind. Data Sheet No.:** 08-041  
**Indication:** 08-041

**Flaw Thruwall Dimension =** 0.38  
**Flaw Length "I" =** 0.25  
**Separation with clad "S" =** 2.39  
**Surface Separation "S" =** 2.20

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.190  
 a/l value = 0.500  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
 a/t = 2.98%

**Comments:**

---



---



---



---

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-19  
Patch ID: BF-065  
Ind. Data Sheet No.: 08-042

Indication: 08-042

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
50.2%	296.75	~	~	~	~	385.00	11.69	~	~	~	~	~
53.5%	297.00	~	~	~	~	384.25	11.69	~	~	~	~	~
64.5%	297.25	~	~	384.00	11.93	384.25	11.69	384.50	11.52	~	~	~
68.7%	297.50	~	~	384.00	11.93	384.25	11.69	384.50	11.50	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Same indication recorded with Ch. 7 (08-038), Ch. 9 (08-040) and Ch. 13 (08-045).  
This indication also seen with Ch. 10 below recordable levels.  
OD surface geometry.  
1.09 dB below Notch sensitivity.

Analyst: Deusa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II Date: 12-18-93

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-19  
**Patch ID:** BF-065  
**Ind. Data Sheet No.:** 08-043

**Indication:** 08-043

**Channel:** 13

**Angle:** 60

**Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
36.7%	290.25	~	~	397.75	5.96	398.00	6.18	398.50	6.62	~	~	~
53.5%	290.50	~	~	397.75	5.74	398.00	6.18	398.75	6.88	~	~	~
60.6%	290.75	~	~	397.50	5.74	398.50	6.62	399.00	7.13	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication rcorred with Ch. 9 (08-039) and Ch. 11 (08-041).  
 Thruwall size was determined by the SPOT technique.

---

TW = 0.34      L = 0.50      S = 3.14      w/clad

**Analyst:** Delesa Kimball

**Level:** III      **Date:** 12-18-93

**Reviewed By:** R.O. Forman

**Level:** II      **Date:** 12-18-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-065

**Exam Data Sheet No.:** E-08-19  
**Ind. Data Sheet No.:** 08-043  
**Indication:** 08-043

**Flaw Thruwall Dimension** = 0.34  
**Flaw Length "l"** = 0.50  
**Separation with clad "S"** = 3.14  
**Surface Separation "S"** = 2.95

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition**  
**TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	4.28	4.96 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			4.28	4.96

a = 0.170  
a/l value = 0.340  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.96%  
a/t = 2.66%

**Comments:**

---



---



---



---





GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

21154

**Project:** TVA, Browns Ferry, Unit 3

**Exam Data Sheet No.:** E-08-19

**Weld ID:** C-2-3

**Patch ID:** BF-065

**Cal. ID:** C-004

**Ind. Data Sheet No.:** 08-044

**Indication:** 08-044

**Channel:** 13

**Angle:** 60

**Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
26.0%	313.50	~	~	400.75	9.62	401.25	9.97	401.50	10.21	~	~	~
32.4%	313.25	~	~	400.50	9.33	401.00	9.76	402.00	10.64	~	~	~
30.4%	313.00	~	~	400.50	9.33	401.00	9.76	402.00	10.64	~	~	~
23.7%	312.75	~	~	~	~	400.50	9.33	402.00	10.62	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals. Thruwall size was determined by the SPOT technique.

TW = 0.32          L = 0.75          S = 1.56

Analyst: Jessa Kimball  
Level: III          Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II          Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-065

Exam Data Sheet No.: E-08-19  
Ind. Data Sheet No.: 08-044  
Indication: 08-044

Flaw Thruwall Dimension = 0.32  
Flaw Length "l" = 0.75  
Separation with clad "S" = N/A  
Surface Separation "S" = 1.56

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.93	3.43 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.93	Allowed 3.43

a = 0.160  
a/l value = 0.213  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.43%  
a/t = 2.51%

Comments:

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3

**Weld ID:** C-2-3

**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-19

**Patch ID:** BF-065

**Ind. Data Sheet No.:** 08-045

**Indication:** 08-045

**Channel:** 13

**Angle:** 60

**Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
53.5%	297.00	~	~	~	~	403.00	12.12	~	~	~	~	~
73.1%	297.25	~	~	402.75	11.88	403.00	12.10	~	~	~	~	~
73.1%	297.50	~	~	402.75	11.88	403.00	12.10	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 7 (08-038), Ch. 9 (08-040) and Ch. 11 (08-042).  
 This indication also recorded with Ch. 10 below recordable levels.  
 OD surface geometry.  
 2.17 dB below Notch sensitivity.

Analyst: Jessie Kimball  
 Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1, 5	08-046	08-048	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-050	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1	08-051	08-052	08-053	~	~
10	45 RS	270 CCW	1	08-054	08-055	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: 5 = Typical non-relevant reflector pattern due to clad surface.

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Laura Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-19-93

21154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-21  
Patch ID: BF-067  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-056	08-057	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-061	08-062	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: Indication Data Sheet 08-056 documents indications 08-056 and 08-058 thru 08-060.

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jessica Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-18-93

Level: II Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-22  
**Patch ID:** BF-068  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-063	08-064	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1	08-065	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-066	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** N/A

**Data Sheet Codes:** G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
**Indication Codes:** 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Jelesa Kimball  
 Level: III Date: 12-19-93

Reviewed By: R.O. Fournier  
 Level: II Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-067	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-068	08-069	08-070	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-071	08-072	08-073	08-074	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-075	08-076	08-077	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-078	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** N/A

**Data Sheet Codes:** G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
**Indication Codes:** 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

**Analyst:** Julesa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Examination Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-24  
**Patch ID:** BF-070  
**Ind. Data Sheet Series:** 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-079	08-080	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-081	08-082	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-083	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

**Comments:** N/A

**Data Sheet Codes:** G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
**Indication Codes:** 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

**Analyst:** Ceresa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Furman  
**Level:** II      **Date:** 12-19-93



R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-25  
Patch ID: BF-071  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	1	08-084	08-085	08-086	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1, 5	08-087	08-088	* G-110	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	5	* G-111	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-089	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: 5 = Indication associated with repair area.  
\* Pictures only - Reflectors associated with a repair area and documented for information only.

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number  
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Corey Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Foman  
Level: II Date: 12-19-23

R1154



GE Nuclear Energy

# GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet Series: 08-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	* 1	08-090	~	~	~	~
2	0 WM	N/A	* 1	08-091	~	~	~	~
3	70 RL	0 UP	1	08-092	08-093	08-094	08-095	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	08-096	08-097	08-098	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1	08-099	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1	08-100	08-101	08-102	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	1	08-103	08-104	08-105	08-106	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	1	08-107	08-108	08-109	08-110	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: \* Same indication

Data Sheet Codes: G-XXX; "G" = Geometry ( may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Debra Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-19-93

Level: II Date: 12-19-93

R1154



# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet No.: 08-046

Indication: 08-046, 08-047 Channel: 3 Angle: 70 Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
73.1%	331.25	~	~	~	~	393.45	8.64	~	~	~	~	08-046
106.4%	331.50	~	~	~	~	393.45	8.48	~	~	~	~	08-046
82.9%	331.75	~	~	~	~	393.95	8.48	~	~	~	~	08-046
~	~	~	~	~	~	~	~	~	~	~	~	~
47.2%	350.75	~	~	~	~	393.95	8.72	~	~	~	~	08-047
100.0%	351.00	~	~	~	~	393.95	8.48	~	~	~	~	08-047
39.1%	351.25	~	~	~	~	394.20	6.64	~	~	~	~	08-047
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Clad interface.  
No apparent tip signals.  
Indications have no determinable thruwall and are acceptable to IWB-3510-1.

Analyst: Correa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Farnan  
Level: II Date: 12-18-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet No.: 04-048

Indication: 08-048, 08-049    Channel: 3    Angle: 70    Direction: 0

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	TOF	Min Y	TOF	Y	TOF	Max Y	TOF	Max Y	TOF	
25.2%	337.75	~	~	~	~	389.95	26.64	~	~	~	~	08-048
28.6%	338.00	~	~	~	~	389.95	26.64	~	~	~	~	08-048
12.7%	338.25	~	~	~	~	389.95	27.04	~	~	~	~	08-048
~	~	~	~	~	~	~	~	~	~	~	~	~
22.3%	351.00	~	~	~	~	388.70	35.60	~	~	~	~	08-049
19.6%	351.25	~	~	~	~	388.70	35.76	~	~	~	~	08-049
16.3%	351.50	~	~	~	~	388.95	33.68	~	~	~	~	08-049
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indications have no determinable thruwall and are acceptable to IWB-3510-1.

Analyst: Jeresa Kimball  
Level: III    Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II    Date: 12-19-93 <sup>12-11-93</sup>

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-20  
**Patch ID:** BF-066  
**Ind. Data Sheet No.:** 08-050

**Indication:** 08-050

**Channel:** 7

**Angle:** 45

**Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	342.85	~	~	~	~	391.00	2.54	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
Indication has no determinable length or thruwall and is acceptable to IWB-3510-1.

Analyst: Chesha Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet No.: 08-051

Indication: 08-051

Channel: 9

Angle: 45

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
7.7%	331.00	~	~	~	~	398.00	7.53	~	~	~	~	~
11.9%	331.25	~	~	397.75	7.18	398.25	7.53	398.50	7.73	~	~	~
16.3%	331.50	~	~	397.75	7.16	398.25	7.51	398.75	7.88	~	~	~
16.3%	331.75	~	~	397.50	7.00	398.25	7.53	398.75	7.89	~	~	~
14.4%	332.00	~	~	397.50	6.98	398.25	7.53	399.00	8.09	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.23      L = 1.00      S = 1.18

Analyst: Debra Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-18-93

Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-066

**Exam Data Sheet No.:** E-08-20  
**Ind. Data Sheet No.:** 08-051  
**Indication:** 08-051

**Flaw Thruwall Dimension =** 0.23  
**Flaw Length "l" =** 1.00  
**Separation with clad "S" =** N/A  
**Surface Separation "S" =** 1.18

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.29	2.62 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.29	Allowed 2.62

a = 0.115  
 a/l value = 0.115  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.62%  
 a/t = 1.80%

**Comments:**

---



---



---



---



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

R1154

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet No.: 08-052

Indication: 08-052

Channel: 9

Angle: 45

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
9.3%	340.00	~	~	~	~	396.25	5.06	~	~	~	~	~
18.5%	340.25	~	~	396.00	4.91	396.25	5.06	396.50	5.25	~	~	~
17.3%	340.50	~	~	396.00	4.89	396.25	5.06	396.50	5.25	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.20          L = 0.50          S = 2.92

Analyst: Jessica Kimball  
Level: III      Date: 12-18-93

Reviewed By: R.O. Foman  
Level: II      Date: 12-19-93



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-066

**Exam Data Sheet No.:** E-08-20  
**Ind. Data Sheet No.:** 08-052  
**Indication:** 08-052

**Flaw Thruwall Dimension** = 0.20  
**Flaw Length "l"** = 0.50  
**Separation with clad "S"** = N/A  
**Surface Separation "S"** = 2.92

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.80	3.30 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.80	Allowed 3.30

a = 0.100  
 a/l value = 0.200  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.30%  
 a/t = 1.57%

**Comments:**

---



---



---



---



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-20  
Patch ID: BF-066  
Ind. Data Sheet No.: 08-053

Indication: 08-053

Channel: 9

Angle: 45

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
25.2%	357.00	~	~	398.25	7.47	398.75	7.84	399.00	8.04	~	~	~
30.4%	357.25	~	~	398.00	7.29	398.75	7.82	399.25	8.22	~	~	~
28.6%	357.50	~	~	398.00	7.31	398.75	7.84	399.25	8.23	~	~	~
19.6%	357.75	~	~	398.25	7.49	398.50	7.66	398.75	7.84	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.33 L = 0.75 S = 0.91

Analyst: Jeresa Kimball  
Level: III Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II Date: 12-19-93



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-066

**Exam Data Sheet No.:** E-08-20  
**Ind. Data Sheet No.:** 08-053  
**Indication:** 08-053

**Flaw Thruwall Dimension** = 0.33  
**Flaw Length "l"** = 0.75  
**Separation with clad "S"** = N/A  
**Surface Separation "S"** = 0.91

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.00	3.50 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.00	Allowed 3.50

a = 0.165  
a/l value = 0.220  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.50%  
a/t = 2.59%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-20

Patch ID: BF-066

Ind. Data Sheet No.: 08-054

Indication: 08-054

Channel: 10

Angle: 45

Direction: 270

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
5.3%	392.25	~	~	342.60	3.47	342.85	3.74	343.35	4.01	~	~	~
4.4%	392.50	~	~	342.60	3.42	342.85	3.74	343.60	4.15	~	~	~
3.6%	392.75	~	~	342.85	3.71	343.10	4.04	343.60	4.28	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the PATT technique.

TW = 0.22      L = 0.50      S = 2.65      with clad

Analyst: Jessie Kimball  
Level: III      Date: 12-18-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-066

**Exam Data Sheet No.:** E-08-20  
**Ind. Data Sheet No.:** 08-054  
**Indication:** 08-054

**Flaw Thruwall Dimension =** 0.22  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 2.65  
**Surface Separation "S" =** 2.46

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.00	3.50 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.00	Allowed 3.50

a = 0.110  
a/l value = 0.220  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.50%  
a/t = 1.72%

**Comments:**

---



---



---



---

0000 0098

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-20  
**Patch ID:** BF-066  
**Ind. Data Sheet No.:** 08-055

**Indication:** 08-055      **Channel:** 10      **Angle:** 45      **Direction:** 270

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
2.7%	392.25	~	~	~	~	344.60	3.93	~	~	~	~	~
4.4%	392.50	~	~	344.35	3.72	344.60	3.90	345.10	4.44	~	~	~
3.4%	392.75	~	~	344.35	3.80	344.60	3.92	345.10	4.39	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.20      L = 0.50      S = 2.66 with clad

Analyst: Geesa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-18-93

Level: II      Date: 12-19-93

R 1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-066

**Exam Data Sheet No.:** E-08-20  
**Ind. Data Sheet No.:** 08-055  
**Indication:** 08-055

**Flaw Thruwall Dimension** = 0.20  
**Flaw Length "l"** = 0.50  
**Separation with clad "S"** = 2.66  
**Surface Separation "S"** = 2.47

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.79	3.28 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.79	Allowed 3.28

a = 0.099  
 a/l value = 0.198  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.28%  
 a/t = 1.55%

**Comments:**

---



---



---



---

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-21  
**Patch ID:** BF-067  
**Ind. Data Sheet No.:** 08-056

**Indication:** 08-056 and 08-058 thru 08-060     **Channel:** 3     **Angle:** 70     **Direction:** 0

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	TOF	Min Y	TOF	Y	TOF	Max Y	TOF	Max Y	TOF	
22.3%	430.50	~	~	~	~	390.45	22.88	~	~	~	~	08-056
14.4%	430.75	~	~	~	~	390.45	22.80	~	~	~	~	08-056
9.9%	431.00	~	~	~	~	390.45	22.80	~	~	~	~	08-056
~	~	~	~	~	~	~	~	~	~	~	~	~
14.4%	449.50	~	~	~	~	390.20	24.96	~	~	~	~	08-058
20.9%	449.75	~	~	~	~	390.20	24.96	~	~	~	~	08-058
11.9%	450.00	~	~	~	~	390.20	25.20	~	~	~	~	08-058
~	~	~	~	~	~	~	~	~	~	~	~	~
11.9%	452.50	~	~	~	~	389.70	27.36	~	~	~	~	08-059
19.6%	452.75	~	~	~	~	390.20	23.20	~	~	~	~	08-059
14.4%	453.00	~	~	~	~	389.95	25.52	~	~	~	~	08-059
~	~	~	~	~	~	~	~	~	~	~	~	~
19.6%	475.50	~	~	~	~	389.70	29.68	~	~	~	~	08-060
28.6%	475.75	~	~	~	~	389.95	27.52	~	~	~	~	08-060
22.3%	476.00	~	~	~	~	389.95	27.52	~	~	~	~	08-060
10.5%	476.25	~	~	~	~	389.95	27.60	~	~	~	~	08-060
15.3%	476.50	~	~	~	~	389.95	27.60	~	~	~	~	08-060
10.5%	476.75	~	~	~	~	389.95	27.84	~	~	~	~	08-060
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indications have no determinable thruwall and are acceptable to IWB-3510-1.

**Analyst:** Janessa Kimball  
**Level:** III     **Date:** 12-18-93

**Reviewed By:** R.O. Foman  
**Level:** II     **Date:** 12-19-93



R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-21

Patch ID: BF-067

Ind. Data Sheet No.: 08-057

Indication: 08-057

Channel: 3

Angle: 70

Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
19.6%	448.50	~	~	~	~	390.45	20.40	~	~	~	~	~
36.7%	448.75	~	~	~	~	390.45	20.16	~	~	~	~	~
44.3%	449.00	~	~	~	~	390.70	20.00	~	~	~	~	~
22.3%	449.25	~	~	~	~	390.45	19.92	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the PATT technique.

TW = 0.44      L = 1.00      S = 0.85      w/clad

Analyst: Jerusa Kimball

Reviewed By: R.O. Foman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-067

**Exam Data Sheet No.:** E-08-21  
**Ind. Data Sheet No.:** 08-057  
**Indication:** 08-057

**Flaw Thruwall Dimension =** 0.44  
**Flaw Length "l" =** 1.00  
**Separation with clad "S" =** 0.85  
**Surface Separation "S" =** 0.66

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.00	3.50 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.00	Allowed 3.50

a = 0.220  
 a/l value = 0.220  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.50%  
 a/t = 3.45%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-21  
**Patch ID:** BF-067  
**Ind. Data Sheet No.:** 08-061

**Indication:** 08-061      **Channel:** 13      **Angle:** 60      **Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
53.5%	448.50	393.50	1.33	~	~	393.75	1.58	394.00	1.87	394.25	2.09	~
88.2%	448.75	393.50	1.35	~	~	394.00	1.87	394.25	2.09	394.50	2.44	~
73.1%	449.00	393.50	1.35	~	~	394.00	1.86	~	~	394.50	2.32	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Thruwall size was determined by the ASME 50% method.

TW = 0.26      L = 0.50      S = 0.81      with clad

**Analyst:** Gresa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-067

**Exam Data Sheet No.:** E-08-21  
**Ind. Data Sheet No.:** 08-061  
**Indication:** 08-061

**Flaw Thruwall Dimension =** 0.26  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 0.81  
**Surface Separation "S" =** 0.62

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition**  
**TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.35	3.86 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			3.35	3.86

a = 0.128  
a/l value = 0.255  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.86%  
a/t = 2.00%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-21  
Patch ID: BF-067  
Ind. Data Sheet No.: 08-062

Indication: 08-062

Channel: 13

Angle: 60

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
50.2%	451.50	393.50	1.42	~	~	394.00	1.86	~	~	394.25	2.08	~
57.0%	451.75	393.50	1.37	~	~	393.75	1.62	394.00	1.87	394.25	2.10	~
32.4%	452.00	~	~	~	~	393.75	1.62	~	~	394.00	1.86	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Thruwall size was determined by the ASME 50% method.

TW = 0.13      L = 0.50      S = 0.75 with clad

Analyst: *Quana Kimball*  
Level: III      Date: 12-19-93

Reviewed By: *R.O. Forman*  
Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

**GERIS 2000 Indication  
Evaluation Sheet**

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-067

**Exam Data Sheet No.:** E-08-21  
**Ind. Data Sheet No.:** 08-062  
**Indication:** 08-062

**Flaw Thruwall Dimension =** 0.13  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 0.75  
**Surface Separation "S" =** 0.56

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.35	2.70 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.35	Allowed 2.70

a = 0.063  
a/l value = 0.125  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.70%  
a/t = 0.98%

**Comments:**

---



---



---



---



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3

**Weld ID:** C-2-3

**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-22

**Patch ID:** BF-068

**Ind. Data Sheet No.:** 08-063

**Indication:** 08-063

**Channel:** 3

**Angle:** 70

**Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
7.2%	499.25	~	~	~	~	389.95	25.12	~	~	~	~	~
18.5%	499.50	~	~	~	~	389.95	24.72	~	~	~	~	~
18.5%	499.75	~	~	~	~	389.95	24.64	~	~	~	~	~
19.6%	500.00	~	~	~	~	389.95	24.56	~	~	~	~	~
13.5%	500.25	~	~	~	~	389.40	28.56	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.

Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Quessa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

R 1154

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-22  
Patch ID: BF-068  
Ind. Data Sheet No.: 08-064

Indication: 08-064      Channel: 3      Angle: 70      Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
28.6%	502.50	~	~	~	~	389.95	25.20	~	~	~	~	~
26.9%	502.75	~	~	~	~	389.95	25.04	~	~	~	~	~
26.9%	503.00	~	~	~	~	389.95	24.96	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Jeena Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-22  
**Patch ID:** BF-068  
**Ind. Data Sheet No.:** 08-065

**Indication:** 08-065      **Channel:** 9      **Angle:** 45      **Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	496.75	~	~	396.75	6.25	397.00	6.41	398.00	7.16	~	~	~
20.9%	497.00	~	~	396.75	6.24	397.50	6.74	397.75	6.98	~	~	~
19.6%	497.25	~	~	396.75	6.24	397.00	6.41	397.75	6.96	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = .226      L = .5      S = 1.72

Analyst: Debra Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

R1154

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-068

**Exam Data Sheet No.:** E-08-22  
**Ind. Data Sheet No.:** 08-065  
**Indication:** 08-065

**Flaw Thruwall Dimension** = 0.23  
**Flaw Length "I"** = 0.50  
**Separation with clad "S"** = N/A  
**Surface Separation "S"** = 1.72

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.06	3.56 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.06	Allowed 3.56

a = 0.113  
a/l value = 0.226  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.56%  
a/t = 1.77%

Comments:



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-22  
Patch ID: BF-068  
Ind. Data Sheet No.: 08-066

Indication: 08-066

Channel: 13

Angle: 60

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
23.7%	~	~	~	~	~	393.75	1.74	~	~	~	~	~
68.7%	484.50	393.50	1.44	~	~	393.75	1.68	394.00	1.90	394.25	2.20	~
22.3%	484.75	393.50	1.47	~	~	393.75	1.68	~	~	394.00	1.91	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Thruwall size was determined by the ASME 50% method.

TW = 0.11      L = 0.50      S = 0.79      w/clad

Analyst: Debra Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-068

Exam Data Sheet No.: E-08-21  
Ind. Data Sheet No.: 08-066  
Indication: 08-066

Flaw Thruwall Dimension = 0.11  
Flaw Length "l" = 0.50  
Separation with clad "S" = 0.79  
Surface Separation "S" = 0.60

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.26	2.58 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.26	2.58

a = 0.055  
a/l value = 0.110  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.58%  
a/t = 0.86%

Comments:

Blank lines for comments.

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-067

**Indication:** 08-067      **Channel:** 3      **Angle:** 70      **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
12.7%	557.75	~	~	~	~	389.45	36.16	~	~	~	~	~
16.3%	558.00	~	~	~	~	389.20	38.00	~	~	~	~	~
41.6%	558.25	~	~	~	~	389.45	35.44	~	~	~	~	~
39.1%	558.50	~	~	~	~	388.70	41.32	~	~	~	~	~
23.7%	558.75	~	~	~	~	389.70	33.12	~	~	~	~	~
18.5%	559.00	~	~	~	~	389.20	37.28	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen with Ch. 7 (see 08-073) and Ch. 11 (not recorded due to less than ASME DAC level and no apparent tip signals).  
 Thruwall size was determined by the PATT technique.

TW = 0.369      L = 1.5      S = 1.656 w/clad

Analyst: Jeana Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Foman  
 Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-068

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-067  
**Indication:** 08-067

**Flaw Thruwall Dimension =** 0.37  
**Flaw Length "l" =** 1.50  
**Separation with clad "S" =** 1.66  
**Surface Separation "S" =** 1.47

**T measured =** 6.55  
**Clad T nominal =** 0.19

Flaw is unacceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.34	2.68 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.34	Allowed 2.68

a = 0.185  
a/l value = 0.123  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.68%  
a/t = 2.82%

**Comments:**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

00114

114 OF 276

81154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-068

**Indication:** 08-068

**Channel:** 5

**Angle:** 70

**Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
22.3%	543.40	~	~	~	~	394.80	23.36	~	~	~	~	~
64.5%	543.65	~	~	~	~	394.80	23.04	~	~	~	~	~
15.3%	543.90	~	~	~	~	394.80	23.04	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the PATT technique.

TW = 0.40      L = 0.75      S = 1.04      w/clad

Analyst: Debra Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Fournier  
Level: II      Date: 12-19-93

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-069

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-068  
**Indication:** 08-068

**Flaw Thruwall Dimension =** 0.40  
**Flaw Length "l" =** 0.75  
**Separation with clad "S" =** 1.04  
**Surface Separation "S" =** 0.85

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.43	3.96 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.43	Allowed 3.96

a = 0.198  
a/l value = 0.263  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.96%  
a/t = 3.10%

Comments:

---



---



---



---



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3

**Exam Data Sheet No.:** E-08-23

**Weld ID:** C-2-3

**Patch ID:** BF-069

**Cal. ID:** C-004

**Ind. Data Sheet No.:** 08-069

**Indication:** 08-069

**Channel:** 5

**Angle:** 70

**Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
25.2%	562.40	~	~	~	394.80	22.80	~	~	~	~	~	~
9.9%	562.65	~	~	~	395.05	25.20	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Chelsea Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-070

**Indication:** 08-070      **Channel:** 5      **Angle:** 70      **Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
13.5%	558.40	~	~	~	~	396.05	33.28	~	~	~	~	~
34.5%	558.65	~	~	~	~	396.05	33.84	~	~	~	~	~
20.9%	558.90	~	~	~	~	396.05	33.52	~	~	~	~	~
11.2%	559.15	~	~	~	~	396.05	33.76	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

**Analyst:** Jerusa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-071

**Indication:** 08-071

**Channel:** 7

**Angle:** 45

**Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
18.5%	548.35	~	~	390.25	4.43	390.50	4.27	390.75	4.08	~	~	-
11.9%	548.60	~	~	390.25	4.43	390.50	4.27	390.75	4.08	~	~	-
11.9%	548.85	~	~	390.25	4.45	390.50	4.25	390.75	4.08	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-
~	~	~	~	~	~	~	~	~	~	~	~	-

**Comments:** Same Indication recorded with Ch. 11 (08-076).  
 Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

TW = 0.23          L = 0.50          S = 2.91          w/clad

Analyst: Gresa Kimball

Reviewed By: R.O. Forman

Level: III          Date: 12-19-93

Level: II          Date: 12-19-93

R 1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-069

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-071  
**Indication:** 08-071

**Flaw Thruwall Dimension =** 0.23  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 2.91  
**Surface Separation "S" =** 2.72

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.06	3.56 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.06	Allowed 3.56

a = 0.113  
 a/l value = 0.226  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.56%  
 a/t = 1.77%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-23  
Patch ID: BF-069  
Ind. Data Sheet No.: 08-072

Indication: 08-072      Channel: 7      Angle: 45      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
6.8%	551.10	~	~	~	~	386.50	8.00	~	~	~	~	~
16.3%	551.35	~	~	385.75	8.50	386.50	7.96	386.75	7.78	~	~	~
14.4%	551.60	~	~	385.75	8.50	386.25	8.13	386.75	7.78	~	~	~
11.9%	551.85	~	~	386.00	8.33	386.25	8.11	386.50	7.96	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.

TW = 0.33      L = 0.75      S = 0.809

Analyst: Jessica Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-069

Exam Data Sheet No.: E-08-23  
Ind. Data Sheet No.: 08-072  
Indication: 08-072

Flaw Thruwall Dimension = 0.33  
Flaw Length "l" = 0.75  
Separation with clad "S" = N/A  
Surface Separation "S" = 0.81

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.97	3.47 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.97	Allowed 3.47

a = 0.163  
a/l value = 0.217  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.47%  
a/t = 2.55%

Comments:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-073

**Indication:** 08-073      **Channel:** 7      **Angle:** 45      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
13.5%	558.10	~	~	390.75	3.20	391.25	2.85	392.00	2.26	~	~	~
7.2%	558.35	~	~	391.25	2.83	391.50	2.65	392.00	2.26	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 3 (08-067).  
Flaw dimensions assigned from Indication Data sheet 08-067.  
Thruwall size was determined by the PATT technique.

TW = 0.369      L = 1.50      S = 1.656 w/clad

Analyst: Jeana Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

00123

123 of 276

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-069

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-073  
**Indication:** 08-073

**Flaw Thruwall Dimension** = 0.37  
**Flaw Length "l"** = 1.50  
**Separation with clad "S"** = 1.66  
**Surface Separation "S"** = 1.47

**T measured** = 6.55  
**Clad T nominal** = 0.19

Flaw is unacceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.34	2.69 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.34	Allowed 2.69

a = 0.185  
a/l value = 0.123  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.69%  
a/t = 2.82%

**Comments:** Above flaw dimensions were assigned from Indication Data Sheet 08-067.



R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-23

Patch ID: BF-069

Ind. Data Sheet No.: 08-074

Indication: 08-074

Channel: 7

Angle: 45

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
13.5%	574.60	~	~	~	~	388.75	5.19	~	~	~	~	~
44.3%	574.85	~	~	388.50	5.39	388.75	5.21	389.00	5.01	~	~	~
44.3%	575.10	~	~	388.00	5.72	388.75	5.19	389.00	5.01	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the PATT technique.

TW = 0.56      L = 0.50      S = 3.55

Analyst: Debra Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-069

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-074  
**Indication:** 08-074

**Flaw Thruwall Dimension** = 0.56  
**Flaw Length "l"** = 0.50  
**Separation with clad "S"** = N/A  
**Surface Separation "S"** = 3.55

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.280  
a/l value = 0.500  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
a/t = 4.39%

Comments:

---



---



---



---

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-23  
 Patch ID: BF-069  
 Ind. Data Sheet No.: 08-075

Indication: 08-075

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
18.5%	545.75	~	~	~	~	388.75	4.54	~	~	~	~	~
25.2%	546.00	~	~	388.50	4.76	388.75	4.54	~	~	~	~	~
39.1%	546.25	~	~	387.50	5.63	388.75	4.54	389.00	4.37	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the PATT technique.

TW = 0.39          L = 0.50          S = 2.48          w/clad

Analyst: Chelsea Kimball

Reviewed By: R.O. Foman

Level: III          Date: 12-19-93

Level: II          Date: 12-19-93

R.1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-069

Exam Data Sheet No.: E-08-23  
Ind. Data Sheet No.: 08-075  
Indication: 08-075

Flaw Thruwall Dimension = 0.39  
Flaw Length "l" = 0.50  
Separation with clad "S" = 2.48  
Surface Separation "S" = 2.29

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	4.88	5.66 Y
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			4.88	5.66

a = 0.195  
a/l value = 0.390  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 5.66%  
a/t = 3.06%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-23  
Patch ID: BF-069  
Ind. Data Sheet No.: 08-076

Indication: 08-076      Channel: 11      Angle: 60      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
23.7%	548.25	~	~	388.25	6.06	388.75	5.63	~	~	~	~	~
47.2%	548.50	~	~	387.75	6.50	388.75	5.63	389.75	4.78	~	~	~
41.6%	548.75	~	~	388.00	6.26	388.50	5.84	389.50	5.00	~	~	~
32.4%	549.00	~	~	388.25	6.06	388.75	5.84	389.00	5.44	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 7 (08-071).  
 Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the PATT technique.

TW = 0.25      L = 0.75      S = 3.06      w/clad

Analyst: Debra Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Freeman  
Level: II      Date: 12-19-93

**00129**  
129 OF 276

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-069

Exam Data Sheet No.: E-08-23  
Ind. Data Sheet No.: 08-076  
Indication: 08-076

Flaw Thruwall Dimension = 0.25  
Flaw Length "I" = 0.75  
Separation with clad "S" = 3.06  
Surface Separation "S" = 2.87

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.60	3.03 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.60	Allowed 3.03

a = 0.125  
a/l value = 0.167  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.03%  
a/t = 1.96%

Comments:

Blank lines for comments.

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-23  
**Patch ID:** BF-069  
**Ind. Data Sheet No.:** 08-077

**Indication:** 08-077      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
30.4%	562.25	391.25	2.17	~	~	391.50	1.96	~	~	391.75	1.81	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** This indication also seen with Ch. 5 (see 08-069).  
Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00      L = 0.25      S = .8543 w/clad

**Analyst:** Jeresa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Foman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-23  
Patch ID: BF-069  
Ind. Data Sheet No.: 08-078

Indication: 08-078

Channel: 13

Angle: 60

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
28.6%	551.75	~	~	395.25	3.30	395.50	3.52	395.25	4.18	~	~	~
34.5%	552.00	~	~	395.00	3.14	395.50	3.52	396.25	4.18	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the PATT technique.

TW = 0.40      L = 0.25      S = 1.91      w/clad

Analyst: C. J. Kinball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93



R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-069

**Exam Data Sheet No.:** E-08-23  
**Ind. Data Sheet No.:** 08-078  
**Indication:** 08-078

**Flaw Thruwall Dimension =** 0.40  
**Flaw Length "I" =** 0.25  
**Separation with clad "S" =** 1.91  
**Surface Separation "S" =** 1.72

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.200  
 a/l value = 0.500  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
 a/t = 3.13%

**Comments:**

---



---



---



---

# 00133

133 OF 276

R1154



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-24  
**Patch ID:** BF-070  
**Ind. Data Sheet No.:** 08-079

**Indication:** 08-079

**Channel:** 3

**Angle:** 70

**Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
10.5%	625.50	~	~	~	~	390.45	18.96	~	~	~	~	~
15.3%	625.75	~	~	~	~	389.45	26.96	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the PATT technique.

TW = 0.57      L = 0.50      S = 0.675 w/clad

**Analyst:** Deresa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



**GE Nuclear Energy**

**GERIS 2000 Indication  
Evaluation Sheet**

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-070

**Exam Data Sheet No.:** E-08-24  
**Ind. Data Sheet No.:** 08-079  
**Indication:** 08-079

**Flaw Thruwall Dimension =** 0.57  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 0.68  
**Surface Separation "S" =** 0.49

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.285  
a/l value = 0.500  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
a/t = 4.46%

**Comments:**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-24  
Patch ID: BF-070  
Ind. Data Sheet No.: 08-080

Indication: 08-080 Channel: 3 Angle: 70 Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
19.6%	648.50	~	~	~	~	389.70	26.16	~	~	~	~	~
18.5%	948.75	~	~	~	~	389.70	26.16	~	~	~	~	~
30.4%	649.00	~	~	~	~	389.70	26.16	~	~	~	~	~
8.2%	649.25	~	~	~	~	389.70	26.08	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the PATT technique.

TW = 0.31 L = 1.00 S = 1.19 with clad

Analyst: Jessica Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-070

**Exam Data Sheet No.:** E-08-24  
**Ind. Data Sheet No.:** 08-080  
**Indication:** 08-080

**Flaw Thruwall Dimension** = 0.31  
**Flaw Length "l"** = 1.00  
**Separation with clad "S"** = 1.19  
**Surface Separation "S"** = 1.00

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.53	2.94 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.53	Allowed 2.94

a = 0.155  
a/l value = 0.155  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.94%  
a/t = 2.43%

Comments:

---



---



---



---

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-24  
**Patch ID:** BF-070  
**Ind. Data Sheet No.:** 08-081

**Indication:** 08-081      **Channel:** 7      **Angle:** 45      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
4.4%	606.35	~	~	~	~	389.75	3.98	~	~	~	~	~
13.5%	606.60	~	~	389.00	4.53	389.50	4.18	390.00	3.81	~	~	~
13.5%	606.85	~	~	389.00	4.53	389.50	4.16	390.25	3.69	~	~	~
12.7%	607.10	~	~	389.00	4.53	389.75	4.00	390.25	3.67	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the PATT technique.

TW = 0.30      L = 0.75      S = 2.79      w/clad

**Analyst:** Debra Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R 1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-070

**Exam Data Sheet No.:** E-08-24  
**Ind. Data Sheet No.:** 08-081  
**Indication:** 08-081

**Flaw Thruwall Dimension =** 0.30  
**Flaw Length "l" =** 0.75  
**Separation with clad "S" =** 2.79  
**Surface Separation "S" =** 2.60

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.80	3.30 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.80	3.30

a = 0.150  
a/l value = 0.200  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.30%  
a/t = 2.35%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-24  
 Patch ID: BF-070  
 Ind. Data Sheet No.: 08-082

Indication: 08-082      Channel: 7      Angle: 45      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
16.3%	619.10	~	~	~	~	388.25	5.91	~	~	~	~	~
22.3%	619.35	~	~	387.50	6.41	388.25	5.87	388.75	5.51	~	~	~
14.4%	619.60	~	~	387.75	6.24	388.00	6.06	388.75	5.53	~	~	~
13.5%	619.85	~	~	387.25	6.60	388.00	6.06	388.25	5.87	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.  
 This indication also seen with Ch. 9 (not recorded due to less than ASME DAC level and no apparent tip signals).

TW = 0.20      L = 0.75      S = 2.35

Analyst: Jelesa Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93





**GE Nuclear Energy**

**GERIS 2000 Indication  
Evaluation Sheet**

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-070

**Exam Data Sheet No.:** E-08-24  
**Ind. Data Sheet No.:** 08-082  
**Indication:** 08-082

**Flaw Thruwall Dimension =** 0.20  
**Flaw Length "l" =** 0.75  
**Separation with clad "S" =** N/A  
**Surface Separation "S" =** 2.35

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.39	2.76 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.39	Allowed 2.76

a = 0.099  
a/l value = 0.132  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.76%  
a/t = 1.55%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-24  
Patch ID: BF-070  
Ind. Data Sheet No.: 08-083

Indication: 08-083

Channel: 11

Angle: 60

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
34.5%	607.50	~	~	387.75	6.44	389.00	5.41	389.25	5.19	~	~	~
16.3%	607.75	~	~	~	~	389.00	5.41	~	~	~	~	~
15.3%	608.00	~	~	~	~	389.00	5.41	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 This indication also seen with Ch. 13 (not recorded due to less than ACME DAC level and no apparent tip signals).  
 Thruwall size was determined by the SPOT technique.

TW = 0.30                      L = 0.50                      S = 2.56      with clad

Analyst: Quessa Kimball  
 Level: III                      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II                      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-070

Exam Data Sheet No.: E-08-24  
Ind. Data Sheet No.: 08-083  
Indication: 08-083

Flaw Thruwall Dimension = 0.30  
Flaw Length "l" = 0.50  
Separation with clad "S" = 2.56  
Surface Separation "S" = 2.37

T nominal = 6.38  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	3.80	4.40 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.80	Allowed 4.40

a = 0.150  
a/l value = 0.300  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.40%  
a/t = 2.35%

Comments:

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-25  
Patch ID: BF-071  
Ind. Data Sheet No.: 08-084

Indication: 08-084

Channel: 3

Angle: 70

Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
30.4%	709.75	~	~	~	~	391.20	17.84	~	~	~	~	~
25.2%	710.00	~	~	~	~	389.95	27.44	~	~	~	~	~
23.7%	710.25	~	~	~	~	389.95	27.36	~	~	~	~	~
14.4%	710.50	~	~	~	~	391.20	17.92	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the PATT technique.

TW = 0.23      L = 1.00      S = 0.723 w/clad

Analyst: Debra Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

R1154

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-071

**Exam Data Sheet No.:** E-08-25  
**Ind. Data Sheet No.:** 08-084  
**Indication:** 08-084

**Flaw Thruwall Dimension** = 0.23  
**Flaw Length "I"** = 1.00  
**Separation with clad "S"** = 0.72  
**Surface Separation "S"** = 0.53

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	-	-
0.05	2.00	2.2	-	-
0.10	2.20	2.5	2.30	2.63 Y
0.15	2.50	2.9	-	-
0.20	2.80	3.3	-	-
0.25	3.30	3.8	-	-
0.30	3.80	4.4	-	-
0.35	4.40	5.1	-	-
0.40	5.00	5.8	-	-
0.45	5.10	6.7	-	-
0.50	5.20	7.6	-	-
			Allowed	Allowed
			2.30	2.63

a = 0.116  
a/l value = 0.116  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.63%  
a/t = 1.82%

**Comments:**

---



---



---



---

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-25  
Patch ID: BF-071  
Ind. Data Sheet No.: 08-085

Indication: 08-085 Channel: 3 Angle: 70 Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
7.2%	719.50	~	~	~	~	390.20	21.20	~	~	~	~	~
20.9%	719.75	~	~	~	~	390.20	20.16	~	~	~	~	~
17.3%	720.00	~	~	~	~	390.20	20.24	~	~	~	~	~
9.9%	720.25	~	~	~	~	390.45	18.72	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Aeresa Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-25  
**Patch ID:** BF-071  
**Ind. Data Sheet No.:** 08-086

**Indication:** 08-086

**Channel:** 3

**Angle:** 70

**Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
22.3%	721.75	~	~	~	~	391.45	17.36	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

**Analyst:** Jessica Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-25  
Patch ID: BF-071  
Ind. Data Sheet No.: 08-087

Indication: 08-087 Channel: 7 Angle: 45 Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
17.3%	696.60	~	~	389.00	4.63	389.25	4.45	389.50	4.27	~	~	~
25.2%	696.85	~	~	389.00	4.61	389.25	4.45	389.75	4.07	~	~	~
15.3%	697.10	~	~	389.00	4.61	389.25	4.45	389.75	4.07	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
Thruwall size was determined by the SPOT technique.  
Same indication recorded with Ch. 11 (08-089).

TW = 0.28 L = 0.50 S = 3.01 w/clad

Analyst: Louisa Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II Date: 12-19-93



R1154



**GE Nuclear Energy**

**GERIS 2000 Indication Evaluation Sheet**

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-071

**Exam Data Sheet No.:** E-08-25  
**Ind. Data Sheet No.:** 08-087  
**Indication:** 08-087

**Flaw Thruwall Dimension =** 0.28  
**Flaw Length "l" =** 0.50  
**Separation with clad "S" =** 3.01  
**Surface Separation "S" =** 2.82

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	-	-
0.05	2.00	2.2	-	-
0.10	2.20	2.5	-	-
0.15	2.50	2.9	-	-
0.20	2.80	3.3	-	-
0.25	3.30	3.8	3.60	4.16 Y
0.30	3.80	4.4	-	-
0.35	4.40	5.1	-	-
0.40	5.00	5.8	-	-
0.45	5.10	6.7	-	-
0.50	5.20	7.6	-	-
			Allowed	Allowed
			3.60	4.16

a = 0.140  
 a/l value = 0.280  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.16%  
 a/t = 2.19%

**Comments:**  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-25  
**Patch ID:** BF-071  
**Ind. Data Sheet No.:** 08-088

**Indication:** 08-088      **Channel:** 7      **Angle:** 45      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
50.2%	695.85	~	~	~	~	381.00	9.55	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indication has no determinable thruwall and is acceptable to IWB-3510-1.  
 This indication seen with Ch. 8 at less than ASME required DAC level.  
 13.05 dB below Notch sensitivity.

**Analyst:** C. Deresakimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** F.O. Fauman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-25  
 Patch ID: BF-071  
 Ind. Data Sheet No.: 08-089

Indication: 08-089      Channel: 11      Angle: 60      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
28.6%	696.75	~	~	~	~	388.25	5.00	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.  
 Same indication recorded with Ch. 7 (08-087).

TW = 0.28      L = 0.25      S = 2.36      with clad

Analyst: Deresa Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93

R.1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-071

**Exam Data Sheet No.:** E-08-25  
**Ind. Data Sheet No.:** 08-089  
**Indication:** 08-089

**Flaw Thruwall Dimension** = 0.28  
**Flaw Length "l"** = 0.25  
**Separation with clad "S"** = 2.36  
**Surface Separation "S"** = 2.17

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition  
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.140  
 a/l value = 0.500  
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%  
 a/t = 2.19%

**Comments:**

---



---



---



---



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

R1154

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-090

Indication: 08-090      Channel: 1      Angle: 0      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
44.3%	756.40	~	~	~	~	393.50	5.00	~	~	~	~	~
60.6%	756.65	~	~	~	~	393.50	4.98	~	~	~	~	~
82.9%	756.90	~	~	392.75	5.08	393.50	5.00	393.75	5.02	~	~	~
82.9%	757.15	~	~	392.75	5.06	393.00	5.05	393.50	5.02	~	~	~
120.6%	757.40	~	~	392.75	5.08	393.25	5.02	393.50	5.00	~	~	~
73.1%	757.65	~	~	~	~	393.25	5.02	~	~	~	~	End of scan
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: This Indication also recorded with channel 2 indication 08-091.  
Indication evaluated as a laminar reflector and is acceptable in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, no Addenda.

Analyst: Alesia Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

21154

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-091

Indication: 08-091      Channel: 2      Angle: 0      Direction: 90

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
64.5%	393.00	~	~	756.85	5.19	757.10	5.19	757.60	5.19	~	~	~
225.7%	393.25	~	~	756.85	5.17	757.60	5.12	758.10	5.17	~	~	~
165.0%	393.50	~	~	757.10	5.10	757.85	5.12	758.35	5.14	~	~	~
165.0%	393.75	~	~	756.60	5.07	757.10	5.07	757.60	5.10	~	~	~
47.2%	394.00	~	~	~	~	757.60	5.12	~	~	~	~	~
60.6%	394.25	~	~	757.35	5.17	757.60	5.19	~	~	~	~	~
41.6%	394.50	~	~	~	~	757.35	5.20	~	~	~	~	~
50.2%	394.75	~	~	~	~	757.35	5.23	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Same indication recorded with Ch. 1 (08-090).  
 Indication evaluated as a laminar reflector and is acceptable in accordance with IWB-3510-2,  
 ASME Section XI, 1986 Edition, no Addenda.

Analyst: Debra Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-092

**Indication:** 08-092      **Channel:** 3      **Angle:** 70      **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
16.3%	739.25	~	~	~	~	390.20	27.36	~	~	~	~	~
25.2%	739.50	~	~	~	~	390.45	25.20	~	~	~	~	~
30.4%	739.75	~	~	~	~	390.20	27.20	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

**Analyst:** Deena Kimbell  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Fournan  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-093

**Indication:** 08-093      **Channel:** 3      **Angle:** 70      **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
18.5%	746.00	~	~	~	~	391.45	18.80	~	~	~	~	~
28.6%	746.25	~	~	~	~	391.45	18.80	~	~	~	~	~
25.2%	746.50	~	~	~	~	391.45	18.88	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Doreen Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93



R1154



**GE Nuclear Energy**

**GERIS 2000 Indication  
Data Sheet**

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-094

**Indication:** 08-094      **Channel:** 3      **Angle:** 70      **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
11.9%	753.25	~	~	~	~	390.70	15.92	~	~	~	~	~
28.6%	753.50	~	~	~	~	390.95	14.40	~	~	~	~	~
36.7%	753.75	~	~	~	~	390.70	16.08	~	~	~	~	~
13.5%	754.00	~	~	~	~	390.95	14.40	~	~	~	~	~
12.7%	754.25	~	~	~	~	390.95	13.60	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

**Analyst:** Deesa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** F.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-095

**Indication:** 08-095      **Channel:** 3      **Angle:** 70      **Direction:** 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
14.4%	757.25	~	~	~	~	390.70	15.84	~	~	~	~	~
19.6%	757.50	~	~	~	~	390.95	13.84	~	~	~	~	~
23.7%	757.75	~	~	~	~	390.95	13.92	~	~	~	~	~
9.3%	758.00	~	~	~	~	390.95	13.84	~	~	~	~	~
22.3%	758.25	~	~	~	~	390.45	17.36	~	~	~	~	~
28.6%	758.50	~	~	~	~	390.45	17.44	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the PATT technique.

TW = 0.34      L = 1.50      S = 0.37 w/clad

**Analyst:** Ceresa Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** F.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3  
Weld ID: C-2-3  
Patch: BF-072

Exam Data Sheet No.: E-08-26  
Ind. Data Sheet No.: 08-095  
Indication: 08-095

Flaw Thruwall Dimension = 0.34  
Flaw Length "l" = 1.50  
Separation with clad "S" = 0.37  
Surface Separation "S" = 0.18

T measured = 6.60  
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.27	2.60 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.27	Allowed 2.60

a = 0.168  
a/l value = 0.112  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.60%  
a/t = 2.55%

Comments:

Blank lines for comments.

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-26

Patch ID: BF-072

Ind. Data Sheet No.: 08-096

Indication: 08-096

Channel: 5

Angle: 70

Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
13.5%	724.15	~	~	~	~	395.05	28.16	~	~	~	~	~
34.5%	724.40	~	~	~	~	395.05	28.80	~	~	~	~	~
32.4%	724.65	~	~	~	~	395.05	28.96	~	~	~	~	~
22.3%	724.90	~	~	~	~	395.05	29.12	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
 Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Debra Kimball  
 Level: III Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-097

**Indication:** 08-097

**Channel:** 5

**Angle:** 70

**Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
10.5%	744.90	~	~	~	~	394.55	24.32	~	~	~	~	~
30.4%	745.15	~	~	~	~	394.55	24.08	~	~	~	~	~
19.6%	745.40	~	~	~	~	394.80	26.48	~	~	~	~	~
17.3%	745.85	~	~	~	~	394.80	26.40	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Ceresa Kimball  
Level: III Date: 12-19-93

Reviewed By: R.O. Fauman  
Level: II Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-098

Indication: 08-098      Channel: 5      Angle: 70      Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
8.2%	747.65	~	~	~	~	394.80	26.40	~	~	~	~	~
11.9%	747.90	~	~	~	~	394.55	24.40	~	~	~	~	~
22.3%	748.15	~	~	~	~	394.55	24.32	~	~	~	~	~
25.2%	748.40	~	~	~	~	394.80	26.32	~	~	~	~	~
13.5%	748.65	~	~	~	~	394.80	27.04	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

Analyst: Deeana Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-2-3

Cal. ID: C-004

Exam Data Sheet No.: E-08-26

Patch ID: BF-072

Ind. Data Sheet No.: 08-099

Indication: 08-099

Channel: 7

Angle: 45

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
12.7%	731.85	~	~	389.50	3.97	390.25	3.24	390.50	3.08	~	~	~
5.6%	732.10	~	~	390.00	3.43	390.25	3.24	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

---

TW = 0.20      L = 0.25      S = 2.19 w/clad

Analyst: C. J. Kimball

Level: III      Date: 12-19-93

Reviewed By: R.O. Forman

Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-072

**Exam Data Sheet No.:** E-08-25  
**Ind. Data Sheet No.:** 08-099  
**Indication:** 08-099

**Flaw Thruwall Dimension =** 0.20  
**Flaw Length "l" =** 0.25  
**Separation with clad "S" =** 2.19  
**Surface Separation "S" =** 2.00

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition**  
**TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	4.95	5.74 Y
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 4.95	Allowed 5.74

a = 0.099  
a/l value = 0.396  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 5.74%  
a/t = 1.55%

**Comments:**

---



---



---



---



R 1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-100

Indication: 08-100      Channel: 9      Angle: 45      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
41.6%	744.75	393.75	1.92	~	~	394.00	2.14	~	~	394.25	2.33	~
60.6%	745.00	393.50	1.77	~	~	394.00	2.14	~	~	394.50	2.50	~
57.0%	745.25	393.50	1.77	~	~	394.00	2.17	~	~	394.50	2.50	~
32.4%	745.50	393.75	1.92	~	~	394.00	2.14	~	~	394.25	2.33	~
11.2%	745.75	~	~	~	~	394.00	2.14	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00      L = 1.00      S = 1.27 w/clad

Analyst: Laura Kimball  
Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-101

**Indication:** 08-101      **Channel:** 9      **Angle:** 45      **Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	750.50	394.00	2.17	~	~	394.25	2.36	~	~	~	~	~
44.3%	750.75	393.75	2.01	~	~	394.00	2.23	~	~	394.50	2.50	~
32.4%	751.00	393.75	2.04	~	~	394.00	2.19	~	~	394.50	2.55	~
14.4%	751.25	~	~	~	~	394.00	2.17	~	~	~	~	~
22.3%	751.50	394.00	2.18	~	~	394.25	2.36	~	~	~	~	~
47.2%	751.75	393.75	2.01	~	~	394.25	2.36	~	~	~	~	~
14.4%	752.00	~	~	~	~	394.00	2.18	~	~	394.50	2.57	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall and is acceptable to IWB-3510-1.

TW = 0.00      L = 1.50      S = 1.668 w/clad

Analyst: C.eresa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-102

Indication: 08-102      Channel: 9      Angle: 45      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
18.5%	754.00	~	~	~	~	394.00	2.08	~	~	~	~	~
22.3%	754.25	394.00	2.08	~	~	394.25	2.22	~	~	394.50	2.39	~
41.6%	754.50	393.75	1.94	~	~	394.25	2.22	~	~	394.50	2.39	~
28.9%	754.75	393.75	2.01	~	~	394.00	2.06	~	~	394.50	2.39	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.

Thruwall size was determined by the Reg. Guide 20% beam spread correction method.

Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = .75      S = 1.569 w/clad

Analyst: Debra Kimball

Reviewed By: R.O. Fournier

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-103

Indication: 08-103      Channel: 11      Angle: 60      Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
113.4%	727.00	390.00	2.56	390.50	2.10	391.00	1.68	~	~	391.50	1.26	~
82.9%	727.25	390.25	2.30	390.75	1.86	391.00	1.66	391.25	1.45	~	~	~
77.9%	727.50	390.25	2.30	390.75	1.88	391.00	1.66	391.25	1.45	391.50	1.33	~
30.4%	727.75	390.50	2.10	~	~	390.75	1.88	~	~	391.25	1.52	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Thruwall size was determined by the ASME 50% method.

TW = .325      L = .75      S = .67 w/clad

Analyst: Corea Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

R1154



**GE Nuclear Energy**

## GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-072

**Exam Data Sheet No.:** E-08-26  
**Ind. Data Sheet No.:** 08-103  
**Indication:** 08-103

**Flaw Thruwall Dimension =** 0.33  
**Flaw Length "l" =** 0.75  
**Separation with clad "S" =** 0.67  
**Surface Separation "S" =** 0.48

**T nominal =** 6.38  
**Clad T nominal =** 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.97	3.47 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.97	3.47

a = 0.163  
a/l value = 0.217  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.47%  
a/t = 2.55%

**Comments:**

---



---



---



---

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-104

**Indication:** 08-104      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20%		50%		@ Max		50%		20%		Remarks
		Min Y	MP	Min Y	MP	Y	MP	Max Y	MP	Max Y	MP	
41.6%	739.25	391.00	2.44	~	~	391.50	1.97	~	~	391.75	1.71	~
50.2%	739.50	391.00	2.44	~	~	391.75	1.75	~	~	~	~	~
41.6%	739.75	309.75	2.70	~	~	391.50	1.97	~	~	391.75	1.75	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.

Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = .50      S = .875    w/clad

**Analyst:** C. J. Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R. O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-105

**Indication:** 08-105      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
36.7%	746.00	391.25	2.36	~	~	391.75	1.86	~	~	392.00	1.55	~
41.6%	746.25	390.25	3.30	~	~	391.75	1.86	~	~	392.00	1.55	~
28.6%	746.50	390.25	3.28	~	~	391.75	1.86	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** Thruwall size was determined by the SPOT technique.

TW = .34      L = .5      S = .76 w/clad

**Analyst:** Jessica Kimball  
**Level:** III      **Date:** 12-19-93

**Reviewed By:** R.O. Forman  
**Level:** II      **Date:** 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-072

**Exam Data Sheet No.:** E-08-26  
**Ind. Data Sheet No.:** 08-104  
**Indication:** 08-104

**Flaw Thruwall Dimension** = 0.34  
**Flaw Length "l"** = 0.50  
**Separation with clad "S"** = 0.76  
**Surface Separation "S"** = 0.57

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

### ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	4.28	4.96 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			4.28	4.96

a = 0.170  
a/l value = 0.340  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.96%  
a/t = 2.66%

**Comments:**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_





**GE Nuclear Energy**

**GERIS 2000 Indication Data Sheet**

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-106

**Indication:** 08-106      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
30.4%	751.00	390.25	2.84	~	~	390.75	2.46	~	~	391.2.	2.27	~
20.9%	751.25	~	~	~	~	390.75	2.42	~	~	~	~	~
18.5%	751.50	~	~	~	~	390.75	2.44	~	~	~	~	~
23.7%	751.75	~	~	~	~	390.50	2.68	~	~	390.75	2.54	~
23.7%	752.00	~	~	~	~	390.50	2.86	~	~	390.50	2.68	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.  
 Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = 1.0      S = 1.23      w/clad

Analyst: <u>Ceresa Kimball</u>	Reviewed By: <u>R.O. Forman</u>
Level: <u>III</u> Date: <u>12-19-93</u>	Level: <u>II</u> Date: <u>12-19-93</u>

R1154



**GE Nuclear Energy**

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-107

**Indication:** 08-107      **Channel:** 11      **Angle:** 60      **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	726.25	394.25	2.34	~	~	394.50	2.58	~	~	~	~	~
20.9%	726.50	~	~	~	~	394.25	2.37	~	~	394.50	2.58	~
20.9%	726.75	~	~	~	~	394.50	2.58	~	~	~	~	~
20.9%	727.00	~	~	~	~	394.50	2.58	~	~	~	~	~
34.5%	727.25	394.00	2.15	~	~	394.25	2.37	~	~	394.50	2.58	~
39.1%	727.50	394.00	2.15	~	~	394.25	2.37	~	~	394.50	2.58	~
50.2%	727.75	393.50	1.81	~	~	394.25	2.37	~	~	394.50	2.58	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.

Thruwall size was determined by the Reg. Guide 20% beam spread correction method.

Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = 1.5      S = 1.185 w/clad

Analyst: Jessica Kimball  
Level: III      Date: 12-19-93

Reviewed By: F.O. Foreman  
Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
Weld ID: C-2-3  
Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
Patch ID: BF-072  
Ind. Data Sheet No.: 08-108

Indication: 08-108      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
20.9%	733.75	394.00	2.10	~	~	394.25	2.32	~	~	394.75	2.78	~
50.2%	734.00	393.75	1.86	~	~	394.00	2.12	~	~	395.00	2.97	~
28.6%	734.25	393.50	1.68	~	~	394.00	2.10	~	~	394.25	2.37	~
36.7%	734.50	393.75	1.88	~	~	394.00	2.12	~	~	394.25	2.37	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.  
Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = .75      S = 1.06      w/clad

Analyst: Julesa Kimball

Reviewed By: R.O. Forman

Level: III      Date: 12-19-93

Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

**Project:** TVA, Browns Ferry, Unit 3  
**Weld ID:** C-2-3  
**Cal. ID:** C-004

**Exam Data Sheet No.:** E-08-26  
**Patch ID:** BF-072  
**Ind. Data Sheet No.:** 08-109

**Indication:** 08-109

**Channel:** 13

**Angle:** 60

**Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
23.7%	740.50	~	~	~	~	394.25	2.25	~	~	~	~	~
30.4%	740.75	394.00	2.05	~	~	394.25	2.27	~	~	394.75	2.76	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

**Comments:** No apparent tip signals.

Thruwall size was determined by the Reg. Guide 20% beam spread correction method.  
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.0      L = .25      S = 1.135 w/clad

Analyst: Chelsea Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3  
 Weld ID: C-2-3  
 Cal. ID: C-004

Exam Data Sheet No.: E-08-26  
 Patch ID: BF-072  
 Ind. Data Sheet No.: 08-110

Indication: 08-110      Channel: 13      Angle: 60      Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
32.4%	744.75	393.75	1.88	~	~	394.50	2.61	~	~	395.00	3.05	~
53.5%	745.00	393.75	1.93	~	~	394.50	2.61	~	~	395.00	3.02	~
53.5%	745.25	393.75	1.88	~	~	394.50	2.61	~	~	395.00	3.05	~
34.5%	745.50	393.75	1.86	~	~	394.50	2.61	~	~	394.75	2.83	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Recorded at less than ASME required levels due to apparent tip diffracted signals.  
 Thruwall size was determined by the SPOT technique.

TW = .44      L = .75      S = 1.09      w/clad

Analyst: Alesia Kimball  
 Level: III      Date: 12-19-93

Reviewed By: R.O. Forman  
 Level: II      Date: 12-19-93

R1154



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Sheet

**Project:** TVA, Browns Ferry Unit 3  
**Weld ID:** C-2-3  
**Patch:** BF-072

**Exam Data Sheet No.:** E-08-26  
**Ind. Data Sheet No.:** 08-110  
**Indication:** 08-110

**Flaw Thruwall Dimension** = 0.44  
**Flaw Length "I"** = 0.75  
**Separation with clad "S"** = 1.09  
**Surface Separation "S"** = 0.90

**T nominal** = 6.38  
**Clad T nominal** = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition**  
**TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.73	4.32 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			3.73	4.32

a = 0.220  
a/l value = 0.293  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.32%  
a/t = 3.45%

**Comments:**

---



---




---



---

# BROWNS FERRY UNIT-3 WELD LOCATIONS



00179


179 OF 276

0000 0179

R1154

GE NUCLEAR ENERGY	BROWNS FERRY UNIT 3	VESSEL ROLLOUT & AS SCANNED PATCH LOCATIONS	BF-3-VMA	REV 0
-------------------	---------------------	---	----------	-------

MMS 0000 0180



Nominal Clad T = 3/16"  
 Nominal Base Metal T = 6 3/8"

CH.	ANGLE	DIR.	MIN Y	MAX Y
1	0 W	0	385.27	397.73
2	0 W	90	385.27	397.73
3	70 UP	0	380.36	397.73
4	70 CW	90	385.27	397.73
5	70 DN	180	385.27	402.64
6	70 CCW	270	385.27	397.73
7	45 UP	0	378.71	397.73
8	45 CW	90	385.27	397.73
9	45 DN	180	385.27	404.30
10	45 CCW	270	385.27	397.73
11	60 UP	0	373.90	397.73
12	60 CW	90	385.27	397.73
13	60 DN	180	385.27	409.10
14	60 CCW	270	385.27	397.73
15	0 BM	0	385.27	409.10
16	0 BM	90	373.90	397.73

R1154

00130 180 OF 276




S 0 : Scale





32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC




Lower Ten  
001




# 00181  
R 1154  
181 DE 276

S 0 : Ch 03 : SV-scan : BF-084 : A 60 : D 0 : H




Line = 0038, Trigger = 0058  
X = 625.65in, Y = 386.54in Z = 0.37in  
Log

S 1 : Ch 05 : SV-scan : BF-084 : A 68 : D 180 : H




Line = 0035, Trigger = 0078  
X = 626.35in, Y = 386.13in Z = 0.30in

S 0 : Ch 03 : AMP C-scan : BF-084 : A 80 : D 0




X = 625.65in, Y = 385.50in  
DAC-LOG

S 1 : Ch 05 : AMP C-scan : BF-084 : A 68 : D 180




X = 626.35in, Y = 386.95in  
DAC-LOG

S 0 : Ch 03 : EV-scan : BF-084 : A 60 : D 0 : H



Line = 0038, Trigger = 0058







S 1 : Ch 05 : EV-scan : BF-084 : A 68 : D 180 : H



Line = 0035, Trigger = 0078

```
Lower Tor
/test>dump /max
tor3/5-109
```

182 of 276  
00182  
R1154



00000 00000



21154  
183 OF 276

00183




S D : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%



Low  
/test>c  
tor3/B-







00184

184 of 276  
R 1154

S 1: Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.0  
93.2

DAC



Lower Ten  
/test>dump /max  
tar3/8-004


R1154  
185 of 276  
00185

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2


S 0 : Ch 05 : AMP C-scan : BF-062 : A 67 : D 180

L[046]  
T[068]  
ABS



x = 87.401in, y = 395.301in  
DAC-LOG


Ch 5 : B-scan Zoom



Slot 0 : A-scan : BF-062 : A 67 : D 180


L[046]  
T[068]  
B[000]  
160%

FREEZE	AUTO SCALE	CHAN 05	VIDEO	LINEAR
TIME SCALE	TRACE OFF	SCRN GAIN	100% DAC	VERT OFF
-A- GATE	-B- GATE	-C- GATE	-I- GATE	-BE- GATE



Dist/Time Start = 25.04, End = 26.80, Diff = 1.76  
Amplitude Start = 66.54, End = 63.83, Diff = 2.72, Mean = 65.19


S 0 : Ch 05 : B-scan : BF-062 : A 67 : D 180 : H



Line = 0046, Trigger = 0068  
x = 87.40in, y = 392.14in z = 1.23in

Lower Tern  
/test>dump /max  
-tor3/8-005

S 0 : Ch 05 : EV-scan : BF-062 : A 67 : D 180 : H



Log


0000 0186  
R1154  
186 of 276  
00186

S 0 : Scale

S 0 : Ch 05 : AMP C-scan : BF-062 : A 67 : D 180


- 32.3
- 36.6
- 41.0
- 45.3
- 49.7
- 54.0
- 58.4
- 62.7
- 67.1
- 71.4
- 75.8
- 80.1
- 84.5
- 88.8
- 93.2

L[046]  
T[068]  
ABS



X = 87.40in, Y = 395.30in  
DAC-LOG


Ch 5 : B-scan Zoom



Slot 0 : A-scan : BF-062 : A 67 : D 180

L[046]  
T[068]  
B[000]


FREEZE	AUTO SCALE	CHAN 05	VIDEO	LINEAR
TIME SCALE	TRACE OFF	SCRN GAIN	100% DAC	VERT OFF
-A- GATE	-B- GATE	-C- GATE	-I- GATE	-BE- GATE



Dist/Time Start = 26.80, End = 26.80, Diff = 0.00  
Amplitude Start = 64.37, End = 64.37, Diff = 0.00, Mean = 64.37

S 0 : Ch 05 : B-scan : BF-062 : A 67 : D 180 : H

ABS  
DAC




Line = 0046, Trigger = 0068  
X = 87.40in, Y = 392.16in Z = 1.21in

Lower Tern  
/test>dump /max  
tor3/B-005

S 0 : Ch 05 : EV-scan : BF-062 : A 67 : D 180 : H

ABS  
DAC



Log






187 OF 276  
R1154  
00187

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC



Lower Ten  
/test>dump /max  
tor3/8-006

R1154  
188 of 274  
00188



S 1: Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2




DAC

S 1: Ch 11: AMP C-scan: BF-062

L[046]  
T[050]  
ABS

379.00  
73.25 88.75 104.25 119.75

X = 85.75in, Y = 390.50in  
DAC-LOG



Lower Ten  
/test>dump /max  
top3/B-007

00189

189 of 276

R1154

S 1 : Scale




32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

S 1 : Ch 11 : AMP C-scan : BF-062

L[036]  
T[129]  
ABS

379.00  
73.25 88.75 104.25 119.75

x = 105.50in, y = 388.00in  
DAC-LOG



Lower-Ten  
/test>dump /max  
tor3/8-008

R 1154  
190 OF 276  
00190

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.7  
84.5  
88.8




100%  
50%  
20%

S 0 : Ch 11 : AMP C-scan : BF-062

L[050]  
T[095]  
ABS

379.00  
73.25 88.75 104.25 119.75

X = 97.00in, Y = 391.50in  
DAC-LOG



Lower Termi

21154  
191 OF 276  
00191

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.0



100%  
50%  
20%

S 0 : Ch 11 : AMP C-scan : BF-062


L [050]  
T [090]  
ABS

379.00  
73.25 88.75 104.25 119.75

X = 95.75in, Y = 391.50in  
DAC-LOG







Lower Termin  
or 3/8-011a



21154  
192 OF 276  
: 00192

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2



00193  
 193 OF 270  
 R1154

S 1 : Scale

32.3

36.6

41.0

45.3

49.7 100%

54.0 50%

58.4

62.7 20%

67.1

71.4

75.8

80.1

84.5

88.8

93.2

S 1 : Ch 13 : AMP C-scan : BF-062

L[024]


T[056]

ABS


388.25 73.25 88.75 104.25 119.75

X = 87.25in, Y = 394.25in


DAC-LOG



Ch 13 : B-scan Zoom





062 : A 57 : D 180 : H





21154  
194 of 276  
00194

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4 20%  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2



Lower Term  
or 3/B-016



R 1154  
195 OF 276  
00195

S 1 : Scale

32.3

36.6

41.0

45.3

49.7 100%

54.0 50%

58.4

62.7 20%

67.1

71.4

75.8





80.1

84.5

88.8

93.2

DAC




21154  
 196 of 276  
 00196



S 0 : Scale





32.3	
36.6	
41.0	
45.3	
49.7	
54.0	
58.4	
62.7	100
67.1	50
71.4	20
75.8	
80.1	
84.5	
88.8	
93.2	

DAC



Lower Tr

1/test>dump /ma  
xtor3/B-018








R1154  
 197 OF 276  
 00197

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.0  
93.2

100%  
50%  
20%

DAC



Lower Tor  
/test>dump /max  
tor3/8-019

R1154  
198 OF 276  
00198

S 0 : Scale

32.3

36.6

41.0

45.3

49.7

54.0

58.4

62.7

67.1

71.4

75.8

80.1

84.5

100%

50%

20%

S 0 : Ch 07 : AMP C-scan : BF-063

L[047]

T[000]




ABS

379.00

136.10 151.60 167.10 182.60

X = 136.10in, Y = 390.75in

DAC-LOG



Line = 0047, Trigger = 0000

X = 136.10in, Y = 392.63in Z = 1.56in

Log

Lower Ten

/test>dump /max

tor3/8-020

00199

199 OF 276

R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.0  
80.4  
84.5  
88.0  
93.2




DAC

S 0 : Ch 11 : AMP C-scan : BF-063

L[043]  
T[117]  
ABS

379.00  
139.25 148.75 164.25 179.75

X = 162.50in, Y = 389.75in  
DAC-LOG






Lower Fan  
/test>dump /max  
tor3/8-021

00200  
R1154  
200 of 276

45.3  
 49.7  
 54.0  
 58.4 100%  
 62.7 50%  
 67.1  
 71.4 20%  
 75.8  
 80.1  
 84.5  
 88.8  
 93.2 DAC

Lower Ten  
 /test/dump /max  
 /ten3/8-022








201 OF 276  
 : 00201







S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
50.4  
62.7 100%  
67.1 50%  
71.4  
75.8 20%  
80.1  
84.5  
88.8  
93.2

DAC



21154  
 202 OF 276  
 00202



Lower Ten  
/test>dump /max  
tor3/B-024

00203

R 1154  
203 OF 276

**S 0 : Scale**

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%





DAC

**S 0 : Ch 07 : AMP C-scan : BF-064**

L[050]  
T[176]  
ABS

379.00  
196.10 211.60 227.10 242.60 258

x = 240.10in, y = 391.50in  
DAC-LOG



Lower Term  
ump / mator3/8-0  
26

204 OF 276  
R1154  
00204



S 0 : Scale

32.3	
36.6	
41.0	
45.3	
49.7	100%
54.0	50%
58.4	
62.7	20%
67.1	
71.4	
75.0	
80.1	
84.5	
88.8	
93.2	




DAC

S 0 : Ch 11 : AMP C-scan : BF-064 :

L[038]
T[022]
ABS

979.00  
193.25 208.75 224.25 239.75 255

x = 198.75in, y = 388.50in  
DAC-LOG



Lower Term  
/test>dump /maxt  
or3/8-026

21154  
205 OF 276  
: 00205

S0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2




DAC

S0 : Ch 11 : AMP C-scan : BF-064 :

L[042]  
T[074]  
ABS

379.00  
193.25 208.75 224.25 239.75 255

X = 211.75in, Y = 389.50in  
DAC-LOG







Lower Term  
/test>dump /maxt  
or 3/8-027

00206  
206 DE 276  
R1154

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4  
75.8 20%  
80.1  
84.5  
88.8  
93.2 DAC

Lower Ten  
/test>dump /max  
tor3/8-028



207 of 276  
21154  
00207

S O : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1 100%  
71.4 50%  
75.8  
80.1 20%  
84.5  
88.8  
93.2

DAC




Lower Ten  
/test>dump /max  
tor3/8-035

S O : Ch 05 : AMP C-scan : BF-065

L[043]  
T[058]  
ABS

383.80  
267.65 283.15 298.65 314.15

X = 282.15in, Y = 394.55in  
DAC-LOG



208 OF 276  
R1154  
00208

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8




100%  
50%  
20%

S 0 : Ch 07 : AMP C-scan : BF-06!

L[030]  
T[095]  
ABS

379.00  
273.35 288.85 304.35 319.85



X = 297.10in, Y = 386.50in  
DAC-LOG




Lower Ten  
/test>dump /max  
tor3/8-038

00209  
209 of 276  
R 1154

S 1: Scale




S 1: Ch 09: B-scan: BF-065: A 45: D 180: H




Line = 0038, Trigger = 0081  
X = 290.75in, Y = 392.39in Z = 2.93in


Slot 1: A-scan: BF-065: A 45: D 180



Ch 9: B-scan Zoom



S 1: Ch 09: EV-scan: BF-065: A 45: D 100: H



Log

Lower Tor  
/test>dump /max  
tor3/8-039

00210  
210 OF 276  
R1154

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



S 1 : Ch 09 : AMP C-scan : BF-06:

L[053]  
T[107]  
ABS


386.00  
270.50 286.00 301.50 317.00

X = 297.25in, Y = 399.25in  
DAC-LOG

S 1 : Ch 09 : 8-scan : BF-065 : A 45 : D 180 : H



S 1 : Ch 09 : EV-scan : BF-065 : A 45 : D 180 : H



Lower Ten  
/test>dump /max  
tor3/8-040

00211

R 1154  
211 OF 276

S D : Scale




32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

S-D: Ch 11: AMP-G-scan: BF-065

L[041]  
T[081]  
ABS

379.00  
270.50 286.00 301.50 317.00

X = 290.75in, Y = 389.25in  
DAC-LOG



212 OF 276  
R1154  
00212



S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

DAC



Lower Ten  
/test>dump /max  
tor3/8-042

S 0 : Ch 11 : AMP C-scan : BF-065

L[021]  
T[107]  
ABS

379.00  
270.50 286.00 301.50 317.00

X = 297.251n, Y = 304.251n  
DAC-LOG







0000 0010

R 1154  
213 OF 276  
00213

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.0



Lower Ter  
/test>dump /max  
tor3/B-043

R 1154  
214 OF 276  
00214

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.0  
80.1  
84.5  
88.0


S 0 : Ch 13 : AMP C-scan : BF-065

L[052]  
T[172]  
ABS



388.25  
270.50 286.00 301.50 317.00

X = 313.50in, Y = 401.25in  
DAC-LOG

S 0 : Ch 13 : B-scan : BF-065 : A 57 : D 100 : H



S 0 : Ch 13 : EV-scan : BF-065 : A 57 : D 100 : H





Lower Ten  
/test>dump /max  
tor3/8-044


215 OF 276  
R1154  
00215

S 0 : Scale


32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8



S 0 : Ch 13 : B-scan : BF-065 : A 57 : D 180 : H




S 0 : Ch 13 : EV-scan : BF-065 : A 57 : D 180 : H







Lower Ten  
/test>dump /max  
tor3/B-045

00216  
216 of 276  
R1154



Lower Ten  
/test>dump /max  
tor3/B-046



R 1154  
217 of 276  
00217





**S 0 : Scale**

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4  
75.8 20%  
80.1  
84.5  
88.8  
93.2

**DAC**

**Lower Ter**

ump /maxtor3/8-048



R 1154  
218 OF 276  
00218




S O : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC

Lower Ter  
/test>dump /max  
tor3/B-050







R 1154  
219 OF 276  
00219

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Ten  
ump /maxtor3/8-  
051

R 1154  
220 OF 276  
00220



S 0 : Scale




32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC

Lower Ten

/test>dump /max  
tor3/8-052







R 1154  
221 OF 276  
00221

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.1  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Ten  
ump /maxtor3/B-  
053



R 1154  
222 OF 276  
00222

S 0 : Scale



32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC



Lower Ten  
/test>dump /max







223 of 276  
R 1154  
: 00223

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.0  
93.2

100%  
50%  
20%

DAC



ip Termis  
it>dump /max  
/B-055






00224

121154  
224 OF 276

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4  
75.0 20%  
80.1  
84.5  
88.8  
93.2

DAC



Lower Ten  
ump /maxon 3/8-  
056






R 1154  
225 OF 276  
00225

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC







Lower Tor  
/test>dump /max  
tor3/8-057

220 OF 276  
R1154  
00226

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

DAC








en  
DeskJe  
isl/lq

121154  
227 of 276  
002227

S D : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4  
75.8 20%  
80.1  
84.5  
88.8  
93.2

DAC



Lower Ten  
3 /maxtor3/B-  
3






002228  
228 of 276  
R 1154



S D : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%



Lower Ten  
/test>dump /max  
tor3/8-065

229 OF 276  
R1154  
00229

S 0 : Scale

32.3

36.6

41.0

45.3

49.7 100%

54.0 50%

58.4

62.7 20%

67.1

71.4

75.0

80.1

84.5

S 0 : Ch 13 : AMP C-scan : BF-066

L[022]

T[018]




ABS

388.25

480.00 495.50 511.00 526.50

X = 484.50in, Y = 393.75in

DAC-LOG



file

np / max

36

00230






230 OF 276

R1154

S0: Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4  
75.8 20%  
80.1  
84.5  
88.8  
93.2

DAC








Power Ten  
st>dump /max  
3/8-067

00231  
R1154  
231 OF 276

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.0  
84.5  
88.0

100%  
50%  
20%








Lower Ten  
st > dump / max  
3/E-068

00232  
232 OF 276  
21154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Tern  
/maxtor3/8-






00233  
233 OF 276  
K1154

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
50.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC



Lower Tern  
1st dump / max  
3/8-070

00234  
234 of 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.0


100%  
50%  
20%

S 0 : Ch 07 : AMP C-scan : BF-069


L[046]  
T[022]  
ABS

-3.50 2.85 18.35 33.85 49.35


X = 548.35in, Y = 390.50in  
DAC-LOG




S 0 : Ch 07 : B-scan : BF-069 : A 47 : D 0 : H



Line = 0046, Trigger = 0022  
X = 548.35in, Y = 393.94in Z = 2.89in  
Log



S 0 : Ch 07 : EV-scan : BF-069 : A 47 : D 0 : H



Log

Lower Ten  
/test>dump /max  
tor3/E-071

00235






235 OF 276

E 1107

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Ten  
/test>dump /max  
tor3/8-072

00236

236 OF 276

K1154

000001 000001



S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.6

100%

50%

20%

S 0 : Ch 07 : AMP C-scan : BF-069

L[050]  
T[061]  
ABS

379.00  
542.85 558.35 573.05 589.35

X = 558.10in, Y = 391.50in  
DAC-LOG

Slot 0 : A-scan : BF-069 : A 47 : D 0

L[050]	FREEZE	AUTO SCALE	CHAN 07	VIDEO	LINEAR
T[061]	TIME SCALE	TRACE OFF	SCRN GAIN	50% DAC	VERT OFF
B[000]	-A- GATE	-B- GATE	-C- GATE	-I- GATE	-BE- GATE

160%


Indication #8-073

80%  
40%  
20%


0.10 0.99 2.08 3.18 4.27 5.37 6.47 7.56 8.65 9.76  
metal path inches

Dist/Time Start = 2.67, End = 2.81, Diff = 0.14  
Amplitude Start = 61.65, End = 68.72, Diff = 7.07, Mean = 65.19


S 0 : Ch 07 : B-scan : BF-069 : A 47 : D 0 : H



Line = 0050, Trigger = 0061  
X = 558.10in, Y = 393.71in Z = 1.79in  
Log



S 0 : Ch 07 : EV-scan : BF-069 : A 47 : D 0 : H



Log

Lower Ten  
/test>dump /max  
tor3/8-073

00237

237 OF 276

R1134

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8





100%  
50%  
20%

S 0 : Ch 07 : AMP C-scan : BF-069

L[039]  
T[129]  
ABS

379.00  
542.85 558.35 573.85 589.35

x = 575.10in, y = 388.75in  
DAC-LOG



Lower Ten  
/test>dump /max  
tor3/B-074

00238  
238 of 276  
R1154


S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1


100%

50%

20%




S 0 : Ch 11 : B-scan : BF-069 : A 57 : D 0 : H




Line = 0039, Trigger = 0025  
x = 546.25in, y = 392.77in z = 2.48in


Slot 0 : A-scan : BF-069 : A 57 : D 0



Ch 11 : B-scan Zoom



S 0 : Ch 11 : EV-scan : BF-069 : A 57 : D 0 : H



Log

Lower Ten  
/test>dump /max  
ton3/8-075

002339

239 OF 276

R1154

S 0 : Scale



32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0  
58.4 50%  
62.7 20%  
67.1  
71.4  
75.8

S 0 : Ch 11 : AMP C-scan : BF-069



L [040]  
T [034]  
ABS

379.00  
540.00 555.50 571.00 586.50

X = 548.50in, Y = 389.00in  
DAC-LOG



Line = 0040, Trigger = 0034  
X = 548.50in, Y = 393.76in Z = 3.00in



Lower Ten  
/test>dump /max  
tor3/B-076

00240

240 OF 276

R1154

S 0 : Scale




32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

S 0 : Ch 11 : AMP C-scan : BF-069

L[050]  
T[089]  
ABS

379.00  
540.00 555.50 571.00 586.50






X = 562.25in, Y = 391.50in  
DAC-LOG



60241  
241 OF 276  
R1154






S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5







Lower Tern  
/test>dump /max  
tor3/B-078

00242  
242 of 276  
R1154



00243






R1154  
243 OF 276



00224A






R1154  
244 OF 276





Lower Terminal  
ris1/local/invesel  
or3/B-081

R1154  
245 of 276  
00245








Lower Terminal  
sel/test>dump /maxt  
or3/8-082

00246

246 OF 276

R1154








Lower Terminal  
sel/test>dump /max  
on3/8-083

R1154  
247 OF 276  
002247

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4 20%  
75.8  
80.1  
84.5  
88.8  
93.2

DAC








00000

00248  
248 of 276  
21154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7 100%  
67.1 50%  
71.4 20%  
75.8  
80.1  
84.5  
88.8  
93.2

DAC




249 of 276  
 21154  
 00249


S 0 : Scale

- 32.3
- 36.6
- 41.0
- 45.3
- 49.7
- 54.0
- 58.4
- 62.7 100%
- 67.1 50%
- 71.4
- 75.8 20%
- 80.1
- 84.5
- 88.8
- 93.2


DAC




Ch 3 : B-scan Zoom



S 0 : Ch 03 : B-scan : BF-071 : A 70 : D 0 : H




S 0 : Ch 03 : EV-scan : BF-071 : A 70 : D 0 : H



Lower Ter  
st > dump / max  
3/8-086


Slot 0 : A-scan : BF-071 : A 70 : D 0




00250  
250 of 274  
R1154

S 0 : Scale


- 32.3
- 36.6
- 41.0
- 45.3
- 49.7
- 54.0
- 58.4
- 62.7
- 67.1
- 71.4
- 75.8
- 80.1
- 84.5
- 88.8




Slot 0 : A-scan : BF-071 : A 47 : D 0




S 0 : Ch 07 : B-scan : BF-071 : A 47 : D 0 : H



Ch 7 : B-scan Zoom



S 0 : Ch 07 : EV-scan : BF-071 : A 47 : D 0 : H



Lower Ten  
/test>dump /max  
tor3/8-087

00251

251 OF 276

R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
51.0  
56.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8




100%  
50%  
20%

S 0 : Ch 07 : AMP C-scan : BF-071

L[008]  
T[114]  
ABS

379.00  
667.95 682.05 698.95 719.85

X = 695.85in, Y = 381.00in  
DAC-LOG



Lower Ten  
/test>dump /max  
tor3/8-088

R1154  
252 of 276  
00252



S 1 : Scale

32.3

36.6

41.0

45.3

49.7

54.0

58.4

62.7

67.1

71.4

75.8






80.1

84.5

100%

50%

20%



PRINT # G-110

Lower Ter

/test>dump /max

tor3/G-110

00253

R1154

253 OF 276


S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2


100%

50%


20%




Slot 0 : A-scan : BF-071 : A 45 : D 180




S 0 : Ch 09 : B-scan : BF-071 : A 45 : D 180 : H



Ch 9 : D-scan Zoom



S 0 : Ch 09 : EV-scan : BF-071 : A 45 : D 180 : H



PRINT \* G-111

Lower Ten
/test>dump /max
ton3/G-111

00254

R1154  
254 OF 276

S 0 : Scale

32.3	
36.6	
41.0	
45.3	
49.7	100%
54.0	50%
58.4	
62.7	20%
67.1	
71.4	
75.8	
80.1	
84.5	
88.0	
93.2	




DAC

S 0 : Ch 11 : AMP C-scan : BF-071

L [037]  
T [129]  
ABS

379.00  
664.50 680.00 695.50 711.00

X = 696.75in, Y = 388.25in  
DAC-LOG



Lower Ten  
/test>dump /max  
tor3/8-089

00255

255 OF 270

L1154





0000 0000

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4 100%  
62.7 50%  
67.1 20%  
71.4  
75.0  
80.1  
84.5  
88.8  
93.2

DAC

Lower Ten  
/test>dump /max  
ton3/8-090



256 of 276  
R 1154  
00256





S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%






DAC

Lower Ten  
/test>dump /max  
tor3/8-091



00000 00000

R1154  
257 OF 276  
00257



Lower Ten  
ump /maxtor3/8-  
092

00258  
258 of 276  
R1154






0000 0258

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8

100%  
50%  
20%

80.1  
84.5  
88.8



Lower Ter  
/test.dump /max  
tor3/B-093






00259  
259 OF 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0

100%  
50%  
20%

80.1  
84.5  
88.8



Lower Ten  
/test>dump /max  
tor3/8-094






00260  
260 OF 276  
R1154



S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Ten  
/test>dump /max  
tor3/B-095

00261






261 OF 270

21154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5

100%  
50%  
20%








Lower Ten  
/test>dump /max  
tor3/B-096

00262  
262 of 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5

100%  
50%  
20%








Lower Ten  
/test>dump /max  
tor3/B-097

00263  
263 OF 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5

100%  
50%  
20%








Lower Tern  
/test>dump /max  
tar3/B-098

00264  
264 OF 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1

100%  
50%  
20%








Lower Tern  
/test>dump /max  
tor3/8-099

00265  
2650E 276  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8

100%  
50%  
20%



Lower Ten  
/test>dump /max  
tor3/B-100

00266  
200 OF 276  
R1154

S 0 : Scale

- 32.3
- 36.6
- 41.0
- 45.3
- 49.7
- 54.0
- 58.4
- 62.7
- 67.1
- 71.4
- 75.8


100%

50%

20%


S 0 : Ch 09 : AMP C-scan : BF-072 : A 45

L[033]  
T[109]  
ABS




K = 751.75in, Y = 394.25in  
DAC-LOG

Slot 0 : A-scan : BF-072 : A 45 : D 100




S 0 : Ch 09 : B-scan : BF-072 : A 45 : D 180 : II




Line = 0033, Trigger = 0109  
K = 751.75in, Y = 392.34in Z = 1.69in  
Log

Ch 9 : B-scan Zoom



S 0 : Ch 09 : EV-scan : BF-072 : A 45 : D 180 : II








Lower Ten  
/test>dump /max  
ton3/B-101

R2154  
 267 of 276  
 00267

S D : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8

100%  
50%  
20%



Lower Tern  
/test>dump /max  
tor3/8-102

00268





121154  
268 of 276



S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%



Lower Tor  
/test>dump /max  
tor3/B-103

00269

269 of 276





R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC







Lower Tor  
/test>dump /max  
tor3/8-104

00270  
270 OF 270  
R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8

100%  
50%  
20%



Lower Ten  
/test>dump /max  
ton3/8-105





00271

271 OF 276

R1154

S 0 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8



Lower Ten  
/test>dump /max  
tar3/8-106

00272

272 of 276





R1154

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC



00273

en  
07 /max

00000 00000 00000

21154





273 of 276

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7  
54.0  
58.4  
62.7  
67.1  
71.4  
75.0  
80.1  
84.5  
88.8  
93.2

100%  
50%  
20%

DAC



en  
1p /max  
08

00274

274 of 276





D1154

0000 0078

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.0  
93.2

DAC







en  
np /max  
09

00275  
275 OF 276  
R1154

S 1 : Scale

32.3  
36.6  
41.0  
45.3  
49.7 100%  
54.0 50%  
58.4  
62.7 20%  
67.1  
71.4  
75.8  
80.1  
84.5  
88.8  
93.2

DAC



00276

276 of 276  
R1154