

R1152



GE Nuclear Energy

GERIS 2000 Examination Summary Sheet

Project: TVA, Browns Ferry Nuclear Plant, Unit 3

System: Reactor Pressure Vessel

Weld ID: C-4-5

ASME Code Category: B-A

Calibration Sheets: C-001, C-004

Supporting Data: Examination Data Sheets E-16-00 thru E-16-12, Indication Data Sheets 16-001 thru 16-094, Indication Evaluation Sheets, Screen Prints, Exam Patch Location Map, Exam Coverage Plots and GERIS 2000 Setup Records.

Examination Summary

The ultrasonic examination of weld C-4-5 resulted in two (2) recorded indications that exceed the allowable standards of IWB-3500, ASME Section XI, 1986 Edition, No Addenda.

The ASME Section XI required examination volume was examined with the GERIS 2000 System from the RPV inside surface utilizing Procedure No. GE-UT-700, Rev. 2. This examination was limited due to the Guide Rods at 0° and 180°. The total examination coverage was calculated to be 93%.

The GERIS 2000 utilizes an array of search units arranged to effectively examine the weld and adjacent base material parallel and perpendicular to the weld axis in two directions. The transducer package consisted of 0° longitudinal, 45° and 60° shear wave, and 70° refracted longitudinal (RL) wave search units.

The two (2) unacceptable indications were recorded and sized in accordance with GE-UT-700, Rev. 2 and GE-UT-701, Rev. 2 with the results tabulated below:

Ind. No.	Oriented	Type	X Pos	Y Pos	Z Pos	"S"	T wall	Length	T Meas	a/t	% a/t Calculated	% a/t Allowed
16-075	circ.	subsurface	603.30"	574.70"	3.17"	2.83"	.30"	2.75"	6.6"	.055	2.27	2.23
16-076	circ.	subsurface	617.50"	574.05"	3.85"	2.53"	.44"	1.50"	6.6"	.147	3.33	2.87

Indication 16-075 was sized with 60° shear wave channel 13 utilizing the SPOT technique. This indication was also recorded with 45° shear wave channel 9 as 16-072.

Indication 16-076 was sized with 60° shear wave channel 13 utilizing the SPOT technique. This indication was also recorded with 45° shear wave channel 9 as 16-074.

The GERIS 2000 also recorded indications with the 0° weld metal scans, 70° RL, 45° and 60° shear wave scans that were evaluated and found to be acceptable per the referencing Code section. Geometric indications from the stabilizer brackets were recorded with the 0° weld metal, 45° and 60° shear wave scans. Geometric indications from the OD surface were recorded with the 45° shear wave scans.

No manual supplemental examination was performed from the RPV outside surface due to access restrictions.

Fabrication records and previous examination results were reviewed prior to the completion of this examination summary.

GERIS Analyst: *QJ Mac*

GE Reviewer: *R.O. Forman*

LEVEL: *III* DATE: *12/20/93*

LEVEL: *II* DATE: *12-20-93*

UTILITY Review: *J. Wood*

ANII Review:

TITLE: *#* DATE: *1/26/94*

TITLE: *Albert Ladd* DATE: *7/11/94*



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-072
Indication: 16-072

Flaw Thruwall Dimension = 0.30
Flaw Length "l" = 2.75
Separation with clad "S" = 3.02
Surface Separation "S" = 2.83

T measured = 6.60
Clad T nominal = 0.19

Flaw is unacceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.02	2.23 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.02	Allowed 2.23

a = 0.150
a/l value = 0.055
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.23%
a/t = 2.27%

Comments: Same as indication 16-075.
Flaw dimensions from 16-075.

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-074
Indication: 16-074

Flaw Thruwall Dimension = 0.44
Flaw Length "l" = 1.50
Separation with clad "S" = N/A
Surface Separation "S" = 2.53

T measured = 6.60
Clad T nominal = 0.19

Flaw is unacceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.48	2.87 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.48	Allowed 2.87

a = 0.220
a/l value = 0.147
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.87%
a/t = 3.33%

Comments: Same as indication 16-076.
Flaw dimensions from 16-076.

5 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
 Weld ID: C-4-5
 Patch: BF-022

Exam Data Sheet No.: E-16-10
 Ind. Data Sheet No.: 16-075
 Indication: 16-075

Flaw Thruwall Dimension = 0.30
 Flaw Length "l" = 2.75
 Separation with clad "S" = 3.02
 Surface Separation "S" = 2.83

T measured = 6.60
 Clad T nominal = 0.19

Flaw is unacceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.02	2.23 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.02	2.23

a = 0.150
 a/l value = 0.055
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.23%
 a/t = 2.27%

Comments: Same as indication 16-072.

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-076
Indication: 16-076

Flaw Thruwall Dimension = 0.44
Flaw Length "l" = 1.50
Separation with clad "S" = N/A
Surface Separation "S" = 2.53

T measured = 6.60
Clad T nominal = 0.19

Flaw is unacceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.48	2.87 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.48	Allowed 2.87

a = 0.220
a/l value = 0.147
Y = 1.000

Flaw is Subsurface


Allowed a/t = 2.87%
a/t = 3.33%

Comments: Same as indication 16-074.

DATE 0000 1400

C-4-5

Ⓢ
573"



Indication 16-076
 Flaw "X" location is 617.50"
 Flaw "Y" location is 574.05"

TW
LENGTH
T MEASURED

Nominal Clad T = 3/16"
 Nominal Base Metal T = 6 3/8"

R1152

10 of 245 • 00373

GE NUCLEAR ENERGY	BROWNS FERRY UNIT 3	WELD C-4-5 IND. 16-076	SCALE: NONE	DWG. BFC45IND	REV. 0
-------------------	---------------------	------------------------	-------------	---------------	--------

1106-245 00374

R1152

C-4-5

573"

45°

60°

WELD

Indication 16-075

Flaw "X" location is 603.30"

Flaw "Y" location is 574.70"

Nominal Clad T = 3/16"
Nominal Base Metal T = 6 3/8"

1106-245 00374

GE NUCLEAR ENERGY	BROWNS FERRY UNIT 3	WELD C-4-5 IND. 16-075	SCALE: NONE	DWG. BFC45IND	REV. 0
-------------------	---------------------	------------------------	-------------	---------------	--------

R1152



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-004

Exam Data Sheet No.: E-16-09
Patch ID: BF-021R
Ind. Data Sheet Series: 16-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	NRI	~	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	1, 3	16-058	16-059	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	1	16-060	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	3	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: (3) Stabilizer bracket geometry.

Data Sheet Codes: G-XXX; "G" = Geometry (may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: CJ Ma

Reviewed By: R.O. Furman

Level: III Date: 12/18/93

Level: II Date: 12-20-93

21 of 245



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-10
Patch ID: BF-022
Ind. Data Sheet Series: 16-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	1, 5	16-061	~	~	~	~
2	0 WM	N/A	1, 5	Note 1	~	~	~	~
3	70 RL	0 UP	1	16-062	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	16-063	16-064	16-065	16-066	~
6	70 RL	270 CCW	1	16-067	~	~	~	~
7	45 RS	0 UP	1, 3, 5	16-068	16-069	16-070	16-071	~
8	45 RS	90 CW	3, 5	~	~	~	~	~
9	45 RS	180 DN	1	16-072	16-073	16-074	~	~
10	45 RS	270 CCW	3, 5	~	~	~	~	~
11	60 RS	0 UP	3	~	~	~	~	~
12	60 RS	90 CW	3	~	~	~	~	~
13	60 RS	180 DN	1, 3	16-075	16-076	~	~	~
14	60 RS	270 CCW	1, 3	16-077	~	~	~	~
15	0 BM	N/A	5	~	~	~	~	~
16	0 BM	N/A	5	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: Note 1: Recorded as 16-061.
 (3) Stabilizer bracket geometry.
 (5) Segregates Shell 4 side (non relevant).

Data Sheet Codes: G-XXX; "G" = Geometry (may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number
 Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: CF M
 Level: III Date: 12/20/93

Reviewed By: R.O. Forman
 Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-11
Patch ID: BF-023
Ind. Data Sheet Series: 16-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	1	16-078	16-079	~	~	~
3	70 RL	0 UP	1	16-080	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	16-081	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	3	~	~	~	~	~
8	45 RS	90 CW	3	~	~	~	~	~
9	45 RS	180 DN	1, 3	16-082	16-083	~	~	~
10	45 RS	270 CCW	3	~	~	~	~	~
11	60 RS	0 UP	3	~	~	~	~	~
12	60 RS	90 CW	3	~	~	~	~	~
13	60 RS	180 DN	1, 3	16-084	~	~	~	~
14	60 RS	270 CCW	3	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: (3) Segregates Shell 4 side (non relevant)

Data Sheet Codes: G-XXX; "G" = Geometry (may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number
Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: Ch M

Reviewed By: R.O. Forman

Level: III Date: 12/18/93

Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-12
Patch ID: BF-024
Ind. Data Sheet Series: 16-XXX

Channel	Angle	Direction	Ind.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sh.	Ind. Data Sheet
1	0 WM	N/A	NRI	~	~	~	~	~
2	0 WM	N/A	NRI	~	~	~	~	~
3	70 RL	0 UP	NRI	~	~	~	~	~
4	70 RL	90 CW	NRI	~	~	~	~	~
5	70 RL	180 DN	1	16-085	~	~	~	~
6	70 RL	270 CCW	NRI	~	~	~	~	~
7	45 RS	0 UP	NRI	~	~	~	~	~
8	45 RS	90 CW	NRI	~	~	~	~	~
9	45 RS	180 DN	NRI	~	~	~	~	~
10	45 RS	270 CCW	NRI	~	~	~	~	~
11	60 RS	0 UP	NRI	~	~	~	~	~
12	60 RS	90 CW	NRI	~	~	~	~	~
13	60 RS	180 DN	NRI	~	~	~	~	~
14	60 RS	270 CCW	NRI	~	~	~	~	~
15	0 BM	N/A	NRI	~	~	~	~	~
16	0 BM	N/A	NRI	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~

Comments: N/A

Data Sheet Codes: G-XXX; "G" = Geometry (may be typical), 6-XXX; "6" = Weld Sequence, XXX = Sheet Number

Indication Codes: 1 = Flaw, 2 = OD Surface, 3 = OD Attachment, 4 = Nozzle, 5 = Other

Analyst: CP M

Reviewed By: R.O Forman

Level: III Date: 12/19/93

Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-01
Patch ID: BF-013
Ind. Data Sheet No.: 16-001

Indication: 16-001 **Channel:** 5 **Angle:** 70 **Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
23.7%	23.35	~	~	~	~	574.95	20.24	~	~	~	~	~
44.3%	23.60	~	~	~	~	574.95	20.24	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Ch Ma.
 Level: III Date: 12/15/93

Reviewed By: R.O. Forman
 Level: II Date: 12-20-93

25 of 295

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-4-5

Cal. ID: C-001

Exam Data Sheet No.: E-16-01

Patch ID: BF-013

Ind. Data Sheet No.: 16-002

Indication: 16-002

Channel: 5

Angle: 70

Direction: 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
44.3%	35.85	~	~	~	~	578.45	44.16	~	~	~	~	~
64.5%	36.10	~	~	~	~	578.45	44.16	~	~	~	~	~
68.7%	36.35	~	~	~	~	578.70	46.40	~	~	~	~	~
26.9%	36.60	~	~	~	~	578.20	42.24	~	~	~	~	~
34.5%	36.85	~	~	~	~	578.45	44.09	~	~	~	~	~
41.6%	37.10	~	~	~	~	578.20	42.32	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: CA M5
 Level: III Date: 12/15/93

Reviewed By: R.O. Forman
 Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-01
Patch ID: BF-013
Ind. Data Sheet No.: 16-003

Indication: 16-003 **Channel:** 5 **Angle:** 70 **Direction:** 180

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
28.6%	53.10	~	~	~	~	576.70	30.88	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: CL Mc

Reviewed By: R.O. Forman

Level: II Date: 12/15/93

Level: II Date: 12-20-93



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

R1152

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-01
Patch ID: BF-013
Ind. Data Sheet No.: 16-004

Indication: 16-004

Channel: 8

Angle: 45

Direction: 90

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
26.9%	573.55	69.29	2.19	~	~	69.79	1.92	~	~	70.04	1.72	~
30.4%	573.80	69.54	2.09	~	~	69.79	2.06	~	~	70.29	1.58	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size determined by the Reg. Guide 20% beam spread correction method.
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

TW = 0.00 L = 0.50 S = 1.46 with clad

Analyst: CJ Mas
Level: III Date: 12/15/93

Reviewed By: R.O. Forman
Level: II Date: 12-20-93

R1152



GE Nuclear Energy

**GERIS 2000 Indication
Evaluation Sheet**

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-013

Exam Data Sheet No.: E-16-01
Ind. Data Sheet No.: 16-005
Indication: 16-005

Flaw Thruwall Dimension = 0.34
Flaw Length "l" = 0.50
Separation with clad "S" = N/A
Surface Separation "S" = 2.66

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	4.28	4.96 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 4.28	Allowed 4.96

a = 0.170
a/l value = 0.340
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.96%
a/t = 2.66%

Comments:

30 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-013

Exam Data Sheet No.: E-16-01
Ind. Data Sheet No.: 16-006
Indication: 16-006

Flaw Thruwall Dimension = 0.23
Flaw Length "l" = 0.50
Separation with clad "S" = 3.03
Surface Separation "S" = 2.84

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.10	3.60 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.10	Allowed 3.60

a = 0.115
 a/l value = 0.230
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.60%
 a/t = 1.80%

Comments:

32 of 245

B1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-013

Exam Data Sheet No.: E-16-01
Ind. Data Sheet No.: 16-007
Indication: 16-007

Flaw Thruwall Dimension = 0.23
Flaw Length "l" = 0.50
Separation with clad "S" = 2.10
Surface Separation "S" = 1.91

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.10	3.60 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.10	Allowed 3.60

a = 0.115
 a/l value = 0.230
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.60%
 a/t = 1.80%

Comments:

39 of 245

B1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-013

Exam Data Sheet No.: E-16-01
Ind. Data Sheet No.: 16-009
Indication: 16-009

Flaw Thruwall Dimension = 0.31
Flaw Length "l" = 1.50
Separation with clad "S" = N/A
Surface Separation "S" = 3.07

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.22	2.53 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.22	Allowed 2.53

a = 0.155
a/l value = 0.103
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.53%
a/t = 2.43%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-013

Exam Data Sheet No.: E-16-01
Ind. Data Sheet No.: 16-010
Indication: 16-010

Flaw Thruwall Dimension = 0.21
Flaw Length "l" = 1.75
Separation with clad "S" = 2.28
Surface Separation "S" = 2.09

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.04	2.26 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.04	Allowed 2.26

a = 0.105
a/l value = 0.060
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.26%
a/t = 1.65%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-02
Patch ID: BF-014
Ind. Data Sheet No.: 16-015

Indication: 16-015 **Channel:** 7 **Angle:** 45 **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
25.8%	127.21	~	~	~	~	571.05	4.36	~	~	~	~	~
47.2%	127.46	~	~	~	~	571.05	4.39	~	~	~	~	~
34.5%	127.71	~	~	~	~	571.30	4.20	~	~	~	~	~
17.3%	127.96	~	~	~	~	571.30	4.17	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: CLM
 Level: III Date: 12/17/93

Reviewed By: R.O. Forman
 Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-014

Exam Data Sheet No.: E-16-02
Ind. Data Sheet No.: 16-017
Indication: 16-017

Flaw Thruwall Dimension = 0.20
Flaw Length "l" = 1.00
Separation with clad "S" = 2.04
Surface Separation "S" = 1.85

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.20	2.50 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.20	Allowed 2.50

a = 0.100
a/l value = 0.100
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.50%
a/t = 1.57%

Comments:

47 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-014

Exam Data Sheet No.: E-16-02
Ind. Data Sheet No.: 16-018
Indication: 16-018

Flaw Thruwall Dimension = 0.20
Flaw Length "l" = 0.50
Separation with clad "S" = 2.77
Surface Separation "S" = 2.58

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.80	3.30 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.80	Allowed 3.30

a = 0.100
a/l value = 0.200
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.30%
a/t = 1.57%

Comments:

49 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-014

Exam Data Sheet No.: E-16-02
Ind. Data Sheet No.: 16-019
Indication: 16-019

Flaw Thruwall Dimension = 0.127
Flaw Length "l" = 0.75
Separation with clad "S" = N/A
Surface Separation "S" = 0.00

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.62	3.05 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.62	Allowed 0.00

a = 0.127
a/l value = 0.169
Y = 0.000

Flaw is Surface

Allowed a/t = 2.62%
a/t = 1.99%

Comments: Evaluated to notch sensitivity assigned thruwall dimension = 2% T.

51 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-014

Exam Data Sheet No.: E-16-02
Ind. Data Sheet No.: 16-021
Indication: 16-021

Flaw Thruwall Dimension = 0.36
Flaw Length "l" = 1.00
Separation with clad "S" = 1.88
Surface Separation "S" = 1.69

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.68	3.14 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.68	3.14

a = 0.180
a/l value = 0.180
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.14%
a/t = 2.82%

Comments:

54 of 245

00417

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-034
Indication: 16-034

Flaw Thruwall Dimension = 0.49
Flaw Length "l" = 1.00
Separation with clad "S" = 2.15
Surface Separation "S" = 1.96

T measured = 6.66
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.25	3.75 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			3.25	3.75

a = 0.245
 a/l value = 0.245
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.75%
 a/t = 3.68%

Comments: T measured with clad = 6.85" without = 6.66"

68 of 245

00431

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-036
Indication: 16-036

Flaw Thruwall Dimension = 0.46
Flaw Length "l" = 0.75
Separation with clad "S" = 2.10
Surface Separation "S" = 1.91

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
 TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	3.88	4.49 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.88	Allowed 4.49

a = 0.230
 a/l value = 0.307
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.49%
 a/t = 3.61%

Comments:

71 of 245

00434

B1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-038
Indication: 16-038

Flaw Thruwall Dimension = 0.25
Flaw Length "l" = 1.00
Separation with clad "S" = 1.82
Surface Separation "S" = 1.63

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.35	2.70 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.35	Allowed 2.70

a = 0.125
a/l value = 0.125
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.70%
a/t = 1.96%

Comments:

Blank lines for handwritten comments.

2406 245

00437

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-039
Indication: 16-039

Flaw Thruwall Dimension = 0.17
Flaw Length "l" = 0.75
Separation with clad "S" = 1.89
Surface Separation "S" = 1.70

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.28	2.61 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.28	Allowed 2.61

a = 0.085
a/l value = 0.113
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.61%
a/t = 1.33%

Comments:

76 of 245

00439



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-4-5

Cal. ID: C-001

Exam Data Sheet No.: E-16-03

Patch ID: BF-015

Ind. Data Sheet No.: 16-040

Indication: 16-040

Channel: 9

Angle: 45

Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
7.2%	155.65	~	~	~	~	575.75	4.38	~	~	~	~	~
15.3%	155.90	~	~	~	~	575.75	4.28	~	~	~	~	SPOT
12.7%	156.15	~	~	~	~	576.00	4.45	~	~	~	~	~
6.4%	156.40	~	~	~	~	576.00	4.56	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the SPOT technique.

TW = 0.17 L = 0.75 S = 2.94 with clad

Analyst: CT M/S

Reviewed By: R.D. Forman

Level: III Date: 12/17/93

Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-040
Indication: 16-040

Flaw Thruwall Dimension = 0.17
Flaw Length "l" = 0.75
Separation with clad "S" = 2.94
Surface Separation "S" = 2.75

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.28	2.61 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.28	Allowed 2.61

a = 0.085
a/l value = 0.113
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.61%
a/t = 1.33%

Comments:

78 of 245

00441

B1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-03
Patch ID: BF-015
Ind. Data Sheet No.: 16-041

Indication: 16-041 Channel: 9 Angle: 45 Direction: 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
19.6%	157.40	~	~	~	~	575.00	3.09	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: CR Mas
Level: III Date: 12/17/93

Reviewed By: RD Forman
Level: II Date: 12-20-93

79 of 245



GE Nuclear Energy

**GERIS 2000 Indication
Evaluation Sheet**

R1152

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-042
Indication: 16-042

Flaw Thruwall Dimension = 0.28
Flaw Length "l" = 0.50
Separation with clad "S" = 1.93
Surface Separation "S" = 1.74

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.60	4.16 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			3.60	4.16

a = 0.140
a/l value = 0.280
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.16%
a/t = 2.19%

Comments:

81 of 245

R 1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-015

Exam Data Sheet No.: E-16-03
Ind. Data Sheet No.: 16-043
Indication: 16-043

Flaw Thruwall Dimension = 0.31
Flaw Length "l" = 0.50
Separation with clad "S" = 2.31
Surface Separation "S" = 2.12

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	3.92	4.54 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.92	Allowed 4.54

a = 0.155
a/l value = 0.310
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.54%
a/t = 2.43%

Comments:

83 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
 Weld ID: C-4-5
 Cal. ID: C-001

Exam Data Sheet No.: E-16-04
 Patch ID: BF-016
 Ind. Data Sheet No.: 16-045

Indication: 16-045 Channel: 3 Angle: 70 Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
57.0%	215.40	~	~	~	~	572.25	35.28	~	~	~	~	~
30.4%	215.65	~	~	~	~	572.50	33.20	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
 Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: CJ Ma
 Level: III Date: 12/18/93

Reviewed By: R.O. Foman
 Level: II Date: 12-20-93

85 of 295



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

R1152

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-4-5

Cal. ID: C-001

Exam Data Sheet No.: E-16-04

Patch ID: BF-016

Ind. Data Sheet No.: 16-046

Indication: 16-046

Channel: 3

Angle: 70

Direction: 0

Amp.	X	20% Min Y	TOF	50% Min Y	TOF	@ Max Y	TOF	50% Max Y	TOF	20% Max Y	TOF	Remarks
36.7%	256.40	~	~	~	~	572.75	34.96	~	~	~	~	~
32.4%	256.65	~	~	~	~	572.75	34.72	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals.
Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: *CJ Mas*
Level: *III* Date: *12/19/93*

Reviewed By: *R.D. Forman*
Level: *II* Date: *12-20-93*

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
 Weld ID: C-4-5
 Cal. ID: C-001

Exam Data Sheet No.: E-16-04
 Patch ID: BF-016
 Ind. Data Sheet No.: 16-047

Indication: 16-047 Channel: 7 Angle: 45 Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
16.3%	214.96	~	~	~	~	571.05	4.76	~	~	~	~	~
34.5%	215.21	~	~	~	~	571.05	4.75	~	~	~	~	~
41.6%	215.46	~	~	~	~	571.05	4.77	~	~	~	~	~
36.7%	215.71	~	~	~	~	571.05	4.76	~	~	~	~	~
50.2%	215.96	~	~	~	~	571.30	4.56	~	~	~	~	SPOT
26.9%	216.21	~	~	~	~	571.30	4.53	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the SPOT technique.

TW = 0.20 L = 1.25 S = 3.12 with clad

Analyst: CL Ma
 Level: III Date: 12/16/93

Reviewed By: R.O. Forman
 Level: I Date: 12-20-93

87 of 245

R 1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-016

Exam Data Sheet No.: E-16-04
Ind. Data Sheet No.: 16-047
Indication: 16-047

Flaw Thruwall Dimension = 0.20
Flaw Length "l" = 1.25
Separation with clad "S" = 3.12
Surface Separation "S" = 2.93

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.12	2.38 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.12	Allowed 2.38

a = 0.100
a/l value = 0.080
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.38%
a/t = 1.57%

Comments:

88 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-05
Patch ID: BF-017
Ind. Data Sheet No.: 16-048

Indication: 16-048 Channel: 7 Angle: 45 Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
88.2%	293.21	~	~	~	~	572.45	3.98	~	~	~	~	~
128.4%	293.46	~	~	570.45	4.02	572.45	3.98	572.95	4.04	~	~	~
187.1%	293.71	~	~	570.45	3.96	572.45	3.93	572.95	3.98	~	~	~
187.1%	293.96	~	~	570.45	3.85	572.45	3.85	572.95	3.87	~	~	~
155.1%	294.21	~	~	570.45	3.93	572.20	3.78	572.70	3.93	~	~	~
328.5%	294.46	~	~	570.70	3.93	572.45	3.78	572.70	2.78	~	~	~
695.8%	294.71	~	~	570.70	3.91	572.45	3.73	573.20	3.65	~	~	~
653.9%	294.96	~	~	570.70	3.85	572.20	3.72	573.20	3.60	~	~	~
478.1%	295.21	~	~	570.70	3.91	572.20	3.70	573.45	3.70	~	~	~
349.5%	295.46	~	~	570.70	3.85	572.20	3.70	573.45	3.65	~	~	~
509.3%	295.71	~	~	570.45	3.78	572.20	3.70	573.20	3.60	~	~	~
478.1%	295.96	~	~	571.45	3.65	572.45	3.57	573.20	3.58	~	~	~
289.7%	296.21	~	~	570.70	3.72	572.45	3.54	573.20	3.60	~	~	~
272.3%	296.46	~	~	571.70	3.72	572.70	3.45	572.95	3.50	~	~	~
165.0%	296.71	~	~	570.95	3.80	572.45	3.45	573.45	3.63	~	~	~
187.1%	296.96	~	~	571.70	3.67	572.45	3.47	573.20	3.45	~	~	~
155.1%	297.21	~	~	570.95	3.65	572.45	3.45	573.20	3.52	~	~	~
255.9%	297.46	~	~	570.70	3.72	572.45	3.45	573.20	3.47	~	~	~
349.5%	297.71	~	~	570.95	3.78	572.70	3.42	572.95	3.63	~	~	~
187.1%	297.96	~	~	571.70	3.89	572.95	3.65	572.95	3.60	~	~	~
211.8%	298.21	~	~	572.20	3.54	572.70	3.57	573.20	3.60	~	~	~
225.7%	298.46	~	~	572.20	3.58	572.45	3.63	573.20	3.54	~	~	~
199.1%	298.71	~	~	572.20	3.60	572.70	3.57	573.20	3.60	~	~	~
82.9%	298.96	~	~	572.20	3.52	572.70	3.52	572.95	3.54	~	~	~
73.1%	299.21	~	~	~	~	572.70	3.65	~	~	~	~	~

Comments: This indication is multiple aligned laminar reflectors.
Loss of backwall accompanying this indication is due to stabilizer bracket below flaw.
This indication is acceptable in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: CF M₁₅
Level: III Date: 12/17/93

Reviewed By: R.O. Forman
Level: II Date: 12-20-93

89 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-05
Patch ID: BF-017
Ind. Data Sheet No.: 16-049

Indication: 16-049

Channel: 1

Angle: 0

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
82.9%	306.46	~	~	~	~	572.45	3.76	~	~	~	~	~
396.3%	306.71	~	~	571.95	3.73	572.45	3.87	572.70	3.89	~	~	~
328.5%	306.96	~	~	571.95	3.91	572.20	3.89	572.70	3.83	~	~	~
199.1%	307.21	~	~	571.70	3.87	572.20	3.87	572.70	3.76	~	~	~
128.4%	307.46	~	~	~	~	572.20	3.83	572.45	3.85	~	~	~
77.9%	307.71	~	~	~	~	572.20	3.89	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: This indication evaluated as a laminar reflector and is acceptable
in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: CL Mas
Level: III Date: 12/17/93

Reviewed By: R.O. Forman
Level: II Date: 12-20-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: C-4-5

Cal. ID: C-001

Exam Data Sheet No.: E-16-05

Patch ID: BF-017

Ind. Data Sheet No.: 16-051

Indication: 16-051

Channel: 1

Angle: 0

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
68.7%	316.46	~	~	~	~	572.45	3.78	~	~	~	~	~
88.5%	316.71	~	~	572.20	3.73	572.45	3.76	572.70	3.83	~	~	~
64.5%	316.96	~	~	~	~	572.20	3.76	572.70	3.72	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: This indication evaluated as a laminar reflector and is acceptable
 in accordance with IWB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: CL Meis
 Level: III Date: 12/17/93

Reviewed By: R.O. Forman
 Level: II Date: 12-21-93

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-019R

Exam Data Sheet No.: E-16-07
Ind. Data Sheet No.: 16-057
Indication: 16-057

Flaw Thruwall Dimension = 0.127
Flaw Length "l" = 0.75
Separation with clad "S" = N/A
Surface Separation "S" = 0.00

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.62	3.05 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.62	Allowed 0.00

a = 0.127
a/l value = 0.169
Y = 0.000

Flaw is Surface

Allowed a/t = 2.62%
a/t = 1.99%

Comments: Evaluated to notch sensitivity assigned thruwall dimension = 2%T.

99 of 245

R 1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-021R

Exam Data Sheet No.: E-16-09
Ind. Data Sheet No.: 16-058
Indication: 16-058

Flaw Thruwall Dimension = 0.23
Flaw Length "l" = 0.75
Separation with clad "S" = 2.44
Surface Separation "S" = 2.25

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.50	2.91 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.50	Allowed 2.91

a = 0.113
a/l value = 0.151
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.91%
a/t = 1.77%

Comments:

R 1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-004

Exam Data Sheet No.: E-16-09
Patch ID: BF-021R
Ind. Data Sheet No.: 16-060

Indication: 16-060 **Channel:** 9 **Angle:** 45 **Direction:** 180

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
17.3%	532.90	~	~	~	~	576.25	3.70	~	~	~	~	~
41.6%	533.15	~	~	~	~	576.25	3.67	~	~	~	~	~
39.1%	533.40	~	~	~	~	576.25	3.67	~	~	~	~	~
30.4%	533.65	~	~	~	~	576.50	3.91	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Thruwall size was determined by the SPOT technique.

TW = 0.23 L = 0.75 S = 2.48 with clad

Analyst: CR Mas
Level: III **Date:** 12/20/93

Reviewed By: R.O. Forman
Level: II **Date:** 12-20-93

B1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-021R

Exam Data Sheet No.: E-16-09
Ind. Data Sheet No.: 16-060
Indication: 16-060

Flaw Thruwall Dimension = 0.23
Flaw Length "l" = 0.75
Separation with clad "S" = 2.48
Surface Separation "S" = 2.29

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.50	2.91 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.50	2.91

a = 0.113
a/l value = 0.151
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.91%
a/t = 1.77%

Comments:

104 of 245

B115Z



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-062
Indication: 16-062

Flaw Thruwall Dimension = 0.31
Flaw Length "l" = 0.50
Separation with clad "S" = 0.90
Surface Separation "S" = 0.71

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	3.93	4.55 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.93	Allowed 4.55

a = 0.156
 a/l value = 0.311
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.55%
 a/t = 2.44%

Comments:

107 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-065
Indication: 16-065

Flaw Thruwall Dimension = 0.20
Flaw Length "I" = 0.75
Separation with clad "S" = 1.08
Surface Separation "S" = 0.89

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.40	2.77 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.40	2.77

a = 0.100
a/l value = 0.133
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.77%
a/t = 1.57%

Comments:

111 of 245

* 00474

B1152



GE Nuclear Energy

**GERIS 2000 Indication
Evaluation Sheet**

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-068
Indication: 16-068

Flaw Thruwall Dimension = 0.25
Flaw Length "l" = 1.00
Separation with clad "S" = 2.90
Surface Separation "S" = 2.71

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.36	2.72 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.36	2.72

a = 0.127
a/l value = 0.127
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.72%
a/t = 1.99%

Comments:

115 of 245

00478

B1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-069
Indication: 16-069

Flaw Thruwall Dimension = 0.23
Flaw Length "l" = 0.50
Separation with clad "S" = 2.90
Surface Separation "S" = 2.71

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.06	3.56 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.06	Allowed 3.56

a = 0.113
 a/l value = 0.226
 Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.56%
 a/t = 1.77%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-073
Indication: 16-073

Flaw Thruwall Dimension = 0.30
Flaw Length "l" = 0.75
Separation with clad "S" = 2.93
Surface Separation "S" = 2.74

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	2.79	3.28 Y
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.79	Allowed 3.28

a = 0.149
a/l value = 0.198
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.28%
a/t = 2.33%

Comments:

121 of 245

00484

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-022

Exam Data Sheet No.: E-16-10
Ind. Data Sheet No.: 16-077
Indication: 16-077

Flaw Thruwall Dimension = 0.32
Flaw Length "l" = 0.25
Separation with clad "S" = 1.70
Surface Separation "S" = 1.51

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.160
a/l value = 0.500
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%
a/t = 2.51%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-023

Exam Data Sheet No.: E-16-11
Ind. Data Sheet No.: 16-081
Indication: 16-081

Flaw Thruwall Dimension = 0.32
Flaw Length "l" = 0.75
Separation with clad "S" = 1.58
Surface Separation "S" = 1.39

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	2.95	3.45 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			2.95	3.45

a = 0.161
a/l value = 0.215
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.45%
a/t = 2.52%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-023

Exam Data Sheet No.: E-16-11
Ind. Data Sheet No.: 16-082
Indication: 16-082

Flaw Thruwall Dimension = 0.43
Flaw Length "I" = 0.75
Separation with clad "S" = 2.38
Surface Separation "S" = 2.19

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	3.67	4.25 Y
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 3.67	Allowed 4.25

a = 0.216
a/l value = 0.287
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.25%
a/t = 3.38%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-023

Exam Data Sheet No.: E-16-11
Ind. Data Sheet No.: 16-083
Indication: 16-083

Flaw Thruwall Dimension = 0.17
Flaw Length "l" = 1.00
Separation with clad "S" = 2.09
Surface Separation "S" = 1.90

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.14	2.41 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.14	Allowed 2.41

a = 0.085
a/l value = 0.085
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.41%
a/t = 1.32%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-023

Exam Data Sheet No.: E-16-11
Ind. Data Sheet No.: 16-084
Indication: 16-084

Flaw Thruwall Dimension = 0.37
Flaw Length "l" = 0.75
Separation with clad "S" = 1.89
Surface Separation "S" = 1.70

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	3.23	3.73 Y
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
		Allowed		Allowed
		3.23		3.73

a = 0.183
a/l value = 0.243
Y = 1.000

Flaw is Subsurface

Allowed a/t = 3.73%
a/t = 2.86%

Comments:

134 of 245

00497

R1152



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3
Weld ID: C-4-5
Cal. ID: C-001

Exam Data Sheet No.: E-16-05
Patch ID: BF-017
Ind. Data Sheet No.: 16-086

Indication: 16-086 **Channel:** 7 **Angle:** 45 **Direction:** 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
34.5%	294.71	~	~	~	~	570.50	4.87	~	~	~	~	~
28.9%	294.96	~	~	~	~	570.05	4.90	~	~	~	~	~
34.5%	295.21	~	~	~	~	570.50	4.79	~	~	~	~	~
44.3%	295.46	~	~	~	~	570.50	4.79	~	~	~	~	~
41.6%	295.71	~	~	~	~	570.05	4.79	~	~	~	~	~
44.3%	295.96	~	~	~	~	570.50	4.82	~	~	~	~	~
30.4%	296.21	~	~	~	~	569.80	4.92	~	~	~	~	~
20.9%	296.46	~	~	~	~	569.30	5.22	~	~	~	~	~
13.5%	296.71	~	~	~	~	569.30	5.12	~	~	~	~	~
23.7%	296.96	~	~	~	~	569.55	5.03	~	~	~	~	~
32.4%	297.21	~	~	~	~	569.30	5.19	~	~	~	~	~
32.4%	297.46	~	~	~	~	569.30	5.19	~	~	~	~	~
34.5%	297.71	~	~	~	~	569.30	5.17	~	~	~	~	~
28.9%	297.96	~	~	~	~	569.30	5.17	~	~	~	~	~
34.5%	298.21	~	~	~	~	569.05	5.56	~	~	~	~	~
25.2%	298.46	~	~	~	~	569.05	5.38	~	~	~	~	~
25.2%	298.71	~	~	~	~	569.30	5.38	~	~	~	~	~
25.2%	298.96	~	~	~	~	569.30	5.22	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: No apparent tip signals. No determinable thruwall dimension. Same indication as 0° ind. 16-048.

This indication evaluated as a laminar reflector and is acceptable
 in accordance with IVB-3510-2, ASME Section XI, 1986 Edition, No Addenda.

Analyst: CG MS
 Level: III Date: 12/18/93

Reviewed By: R.D. Forman
 Level: II Date: 12-20-93

136 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-017

Exam Data Sheet No.: E-16-05
Ind. Data Sheet No.: 16-087
Indication: 16-087

Flaw Thruwall Dimension = 0.44
Flaw Length "I" = 0.50
Separation with clad "S" = 1.92
Surface Separation "S" = 1.73

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	5.08	6.48 Y
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			5.08	6.48

a = 0.219
a/t value = 0.438
Y = 1.000

Flaw is Subsurface

Allowed a/t = 6.48%
a/t = 3.43%

Comments:

138 of 245 # 00501

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-017

Exam Data Sheet No.: E-16-05
Ind. Data Sheet No.: 16-088
Indication: 16-088

Flaw Thruwall Dimension = 0.24
Flaw Length "l" = 0.25
Separation with clad "S" = 2.80
Surface Separation "S" = 2.61

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	5.16	7.24 Y
0.50	5.20	7.6	~	~
			Allowed	Allowed
			5.16	7.24

a = 0.120
a/l value = 0.480
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.24%
a/t = 1.88%

Comments:

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-018R

Exam Data Sheet No.: E-16-06
Ind. Data Sheet No.: 16-092
Indication: 16-092

Flaw Thruwall Dimension = 0.127
Flaw Length "l" = 1.50
Separation with clad "S" = N/A
Surface Separation "S" = 0.00

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	2.14	2.41 Y
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.14	Allowed 0.00

a = 0.127
a/l value = 0.085
Y = 0.000

Flaw is Surface

Allowed a/t = 2.14%
a/t = 1.99%

Comments: Evaluated to notch sensitivity assigned thruwall dimension = 2%T.

145 of 245

R1152



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: C-4-5
Patch: BF-018R

Exam Data Sheet No.: E-16-06
Ind. Data Sheet No.: 16-094
Indication: 16-094

Flaw Thruwall Dimension = 0.127
Flaw Length "l" = 1.25
Separation with clad "S" = N/A
Surface Separation "S" = 0.00

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	2.21	2.51 Y
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed 2.21	Allowed 0.00

a = 0.127
a/l value = 0.102
Y = 0.000

Flaw is Surface

Allowed a/t = 2.21%
a/t = 1.99%



Comments: Evaluated to notch sensitivity assigned thruwall dimension = 2%T.

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC







Lower 1



149 of 245

00512
R 1152








S D : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



15108295
R1152
UUC14

S 1 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC


S 1 : Ch 08 : AMP C-scan : BF-013 : A

L[073]
T[247]
ABS



565.80
555.30

8.04 23.54 39.04 54.54 70.04






x = 69.79in, y = 573.55in
DAC-LOG








LOWER








15208245
2152
00010








R 1152
15306245
0051







15406245
R 115Z
0051







155 of 245
R 1152 00516



15607245
R 1152 0051







157 of 245
R115200520



00521

15808295
R1152




00522

159 of 245
R1152


S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
92.7


100%
50%
20%





Lower T



Log



Log



Log



00523

160 of 245
R1152



S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

DAC



Lower T



00524


R1152
161 of 245

S 1 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%



DAC






Lower 1





00525



R1152
162 of 245



00526






168 of 295
R1152

S 2 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



00527




1698295
R.152

S 1 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%



DAC



Lower T
16-017



00528




R1152
165 of 245

S 1 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%



DAC



Lower T



00529





R 1152
166 of 295

S 1 : Scale



32.3	
36.6	
41.0	100%
45.3	50%
49.7	
54.0	20%
58.4	
62.7	
67.1	
71.4	
75.8	
80.1	
84.5	
88.8	
93.2	

DAC



Lower T

00530






R 1152
167 of 245

S 0 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower
/test>dumpe



00521




R 1152
168 of 245

S O : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



Lower



00532







169 of 295
R1152

S O : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC







R1152
170 of 245
0053

S D : Scale

32.3
36.6
41.0
45.3
49.7 100%
54.0 50%
58.4
62.7 20%
67.1
71.4
75.8
80.1
84.5
88.8
93.2

DAC




00534
R1152
17106295

S 0 : Scale





32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T





R 1152
 122 of 201
 * 00535

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2




100%
50%
20%

DAC



12304 245

12304 245
R 1100536




S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T







R115-20537
723 17408-295

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC






125 of 295
R1152
00538

S 0 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T





1764-245
R 1152
00539

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T




R1152 00540
1798245





S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7 100
67.1 50
71.4
75.8 20
80.1
84.5
88.8
93.2

DAC



Lower T







178 of 295
R11500541

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100
50
20

DAC





00542
 R 1152
 17908295

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T



18008245
R 1152
* 00543






S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC

Lower









00544
R1152
18108245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.0
93.2

100
50
20







182 of 295
R1100545

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



18308 245
R1152
* 00546

S 0 : Scale

32.3

36.6

41.0

45.3

49.7

54.0

58.4

62.7

67.1

71.4

75.8

80.1

84.5

88.8






93.2

180

50

20







DAC



Lower T

184 of 245

R11500547



185 of 295
R1152
UUC48







S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC







18608245
R1192549

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2






100%
50%
20%

DAC



Lower T

187 of 245
R1152
00550







S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100
50
20

DAC



Lower T

18906-245





00552
21152

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T






1908245
21152
00553

S D : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100
50
20


DAC








S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

DAC



Lower T







4 00555
R1152
1929-295

S D : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100%
50%
20%

DAC




19306245
21152
* 00556

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower T




199 of 295
R1152
00557

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



Lower T






R1152
19506245
00558

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



LOWER



00559
21152
19604-245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

DAC

100%
50%
20%

S 0 : Ch 02 : AMP C-scan : BF-017


L[069]
T[179]
ABS

565.80
555.30


252.15 267.65 283.15 298.65

X = 296.90in, Y = 572.55in
DAC-LOG



Lower



S 0 : Ch 02 : SV-scan : BF-017 : A 0 : D 90 : H



S 0 : Ch 02 : EV-scan : BF-017 : A 0 : D 90 : H






1978 245
R21152
00560

S D : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



Lower






00561 1988
R1152 245

S O : Scale



32.3
36.6
41.0
45.3
49.7
51.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%






DAC













Lower



00562 199 of 245
21152








202 of 245
R1152
00565

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.0
93.2

100
50
20

DAC



Lower



00000
R1152
20306 295

S D : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.8
93.2

100%
50%
20%

DAC

S D : Ch 05 : AMP C-scan : BF-017




L[058]
T[122]
ABS

570.20
559.70

257.85 273.35 288.85 304.35

x = 288.35in, y = 574.20in
DAC-LOG

Lower



204 of 2015
R1152
* 06567

S 0 : Scale

32.3

36.6

41.0

45.3

49.7

54.0

58.4

62.7

67.1

71.4

75.8

80.1

84.5

88.8


93.2

100%




50%

20%

DAC



Lower



00568

21152


205 of 295

S 1 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%






DAC







Lower




00569 R1152
206 of 295







00570 R1152
207 of 245



* 00571 R1152
208 of 295





Lower Term






00572
R1152
20904 295

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC





* 00573
R1152
210 of 295

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower




R1152
2/2 of 245
00575

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower



0000 1000



R1152
21307245
00576

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower





R1152
2/14 of 295
* 00577

S 0 : Scale



32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



Lower




R1152
2154-295
00578

S 0 : Scale





32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower





00579
R1152
216 of 245

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower





00580
R 1152
217 of 295

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower








218 of 245
R 1152
00581

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC








21908-245
R 00582
R 1152

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.3
75.8
80.1
84.5
88.8
93.2






100%
50%
20%

DAC







00583 R 1152

220 of 245







00584 R1152

22/04/2015



00585 R1152
2220f 245





00586 R1152
22307-245

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



Lower



0000 1000

00587 R1152






2246/245

S 0 : Scale

32.3
36.6
41.0
45.3
50.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC







00588 R1152
R2564 245

S 0 : Scale






32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

180
50
20






DAC



00000 3700
 00589 R1152
 22607295



00590 R 1152
 227 of 295







00551 R 1152
2284 245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
81.5
88.8
93.2

100%
50%
20%

DAC







00592 21152
229 of 245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.0
80.1
84.5
88.0
93.2

100%
50%
20%

DAC








00593 R 1152
230 of 245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

DAC






00594 R1152
23/07/245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%






DAC



Lower T



00593 R1152
232 of 245




00596 R1152
233 of 245

S 0 : Scale




32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.0
93.2

100%
50%
20%

DAC



Lower T









A. 00597
23910f-245
R1152

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC







235 of 245
00598 R1152

S 0 : Scale






32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC



00599 R1152
236 of 245







00600 R1152
237 of 245

S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC





00601 R1152
238 of 245

S 0 : Scale


32.3
36.6
41.0
45.3
49.7
54.0
58.4 100%
62.7 50%
67.1 20%
71.4
75.8
80.1
84.5
88.8
93.2

DAC



16-090
can return

Top Te r



00602 R 1152
23907-245

S 0 : Scale

- 32.3
- 36.6
- 41.0
- 45.3
- 49.7
- 54.0
- 58.4
- 62.7
- 67.1
- 71.4
- 75.8
- 80.1
- 84.5
- 88.8
- 93.2


100

50%

20%

DA


S 0 : Ch 07 : SV-scan : BF-018R : A 47 : D 0 : H



Top Te

16-091
CMT 12/13/97

S 0 : Ch 07 : EV-scan : BF-018R : A 47 : D 0 : H








00603 R1152
2400 245

S 1: Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

50%
20%

DAC



00604
R1152
29/08/245


S 0 : Scale

- 32.3
- 36.6
- 41.0
- 45.3 100%
- 49.7 50%
- 54.0
- 58.4 20%
- 62.7
- 67.1
- 71.4
- 75.0
- 80.1
- 84.5
- 88.8
- 93.2

DAC




S 0 : Ch 08 : AMP C-scan : BF-018



X = 357.04in, Y = 571.80in
RAM-LOG


S 0 : Ch 08 : EV-scan : BF-018R : A 46 : D 90



Line = 0066, Trigger = 0168

16-097 093
CAM 12/13/93

S 0 : Ch 08 : SV-scan : BF-018R : A 46 : D 90 : H



Line = 0066, Trigger = 0168
X = 360.93in, Y = 571.80in Z = 3.78in
Log

00605

R 1152

242 of 245






S 0 : Scale

32.3
36.6
41.0
45.3
49.7
54.0
58.4
62.7
67.1
71.4
75.8
80.1
84.5
88.8
93.2

100%
50%
20%

DAC


Lower Ter
-094



00606 R 1152

24304-245

BROWNS FERRY UNIT-3 WELD LOCATIONS




Shego hkr

FOR INFORMATION ONLY

00607R1152

GE NUCLEAR ENERGY	BROWNS FERRY UNIT 3	VESSEL ROLLOUT & AS SCANNED PATCH LOCATIONS	BF-3-VMA	REV 0
-------------------	---------------------	---	----------	-------



Nominal Clad T = 3/16"
 Nominal Base Metal T = 6 3/8"

CH.	ANGLE	DIR.	MIN Y	MAX Y
1	0 W	0	566.75	579.25
2	0 W	90	566.75	579.25
3	70 UP	0	561.86	579.25
4	70 CW	90	566.75	579.25
5	70 DN	180	566.75	584.14
6	70 CCW	270	566.75	579.25
7	45 UP	0	560.21	579.25
8	45 CW	90	566.75	579.25
9	45 DN	180	566.75	585.80
10	45 CCW	270	566.75	579.25
11	60 UP	0	555.40	579.25
12	60 CW	90	566.75	579.25
13	60 DN	180	566.75	590.60
14	60 CCW	270	566.75	579.25
15	0 BM	0	566.75	590.60
16	0 BM	90	555.40	579.25

06608 245 of 295

R1152