



GE Nuclear Energy

GERIS 2000 Examination Summary Sheet

Project: TVA, Browns Ferry Nuclear Plant, Unit 3

System: Reactor Pressure Vessel

Weld ID: V-4-C

ASME Code Category: B-A

Calibration Sheets: C-001

Supporting Data: Examination Data Sheets E-15-00 and E-15-01, Indication Data Sheets 15-001, 15-004, 15-005, 15-012, 15-018, 15-024, 15-027 thru 15-032, Indication Evaluation Sheets, Screen Prints, Exam Patch Location Map, Exam Coverage Plots, and GERIS 2000 Setup Records.

Examination Summary

The ultrasonic examination of weld V-4-C resulted in no recorded indications that exceed the allowable standards of IWB-3500, ASME Section XI, 1986 Edition, No Addenda.

The ASME Section XI required examination volume was examined with the GERIS 2000 System from the RPV inside surface utilizing Procedure No. GE-UT-700, Rev. 2. The total examination coverage was calculated to be 100%.

The GERIS 2000 utilizes an array of search units arranged to effectively examine the weld and adjacent base material parallel and perpendicular to the weld axis in two directions. The transducer package consisted of 0° longitudinal, 45° and 60° shear wave, and 70° refracted longitudinal (RL) wave search units.

The GERIS 2000 recorded indications with the 0° weld metal scans, 45° and 60° shear wave scans that were evaluated and found to be acceptable per the referencing Code section.

Fabrication records and previous examination results were reviewed prior to the completion of this examination summary.

GERIS Analyst: <i>Debra Kimball</i>		GE Reviewer: <i>R.D. Forman</i>	
LEVEL: <i>III</i>	DATE: <i>12-16-93</i>	LEVEL: <i>II</i>	DATE: <i>12-18-93</i>
UTILITY Review: <i>2 new code</i>		ANII Review:	
TITLE: <i>HA</i>	DATE: <i>1/26/94</i>	TITLE: <i>Mount Fold</i>	DATE: <i>1/13/94</i>



GERIS 2000 Examination Data Sheet

Procedure No.: GE-UT-700
Revision No.: 2
FRR No.: N/A

[illegible]

Limitations: None

Level: II Date: 12-18-93



GERIS 2000 Examination Data Sheet



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-001

Indication: 15-001/003

Channel: 1

Angle: 0

Direction: 0

Amp.	X	20% Min Y	MP	50% Min Y	MP	@ Max Y	MP	50% Max Y	MP	20% Max Y	MP	Remarks
44.3%	356.75	~	~	~	~	~	~	~	~	~	~	15-001
60.6%	356.96	~	~	558.70	BL	558.95	3.57	559.20	3.58	~	~	15-001
50.2%	357.21	~	~	~	~	559.21	3.50	~	~	~	~	15-001
57.0%	357.46	~	~	558.70	BL	558.95	3.45	559.20	3.52	~	~	15-001
82.9%	357.71	~	~	559.20	3.44	559.45	3.44	559.70	3.44	~	~	15-001
88.2%	357.96	~	~	558.95	3.45	559.20	3.44	559.70	3.42	~	~	15-001
73.1%	358.21	~	~	558.95	3.42	559.20	3.45	559.45	3.39	~	~	15-001
57.0%	358.46	~	~	~	~	559.20	3.39	~	~	~	~	15-001
53.5%	358.71	~	~	~	~	559.45	3.42	~	~	~	~	15-001
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
68.7%	357.96	~	~	569.70	BL	568.59	3.26	569.70	3.32	~	~	15-002
53.5%	358.21	~	~	~	~	569.20	3.24	~	~	~	~	15-002
~	358.46	~	~	~	~	~	~	~	~	~	~	15-002
60.6%	358.71	~	~	568.70	3.22	568.95	3.26	569.20	3.22	~	~	15-002
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
60.6%	357.71	~	~	569.70	BL	569.95	3.78	570.20	3.83	~	~	15-003
68.7%	357.96	~	~	569.95	3.76	570.20	3.76	570.45	3.63	~	~	15-003
60.6%	358.96	~	~	569.95	BL	570.20	3.73	570.45	BL	~	~	15-003
50.2%	358.46	~	~	~	~	570.20	3.72	~	~	~	~	15-003
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments:

Non-relevant straight beam indications due to plate segregates, no significant loss of backwall.

Recorded for reference only.

Analyst: Ceresa Kimball

Level: III

Date: 12-16-93

Reviewed By: R.O. Forman

Level: II

Date: 12-16-93



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01**Patch ID:** BF-049**Ind. Data Sheet No.: 15-004**

Indication: 15-004

Channel: 1

Angle: 0

Direction: 0

[illegible]

Comments:

Non-relevant straight beam indications due to plate segregates, no significant loss of backwall.

Recorded for reference only.

Analyst:

Analyst: Debra Kimball

Level:

Level: III Date: 12-16-93

Reviewed By:

Reviewed By: R.O. Freeman

Level:

Level: IV Date: 12-16-93

R1168



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-005

Indication: 15-005/011

Channel: 2

Angle: 0

Direction: 90

Amp.	Y	20%		50%		@ Max		50%		20%		Remarks
		Min X	MP	Min X	MP	X	MP	Max X	MP	Max X	MP	
44.3%	538.05	~	~	~	~	355.90	4.77	~	~	~	~	15-005
82.9%	538.30	~	~	355.65	4.69	356.15	4.66	356.40	4.66	~	~	15-005
155.1%	538.55	~	~	355.40	4.69	355.90	4.66	356.40	4.66	~	~	15-005
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
68.7%	538.55	~	~	~	~	357.90	4.43	~	~	~	~	15-006
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
77.9%	538.55	~	~	~	~	358.90	3.38	~	~	~	~	15-007
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
68.7%	540.80	~	~	357.15	4.92	357.40	4.94	357.65	4.92	~	~	15-008
68.7%	541.05	~	~	357.15	4.92	357.40	4.92	357.65	4.92	~	~	15-008
106.4%	541.30	~	~	357.15	4.89	357.40	4.90	357.90	4.90	~	~	15-008
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
94.0%	549.30	~	~	357.90	3.31	358.15	3.36	358.40	3.36	~	~	15-009
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
57.0%	550.30	~	~	~	~	357.15	3.44	~	~	~	~	15-010
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
73.1%	552.05	~	~	356.65	4.31	357.15	4.33	357.40	4.31	~	~	15-011
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments:

Non-relevant straight beam indications due to plate segregates, no significant loss of backwall.

Recorded for reference only.

Analyst: Deese Kimball

Level: III

Date: 12-16-93

Reviewed By: R.O. Forman

Level: II

Date: 12-16-93



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-012

Indication: 15-012/017

Channel: 2

Angle: 0

Direction: 90

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
155.1%	554.55	~	~	357.40	3.47	357.90	3.47	358.40	3.44	~	~	15-012
225.7%	554.80	~	~	357.40	3.43	357.90	3.44	358.65	3.43	~	~	15-012
50.1%	555.05	~	~	~	~	357.65	3.44	~	~	~	~	15-012
~	555.30	~	~	~	~	~	~	~	~	~	~	15-012
175.6%	555.55	~	~	357.40	3.47	357.90	3.44	358.40	3.44	~	~	15-012
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
57.0%	560.30	~	~	~	~	357.40	3.62	~	~	~	~	15.013
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
57.0%	563.55	~	~	357.65	3.38	358.15	3.21	~	~	~	~	15.014
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
77.9%	564.80	~	~	~	~	355.15	4.46	355.65	4.49	~	~	15-015
73.1%	565.05	~	~	~	~	354.90	4.60	355.15	4.62	~	~	15-015
94.0%	565.30	~	~	354.90	4.49	355.15	4.54	355.65	4.49	~	~	15-015
155.1%	565.55	~	~	354.90	4.45	355.15	4.45	355.90	4.51	~	~	15-015
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
50.1%	565.30	~	~	~	~	356.90	4.73	~	~	~	~	15-016
100.0%	565.55	~	~	356.15	BL	356.65	4.73	356.90	4.73	~	~	15-016
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
68.7%	566.30	~	~	356.90	4.60	357.15	4.56	357.65	4.60	~	~	15-017
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments:

Non-relevant straight beam indications due to plate segregates, no significant loss of backwall.

Recorded for reference only.

Analyst: Debra Kimball

Level: III Date: 12-16-93

Reviewed By: R.O. Forman

Level: II Date: 12-16-93



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-018

Indication: 15-018/023

Channel: 2

Angle: 0

Direction: 90

Amp.	Y	20% Min X	MP	50% Min X	MP	@ Max X	MP	50% Max X	MP	20% Max X	MP	Remarks
50.1%	568.05	~	~	~	~	355.15	3.92	~	~	~	~	15-018
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
73.1%	568.05	~	~	355.90	4.56	356.15	4.56	356.40	4.58	~	~	15-019
68.7%	568.30	~	~	355.90	4.53	356.15	4.60	356.40	4.56	~	~	15-019
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
57.0%	568.05	~	~	357.90	4.31	358.15	4.31	358.40	4.30	~	~	15-020
68.7%	568.30	~	~	357.90	BL	358.40	4.20	358.65	4.20	~	~	15-020
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
57.0%	570.55	~	~	~	~	357.90	3.90	358.15	3.89	~	~	15-021
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
44.3%	570.55	~	~	~	~	356.40	3.49	~	~	~	~	15-022
73.1%	570.80	~	~	356.15	3.36	356.90	3.36	357.15	3.38	~	~	15-022
106.4%	571.05	~	~	356.15	3.41	356.65	3.36	356.90	3.36	~	~	15-022
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
100.0%	571.30	~	~	356.65	5.99	356.90	5.99	357.40	5.94	~	~	15-023
120.6%	571.55	~	~	356.65	6.06	356.90	6.01	357.40	5.99	~	~	15-023
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~

Comments:

Non-relevant straight beam indications due to plate segregates, no significant loss of backwall.

Recorded for reference only.

Analyst: Debra Kimball

Level: III Date: 12-16-93

Reviewed By: R.O. Fournier

Level: II Date: 12-16-93



GERIS 2000 Indication Data Sheet

R1168



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01**Patch ID:** BF-049

Ind. Data Sheet No.: 15-027

Indication: 15-027

Channel: 9

Angle: 45

Direction: 180

[illegible]

Comments: OD surface geometry.

13.05 dB below notch sensitivity.

No apparent tip signals.

Indication has no determinable thruwall dimension and is acceptable to IWB-3510-1.

Analyst: Delesa Kimball

Level: III Date: 12-16-93

Reviewed By: R.O. Freeman

Level: II Date: 12-16-93

R1168



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-028

Indication: 15-028

Channel: 9

Angle: 45

Direction: 180

[illegible]

Comments: This indication also seen with Ch. 10 & 13 below recordable levels (See 15-031).

Recorded at less than ASME required DAC levels due to apparent tip diffracted signals.

Thruwall size was determined by the PATT technique.

TW = .51

$$L = .75$$

S = 2.26 w/clad

Analyst:

Analyst: Jessica Kimball

Reviewed By:

Reviewed By: R.O. Forman

Level:

Level: III Date: 12-16-93

Level:

Level: II Date: 12-16-93

R1168



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: V-4-C
Patch: BF-049

Exam Data Sheet No.: E-15-01
Ind. Data Sheet No.: 15-028
Indication: 15-028

Flaw Thruwall Dimension = 0.51
Flaw Length "l" = 0.75
Separation with clad "S" = 2.26
Surface Separation "S" = 2.07

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	4.28	4.96 Y
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	~	~
			Allowed	Allowed
			4.28	4.96

a = 0.255
a/l value = 0.340
Y = 1.000

Flaw is Subsurface

Allowed a/t = 4.96%
a/t = 4.00%

Comments:



GERIS 2000 Indication Data Sheet

Cal. ID: C-001

Ind. Data Sheet No.: 15-029

Direction: 270

* 00219

R1168



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01

Patch ID: BF-049

Ind. Data Sheet No.: 15-030

Indication: 15-030

Channel: 13

Angle: 60

Direction: 180

[illegible]

Comments: No apparent tip signals.

Thruwall size was determined by the ASME 50% method.

This indication also seen with Ch.10 below recordable levels.

TW = .31

$$L = .25$$

S = 2.415 w/clad

Analyst:

Reviewed By:

Level:

Date: 12-16-93

Level:

Date: 12-16-93



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: V-4-C
Patch: BF-049

Exam Data Sheet No.: E-15-01
Ind. Data Sheet No.: 15-030
Indication: 15-030

Flaw Thruwall Dimension = 0.31
Flaw Length "l" = 0.25
Separation with clad "S" = 2.42
Surface Separation "S" = 2.23

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.155
a/l value = 0.500
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%
a/t = 2.43%

Comments:

R1168



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01**Patch ID:** BF-049**Ind. Data Sheet No.: 15-031**

Indication: 15-031

Channel: 13

Angle: 60

Direction: 180

[illegible]

Comments: This indication also recorded with Ch. 9 (see 15-028).

Recorded at less than ASME required amplitude level due to apparent tip diffracted signals.

Thruwall size was determined by the PATT technique

TW = .5

 $L = .5$

S = 2.39 w/clad

w/clad

Analyst:

Analyst: Aeresa Kimball

Reviewed By:

Reviewed By: R.O. Forman

Level:

Level: III

Date:

Date: 12-16-93

Level:

Level: II

Date:

Date: 12-16-93



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: V-4-C
Patch: BF-049

Exam Data Sheet No.: E-15-01
Ind. Data Sheet No.: 15-031
Indication: 15-031

Flaw Thruwall Dimension = 0.50
Flaw Length "I" = 0.50
Separation with clad "S" = 2.39
Surface Separation "S" = 2.20

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.250
a/l value = 0.500
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%
a/t = 3.92%

Comments:



GE Nuclear Energy

GERIS 2000 Indication Data Sheet

Project: TVA, Browns Ferry, Unit 3

Weld ID: V-4-C

Cal. ID: C-001

Exam Data Sheet No.: E-15-01**Patch ID:** BF-049

Ind. Data Sheet No.: 15-032

Indication: 15-032

Channel: 14

Angle: 60

Direction: 270

[illegible]

Comments: No apparent tip signals.

Thruwall size was determined by the ASME 50% method.

This indication also seen with Ch. 10 at below recordable levels.

TW = .44

L = .25

S = 2.34 w/clad

Analyst: Deusa Kimball

Reviewed By: R.O. Forman

Level: III Date: 12-16-93

Level: II Date: 12-16-93

R1168



GE Nuclear Energy

GERIS 2000 Indication Evaluation Sheet

Project: TVA, Browns Ferry Unit 3
Weld ID: V-4-C
Patch: BF-049

Exam Data Sheet No.: E-15-01
Ind. Data Sheet No.: 15-032
Indication: 15-032

Flaw Thruwall Dimension = 0.44
Flaw Length "I" = 0.25
Separation with clad "S" = 2.34
Surface Separation "S" = 2.15

T nominal = 6.38
Clad T nominal = 0.19

Flaw is acceptable by Table IWB-3510-1

**ASME Section XI, 1986 Edition
TABLE IWB-3510-1 for 4" to 12"**







a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.90	2	~	~
0.05	2.00	2.2	~	~
0.10	2.20	2.5	~	~
0.15	2.50	2.9	~	~
0.20	2.80	3.3	~	~
0.25	3.30	3.8	~	~
0.30	3.80	4.4	~	~
0.35	4.40	5.1	~	~
0.40	5.00	5.8	~	~
0.45	5.10	6.7	~	~
0.50	5.20	7.6	5.20	7.60 Y
			Allowed	Allowed
			5.20	7.60

a = 0.220
a/l value = 0.500
Y = 1.000

Flaw is Subsurface

Allowed a/t = 7.60%
a/t = 3.45%

Comments:



4-00226

20 of 29

21168

00227










Figure 1 consists of 12 sub-diagrams labeled (a) through (l), each showing a 2D coordinate system with a shaded feasible region and a dashed objective function line. The steps are as follows:




- (a) Initial feasible region and objective function line.
- (b) Objective function line moved to the right.
- (c) Objective function line moved further to the right.
- (d) Objective function line moved to the left.
- (e) Objective function line moved further to the left.
- (f) Objective function line moved to the right.
- (g) Objective function line moved further to the right.
- (h) Objective function line moved to the left.
- (i) Objective function line moved further to the left.
- (j) Objective function line moved to the right.
- (k) Objective function line moved further to the right.
- (l) Final optimal solution reached at the vertex (4, 4).

202

R1168










00228



22 OF 29







R1168



00229

23 of 29


21168








0000 0728

00230 24 OF 29

R1168




Top Termi
tar3/15-030








00231

25 of 29






R1168



Top Termi
tor3/15-031





21168
26 OF 29
00232



27 OF 29
* 00233
K1168

BROWNS FERRY UNIT-3 WELD LOCATIONS





Nominal Clad T = 3/16"
 Nominal Base Metal T = 6 3/8"
 1 Degree = 2.19"

CH.	ANGLE	DIR.	MIN X	MAX X
1	0 W	0	355.10	367.29
2	0 W	90	355.10	367.29
3	70 UP	0	355.10	367.29
4	70 CW	90	350.83	367.29
5	70 DN	180	355.10	367.29
6	70 CCW	270	355.10	371.87
7	45 UP	0	355.10	367.29
8	45 CW	90	349.34	367.29
9	45 DN	180	355.10	367.29
10	45 CCW	270	355.10	373.36
11	60 UP	0	355.10	367.29
12	60 CW	90	345.35	367.29
13	60 DN	180	355.10	367.29
14	60 CCW	270	355.10	377.35
15	0 BM	0	355.10	377.35
16	0 BM	90	345.35	367.29