

PMFermiCOLPEm Resource

From: FermiCOL Resource
Sent: Thursday, September 20, 2012 10:48 AM
To: PMFermiCOLPEm Resource
Subject: DRAFT RAIs Section 2.5.2
Attachments: RAI 3937.doc

From: Berrios, Ilka
Sent: Tuesday, January 05, 2010 1:44 PM
To: Berrios, Ilka; LaShawn G Green; Peter W Smith; peterosonn@dteenergy.com
Cc: FermiCOL Resource; Kevern, Thomas; Patel, Chandu
Subject: DRAFT RAIs Section 2.5.2

All,

Attached file is a DRAFT RAI related to FSAR section 2.5.2. Please review it and let me know if a call is needed to clarify this question. If we don't hear from you by Wednesday, we'll assume that a call is not needed and the RAI letter will be issued.

Any questions, please let me know.

Hearing Identifier: Fermi_COL_Public
Email Number: 1073

Mail Envelope Properties (0AA17736E4C4154CA37233EEBFC8DEB20111BA669D7F)

Subject: DRAFT RAIs Section 2.5.2
Sent Date: 9/20/2012 10:48:28 AM
Received Date: 9/20/2012 10:48:38 AM
From: FermiCOL Resource

Created By: FermiCOL.Resource@nrc.gov

Recipients:
"PMFermiCOLPEm Resource" <PMFermiCOLPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	555	9/20/2012 10:48:38 AM
RAI 3937.doc	30202	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 3937 Revision 0

Fermi Unit 3
Detroit Edison
Docket No. 52-033
SRP Section: 02.05.02 - Vibratory Ground Motion
Application Section: 2.5.2

QUESTIONS for ESBWR/ABWR Projects 1 (NGE1)

02.05.02-***

In order for the staff to verify the adequacy of the Fermi 3 site PSHA relative to the seismicity in the Anna, Ohio and Northeast Ohio areas, please provide the input source parameters (e.g. activity rates) as well as the specific source geometries used by each of the EPRI Teams to model these two potential sources. In addition, provide the corresponding PSHA hazard curves for these two sources.