

PMSTPCOL PEmails

From: Tai, Tom
Sent: Thursday, September 13, 2012 4:06 PM
To: Tomkins, James
Cc: STPCOL
Subject: STP - Long Term Cooling Clarifications

Jim,

Please confirm the following:

1. The wetwell design temperature is 104 C.
2. The re-analysis of the ABWR DCD containment (due to DCD errors) resulted in higher M&E releases. This increase is not driven by the correction of DCD errors.

I may have a couple more questions later.

Thanks

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3448

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED1B0C43A4911)

Subject: STP - Long Term Cooling Clarifications
Sent Date: 9/13/2012 4:06:05 PM
Received Date: 9/13/2012 4:06:10 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Tomkins, James" <jetomkins@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	402	9/13/2012 4:06:10 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: