

ATTACHMENT 2

Heat transfer calculations used to develop Attachment 5 and Table A5-1 in the July 12, 2012, License Amendment Request

Component EPN	Noun Name	Design Analysis
1(2)E12-B001A/B	RHR Heat Exchanger	97-201, Rev. A02
0DG01A	0 DG Jacket Water Cooler	97-195, Rev. A01
1(2)DG01A	A DG Jacket Water Cooler	97-195, Rev. A01
1(2)E22-S001	B DG Jacket Water Cooler	97-197, Rev. A04
1(2)VY01A	NW ECCS (A RHR) Pump Cubicle Cooler	97-200, Rev. A05
1(2)VY02A	SW ECCS (HPCS) Pump Cubicle Cooler	97-200, Rev. A05
1(2)VY03A	SE ECCS (B/C RHR) Pump Cubicle Cooler	97-199, Rev. B03
1(2)VY04A	NE ECCS (LPCS/RCIC) Pump Cubicle Cooler	97-198, Rev. A03

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet

Design Analysis (Minor Revision)		Last Page No. ⁶ Attachment B, B2	
Analysis No.: ¹ 97-201	Revision: ² A02		
Title: ³ Thermal Model of ComEd/LSCS RHR Heat Exchangers 1(2)RH01A & B			
EC/ECR No.: ⁴ 388666	Revision: ⁵ 000		
Station(s): ⁷ LaSalle	Unit No.: ⁸ 01 & 02		
Safety/QA Class: ⁹ SR	System Code(s): ¹⁰ E12, RH		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, AT/AR#: N/A
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴ This revision evaluates a maximum cooling water inlet temperature of 107 °F for the RHR heat exchangers. The previous temperature that was evaluated was 104 °F. Affected pages are Pages 1-3, Attachment A, Pages A1-A2, and Attachment B, Pages B1-B2.			
Disposition of Changes: ¹⁵ See attached pages. The changes made are acceptable.			
Preparer: ¹⁶	Sean Tanton <small>Print Name</small>	<i>Sean Tanton</i> <small>Sign Name</small>	5/23/12 <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	Steve Chon <small>Print Name</small>	<i>Steve Chon</i> <small>Sign Name</small>	6/6/12 <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/>	Peer review <input type="checkbox"/>	
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	N/A <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Reviewer ²¹	N/A <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Approver: ²²	DAN SCHMIT <small>Print Name</small>	<i>DASchmit</i> <small>Sign Name</small>	6/6/12 <small>Date</small>

Purpose:

The purpose of this revision is to determine the amount of heat that can be removed via the 1(2)E12-B001A/B heat exchangers for the containment cooling mode (CCM) and to verify that the heat exchangers can remove the design heat load of 41.6 MBTU/hr for the shutdown cooling (SDC) mode with a revised maximum cooling water temperature of 107 °F. The revised design heat load to be used for GL 89-13 surveillance testing will also be determined with this revision.

Assumptions:

There are no assumptions for this revision.

Inputs:

- Cooling water temperature = 107 °F (Reference 2)
- Cooling water flow rate = 7400 gpm (Reference 1)
- RHR System water temperature during CCM = 212 °F (Reference 1)
- RHR System water temperature during SDC = 120 °F (Reference 1)
- RHR System flow rate through 1(2)E12-B001A/B = 7200 gpm (Reference 1)
- Fouling factor for 1(2)E12-B001A/B = 0.00185 hr·ft²·°F/BTU (Reference 1)
- 53 tubes plugged (5% tube plugging) (Reference 1)
- RHR Heat Exchanger K factor = 438 (Reference 2)

References:

1. Design analysis 97-201, Rev. A, up to and including Rev A01
2. EC 388666, Rev. 000
3. L-000711, Rev. 004D (See EC 388666)
4. EC 382267, Rev. 000
5. L-002857, Rev. 001 (See EC 388666)
6. L-003352, Rev. 000A (See EC 388666)

Identification of Computer Programs:

The computer program used in this analysis is Proto HX version 4.01. This program has been validated per DTSQA tracking number EX0000103.

Method of Analysis / Numeric Analysis:

As stated in Reference 2, to maintain peak suppression pool temperatures at or below their current analyzed values, the RHR heat exchanger K factor is required to be raised from 417 to 438. This number is used as an input for various analyses. The RHR Heat Exchanger K factor [Btu/sec·°F] is determined as follows:

$$K = \frac{Q}{(T_{SP} - T_{SW}) \times 3600}$$

Where:

Q = heat load (Btu/hr)

T_{SP} = Suppression Pool Temperature (°F)

T_{SW} = Cooling Water Temperature (°F)

3600 = Conversion from hours to seconds

Using this equation, the credited K factor can be used to determine the design heat load to be removed. Using a K factor of 438, a bounding suppression pool temperature of 212 °F, and a cooling water temperature of 107 °F, the design heat load becomes 165,564,000 Btu/hr. Note that Reference 5 performs a sensitivity study of the K factor based on various suppression pool temperatures. It demonstrates that 438 is the appropriate K factor even with varying suppression pool temperatures. Reference 6 shows a peak suppression pool temperature of 197 °F, which would equate to a design heat load lower than that which was calculated with 212 °F. Because 165,564,000 Btu/hr is bounding, it will be used as the acceptance criteria.

To determine the amount of heat that could be transferred with a cooling water temperature of 107 °F, the existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp" from 104 °F to 107 °F for containment cooling mode.

To achieve the required heat transfer rates a change in fouling factor from 0.00185 hr·ft²·°F/BTU to 0.00147 hr·ft²·°F/BTU was necessary. A review of trend data from previous RHR heat exchanger thermal performance evaluations was performed. The most recent thermal performance test data shows a worst case fouling factor of 0.000410 hr·ft²·°F/BTU (Ref. 4), which is well below the new fouling factor of 0.00147 hr·ft²·°F/BTU. The thermal performance testing prior to that shows small changes between each test. The heat exchangers are also cleaned regularly to maintain a very low actual fouling factor. The new fouling factor of 0.00147 hr·ft²·°F/BTU has been accepted by the GL 89-13 program manager.

Results / Conclusions:

The RHR Heat Exchangers can remove the revised design heat load of 165,564,000 Btu/hr with the following CCM conditions:

- 107 °F cooling water temperature
- 7400 gpm cooling water flow
- fouling factor of 0.00147 hr·ft²·°F/BTU
- 53 tubes plugged
- RHR process temperature of 212 °F (CCM)
- RHR process flow of 7200 gpm

The total heat removed at these conditions is 166,468,480 BTU/hr, which provides 0.5% thermal margin over the design heat load. The model benchmark was shown to conservatively underestimate the heat transfer of the cooler by 1.31% for CCM. Therefore, any positive margin shown in the model would be an underestimate of actual thermal performance, which would show more margin than what is calculated. The previous maximum fouling factor of 0.00185 hr·ft²·°F/BTU has been revised to 0.00147 hr·ft²·°F/BTU. This case is shown in Attachment A.

The RHR Heat Exchangers can remove the design heat load of 41.6 MBTU/hr with the following SDC conditions:

- 107 °F cooling water temperature
- 7400 gpm cooling water flow
- fouling factor of 0.00147 hr·ft²·°F/BTU
- 53 tubes plugged
- RHR process temperature of 121 °F (SDC) (see below)
- RHR process flow of 7200 gpm

The total heat removed at the above listed conditions is 21,770,576 BTU/hr per heat exchanger, which equates to a total of 43,541,152 BTU/hr for two heat exchangers. The operation of 2 heat exchangers for SDC mode is acceptable as it is a non-safety related function of RHR. Operation of two heat exchangers provides 4.7% thermal margin over the design heat load. The model benchmark was shown to conservatively underestimate the heat transfer of the cooler by 0.31% for the SDC mode. Therefore, any positive margin shown in the model would be an underestimate of actual thermal performance, which would show more margin than what is calculated.

Note that the previous process temperature used for the SDC case was 120 °F. Because SDC mode is non-safety related, the basis for the number is outage productivity. This temperature is used to maintain comfortable conditions during refueling outages. Additionally, the change to 121 °F is a change of 0.83% and is considered to be essentially the same. The RHR pumps and seals are rated for a much higher temperature than this (250 °F, Refs. 2 & 3). Because this is considered to be essentially the same, 120 °F should be used for future evaluations of the RHR heat exchangers for the SDC mode. Just as was done for the CCM mode, the previous maximum fouling factor of 0.00185 hr·ft²·°F/BTU has been revised to 0.00147 hr·ft²·°F/BTU. This case is shown in Attachment B

The acceptance criteria to be used in GL 89-13 thermal performance testing is a fouling factor of 0.00147 hr·ft²·°F/BTU and a total heat removal of 165,564,000 BTU/hr for CCM. The heat removal of 41.6 MBTU/hr for SDC remains the same.

Attachments:

- A. CCM Data Report for 1(2)E12-B001A/B (2 pgs)
- B. SDC Data Report for 1(2)E12-B001A/B (2 pgs)

Data Report for E12-B001 - LSCS - RHR Hx.

CCM - tube side = 107 °F, 7400 gpm, shell side = 212 °F, 7200 gpm, 53 tubes plugged, FF = 0.00147

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28
Mass Fluid Quantity, Total	lbm/hr	7,396.31
Inlet Temperature	°F	0.00
Outlet Temperature	°F	120.00
Fouling Factor	hr·ft ² ·°F/BTU	108.80
		0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Q (BTU/hr)		41,600,000
Design U (BTU/hr·ft ² ·°F)		215.00
Outside h Factor (Hoff)		0.563555000
Fixed U (BTU/hr·ft ² ·°F)		0
Fixed Area (ft ²)		0.00
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA - E
Total Effective Area per Unit (ft ²)		11,500.00
Area Factor		0.996344561
Area Ratio		0.00000
Number of Shells Per Unit		1
Shell Minimum Area		4.880000000
Shell Velocity (ft/s)		3.400
Tube Pitch (in)		1.0000
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		Yes
Total Number of Tubes		1,063
Number of Active Tubes		1,010
Tube Length (ft)		55.30
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall K (BTU/hr·ft·°F)		9.40
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube Circle Diameter		0.000
Bh, Baffle Cut Height (in)		0.000
Ds, Shell Inside Diameter (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - tube side = 107 °F, 7400 gpm, shell side = 212 °F, 7200 gpm, 53 tubes plugged, FF = 0.00147

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,344.00
 Shell Flow (gpm) 6,905.00
 Tube Inlet Temp (°F) 107.00
 Shell Inlet Temp (°F) 212.00
 Input Fouling Factor 0.001470

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3,454,223.04
 Tube Mass Flow (lbm/hr) 3,673,832.59
 Heat Transferred (BTU/hr) 166,468,480.24
 LMTD 58.3
 Effective Area (ft²) 10,926.6

Overall Fouling (hr-ft²-°F/BTU) 0.001470
 Shell-Side ho (BTU/hr-ft²-°F) 1,128.7
 Tube-Side hi (BTU/hr-ft²-°F) 2,079.4
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.8820

U Overall (BTU/hr-ft²-°F) 296.3

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.26	7.08
Reynold's Number	55,935	69,169
Prandtl Number	2.0490	3.2991
Bulk Visc (lbm/ft-hr)	0.7909	1.2323
Skin Visc (lbm/ft-hr)	0.8775	1.1347
Density (lbm/ft³)	60.3957	61.5557
Cp (BTU/lbm-°F)	1.0032	0.9990
K (BTU/hr-ft-°F)	0.3872	0.3732

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 164.0
 Tav Shell (°F) 188.0
 Shell Skin Temp (°F) 172.7
 Tube Temp In (°F) 107.0
 Tube Temp Out (°F) 152.4
 Tav Tube (°F) 129.7
 Tube Skin Temp (°F) 139.2

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

PROTO-HX 4.00 by Proto-Power Corporation (SN#PHX-1002)
Commonwealth Edison

Data Report for E12-B001 - LSCS - RHR Hx.

SDC - tube side = 107 °F, 7400 gpm, shell side = 121 °F, 7200 gpm, 53 tubes plugged, FF = 0.00147

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Mass Fluid Quantity, Total	lbm/hr	0.00	0.00
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor	hr·ft ² ·°F/BTU	0.00250	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Q (BTU/hr)			41,600,000
Design U (BTU/hr·ft ² ·°F)			215.00
Outside h Factor (Hoff)			0.563555000
Fixed U (BTU/hr·ft ² ·°F)			0
Fixed Area (ft ²)			0.00
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA - E
Total Effective Area per Unit (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			0.00000
Number of Shells Per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall K (BTU/hr·ft ² ·°F)			9.40
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube Circle Diameter			0.000
Bh, Baffle Cut Height (in)			0.000
Ds, Shell Inside Diameter (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - tube side = 107 °F, 7400 gpm, shell side = 121 °F, 7200 gpm, 53 tubes plugged, FF = 0.00147

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,344.00
 Shell Flow (gpm) 7,122.00
 Tube Inlet Temp (°F) 107.00
 Shell Inlet Temp (°F) 121.00
 Input Fouling Factor 0.001470

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3,562,777.19
 Tube Mass Flow (lbm/hr) 3,673,832.59
 Heat Transferred (BTU/hr) 21,770,576.54
 LMTD 8.0
 Effective Area (ft²) 10,926.6





Overall Fouling (hr-ft²-°F/BTU) 0.001470
 Shell-Side ho (BTU/hr-ft²-°F) 965.4
 Tube-Side hi (BTU/hr-ft²-°F) 1,865.5
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.8965
 U Overall (BTU/hr-ft²-°F) 278.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.28	7.04
Reynold's Number	33,234	57,419
Prandtl Number	3.7131	4.0454
Bulk Visc (lbm/ft-hr)	1.3730	1.4845
Skin Visc (lbm/ft-hr)	1.4037	1.4643
Density (lbm/ft³)	61.7433	61.8605
Cp (BTU/lbm-°F)	0.9988	0.9988
K (BTU/hr-ft-°F)	0.3693	0.3665

Shell Temp In (°F) 121.0
 Shell Temp Out (°F) 114.9
 Tav Shell (°F) 117.9
 Shell Skin Temp (°F) 115.6
 Tube Temp In (°F) 107.0
 Tube Temp Out (°F) 112.9
 Tav Tube (°F) 110.0
 Tube Skin Temp (°F) 111.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet
 Page 1 of 1

Analysis No. 97-201 EC/ECR No. EC 352363 Title: Thermal Model of ComEd/LSCS RHR Heat Exchangers 1(2)RHR01A & B		Last Page No. 1 Revision A01 Revision 0
Station(s) LaSalle Unit No.: Units 1 and 2 Safety Class Safety Related System Code E12, RH	Is this Design Analysis Safeguards? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Does this Design Analysis Contain Unverified Assumptions? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ATI/AR#	
Description of Change This revision clarifies that the required heat removal capability of an RHR HX for the Containment Cooling Mode is now 163.1 MBtu/hr with an RHR service water inlet temperature of 104 deg. F, a maximum fouling factor of 0.00185 hr-ft ² -deg F/Btu, and a 5% tube plugging allowance (ref. Case 3 on page 7 of rev. A00 of this calculation). This heat removal value is to be used as the acceptance criteria in RHR HX thermal performance evaluations. Based on Calculation L-002826 rev. 0, SIL 636 Disposition for LaSalle County Station and New Decay Heat Table, and General Electric Power Uprate Project Task Report 310: Residual Heat Removal System, GE-NE-A1300384-12-01 rev. 0, no change to the Shutdown Cooling Condition (SDC) design heat load acceptance criteria of 41.6 Mbtu/hr is required.		
Disposition of Changes (include additional pages as required) EC 334017 (dated 5-16-02) evaluated the increased cooling water temperature to a new maximum temperature of 104 deg-F. The Design Considerations Summary states in part for the Post LOCA Suppression Pool Temperature Analysis: "Design Analysis No. L-002857, Rev. 0 has been completed to determine the RHR heat exchanger efficiency (expressed as a "K" factor in LaSalle's existing Containment Analysis...) with an increased inlet service water temperature of 104°F at various suppression pool temperatures. After the heat exchanger K factor had been determined, the impact on the LaSalle suppression pool temperature response following a LOCA was evaluated. As detailed within this design analysis, the post LOCA peak suppression pool temperature (193 deg-F) has not increased even with a higher inlet service water temperature of 104°F. The peak suppression pool temperature demonstrated within this design analysis is still well below the suppression pool temperature NPSH limit for the ECCS pumps of 212°F." The increased efficiency implies a higher heat load capability. Based on a review of L-002857: -the credited heat rejection capability is 163.1 MBtu/hr for the CCM case (Table 2 value for Q2). This is the value of Q used to get a 'K factor' of 417. Since we are crediting this heat load capability and this value is higher than 155 Mbtu/hr, this value should be used as the approved acceptance criteria.		
Preparer Dan Schmit _____ Print Name	 _____ Sign Name	11/11/04 _____ Date
Reviewer Terry Martin _____ Print Name	 _____ Sign Name	11/24/04 _____ Date
Method of Review <input checked="" type="checkbox"/> Detailed Review <input type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing		
Review Notes:		
Approver  _____ Print Name	 _____ Sign Name	11-30-04 _____ Date
(For External Analyses Only)		
Exelon Reviewer NA _____ Print Name	_____ Sign Name	_____ Date
Approver NA _____ Print Name	_____ Sign Name	_____ Date

CC-AA-309 - ATTACHMENT 1 - Design Analysis Approval

Page 1 of 2

DESIGN ANALYSIS NO.: Calc. # 97-201		PAGE NO. 1	
Major REV Number: A		Minor Rev Number: 00	
<input type="checkbox"/> BRAIDWOOD STATION <input type="checkbox"/> BYRON STATION <input type="checkbox"/> CLINTON STATION <input type="checkbox"/> DRESDEN STATION <input checked="" type="checkbox"/> LASALLE CO. STATION <input type="checkbox"/> QUAD CITIES STATION		DESCRIPTION CODE: (C018)	M010
Unit: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3		DISCIPLINE CODE: (C011)	M
		SYSTEM CODE: (C011)	E12, RH
TITLE: THERMAL MODEL OF COMED/LSCS RHR Heat Exchangers 1(2)RHR01A & B.			
<input checked="" type="checkbox"/> Safety Related		<input type="checkbox"/> Augmented Quality	
<input type="checkbox"/> Non-Safety Related			
ATTRIBUTES (C016)			
TYPE	VALUE	TYPE	VALUE
Elevation	710'		
Software	Proto-HX		
COMPONENT EPN: (C014 Panel)		DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)	
EPN	TYPE	Type/Sub	Document Number
			Input (Y/N)
1E12-B001A	H15	EC/DCP	EC# 334017
1E12-B001B	H15	/	
2E12-B001A	H15	/	
2E12-B001B	H15	/	
		/	
		/	
		/	
REMARKS: NA			

CALCULATION TABLE OF CONTENTS

CALCULATION NO. 97-201		REV. NO. A00	PAGE NO. 3
SECTION:	PAGE NO.	SUB-PAGE NO.	
DESIGN ANALYSIS APPROVAL / TITLE PAGE	1		
DESIGN ANALYSIS APPROVAL / REVISION SUMMARY	2		
TABLE OF CONTENTS	3		
1.0 PURPOSE / OBJECTIVE	4		
2.0 METHODOLOGY AND ACCEPTANCE CRITERIA	4		
3.0 ASSUMPTIONS / ENGINEERING JUDGEMENTS	4		
4.0 DESIGN INPUT	4		
5.0 REFERENCES	5		
6.0 CALCULATIONS	6		
7.0 SUMMARY AND CONCLUSIONS	8		
8.0 ATTACHMENTS:	8		
Attachment "A" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC (CSCS=104 F @ Design FF, 5% plugged)	A1 to A5		
Attachment "B" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC (CSCS=104 F @ 2X As-Tested FF)	B1 to B5		
Attachment "C" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC (CSCS=104 F @ 2X As-Tested FF, 5% plugged)	C1 to C5		
Attachment "D" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC (CSCS=104 F @ Max. Allowable FF, w\ 5% plugged)	D1 to D5		

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-201

REV. NO. A00

PAGE NO. 4 of 8

1.0 PURPOSE/OBJECTIVE

The purpose of this minor revision is to revise the thermal model of this heat exchanger for a 104°F Service Water inlet temperature. This assessment will evaluate the adequacy of the RHR Heat Exchangers at both Containment Cooling Mode (CCM) and Shutdown Cooling Conditions (SDC) during a maximum allowable inlet service water temperature of 104°F to ensure that adequate thermal margin still exists.

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp." to 104°F and simulated for the following conditions: (Case 1) design fouling factor with 5% of the tubes plugged, (Case 2) twice the 'as-tested' fouling factor and (Case 3) twice the 'as-tested' fouling factor with a 5% tube plugging allowance. The acceptance criteria will be for the thermal margin at Case 3 stated conditions to exceed the LaSalle Design Heat Load of 155,000,000 BTU/hr for Containment Cooling Mode (CCM) and 41,600,000 BTU/hr in Shutdown Cooling Condition (SDC) (Ref. 1, Tables 3-1 & 3-2). If desired, both RHR heat exchangers may be placed in service to provide the maximum cool down rate specified above during the Shutdown Cooling Condition.

Additional conservatism was built into this acceptance criteria by assuming a 5% uncertainty in the Proto-HX heat transfer calculations. The Reference 1 model developed for this heat exchanger demonstrated a correlation to vendor performance specification well within this assumed 5% margin.

A final case will be evaluated which determines the maximum acceptable fouling factor at which the design heat loads can be accommodated including heat transfer model uncertainty.

3.0 ASSUMPTIONS / ENGINEERING JUDGMENTS

The assumptions indicated in section 5.0 of Reference 1 are still valid.

Note: The shell side flow rate specified within reference 1 (8,400 gpm) has been changed to a more conservative number given within Tech. Spec. S.R. 3.5.1.5 as a minimum flow rate of 7,200 gpm. This flow rate was further reduced to account for volumetric flow rate correction required by Proto-Hx software limitations, refer to Table 1.

4.0 DESIGN INPUTS

The design inputs consist of References 1, 2 and 4 listed below.

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-201

REV. NO. A00

PAGE NO. 5 of 8

5.0 REFERENCES

1. Calculation No. 97-201, Rev. A, "Thermal Model of COMED/LSCS RHR Heat Exchangers 1(2)RHR01A & B".
2. NDIT LS-1154, Upgrade 0, "1B RHR Heat Exchanger Test on 10-25-99 Evaluation" and Calculation L-002571, Rev. 0, "1A RHR Heat Exchanger Test performed on 01/10/02".
3. EC# 331912, "Assessment of High Lake Temperature Upon the Functionality of the Plant"
4. Crane Co. Technical Paper No. 410 "Flow of Fluids", Twenty-Fifth Printing – 1991.
5. "Standards of the Tubular Exchanger Manufacturers Association" (TEMA), Seventh Edition, 1988.

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-201	REV. NO. A00	PAGE NO. 6 of 8
------------------------	--------------	-----------------

6.0 CALCULATIONS

The current calculation model is based on a Service Water inlet temperature of 90°F (SDC) and 100°F (CCM). At these temperatures, a design fouling factor of 0.0025 hr*ft²*°F/BTU and a 5% tube plugging allowance, the amount of heat transferred is 163,700,000 BTU/hr compared with a LaSalle Station Containment Cooling Design Heat Load of 155,000,000 BTU/hr for a 5.61% thermal margin. For Shutdown Cooling, the design case temperature, the same fouling factor and tube plugging results in a 41,310,000 BTU/hr heat transfer compared to a Shutdown Cooling Reference Load of 41,600,000 BTU/hr which appears to indicate no thermal margin available (Ref. 1, Tables 6-3 & 6-4).

Thermal margin is calculated by the following method:

$$\text{Required Heat Load} - \text{Calculated Heat Transfer} = \text{Thermal Margin} \quad [\text{Equation 1}]$$

To express this as a percent of the required heat load, the following method is used:

$$\frac{\text{Thermal Margin}}{\text{Required Heat Load}} \times 100\% = \% \text{Thermal Margin} \quad [\text{Equation 2}]$$

As detailed in reference 1 Proto-Hx inputs for fluid flow rates need to be adjusted using the ratio of the actual water density and the density of water at 60°F (assumed by Proto-Hx software). The following formula is used for this adjustment and the calculation inputs are tabulated with Table 1.

$$Q_{\text{phx}} = Q_{\text{temp}} * (\text{Density}_{\text{@temp}} / \text{Density}_{\text{@60 F}}) \quad [\text{Equation 3}]$$

Table 1: Reference Conditions, Proto-Hx Flow Rate Inputs

Parameter	Density (lb/ft ³) Ref. 4	Actual Flow (gpm)	Proto-Hx Input (gpm)
Tube Side, 104 F	61.93	7,400	7,348
Shell-side, 120 F	61.71	7,200	7,124
Shell-side, 212 F	59.81	7,200	6,905
Proto-Hx, 60 F	62.37		

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-201

REV. NO. A00

PAGE NO. 7 of 8

Case 1

When the service water inlet temperature is increased to 104°F for the same design fouling factor and 5% tube plugging allowance, the amount of heat transferred decreases to 150,800,000 BTU/hr, which appears to have no thermal margin at this elevated temperature and fouling condition for the Containment Cooling required heat load of 155,000,000 BTU/hr. With the RHR system operating in Shutdown Cooling conditions at 104°F service water inlet, design fouling factor, and 5% tube plugging allowance, 21,920,000 BTU/hr is transferred which is below the required heat removal of 41,600,000 BTU/hr and would necessitate the operation of the second RHR heat exchanger thereby providing an ample cooling capacity of 43,840,000 BTU/hr, resulting in a thermal margin of 5.4% (w/ 2 RHR Hx in service) [Attachment A].

Case 2

Regular cleaning and testing of these heat exchangers limits the amount of fouling well below the values assumed above. The heat exchanger performance data taken under the G.L. 89-13 program here at LaSalle demonstrates a maximum measured fouling factor of 0.00065 hr* ft^2 *°F/BTU (Ref. 2). For conservatism, this value was doubled to 0.0013 hr* ft^2 *°F/BTU and simulated with 104°F service water inlet temperature. The result was a heat transfer rate of 177,900,000 BTU/hr for a thermal margin of 14.8% [Attachment B]. Likewise for Shutdown Cooling condition at this fouling factor and service water condition the resulting heat transfer rate is 25,870,000 BTU/hr. This still necessitates the use of two heat exchangers to remove the design SDC heat load of 41,600,000 BTU/hr. However with two RHR heat exchangers in service the resulting thermal margin is 24.4% [Attachment B].

Case 3

With additional conservatism included by adding a plugging allowance of 53 tubes, 5% of the total, in the heat exchanger and running the model again at the above fouling factor and inlet temperature for a 174,800,000 BTU/hr heat transfer rate, a 12.8% thermal margin above the 155,000,000 BTU/hr Design Containment Cooling Heat Load. As with the previous cases, Shutdown Cooling would require two RHR heat exchangers at 0.0013 hr* ft^2 *°F/BTU, 104°F inlet temperature and 5% tube plugging allowance. However with 2 heat exchangers in service the resulting heat transfer rate is 50,780,000 BTU/hr (25,390,000 BTU/hr per Hx), resulting in a thermal margin of 22.1% [Attachment C].

The maximum fouling factor was found to be 0.00185 hr* ft^2 *°F/BTU while maintaining the required heat transfer rate at 104°F inlet temperature and with a 5% plugging allowance [Attachment D]. The resulting heat transfer of 163,100,000 BTU/hr for CCM and 47,380,000 BTU/hr for SDC (w/2 RHR Hx in service) accommodates the design heat loads of 155,000,000 BTU/hr for CCM and 41,600,000 BTU/hr for SDC including analytical model uncertainty.

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-201

REV. NO. A00

PAGE NO. 8 of 8

This is judged to be a reasonably conservative fouling factor even though it is slightly lower than the typical fouling factor stated in Ref. 5, page 215. The LaSalle lake water quality exceeds the "River Water Fouling Factor" (at a velocity greater than 3 ft/sec) given in this reference. The lake water passes through strainers and is chemically treated to control silt and scale prevention.

7.0 SUMMARY AND CONCLUSIONS

The RHR Heat Exchanger Model has been updated to reflect a maximum lake temperature of 104°F. The model found adequate thermal margin when operated for Containment Cooling Mode and would require two heat exchangers in operation to achieve the Design Heat Rate removal during Shutdown Cooling Mode. The maximum fouling factor was found to be 0.00185 $\text{hr} \cdot \text{ft}^2 \cdot \text{°F} / \text{BTU}$ while maintaining the required heat transfer rate at 104°F inlet temperature and with a 5% plugging allowance. This fouling factor has been determined to be an acceptable benchmark value that can be used in Generic Letter 89-13 testing evaluations of this model heat exchanger.

8.0 ATTACHMENTS:

- Attachment "A" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ Design FF, 5% plugged)
- Attachment "B" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ 2X As-Tested FF)
- Attachment "C" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ 2X As-Tested FF, 5% plugged)
- Attachment "D" – Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ Max. Allowable FF, w/ 5% plugged)

Final Page
(Last Page)

E-FORM

Attachment "A"

Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ Design FF, 5% plugged)

E-FORM

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM-5% PLUG, DESIGN FF @ 104 F

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010 ✓
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

CASE

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM-5% PLUG, DESIGN FF @ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

CAS61

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,348.0
Shell Flow (gpm)	Shell Flow (gpm)	6,905.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	212.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
Shell Temp Out (°F)
Tav Shell (°F)
Shell Skin Temp (°F)
Tube Temp In (°F)
Tube Temp Out (°F)
Tav Tube (°F)
Tube Skin Temp (°F)

Calculation No. 97-201
 Revision No. A00
 Attachment A
 Page No. A3 of A5

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.454E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,136.9
Heat Transferred (BTU/hr)	1.508E+8	Tube-Side hi (BTU/hr-ft ² -°F)	2,027.7
LMTD	65.7	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9268

U Overall (BTU/hr-ft²-°F) 226.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.26	7.07
Reynold's Number	5.677E+04	6.607E+04
Prandtl Number	2.02	3.47
Bulk Visc (lbm/ft-hr)	0.78	1.29
Skin Visc (lbm/ft-hr)	0.85	1.20
Density (lbm/ft ³)	60.34	61.64
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	212.0
Shell Temp Out (°F)	168.5
Tav Shell (°F)	190.2
Shell Skin Temp (°F)	177.1
Tube Temp In (°F)	104.0
Tube Temp Out (°F)	145.1
Tav Tube (°F)	124.5
Tube Skin Temp (°F)	133.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC-5% PLUG, DESIGN FF (104 F)

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

CAR 1

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC-5% PLUG, DESIGN FF (104 F)

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

CASE 1

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,348.0
Shell Flow (gpm)	Shell Flow (gpm)	7,124.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
Shell Temp Out (°F)
Tav Shell (°F)
Shell Skin Temp (°F)
Tube Temp In (°F)
Tube Temp Out (°F)
Tav Tube (°F)
Tube Skin Temp (°F)

Calculation No. 97-201
 Revision No. A00
 Attachment A
 Page No. AS of AS

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.564E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	962.4
Heat Transferred (BTU/hr)	2.192E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,836.6
LMTD	9.9	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9348
		U Overall (BTU/hr-ft ² -°F)	215.9
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.29	7.04	Shell Temp In (°F)
Reynold's Number	3.292E+04	5.574E+04	Shell Temp Out (°F)
Prandtl Number	3.75	4.18	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	1.39	1.53	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	1.42	1.51	Tube Temp In (°F)
Density (lbm/ft ³)	61.76	61.90	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)
K (BTU/hr-ft-°F)	0.37	0.37	Tube Skin Temp (°F)

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "B"

Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ 2X As-Tested FF)

E-FORM

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM-ALL TUBES 2X TEST FF @ 104 F

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 7,446.28	7,396.31
Inlet Temperature	°F 120.00	90.00
Outlet Temperature	°F 108.80	101.25
Fouling Factor	0.00250*	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		215.00
Empirical Factor for Outside h		0.563555000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		11,500.00
Area Factor		0.996344561
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		4.880000000
Shell Velocity (ft/s)		3.400
Tube Pitch (in)		1.0000
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		Yes
Total Number of Tubes		1,063
Number of Active Tubes		1,063
Tube Length (ft)		55.30
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		9.40
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Case 2

Calculation No. 97-201

Revision No. A00

Attachment BPage No. 02 of 05

* Fouling Factor input on next page.

lig

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM-ALL TUBES 2X TEST FF @ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 * Fouling Was Input by User

CASE 2

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,348.0
Shell Flow (gpm)	Shell Flow (gpm) 6,905.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 212.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	Input Fouling Factor 0.001300 *

Fouling Calculation Results

Shell Mass Flow (lbm/hr)		U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)		Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)		Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD		1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)		LMTD Correction Factor	
		Overall Fouling (hr-ft ² -°F/BTU)	
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)
			Calculation No. 97-201
			Revision No. A00
			Attachment <u>B</u>
			Page No. <u>63</u> of <u>85</u>

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.454E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001300
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,123.8
Heat Transferred (BTU/hr)	1.779E+8	Tube-Side hi (BTU/hr-ft ² -°F)	1,985.4
LMTD	58.1	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.8618
		U Overall (BTU/hr-ft ² -°F)	309.1
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)	3.25	6.73	Shell Temp In (°F) 212.0
Reynold's Number	5.533E+04	6.491E+04	Shell Temp Out (°F) 160.6
Prandtl Number	2.07	3.35	Tav Shell (°F) 186.3
Bulk Visc (lbm/ft-hr)	0.80	1.25	Shell Skin Temp (°F) 170.3
Skin Visc (lbm/ft-hr)	0.89	1.14	Tube Temp In (°F) 104.0
Density (lbm/ft ³)	60.43	61.58	Tube Temp Out (°F) 152.5
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 128.2
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 138.6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC-ALL TUBES, 2X TEST FF@104 F

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250X	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,063
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Case 2

* Fouling Factor input on next page.

Calculation No. 97-201

Revision No. A00

Attachment BPage No. B4 of B5

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC-ALL TUBES, 2X TEST FF@104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 * Fouling Was Input by User

Case 2

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,348.0
Shell Flow (gpm)	Shell Flow (gpm) 7,124.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 120.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	Input Fouling Factor 0.001300 <i>X</i>

Fouling Calculation Results

Shell Mass Flow (lbm/hr)		U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)		Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)		Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD		1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)		LMTD Correction Factor	
		Overall Fouling (hr-ft ² -°F/BTU)	
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)
			Calculation No. 97-201
			Revision No. A00
			Attachment <u>B</u>
			Page No. <u>85</u> of <u>85</u>

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.564E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001300
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	960.0
Heat Transferred (BTU/hr)	2.587E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,768.9
LMTD	8.8	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.8794
		U Overall (BTU/hr-ft ² -°F)	289.2
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)	3.28	6.69	Shell Temp In (°F) 120.0
Reynold's Number	3.274E+04	5.325E+04	Shell Temp Out (°F) 112.7
Prandtl Number	3.78	4.16	Tav Shell (°F) 116.4
Bulk Visc (lbm/ft-hr)	1.39	1.52	Shell Skin Temp (°F) 113.7
Skin Visc (lbm/ft-hr)	1.43	1.50	Tube Temp In (°F) 104.0
Density (lbm/ft ³)	61.77	61.90	Tube Temp Out (°F) 111.0
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 107.5
K (BTU/hr-ft-°F)	0.37	0.37	Tube Skin Temp (°F) 109.2

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "C"

Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ 2X As-Tested FF, 5% plugged)

E-FORM

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM-5% PLUG, 2X TEST FF @ 104 F

Shell and Tube Heat Exchanger Input Parameters			
--	--	--	--

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250 X	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

CASE 3

* Fouling Factor input on next page.

Calculation No. 97-201
Revision No. A00
Attachment
Page No. of

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM-5% PLUG, 2X TEST FF @ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions

* Fouling Was Input by User

CASE 3

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,348.0
Shell Flow (gpm)	Shell Flow (gpm)	6,905.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	212.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.001300 ✕

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Calculation No. 97-201
 Revision No. A00
 Attachment c
 Page No. 41 of 45

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.454E+6	Overall Fouling (hr-ft²-°F/BTU)	0.001300	
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft²-°F)	1,124.6	
Heat Transferred (BTU/hr)	1.748E+8	Tube-Side hi (BTU/hr-ft²-°F)	2,063.8	
LMTD	59.0	1/Wall Resis (BTU/hr-ft²-°F)	2,148.1	
Effective Area (ft²)	10,926.6	LMTD Correction Factor	0.8717	
		U Overall (BTU/hr-ft²-°F)	311.3	
Property	Shell-Side	Tube-Side		
Velocity (ft/s)	3.25	7.08	Shell Temp In (°F)	212.0
Reynold's Number	5.549E+04	6.806E+04	Shell Temp Out (°F)	161.5
Prandtl Number	2.07	3.36	Tav Shell (°F)	186.8
Bulk Visc (lbm/ft-hr)	0.80	1.25	Shell Skin Temp (°F)	170.4
Skin Visc (lbm/ft-hr)	0.89	1.15	Tube Temp In (°F)	104.0
Density (lbm/ft³)	60.42	61.59	Tube Temp Out (°F)	151.6
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)	127.8
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F)	138.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC-5% PLUG, 2X TEST FF@ 104 F

Shell and Tube Heat Exchanger Input Parameters			
--	--	--	--

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250 X	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Case 3

* Fouling Factor input on next page.

Calculation No. 97-201

Revision No. A00

Attachment cPage No. 44 of 45

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC-5% PLUG, 2X TEST FF@ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 * Fouling Was Input by User

CASE 3

Test Data	Extrapolation Data	
Data Date	Tube Flow (gpm)	7,348.0
Shell Flow (gpm)	Shell Flow (gpm)	7,124.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.001300*

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)
			Calculation No. 97-201
			Revision No. A00
			Attachment <u>c</u>
			Page No. <u>c5</u> of <u>C5</u>

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.564E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001300
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	960.2
Heat Transferred (BTU/hr)	2.539E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,842.0
LMTD	9.0	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.8882
		U Overall (BTU/hr-ft ² -°F)	291.4
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)	3.28	7.04	Shell Temp In (°F)
Reynold's Number	3.277E+04	5.601E+04	Shell Temp Out (°F)
Prandtl Number	3.77	4.16	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	1.39	1.52	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	1.43	1.50	Tube Temp In (°F)
Density (lbm/ft ³)	61.77	61.90	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)
K (BTU/hr-ft-°F)	0.37	0.37	Tube Skin Temp (°F)

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "D"

Proto-Hx Calc. Report for RHR Hx during CCM & SDC
(CSCS=104 F @ Max. Allowable FF, w\ 5% plugged)

E-FORM

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM-MAX FF, w\5% PLUG, @ 104 F

Shell and Tube Heat Exchanger Input Parameters			
--	--	--	--

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250 y	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010 } 5% PLUGGED
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

* Fouling Factor input on next page.

Calculation No. 97-201
Revision No. A00
Attachment 0
Page No. 02 of 05

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM-MAX FF, w\5% PLUG, @ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 ✱ Fouling Was Input by User

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,348.0
Shell Flow (gpm)	Shell Flow (gpm) 6,905.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 212.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	Input Fouling Factor 0.001850✱

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
	Overall Fouling (hr-ft ² -°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)	Calculation No. 97-201 Revision No. A00 Attachment <u>D</u> Page No. <u>13</u> of <u>05</u>
Shell Temp Out (°F)	
Tav Shell (°F)	
Shell Skin Temp (°F)	
Tube Temp In (°F)	
Tube Temp Out (°F)	
Tav Tube (°F)	
Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.454E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001850
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,130.7
Heat Transferred (BTU/hr)	1.631E+8	Tube-Side hi (BTU/hr-ft ² -°F)	2,046.1
LMTD	62.2	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9024
		U Overall (BTU/hr-ft ² -°F)	265.8
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.26	7.08	Shell Temp In (°F) 212.0
Reynold's Number	5.611E+04	6.709E+04	Shell Temp Out (°F) 164.9
Prandtl Number	2.04	3.41	Tav Shell (°F) 188.5
Bulk Visc (lbm/ft-hr)	0.79	1.27	Shell Skin Temp (°F) 173.8
Skin Visc (lbm/ft-hr)	0.87	1.17	Tube Temp In (°F) 104.0
Density (lbm/ft ³)	60.39	61.61	Tube Temp Out (°F) 148.4
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 126.2
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 135.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC-MAX FF,w\5% PLUG @ 104 F

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250*	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Emprical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010 } 5% PLUGGED
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

* Fouling Factor input on next page.

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC-MAX FF,w5% PLUG @ 104 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 * Fouling Was Input by User

Test Data	Extrapolation Data	
Data Date	Tube Flow (gpm)	7,348.0
Shell Flow (gpm)	Shell Flow (gpm)	7,124.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.001850 <i>X</i>

Fouling Calculation Results

Shell Mass Flow (lbm/hr)		U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)		Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)		Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD		1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)		LMTD Correction Factor	
		Overall Fouling (hr-ft ² -°F/BTU)	
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Calculation No. 97-201
 Revision No. A00
 Attachment D
 Page No. 05 of 05

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.564E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001850
Tube Mass Flow (lbm/hr)	3.676E+6	Shell-Side ho (BTU/hr-ft ² -°F)	961.3
Heat Transferred (BTU/hr)	2.369E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,839.3
LMTD	9.4	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9140
		U Overall (BTU/hr-ft ² -°F)	251.2
<u>Property</u>	<u>Shell-Side</u>	<u>Tube-Side</u>	
Velocity (ft/s)	3.28	7.04	Shell Temp In (°F)
Reynold's Number	3.284E+04	5.588E+04	Shell Temp Out (°F)
Prandtl Number	3.76	4.17	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	1.39	1.53	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	1.42	1.50	Tube Temp In (°F)
Density (lbm/ft ³)	61.76	61.90	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)
K (BTU/hr-ft-°F)	0.37	0.37	Tube Skin Temp (°F)

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

**PROTO-POWER CORPORATION
CALCULATION TITLE SHEET**

CLIENT: Commonwealth Edison / LaSalle County Station

PROJECT: COMED / LSCS GL 89-13 Program

CALCULATION TITLE: Thermal Model of COMED / LSCS RHR Heat Exchangers
1(2)RHR01A & B.

CALCULATION NO.: 97-201

FILE NO.: 31-003

COMPUTER CODE & VERSION (if applicable): PROTO-HX™ Version 3.02

REV	TOTAL NO. OF PAGES	ORIGINATOR/DATE	VERIFIER/DATE	APPROVAL/DATE
A	57	<i>D. Phyfe</i> 7/16/98 D. Phyfe	<i>S. Ingalls</i> 7/16/98 S. Ingalls	<i>L. Philpot</i> 7/17/98 L. Philpot

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE ii OF v
	ORIGINATOR D. Phyfe		DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station		PROJECT COMED / LSCS GL 89-13 Program	
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Revision History

Revision	Revision Description
A	Original Issue

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE <u>iii</u> OF <u>v</u>
	ORIGINATOR D. Phyfe	DATE 7/16/98	
	VERIFIED BY S. Ingalls	JOB NO. 31-003	
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

CALCULATION VERIFICATION FORM

REVIEW METHOD:

- | | | | |
|--|-------------------------------------|-----|-------------------------------------|
| Approach Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Logic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Arithmetic Checked: | <input checked="" type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Alternate Method
(Attach Brief Summary) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Computer Program Used
(Attach Listing) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Other | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |

EXTENT OF VERIFICATION:

- | | |
|-------------------------|-------------------------------------|
| Complete Calculation: | <input checked="" type="checkbox"/> |
| Revised areas only: | <input type="checkbox"/> |
| Other (describe below): | <input type="checkbox"/> |

***Errors Detected**

Minor editorial

***Error Resolution**

editorial + minor numerical changes incorporated.

***Other Comments**

- None -

***Extra References Used**

N/A

*(Attach extra sheets if needed)

CALCULATION FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT AND REASONABLE:

IDV Signature: Scott M. Ingalls
 Printed Name: Scott M. Ingalls

Initials: SMI
 Date: 7/16/98

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE iv OF v
	ORIGINATOR D. Phyfe		DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

TABLE OF CONTENTS

CALC TITLE SHEET i
REVISION HISTORY ii
CALC VERIFICATION SHEET iii
TABLE OF CONTENTS iv
LIST OF ATTACHMENTS v

Total number of pages in Preface of Calc 5

1.0 PURPOSE 1
2.0 BACKGROUND 1
3.0 DESIGN INPUTS 1
 3.1. LASALLE STATION REFERENCE CONDITION 2
 3.2. CONSTRUCTION DETAILS 2
 3.3. PERFORMANCE DETAILS 3
 3.4. VENDOR DESIGN FOULING FACTOR 5
4.0 APPROACH 6
 4.1. PROTO-HX™ PARAMETER CALCULATION 6
 4.2. PROTO-HX™ EXTRAPOLATION METHOD 7
 4.3. PROTO-HX FLOW RATE INPUTS 7
5.0 ASSUMPTIONS 8
6.0 ANALYSIS 9
 6.1. PROTO-HX™ MODEL 9
 6.2. FOULING SENSITIVITY 9
 6.3. THERMAL PERFORMANCE MARGIN 10
7.0 CONCLUSION 11
 7.1. PROTO-HX™ MODEL 11
 7.2. FOULING SENSITIVITY 12
 7.3. THERMAL PERFORMANCE MARGIN 12
8.0 REFERENCES 12

Total number of pages in Body of Calc 12

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE v OF v
	ORIGINATOR D. Phyfe	DATE 7/16/98	
	VERIFIED BY S. Ingalls	JOB NO. 31-003	
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

LIST OF ATTACHMENTS

<u>Attachment</u>	<u>Subject Matter</u>	<u>Total Pages</u>
A	Proto-Power Calc. 97-201, Rev. A; Vendor Data Sheet & Drawings	5
B	Proto-Power Calc. 97-201, Rev. A; RHR Process Flow Diagram, 731E966AA Sheets 1 & 3	3
C	Proto-Power Calc. 97-201, Rev. A; PROTO-HX™ Calculation Reports and Model Data Sheets	9
D	Proto-Power Calc. 97-201, Rev. A; PROTO-HX Calculation Reports for the Fouling Sensitivity	11
E	Proto-Power Calc. 97-201, Rev. A; PROTO-HX Calculation Reports for the Margin Analysis	10
F	Proto-Power Calc. 97-201, Rev. A; PROTO-HX Model of the LaSalle Station RHR Hx.	2

Number of Attachment Pages: 40

Total number of pages: 57

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 1 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

1.0 PURPOSE

The purpose of this calculation is to develop a thermal performance analysis model for the Commonwealth Edison (ComEd) LaSalle Station, Residual Heat Removal Heat Exchanger. This model is to be used for the analysis of heat exchanger thermal performance test data as part of the LaSalle Station heat exchanger testing program.

Once developed, the model is used to evaluate the thermal margin of the heat exchanger at the LaSalle Station Reference Conditions as currently defined in the LaSalle design and licensing basis.

The thermal performance model documented in this calculation has been created and used with PROTO-HX, Version 3.02. The model can be used with previous versions of PROTO-HX and produce identical results as long as the following restrictions are upheld:

- Versions prior to version 3.02 will not calculate a negative fouling factor when calculating the fouling factor based on test data.
- Shell and tube heat exchangers analyzed in Version 3.0 or earlier must have a tube-side Reynolds Number greater than 10,000 (i.e., fully developed turbulent flow).

Current limitations of use for PROTO-HX are established by the limits on fluid properties included within the software. Fluid properties contained within PROTO-HX are currently limited to the following temperature ranges:

- Water (fresh and salt): 32-500°F

2.0 BACKGROUND

LaSalle County Station is in the process of implementing a heat exchanger thermal performance monitoring program in response to the requirements of NRC Generic Letter 89-13 (Reference 8.2). Development of an analytical model in PROTO-HX™, Version 3.02, will allow timely analysis of data resulting from the test program.

3.0 DESIGN INPUTS

The PROTO-HX™ program was developed and validated in accordance with Proto-Power's Nuclear Software Quality Assurance Program (SQAP). This program meets the requirements of 10CFR50 Appendix B, 10CFR21, and ANSI NQA-1, and was developed in accordance with the guidelines and standards contained in ANSI/IEEE Standard 730/1984 and ANSI NQA-2b-1991. PROTO-HX™ Version 3.02 was verified and approved for use as documented in Reference 8.11.

The design inputs for this calculation consist of the heat exchanger LaSalle Station Reference Condition (Section 3.1), Construction Details (Section 3.2), Performance Details (Section 3.3) provided by the Hx vendor data sheets or design documents as referenced. Construction details give the necessary information for model construction while performance specifications provided

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 2 OF 12
	ORIGINATOR D. Phye		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

by the vendor are used to benchmark the models. Section 3.4 discusses the design overall fouling factor used on the vendor data sheets.

3.1. LASALLE STATION REFERENCE CONDITION

Table 3-1 describes the performance requirement of the RHR heat exchanger during Containment Cooling mode of operation.

Table 3-1 Reference Condition - Containment Cooling Mode

Parameter	Value	Reference
Heat Rate (BTU/hr)	155,000,000	8.1
Shell-Side Flow Rate (gpm)	8400	8.1
Shell-Side Inlet Temperature (°F)	212	8.1
Tube-Side Flow Rate (gpm)	7400	8.1
Tube-Side Inlet Temperature (°F)	100	8.1

Table 3-2 describes the performance requirement of the RHR heat exchanger during Shutdown Cooling mode of operation.

Table 3-2 Reference Condition - Shutdown Cooling Mode

Parameter	Value	Reference
Heat Rate (BTU/hr)	41,600,000	8.1
Shell-Side Flow Rate (gpm)	7450	8.1
Shell-Side Inlet Temperature (°F)	120	8.1
Tube-Side Flow Rate (gpm)	7400	8.1
Tube-Side Inlet Temperature (°F)	90	8.1

3.2. CONSTRUCTION DETAILS

The majority of the construction details stay consistent between both the shutdown cooling and containment cooling modes of operation. The values that are specific to a mode of operation or number of available tubes in Table 3-3 are based on the shutdown cooling mode with all tubes available.

Table 3-3 Construction Detail

Parameter	Value	Reference
Heat Exchanger Type	TEMA E / Vertical - AEU	8.6
Total Effective Area per unit (ft ²)	11,500	8.6
Number of Shells per unit	1	8.6
Tube Passes per shell	2	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 3 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Table 3-3 Construction Detail

Parameter	Value	Reference
U-Tubes (yes or no)	Yes	8.6
Total Number of Tubes	1063	8.6
Tube Length (ft)	55.3	8.6, See below
Tube Inside Diameter (in)	0.652 (18 BWG)	8.6
Tube Outside Diameter (in)	3/4	8.6
Tube Wall Conductivity (BTU/hr-ft-°F)	9.40 (A-249 TP 304L SS)	8.9 (8.6)
Tube Pitch (in)	1	8.6
Pitch Type	Triangle	8.6
Tube Circle Diameter (in)	51.25	8.3

The length of a U-Tube in PROTO-HX™ is twice the straight length of tube plus 30% of the shell diameter (Equation 1). This value is then entered into the PROTO-HX™ data sheet. Based on Reference 8.6 the RHR U-Tube length:

$$U - Tube = 2 \cdot L_{Tube} + 30\% \cdot ID_{Shell} \quad \text{Equation 1}$$

$$L_{Tube} = 50\% \cdot 26.5ft + 25\% \cdot 27ft + 25\% \cdot 28ft = 27ft$$

$$U - Tube = 2 \cdot 27ft + 0.30 \cdot 51.25 \text{ in} \cdot \frac{1ft}{12in} = 55.3 \text{ ft}$$

3.3. PERFORMANCE DETAILS

Table 3-4 shows the performance parameters for the RHR heat exchanger in Containment Cooling mode; whereas, Table 3-5 shows the performance parameters for the RHR heat exchanger in Shutdown Cooling mode. The Shutdown Cooling mode (5% plugged, 53 tubes plugged) performance data was used to create the PROTO-HX™ model.

Table 3-4 Containment Cooling Performance Detail

Parameter	Value	Reference
Shell Side Fluid Type	Demineralized Water (Fresh)	8.6
Shell Side Fouling Factor (Design)	0.0005	8.6
Shell Side Fluid Flow Rate (gpm)	8,400 (4,200,000 lb/hr)	8.6
Shell Side Inlet Temperature (°F)	212.0	8.6
Shell Side Outlet Temperature (°F)	All Tubes: 171.6 5% Plugged: 172	8.6
Tube Side Fluid Type	Service Water (Fresh)	8.6
Tube Side Fouling Factor (Design)	0.002	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 4 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Table 3-4 Containment Cooling Performance Detail

Parameter	Value	Reference
Tube Side Fluid Flow Rate (gpm)	7,400 (3,700,000 lb/hr)	8.6
Tube Side Inlet Temperature (°F)	100	8.6
Tube Side Outlet Temperature (°F)	All Tubes: 145.9 5% Plugged: 145.3	8.6
Design Q - Service (BTU/hr)	All Tubes: 170,000,000 5% Plugged: 168,000,000	8.6
Design U - Clean (BTU/hr-ft ² -°F)	All Tubes: 563 5% Plugged: 568	8.6
Design U - Service (BTU/hr-ft ² -°F)	All Tubes: 231 5% Plugged: 235	8.6
Shell Velocity (ft/sec)	3.82	8.6
Number of Plugged Tubes	All Tubes: 0 5% Plugged: 53	8.6

Table 3-5 Shutdown Cooling Performance Detail

Parameter	Value	Reference
Shell Side Fluid Type	Reactor Water (Fresh)	8.6
Shell Side Fouling Factor (Design)	0.0005	8.6
Shell Side Fluid Flow Rate (gpm)	7,450 (3,725,000 lb/hr)	8.6
Shell Side Inlet Temperature (°F)	120.0	8.6
Shell Side Outlet Temperature (°F)	All Tubes: 108.6 5% Plugged: 108.8	8.6
Tube Side Fluid Type	Service Water (Fresh)	8.6
Tube Side Fouling Factor (Design)	0.002	8.6
Tube Side Fluid Flow Rate (gpm)	7,400 (3700,000 lb/hr)	8.6
Tube Side Inlet Temperature (°F)	90	8.6
Tube Side Outlet Temperature (°F)	All Tubes: 101.5 5% Plugged: 101.25	8.6
Design Q - Service (BTU/hr)	All Tubes: 42,550,000 5% Plugged: 41,600,000	8.6
Design U - Clean (BTU/hr-ft ² -°F)	All Tubes: 463 5% Plugged: 466	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 5 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Table 3-5 Shutdown Cooling Performance Detail

Parameter	Value	Reference
Design U - Service (BTU/hr-ft ² -°F)	All Tubes: 213 5% Plugged: 215	8.6
Shell Velocity (ft/sec)	3.4	8.6
Number of Plugged Tubes	All Tubes: 0 5% Plugged: 53	8.6

3.4. VENDOR DESIGN FOULING FACTOR

The PROTO-HX convention for calculating overall fouling factors is to combine the shell-side and tube-side fouling factor using the outside heat transfer surface as the reference area. Equations 2 and 3 show the PROTO-HX method of combining the shell-side and tube-side fouling factors.

$$\text{Area Ratio} = \frac{\text{Tube OD}}{\text{Tube ID}} \quad \text{Equation 2}$$

$$f_{\text{total}} = f_{\text{shell}} + (\text{Area Ratio}) \cdot f_{\text{tube}} \quad \text{Equation 3}$$

Table 3-6 shows the results of combining the shell-side and tube-side fouling factors using the area ratio.

Table 3-6 PROTO-HX Design Fouling

Tube ID, in:	0.750
Tube OD, in:	0.652
Area Ratio (OD/ID)	1.150
Tube-side FF	0.002
Shell-side FF	0.0005
Overall FF (Area Ratio)	0.0028006

However, according to the vendor data sheets (Reference 8.6), the design overall fouling factor used by the vendor in the performance analysis presented on the data sheets appears to be approximately 0.0025 verse the 0.0028 calculated in Table 3-6. The fouling factor is calculated from the vendor data sheets by comparing the difference between the service and the clean overall heat transfer coefficients.

$$U = \frac{1}{r(h_i) + r_{\text{tube-side FF}} + r_{\text{wall}} + r_{\text{shell-side FF}} + r(rh_o)} \quad \text{Equation 4}$$

Reference 8.5 discusses that the fouling factor may be calculated directly from the difference between the service and clean overall heat transfer coefficients only when all other parameters remain constant (flow and temperature). Likewise, the total fouling

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 6 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98 .
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

factor may be calculated as the sum of the shell-side and tube-side fouling factors (Equation 5).

$$f_{\text{total}} = f_{\text{tube-side}} + f_{\text{shell-side}} \quad \text{Equation 5}$$

Table 3-7 shows that the difference between the service and clean overall heat transfer coefficients is approximately 0.0025. The variations in the fouling factor can be attributed to the round-off error as reported on the vendor data sheets.

Table 3-7 Vendor Data Sheet Fouling Factor

Vendor Data Sheet	U-Service	U-Clean	Fouling (U)
All Tubes - SDC	213	463	0.0025350
5% PLG - SDC	215	466	0.0025052
All Tubes - CCM	231	563	0.0025528
5% PLG - CCM	235	568	0.0024948
		Overall FF=	0.0025

Therefore, the PROTO-HX benchmarking of the RHR model will be performed with an overall fouling factor of 0.0025 versus the standard PROTO-HX method of referencing the fouling resistances to the outside heat transfer area. For PROTO-HX to use the 0.0025 value for fouling it will be entered into the heat exchanger data sheet as a shell-side fouling factor and zero will be entered as the tube-side fouling factor.

The direct addition of the shell-side and tube-side fouling factors will yield a more conservative model than the standard PROTO-HX method of combining the fouling factors. This is because the Hoff calculated at data sheet conditions with a lower overall fouling factor is lower than that calculated with the higher value of overall fouling factor.

4.0 APPROACH

This calculation utilizes plant/vendor fabrication specifications provided in Attachment (A) to develop a thermal performance prediction model for the LSCS RHR Hx. The calculation then benchmarks the models by comparing the heat transfer rate calculated by PROTO-HX™ Version 3.02 with the vendor's specifications for thermal performance under different cooling modes.

4.1. PROTO-HX™ PARAMETER CALCULATION

Minimum Shell Area

The minimum shell area is calculated using either the shell side velocity or shell geometry. The preferred method of calculation is using the shell side velocity. Reference 8.6 gives the shell side velocity to be 3.4 ft/sec at a flow rate of 7396.31 gpm (Section 4.3). Based on this velocity and flow rate the minimum shell side area is 4.880 ft².

Outside H Factor (Hoff)

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 7 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98 .
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

The Outside H Factor is a multiplier, with value less than 1.0, used to reduce the ideal shell side film heat transfer coefficient. The Outside H Factor accounts for inefficiency in the heat exchanger. Using the back calculation method, based on the design overall heat transfer coefficient (215 Btu/hr ft² °F), the Outside H Factor was calculated by PROTO-HX™ to be 0.56355.

4.2. PROTO-HX™ EXTRAPOLATION METHOD

All calculations performed for this calculation are based on a constant cold inlet temperature (except where noted). This allows the comparison of the heat transfer, outlet temperatures, log mean temperature difference (LMTD), and heat transfer coefficient. There is no comparison of the heat transfer coefficient in the design case since PROTO-HX™ used the data sheet value of the heat transfer coefficient to calculate the outside heat transfer coefficient.

4.3. PROTO-HX FLOW RATE INPUTS

The vendor data sheets have the actual heat exchanger mass flow rates listed on them. The mass flow must be converted to a volumetric flow rate at 60°F for entry into PROTO-HX.

$$Q_{PHX} = \frac{7.48 \cdot \dot{m}}{60 \cdot \rho_{60°F}} \quad \text{Equation 6}$$

Table 4-1 Vendor Data Sheet: PROTO-HX Flow Rate Inputs

Parameter	Actual Flow (lb/hr)	PROTO-HX Input (gpm)
Tube-side, 90°F	3,700,000	7396.31
Tube-side, 100°F	3,700,000	7396.31
Shell-side, 120°F	3,725,000	7446.28
Shell-side, 212°F	4,200,000	8395.81
Density, 60°F	62.364 lb/ft ³ (8.12)	

Volumetric flow rates are converted to mass flow rates based on a set temperature of 60°F in PROTO-HX. Therefore, the actual PROTO-HX inputs have to be adjusted to give the correct mass flow rate. The PROTO-HX input is adjusted using the ratio of the actual water density and the density of water at 60°F.

$$Q_{phx} = Q_{temp} \cdot \frac{\rho_{temp}}{\rho_{60°F}} \quad \text{Equation 7}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 8 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98.
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Table 4-2 Reference Condition: PROTO-HX Flow Rate Inputs

Parameter	Density (lb/ft ³)	Actual Flow (gpm)	PROTO-HX Input (gpm)
Tube-side, 90°F	62.113 (8.12)	7400	7370.22
Tube-side, 100°F	61.994 (8.12)	7400	7356.08
Shell-side, 120°F	61.712 (8.12)	7450	7372.02
Shell-side, 212°F	59.823 (8.12)	8400	8057.65
PROTO-HX, 60°F	62.364 (8.12)		

5.0 ASSUMPTIONS

- 5.1. For the containment cooling mode of operation with a 212°F shell side inlet temperature all fluid entering the shell is considered to be in the liquid phase. This is consistent with the vendor's analysis of the heat exchanger in Reference 8.6. Therefore, future validation of this assumption is not required.
- 5.2. The vendor data sheet (Reference 8.6) is considered an accurate reflection of the vendor's expectation for the heat exchanger's outside film heat transfer coefficient. Therefore, the benchmarking of the PROTO-HX model to the vendor data sheet will ensure that the PROTO-HX calculated outside film heat transfer coefficient is consistent with the vendor's expectation. Future validation of this assumption is not required.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 9 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

6.0 ANALYSIS

6.1. PROTO-HX™ MODEL

Table 6-1 compares the PROTO-HX™ (P-HX) values to the values shown on the Vendor Data Sheets (V - DS). PROTO-HX output reports can be found in Attachment C.

Table 6-1 PROTO-HX Model Results

Parameter	CONTAINMENT COOLING MODE				SHUTDOWN COOLING MODE			
	ALL TUBES		5% PLUGGED		ALL TUBES		5% PLUGGED	
	P-HX	V - DS	P-HX	V - DS	P-HX	V - DS	P-HX	V - DS
Shell Side Outlet Temp, °F	171.7	171.6	172.7	172	108.6	108.6	108.9	108.8
Tube Side Outlet Temp, °F	146.0	145.9	144.9	145.3	101.5	101.5	101.2	101.25
Heat Transferred, BTU/hr	1.7 E8	1.70 E8	1.658E8	1.68 E8	4.251E7	4.255E7	4.147E7	4.16E7
Heat Transfer Coef, BTU/hr ft ² °F	230.7	231	231.9	235	213.7	213	215	215
Corrected LMTD	64.0	64.1	65.5	65	17.26	17.35	17.6	17.6

Table 6-2 shows the correlation between the manufacture data sheets and the PROTO-HX™ model. PROTO-HX output reports can be found in Attachment C.

Table 6-2 PROTO-HX Model Correlation

Parameter	CONTAINMENT COOLING MODE		SHUTDOWN COOLING MODE	
	ALL TUBES (%)	53 PLUGS (%)	ALL TUBES (%)	53 PLUGS (%)
Shell Side Outlet Temp	0.06	0.41	0.00	0.09
Tube Side Outlet Temp	0.07	-0.27	0.00	-0.05
Heat Transferred	0.00	-1.31	-0.09	-0.31
Heat Transfer Coef	-0.13	-1.32	0.33	N/A
Corrected LMTD	-0.16	0.77	-0.52	0.00


6.2. FOULING SENSITIVITY

The fouling sensitivity of the jacket water cooler is shown in Figure 6-1. The fouling sensitivity was developed at both sets of Reference Conditions (Table 3-1 and Table 3-2).

The tube-side fouling factor was varied from 0.0000 until the required heat load was met by increments of 0.0005 (hr ft² °F/Btu). The shell-side fouling factor is held constant at the design value of 0.0005 (hr ft² °F/Btu). The fouling factors overall fouling factors were entered in PROTO-HX based on the combining of the tube-side and shell-side fouling factors as described in the Heat Exchanger Design Handbook (Reference 8.5). The PROTO-HX Calculation Reports for the fouling sensitivity can be found in Attachment D.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 10 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Figure 6-1 Fouling Sensitivity



6.3. THERMAL PERFORMANCE MARGIN

The clean thermal margin is assessed by a comparison of the reference condition performance requirements to the heat exchanger performance capability with a zero (0) fouling factor. Using a zero (0) fouling factor shows the maximum available performance of the heat exchanger. Likewise, the service thermal margin is assessed by comparing the reference condition performance requirements to the heat exchanger performance capability with the design fouling factor.

The margin is calculated directly and as a percentage compared to the required heat rate to perform the component's safety function. The PROTO-HX reports can be found in Attachment E.

$$\text{Margin} = (\text{Heat Rate}) - (\text{Heat Rate})_{\text{required}} \tag{Equation 8}$$

$$\% \text{ Margin} = 100 \cdot \frac{\text{Margin}}{(\text{Heat Rate})_{\text{required}}} \tag{Equation 9}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 11 OF 12
	ORIGINATOR D. Phyfe		/DATE 7/16/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

Table 6-3 Thermal Margin – Containment Cooling Mode

Parameter	Service (Design Fouling)		Clean (0 Fouling)	
	All Tubes	53 Plugs	All Tubes	53 Plugs
Heat Transfer Rate	167,700,000	163,700,000	230,700,000	228,700,000
Required Heat Transfer Rate	155,000,000	155,000,000	155,000,000	155,000,000
Thermal Margin	12,700,000	8,700,000	75,700,000	73,700,000
% Thermal Margin	8.19%	5.61%	48.84%	47.55%

Table 6-4 Thermal Margin – Shutdown Cooling Mode

Parameter	Service (Design Fouling)		Clean (0 Fouling)	
	All Tubes	53 Plugs	All Tubes	53 Plugs
Heat Transfer Rate	42,330,000	41,310,000	57,440,000	56,840,000
Required Heat Transfer Rate	41,600,000	41,600,000	41,600,000	41,600,000
Thermal Margin	730,000	-290,000	15,840,000	15,240,000
% Thermal Margin	1.75%	-0.70%	38.08%	36.63%

Table 6-5 Adjusted Tube Plugging for Shutdown Cooling

Parameter	Shutdown Cooling – 38 Plugs
Heat Transfer Rate	41,600,000
Required Heat Transfer Rate	41,600,000
Thermal Margin	0
% Thermal Margin	0.00%

7.0 CONCLUSION

7.1. PROTO-HX™ MODEL

The RHR Hx Model was developed using PROTO-HX™, Version 3.02. The model was benchmarked and validated using the vendor supplied performance data sheets (Containment Cooling and Shutdown Cooling) for the heat exchangers. Model correlation to the vendor's performance specification for Shutdown Cooling Mode with 53 Plugs was within one percent (-0.31 %). The model correlation with other modes of operation can be found in Table 6-2.

This model should be considered suitable for use in the analysis of thermal performance test data.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-201	REV A	PAGE 12 OF 12
	ORIGINATOR D. Phyfe	/DATE 7/16/98	
	VERIFIED BY S. Ingalls	JOB NO. 31-003	
CLIENT COMED / LaSalle County Station	PROJECT COMED / LSCS GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station RHR Heat Exchangers 1(2)RHR01A & B.			

7.2. FOULING SENSITIVITY

Given a constant shell-side fouling at the model design value, the sensitivity of the RHR heat exchanger to tube-side fouling effects is shown on Figure 6-1.

7.3. THERMAL PERFORMANCE MARGIN

The available clean thermal margin of the RHR heat exchanger with no tubes plugged in Containment Cooling Mode of operation is 48.84% margin as compared to the Shutdown Cooling Mode of operation margin of 38.08%.

Table 6-3 through Table 6-5 show the thermal margin for the RHR heat exchanger in both the Containment Cooling and Shutdown Cooling modes in service and clean conditions at various tube plugging levels.

For the Shutdown Cooling mode with tubes plugged, the maximum allowable plugs allowed to still meet the required heat load with design fouling is 38 plugs.

8.0 REFERENCES

- 8.1. Process Flow Diagram, Residual Heat Removal System, 731E966AA Sheets 1 & 3 (Attachment B)
- 8.2. NRC Generic Letter 89-13
- 8.3. Struthers Wells Drawing 1-71-04-30971 D2, Revision 1, "2-Pass Tube Layout for 52" I.D. Residual Heat Removal Hx. 52-27U12-6V"
- ~~8.4. Calculation Acceptance Letter by COMED, Dated 2/6/98 (Attachment D)~~ *8/17/98*
- 8.5. Heat Exchanger Design Handbook, Volume 3, Thermal and Hydraulic Design of Heat Exchangers, Hemisphere Publishing Corp., Rev. 1989
- 8.6. Struther Wells Hx Data Sheet (Attachment A)
- 8.7. LSCS Drawing, VPF 3161-4-6, J-2500
- 8.8. LSCS Drawing, VPF 3161-8-2, J-2500
- 8.9. PROTO-HX™ User Manual
- 8.10. LSCS Drawing, T-2792, J-2500
- 8.11. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.02 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision F, dated 2/17/98
- 8.12. Proto-Power Calculation 93-048, "Fluid Properties – Fresh Water – Range 32°F to 500°F", Rev. A

**Attachment A to
Proto-Power Calculation
97-201
Revision A**

18011.6

STRUTHERS WELLS CORPORATION

Heat Exchanger Specification Sheet



ALL TUBES AVAILABLE - SHUTDOWN OPERATING MODE

1		JOB NO.
2	CUSTOMER GENERAL ELECTRIC COMPANY	REFERENCE NO. 205-AA668
3	ADDRESS San Jose, California	PROJECT NO. (S.W.) 1-71-04-30971
4	PLANT LOCATION La Salle I & La Salle II	DATE 5/19/71
5	SERVICE OF UNIT Residual Heat Removal Heat Exchs.	ITEM NO. E-12-R001
6	SIZE 52" I.D. x 27' Avg. Tl. TYPE (TEMA) "AEU"	Channel Down
7	SURF./UNIT (GROSS) 11,790 (EFF.) 11,500	SHELLS/UNIT One * SURF./SHELL (GROSS) 11,790 (EFF.) 11,500
8	* Four (4) Units Req'd	
9	PERFORMANCE OF ONE UNIT	
10	FLUID CIRCULATED	SHELL SIDE Reactor Water
11	TOTAL FLUID ENTERING #/HR	TUBE SIDE Service Water
12	VAPOR	3,725,000 (7450 GPM)
13	LIQUID	3,700,000 (7400 GPM)
14	STEAM	3,725,000
15	NON-CONDENSABLES	3,700,000
16	FLUID VAPORIZED OR CONDENSED	
17	STEAM CONDENSED	
18	SPECIFIC GRAVITY	
19	VISCOSITY	
20	MOLECULAR WEIGHT	
21	SPECIFIC HEAT BTU/LB °F	
22	THERMAL CONDUCTIVITY BTU/HR-FT-°F	
23	LATENT HEAT BTU/LB	
24	TEMPERATURE IN °F	120.0
25	TEMPERATURE OUT °F	90.0
26	OPERATING PRESSURE PSIG	108.6
27	NO. PASSES PER SHELL	101.5
28	VELOCITY FT/SEC	One
29	PRESSURE DROP Max. PSI	Two
30	FOULING RESISTANCE (MIN)	3.4 Avg. Long
31	HEAT EXCHANGED. BTU/HR	6.7
32	TRANSFER RATE - SERVICE	8.5
33	CONSTRUCTION OF ONE SHELL (see Shutdown Mode 5% tubes plw)	9.0
34	DESIGN PRESSURE PSIG	42,550,000
35	TEST PRESSURE PSIG	213
36	DESIGN TEMPERATURE °F	CLEAN
37	TUBES NO. O.D. BWG	463
38	SHELL I. D. O.D.	
39	CHANNEL OR BONNET	
40	TUBESHEET STATIONARY	
41	BAFFLE-CROSS TYPE	
42	BAFFLES-LONG TYPE	
43	TUBE SUPPORTS	
44	TUBE TO TUBE SHEET JOINT	
45	GASKETS	
46	CONNECTIONS-SHELL SIDE IN OUT RATING	
47	CHANNEL SIDE IN OUT RATING	
48	CORROSION ALLOWANCE-SHELL SIDE TUBE SIDE	
49	CODE REQUIREMENTS	
50	REMARKS	
51		
52		
53		
54		

Proto-Power Calc: 97-201

Attachment: A

Rev: A Page 2 of 5

SECTION X

STRUTHERS WELLS CORPORATION

Heat Exchanger Specification Sheet



18011A

FIVE PERCENT TUBES PLUGGED- SHUTDOWN OPERATING MODE

1	JOB NO.	
2	CUSTOMER GENERAL ELECTRIC COMPANY	REFERENCE NO. 205-AA668
3	ADDRESS San Jose, California	PT# 200971 NO. (S.W.) 1-71-04-30971
4	PLANT LOCATION La Salle I & La Salle II	DATE 5/19/71
5	SERVICE OF UNIT Residual Heat Removal Heat Exchs.	ITEM NO. E12-Boo1
6	SIZE 52" I.D. x 27' Avg. T.L. TYPE (TEMA) "AEU" (VENT.)	Channel Down
7	SURF./UNIT 11,790 (GROSS EFF.)	SHELLS/UNIT One * SURF./SHELL 11,790 (GROSS EFF.)
8	* Four (4) Units Req'd PERFORMANCE OF ONE UNIT	
9		
10	FLUID CIRCULATED	SHELL SIDE Tube Side
11	TOTAL FLUID ENTERING #/HR	Reactor Water 3,725,000 (7450 GPM) Service Water 3,700,000 (7,400 GPM)
12	VAPOR	
13	LIQUID	3,725,000 3,700,000
14	STEAM	
15	NON-CONDENSABLES	
16	FLUID VAPORIZED OR CONDENSED	
17	STEAM CONDENSED	
18	SPECIFIC GRAVITY	
19	VISCOSITY	
20	MOLECULAR WEIGHT	
21	SPECIFIC HEAT BTU/LB °F	
22	THERMAL CONDUCTIVITY BTU/HR-FT. °F	
23	LATENT HEAT BTU/LB	
24	TEMPERATURE IN °F	120.0 90.0
25	TEMPERATURE OUT °F	108.8 101.25
26	OPERATING PRESSURE PSIG	
27	NO. PASSES PER SHELL	One Two
28	VELOCITY FT/SEC	3.4 Avg. Long 7.04
29	PRESSURE DROP Max. PSI	8.5 10.0
30	FOULING RESISTANCE (MIN)	.0005 .002
31	HEAT EXCHANGED, BTU/HR	41,600,000 MTD CORRECTED, °F 17.6
32	TRANSFER RATE - SERVICE	215 CLEAN 466
33	CONSTRUCTION OF ONE SHELL	
34	DESIGN PRESSURE PSIG	500 150
35	TEST PRESSURE PSIG	Per Code Per Code
36	DESIGN TEMPERATURE °F	40 to 480 32 to 480
37	TUBES 304 L 3/8 (A-249) NO. 1063 U; 0.0 3/4" BWG 18	LENGTH *** PITCH 1" Triang.
38	SHELL C.S. w/304 L 3/8 sch. D. 52" x x	SHELL COVER C.S. w/304 L 3/8 sch. D. (INTEG. 1063 U)
39	CHANNEL OR BONNET C.S. w/Carbamastic Coating	CHANNEL COVER C.S. w/Carbamastic Coating
40	TUBESHEET STATIONARY Solid 304 L 3/8	TUBESHEET FLOATING
41	BAFFLE-CROSS 304 L 3/8 TYPE Mod. Split Flow	FLOATING HEAD COVER
42	BAFFLES-LONG TYPE	IMPINGEMENT PROTECTION Yes
43	TUBE SUPPORTS 304 L 3/8 - U-Bend Support	
44	TUBE TO TUBE SHEET JOINT Welded & Roller Expanded	
45	GASKETS Metal Jack Ash	
46	CONNECTIONS-SHELL SIDE IN 18" OUT 18" RATING W.F.	
47	CHANNEL SIDE IN 18" OUT 18" RATING W.F.	
48	CORROSION ALLOWANCE-SHELL SIDE Per Spec. 21A1686 TUBE SIDE Per Spec. 21A1686	
49	CODE REQUIREMENTS Shell Side - Sec. III-C; Tube Side - Sec. III-C TEMA CLASS "C"	
50	REMARKS Performance conditions shown above are based on 53 U-tubes	
51	being plugged. *** Approximately 50% of tubes have a straight	
52	length of U-tube equal to 26.5'; 25% have 27' straight length and	
53	25% have straight length of 28'.	
54		

Proto-Power Calc: 97-201

Attachment: A

Rev: A Page 3 of 5

SECTION X

10011.6

STRUTHERS WELLS CORPORATION

Heat Exchanger Specification Sheet



ALL TUBES AVAILABLE - CONTAINMENT COOLING MODE

1			JOB NO.	
2	CUSTOMER	GENERAL ELECTRIC COMPANY	REFERENCE NO.	205-AA668
3	ADDRESS	San Jose, California	PROJECT NO. (S.W.)	1-71-04-30971
4	PLANT LOCATION	La Salle I & La Salle II	DATE	5/19/71
5	SERVICE OF UNIT	Residual Heat Removal Heat Exchs.	ITEM NO.	E12-B001
6	SIZE	52" I.D. x 27' Avg. T.L. TYPE (TEMA) "AEU" (VEHT.)		Channel Down
7	SURF./UNIT (GROSS) (EFF.)	11,790 (11,500)	SHELLS/UNIT	One *
			SURF./SHELL (GROSS) (EFF.)	11,790 (11,500)
8	* Four (4) Units Req'd			
9	PERFORMANCE OF ONE UNIT			
10	FLUID CIRCULATED		SHELL SIDE	TUBE SIDE
11	TOTAL FLUID ENTERING #/HR		Demin. Water	Service Water
12	VAPOR		4,200,000 (8400 GPM)	3,700,000 (7400 GPM)
13	LIQUID		4,200,000	3,700,000
14	STEAM			
15	NON-CONDENSABLES			
16	FLUID VAPORIZED OR CONDENSED			
17	STEAM CONDENSED			
18	SPECIFIC GRAVITY			
19	VISCOSITY			
20	MOLECULAR WEIGHT			
21	SPECIFIC HEAT BTU/LB °F			
22	THERMAL CONDUCTIVITY BTU/HR-FT. °F			
23	LATENT HEAT BTU/LB			
24	TEMPERATURE IN °F		212.0	100.0
25	TEMPERATURE OUT °F		171.6	145.9
26	OPERATING PRESSURE PSIG			
27	NO. PASSES PER SHELL		One	Two
28	VELOCITY FT/SEC		3-82 Avg. Long	6.7
29	PRESSURE DROP Max. PSI		10.0	9.0
30	FOULING RESISTANCE (MIN)		.0005	.002
31	HEAT EXCHANGED, BTU/HR	170,000,000	MTD CORRECTED, °F	64.1
32	TRANSFER RATE - SERVICE	231	CLEAN	563
33	CONSTRUCTION OF ONE SHELL (See Shutdown Mode 5% tubes)			
34	DESIGN PRESSURE PSIG			
35	TEST PRESSURE PSIG			
36	DESIGN TEMPERATURE °F			
37	TUBES NO.	O.D.	BWG	MIN. WALLS. AVG. WLD.
38	SHELL I. D.	O.D.		LENGTH
39	CHANNEL OR BONNET			PITCH
40	TUBESHEET-STATIONARY			(INTEG.)(REMOV.)
41	BAFFLE-CROSS TYPE			SHELL COVER
42	BAFFLES-LONG TYPE			CHANNEL COVER
43	TUBE SUPPORTS			TUBESHEET FLOATING
44	TUBE TO TUBE SHEET JOINT			FLOATING HEAD COVER
45	GASKETS			IMPINGEMENT PROTECTION
46	CONNECTIONS-SHELL SIDE IN	OUT		
47	CHANNEL SIDE IN	OUT		
48	CORROSION ALLOWANCE-SHELL SIDE	TUBE SIDE		
49	CODE REQUIREMENTS			TEMA CLASS
50	REMARKS			
51				
52				
53				
54				


Proto-Power Calc: 97-201

Attachment: A

18011A

STRUTHERS WELLS CORPORATION

Heat Exchanger Specification Sheet



FIVE PERCENT TUBES PLUGGED - CONTAINMENT COOLING MODE

1	JOB NO.	
2	CUSTOMER GENERAL ELECTRIC COMPANY	REFERENCE NO. 205-AA668
3	ADDRESS San Jose, California	TEMA NO. (S.W.) 1-71-04-30971
4	PLANT LOCATION La Salle I & La Salle II	DATE 5/19/71
5	SERVICE OF UNIT Residual Heat Removal Heat Exchs.	ITEM NO. F12-3001
6	SIZE 52" I.D. x 27' Avg. T.L. TYPE (TEMA) "AEU" (VERT.)	Channel Down
7	SURF./UNIT (GROSS I.E.F.F.) 11,750	SHELLS/UNIT One* SURF./SHELL (GROSS I.E.F.F.) 11,750
8	* Four (4) Units Req'd	
9	PERFORMANCE OF ONE UNIT	
10	FLUID CIRCULATED	Shell Side: Demin. Water Tube Side: Service Water
11	TOTAL FLUID ENTERING #/HR	Shell Side: 4,200,000 (8400 GPM) Tube Side: 3,700,000 (7400 GPM)
12	VAPOR	
13	LIQUID	Shell Side: 4,200,000 Tube Side: 3,700,000
14	STEAM	
15	NON-CONDENSABLES	
16	FLUID VAPORIZED OR CONDENSED	
17	STEAM CONDENSED	
18	SPECIFIC GRAVITY	
19	VISCOSITY	
20	MOLECULAR WEIGHT	
21	SPECIFIC HEAT BTU/LB °F	
22	THERMAL CONDUCTIVITY BTU/HR-FT-°F	
23	LATENT HEAT BTU/LB	
24	TEMPERATURE IN °F	Shell Side: 212 Tube Side: 100
25	TEMPERATURE OUT °F	Shell Side: 172 Tube Side: 145.3
26	OPERATING PRESSURE PSIG	
27	NO. PASSES PER SHELL	Shell Side: One Tube Side: Two
28	VELOCITY FT/SEC	Shell Side: 3.82 Avg. Long Tube Side: 7.04
29	PRESSURE DROP Max. PSI	Shell Side: 10.0 Tube Side: 10.0
30	FOULING RESISTANCE (MIN)	Shell Side: .0005 Tube Side: .002
31	HEAT EXCHANGED, BTU/HR	Shell Side: 168,000,000 MTD CORRECTED, °F 65.0
32	TRANSFER RATE - SERVICE	Shell Side: 235 CLEAN Tube Side: 568
33	CONSTRUCTION OF ONE SHELL (See Shutdown Mode)	
34	DESIGN PRESSURE PSIG	
35	TEST PRESSURE PSIG	
36	DESIGN TEMPERATURE °F	
37	TUBES NO. O.D. BWG	MIN. WALLS. AVG. WLD. LENGTH PITCH
38	SHELL I. D. O.D.	SHELL COVER (INTEG.)(REMOV.)
39	CHANNEL OR BONNET	CHANNEL COVER
40	TUBESHEET-STATIONARY	TUBESHEET FLOATING
41	BAFFLE-CROSS TYPE	FLOATING HEAD COVER
42	BAFFLES-LONG TYPE	IMPINGEMENT PROTECTION
43	TUBE SUPPORTS	
44	TUBE TO TUBE SHEET JOINT	
45	GASKETS	
46	CONNECTIONS-SHELL SIDE IN OUT	RATING
47	CHANNEL SIDE IN OUT	RATING
48	CORROSION ALLOWANCE-SHELL SIDE TUBE SIDE	
49	CODE REQUIREMENTS	TEMA CLASS
50	REMARKS Performance conditions are based on 53 U-tubes being plugged.	
51		
52		
53		
54		


Proto-Power Calc. 97-201

Attachment: A

Rev: A Page 5 of 5

**Attachment B to
Proto-Power Calculation
97-201
Revision A**

REFERENCE 8.1



1316966A
RESIDUAL HEAT REMOVAL SYS

1316966A

SUPERSEDES PRINT
REVIEWED 6-3-76
SUP. LTR. T-0915

REV. 5 J-2500 T-2732

1316966A

REVISED FOR
LA SAHLE STATION
COMM. BY LA SAHLE CO.
SHEET NO. 2
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

MODE F

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
POSITION																					
POSITION																					
POSITION																					
POSITION																					

MODE A-1

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
POSITION																					
POSITION																					
POSITION																					
POSITION																					

MODE G

POSITION	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	
POSITION																							
POSITION																							
POSITION																							
POSITION																							

MODE A-2

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE S

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE B

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE S (cont'd)

POSITION	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	
POSITION																							
POSITION																							
POSITION																							
POSITION																							

MODE C-1

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE C-2

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE C-2 (cont'd)

POSITION	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	
POSITION																							
POSITION																							
POSITION																							
POSITION																							

MODE C-3

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE C-3 (cont'd)

POSITION	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	
POSITION																							
POSITION																							
POSITION																							
POSITION																							

MODE E

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

MODE D

POSITION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
POSITION																						
POSITION																						
POSITION																						
POSITION																						

1 20
2
3
FOR R.H.R. 515
EQUIPMENT NO. 1-11-82
SPEC. NO. 1-11-82

REVISIONS
1. 11/11/82
2. 11/11/82
3. 11/11/82
4. 11/11/82
5. 11/11/82
6. 11/11/82
7. 11/11/82
8. 11/11/82
9. 11/11/82
10. 11/11/82
11. 11/11/82
12. 11/11/82
13. 11/11/82
14. 11/11/82
15. 11/11/82
16. 11/11/82
17. 11/11/82
18. 11/11/82
19. 11/11/82
20. 11/11/82

REFERENCE 8.1

SUPERSEDES PRINT
REVISION NO.
SUB LTR. T-05-461

**Attachment C to
Proto-Power Calculation
97-201
Revision A**

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - All Tubes, Vendor Fouling

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Empirical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,063
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

} }
}

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - All Tubes, Vendor Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,396.3
Shell Flow (gpm)	Shell Flow (gpm)	7,446.3
Shell Temp In (°F)	Tube Inlet Temp (°F)	90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr·ft ² ·°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr·ft ² ·°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr·ft ² ·°F)
LMTD	1/Wall Resis (BTU/hr·ft ² ·°F)
Effective Area (ft ²)	LMTD Correction Factor
	Overall Fouling (hr·ft ² ·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft ³)		
Cp ^l (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)	
Shell Temp Out (°F)	
Tav Shell (°F)	
Shell Skin Temp (°F)	
Tube Temp In (°F)	
Tube Temp Out (°F)	
Tav Tube (°F)	
Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.725E+6	Overall Fouling (hr·ft ² ·°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.7E+6	Shell-Side ho (BTU/hr·ft ² ·°F)	977.6
Heat Transferred (BTU/hr)	4.251E+7	Tube-Side hi (BTU/hr·ft ² ·°F)	1,666.6
LMTD	18.5	1/Wall Resis (BTU/hr·ft ² ·°F)	2,148.1
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.9328

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.43	6.72
Reynold's Number	3.354E+04	4.729E+04
Prandtl Number	3.86	4.77
Bulk Visc (lbm/ft·hr)	1.42	1.73
Skin Visc (lbm/ft·hr)	1.48	1.67
Density (lbm/ft ³)	61.80	62.05
Cp (BTU/lbm·°F)	1.00	1.00
K (BTU/hr·ft·°F)	0.37	0.36

U Overall (BTU/hr·ft ² ·°F)	213.7
Shell Temp In (°F)	120.0
Shell Temp Out (°F)	108.6
Tav Shell (°F)	114.3
Shell Skin Temp (°F)	110.2
Tube Temp In (°F)	90.0
Tube Temp Out (°F)	101.5
Tav Tube (°F)	95.7
Tube Skin Temp (°F)	98.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - 53 Plugs, Vendor Fouling

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 7,446.28	7,396.31
Inlet Temperature	°F 120.00	90.00
Outlet Temperature	°F 108.80	101.25
Fouling Factor	0.00250	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		215.00
Emprical Factor for Outside h		0.563555000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		11,500.00
Area Factor		0.996344561
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		4.880000000
Shell Velocity (ft/s)		3.400
Tube Pitch (in)		1.0000
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		Yes
Total Number of Tubes		1,063
Number of Active Tubes		1,010
Tube Length (ft)		55.30
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		9.40
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Proto-Power Calc: 97-201

Attachment: C

Rev: A Page 4 of 9

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - 53 Plugs, Vendor Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,396.3
 Shell Flow (gpm) 7,446.3
 Tube Inlet Temp (°F) 90.0
 Shell Inlet Temp (°F) 120.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3.725E+6
 Tube Mass Flow (lbm/hr) 3.7E+6
 Heat Transferred (BTU/hr) 4.147E+7
 LMTD 18.8
 Effective Area (ft²) 10,926.6

Overall Fouling (hr-ft²-°F/BTU) 0.002500
 Shell-Side ho (BTU/hr-ft²-°F) 978.0
 Tube-Side hi (BTU/hr-ft²-°F) 1,734.7
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9382
 U Overall (BTU/hr-ft²-°F) 215.0

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.43	7.07
Reynold's Number	3.359E+04	4.970E+04
Prandtl Number	3.85	4.78
Bulk Visc (lbm/ft-hr)	1.42	1.73
Skin Visc (lbm/ft-hr)	1.48	1.68
Density (lbm/ft³)	61.80	62.05
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

Shell Temp In (°F) 120.0
 Shell Temp Out (°F) 108.9
 Tav Shell (°F) 114.4
 Shell Skin Temp (°F) 110.3
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 101.2
 Tav Tube (°F) 95.6
 Tube Skin Temp (°F) 98.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-201
 Attachment: C
 Rev: A Page 5 of 9

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - All Tubes, Vendor Fouling

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 7,446.28	7,396.31
Inlet Temperature	°F 120.00	90.00
Outlet Temperature	°F 108.80	101.25
Fouling Factor	0.00250	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		215.00
Empirical Factor for Outside h		0.563555000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		11,500.00
Area Factor		0.996344561
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		4.880000000
Shell Velocity (ft/s)		3.400
Tube Pitch (in)		1.0000
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		Yes
Total Number of Tubes		1,063
Number of Active Tubes		1,063
Tube Length (ft)		55.30
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		9.40
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Proto-Power Calc: 97-201

Attachment: C

Rev: A Page 6 of 9

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - All Tubes, Vendor Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,396.3
 Shell Flow (gpm) 8,395.8
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 212.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.2E+6
 Tube Mass Flow (lbm/hr) 3.7E+6
 Heat Transferred (BTU/hr) 1.7E+8
 LMTD 68.8
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.002500
 Shell-Side ho (BTU/hr-ft²-°F) 1,286.8
 Tube-Side hi (BTU/hr-ft²-°F) 1,944.4
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9309
 U Overall (BTU/hr-ft²-°F) 230.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.96	6.76
Reynold's Number	6.973E+04	6.230E+04
Prandtl Number	2.00	3.53
Bulk Visc (lbm/ft-hr)	0.77	1.31
Skin Visc (lbm/ft-hr)	0.84	1.20
Density (lbm/ft³)	60.31	61.67
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 171.7
 Tav Shell (°F) 191.8
 Shell Skin Temp (°F) 179.5
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 146.0
 Tav Tube (°F) 123.0
 Tube Skin Temp (°F) 132.4

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - 53 Plugs, Vendor Fouling

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	7,446.28	7,396.31
Inlet Temperature	°F	120.00	90.00
Outlet Temperature	°F	108.80	101.25
Fouling Factor		0.00250	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			41,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			215.00
Emprical Factor for Outside h			0.563555000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			11,500.00
Area Factor			0.996344561
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			4.880000000
Shell Velocity (ft/s)			3.400
Tube Pitch (in)			1.0000
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			Yes
Total Number of Tubes			1,063
Number of Active Tubes			1,010
Tube Length (ft)			55.30
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			9.40
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Proto-Power Calc: 97-201

Attachment: C

Rev: A Page 8 of 9

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM - 53 Plugs, Vendor Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,396.3
Shell Flow (gpm)	Shell Flow (gpm) 8,395.8
Shell Temp In (°F)	Tube Inlet Temp (°F) 100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 212.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
	Overall Fouling (hr-ft ² -°F/BTU)

Property	Shell-Side	Tube-Side	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	4.2E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.7E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,287.9
Heat Transferred (BTU/hr)	1.658E+8	Tube-Side hi (BTU/hr-ft ² -°F)	2,019.7
LMTD	69.9	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9365
		U Overall (BTU/hr-ft ² -°F)	231.9
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.97	7.12	Shell Temp In (°F) 212.0
Reynold's Number	6.995E+04	6.523E+04	Shell Temp Out (°F) 172.7
Prandtl Number	1.99	3.55	Tav Shell (°F) 192.3
Bulk Visc (lbm/ft-hr)	0.77	1.32	Shell Skin Temp (°F) 179.7
Skin Visc (lbm/ft-hr)	0.84	1.21	Tube Temp In (°F) 100.0
Density (lbm/ft ³)	60.30	61.67	Tube Temp Out (°F) 144.9
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 122.4
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 131.7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment D to
Proto-Power Calculation
97-201
Revision A**

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - Tube-side FF = 0.0000

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,370.2
 Shell Flow (gpm) 7,372.0
 Tube Inlet Temp (°F) 90.0
 Shell Inlet Temp (°F) 120.0
 Input Fouling Factor 0.000500

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3.688E+6
 Tube Mass Flow (lbm/hr) 3.687E+6
 Heat Transferred (BTU/hr) 5.4E+7
 LMTD 15.3
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.000500
 Shell-Side ho (BTU/hr-ft²-°F) 963.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,680.3
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.8229
 U Overall (BTU/hr-ft²-°F) 372.1

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.40	6.70
Reynold's Number	3.268E+04	4.796E+04
Prandtl Number	3.93	4.68
Bulk Visc (lbm/ft-hr)	1.45	1.70
Skin Visc (lbm/ft-hr)	1.53	1.63
Density (lbm/ft³)	61.82	62.03
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

Shell Temp In (°F) 120.0
 Shell Temp Out (°F) 105.3
 Tav Shell (°F) 112.7
 Shell Skin Temp (°F) 106.7
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 104.7
 Tav Tube (°F) 97.3
 Tube Skin Temp (°F) 101.2

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Tube-side FF = 0.0005

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	7,372.0
Tube Inlet Temp (°F)	90.0
Shell Inlet Temp (°F)	120.0
Input Fouling Factor	0.001075

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3.688E+6
 Tube Mass Flow (lbm/hr) 3.687E+6
 Heat Transferred (BTU/hr) 5.024E+7
 LMTD 16.4
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.001075
 Shell-Side ho (BTU/hr-ft²-°F) 966.4
 Tube-Side hi (BTU/hr-ft²-°F) 1,674.1
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.8710
 U Overall (BTU/hr-ft²-°F) 306.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.40	6.70
Reynold's Number	3.285E+04	4.769E+04
Prandtl Number	3.91	4.71
Bulk Visc (lbm/ft-hr)	1.44	1.70
Skin Visc (lbm/ft-hr)	1.51	1.64
Density (lbm/ft³)	61.81	62.03
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

Shell Temp In (°F) 120.0
 Shell Temp Out (°F) 106.4
 Tav Shell (°F) 113.2
 Shell Skin Temp (°F) 108.0
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 103.6
 Tav Tube (°F) 96.8
 Tube Skin Temp (°F) 100.3

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 3 of 11

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - Tube-side FF = 0.0010

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	7,372.0
Tube Inlet Temp (°F)	90.0
Shell Inlet Temp (°F)	120.0
Input Fouling Factor	0.001650

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 3.688E+6
 Tube Mass Flow (lbm/hr) 3.687E+6
 Heat Transferred (BTU/hr) 4.679E+7
 LMTD 17.3
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.001650
 Shell-Side ho (BTU/hr-ft²-°F) 968.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,668.7
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9026
 U Overall (BTU/hr-ft²-°F) 260.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.40	6.70
Reynold's Number	3.300E+04	4.744E+04
Prandtl Number	3.89	4.74
Bulk Visc (lbm/ft-hr)	1.43	1.71
Skin Visc (lbm/ft-hr)	1.50	1.66
Density (lbm/ft³)	61.81	62.04
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

Shell Temp In (°F) 120.0
 Shell Temp Out (°F) 107.3
 Tav Shell (°F) 113.6
 Shell Skin Temp (°F) 109.0
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 102.7
 Tav Tube (°F) 96.4
 Tube Skin Temp (°F) 99.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 4 of 11

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Tube-side FF = 0.0015

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	Shell Flow (gpm)	7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.002225

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
	Tube-Side hi (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	1/Wall Resis (BTU/hr-ft ² -°F)
LMTD	LMTD Correction Factor
Effective Area (ft ²)	

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)	
Shell Temp Out (°F)	
Tav Shell (°F)	
Shell Skin Temp (°F)	
Tube Temp In (°F)	
Tube Temp Out (°F)	
Tav Tube (°F)	
Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002225
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr-ft ² -°F)	970.7
		Tube-Side hi (BTU/hr-ft ² -°F)	1,663.9
Heat Transferred (BTU/hr)	4.369E+7	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
LMTD	18.1	LMTD Correction Factor	0.9242
Effective Area (ft ²)	11,500.0		

U Overall (BTU/hr-ft²-°F) 226.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.40	6.70
Reynold's Number	3.314E+04	4.722E+04
Prandtl Number	3.87	4.76
Bulk Visc (lbm/ft-hr)	1.43	1.72
Skin Visc (lbm/ft-hr)	1.49	1.67
Density (lbm/ft ³)	61.80	62.05
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

Shell Temp In (°F)	120.0
Shell Temp Out (°F)	108.1
Tav Shell (°F)	114.1
Shell Skin Temp (°F)	109.8
Tube Temp In (°F)	90.0
Tube Temp Out (°F)	101.9
Tav Tube (°F)	95.9
Tube Skin Temp (°F)	98.8

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 5 of 11

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

SDC - Tube-side FF = 0.0020

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	Shell Flow (gpm)	7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.002801

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)			Tube Temp In (°F)
Skin Visc (lbm/ft-hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm-°F)			Tube Skin Temp (°F)
K (BTU/hr-ft-°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002801
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr-ft ² -°F)	972.4
Heat Transferred (BTU/hr)	4.092E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,659.7
LMTD	18.9	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.9395
		U Overall (BTU/hr-ft ² -°F)	200.5
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	3.40	6.70	Shell Temp Out (°F)
Reynold's Number	3.326E+04	4.703E+04	Tav Shell (°F)
Prandtl Number	3.85	4.78	Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)	1.42	1.73	Tube Temp In (°F)
Skin Visc (lbm/ft-hr)	1.48	1.68	Tube Temp Out (°F)
Density (lbm/ft ³)	61.80	62.05	Tav Tube (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr-ft-°F)	0.37	0.36	

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 6 of 11

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM - Tube-side FF = 0.0000

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,356.1
 Shell Flow (gpm) 8,057.7
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 212.0
 Input Fouling Factor 0.000500

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 2.168E+8
 LMTD 55.7
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.000500
 Shell-Side ho (BTU/hr-ft²-°F) 1,227.9
 Tube-Side hi (BTU/hr-ft²-°F) 2,006.2
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.7971
 U Overall (BTU/hr-ft²-°F) 424.9

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.80	6.74
Reynold's Number	6.408E+04	6.572E+04
Prandtl Number	2.09	3.31
Bulk Visc (lbm/ft-hr)	0.81	1.23
Skin Visc (lbm/ft-hr)	0.92	1.10
Density (lbm/ft³)	60.46	61.56
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 158.4
 Tav Shell (°F) 185.2
 Shell Skin Temp (°F) 165.9
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 159.0
 Tav Tube (°F) 129.5
 Tube Skin Temp (°F) 143.1

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 7 of 11

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - Tube-side FF = 0.0005

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,356.1
Shell Flow (gpm)	Shell Flow (gpm)	8,057.7
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	212.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.001075

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)	LMTD Correction Factor	
	Overall Fouling (hr-ft ² -°F/BTU)	
Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		
	Shell Temp In (°F)	
	Shell Temp Out (°F)	
	Tav Shell (°F)	
	Shell Skin Temp (°F)	
	Tube Temp In (°F)	
	Tube Temp Out (°F)	
	Tav Tube (°F)	
	Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	4.031E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.001075
Tube Mass Flow (lbm/hr)	3.68E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,236.8
Heat Transferred (BTU/hr)	2.01E+8	Tube-Side hi (BTU/hr-ft ² -°F)	1,982.3
LMTD	59.8	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.8568
		U Overall (BTU/hr-ft ² -°F)	341.4
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.80	6.73	Shell Temp In (°F)
Reynold's Number	6.491E+04	6.447E+04	Shell Temp Out (°F)
Prandtl Number	2.06	3.38	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	0.80	1.26	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	0.89	1.14	Tube Temp In (°F)
Density (lbm/ft ³)	60.42	61.59	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F)

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 8 of 11

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - Tube-side FF = 0.0010

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,356.1
 Shell Flow (gpm) 8,057.7
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 212.0
 Input Fouling Factor 0.001650

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 1.865E+8
 LMTD 63.5
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.001650
 Shell-Side ho (BTU/hr-ft²-°F) 1,244.2
 Tube-Side hi (BTU/hr-ft²-°F) 1,961.1
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.8946
 U Overall (BTU/hr-ft²-°F) 285.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.80	6.73
Reynold's Number	6.568E+04	6.332E+04
Prandtl Number	2.04	3.44
Bulk Visc (lbm/ft-hr)	0.79	1.28
Skin Visc (lbm/ft-hr)	0.87	1.17
Density (lbm/ft³)	60.37	61.63
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 165.9
 Tav Shell (°F) 188.9
 Shell Skin Temp (°F) 174.4
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 150.7
 Tav Tube (°F) 125.4
 Tube Skin Temp (°F) 136.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-201
 Attachment: D
 Rev: A Page 9 of 11

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - Tube-side FF = 0.0015

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,356.1
Shell Flow (gpm)	8,057.7
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	212.0
Input Fouling Factor	0.002225

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 1.734E+8
 LMTD 66.9
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.002225
 Shell-Side ho (BTU/hr-ft²-°F) 1,250.4
 Tube-Side hi (BTU/hr-ft²-°F) 1,942.3
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9196

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.80	6.73
Reynold's Number	6.638E+04	6.230E+04
Prandtl Number	2.01	3.50
Bulk Visc (lbm/ft-hr)	0.78	1.30
Skin Visc (lbm/ft-hr)	0.85	1.19
Density (lbm/ft³)	60.34	61.66
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

U Overall (BTU/hr-ft²-°F) 244.9
 Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 169.1
 Tav Shell (°F) 190.6
 Shell Skin Temp (°F) 177.4
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 147.2
 Tav Tube (°F) 123.6
 Tube Skin Temp (°F) 133.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-201

Attachment: D

Rev: A Page 10 of 11

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - Tube-side FF = 0.0020

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,356.1
Shell Flow (gpm)	8,057.7
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	212.0
Input Fouling Factor	0.002801

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 1.618E+8
 LMTD 70.0
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.002801
 Shell-Side ho (BTU/hr-ft²-°F) 1,255.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,925.7
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9369
 U Overall (BTU/hr-ft²-°F) 214.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.81	6.72
Reynold's Number	6.700E+04	6.139E+04
Prandtl Number	1.99	3.56
Bulk Visc (lbm/ft-hr)	0.77	1.32
Skin Visc (lbm/ft-hr)	0.83	1.22
Density (lbm/ft³)	60.30	61.68
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 172.0
 Tav Shell (°F) 192.0
 Shell Skin Temp (°F) 180.0
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 144.0
 Tav Tube (°F) 122.0
 Tube Skin Temp (°F) 131.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment E to
Proto-Power Calculation
97-201
Revision A**

Commonwealth Edison

Calculation Report for E12-B001 - LSCS - RHR Hx.

CCM - Service Margin - All Tubes

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,356.1
Shell Flow (gpm)	8,057.7
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	212.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 1.677E+8
 LMTD 68.4
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.002500
 Shell-Side ho (BTU/hr-ft²-°F) 1,253.0
 Tube-Side hi (BTU/hr-ft²-°F) 1,934.1
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.9286

U Overall (BTU/hr-ft²-°F) 229.4

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.80	6.73
Reynold's Number	6.668E+04	6.185E+04
Prandtl Number	2.00	3.53
Bulk Visc (lbm/ft-hr)	0.77	1.31
Skin Visc (lbm/ft-hr)	0.84	1.21
Density (lbm/ft³)	60.32	61.67
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 170.5
 Tav Shell (°F) 191.3
 Shell Skin Temp (°F) 178.7
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 145.6
 Tav Tube (°F) 122.8
 Tube Skin Temp (°F) 132.2

Proto-Power Calc: 97-201

Attachment: E

Rev: A Page 2 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM - Service Margin - 53 Plugs

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,356.1
 Shell Flow (gpm) 8,057.7
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 212.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	4.031E+6
Tube Mass Flow (lbm/hr)	3.68E+6
Heat Transferred (BTU/hr)	1.637E+8
LMTD	69.5
Effective Area (ft²)	10,926.6

Overall Fouling (hr-ft²-°F/BTU)	0.002500
Shell-Side ho (BTU/hr-ft²-°F)	1,254.1
Tube-Side hi (BTU/hr-ft²-°F)	2,009.1
1/Wall Resis (BTU/hr-ft²-°F)	2,148.1
LMTD Correction Factor	0.9344

U Overall (BTU/hr-ft²-°F)	230.7
---------------------------	-------

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.80	7.08
Reynold's Number	6.690E+04	6.477E+04
Prandtl Number	2.00	3.55
Bulk Visc (lbm/ft-hr)	0.77	1.32
Skin Visc (lbm/ft-hr)	0.84	1.21
Density (lbm/ft³)	60.31	61.68
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	212.0
Shell Temp Out (°F)	171.5
Tav Shell (°F)	191.8
Shell Skin Temp (°F)	179.0
Tube Temp In (°F)	100.0
Tube Temp Out (°F)	144.5
Tav Tube (°F)	122.3
Tube Skin Temp (°F)	131.4

Proto-Power Calc: 97-201

Attachment: E

Rev: A Page 3 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM - Clean Margin - All Tubes

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 7,356.1
 Shell Flow (gpm) 8,057.7
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 212.0
 Input Fouling Factor 0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 4.031E+6
 Tube Mass Flow (lbm/hr) 3.68E+6
 Heat Transferred (BTU/hr) 2.307E+8
 LMTD 52.0
 Effective Area (ft²) 11,500.0

Overall Fouling (hr-ft²-°F/BTU) 0.000000
 Shell-Side ho (BTU/hr-ft²-°F) 1,218.2
 Tube-Side hi (BTU/hr-ft²-°F) 2,029.2
 1/Wall Resis (BTU/hr-ft²-°F) 2,148.1
 LMTD Correction Factor 0.7148
 U Overall (BTU/hr-ft²-°F) 539.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.79	6.74
Reynold's Number	6.335E+04	6.683E+04
Prandtl Number	2.12	3.25
Bulk Visc (lbm/ft-hr)	0.82	1.21
Skin Visc (lbm/ft-hr)	0.96	1.06
Density (lbm/ft³)	60.50	61.53
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 212.0
 Shell Temp Out (°F) 154.9
 Tav Shell (°F) 183.5
 Shell Skin Temp (°F) 160.4
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 162.8
 Tav Tube (°F) 131.4
 Tube Skin Temp (°F) 147.3

Proto-Power Calc: 97-201

Attachment: E

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 CCM - Clean Margin - 53 Plugs

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,356.1
Shell Flow (gpm)	Shell Flow (gpm) 8,057.7
Shell Temp In (°F)	Tube Inlet Temp (°F) 100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 212.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	Input Fouling Factor 0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
	Overall Fouling (hr-ft ² -°F/BTU)

Property	Shell-Side	Tube-Side	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	4.031E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.000000
Tube Mass Flow (lbm/hr)	3.68E+6	Shell-Side ho (BTU/hr-ft ² -°F)	1,218.3
Heat Transferred (BTU/hr)	2.287E+8	Tube-Side hi (BTU/hr-ft ² -°F)	2,110.6
LMTD	52.5	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.7295
		U Overall (BTU/hr-ft ² -°F)	546.0
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.79	7.09	Shell Temp In (°F) 212.0
Reynold's Number	6.345E+04	7.016E+04	Shell Temp Out (°F) 155.4
Prandtl Number	2.11	3.25	Tav Shell (°F) 183.7
Bulk Visc (lbm/ft-hr)	0.81	1.22	Shell Skin Temp (°F) 160.1
Skin Visc (lbm/ft-hr)	0.96	1.07	Tube Temp In (°F) 100.0
Density (lbm/ft ³)	60.49	61.53	Tube Temp Out (°F) 162.2
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 131.1
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 146.8

Proto-Power Calc: 97-201
 Attachment: E
 Rev: A Page 5 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Service Margin - All Tubes

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	Shell Flow (gpm)	7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)	LMTD Correction Factor	
	Overall Fouling (hr-ft ² -°F/BTU)	
Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		
	Shell Temp In (°F)	
	Shell Temp Out (°F)	
	Tav Shell (°F)	
	Shell Skin Temp (°F)	
	Tube Temp In (°F)	
	Tube Temp Out (°F)	
	Tav Tube (°F)	
	Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500	
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr-ft ² -°F)	971.5	
Heat Transferred (BTU/hr)	4.233E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,661.9	
LMTD	18.5	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1	
Effective Area (ft ²)	11,500.0	LMTD Correction Factor	0.9322	
		U Overall (BTU/hr-ft ² -°F)	213.4	
Property	Shell-Side	Tube-Side		
Velocity (ft/s)	3.40	6.70	Shell Temp In (°F)	120.0
Reynold's Number	3.320E+04	4.713E+04	Shell Temp Out (°F)	108.5
Prandtl Number	3.86	4.77	Tav Shell (°F)	114.3
Bulk Visc (lbm/ft-hr)	1.42	1.73	Shell Skin Temp (°F)	110.2
Skin Visc (lbm/ft-hr)	1.48	1.67	Tube Temp In (°F)	90.0
Density (lbm/ft ³)	61.80	62.05	Tube Temp Out (°F)	101.5
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)	95.7
K (BTU/hr-ft-°F)	0.37	0.36	Tube Skin Temp (°F)	98.5

Proto-Power Calc: 97-201

Attachment: E

Rev: A Page 6 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Service Margin - 53 Plugs

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,370.2
Shell Flow (gpm)	Shell Flow (gpm) 7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 120.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Property	Shell-Side	Tube-Side	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr-ft ² -°F)	971.9
Heat Transferred (BTU/hr)	4.131E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,729.7
LMTD	18.8	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.9376
		U Overall (BTU/hr-ft ² -°F)	214.6
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.40	7.05	Shell Temp In (°F) 120.0
Reynold's Number	3.324E+04	4.952E+04	Shell Temp Out (°F) 108.8
Prandtl Number	3.86	4.78	Tav Shell (°F) 114.4
Bulk Visc (lbm/ft-hr)	1.42	1.73	Shell Skin Temp (°F) 110.2
Skin Visc (lbm/ft-hr)	1.48	1.68	Tube Temp In (°F) 90.0
Density (lbm/ft ³)	61.80	62.05	Tube Temp Out (°F) 101.2
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 95.6
K (BTU/hr-ft-°F)	0.37	0.36	Tube Skin Temp (°F) 98.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC -- Service Margin - 38 Plugs

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	Shell Flow (gpm)	7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F)	90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	120.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Property	Shell-Side	Tube-Side	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr-ft ² -°F/BTU)	0.002500
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr-ft ² -°F)	971.8
Heat Transferred (BTU/hr)	4.16E+7	Tube-Side hi (BTU/hr-ft ² -°F)	1,709.9
LMTD	18.7	1/Wall Resis (BTU/hr-ft ² -°F)	2,148.1
Effective Area (ft ²)	11,088.9	LMTD Correction Factor	0.9361
		U Overall (BTU/hr-ft ² -°F)	214.3
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.40	6.95	Shell Temp In (°F)
Reynold's Number	3.323E+04	4.882E+04	Shell Temp Out (°F)
Prandtl Number	3.86	4.78	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	1.42	1.73	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	1.48	1.68	Tube Temp In (°F)
Density (lbm/ft ³)	61.80	62.05	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F)
K (BTU/hr-ft-°F)	0.37	0.36	Tube Skin Temp (°F)

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Clean Margin - All Tubes

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	7,370.2
Shell Flow (gpm)	7,372.0
Tube Inlet Temp (°F)	90.0
Shell Inlet Temp (°F)	120.0
Input Fouling Factor	0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6
Tube Mass Flow (lbm/hr)	3.687E+6
Heat Transferred (BTU/hr)	5.744E+7
LMTD	14.4
Effective Area (ft²)	11,500.0

Overall Fouling (hr-ft²-°F/BTU)	0.000000
Shell-Side ho (BTU/hr-ft²-°F)	960.9
Tube-Side hi (BTU/hr-ft²-°F)	1,686.2
1/Wall Resis (BTU/hr-ft²-°F)	2,148.1
LMTD Correction Factor	0.7586

Property	Shell-Side	Tube-Side
Velocity (ft/s)	3.40	6.70
Reynold's Number	3.253E+04	4.820E+04
Prandtl Number	3.95	4.66
Bulk Visc (lbm/ft-hr)	1.45	1.69
Skin Visc (lbm/ft-hr)	1.56	1.61
Density (lbm/ft³)	61.83	62.02
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.37	0.36

U Overall (BTU/hr-ft²-°F)	457.0
Shell Temp In (°F)	120.0
Shell Temp Out (°F)	104.4
Tav Shell (°F)	112.2
Shell Skin Temp (°F)	105.4
Tube Temp In (°F)	90.0
Tube Temp Out (°F)	105.6
Tav Tube (°F)	97.8
Tube Skin Temp (°F)	102.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-201

Attachment: E

Rev: A Page 9 of 10

Commonwealth Edison
 Calculation Report for E12-B001 - LSCS - RHR Hx.
 SDC - Clean Margin - 53 Plugs

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 7,370.2
Shell Flow (gpm)	Shell Flow (gpm) 7,372.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 90.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 120.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	Input Fouling Factor 0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)		U Overall (BTU/hr·ft ² ·°F)
Tube Mass Flow (lbm/hr)		Shell-Side ho (BTU/hr·ft ² ·°F)
Heat Transferred (BTU/hr)		Tube-Side hi (BTU/hr·ft ² ·°F)
LMTD		1/Wall Resis (BTU/hr·ft ² ·°F)
Effective Area (ft ²)		LMTD Correction Factor
		Overall Fouling (hr·ft ² ·°F/BTU)
Property	Shell-Side	Tube-Side
Velocity (ft/s)		Shell Temp In (°F)
Reynold's Number		Shell Temp Out (°F)
Prandtl Number		Tav Shell (°F)
Bulk Visc (lbm/ft·hr)		Shell Skin Temp (°F)
Skin Visc (lbm/ft·hr)		Tube Temp In (°F)
Density (lbm/ft ³)		Tube Temp Out (°F)
Cp (BTU/lbm·°F)		Tav Tube (°F)
K (BTU/hr·ft·°F)		Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	3.688E+6	Overall Fouling (hr·ft ² ·°F/BTU)	0.000009
Tube Mass Flow (lbm/hr)	3.687E+6	Shell-Side ho (BTU/hr·ft ² ·°F)	960.9
Heat Transferred (BTU/hr)	5.684E+7	Tube-Side hi (BTU/hr·ft ² ·°F)	1,755.7
LMTD	14.6	1/Wall Resis (BTU/hr·ft ² ·°F)	2,148.1
Effective Area (ft ²)	10,926.6	LMTD Correction Factor	0.7717
		U Overall (BTU/hr·ft ² ·°F)	462.7
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	3.40	7.05	Shell Temp In (°F) 120.0
Reynold's Number	3.256E+04	5.068E+04	Shell Temp Out (°F) 104.6
Prandtl Number	3.94	4.66	Tav Shell (°F) 112.3
Bulk Visc (lbm/ft·hr)	1.45	1.69	Shell Skin Temp (°F) 105.3
Skin Visc (lbm/ft·hr)	1.56	1.61	Tube Temp In (°F) 90.0
Density (lbm/ft ³)	61.83	62.02	Tube Temp Out (°F) 105.4
Cp (BTU/lbm·°F)	1.00	1.00	Tav Tube (°F) 97.7
K (BTU/hr·ft·°F)	0.37	0.36	Tube Skin Temp (°F) 102.1

Proto-Power Calc: 97-201

Attachment: E

Rev: A Page 10 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment F to
Proto-Power Calculation
97-201
Revision A**

PROTO-HX™ Version 3.02 MODEL

LASALLE STATION RESIDUAL HEAT REMOVAL
HEAT EXCHANGER.

FILE NAME:	E12-B001.PHX
DATE LAST MODIFIED:	7/16/98
TIME LAST MODIFIED:	1:53:18 PM
FILE SIZE:	960 KB

**ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet**

Design Analysis (Minor Revision)		Last Page No. Attachment A, A2	
Analysis No.: ¹	97-195	Revision: ²	A01
Title: ³	Thermal Model of ComEd/LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers		
EC/ECR No.: ⁴	388666	Revision: ⁵	000
Station(s): ⁷	LaSalle		
Unit No.: ⁸	01 & 02		
Safety/QA Class: ⁹	SR		
System Code(s): ¹⁰	DG		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, AT/AR#: N/A
This Design Analysis SUPERCEDES: ¹³ N/A		In its entirety.	
Description of Changes (list affected pages): ¹⁴ This revision evaluates a maximum cooling water inlet temperature of 107 °F. The previous temperature that was evaluated was 104 °F. Affected pages are Pages 1 - 2 and Attachment A, Pages A1-A2			
Disposition of Changes: ¹⁵ See attached pages. The changes made are acceptable.			
Preparer: ¹⁶	<u>Sean Tanton</u> <small>Print Name</small>	<u>Sean Tanton</u> <small>Sign Name</small>	<u>5/1/12</u> <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	<u>Steve Chon</u> <small>Print Name</small>	<u>Steve Chon</u> <small>Sign Name</small>	<u>5/16/12</u> <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>		
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Reviewer ²¹	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Approver: ²²	<u>DAN SCHMIT</u> <small>Print Name</small>	<u>D Schmit</u> <small>Sign Name</small>	<u>5/18/12</u> <small>Date</small>

Purpose:

The purpose of this revision is to verify that the 0(1)(2)DG01A coolers can remove the design heat load of 8,600,000 BTU/hr with a revised maximum cooling water temperature of 107 °F.

Assumptions:

There are no assumptions for this revision.

Inputs:

- Cooling water temperature = 107 °F (Reference 2)
- Cooling water flow rate = 800 gpm (Reference 1)
- Jacket water temperature for 0(1)(2)DG01A = 190 °F (Reference 1)
- Jacket water flow rate for 0(1)(2)DG01A = 1100 gpm (Reference 1)
- Fouling factor for 0(1)(2)DG01A = 0.0022 hr·ft²·°F/BTU (Reference 1)
- 9 tubes plugged (5% tube plugging) (Reference 1)

References:

1. Design analysis 97-195, Rev. A, up to and including Rev A00
2. EC 388666, Rev. 000
3. EC 384217, Rev. 000

Identification of Computer Programs:

The computer program used in this analysis is Proto HX version 4.01. This program has been validated per DTSQA tracking number EX0000103.

Method of Analysis / Numeric Analysis:

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp" from 104 °F to 107 °F.

Results / Conclusions:

The 0(1)(2)DG01A coolers can remove the design heat load of 8,600,000 BTU/hr with the following conditions:

- 107 °F cooling water temperature
- 800 gpm cooling water flow
- fouling factor of 0.0022 hr·ft²·°F/BTU
- 9 tubes plugged
- jacket water temperature of 190 °F
- jacket water flow rate of 1100 gpm

The total heat removed at these conditions is 8,727,760 BTU/hr, which provides 1.5% thermal margin over the design heat load. The benchmark of the model was shown to perform within 0.13% of the vendor data sheet, which is bounded by the 1.5% thermal margin. Note that the most recent thermal performance evaluation (Ref. 3) shows a maximum fouling factor of 0.000429 hr·ft²·°F/BTU, which shows that there is actually more margin than what is shown in this analysis. The coolers are cleaned on a regular basis to maintain acceptable fouling factors. The previous maximum fouling factor of 0.0022 hr·ft²·°F/BTU was used, which is the bounding fouling factor. This case is shown in Attachment A.

Attachments:

- A. Data Report for 0(1)(2)DG01A (2 pgs)

PROTO-HX 4.00 by Proto-Power Corporation (SN#PHX-1002)
Commonwealth Edison

Data Report for DG01A - DG Jacket Water Cooler

0, 1A, 2A DG - 107 °F tube side, 800 gpm, 190 °F shell side, 1100 gpm, FF = 0.0022, 9 tubes plugged

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,099.45	775.61
Mass Fluid Quantity, Total	lbm/hr	0.00	0.00
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	174.40	122.20
Fouling Factor	hr·ft ² ·°F/BTU	0.00278	0.00000
Shell Fluid Name		Fresh Water	
Tube Fluid Name		Fresh Water	
Design Q (BTU/hr)		8,600,000	
Design U (BTU/hr·ft ² ·°F)		255.20	
Outside h Factor (Hoff)		0.780339000	
Fixed U (BTU/hr·ft ² ·°F)		0	
Fixed Area (ft ²)		0.00	
Performance Factor (% Reduction)		0.00	
Heat Exchanger Type		TEMA - E	
Total Effective Area per Unit (ft ²)		471.23	
Area Factor		0.981978184	
Area Ratio		0.00000	
Number of Shells Per Unit		1	
Shell Minimum Area		0.490000000	
Shell Velocity (ft/s)		5.000	
Tube Pitch (in)		0.7500	
Tube Pitch Type		Triangular	
Number of Tube Passes		2	
U-Tubes		No	
Total Number of Tubes		188	
Number of Active Tubes		179	
Tube Length (ft)		13.00	
Tube Inside Diameter (in)		0.652	
Tube Outside Diameter (in)		0.750	
Tube Wall K (BTU/hr·ft·°F)		112.00	
Lbc, Central Baffle Spacing (in)		0.000	
Lbi, Inlet Baffle Spacing (in)		0.000	
Lbo, Outlet Baffle Spacing (in)		0.000	
Dotl, Tube Circle Diameter		0.000	
Bh, Baffle Cut Height (in)		0.000	
Ds, Shell Inside Diameter (in)		0.000	
Lsb, Diametral difference between Baffle and Shell (in)		0.000	
Ltb, Diametral difference between Tube and Baffle (in)		0.000	
Nss, Number Sealing Strips		0.000	

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

0, 1A, 2A DG - 107 °F tube side, 800 gpm, 190 °F shell side, 1100 gpm, FF = 0.0022, 9 tubes plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 793.98
 Shell Flow (gpm) 1,064.50
 Tube Inlet Temp (°F) 107.00
 Shell Inlet Temp (°F) 190.00
 Input Fouling Factor 0.002200

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr·ft²·°F)
 Shell-Side ho (BTU/hr·ft²·°F)
 Tube-Side hi (BTU/hr·ft²·°F)
 1/Wall Resis (BTU/hr·ft²·°F)
 LMTD Correction Factor
 Overall Fouling (hr·ft²·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft³)		
Cp (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 532,515.63
 Tube Mass Flow (lbm/hr) 397,188.13
 Heat Transferred (BTU/hr) 8,727,760.47
 LMTD 63.8
 Effective Area (ft²) 448.7

Overall Fouling (hr·ft²·°F/BTU) 0.002200
 Shell-Side ho (BTU/hr·ft²·°F) 2,031.5
 Tube-Side hi (BTU/hr·ft²·°F) 2,305.6
 1/Wall Resis (BTU/hr·ft²·°F) 25,594.8
 LMTD Correction Factor 0.9851

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.61
Reynold's Number	82,443	75,787
Prandtl Number	2.1391	3.7108
Bulk Visc (lbm/ft·hr)	0.8239	1.3722
Skin Visc (lbm/ft·hr)	0.8810	1.2526
Density (lbm/ft³)	60.5342	61.7424
Cp (BTU/lbm·°F)	1.0024	0.9988
K (BTU/hr·ft·°F)	0.3861	0.3694

U Overall (BTU/hr·ft²·°F) 309.6
 Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.7
 Tav Shell (°F) 181.8
 Shell Skin Temp (°F) 172.1
 Tube Temp In (°F) 107.0
 Tube Temp Out (°F) 129.0
 Tav Tube (°F) 118.0
 Tube Skin Temp (°F) 127.9

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

DESIGN ANALYSIS NO.: Calc. # 97-195		PAGE NO. 1	
Major REV Number: A		Minor Rev Number: 00	
<input type="checkbox"/> BRAIDWOOD STATION <input type="checkbox"/> BYRON STATION <input type="checkbox"/> CLINTON STATION <input type="checkbox"/> DRESDEN STATION <input checked="" type="checkbox"/> LASALLE CO. STATION <input type="checkbox"/> QUAD CITIES STATION		DESCRIPTION CODE: (C018) <u>M010</u>	
Unit: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3		DISCIPLINE CODE: (C011) <u>M</u>	
		SYSTEM CODE: (C011) <u>DG</u>	
TITLE: THERMAL MODEL OF COMED/LASALLE STATION UNIT 0, 1, AND 2 DIESEL GENERATOR JACKET WATER COOLERS			
<input checked="" type="checkbox"/> Safety Related <input type="checkbox"/> Augmented Quality <input type="checkbox"/> Non-Safety Related			
ATTRIBUTES (C016)			
TYPE	VALUE	TYPE	VALUE
Elevation	710'		
Software	PROTO-HX		
COMPONENT EPN: (C014 Panel)		DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)	
EPN	TYPE	Type/Sub	Document Number
0DG01A	H15	EC/DCP	EC# 334017
1DG01A	H15	/	
2DG01A	H15	/	
		/	
		/	
		/	
		/	
REMARKS: NA			

DESIGN ANALYSIS NO. 97-195

REV: A00 PAGE NO. 2

Revision Summary (including EC's incorporated): Updated ProtoHX model for 104°F Service Water inlet temperature and calculated Unit 0, 1, and 2 DG Cooler thermal margins for different fouling factors and 5% tubes plugged.

Electronic Calculation Data Files: ProtoHX 3.02, dg01a.phx, 704 KB, 04/14/2002, 4:01 pm
(Program Name, Version, File Name extension/size/date/hour/min)

Design impact review completed? Yes N/A, Per EC#: 334017
(If yes, attach impact review sheet)

Prepared by: Jeff W. VanStrien / [Signature] / 1 5/9/02
Print Sign Date

Reviewed by: Brian L. Davenport / [Signature] / 1 5/09/02
Print Sign Date

Method of Review: Detailed Alternate Test

This Design Analysis supersedes: N/A in its entirety.

Supplemental Review Required? Yes No
 Additional Review Special Review Team

Additional Reviewer or Special Review Team Leader: _____
Print Sign Date

Special Review Team: (N/A for Additional Review)

Reviewers: 1) _____ 2) _____
Print Sign Date Print Sign Date
3) _____ 4) _____
Print Sign Date Print Sign Date

Supplemental Review Results:

Approved by: [Signature] / [Signature] / 1 5/14/02
Print Sign Date

External Design Analysis Review (Attachment 3 Attached)

Reviewed by: _____
Print Sign Date

Approved by: _____
Print Sign Date

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? Yes No
Tracked By: AT#, EC# etc.) _____

CALCULATION TABLE OF CONTENTS

CALCULATION NO. 97-195		REV. NO. A00 PAGE NO. 3	
SECTION:	PAGE NO.	SUB-PAGE NO.	
DESIGN ANALYSIS APPROVAL / TITLE PAGE	1		
DESIGN ANALYSIS APPROVAL / REVISION SUMMARY	2		
TABLE OF CONTENTS	3		
1.0 PURPOSE / OBJECTIVE	4		
2.0 METHODOLOGY AND ACCEPTANCE CRITERIA	4		
3.0 ASSUMPTIONS / ENGINEERING JUDGEMENTS	4		
4.0 DESIGN INPUT	4		
5.0 REFERENCES	4		
6.0 CALCULATIONS	5		
7.0 SUMMARY AND CONCLUSIONS	6		
8.0 ATTACHMENTS:	6		
Attachment "A" – Proto-Hx Calc. Report for DG01A (CSCS=104 F @ Design Fouling)	A1 to A3		
Attachment "B" – Proto-Hx Calc. Report for DG01A (CSCS=104 F @ 2X Max. Tested FF)	B1 to B3		
Attachment "C" – Proto-Hx Calc. Report for DG01A (CSCS=104 F @ 2X Max. Tested FF, w\ 5% plugged)	C1 to C3		
Attachment "D" – Proto-Hx Calc. Report for DG01A (CSCS=104 F @ Max. Allowable FF, w\ 5% plugged)	D1 to D3		

E-FORM

CALCULATION PAGE**CALCULATION NO. 97-195****REV. NO. A00****PAGE NO. 4 of 6****1.0 PURPOSE/OBJECTIVE**

The purpose of this minor revision is to revise the thermal model of the Diesel Generator Coolers (0DG01A, 1DG01A, 2DG01A) for a 104°F Service Water inlet temperature. This assessment will evaluate the adequacy of these heat exchangers during a maximum allowable inlet service water temperature of 104°F. Also an acceptable design fouling factor for use as a benchmark during Generic Letter 89-13 testing evaluations will be determined.

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp." from 100°F to 104°F and simulated for the following conditions: (Case 1) design fouling factor, (Case 2) twice the 'as-tested' fouling factor and (Case 3) twice the 'as-tested' fouling factor with a 5% tube plugging allowance. The acceptance criteria will be for the thermal margin at Case 3 conditions to exceed the LaSalle design heat load of 8,600,000 BTU/hr (Ref. 1, Table 3-1). Additional conservatism was built into this acceptance criteria by assuming a 5% uncertainty in the Proto-HX heat transfer calculations. The Reference 1 model developed for this heat exchanger demonstrated a correlation to vendor performance specification well within this assumed 5% margin.

A final case will be evaluated which determines the maximum acceptable fouling factor at which the design heat load can be accommodated including heat transfer model uncertainty.

3.0 ASSUMPTIONS / ENGINEERING JUDGMENTS

The assumptions indicated in section 5.0 of Reference 1 are still valid.

Note: The density of water at 104°F is 61.94 lb/ft³ (per steam tables), this is an insignificant change to the density shown in table 4-1 of Ref. 1 for 100°F, the tube side volumetric flow rate correction made in Ref. 1 is still valid.

4.0 DESIGN INPUTS

The design inputs consist of References 1 and 2 listed below.

5.0 REFERENCES

1. Calculation No. 97-195, Rev. A, "Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers".
2. Calculation L-002211, Rev. 0, "2DG01A, 2A Emergency Diesel Generator Cooler Thermal Heat Transfer Performance"
3. "Standards of the Tubular Exchanger Manufacturers Association" (TEMA), Seventh Edition, 1988.

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-195

REV. NO. A00

PAGE NO. 5 of 6

6.0 CALCULATIONS

The current calculation model is based on a Service Water inlet temperature of 100°F. At this temperature, a maximum fouling factor of 0.002782 hr*ft²*°F/BTU was calculated within reference 1 while maintaining a heat transfer rate of 8,600,000 BTU/hr (Ref. 1, Table 6-3). This is the LaSalle Station Design Heat Load for 110% power operating conditions. Thus, it presents the appearance that no thermal margin exists at these conditions.

Thermal margin is calculated by the following method:

$$\text{Required Heat Load} - \text{Calculated Heat Transfer} = \text{Thermal Margin} \quad [\text{Equation 1}]$$

To express this as a percent of the required heat load, the following method is used:

$$\frac{\text{ThermalMargin}}{\text{RequiredHeatLoad}} \times 100\% = \% \text{ThermalMargin} \quad [\text{Equation 2}]$$

Case 1

When the service water inlet temperature is increased to 104°F for the same fouling factor (0.002782 hr*ft²*°F/BTU), heat transfer reduces to 8,234,000 BTU/hr, which is 4.3% below the design heat load of 8,600,000 BTU/hr for 110% power operating conditions [Attachment A]. With the Diesel Generator operating at 100% power, its design heat load is 7,800,000 BTU/hr resulting in a 5.6% thermal margin at a fouling factor of 0.002782 hr*ft²*°F/BTU.

Case 2

Regular cleaning and testing of these heat exchangers limits the amount of fouling well below the values assumed above. The heat exchanger performance data taken under the G.L. 89-13 program here at LaSalle demonstrates a maximum measured fouling factor of 0.000534 hr*ft²*°F/BTU (Ref. 2, page 9). For conservatism, this value was doubled to 0.001068 hr*ft²*°F/BTU and simulated with 104°F service water inlet temperature. The result was a heat transfer of 12,520,000 BTU/hr for a 45.6% thermal margin at 110% power operating conditions [Attachment B].

Case 3

With additional conservatism included by adding a plugging allowance of 9 tubes, 5% of the total, in the heat exchanger and running the model again at the above fouling factor (0.001068

E-FORM

CALCULATION PAGE**CALCULATION NO. 97-195****REV. NO. A00****PAGE NO. 6 of 6**

hr*ft²*°F/BTU) and inlet temperature (104°F) results in a 12,210,000 BTU/hr heat transfer rate, a 42% thermal margin above the worst case heat load [Attachment C].

A final case was evaluated in which the maximum fouling factor was found to be 0.002200 hr*ft²*°F/BTU for the 110% power operating condition, 104°F inlet temperature and with a 5% plugging allowance [Attachment D]. The resulting heat transferred of 9,032,000 BTU/hr accommodates the design heat load of 8,600,000 BTU/hr including analytical model uncertainty.

This is judged to be a reasonably conservative fouling factor since it is slightly higher than the typical fouling factors stated in Ref. 3, page 215. The LaSalle lake water quality will meet or exceed the "River Water Fouling Factor" (at a velocity greater than 3 ft/sec) given in this reference. The lake water passes through strainers and is chemically treated for silt control and scale prevention.

7.0 SUMMARY AND CONCLUSIONS

The Diesel Generator Jacket Water Cooler Model was found to have adequate thermal margin for a maximum lake temperature of 104°F even when operated at 110% power if fouling is less than 0.002200 hr*ft²*°F/BTU. This fouling factor has been determined to be an acceptable benchmark value that can be used in Generic Letter 89-13 testing evaluations of this model heat exchanger.

8.0 ATTACHMENTS:

- Attachment "A" – Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ Design Fouling)
- Attachment "B" – Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ 2X Max. Tested FF)
- Attachment "C" – Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ 2X Max. Tested FF, w\ 5% plugged)
- Attachment "D" – Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ Max. Allowable FF, w\ 5% plugged)

Final Page**E-FORM**

Attachment "A"

Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ Design Fouling)

E-FORM

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS= 104 F @ Design FF

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	0.00278	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		255.20
Emprical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		471.23
Area Factor		0.981978184
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		188
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 CSCS= 104 F @ Design FF

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 104.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 l/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Calculation No. 97-195
 Revision No. A00
 Attachment A
 Page No. A3 of A3

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.234E+6
 LMTD 67.9
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,035.7
 Tube-Side hi (BTU/hr-ft²-°F) 2,177.8
 l/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9884

U Overall (BTU/hr-ft²-°F) 260.4

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.21
Reynold's Number	8.270E+04	6.978E+04
Prandtl Number	2.13	3.86
Bulk Visc (lbm/ft-hr)	0.82	1.42
Skin Visc (lbm/ft-hr)	0.87	1.30
Density (lbm/ft³)	60.52	61.80
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.6
 Tav Shell (°F) 182.3
 Shell Skin Temp (°F) 173.6
 Tube Temp In (°F) 104.0
 Tube Temp Out (°F) 124.7
 Tav Tube (°F) 114.4
 Tube Skin Temp (°F) 123.7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "B"

Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ 2X Max. Tested FF)

E-FORM

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 104 F @ 2X NDIT FF

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,099.45	775.61
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	174.40	122.20
Fouling Factor		* 0.00278	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			255.20
Empirical Factor for Outside h			0.780339000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			471.23
Area Factor			0.981978184
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.490000000
Shell Velocity (ft/s)			5.000
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			188
Number of Active Tubes			188
Tube Length (ft)			13.00
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			112.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Calculation No. 97-195

Revision No. A00

Attachment BPage No. B2 of B3

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 104 F @ 2X NDIT FF

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions

* Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 104.0
 Shell Inlet Temp (°F) 190.0

* Input Fouling Factor 0.001068

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Calculation No. 97-195
 Revision No. A00
 Attachment **B**
 Page No. **B3** of **B7**

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 1.252E+7
 LMTD 58.4
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.001068
 Shell-Side ho (BTU/hr-ft²-°F) 2,006.8
 Tube-Side hi (BTU/hr-ft²-°F) 2,250.9
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9628

U Overall (BTU/hr-ft²-°F) 472.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.98	8.22
Reynold's Number	8.047E+04	7.349E+04
Prandtl Number	2.19	3.64
Bulk Visc (lbm/ft-hr)	0.84	1.35
Skin Visc (lbm/ft-hr)	0.93	1.19
Density (lbm/ft ³)	60.61	61.72
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 166.5
 Tav Shell (°F) 178.3
 Shell Skin Temp (°F) 164.5
 Tube Temp In (°F) 104.0
 Tube Temp Out (°F) 135.5
 Tav Tube (°F) 119.8
 Tube Skin Temp (°F) 133.9

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "C"

Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ 2X Max. Tested FF & 5% plugged)

E-FORM

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS=104 F@2X NDIT FF, 5% plugged

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	* 0.00278	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr-ft ² -°F)		255.20
Empirical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		471.23
Area Factor		0.981978184
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		179
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr-ft-°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Calculation No. 97-195
Revision No. A00
Attachment C
Page No. C2 of C3

*Fouling Factor input on next page.

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS=104 F@2X NDIR FF, 5% plugged

Calculation Specifications

- Constant Inlet Temperature Method Was Used
- Extrapolation Was to User Specified Conditions
- * Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	795.3
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	* Input Fouling Factor	0.001068

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
Shell Temp Out (°F)
Tav Shell (°F)
Shell Skin Temp (°F)
Tube Temp In (°F)
Tube Temp Out (°F)
Tav Tube (°F)
Tube Skin Temp (°F)

Calculation No. 97-195
 Revision No. A00
 Attachment C
 Page No. C3 of C3

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.001068
Tube Mass Flow (lbm/hr)	3.978E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,007.6
Heat Transferred (BTU/hr)	1.221E+7	Tube-Side hi (BTU/hr-ft ² -°F)	2,335.8
LMTD	59.1	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	448.7	LMTD Correction Factor	0.9655

U Overall (BTU/hr-ft²-°F)

476.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.98	8.63
Reynold's Number	8.063E+04	7.690E+04
Prandtl Number	2.19	3.66
Bulk Visc (lbm/ft-hr)	0.84	1.36
Skin Visc (lbm/ft-hr)	0.93	1.19
Density (lbm/ft ³)	60.61	61.72
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	190.0
Shell Temp Out (°F)	167.1
Tav Shell (°F)	178.6
Shell Skin Temp (°F)	164.5
Tube Temp In (°F)	104.0
Tube Temp Out (°F)	134.7
Tav Tube (°F)	119.4
Tube Skin Temp (°F)	133.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Attachment "D"

Attachment "D" – Proto-Hx Calc. Report for DG01A
(CSCS=104 F @ Max. Allowable FF, w\ 5% plugged)

E-FORM

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS=104 F@Max. FF, 5% plugged

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	* 0.00278	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		255.20
Emprical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		471.23
Area Factor		0.981978184
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		179
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Calculation No. 97-195

Revision No. A00

Attachment 0Page No. 02 of 03

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS=104 F@Max. FF, 5% plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 * Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	795.3
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	* Input Fouling Factor	0.002200

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)	Calculation No. 97-195
Shell Temp Out (°F)	Revision No. A00
Tav Shell (°F)	Attachment <u>D</u>
Shell Skin Temp (°F)	Page No. <u>D3</u> of <u>D3</u>
Tube Temp In (°F)	
Tube Temp Out (°F)	
Tav Tube (°F)	
Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002200
Tube Mass Flow (lbm/hr)	3.978E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,029.5
Heat Transferred (BTU/hr)	9.032E+6	Tube-Side hi (BTU/hr-ft ² -°F)	2,279.5
LMTD	66.1	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	448.7	LMTD Correction Factor	0.9852

U Overall (BTU/hr-ft²-°F) 309.0

Property	Shell-Side	Tube-Side	
Velocity (ft/s)	4.99	8.62	Shell Temp In (°F) 190.0
Reynold's Number	8.228E+04	7.401E+04	Shell Temp Out (°F) 173.1
Prandtl Number	2.14	3.82	Tav Shell (°F) 181.5
Bulk Visc (lbm/ft-hr)	0.83	1.41	Shell Skin Temp (°F) 171.5
Skin Visc (lbm/ft-hr)	0.89	1.28	Tube Temp In (°F) 104.0
Density (lbm/ft ³)	60.54	61.78	Tube Temp Out (°F) 126.7
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 115.4
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 125.7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

**PROTO-POWER CORPORATION
CALCULATION TITLE SHEET**

CLIENT: Commonwealth Edison / LaSalle County Station

PROJECT: COMED / LaSalle Station GL 89-13 Program

CALCULATION TITLE: Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers

CALCULATION NO.: 97-195

FILE NO.: 31-003

COMPUTER CODE & VERSION (if applicable): PROTO-HX ver 3.02

REV	TOTAL NO. OF PAGES	ORIGINATOR/DATE	VERIFIER/DATE	APPROVAL/DATE
A	73	<i>D. Phyfe 6/29/98</i> D. Phyfe	<i>Scott M. Ingalls 6/29/98</i> S. Ingalls	<i>L. Philpot 6/30/98</i> L. Philpot

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE ii OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Revision History

Revision	Revision Description
A	Original Issue

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE iii OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

CALCULATION VERIFICATION FORM

REVIEW METHOD:

- | | | | |
|--|-------------------------------------|-----|-------------------------------------|
| Approach Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Logic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Arithmetic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Alternate Method
(Attach Brief Summary) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Computer Program Used
(Attach Listing) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Other | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |

EXTENT OF VERIFICATION:

- | | |
|-------------------------|-------------------------------------|
| Complete Calculation: | <input checked="" type="checkbox"/> |
| Revised areas only: | <input type="checkbox"/> |
| Other (describe below): | <input type="checkbox"/> |

***Errors Detected**

Minor Editorial

***Error Resolution**

Corrected

***Other Comments**

***Extra References Used**

*(Attach extra sheets if needed)

CALCULATION FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT AND REASONABLE:

IDV Signature: Scott M. Ingalls

Printed Name: Scott M. Ingalls

Initials: SI

Date: 6/29/98

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE iv OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

TABLE OF CONTENTS

CALC TITLE SHEETI
REVISION HISTORY II
CALC VERIFICATION SHEETIII
TABLE OF CONTENTSIV
LIST OF ATTACHMENTS V

Total number of pages in Preface of Calc 5

1. PURPOSE 1
2. BACKGROUND..... 1
3. DESIGN INPUTS 1
 3.1.LASALLE STATION REFERENCE CONDITIONS..... 2
 3.2.CONSTRUCTION DETAILS 2
 3.3.PERFORMANCE DETAILS 3
4. APPROACH 4
 4.1.PROTO-HX™ PARAMETER CALCULATION 4
 4.2.PROTO-HX™ FLOW RATE INPUTS 4
 4.3.PROTO-HX™ EXTRAPOLATION METHOD..... 5
5. ASSUMPTIONS 5
6. ANALYSIS..... 5
 6.1.PROTO-HX™ MODEL..... 5
 6.2.HEAT EXCHANGER FOULING FACTOR LIMIT..... 6
 6.3.FOULING SENSITIVITY..... 7
 6.4.THERMAL MARGIN ASSESSMENT..... 8
 6.5.MINIMUM SERVICE WATER FLOW RATE..... 9
7. CONCLUSION 11
 7.1.PROTO-HX™ MODEL..... 11
 7.2.HEAT EXCHANGER FOULING FACTOR LIMIT..... 11
 7.3.FOULING SENSITIVITY..... 11
 7.4.THERMAL MARGIN ASSESSMENT..... 11
 7.5.MINIMUM SERVICE WATER FLOW RATE..... 11
8. REFERENCES 12

Total number of pages in Body of Calc 12

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE v OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

LIST OF ATTACHMENTS		
<u>Attachment</u>	<u>Subject Matter</u>	<u>Total Pages</u>
A	Proto-Power Calc. 97-195, Rev. A; Vendor Supplied Hx. Information	3
B	Proto-Power Calc. 97-195, Rev. A; Sargent & Lundy Specification J-2544	3
C	Proto-Power Calc. 97-195, Rev. A; Form N-1 Manufacturer's Data Report for Nuclear Vessels	7
D	Proto-Power Calc. 97-195, Rev. A; LaSalle Station UFSAR Sections: 9.2.1.1.1, 9.5.5.1.1, FSAR Q40.92	5
E	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports and Model Data Sheets	13
F	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports for Fouling Sensitivity	6
G	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports for Minimum Service Water Flow	17
H	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Version 3.02 Model	2 (and disk)

Complete Calc (total number of pages)

73

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 1 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

1. PURPOSE

The purpose of this calculation is to develop a thermal performance analysis model for the Commonwealth Edison (ComEd) LaSalle Station, Standby Diesel Generator heat exchanger. This model is to be used for the analysis of heat exchanger thermal performance test data as part of the LaSalle Station heat exchanger testing program.

Once developed, the model is used to evaluate the thermal margin of the heat exchanger at the LaSalle Station Reference Conditions as currently defined in the LaSalle design and licensing basis.

The thermal performance model documented in this calculation has been created and used with PROTO-HX, Version 3.02. The model can be used with previous versions of PROTO-HX and produce identical results as long as the following restrictions are upheld:

- Versions prior to version 3.02 will not calculate a negative fouling factor when calculating the fouling factor based on test data.
- Shell and tube heat exchangers analyzed in Version 3.0 or earlier must have a tube-side Reynolds Number greater than 10,000 (i.e., fully developed turbulent flow).

Current limitations of use for PROTO-HX are established by the limits on fluid properties included within the software. Fluid properties contained within PROTO-HX are currently limited to the following temperature ranges:

- Water (fresh and salt): 32-500°F

2. BACKGROUND

LaSalle Station is in the process of implementing a heat exchanger thermal performance monitoring program in response to the requirements of NRC Generic Letter 89-13 (Reference 8.2). Development of an analytical model in PROTO-HX™, Version 3.02, will allow timely analysis of data resulting from the test program.

3. DESIGN INPUTS

The PROTO-HX™ program was developed and validated in accordance with Proto-Power's Nuclear Software Quality Assurance Program (SQAP). This program meets the requirements of 10CFR50 Appendix B, 10CFR21, and ANSI NQA-1, and was developed in accordance with the guidelines and standards contained in ANSI/IEEE Standard 730/1984 and ANSI NQA-2b-1991. PROTO-HX™ Version 3.02 was verified and approved for use as documented in Reference 8.10.

The design inputs for this calculation consist of the heat exchanger design basis requirement (Section 3.1), construction details (Section 3.2), and performance specifications (Section 3.3) provided by the Hx manufacturer data sheets or design documents as referenced. Construction

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 2 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

details give the necessary information for model construction while performance specifications provided by the manufacturer are used to benchmark the model.

Thermal performance of the Standby diesel generator heat exchanger is assessed in this calculation at the LaSalle Station Reference Conditions of Section 3.1 with all tubes active at 100% and 110% of rated load. No tube plugging margin is considered.

3.1. LASALLE STATION REFERENCE CONDITIONS

Table 3-1 describes the performance requirement of the jacket water cooler. These conditions ensure that the engine operating temperature range will not be exceeded.

Table 3-1 LaSalle Station Reference Conditions

Parameter	Value	Reference
Heat Load at 100% power/110% power (BTU/hr)	7,800,000 / 8,600,000	8.1, 8.4
Shell-Side Flow Rate (gpm)	1,100	8.4
Shell-Side Inlet Temperature (°F)	190	8.4
Tube-Side Flow Rate (gpm)	800	8.1, 8.4
Tube-Side Inlet Temperature (°F)	100	8.1

3.2. CONSTRUCTION DETAILS

Table 3-2 Construction Details

Parameter	Value	Reference
Heat Exchanger Type	AEW	8.11
Total Effective Area per unit (ft ²)	479	8.11
Number of Shells per unit	1	8.11
Shell Velocity (ft/sec)	5	8.11
Tube Passes per shell	2	8.11
U-Tubes (yes or no)	No	8.11
Total Number of Tubes	188	8.11
Tube Length (ft)	13	8.11
Tube Inside Diameter (in)	0.652 (18 BWG)	8.11
Tube Outside Diameter (in)	0.750	8.11
Stationary Tubesheet Thickness (in)	0.938	8.3
Floating Tubesheet Thickness (in)	1.875	8.3
Tube Wall Conductivity (BTU/hr-ft-°F)	112 (Arsenical Cooper)	8.9, (8.11)
Tube Pitch (in)	0.750	8.11

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 3 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 3-2 Construction Details

Parameter	Value	Reference
Pitch Type	Triangle	8.11

The vendor data sheet shows the effective area as 479 ft², however, based on the outside tube diameter and tube length, this value is a gross area (A_{gr}) approximation:

$$A_{gr} = (\text{number of tubes}) \cdot (L_{\text{tube}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 1}$$

$$A_{gr} = 188 \cdot 13 \text{ ft} \cdot \pi \cdot \left(\frac{0.750 \text{ in}}{12 \text{ in/ft}} \right) = 479.878 \text{ ft}^2$$

The effective area (A_{eff}) can be approximated as follows:

$$A_{\text{eff}} = (\text{number of tubes}) \cdot (L_{\text{tube}} - T_{\text{fixed}} - T_{\text{floating}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 2}$$

$$A_{\text{eff}} = 188 \cdot \left(13 \text{ ft} - \frac{(0.938 \text{ in} + 1.875 \text{ in})}{12 \text{ in/ft}} \right) \cdot \pi \cdot \left(\frac{0.750 \text{ in}}{12 \text{ in/ft}} \right) = 471.2251 \text{ ft}^2$$

where :

- A_{gr} – Heat Exchanger Gross Area, ft²
- A_{eff} – Heat Exchanger Effective Area, ft²
- L_{tube} – Tube Length, ft
- T_{fixed} – Fixed End Tubesheet Thickness, ft (0.938" per Reference 8.3)
- T_{floating} – Floating End Tubesheet Thickness, ft (1.875" per Reference 8.3)

The data sheet value for the effective area will be used in the model benchmarking process. However, for PROTO-HX™ runs of the Standby heat exchanger model the above calculated effective area will be used.

3.3. PERFORMANCE DETAILS

Table 3-3 Performance Details

Parameter	Value	Reference
Shell Side Fluid Type	Jacket Water (Fresh)	8.11
Total Fouling Factor (Design)	0.00285	8.11
Shell Side Fluid Flow Rate (lb/hr)	550,000	8.11
Shell Side Inlet Temperature (°F)	190	8.11
Shell Side Outlet Temperature (°F)	174.4	8.11
Tube Side Fluid Type	Service Water (Fresh)	8.1/8.7

PROTO-POWER CORPORATION		CALC NO. 97-195	REV A	PAGE 4 OF 12
GROTON, CONNECTICUT		ORIGINATOR D. Phyfe		DATE 6/29/98
		VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT	COMED / LaSalle County Station		PROJECT COMED / LaSalle Station GL 89-13 Program	
TITLE	Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 3-3 Performance Details

Parameter	Value	Reference
Tube Side Fluid Flow Rate (lb/hr)	388,000	8.11
Tube Side Inlet Temperature (°F)	100	8.11
Tube Side Outlet Temperature (°F)	122.2	8.11
Hx. Design Q - Service (BTU/hr)	8,600,000	8.11
Hx. Design U - Service (BTU/hr-ft ² -°F)	255.2	8.11

4. APPROACH

This calculation utilizes plant/vendor fabrication specifications provided in Attachment (A) to develop a thermal performance prediction model for the LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers. The calculation then benchmarks the model by comparing the heat transfer rate calculated by PROTO-HX™ Version 3.02 with the manufacturer's specifications for thermal performance.

4.1. PROTO-HX™ PARAMETER CALCULATION

Minimum Shell Area

The minimum shell area is calculated using either the shell side velocity or a shell geometry. The preferred method of calculation is using the shell side velocity. Reference 8.11 gives the shell side velocity to be 5 ft/sec at a flow rate of 1100 gpm. Based on this velocity and flow rate the minimum shell side area is calculated by PROTO-HX™ to be 0.490 ft².

Outside H Factor (Hoff)

The Outside H Factor is a multiplier, with value less than 1.0, used to reduce the ideal shell side film heat transfer coefficient. The Outside H Factor accounts for inefficiency in the heat exchanger. Using the back calculation method, based on the design overall heat transfer coefficient, the Outside H Factor was calculated by PROTO-HX™ to be 0.780.

4.2. PROTO-HX™ FLOW RATE INPUTS

Volumetric flow rates are converted to mass flow rates based on a set temperature of 60°F in PROTO-HX™. Therefore, the actual PROTO-HX™ inputs have to be adjusted to give the correct mass flow rate. The PROTO-HX™ input is adjusted using the ratio of the actual water density and the density of water at 60°F.

$$Q_{phx} = Q_{temp} \cdot \frac{\rho_{temp}}{\rho_{60°F}} \quad \text{Equation 3}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 5 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 4-1 PROTO-HX™ Flow Rate Inputs

Parameter	Density (lb/ft ³)	Actual Flow (gpm)	PROTO-HX™ Input (gpm)
Tube-side, 100°F	61.994 (8.12)	800	795.25
Shell-side, 190°F	60.349 (8.12)	1,100	1,064.495
PROTO-HX™, 60°F	62.364 (8.12)		

4.3. PROTO-HX™ EXTRAPOLATION METHOD

All calculations performed for this calculation are based on a constant cold inlet temperature. This allows the comparison of the heat transfer, outlet temperatures, log mean temperature difference (LMTD), and overall heat transfer coefficient. There is no comparison of the overall heat transfer coefficient in the design case since PROTO-HX™ used the data sheet value of the overall heat transfer coefficient to calculate the shell side film heat transfer coefficient.

5. ASSUMPTIONS

- 5.1. The vendor data sheet (Reference 8.11) is considered an accurate reflection of the vendor's expectation for the heat exchanger's outside film heat transfer coefficient. Therefore, the benchmarking of the PROTO-HX™ model to the vendor data sheet will ensure that the PROTO-HX™ calculated outside film heat transfer coefficient is consistent with the vendor's expectation. The PROTO-HX™ model is benchmarked with the vendor data sheet effective area. However, calculations performed with the model use the effective area determined in Section 3.2. Future validation of this assumption is not required.

6. ANALYSIS

6.1. PROTO-HX™ MODEL

Table 6-1 shows the PROTO-HX™ benchmarking of the Jacket Water Cooler for the Standby Diesel Generator. The PROTO-HX™ reports can be found in Attachment E.

Table 6-1 Model Benchmark Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	479	479	0.00 %
Shell Side Outlet Temp, °F	174.4	174.4	0.00 %
Tube Side Outlet Temp, °F	122.2	122.2	0.00 %
Heat Transferred, BTU/hr	8,589,000	8,600,000	-0.13 %
Corrected LMTD	70.3	70.2	0.14 %

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 6 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-2 shows the PROTO-HX™ results for the heat exchanger design conditions using the corrected effective area, Section 3.2. The PROTO-HX™ reports can be found in Attachment E.

Table 6-2 Model Design Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	471.2	479	-1.63 %
Shell Side Outlet Temp, °F	174.6	174.4	0.11 %
Tube Side Outlet Temp, °F	121.9	122.2	-0.25 %
Heat Transferred, BTU/hr	8,481,000	8,600,000	-1.38 %
Corrected LMTD	70.5	70.2	0.43 %

All PROTO-HX™ calculations performed with the Standby Jacket Water Cooler model will use the effective area of 471.23 ft². This change is made to the PROTO-HX™ heat exchanger data sheet as shown in Attachment E.

6.2. HEAT EXCHANGER FOULING FACTOR LIMIT

In order for the jacket water cooler to meet the Reference Conditions (Table 3-1) the fouling must be limited from the values listed on the vendor's data sheet (Reference 8.11). The overall fouling factor limit was determined by iterating on the overall fouling factor, a PROTO-HX™ input, until the required heat load was matched. Table 6-3 shows the results of the PROTO-HX™ runs for the limited fouling factor case, see Attachment E.

Table 6-3 Fouling Factor Limit

Parameter	Design Fouling	Limited Fouling
Overall Fouling Factor	0.00285	0.002782
Overall Heat Transfer Coefficient	255.2	259.7
Heat Transfer Rate	8,484,000	8,600,000
Required Heat Transfer Rate	8,600,000	8,600,000
Thermal Margin	-116,000	0.0
% Thermal Margin	--1.35 %	0.00 %

The limitations on the fouling factor are placed on the tube-side fouling factor, since the tube-side is the most controllable via periodic tube-side cleaning. To be consistent with the HPCS Diesel the shell-side fouling factor will be set to 0.0005 hr ft² °F/Btu for this analysis. The tube-side fouling factor is calculated from the overall fouling found from the PROTO-HX™ iteration process.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 7 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

The area ratio is used to convert the overall fouling factor to a tube-side and shell-side fouling factor

$$f_{\text{total}} = f_{\text{shell}} + (\text{Area Ratio}) \cdot f_{\text{tube}} \quad \text{Equation 4}$$

$$\text{Area Ratio} = \frac{\text{Tube OD}}{\text{Tube ID}} \quad \text{Equation 5}$$

$$\text{Area Ratio} = \frac{0.750 \text{ in}}{0.652 \text{ in}} = 1.150$$

From the vendor datasheet the design overall fouling factor is

$$f_{\text{Total}} = 0.002850 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

From the PROTO - HX iteration the adjusted overall fouling factor is found :

$$f_{\text{adjusted}} = 0.002782 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

From the new overall fouling factor the new tube - side fouling factor is calculated :

$$f_{\text{tube}} = \frac{(f_{\text{adjusted}} - f_{\text{shell}})}{\text{Area Ratio}} = \frac{(0.002782 - 0.0005) \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}}{1.150} = 0.001984 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

The PROTO-HX™ heat exchanger data sheet is changed to reflect the adjusted design fouling as calculated above. Like the effective area change in the heat exchanger data sheet, this change is made without recalculating the Hoff factor.


Attachment E includes a final model calculation report for the Reference Conditions and the adjusted tube-side fouling entered into the PROTO-HX™ data sheet.

6.3. FOULING SENSITIVITY

The fouling sensitivity of the jacket water cooler is shown in Figure 6-1. The fouling sensitivity was developed at 800 gpm CSCS flow, 100°F CSCS inlet temperature, 1100 gpm jacket water flow, and 190°F jacket water inlet temperature. The tube-side fouling factor was varied from 0.0000 to 0.001984 (hr ft² °F/Btu) by increments of 0.0005 (hr ft² °F/Btu). As in Section 6.2, the shell-side fouling factor is held constant at 0.0005 (hr ft² °F/Btu). The PROTO-HX™ Calculation Reports for the fouling sensitivity can be found in Attachment F.

PROTO-POWER CORPORATION		CALC NO. 97-195	REV A	PAGE 8 OF 12
GROTON, CONNECTICUT		ORIGINATOR D. Phyfe		DATE 6/29/98
		VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT	COMED / LaSalle County Station		PROJECT COMED / LaSalle Station GL 89-13 Program	
TITLE	Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Figure 6-1



6.4. THERMAL MARGIN ASSESSMENT

The clean thermal margin is assessed by a comparison of the reference condition performance requirements to the heat exchanger performance capability with a zero (0) fouling factor. Using a zero (0) fouling factor shows the maximum available performance of the heat exchanger. Likewise, the service thermal margin is assessed by comparing the reference condition performance requirements to the heat exchanger performance capability with the design fouling factor.

The margin is calculated directly and as a percentage compared to the required heat rate to perform the component's safety function. The PROTO-HX™ reports can be found in Attachment E.

$$\text{margin} = \text{Heat Rate} - \text{Heat Rate}_{\text{required}} \quad \text{Equation 6}$$

$$\% \text{ margin} = 100 \cdot \left(\frac{\text{margin}}{\text{Heat Rate}_{\text{required}}} \right) \quad \text{Equation 7}$$

PROTO-POWER CORPORATION		CALC NO. 97-195	REV A	PAGE 9 OF 12
GROTON, CONNECTICUT		ORIGINATOR D. Phyfe		DATE 6/29/98
		VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT	COMED / LaSalle County Station		PROJECT COMED / LaSalle Station GL 89-13 Program	
TITLE	Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-4 Thermal Margin

Parameter	Service (Design Fouling)	Clean (0 Fouling)
Overall Heat Transfer Coefficient	259.7	955.9
Heat Transfer Rate	8,600,000	18,850,000
Required Heat Transfer Rate	8,600,000	8,600,000
Thermal Margin	0.0	10,250,000
% Thermal Margin	0.00 %	119.19 %

6.5. MINIMUM SERVICE WATER FLOW RATE

The minimum service water flow rate for the adjusted design fouling condition is calculated with the shell-side inlet temperature at 190°F and a flow rate of 1,100 gpm. Iterating using the service water flow rate and inlet temperature, the minimum acceptable flow rate is found for each inlet temperature (Attachment G). The heat load for each iteration must be equal to or slightly above the required heat load of 7,800,000 BTU/hr and 8,600,000 BTU/hr, the diesel heat load at 100% and 110% power, respectively (Reference 8.1). Figure 6-2 shows the results of this iteration process.

The results of the model iterations are summarized in Table 6-5 and Table 6-6 along with Figure 6-2. Density corrections of the PROTO-HX™ flow rates are made in accordance with Equation 3. Values for fluid density are obtained from Reference 8.12.

Table 6-5 Minimum CSCS Flow Rate at 100% Power


CSCS Inlet Temperature (°F)	Density at Inlet Temperature (lbm/ft³)	PROTO-HX™ Input Flow Rate (gpm)	Density Corrected Flow Rate (gpm)
35	62.41903	161.1	161.0
40	62.42184	169.8	169.6
50	62.40595	190.5	190.3
60	62.36445	217.5	217.5
70	62.30034	254.2	254.5
80	62.21603	307.0	307.7
90	62.11349	389.3	390.9
100	61.99437	534.5	537.7

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 10 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-6 Minimum CSCS Flow Rate at 110% Power

CSCS Inlet Temperature (°F)	Density at Inlet Temperature (lbm/ft ³)	PROTO-HX™ Input Flow Rate (gpm)	Density Corrected Flow Rate (gpm)
35	62.41903	193.5	193.3
40	62.42184	204.8	204.6
50	62.40595	232.2	232.1
60	62.36445	269.1	269.1
70	62.30034	321.0	321.3
80	62.21603	399.3	400.3
90	62.11349	530.9	533.1
100	61.99437	795.3	800.0

Figure 6-2 Minimum Service Water Flow



PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 11 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

7. CONCLUSION

7.1. PROTO-HX™ MODEL

The Standby Jacket Water Cooler model was developed using PROTO-HX™, Version 3.02. The model was benchmarked to the vendor data sheet. The benchmark model correlation to the vendor data sheet is -0.13 %. The benchmark model is for reference only based on the non-conservative approximation of heat exchanger effective area as discussed in Section 3.2 and Assumption 5.1. Calculations performed with the Standby Jacket Water Cooler model are to use the effective area developed in Section 3.2.

This model should be considered suitable for use in the analysis of thermal performance test data.

The model database is saved under file name dg01a.phx, with a file size of 640 KB, and a file date and time of 6/29/98 at 1:50:34 PM. The saved database is set up to run the Reference Conditions with design fouling factor selected, the design fouling factor is a shell-side fouling of 0.002782. The database file is included as Attachment H.

7.2. HEAT EXCHANGER FOULING FACTOR LIMIT

For the Standby Diesel Generator Jacket Water Cooler to provide adequate heat removal at the specified LaSalle Station Reference Conditions the overall fouling factor must be equal to or less than 0.002782 hr ft² °F/Btu. This overall fouling factor is entered in the model as the shell-side design fouling factor.

7.3. FOULING SENSITIVITY

Given a constant shell-side fouling at the model design value, the sensitivity of the jacket water cooler to tube-side fouling effects is shown on Figure 6-1.

7.4. THERMAL MARGIN ASSESSMENT

Assuming the adjusted heat exchanger effective area and maximum overall fouling factor, the clean and service available thermal margins are 119.19 % and 0.00 % respectively.

7.5. MINIMUM SERVICE WATER FLOW RATE

As shown in Figure 6-2 the service water flow can be throttled down to account for lower service water inlet temperature conditions. The heat exchanger can remove the design heat load for the diesel at 100% (7,800,000 BTU/hr) and 110% (8,600,000 BTU/hr) rated power, by reducing service water flow rates as the service water temperature decreases.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 12 OF 12
	ORIGINATOR D. Phyfe	DATE 6/29/98	
	VERIFIED BY S. Ingalls	JOB NO. 31-003	
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

8. REFERENCES

- 8.1. LaSalle Station UFSAR, Sections: 9.2.1.1.1, 9.5.5.1.1 (Attachment D)
- 8.2. NRC Generic Letter 89-13
- 8.3. The National Board of Boiler and Pressure Vessel Inspectors, Form N-1 Manufacturers' Data Report for nuclear Vessels (Attachment C)
- 8.4. LaSalle Station FSAR Q40.92 (Attachment D)
- 8.5. Stewart & Stevens Vendor Manual, VM J-152 through VM J-157
- 8.6. LaSalle Station Drawing, D-22079
- 8.7. Sargent and Lundy Specification J-2544 (Selected Pages, Attachment B)
- 8.8. Not used
- 8.9. Standard of the Tubular Exchanger Manufacturers Association
- 8.10. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.02 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision F, dated 2/17/98
- 8.11. American Standard Heat Exchanger Data Sheet for the LaSalle Station Standby Diesel Generator Jacket Water Coolers. (Attachment A)
- 8.12. Proto-Power Calculation 93-048, "Fluid Properties – Fresh Water – Range 32°F to 500°F", Rev. A

**Attachment A to
Proto-Power Calculation
97-197
Revision A**



EX-111

JUN -5 1998

STEWART & STEVENSON SERVICES, INC.

RECIPROCATING ENGINE SALES

8631 EAST FREEWAY

HOUSTON, TEXAS 77029

WE ARE TRANSMITTING 2 PAGE(S) INCLUDING COVER. IF INCOMPLETE, PLEASE CALL, 713/671-6218 OR 713/671-6152

PLEASE DELIVER TO:

DATE:

6/4/98

NAME:

Duncan Phyfe

FROM:

Robert E. Mitcham

FIRM:

COMED

PHONE:

713/671-6 137

FAX:

868-446-8292

FAX:

713/671-6127

REF:

LaSalle Heat Exchanger Data Sheets

Please find enclosed data sheets
you requested

- Robert Mitcham

Proto-Power Calc: 97-195

Attachment: A

Rev: A Page 2 of 3



HEAT TRANSFER DIVISION
BUFFALO, N. Y. 14240

HEAT EXCHANGER SPECIFICATION SHEET

1	P. Order NO. F-68683-77339	
2	CUSTOMER Stewart & Stevenson for Commonwealth Edison	REFERENCE NO. HU-974-126 Rev. 1
3	ADDRESS LaSalle County Station Units 1 and 2	INQUIRY NO. June 27, 1975
4	PLANT LOCATION	DATE
5	SERVICE OF UNIT Jacket Water Cooler	ITEM NO. 01 Alt.
6	SIZE 15156 CPK	TYPE TEMA AEW#
7	SQ. FT. SURF./UNIT (GROSS) (EPP.) 479	SHELLS/UNIT One
		SQ. FT. SURF./SHELL (GROSS) (EPP.) 479

PERFORMANCE OF ONE UNIT			
	SHELL SIDE		TUBE SIDE
9	FLUID CIRCULATED		Raw Water
10	TOTAL FLUID ENTERING		388,000 #/Hr
11	VAPOR		
12	LIQUID		388,000 #/Hr
13	STEAM		
14	NON-CONDENSABLES		
15	FLUID VAPORIZED OR CONDENSED		
16	STEAM CONDENSED		
17	GRAVITY		
18	VISCOSITY		
19	MOLECULAR WEIGHT		
20	SPECIFIC HEAT		BTU/LB-°F
21	THERMAL CONDUCTIVITY		BTU/HR-FT-°F
22	LATENT HEAT		BTU/LB
23	TEMPERATURE IN		100 °F
24	TEMPERATURE OUT		122.2 °F
25	OPERATING PRESSURE		PSIG
26	NO. PASSES PER SHELL		Two
27	VELOCITY		FT/SEC
28	PRESSURE DROP		PSI
29	FOULING RESISTANCE (MIN.)		.00285 Total
30	HEAT EXCHANGED-BTU/HR		8.6 x 10 ⁶
31	TRANSFER RATE-SERVICE		255.2
32	MTD CORRECTED-°F		70.2
33	CLEAN		

CONSTRUCTION OF ONE SHELL			
34	DESIGN PRESSURE	150	PSI
35	TEST PRESSURE	225	PSI
36	DESIGN TEMPERATURE	300	°F
37	TUBES ARE Copper Alloy 142 No. 188 o.d. 3/4" BWG. 18 LENGTH 156" PITCH 3/4" Tri.		
38	SHELL Steel	I.D. 16"	O.D. 16"
39	CHANNEL COVER Muntz	SHELL COVER None	
40	TUBESHEET-STATIONARY Muntz	CHANNEL COVER Steel	
41	BAFFLES-CROSS Steel TYPE	TUBESHEET-FLOATING Muntz	
42	BAFFLES-LONG TYPE	FLOATING HEAD COVER	
43	TUBE SUPPORTS Steel	IMPINGEMENT PROTECTION No	
44	TUBE TO TUBESHEET JOINT Rolled		
45	GASKETS Comp. Asbestos	Packing - Neoprene	
46	CONNECTIONS-SHELL SIDE IN 10"	OUT 10"	RATING 150# ANSI
47	CHANNEL SIDE IN 8"	OUT 8"	RATING 150# ANSI
48	CORROSION ALLOWANCE-SHELL SIDE 1/16" on C. Steel		
49	TUBE SIDE 1/16" on C. Steel		
50	CODE REQUIREMENTS ASME Code III - 3 Stamped		
51	TEMA CLASS "1C"		
52	WEIGHTS-EACH SHELL 3260		
	BUNDLE 1860		
	FULL OF WATER 4410		
NOTE: INDICATE AFTER EACH PART WHETHER STRESS RELIEVED (S.R.) AND WHETHER RADIOGRAPHED (X-R)			
REMARKS: "Removable Tube Bundle			
American Standard P/N 5-046-15-156-001		Proto-Power Calc: 97-195	
American Standard Serial No. 8-20005		Attachment: A	
Rev: A Page 3 of 3			

FORM 100-7 N.Y. REVISED 8-70

**Attachment B to
Proto-Power Calculation
97-195
Revision A**

REFERENCE 8.7

include a shell and tube heat exchanger which will be supplied with cooling water from the Purchaser's cooling water system.

- b. The closed cooling water system pump shall be of the centrifugal type and shall be driven by the engine.
- c. The shell and the tube heat exchanger shall be of the capacity required for 110 percent of rated power with a fouling factor of 0.0005 on shell side and .002 on the tube side. The heat exchanger shall be in accordance with the requirements of ITEM A, TEMA (Tube Exchanger Manufacturers' Association) Class C and the ASME Code Section III. The type bundle shall be removable without removing shell from its mounting. The tubes shall be 5/8 inch minimum and be of admiralty metal.
- d. The circulating water system shall be provided with controls which will sense and maintain optimum jacket water temperature.
- e. Cooling water supply for the heat exchangers will be at a maximum inlet temperature of 100°F and a minimum of 32°F. The coolers shall be designed for a 150 psig water working pressure and tested at a hydraulic pressure of 225 psig.

F. Starting System

- a. Each engine shall be equipped with an independent pneumatic starting system complete with all valves, integral piping, controls, etc.
- b. The reliability of the starting system is paramount and no compromise of the starting capability shall be made with other basic requirements of the equipment design. Any special devices or auxiliaries required to insure successful starting shall be provided, except any equipment of an experimental type will be unacceptable. Contractor shall describe in his proposal what occurrences are possible to preclude successful starting, and what remedies would be necessary that are not already provided for in the equipment design.
- c. The compressed air starting system shall consist of two redundant sets of equipment, each completely independent of the other for successful operation. A cross-connecting line with a normally closed valve shall be provided between sets. The accumulator furnished with each set of equipment shall have the capacity for a minimum of three normal cranking cycles in rapid succession without the use of its air compressor. Each accumulator shall be furnished with a shut-off cock, pressure gauge drain valve, safety valve, and sensing element for low pressure alarm.

Proto-Power Calc: 97-195

Attachment: B

Rev: A Page 2 of 3

REFERENCE 8.7

Name of Bidder: Stewart & Stevenson Services, Inc.

ENGINE-GENERATOR DATA, Cont.	(Insert all data in these columns)		
	BASE BID		ALTERNATE 1
	DIESEL GEN. 0	DIESEL GEN. 1A AND 2A	DIESEL GEN. 0, 1A AND 2A
(Contractor to furnish complete information for starting system furnished)			
E. Engine Cooling System:			
a. Cooling system capacity.(gal)	545		
b. Pipe size for cooling water connections.....(in)	8		
c. Heat exchanger dimensions:			
(1) Length.....(in)	179.5		
(2) Diam.....(in)	16"		
(3) Height.....(in)	19.5"		
→ d. Quantity of cooling water at rated load, required at 80°F.....(gal/min)	550		
at 95°F.....(gal/min)	750		
at 100°F.....(gal/min)	840		
→ e. Tube material.....	Arsenical Copper (SB111)		
→ f. Diameter and thickness of tubes.....(in)	3/4" x 18 BWG		
g. Total tube cooling surface.....(ft ²)	479		
h. Water box material.....	Carbon Steel		
	Weights: 3050 lbs Dry 4350 lbs Wet		

**Attachment C to
Proto-Power Calculation
97-195
Revision A**

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION - BUFFALO, NEW YORK 14240
(Name and address of Manufacturer)
2. Manufactured for STEWART-STEVENSON SERVICES; HOUSTON, TEXAS
(Name and address of Purchaser)
3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-PI-1 Nat'l Id. No. 29386 Yr. Built 1976
(Horiz. or Vert.) (Heat Exch. Heat Ex.) (Mfg. Serial No.) (State & State No.)
3a. Applicable ASME Code: Section III, Edition 1974, Addenda date WINTER 1974, Case No. _____
Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SMLS STL Nominal Thickness 375 Corrosion Allowance 0.03 in. Dia. 16.000 ft. Length 152.438 ft.
(Kind & Spec. No.) (Min. of range specified) in. in. in. ft. in. ft.
5. Seams: Long SMLS H.T. NO R.T. NONE Efficiency 100 %
Girth _____ H.T. _____ R.T. _____ No. of Courses 1

6. Heads (a) Material T.S. (b) Material T.S.
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. Jacket Closure _____
(Describe as open & weld, bar, etc. If bar give dimensions, describe or sketch)
Drop Weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure 225 psi
8. Design Pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material MUNTZ SB7 Dia. 17.250 in. Thickness 0.38 in. Attachment BOLTED
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)
Floating. Material MUNTZ SB7 Dia. 15.000 in. Thickness 0.375 in. Attachment BOLTED
(Kind & Spec. No.)
10. Tubes: Material ARS. COPPER SB 111 O.D. 3/4 in. Thickness 18 inches or gage Number 188 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material CHANNEL SMLS STL Nominal Thickness 375 Corrosion Allowance 0.03 in. Dia. 16.000 ft. Length 14.000 ft.
(Kind & Spec. No.) (Min. of range specified) in. in. in. ft. in. ft.
12. Seams: Long SMLS H.T. NO R.T. NONE Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)
Girth _____ H.T. _____ R.T. _____ No. of Courses 1
13. Heads (a) Material F.Q. STL SA285-C T.S. 55,000 (b) Material _____ T.S. _____ (c) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(a) Top, bottom, ends 1.250 19.500 FLAT
(b) Channel _____
(c) Floating _____

14. Design pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____
(Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)
Drop weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure 225 psi
Attachment C

FORM N-1 (back)

Items below to be completed for all vessels where applicable.

- 13. Safety Valve Outlets: Number _____ Size _____ Location _____
- 16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. of Size	Type	Material	Thickness	Reinforcement Material	How Attached
SHELL IN & OUT	2	10"-150# ASA PIPE	FLG.	SA106B	.307	-	WELDED
TUBE IN & OUT	2	8"-150# ASA PIPE	FLG.	SA106B	.277	-	WELDED
- 17. Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____
- 18. Supports: Skirt NO Lugs _____ Legs _____ Other CRADLES Attached WELDED TO SHELL
 (Yes or No) (Number) (Number) (Describe) (Where & How)
- 19. Remarks: JACKET WATER COOLER

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file AMERICAN STD. HEAT TRANS. DIV. BUFFALO N.Y.
 Stress analysis report on file NOT APPLICABLE TO SECTION III CLASS 3 VESSEL
 Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21850
 Stress analysis report certified by NOT APPLICABLE Prof. Eng. State _____ Reg. No. _____

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III. AMERICAN STANDARD HEAT TRANSFER DIVISION
 Date 2/26/76 Signed TRANSFER DIVISION By R. R. Warner
 (Manufacturer) (K. R. Warner - Manager, Q.C.)

Certificate of authorization Expires AUGUST 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois
 have inspected the pressure vessel described in this Manufacturer's Data Report on February 26, 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date February 26, 1976
 Inspector's Signature J. A. Thomas Commission NB 7710
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of _____ psi.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____
 Inspector's Signature _____ Commission _____
 National Board, State, Province and No.

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS

As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION, BUFFALO, NEW YORK 14240

2. Manufactured for STEWART-STEVENSON SERVICES, HOUSTON, TEXAS

3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-01-2 Nat'l Id. No. 29387 Yr. Built 1976

4. Applicable ASME Codes Section III, Edition 1974, Addenda date WINTER 1974, Case No. Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell Material SA106-B T.S. 60,000 Nominal Thickness 375 Corrosion Allowance .063 in. Dia. 16.000 in. Length 152.438 in.

5. Seams Long SMA's H.T. NO R.T. NONE Efficiency 100%

Girth H.T. R.T. No. of Courses 1

6. Heads (a) Material T.S. (b) Material T.S.

Table with 9 columns: Location, Thickness, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Press. Rows (a) and (b) are blank.

If removable, bolts used Other fastening

7. Jacket Closure

8. Design Pressure 150 psi at 300 F at temp. of Test Pressure 225 psi

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet Stationary Material MONIZ SB717 Dia. 11.250 in. Thickness .938 in. Attachment BOLTED

Floating Material MONIZ SB717 Dia. 15.000 in. Thickness .875 in. Attachment BOLTED

10. Tubear Material SB 111 O.D. 3/4 in. Thickness .18 in. Number 188 Type STRAIGHT

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell Material SA106-B T.S. 60,000 Nominal Thickness 375 Corrosion Allowance .063 in. Dia. 16.000 in. Length 14.000 in.

12. Seams Long SMA's H.T. NO R.T. NONE Efficiency 100%

Girth H.T. R.T. No. of Courses 1

13. Header (a) Material SA385-C T.S. 55,000 (b) Material T.S. (c) Material T.S.

Table with 9 columns: Location, Thickness, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Press. Rows (a) and (b) are filled with data.

If removable, bolts used (a) 125,000 5/8-16 (b) Other fastening

14. Design pressure 150 psi at 300 F at temp. of Test Pressure 225

1 If Postweld Heat-Treated 2 List other internal or external pressures with coincident temperature when applicable.

Pre-Post Power Calc 97199 Attachment: C Rev. A Page 4 of 7

NB# 29387

FORM N-1 (back)

Items below to be completed for all vessels where applicable.

- 15. Safety Valve Outlets: Number _____ Size _____ Location _____
- 16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
SPELLING OUT	2	10" 150# ASA PIPE	(FLG. SA106B)		307		WELDED
TUBING OUT	2	8" 150# ASA PIPE	(FLG. SA106B)		277		WELDED
- 17. Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____
- 18. Supports: Skirt NO Legs _____ Legs _____ Other CRADLES Attached WELDED TO SHELL
 (Yes or No) (Number) (Number) (Describe) (Where & How)
- 19. Remarks: JACKET WATER COOLER

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file at AMERICAN S.I.P. HEAT TRANS. DIV. BUFFALO N.Y.
 Stress analysis report on file at NOT APPLICABLE TO SECTION III CLASS B VESSEL
 Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21850
 Stress analysis report certified by NOT APPLICABLE Prof. Eng. State _____ Reg. No. _____

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III. AMERICAN STANDARD HEAT TRANSFER DIVISION
 Date 2/26/76 Signed R. R. Warner By R. R. Warner - Manager, Q.C.
 (Manufacturer)
 Certificate of authorization Expires August 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois
 have inspected the pressure vessel described in this Manufacturer's Data Report on February 26 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date February 26 1976
 Inspector's Signature J. A. Thomas Commission NB 7710
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of _____ psi.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ 19_____
 Inspector's Signature _____ Commission _____
 National Board, State, Province and No.

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION - BUFFALO, NEW YORK 14240
(Name and address of Manufacturer)
2. Manufactured for STEWART-STEVENSON SERVICES; HOUSTON, TEXAS
(Name and address of Purchaser)
3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-PI-9 (Name, serial No.) (State & State No.) 29388 Nat'l Id. No. 1976 Yr. Built
(11012, or Vess.) (Type & Spec. No.) (Min. of range specified)
3a. Applicable ASME Code: Section III, Edition 1974, Addenda date WINTER 1974, Case No. 3
Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SMLS-5TL Nominal Thickness 375 Corrosion Allowance 0.03 Dia. 16.000 Length 152.438
(Kind & Spec. No.) (Min. of range specified) in. in. ft. in. in.
5. Seams: Loog SMLS H.T. NO R.T. NONE Efficiency 100 %
Girth - H.T. - R.T. - No. of Courses 1

6. Heads (a) Material T.S. (b) Material T.S.
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press.
(Top, bottom, ends) (Welded, Bolted)

If removable, bolts used (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or attach sketch)

7. Jacket Closure (Describe as open & weld, bar, etc. If bar give dimensions, describe or sketch)
Drop Weight Pneumatic
Charpy Impact ft-lb Hydrostatic or Test Pressure

8. Design Pressure: 150 psi at 300 °F at temp. of - °F. Combination Pressure 225 psi

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material MUNTZ SB71 Dia. 11.250 in. Thickness .438 in. Attachment BOLTED
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)
Floating. Material MUNTZ SB71 Dia. 15.000 in. Thickness .875 in. Attachment BOLTED
ARS. COPPER
10. Tubes: Material SA311 O.D. 3/4 in. Thickness 18 inches Number 188 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material CHANNEL SMLS 5TL Nominal Thickness 375 Corrosion Allowance 0.03 Dia. 16.000 Length 14.000
(Kind & Spec. No.) (Min. of range specified) in. in. ft. in. in.

12. Seams: Loog SMLS H.T. NO R.T. NONE Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)
Girth - H.T. - R.T. - No. of Courses 1

13. Header (a) Material F.Q. 5TL (b) Material SA385-C T.S. 55,000 (c) Material T.S.
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press.
(Top, bottom, ends) (Welded, Bolted)

If removable, bolts used (a) 25,000 5/8-16 (b) 16 (c) 16 Other fastening (Describe or attach sketch)
Drop weight Pneumatic
Charpy Impact ft-lb Hydrostatic or Test Pressure

14. Design pressure: 150 psi at 300 °F at temp. of - °F. Combination Pressure 225 psi

* If Postweld Heat-Treated
† List other internal or external processes with coincident temperature when applicable.

Power-Calco 97-1
Attachment: C
Rev: A Page 6 of 7

NB# 29388

FORM N-1 (back)

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement, Material	How Attached
SHELL IN & OUT	2	10"-150# ASA	PIPE	FLG. SA106B	.307	---	WELDED
TUBE IN & OUT	2	8"-150# ASA	PIPE	FLG. SA106B	.277	---	WELDED

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt NO Lugs _____ Legs _____ Other CRADLES Attached WELDED TO SHELL
(Yes or No) (Number) (Number) (Describe) (Where & How)

19. Remarks: JACKET WATER COOLER.

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file AMERICAN STD. HEAT TRANS. DIV. BUFFALO NY.
Stress analysis report on file NOT APPLICABLE TO SECTION III CLASS 3 VESSEL
Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21850
Stress analysis report certified by NOT APPLICABLE Prof. Eng. State _____ Reg. No. _____

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III. **AMERICAN STANDARD HEAT**

Date: 2/26/76 19 76 Signed TRANSFER DIVISION By R. R. Warner
(Manufacturer) (R. R. Warner - Manager, Q.C.)

Certificate of authorization Expires AUGUST 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois

have inspected the pressure vessel described in this Manufacturer's Data Report on February 26 19 76, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date February 26 19 76
J. A. Thomas Inspector's Signature Commission NB 7710
National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____

have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as date items _____, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of _____ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19 _____
Inspector's Signature _____ Commission _____
National Board, State, Province and No.

**Attachment D to
Proto-Power Calculation
97-195
Revision A**

REFERENCE 8.1

LSCS-UFSAR

9.2 WATER SYSTEMS

The auxiliary water systems for the LaSalle County Station are as follows:

- a. CSCS equipment cooling water system,
- b. station service water system,
- c. reactor building closed cooling water system,
- d. demineralized water makeup system,
- e. potable and sanitary water system,
- f. ultimate heat sink,
- g. cycled condensate system and refueling water storage facilities,
- h. turbine building closed cooling water system (TBCCWS),
- i. primary containment chilled water system,
- j. station heat recovery system,
- k. suppression pool cleanup system, and
- l. chemical feed system.

9.2.1 CSCS Equipment Cooling Water System

The function of the core standby cooling system-equipment cooling water system (CSCS-ECWS) is to circulate lake water from the ultimate heat sink for cooling of the residual heat removal (RHR) heat exchangers, diesel-generator coolers, CSCS cubicle area cooling coils, RHR pump seal coolers, and low-pressure core spray (LPCS) pump motor cooling coils. This system also provides a source of emergency makeup water for fuel pool cooling and also provides containment flooding water for post-accident recovery. This CSCS-ECWS system is equivalent in purpose to the essential service water cooling systems at other stations.

9.2.1.1 Design Bases

9.2.1.1.1 Safety Design Bases

- a. The system is sized based on the following minimum equipment cooling water flow requirements:
 1. RHR heat exchanger - 7400 gpm
 2. diesel-generator cooler (division 1 and 2 only) - 800 gpm
 3. diesel-generator cooler (division 3) - 650 gpm

Proto-Power Calc: 97-195

Attachment: D

Rev: A Page 2 of 5

REFERENCE 8.1

LSCS-UFSAR

9.5.4.5 Instrumentation and Controls

Fuel levels in each day tank and storage tank are indicated locally, and storage tank levels are also indicated at each storage tank filling station. Control room alarms annunciate high or low levels in each day tank and low level in each storage tank. All day tank level instruments and diesel-generator transfer pump controls are Seismic Category I and Class 1E. A local pressure indicator is connected to the discharge of each transfer pump to monitor pump discharge head. A local differential pressure indicator is connected across the transfer pump suction strainer to identify a clogged strainer.

Each diesel engine gauge panel includes local gauges for monitoring the following diesel-generator skid-mounted system fuel oil parameters: fuel oil temperature, fuel pump suction strainer inlet and outlet pressure (Divisions 1 and 2 diesel generators only), fuel pump discharge pressure, fuel filter inlet pressure, and fuel filter outlet pressures (for the Division 3 diesel generators, filter inlet and outlet pressure gauges are mounted on the engine and not on the gauge panel). In addition, pressure switches are installed in the skid-mounted systems to annunciate high fuel filter differential pressure for the Divisions 1 and 2 diesel generators and low fuel pump discharge pressure for the Division 3 diesel generators. The entire skid-mounted fuel oil system, including instrumentation, is supplied by the engine manufacturer as a part of the diesel engine.

Each diesel-generator fuel transfer pump is started and stopped automatically by day tank level control switches. The diesel fire pump fuel transfer pump is started manually; however, it is automatically shut down by day tank high level. Elapsed time instrumentation monitors diesel-generator transfer pump running time and, when the diesel engine is operating, pump shutdown time. This instrumentation actuates control room alarm lights if pump running time is excessive or shutdown time is too short to permit remote detection of possible fuel oil leaks at the day tank or diesel generator.

9.5.5 Diesel-Generator Cooling Water System

The function of the diesel-generator cooling water system is to transfer the heat rejected from the engine water jacket, the lube oil cooler and the engine air aftercooler to the CSCS equipment cooling water system (CSCS-ECWS).

9.5.5.1 Design Bases

9.5.5.1.1 Safety Design Bases

Cooling capacity of this system is based on a diesel-generator output of 2860 kW with an environmental temperature of 122° F maximum and a minimum and maximum lake water temperature of 32° F and 100° F, respectively. Total heat transfer by this system is

REFERENCE 8.1

LSCS-UFSAR

approximately 7.8×10^6 Btu/hr per diesel-generator set at rated engine capacity. The diesel cooling water heat exchangers are sized based on operation of 110% of rated load.

High water temperature is alarmed at 200° F and the engine is automatically shut down if the cooling water temperature at the engine outlet exceeds 208° F in order to prevent engine damage due to overheating. This shutdown control is in effect only when the engine is started manually and bypassed when the diesel generator is started automatically during an emergency.

Heaters are installed in the cooling water piping below the lube oil cooler to maintain the engine water and lube oil in a warm standby condition while the engine is not operating; thus increasing the starting reliability of the diesel generator. Natural convection is employed to circulate the warm engine water through the lube oil cooler during standby.

Each system is designed based on Seismic Category I requirements and is protected from tornadoes, missiles, and flooding.

9.5.5.1.2 Power Generation Design Bases

The diesel-generator cooling water system is not required during power generation. Consequently, it possesses no power generation design bases.

9.5.5.2 System Description

Each diesel-generator cooling water system is a separate, independent closed loop system supplied with the diesel generator and located entirely on the diesel-generator skid. It consists of two parallel engine driven centrifugal circulating pumps, a low-pressure expansion tank, an AMOT temperature regulating valve, a lube oil cooler, and the engine cooling water heat exchanger. The expansion tank is fitted with a 7 psig relief cap which also will relieve vacuum. Engine coolant is demineralized water treated with chromate, borate-nitrite, or silicate-nitrite type corrosion inhibitors in accordance with the engine manufacturer's recommendations.

During operation, cooling water at a flow of 1100 gpm per diesel-generator set is circulated by the engine driven pumps through the diesel engine cooling water passages to the lube oil cooler, through the temperature regulating valve, and then to the engine cooling water heat exchanger. See Figure 9.5-5 for additional details.

The engine cooling water heat exchanger is a two-pass shell and tube type heat exchanger having admiralty tubes with a carbon steel water box and shell. Engine cooling water is circulated through the shell side while strained lake water is pumped through the tube side by the CSCS-ECWS (Subsection 9.2.1). Design pressure and temperature is 150 psig and 300° F for both

REFERENCE 8.4

LSCS-FSAR

AMENDMENT 29
JANUARY 1978

QUESTION 040.92

"In response to Question 040.16 you have provided in section 9.5.5.1.1 a total diesel generator cooling water heat rate of approximately 6.15 million Btu/hr. This heat is rejected in the heat exchanger interfacing with CSCS equipment cooling water system when the diesel generator is operating at rated capacity. Also, in section 9.5.5.2 you mention that the cooling waterflow rate in the diesel engine is 1,100 gpm. It is not clear whether these heat and flow rates are for the total five diesel generators or for a single diesel generator. Please provide the heat and flow rates for each of the five diesel generators. In addition, also provide the design temperature differential ($^{\circ}$ F) for each diesel engine cooling water when operating at rated capacity."

RESPONSE

The design conditions for each diesel-generator cooling water system are:

Shell side flow	1100 gpm
Design shell side inlet temperature	190 $^{\circ}$ F
Shell side outlet temperature	175 $^{\circ}$ F
Tube side design flow	800 gpm
Tube side inlet temperature	100 $^{\circ}$ F
Tube side outlet temperature	122 $^{\circ}$ F
Heat exchanger design heat removal	8.6 x 10 ⁶ btu/hr
Diesel-generator set cooling requirement	7.8 x 10 ⁶ btu/hr

(The value of 6.15 x 10⁶ btu/hr heat removal specified in Subsection 9.5.5.1.1 has been corrected to read 7.8 x 10⁶ btu/hr in accordance with the above data).

**Attachment E to
Proto-Power Calculation
97-195
Revision A**

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Vendor Data Sheet - BENCHMARK

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	0.00285	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr-ft ² -°F)		255.20
Empirical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		479.00
Area Factor		0.998169790
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		188
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr-ft-°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

VENDOR DATA SHEET GIVES TOTAL FOULING
• THEREFORE, SHELL-SIDE IS SET TO TOTAL FOULING AND TUBE-SIDE FOUW IS SET TO 0.

PROTO-HX CALCULATED VALUE @ BENCHMARK CONDITIONS.

DATA SHEET AREA (EFFECTIVE)

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 Vendor Data Sheet - BENCHMARK

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 775.6
Shell Flow (gpm)	Shell Flow (gpm) 1,099.5
Shell Temp In (°F)	Tube Inlet Temp (°F) 100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 190.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)	
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)	
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)	
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)	
Effective Area (ft ²)	LMTD Correction Factor	
	Overall Fouling (hr-ft ² -°F/BTU)	
Property	Shell-Side	Tube-Side
Velocity (ft/s)		Shell Temp In (°F)
Reynold's Number		Shell Temp Out (°F)
Prandtl Number		Tav Shell (°F)
Bulk Visc (lbm/ft-hr)		Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)		Tube Temp In (°F)
Density (lbm/ft ³)		Tube Temp Out (°F)
Cp (BTU/lbm-°F)		Tav Tube (°F)
K (BTU/hr-ft-°F)		Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.5E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002850
Tube Mass Flow (lbm/hr)	3.88E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,075.6
Heat Transferred (BTU/hr)	8.589E+6	Tube-Side hi (BTU/hr-ft ² -°F)	2,100.5
LMTD	71.1	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	479.0	LMTD Correction Factor	0.9886
		U Overall (BTU/hr-ft ² -°F)	255.2
Property	Shell-Side	Tube-Side	
Velocity (ft/s)	5.15	8.00	Shell Temp In (°F) 190.0
Reynold's Number	8.537E+04	6.589E+04	Shell Temp Out (°F) 174.4
Prandtl Number	2.13	4.00	Tav Shell (°F) 182.2
Bulk Visc (lbm/ft-hr)	0.82	1.47	Shell Skin Temp (°F) 173.5
Skin Visc (lbm/ft-hr)	0.87	1.33	Tube Temp In (°F) 100.0
Density (lbm/ft ³)	60.53	61.85	Tube Temp Out (°F) 122.2
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 111.1
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 121.0

COMPARER
TO VENDOR
DATA SHEET

Proto-Power Calc: 97-195

Attachment: E

Rev: A Page 3 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Vendor Design Condition - Adj. Area

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,099.45	775.61
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	174.40	122.20
Fouling Factor		0.00285	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,600,000
Design Heat Trans Coeff (BTU/hr-ft ² -°F)			255.20
Empirical Factor for Outside h			0.780339000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)		471.23	
Area Factor			0.981978184
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.490000000
Shell Velocity (ft/s)			5.000
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			188
Number of Active Tubes			188
Tube Length (ft)			13.00
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr-ft-°F)			112.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

VENDOR DATA SHEET VALUES.

CALCULATED IN SECTION 3.2

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 Vendor Design Condition - Adj. Area

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Tube Flow (gpm) 775.6
 Shell Flow (gpm) 1,099.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.5E+5
 Tube Mass Flow (lbm/hr) 3.88E+5
 Heat Transferred (BTU/hr) 8.481E+6
 LMTD 71.3
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002850
 Shell-Side ho (BTU/hr-ft²-°F) 2,076.0
 Tube-Side hi (BTU/hr-ft²-°F) 2,099.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9889

U Overall (BTU/hr-ft²-°F) 255.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.15	8.00
Reynold's Number	8.543E+04	6.580E+04
Prandtl Number	2.13	4.00
Bulk Visc (lbm/ft-hr)	0.82	1.47
Skin Visc (lbm/ft-hr)	0.87	1.34
Density (lbm/ft³)	60.52	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.6
 Tav Shell (°F) 182.3
 Shell Skin Temp (°F) 173.5
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 121.9
 Tav Tube (°F) 110.9
 Tube Skin Temp (°F) 120.9

Proto-Power Calc: 97-195

Attachment: E

Rev: A Page 5 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Adj. Area - LSCS Ref. Conditions

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	0.00285	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		255.20
Emprical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		471.23
Area Factor		0.981978184
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		188
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 Adj. Area - LSCS Ref. Conditions

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

5.325E+5
 3.978E+5
**LESS THAN
 REF. COND.
 REQUIRED
 HEATRATE**
 8.484E+6
 71.3
 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002850
 Shell-Side ho (BTU/hr-ft²-°F) 2,034.1
 Tube-Side hi (BTU/hr-ft²-°F) 2,138.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9889

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.20
Reynold's Number	8.257E+04	6.728E+04
Prandtl Number	2.14	4.01
Bulk Visc (lbm/ft-hr)	0.82	1.47
Skin Visc (lbm/ft-hr)	0.88	1.34
Density (lbm/ft³)	60.53	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

U Overall (BTU/hr-ft²-°F) 255.2
 Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.1
 Tav Shell (°F) 182.1
 Shell Skin Temp (°F) 173.1
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 121.4
 Tav Tube (°F) 110.7
 Tube Skin Temp (°F) 120.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Reference Condition - Fouling Limit

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,099.45	775.61
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	174.40	122.20
Fouling Factor		0.00285	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			255.20
Empirical Factor for Outside h			0.780339000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			471.23
Area Factor			0.981978184
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.490000000
Shell Velocity (ft/s)			5.000
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			188
Number of Active Tubes			188
Tube Length (ft)			13.00
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			112.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Fouling
INPUT MODE
USED IN
FOLLOWING
CALCULATION

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 Reference Condition - Fouling Limit

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions

Fouling Was Input by User

ITERATION USING FOULING
 UNTIL REF. CONDITION HEAT RATE
 IS REACHED

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	795.3
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.002782

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)			Tube Temp In (°F)
Skin Visc (lbm/ft-hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm-°F)			Tube Skin Temp (°F)
K (BTU/hr-ft-°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002782
Tube Mass Flow (lbm/hr)	3.978E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,033.3
Heat Transferred (BTU/hr)	8.6E+6	Tube-Side hi (BTU/hr-ft ² -°F)	2,140.0
LMTD	71.1	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	471.2	LMTD Correction Factor	0.9885
		U Overall (BTU/hr-ft ² -°F)	259.7
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	4.99	8.20	Shell Temp Out (°F)
Reynold's Number	8.251E+04	6.738E+04	Tav Shell (°F)
Prandtl Number	2.14	4.01	Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)	0.82	1.47	Tube Temp In (°F)
Skin Visc (lbm/ft-hr)	0.88	1.34	Tube Temp Out (°F)
Density (lbm/ft ³)	60.53	61.85	Tav Tube (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr-ft-°F)	0.39	0.37	

REFERENCE
HEAT RATE

ADJUSTED
OVERALL
FOULING
FACTOR

Proto-Power Calc: 97-195

Attachment: E

Rev: A Page 9 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

**** FINAL MODEL ****

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,099.45	775.61
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 174.40	122.20
Fouling Factor	0.00278	0.00000
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		255.20
Empirical Factor for Outside h		0.780339000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		471.23
Area Factor		0.981978184
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.490000000
Shell Velocity (ft/s)		5.000
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		188
Number of Active Tubes		188
Tube Length (ft)		13.00
Tube Inside Diameter (in)		0.652
Tube Outside Diameter (in)		0.750
Tube Wall Conductivity (BTU/hr·ft·°F)		112.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		0.000
Lbo, Outlet Baffle Spacing (in)		0.000
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

REDUCED
OVERALL
FOULING
SECTION 6.2

ADJUSTED AREA
SECTION 3.2

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 **** FINAL MODEL ****

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions

Design Fouling Factors Were Used

ADJUSTED FOULING NOW
 DESIGN FOULING FACTOR
 IN PROTO-HX MODEL

Test Data

Extrapolation Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Tube Flow (gpm)	795.3
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 71.1
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,033.3
 Tube-Side hi (BTU/hr-ft²-°F) 2,140.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9885

ADJUSTED
 FOULING

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.20
Reynold's Number	8.251E+04	6.738E+04
Prandtl Number	2.14	4.01
Bulk Visc (lbm/ft-hr)	0.82	1.47
Skin Visc (lbm/ft-hr)	0.88	1.34
Density (lbm/ft³)	60.53	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

U Overall (BTU/hr-ft²-°F) 259.7
 Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.9
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 121.6
 Tav Tube (°F) 110.8
 Tube Skin Temp (°F) 120.8

Proto-Power Calc: 97-195
 Attachment: E
 Rev. A Page 11 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

FINAL MODEL- CLEAN (0 Fouling)

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,099.45	775.61
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	174.40	122.20
Fouling Factor		0.00278	0.00000
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,600,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			255.20
Empirical Factor for Outside h			0.780339000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			471.23
Area Factor			0.981978184
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.490000000
Shell Velocity (ft/s)			5.000
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			188
Number of Active Tubes			188
Tube Length (ft)			13.00
Tube Inside Diameter (in)			0.652
Tube Outside Diameter (in)			0.750
Tube Wall Conductivity (BTU/hr·ft·°F)			112.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			0.000
Lbo, Outlet Baffle Spacing (in)			0.000
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Proto-Power Calc: 97-195

Attachment: E

Rev: A Page 12 of 13

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

FINAL MODEL- CLEAN (0 Fouling)

Calculation Specifications

Constant Inlet Temperature Method Was Used

Extrapolation Was to User Specified Conditions

Fouling Was Input by User

Ø FOULING FOR "CLEAN"
Hx. Analysis.

Test Data

Extrapolation Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Tube Flow (gpm) 795.3
Shell Flow (gpm) 1,064.5
Tube Inlet Temp (°F) 100.0
Shell Inlet Temp (°F) 190.0

Input Fouling Factor 0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
Tube Mass Flow (lbm/hr)

Heat Transferred (BTU/hr)
LMTD
Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
Shell-Side ho (BTU/hr-ft²-°F)
Tube-Side hi (BTU/hr-ft²-°F)
1/Wall Resis (BTU/hr-ft²-°F)
LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
Shell Temp Out (°F)
Tav Shell (°F)
Shell Skin Temp (°F)
Tube Temp In (°F)
Tube Temp Out (°F)
Tav Tube (°F)
Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)
Tube Mass Flow (lbm/hr)

Heat Transferred (BTU/hr)
LMTD
Effective Area (ft²)

CLEAN HEAT RATE

5.325E+5
3.978E+5

1.885E+7

48.3
471.2

Overall Fouling (hr-ft²-°F/BTU)
Shell-Side ho (BTU/hr-ft²-°F)
Tube-Side hi (BTU/hr-ft²-°F)
1/Wall Resis (BTU/hr-ft²-°F)
LMTD Correction Factor

0.000000
1,957.5
2,318.4
25,594.8
0.8656

"CLEAN"

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.97	8.22
Reynold's Number	7.721E+04	7.626E+04
Prandtl Number	2.29	3.50
Bulk Visc (lbm/ft-hr)	0.88	1.30
Skin Visc (lbm/ft-hr)	1.05	1.07
Density (lbm/ft³)	60.74	61.65
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.38	0.37

U Overall (BTU/hr-ft²-°F)

955.9

Shell Temp In (°F) 190.0
Shell Temp Out (°F) 154.6
Tav Shell (°F) 172.3
Shell Skin Temp (°F) 148.6
Tube Temp In (°F) 100.0
Tube Temp Out (°F) 147.4
Tav Tube (°F) 123.7
Tube Skin Temp (°F) 146.8

Proto-Power Calc: 97-195
Attachment: E
Rev: A Page 13 of 13

** Reynolds Number Outside Range of Equation Applicability
!! With Minimum Fouling The Test Heat Load Could Not Be Achie

**Attachment F to
Proto-Power Calculation
97-195
Revision A**

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Tube-side Fouling = 0.0000

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0
 Input Fouling Factor 0.000500

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 1.57E+7
 LMTD 55.4
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.000500
 Shell-Side ho (BTU/hr-ft²-°F) 1,983.9
 Tube-Side hi (BTU/hr-ft²-°F) 2,261.9
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9332

U Overall (BTU/hr-ft²-°F) 644.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.98	8.22
Reynold's Number	7.883E+04	7.349E+04
Prandtl Number	2.24	3.64
Bulk Visc (lbm/ft-hr)	0.86	1.35
Skin Visc (lbm/ft-hr)	0.98	1.15
Density (lbm/ft³)	60.68	61.72
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 160.6
 Tav Shell (°F) 175.3
 Shell Skin Temp (°F) 157.2
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 139.5
 Tav Tube (°F) 119.8
 Tube Skin Temp (°F) 138.0

Proto-Power Calc: 97-195

Attachment: F

Rev: A Page 2 of 6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Tube-side Fouling = 0.0005

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0
 Input Fouling Factor 0.001075

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 1.304E+7
 LMTD 61.3
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.001075
 Shell-Side ho (BTU/hr-ft²-°F) 2,003.3
 Tube-Side hi (BTU/hr-ft²-°F) 2,216.1
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9633

U Overall (BTU/hr-ft²-°F) 469.0

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.98	8.21
Reynold's Number	8.020E+04	7.118E+04
Prandtl Number	2.20	3.77
Bulk Visc (lbm/ft-hr)	0.85	1.39
Skin Visc (lbm/ft-hr)	0.94	1.21
Density (lbm/ft³)	60.62	61.77
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 165.6
 Tav Shell (°F) 177.8
 Shell Skin Temp (°F) 163.4
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 132.8
 Tav Tube (°F) 116.4
 Tube Skin Temp (°F) 131.4

Proto-Power Calc: 97-195

Attachment: F

Rev: A Page 3 of 6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Tube-side Fouling = 0.0010

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	795.3
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.001650

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)			Tube Temp In (°F)
Skin Visc (lbm/ft-hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm-°F)			Tube Skin Temp (°F)
K (BTU/hr-ft-°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.001650
Tube Mass Flow (lbm/hr)	3.978E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,016.5
Heat Transferred (BTU/hr)	1.112E+7	Tube-Side hi (BTU/hr-ft ² -°F)	2,183.2
LMTD	65.5	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	471.2	LMTD Correction Factor	0.9770
		U Overall (BTU/hr-ft ² -°F)	368.8
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	4.98	8.20	Shell Temp Out (°F)
Reynold's Number	8.120E+04	6.953E+04	Tav Shell (°F)
Prandtl Number	2.17	3.87	Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)	0.84	1.43	Tube Temp In (°F)
Skin Visc (lbm/ft-hr)	0.91	1.27	Tube Temp Out (°F)
Density (lbm/ft ³)	60.58	61.80	Tav Tube (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr-ft-°F)	0.39	0.37	

Proto-Power Calc: 97-195
 Attachment: F
 Rev: A Page 4 of 6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Tube-side Fouling = 0.0015

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0
 Input Fouling Factor 0.002225

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 9.683E+6
 LMTD 68.7
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002225
 Shell-Side ho (BTU/hr-ft²-°F) 2,026.2
 Tube-Side hi (BTU/hr-ft²-°F) 2,158.6
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9842
 U Overall (BTU/hr-ft²-°F) 303.9

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.20
Reynold's Number	8.194E+04	6.830E+04
Prandtl Number	2.15	3.95
Bulk Visc (lbm/ft-hr)	0.83	1.45
Skin Visc (lbm/ft-hr)	0.89	1.31
Density (lbm/ft³)	60.55	61.83
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 171.9
 Tav Shell (°F) 180.9
 Shell Skin Temp (°F) 170.6
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 124.4
 Tav Tube (°F) 112.2
 Tube Skin Temp (°F) 123.3

Proto-Power Calc: 97-195
 Attachment: F
 Rev: A Page 5 of 6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

Tube-side Fouling = 0.001984 (LIMIT)

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0
 Input Fouling Factor 0.002782

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 71.1
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,033.3
 Tube-Side hi (BTU/hr-ft²-°F) 2,140.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9885
 U Overall (BTU/hr-ft²-°F) 259.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.20
Reynold's Number	8.251E+04	6.738E+04
Prandtl Number	2.14	4.01
Bulk Visc (lbm/ft-hr)	0.82	1.47
Skin Visc (lbm/ft-hr)	0.88	1.34
Density (lbm/ft³)	60.53	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.9
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 121.6
 Tav Tube (°F) 110.8
 Tube Skin Temp (°F) 120.8

Proto-Power Calc: 97-195
 Attachment: F
 Rev: A Page 6 of 6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

**Attachment G to
Proto-Power Calculation
97-195
Revision A**

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 35°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 193.5
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 35.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 9.68E+4
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 98.1
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,032.2
 Tube-Side hi (BTU/hr-ft²-°F) 599.1
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9740

U Overall (BTU/hr-ft²-°F) 191.1

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	1.98
Reynold's Number	8.251E+04	1.155E+04
Prandtl Number	2.14	5.90
Bulk Visc (lbm/ft-hr)	0.82	2.09
Skin Visc (lbm/ft-hr)	0.88	1.39
Density (lbm/ft³)	60.53	62.22
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.35

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.3
 Tube Temp In (°F) 35.0
 Tube Temp Out (°F) 123.9
 Tav Tube (°F) 79.4
 Tube Skin Temp (°F) 117.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-195

Attachment: G

Rev: A Page 2 of 17

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 40°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	204.8
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	40.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr·ft²·°F)
 Shell-Side ho (BTU/hr·ft²·°F)
 Tube-Side hi (BTU/hr·ft²·°F)
 1/Wall Resis (BTU/hr·ft²·°F)
 LMTD Correction Factor

Overall Fouling (hr·ft²·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft³)		
Cp (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.024E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 96.0
 Effective Area (ft²) 471.2

Overall Fouling (hr·ft²·°F/BTU) 0.002782
 Shell-Side ho (BTU/hr·ft²·°F) 2,032.3
 Tube-Side hi (BTU/hr·ft²·°F) 634.9
 1/Wall Resis (BTU/hr·ft²·°F) 25,594.8
 LMTD Correction Factor 0.9744

U Overall (BTU/hr·ft²·°F) 195.1

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	2.10
Reynold's Number	8.251E+04	1.261E+04
Prandtl Number	2.14	5.70
Bulk Visc (lbm/ft·hr)	0.82	2.02
Skin Visc (lbm/ft·hr)	0.88	1.38
Density (lbm/ft³)	60.53	62.20
Cp (BTU/lbm·°F)	1.00	1.00
K (BTU/hr·ft·°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.3
 Tube Temp In (°F) 40.0
 Tube Temp Out (°F) 124.0
 Tav Tube (°F) 82.0
 Tube Skin Temp (°F) 117.3

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 50°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 232.2
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 50.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.162E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 91.9
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,032.5
 Tube-Side hi (BTU/hr-ft²-°F) 719.6
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9756

U Overall (BTU/hr-ft²-°F) 203.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	2.38
Reynold's Number	8.251E+04	1.520E+04
Prandtl Number	2.14	5.33
Bulk Visc (lbm/ft-hr)	0.82	1.91
Skin Visc (lbm/ft-hr)	0.88	1.37
Density (lbm/ft³)	60.53	62.15
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.4
 Tube Temp In (°F) 50.0
 Tube Temp Out (°F) 124.1
 Tav Tube (°F) 87.0
 Tube Skin Temp (°F) 117.9

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-195

Attachment: G

Rev: A Page 4 of 17

Commonwealth Edison
 Calculation Report for DG01A - DG Jacket Water Cooler
 CSCS = 60°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	269.1
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	60.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.346E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 87.8
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,032.7
 Tube-Side hi (BTU/hr-ft²-°F) 828.7
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9770

U Overall (BTU/hr-ft²-°F) 212.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	2.76
Reynold's Number	8.251E+04	1.865E+04
Prandtl Number	2.14	5.00
Bulk Visc (lbm/ft-hr)	0.82	1.80
Skin Visc (lbm/ft-hr)	0.88	1.37
Density (lbm/ft³)	60.53	62.09
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.5
 Tube Temp In (°F) 60.0
 Tube Temp Out (°F) 123.9
 Tav Tube (°F) 92.0
 Tube Skin Temp (°F) 118.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-195

Attachment: G

Rev: A Page 5 of 17

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 70°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 321.0
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 70.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.606E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 83.7
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,032.8
 Tube-Side hi (BTU/hr-ft²-°F) 975.6
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9790

U Overall (BTU/hr-ft²-°F) 222.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	3.30
Reynold's Number	8.251E+04	2.348E+04
Prandtl Number	2.14	4.71
Bulk Visc (lbm/ft-hr)	0.82	1.71
Skin Visc (lbm/ft-hr)	0.88	1.36
Density (lbm/ft³)	60.53	62.03
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.6
 Tube Temp In (°F) 70.0
 Tube Temp Out (°F) 123.6
 Tav Tube (°F) 96.8
 Tube Skin Temp (°F) 119.2

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-195

Attachment: G

Rev: A Page 6 of 17

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 80°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 399.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 80.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.997E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 79.6
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,033.0
 Tube-Side hi (BTU/hr-ft²-°F) 1,186.3
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9814

U Overall (BTU/hr-ft²-°F) 233.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	4.11
Reynold's Number	8.251E+04	3.075E+04
Prandtl Number	2.14	4.45
Bulk Visc (lbm/ft-hr)	0.82	1.62
Skin Visc (lbm/ft-hr)	0.88	1.35
Density (lbm/ft³)	60.53	61.97
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.7
 Tube Temp In (°F) 80.0
 Tube Temp Out (°F) 123.1
 Tav Tube (°F) 101.5
 Tube Skin Temp (°F) 119.8

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 7 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 90°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 530.9
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 90.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 2.656E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 75.4
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,033.2
 Tube-Side hi (BTU/hr-ft²-°F) 1,519.8
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9845

U Overall (BTU/hr-ft²-°F) 245.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	5.47
Reynold's Number	8.251E+04	4.293E+04
Prandtl Number	2.14	4.22
Bulk Visc (lbm/ft-hr)	0.82	1.54
Skin Visc (lbm/ft-hr)	0.88	1.34
Density (lbm/ft³)	60.53	61.91
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.8
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 122.4
 Tav Tube (°F) 106.2
 Tube Skin Temp (°F) 120.3

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 8 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieve

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 100°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.6E+6
 LMTD 71.1
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,033.3
 Tube-Side hi (BTU/hr-ft²-°F) 2,140.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9885

U Overall (BTU/hr-ft²-°F) 259.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	8.20
Reynold's Number	8.251E+04	6.738E+04
Prandtl Number	2.14	4.01
Bulk Visc (lbm/ft-hr)	0.82	1.47
Skin Visc (lbm/ft-hr)	0.88	1.34
Density (lbm/ft³)	60.53	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 173.9
 Tav Shell (°F) 181.9
 Shell Skin Temp (°F) 172.9
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 121.6
 Tav Tube (°F) 110.8
 Tube Skin Temp (°F) 120.8

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 9 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 35°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	161.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	35.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
Property	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)	Shell Temp In (°F)
Reynold's Number	Shell Temp Out (°F)
Prandtl Number	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	Tube Temp In (°F)
Density (lbm/ft ³)	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	Tav Tube (°F)
K (BTU/hr-ft-°F)	Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002782
Tube Mass Flow (lbm/hr)	8.059E+4	Shell-Side ho (BTU/hr-ft ² -°F)	2,037.1
Heat Transferred (BTU/hr)	7.8E+6	Tube-Side hi (BTU/hr-ft ² -°F)	531.4
LMTD	93.3	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	471.2	LMTD Correction Factor	0.9713
Property	Shell-Side	Tube-Side	U Overall (BTU/hr-ft ² -°F)
Velocity (ft/s)	4.99	1.65	182.6
Reynold's Number	8.292E+04	1.010E+04	Shell Temp In (°F)
Prandtl Number	2.13	5.59	Shell Temp Out (°F)
Bulk Visc (lbm/ft-hr)	0.82	1.99	Tav Shell (°F)
Skin Visc (lbm/ft-hr)	0.87	1.31	Shell Skin Temp (°F)
Density (lbm/ft ³)	60.52	62.18	Tube Temp In (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Temp Out (°F)
K (BTU/hr-ft-°F)	0.39	0.36	Tav Tube (°F)
			Tube Skin Temp (°F)

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 10 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 40°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 169.8
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 40.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 8.492E+4
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 91.4
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,037.2
 Tube-Side hi (BTU/hr-ft²-°F) 561.0
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9716

U Overall (BTU/hr-ft²-°F) 186.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	1.74
Reynold's Number	8.292E+04	1.097E+04
Prandtl Number	2.13	5.40
Bulk Visc (lbm/ft-hr)	0.82	1.93
Skin Visc (lbm/ft-hr)	0.87	1.31
Density (lbm/ft³)	60.52	62.16
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.8
 Tube Temp In (°F) 40.0
 Tube Temp Out (°F) 131.9
 Tav Tube (°F) 86.0
 Tube Skin Temp (°F) 122.9

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 11 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 50°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 190.5
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 50.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 9.527E+4
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 87.5
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,037.4
 Tube-Side hi (BTU/hr-ft²-°F) 629.9
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9726

U Overall (BTU/hr-ft²-°F) 194.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	1.96
Reynold's Number	8.292E+04	1.305E+04
Prandtl Number	2.13	5.06
Bulk Visc (lbm/ft-hr)	0.82	1.82
Skin Visc (lbm/ft-hr)	0.87	1.30
Density (lbm/ft³)	60.52	62.10
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.9
 Tube Temp In (°F) 50.0
 Tube Temp Out (°F) 131.9
 Tav Tube (°F) 91.0
 Tube Skin Temp (°F) 123.6

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 12 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 60°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 217.5
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 60.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr·ft²·°F)
 Shell-Side ho (BTU/hr·ft²·°F)
 Tube-Side hi (BTU/hr·ft²·°F)
 1/Wall Resis (BTU/hr·ft²·°F)
 LMTD Correction Factor

Overall Fouling (hr·ft²·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft³)		
Cp (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.088E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 83.6
 Effective Area (ft²) 471.2

Overall Fouling (hr·ft²·°F/BTU) 0.002782
 Shell-Side ho (BTU/hr·ft²·°F) 2,037.6
 Tube-Side hi (BTU/hr·ft²·°F) 716.3
 1/Wall Resis (BTU/hr·ft²·°F) 25,594.8
 LMTD Correction Factor 0.9739

U Overall (BTU/hr·ft²·°F) 203.3

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	2.24
Reynold's Number	8.292E+04	1.575E+04
Prandtl Number	2.13	4.76
Bulk Visc (lbm/ft·hr)	0.82	1.72
Skin Visc (lbm/ft·hr)	0.87	1.29
Density (lbm/ft³)	60.52	62.05
Cp (BTU/lbm·°F)	1.00	1.00
K (BTU/hr·ft·°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 174.0
 Tube Temp In (°F) 60.0
 Tube Temp Out (°F) 131.8
 Tav Tube (°F) 95.9
 Tube Skin Temp (°F) 124.2

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 13 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 70°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	254.2
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	70.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
Property	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)	Shell Temp In (°F)
Reynold's Number	Shell Temp Out (°F)
Prandtl Number	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	Tube Temp In (°F)
Density (lbm/ft ³)	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	Tav Tube (°F)
K (BTU/hr-ft-°F)	Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002782
Tube Mass Flow (lbm/hr)	1.272E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,037.8
Heat Transferred (BTU/hr)	7.8E+6	Tube-Side hi (BTU/hr-ft ² -°F)	829.2
LMTD	79.7	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	471.2	LMTD Correction Factor	0.9757
Property	Shell-Side	Tube-Side	U Overall (BTU/hr-ft ² -°F)
Velocity (ft/s)	4.99	2.62	212.8
Reynold's Number	8.292E+04	1.940E+04	Shell Temp In (°F)
Prandtl Number	2.13	4.50	Shell Temp Out (°F)
Bulk Visc (lbm/ft-hr)	0.82	1.63	Tav Shell (°F)
Skin Visc (lbm/ft-hr)	0.87	1.29	Shell Skin Temp (°F)
Density (lbm/ft ³)	60.52	61.99	Tube Temp In (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Temp Out (°F)
K (BTU/hr-ft-°F)	0.39	0.36	Tav Tube (°F)
			Tube Skin Temp (°F)

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 14 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 80°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 307.0
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 80.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.536E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 75.8
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,038.0
 Tube-Side hi (BTU/hr-ft²-°F) 984.2
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9779

U Overall (BTU/hr-ft²-°F) 223.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	3.16
Reynold's Number	8.292E+04	2.462E+04
Prandtl Number	2.13	4.26
Bulk Visc (lbm/ft-hr)	0.82	1.56
Skin Visc (lbm/ft-hr)	0.87	1.28
Density (lbm/ft³)	60.52	61.92
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 174.2
 Tube Temp In (°F) 80.0
 Tube Temp Out (°F) 130.8
 Tav Tube (°F) 105.4
 Tube Skin Temp (°F) 125.6

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 15 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 90°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Tube Flow (gpm)	389.3
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	90.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.947E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 71.9
 Effective Area (ft²) 471.2

Overall Fouling (hr-ft²-°F/BTU) 0.002782
 Shell-Side ho (BTU/hr-ft²-°F) 2,038.2
 Tube-Side hi (BTU/hr-ft²-°F) 1,213.3
 1/Wall Resis (BTU/hr-ft²-°F) 25,594.8
 LMTD Correction Factor 0.9808

U Overall (BTU/hr-ft²-°F) 234.8

Property	Shell-Side	Tube-Side
Velocity (ft/s)	4.99	4.01
Reynold's Number	8.292E+04	3.273E+04
Prandtl Number	2.13	4.04
Bulk Visc (lbm/ft-hr)	0.82	1.48
Skin Visc (lbm/ft-hr)	0.87	1.27
Density (lbm/ft³)	60.52	61.86
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 174.3
 Tube Temp In (°F) 90.0
 Tube Temp Out (°F) 130.1
 Tav Tube (°F) 110.1
 Tube Skin Temp (°F) 126.2

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 16 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01A - DG Jacket Water Cooler

CSCS = 100°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	534.5
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
Property	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)	Shell Temp In (°F)
Reynold's Number	Shell Temp Out (°F)
Prandtl Number	Tav Shell (°F)
Bulk Visc (lbm/ft-hr)	Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)	Tube Temp In (°F)
Density (lbm/ft ³)	Tube Temp Out (°F)
Cp (BTU/lbm-°F)	Tav Tube (°F)
K (BTU/hr-ft-°F)	Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002782
Tube Mass Flow (lbm/hr)	2.674E+5	Shell-Side ho (BTU/hr-ft ² -°F)	2,038.4
Heat Transferred (BTU/hr)	7.8E+6	Tube-Side hi (BTU/hr-ft ² -°F)	1,592.6
LMTD	67.8	1/Wall Resis (BTU/hr-ft ² -°F)	25,594.8
Effective Area (ft ²)	471.2	LMTD Correction Factor	0.9844
Property	Shell-Side	Tube-Side	U Overall (BTU/hr-ft ² -°F)
Velocity (ft/s)	4.99	5.52	247.9
Reynold's Number	8.292E+04	4.701E+04	Shell Temp In (°F)
Prandtl Number	2.13	3.85	Shell Temp Out (°F)
Bulk Visc (lbm/ft-hr)	0.82	1.42	Tav Shell (°F)
Skin Visc (lbm/ft-hr)	0.87	1.27	Shell Skin Temp (°F)
Density (lbm/ft ³)	60.52	61.79	Tube Temp In (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Temp Out (°F)
K (BTU/hr-ft-°F)	0.39	0.37	Tav Tube (°F)
			Tube Skin Temp (°F)
			190.0
			175.4
			182.7
			174.4
			100.0
			129.2
			114.6
			126.8

Proto-Power Calc: 97-195
 Attachment: G
 Rev: A Page 17 of 17

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment H to
Proto-Power Calculation
97-195
Revision A**

PROTO-HX™ Version 3.02 MODEL

LASALLE STATION STANDBY DIESEL GENERATOR
HEAT EXCHANGER.

FILE NAME:	DG01A.PHX
DATE LAST MODIFIED:	6/29/98
TIME LAST MODIFIED:	1:50:34 PM
FILE SIZE:	640 KB

**ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet**

Design Analysis (Minor Revision)		Last Page No. ⁶ Attachment B, B2	
Analysis No.: ¹ 97-197	Revision: ² A04		
Title: ³ Thermal Model of ComEd/LaSalle Station HPCS Diesel Generator Jacket Water Coolers			
EC/ECR No.: ⁴ 388666	Revision: ⁵ 000		
Station(s): ⁷ LaSalle	Unit No.: ⁸ 01 & 02		
Safety/QA Class: ⁹ SR	System Code(s): ¹⁰ HP, DG, E22		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106	
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, AT/AR#: N/A	
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴ This revision evaluates a maximum cooling water inlet temperature of 107 °F. The previous temperature that was evaluated was 104 °F. Affected pages are Pages 1 – 3, Attachment A, Pages A1-A2, and Attachment B, Pages B1-B2			
Disposition of Changes: ¹⁵ See attached pages. The changes made are acceptable.			
Preparer: ¹⁶	<u>Sean Tanton</u> <small>Print Name</small>	<u>Sean Tanton</u> <small>Sign Name</small>	<u>5/18/12</u> <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing <input type="checkbox"/>		
Reviewer: ¹⁸	<u>Steve Chon</u> <small>Print Name</small>	<u>Steve Chon</u> <small>Sign Name</small>	<u>5/18/12</u> <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>		
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Reviewer: ²¹	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Approver: ²²	<u>DAN SCHMIT</u> <small>Print Name</small>	<u>DJ Schmit</u> <small>Sign Name</small>	<u>5/18/12</u> <small>Date</small>

Purpose:

The purpose of this revision is to verify that the 1(2)E22-S001 coolers can remove the design heat load of 7,800,000 BTU/hr with a revised maximum cooling water temperature of 107 °F.

Assumptions:

There are no assumptions for this revision.

Inputs:

- Cooling water temperature = 107 °F (Reference 2)
- Cooling water flow rate = 650 gpm* (References 1, 3, and 4)
- Jacket water temperature for 1(2)E22-S001 = 190 °F (Reference 1)
- Jacket water flow rate for 1(2)E22-S001 = 1100 gpm (Reference 1)
- Fouling factor for 1(2)E22-S001 = 0.00223 hr·ft²·°F/BTU** (Reference 1, 3, and 4)
- 4 tubes plugged (1% tube plugging) (Reference 1)

*The flow rate for this cooler was reduced to 550 gpm for both units per References 3 and 4. An additional case is run with this flow rate and a CSCS temperature of 107 °F.

**The fouling factor for this cooler was increased to 0.00196 hr·ft²·°F/BTU per References 3 and 4. An additional case is run with this fouling factor and a CSCS temperature of 107 °F.

References:

1. Design analysis 97-197, Rev. A, up to and including Rev A03
2. EC 388666, Rev. 000
3. EC 370853, Rev. 000
4. EC 384525, Rev. 000
5. EC 382117, Rev. 000

Identification of Computer Programs:

The computer program used in this analysis is Proto HX version 4.01. This program has been validated per DTSQA tracking number EX0000103.

Method of Analysis / Numeric Analysis:

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp" from 104 °F to 107 °F.

Results / Conclusions:

The 1(2)E22-S001 coolers can remove the design heat load of 7,800,000 BTU/hr with the following conditions:

- 107 °F cooling water temperature
- 650 gpm and 550 gpm cooling water flow
- fouling factor of 0.00223 hr·ft²·°F/BTU and 0.00196 hr·ft²·°F/BTU
- 4 tubes plugged
- jacket water temperature of 190 °F
- jacket water flow rate of 1100 gpm

The total heat removed at 650 gpm with a fouling factor of 0.00223 hr·ft²·°F/BTU is 7,916,590 BTU/hr, which provides 1.5% thermal margin over the design heat load. The total heat removed at 550 gpm with a fouling factor of 0.00196 hr·ft²·°F/BTU is 7,936,128 BTU/hr, which provides 1.7% thermal margin over the design heat load. The model benchmark was shown to conservatively underestimate the heat transfer of the cooler by 2.68%. Therefore, any positive margin shown in the model would be an underestimate of actual thermal performance, which would show more margin than what is calculated. Additionally, the most recent thermal performance evaluation (Ref. 5) shows a maximum fouling factor of 0.000447 hr·ft²·°F/BTU, which also shows that additional margin exists. The calculated thermal margin of 1.5% and 1.7% for the two cases is acceptable. The maximum fouling factor of 0.00196 hr·ft²·°F/BTU shall be used for acceptance criteria in thermal performance evaluations after ECs 370853 and 384525 have been implemented on Units 1 & 2, respectively. The two cases are shown in Attachments A and B.

Attachments:

- A. Data Report for 1(2)E22-S001 at 650 gpm with $FF = 0.00223 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$ (2 pgs)
- B. Data Report for 1(2)E22-S001 at 550 gpm with $FF = 0.00196 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$ (2 pgs)

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Mass Fluid Quantity, Total	lbm/hr	0.00	0.00
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor	hr·ft ² ·°F/BTU	0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Q (BTU/hr)			8,505,000
Design U (BTU/hr·ft ² ·°F)			241.70
Outside h Factor (Hoff)			0.633693000
Fixed U (BTU/hr·ft ² ·°F)			0
Fixed Area (ft ²)			0.00
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA - E
Total Effective Area per Unit (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			0.00000
Number of Shells Per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			416
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall K (BTU/hr·ft·°F)			58.00
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube Circle Diameter			0.000
Bh, Baffle Cut Height (in)			0.000
Ds, Shell Inside Diameter (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

1B, 2B DG - 107 °F tube side, 650 gpm, 190 °F shell side, 1100 gpm, FF = 0.00223, 4 tubes plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 645.10
 Shell Flow (gpm) 1,064.50
 Tube Inlet Temp (°F) 107.00
 Shell Inlet Temp (°F) 190.00
 Input Fouling Factor 0.002230

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr·ft²·°F)
 Shell-Side ho (BTU/hr·ft²·°F)
 Tube-Side hi (BTU/hr·ft²·°F)
 1/Wall Resis (BTU/hr·ft²·°F)
 LMTD Correction Factor
 Overall Fouling (hr·ft²·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft³)		
Cp (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 532,515.63
 Tube Mass Flow (lbm/hr) 322,710.98
 Heat Transferred (BTU/hr) 7,916,590.94
 LMTD 63.2
 Effective Area (ft²) 463.7

Overall Fouling (hr·ft²·°F/BTU) 0.002230
 Shell-Side ho (BTU/hr·ft²·°F) 1,891.2
 Tube-Side hi (BTU/hr·ft²·°F) 1,408.2
 1/Wall Resis (BTU/hr·ft²·°F) 15,431.0
 LMTD Correction Factor 0.9847

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.37
Reynold's Number	77.252	32,323
Prandtl Number	2.1276	3.6616
Bulk Visc (lbm/ft·hr)	0.8197	1.3556
Skin Visc (lbm/ft·hr)	0.8730	1.1913
Density (lbm/ft³)	60.5172	61.7228
Cp (BTU/lbm·°F)	1.0025	0.9988
K (BTU/hr·ft·°F)	0.3862	0.3698

U Overall (BTU/hr·ft²·°F) 274.4
 Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.2
 Tav Shell (°F) 182.6
 Shell Skin Temp (°F) 173.4
 Tube Temp In (°F) 107.0
 Tube Temp Out (°F) 131.6
 Tav Tube (°F) 119.3
 Tube Skin Temp (°F) 133.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

PROTO-HX 4.00 by Proto-Power Corporation (SN#PHX-1002)
Commonwealth Edison

Data Report for DG01B - LSCS - HPCS DG Hx.

1B, 2B DG - 107 °F tube side, 550 gpm, 190 °F shell side, 1100 gpm, FF = 0.00196, 4 tubes plugged

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Mass Fluid Quantity, Total	lbm/hr	0.00	0.00
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor	hr-ft ² ·°F/BTU	0.00050	0.00193
Shell Fluid Name		Fresh Water	
Tube Fluid Name		Fresh Water	
Design Q (BTU/hr)		8,505,000	
Design U (BTU/hr-ft ² ·°F)		241.70	
Outside h Factor (Hoff)		0.633693000	
Fixed U (BTU/hr-ft ² ·°F)		0	
Fixed Area (ft ²)		0.00	
Performance Factor (% Reduction)		0.00	
Heat Exchanger Type		TEMA - E	
Total Effective Area per Unit (ft ²)		468.17	
Area Factor		0.973212339	
Area Ratio		0.00000	
Number of Shells Per Unit		1	
Shell Minimum Area		0.438000000	
Shell Velocity (ft/s)		5.600	
Tube Pitch (in)		0.7500	
Tube Pitch Type		Triangular	
Number of Tube Passes		2	
U-Tubes		No	
Total Number of Tubes		420	
Number of Active Tubes		416	
Tube Length (ft)		7.00	
Tube Inside Diameter (in)		0.541	
Tube Outside Diameter (in)		0.625	
Tube Wall K (BTU/hr-ft·°F)		58.00	
Lbc, Central Baffle Spacing (in)		0.000	
Lbi, Inlet Baffle Spacing (in)		19.688	
Lbo, Outlet Baffle Spacing (in)		19.688	
Dotl, Tube Circle Diameter		0.000	
Bh, Baffle Cut Height (in)		0.000	
Ds, Shell Inside Diameter (in)		0.000	
Lsb, Diametral difference between Baffle and Shell (in)		0.000	
Ltb, Diametral difference between Tube and Baffle (in)		0.000	
Nss, Number Sealing Strips		0.000	

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

1B, 2B DG - 107 °F tube side, 550 gpm, 190 °F shell side, 1100 gpm, FF = 0.00196, 4 tubes plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 545.90
 Shell Flow (gpm) 1,064.50
 Tube Inlet Temp (°F) 107.00
 Shell Inlet Temp (°F) 190.00
 Input Fouling Factor 0.001960

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 532,515.63
 Tube Mass Flow (lbm/hr) 273,086.22
 Heat Transferred (BTU/hr) 7,936,128.27
 LMTD 60.7
 Effective Area (ft²) 463.7

Overall Fouling (hr-ft²-°F/BTU) 0.001960
 Shell-Side ho (BTU/hr-ft²-°F) 1,890.9
 Tube-Side hi (BTU/hr-ft²-°F) 1,248.7
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9802
 U Overall (BTU/hr-ft²-°F) 287.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	3.70
Reynold's Number	77,243	27,941
Prandtl Number	2.1278	3.5771
Bulk Visc (lbm/ft-hr)	0.8198	1.3270
Skin Visc (lbm/ft-hr)	0.8737	1.1487
Density (lbm/ft ³)	60.5176	61.6875
Cp (BTU/lbm-°F)	1.0025	0.9988
K (BTU/hr-ft-°F)	0.3862	0.3705

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.1
 Tav Shell (°F) 182.6
 Shell Skin Temp (°F) 173.3
 Tube Temp In (°F) 107.0
 Tube Temp Out (°F) 136.1
 Tav Tube (°F) 121.5
 Tube Skin Temp (°F) 137.8

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet

Design Analysis (Minor Revision)		Last Page No. ⁶ 1	
Analysis No.: ¹ 97-197	Revision: ² A03		
Title: ³ Thermal Model of ComEd / LaSalle Station HPCS Diesel Generator Jacket Water Coolers			
EC/ECR No.: ⁴ EC 384525	Revision: ⁵ 000		
Station(s): ⁷ LaSalle	Unit No.: ⁸ 02		
Safety/QA Class: ⁹ SR	System Code(s): ¹⁰ HP, E22, DG		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, ATI/AR#: N/A
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴ EC 384525 revised the flows in Division 3 of the Unit 2 CSCS. This revision makes the changes made in Revision A02 applicable to both Units.			
Disposition of Changes: ¹⁵ As shown in Attachment A of Revision A02, the changes made are acceptable. The revised flows in combination with the reduced fouling factor allow the heat exchanger to remove the design basis heat load. System engineering has agreed to accept more stringent criteria for the cleanliness of the 2E22-S001 cooler.			
Preparer: ¹⁶	Sean Tanton <small>Print Name</small>	<i>Sean Tanton</i> <small>Sign Name</small>	3/20/12 <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	Matthew Cosenza <small>Print Name</small>	<i>Matthew Cosenza</i> <small>Sign Name</small>	3/20/12 <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>		
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	N/A <small>Print Name</small>	N/A <small>Sign Name</small>	N/A <small>Date</small>
Exelon Reviewer: ²¹	N/A <small>Print Name</small>	N/A <small>Sign Name</small>	N/A <small>Date</small>
Exelon Approver: ²²	Dan Schmit <small>Print Name</small>	<i>D Schmit</i> <small>Sign Name</small>	3/28/12 <small>Date</small>

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet

Design Analysis (Minor Revision)		Last Page No. ⁶ Attachment A, pg A2	
Analysis No.: ¹	97-197	Revision: ²	A02
Title: ³	Thermal Model of ComEd / LaSalle Station HPCS Diesel Generator Jacket Water Coolers		
EC/ECR No.: ⁴	370853	Revision: ⁵	000
Station(s): ⁷	LaSalle		
Unit No.: ⁸	01		
Safety/QA Class: ⁹	SR		
System Code(s): ¹⁰	HP, E22, DG		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, ATI/AR#: N/A
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴			
<p>To recover margin in Division 3 of Unit 1 of the CSCS, EC 370853 revises the flows of the 1E22-S001 cooler. 100 gpm will be diverted from the 1E22-S001 cooler. Of this 100 gpm, 50 gpm will be returned to the 1E22-C002 pump, while the other 50 gpm will be given to the 1VY02A cooler. This revision determines if the revised flows are acceptable and can remove the required amount of heat for the heat exchangers.</p> <p>This revision only applies to Unit 1. The flows shown for Unit 2 remain valid and are not impacted by this revision.</p>			
Disposition of Changes: ¹⁵			
<p>Attachment A shows that a sufficient heat transfer rate can be achieved by reducing the fouling factor to 0.00196 hr*ft²*°F/BTU. By inputting 546.26 gpm tube flow, 104 °F tubeside inlet water temperature, 4 tubes plugged, and a fouling factor of 0.00196 hr*ft²*°F/BTU the resulting heat transfer rate is approximately 8.21E+06 BTU/hr, which maintains the 5% margin above the design heat transfer rate. System engineering has agreed to accept more stringent criteria for the cleanliness of the 1E22-S001 cooler. Therefore, the changes to the flows are acceptable and can remove the required amount of heat.</p>			
Preparer: ¹⁶	Sean Tanton	<i>Sean Tanton</i>	5/24/11
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	Matthew Cosenza	<i>Matthew Cosenza</i>	05/24/2011
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/>	Peer review <input type="checkbox"/>	
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	N/A	N/A	N/A
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Exelon Reviewer ²¹	N/A	N/A	N/A
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Exelon Approver: ²²	Dan Schmit	<i>DASchmit</i>	6/1/11
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>

Purpose:

To recover margin in Division 3 of Unit 1 of the CSCS, EC 370853 revises the flows of the 1E22-S001 cooler. 100 gpm will be diverted from the 1E22-S001 cooler. Of this 100 gpm, 50 gpm will be returned to the 1E22-C002 pump, while the other 50 gpm will be given to the 1VY02A cooler. This minor revision documents the change in flow. These flow revisions were selected by system engineering and are specified in reference 2.

This revision only applies to Unit 1. A later EC and revision to this calculation will incorporate the changes on Unit 2.

Inputs:

Tubeside flow¹ = 550 gpm (Ref. 2)
 Plugging allowance = 1% (4 tubes) (Ref. 1)
 Tubeside inlet water temperature = 104 °F (Ref. 1)
 Overall fouling factor² = 0.00223 hr*ft²*°F/BTU (Ref. 1)
 Design heat load³ = 7.8E+06 BTU/hr (Ref. 1)

¹ Note that since Proto HX assumes a water density at 60 °F, the impact on the required mass flow due to the density change at a CSCS water temperature of 104 °F was evaluated and the actual flow input in Proto-HX was 546.26 gpm.

² A fouling factor of 0.00223 hr*ft²*°F/BTU was used as a starting point for iterations to achieve the design heat transfer + 5% margin. The fouling factor that resulted in the desired margin (5%, see note 3) was 0.00196 hr*ft²*°F/BTU

³ The design heat load for the Division 3 jacket water coolers is 7.8E+06 BTU/hr, however, the desired heat load is $\geq 8.189E+06$ BTU/hr to maintain 5% thermal margin at 100% operating conditions. The 5% margin accounts for uncertainty in the Proto HX heat transfer calculations. (Ref. 1)

Assumptions:

There are no assumptions associated with this revision.

References:

1. 97-197, Rev. A, up to and including Revs A00 through A01, Thermal Model of ComEd / LaSalle Station HPCS Diesel Generator Jacket Water Coolers
2. AT 595380-11-13, CSCS HIT team - Use values provided by System Engineering to determine the new Div 3 accident penalty

Identification of Computer Programs:

The computer program used in this analysis is Proto HX version 4.01. This program has been validated per DTSQA tracking number EX0000103.

Method of Analysis / Numerical Analysis:

The existing heat exchanger model will be revised by changing the input of the "Tube Flow" from 646.1 gpm to 546.26 gpm. Iterations are made by adjusting the fouling factor to achieve the desired heat transfer rate. The results are detailed below.

Results / Conclusion:

Attachment A shows that a sufficient heat transfer rate can be achieved by reducing the fouling factor to 0.00196 hr*ft²*°F/BTU. By inputting 546.26 gpm tube flow, 104 °F tubeside inlet water temperature, 4 tubes plugged, and a fouling factor of 0.00196 hr*ft²*°F/BTU the resulting heat transfer rate is approximately 8.21E+06 BTU/hr, which maintains the 5% margin above the design heat transfer rate.

Attachments:

- A. Proto HX Calculation Report (2 pages)

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

546.26 gpm Tube Flow, 104 F Tube Temp, FF = 0.00196, 4 Tubes Plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 546.26
 Shell Flow (gpm) 1,064.50
 Tube Inlet Temp (°F) 104.00
 Shell Inlet Temp (°F) 190.00
 Input Fouling Factor 0.001960

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor
 Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 532,515.63
 Tube Mass Flow (lbm/hr) 273,266.31
 Heat Transferred (BTU/hr) 8,206,590.75
 LMTD 63.0
 Effective Area (ft²) 463.7

Overall Fouling (hr-ft²-°F/BTU) 0.001960
 Shell-Side ho (BTU/hr-ft²-°F) 1,889.2
 Tube-Side hi (BTU/hr-ft²-°F) 1,235.3
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9803
 U Overall (BTU/hr-ft²-°F) 286.6

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	3.70
Reynold's Number	77.111	27,306
Prandtl Number	2.1317	3.6710
Bulk Visc (lbm/ft-hr)	0.8212	1.3588
Skin Visc (lbm/ft-hr)	0.8772	1.1663
Density (lbm/ft³)	60.5233	61.7266
Cp (BTU/lbm-°F)	1.0025	0.9988
K (BTU/hr-ft-°F)	0.3862	0.3697

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.6
 Tav Shell (°F) 182.3
 Shell Skin Temp (°F) 172.7
 Tube Temp In (°F) 104.0
 Tube Temp Out (°F) 134.1
 Tav Tube (°F) 119.0
 Tube Skin Temp (°F) 136.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Zero Fouling The Test Heat Load Could Not Be Achieved

97-197
 Rev. A02
 Attachment A
 Page A1 of A2

Data Report for DG01B - LSCS - HPCS DG Hx.

546.26 gpm Tube Flow, 104 F Tube Temp, FF = 0.00196, 4 Tubes Plugged

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Mass Fluid Quantity, Total	lbm/hr	0.00	0.00
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor	hr·ft ² ·°F/BTU	0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Q (BTU/hr)			8,505,000
Design U (BTU/hr·ft ² ·°F)			241.70
Outside h Factor (Hoff)			0.633693000
Fixed U (BTU/hr·ft ² ·°F)			0
Fixed Area (ft ²)			0.00
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA - E
Total Effective Area per Unit (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			0.00000
Number of Shells Per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			416
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall K (BTU/hr·ft·°F)			58.00
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube Circle Diameter			0.000
Bh, Baffle Cut Height (in)			0.000
Ds, Shell Inside Diameter (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000




97-197

Rev. A02

Attachment A

Page A2 of A2

**ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet**

Design Analysis (Minor Revision)		Last Page No. ⁶ Attach. B Pg. 4/5
Analysis No.: ¹ 97-197	Revision: ² A01	
Title: ³ Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers		
EC/ECR No.: ⁴ EC 366846	Revision: ⁵ 0	
Station(s): ⁷ LaSalle	Unit No.: ⁸ 1 and 2	
Safety/QA Class: ⁹ SR	System Code(s): ¹⁰ E22	
Is this Design Analysis Safeguards Information? ¹¹ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹² Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		If yes, ATI/AR#: _____
This Design Analysis SUPERCEDES: ¹³ NA		in its entirety.
Description of Changes (list affected pages): ¹⁴		
<ul style="list-style-type: none"> • Revised pg. 2/12 of Rev. A to add new Reference 8.12 to Table 3-1 • Added Reference 8.12 to references list on page 12 of 12 of Rev. A • Replaced pgs. 3 and 4 of Attachment B in Rev. A, UFSAR Section 9.5.5.1.1 Rev. 0, with new pg. 3, UFSAR Section 9.5.5.1.1 from pending approved UFSAR Change LUCR-0082 for Rev. 17 of the UFSAR • Added new Ref. 8.12 (pg. PTD-7 from Specification J-2544 Amd. 2) to Attachment B as page 4 		
Verified no UFSAR change to the 650 gpm minimum cooling water flow value shown on Attachment B pg. 2/5 of Rev. A (UFSAR Section 9.2.1.1.1 a. 3) has occurred over time.		
Disposition of Changes: ¹⁵		
This revision updates an included UFSAR section reference with the latest approved UFSAR information, and provides an additional reference for the basis of the heat load from the DG cooler. This revision also addresses A/R (Issue Report) No. 628211 and associated assignment 02.		
Based on diesel generator nameplate data obtained by the System Manager, the Div. 3 diesel is from the same manufacturer, is the same model number, and has the same rated output as the Div. 1 and 2 DGs. Technical proposal heat balance data for the Div. 1 and 2 DGs, submitted by the supplier (see Ref. 8.12 in Attachment B, pg. PTD-7 from Purchase Specification J-2544 Amendment 2), shows that the energy absorbed by the cooling water at rated load and design ambient conditions is 2284 kW, which converts to 7.8E+06 Btu/hr, as stated in the UFSAR and used in previous revisions of the calculation.		
Preparer: ¹⁶ Dan Schmit	 _____ Print Name	8/03/07 _____ Date
Method of Review: ¹⁷ Detailed Review <input checked="" type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing <input type="checkbox"/>		
Reviewer: ¹⁸ Sean Tanton	 _____ Print Name	8/9/07 _____ Date
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>	
<small>(For External Analyses Only)</small>		
External Approver: ²⁰ NA	_____ Print Name	_____ Sign Name
Exelon Reviewer ²¹ NA	_____ Print Name	_____ Sign Name
Exelon Approver: ²² Bill Hilton	 _____ Print Name	8-10-07 _____ Date

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A 01	PAGE 2 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

the necessary information for model construction while performance specifications provided by the vendor are used to benchmark the model.

Thermal performance of the HPCS diesel generator heat exchanger is assessed in this calculation at the LaSalle Station Reference Conditions of Section 3.1 with all tubes active and 100% of rated load. No tube plugging margin or load conditions beyond 100% are considered.

3.1. LASALLE STATION REFERENCE CONDITIONS

Table 3-1 describes the performance requirement of the jacket water cooler. These conditions ensure that the engine operating temperature range will not be exceeded.

Table 3-1 LaSalle Station Reference Conditions

Parameter	Value	Reference
Heat Load at 100% power (BTU/hr)	7,800,000	8.1, 8.4, 8.12
Shell-Side Flow Rate (gpm)	1,100	8.4
Shell-Side Inlet Temperature (°F)	190	8.4
Tube-Side Flow Rate (gpm)	650	8.1
Maximum Tube-Side Inlet Temperature (°F)	100	8.1

3.2. CONSTRUCTION DETAILS

Table 3-2 Vendor Construction Detail

Parameter	Value	Reference
Heat Exchanger Type	TEMA - E	8.7, 8.8
Number of Shells per unit	1	8.7
Total Effective Area per unit (ft ²)	482	8.6, See Below
Shell Velocity (ft/sec)	5.6	8.6
Baffle Thickness (in)	3/8 (min)	8.8
Fixed Tubesheet Thickness (in)	1	8.8
Floating Tubesheet Thickness (in)	1-1/4	8.8
Tube Passes per shell	2	8.7
U-Tubes (yes or no)	No	8.7
Total Number of Tubes	420	8.6, 8.8
Tube Length (ft)	7	8.6
Tube Inside Diameter (in)	0.541 (19 BWG)	8.6
Tube Outside Diameter (in)	5/8	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A 01	PAGE 12 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

8.0 REFERENCES

- 8.1. LaSalle Station UFSAR, Sections: 9.2.1 and 9.5.5.1.1 (Attachment B)
- 8.2. NRC Generic Letter 89-13
- 8.3. GE Purchase Specification - 211872RO-SW9 Item 4.3.6.1
- 8.4. LaSalle Station FSAR Q40.92 (Attachment B)
- 8.5. Stewart & Stevens Vendor Manual, VM J-152 through VM J-157
- 8.6. O & M Manufacturing Hx Data Sheet (Attachment A)
- 8.7. LaSalle Station Drawing, VPF - 3411-080(1)-1, J-2500 (Attachment A)
- 8.8. LaSalle Station Drawing, VPF - 3411-080(2)-1, J-2500 (Attachment A)
- 8.9. Standard of the Tubular Exchanger Manufacturers Association
- 8.10. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.02 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision F, dated 2/17/98
- 8.11. Proto-Power Calculation 93-048, "Fluid Properties – Fresh Water – Range 32°F to 500°F", Rev. A
- 8.12. Proposal Technical Data for Diesel Engine-Generator Sets from Specification J-2544 Amd. 2, pg. PTD-7

LSCS-UFSAR

excessive or shutdown time is too short to permit remote detection of possible fuel oil leaks at the day tank or diesel generator.

9.5.5 Diesel-Generator Cooling Water System

The function of the diesel-generator cooling water system is to transfer the heat rejected from the engine water jacket, the lube oil cooler and the engine air aftercooler to the CSCS equipment cooling water system (CSCS-ECWS).

9.5.5.1 Design Bases

9.5.5.1.1 Safety Design Bases

Cooling capacity of this system is based on a diesel-generator output of 2860 kW with an environmental temperature of 122° F maximum and a minimum and maximum lake water temperature of 32° F and (102) F, respectively. Total heat transfer by this system is approximately 7.8×10^6 Btu/hr per diesel-generator set at rated engine capacity. The Division I and II diesel cooling water heat exchangers are sized based on operation of 110% of rated load. The Division III diesel cooling water heat exchangers are sized based on operation of 100% of rated load. 104

High water temperature is alarmed at 200° F and the engine is automatically shut down if the cooling water temperature at the engine outlet exceeds 208° F in order to prevent engine damage due to overheating. This shutdown control is in effect only when the engine is started manually and bypassed when the diesel generator is started automatically during an emergency.

Heaters are installed in the cooling water piping below the lube oil cooler to maintain the engine water and lube oil in a warm standby condition while the engine is not operating; thus increasing the starting reliability of the diesel generator. Natural convection is employed to circulate the warm engine water through the lube oil cooler during standby.

Each system is designed based on Seismic Category I requirements and is protected from tornadoes, missiles, and flooding.

9.5.5.1.2 Power Generation Design Bases

The diesel-generator cooling water system is not required during power generation. Consequently, it possesses no power generation design bases.

9.5.5.2 System Description

Each diesel-generator cooling water system is a separate, independent closed loop system supplied with the diesel generator and located entirely on the diesel-generator skid. It consists of two parallel engine driven centrifugal circulating pumps, a low-pressure expansion tank, an AMOT temperature regulating valve, a

REFERENCE 8.12

Proposal Technical Data for
 Diesel Engine-Generator Sets, Cont.
 La Salle County Station - Units 1 and 2

J-2544
 Amd. 2, 01-27-78

Name of Bidder: Steward & Stevenson Services, Inc.

ENGINE-GENERATOR DATA, Cont.

(Insert all data in these columns)

	BASE BID		ALTERNATE 1
	DIESEL GEN. 0	DIESEL GEN. 1A AND 2A	DIESEL GEN. 0, 1A AND 2A
k. WK ² value of all rotating parts.....(lb-ft ²)	34,690		
l. Is base frame stress relieved after fabrication but before machining.....	no		
m. Vibration Dampers:			
(1) Type.....	None required or recommended		
(2) Number.....	N/A		
n. Full load speed.....(r/min)	900		
o. Diesel Heat Balance at rated load and design ambient temperature:			
(1) Diesel shaft output (kW)	* 2,600		
(2) Energy absorbed by cooling water.....(kW)	2,284 × 3.	$414 \times 10^3 \frac{Btu}{hr} \times \frac{1}{kW} = 7.8 \times 10^6 \frac{Btu}{hr}$	
(3) Energy dissipated in exhaust gases.....(kW)	2,689		
(4) Energy lost to ambient by radiation and convection.....(kW)	260		
p. Environmental Data:			
(1) Maximum ambient temperature for continuous operation.....(°F)	104°		Amd. 2
(2) Minimum ambient temperature for continuous operation.....(°F)	30°		Amd. 2
(3) Generator losses to ambient at rated load and design ambient.(kW)	98		

*Note: 2,600 kW at 90°F Ambient (This would derate 4% in 40°C - 104°F)

Calc. 97-197 R. A01
 Attach. B
 Pg. 4/5

125

LASALLE CALCULATION

EDITORIAL - COMMENT TO CALCULATION

Affecting

Calculation No.: 97-197

Rev: A00

For Reference

Page No. 1 of 1

The use of this form shall be limited to document corrections of editorial nature. Return to Sylvia Venecia

Prepared by:

~~Sylvia Venecia~~
Print Sign

6/3/02

Date

Reviewed by:

Print

Sign

Date

Approved by:

Print

Sign

Date

Description of Correction:

1) Pages 3 thru 6, A1, B1 + C1 are on forms with the
Comed logo, which are not the most current
forms.

Per J.T. Conner on 5/28/02. OK to Process. In
the future the most current forms will be
used.

When these comments are incorporated, return this form with the revised calculation.

Incorporated on Calc Rev.

By:

Date:

CC-AA-309 - ATTACHMENT 1 - Design Analysis Approval

Page 1 of 2

DESIGN ANALYSIS NO.: Calc. # 97-197		PAGE NO. 1	
Major REV Number: A		Minor Rev Number: 00	
<input type="checkbox"/> BRAIDWOOD STATION <input type="checkbox"/> BYRON STATION <input type="checkbox"/> CLINTON STATION <input type="checkbox"/> DRESDEN STATION <input checked="" type="checkbox"/> LASALLE CO. STATION <input type="checkbox"/> QUAD CITIES STATION		DESCRIPTION CODE: (C018) <u>M010</u>	
Unit: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3		DISCIPLINE CODE: (C011) <u>M</u>	
		SYSTEM CODE: (C011) <u>E22</u>	
TITLE: THERMAL MODEL OF COMED/LASALLE STATION UNIT 1 AND 2 HPCS DIESEL GENERATOR COOLERS			
<input checked="" type="checkbox"/> Safety Related		<input type="checkbox"/> Augmented Quality	
<input type="checkbox"/> Non-Safety Related			
ATTRIBUTES (C016)			
TYPE	VALUE	TYPE	VALUE
Elevation	710' 0"		
Software	PROTO-HX		
COMPONENT EPN: (C014 Panel)		DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)	
EPN	TYPE	Type/Sub	Document Number
1E22-S001	H15	EC/DCP	EC# 334017
2E22-S001	H15	/	
		/	
		/	
		/	
		/	
		/	
REMARKS: NA			

DESIGN ANALYSIS NO. 97-197

REV: A00 PAGE NO. 2

Revision Summary (including EC's incorporated): Updated Proto-HX model for 104°F Service Water inlet temperature and calculated Unit 1 and 2 HPCS DG Cooler thermal margins for different fouling factors and 1% tubes plugged.

Electronic Calculation Data Files: ProtoHX 3.02, dg01b.phx, 192 KB, 04/14/2002, 5:04pm
(Program Name, Version, File Name extension/size/date/hour/min)

Design impact review completed? Yes N/A, Per EC#: 334017
(If yes, attach impact review sheet)

Prepared by: Jeff W. VanStrien / Jeff W. VanStrien / 1 5 9-02
- Print Sign Date

Reviewed by: Brian L. Davenport / Brian L. Davenport / 1 5-9-02
- Print Sign Date

Method of Review: Detailed Alternate Test

This Design Analysis supersedes: N/A in its entirety.

Supplemental Review Required? Yes No
 Additional Review Special Review Team

Additional Reviewer or Special Review Team Leader: _____ / _____ / _____
- Print Sign Date

Special Review Team: (N/A for Additional Review)

Reviewers: 1) _____ / _____ / _____ 2) _____ / _____ / _____
- Print Sign Date Print Sign Date
3) _____ / _____ / _____ 4) _____ / _____ / _____
- Print Sign Date Print Sign Date

Supplemental Review Results:

Approved by: J.T. Connor / J.T. Connor / 1 5/14/02
- Print Sign Date

External Design Analysis Review (Attachment 3 Attached)

Reviewed by: _____ / _____ / _____
- Print Sign Date

Approved by: _____ / _____ / _____
- Print Sign Date

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? Yes No
Tracked By: AT#, EC# etc.) _____

CALCULATION TABLE OF CONTENTS

CALCULATION NO. 97-197		REV. NO. A00 PAGE NO. 3	
SECTION:	PAGE NO.	SUB-PAGE NO.	
DESIGN ANALYSIS APPROVAL / TITLE PAGE	1		
DESIGN ANALYSIS APPROVAL / REVISION SUMMARY	2		
TABLE OF CONTENTS	3		
1.0 PURPOSE / OBJECTIVE	4		
2.0 METHODOLOGY AND ACCEPTANCE CRITERIA	4		
3.0 ASSUMPTIONS / ENGINEERING JUDGEMENTS	4		
4.0 DESIGN INPUT	4		
5.0 REFERENCES	4		
6.0 CALCULATIONS	5		
7.0 SUMMARY AND CONCLUSIONS	6		
8.0 ATTACHMENTS:	6		
Attachment "A" – Proto-Hx Calc. Report for DG01B (CSCS=104 F @ Design Fouling)	A1 to A3		
Attachment "B" – Proto-Hx Calc. Report for DG01B (CSCS=104 F @ 2X Max. Tested FF)	B1 to B3		
Attachment "C" – Proto-Hx Calc. Report for DG01B (CSCS=104 F @ 2X Max. Tested FF, w\ 1% plugged)	C1 to C3		

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-197

REV. NO. A00

PAGE NO. 4 of 6

1.0 PURPOSE/OBJECTIVE

The purpose of this minor revision is to revise the thermal model of this heat exchanger for a 104°F Service Water inlet temperature. This assessment will evaluate the adequacy of HPCS Diesel Generator Coolers during a maximum allowable inlet service water temperature of 104°F to ensure adequate thermal margin still exist. Also an acceptable design fouling factor for use as a benchmark during Generic Letter 89-13 testing evaluations will be determined.

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp." from 100°F to 104°F and simulated for the following conditions: (Case 1) design fouling factor, (Case 2) twice the 'as-tested' fouling factor and (Case 3) twice the 'as-tested' fouling factor with 1% of the tubes plugged. The acceptance criteria will be for the thermal margin during Case 3 conditions to exceed the LaSalle design heat load of 7,800,000 BTU/hr at 100% rated power output (Ref. 1, Table 3-1). Additional conservatism is built into this acceptance criteria by assuming a 5% uncertainty in the Proto-HX heat transfer calculations. The Reference 1 model developed for this heat exchanger demonstrated a correlation to vendor performance specification well within this assumed 5% margin.

3.0 ASSUMPTIONS / ENGINEERING JUDGMENTS

The assumptions indicated in section 5.0 of Reference 1 are still valid.

Note: The density of water at 104°F is 61.94 lb/ft³ (per steam tables), this is an insignificant change to the density shown in table 4-1 of Ref. 1 for 100°F, the tube side volumetric flow rate correction made in Ref. 1 is still valid.

4.0 DESIGN INPUTS

The design inputs consist of References 1 and 2 listed below.

5.0 REFERENCES

1. Calculation No. 97-197, Rev. A, "Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers".
2. Calculations L-002399, Rev. 0 (Unit 2) & L-002684, Rev. 0 (Unit 1), "1 & 2E22-S001 HPCS Diesel Generator Cooler Thermal Heat Transfer Performance"
3. "Standards of the Tubular Exchanger Manufacturers Association" (TEMA), Seventh Edition, 1988.

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-197

REV. NO. A00

PAGE NO. 5 of 6

6.0 CALCULATIONS

The current calculation model is based on a Service Water inlet temperature of 100°F. At this temperature and with a fouling factor of 0.002732 hr* ft^2 *°F/BTU, the amount of heat transferred is 7,801,000 BTU/hr compared with a LaSalle Station design heat load of 7,800,000 BTU/hr at 100% rated power output resulting in a 0.01% thermal margin (Ref. 1, Table 6-3). The cooler appears to have little thermal margin.

Thermal margin is calculated by the following method:

Required Heat Load - Calculated Heat Transfer = Thermal Margin [Equation 1]

To express this as a percent of the required heat load, the following method is used:

$$\frac{\text{Thermal Margin}}{\text{Required Heat Load}} \times 100\% = \% \text{Thermal Margin} \quad \text{[Equation 2]}$$

Case 1

When the service water inlet temperature is increased to 104°F for the same fouling factor (0.002732 hr* ft^2 *°F/BTU), the heat transfer reduces to 7,474,000 BTU/hr, which is 4.2% below the required load of 7,800,000 BTU/hr for 100% power operating conditions [Attachment A].

Case 2

Regular cleaning and testing of these heat exchangers limits the amount of fouling well below the values assumed above. The heat exchanger performance data taken under the G.L. 89-13 program here at LaSalle demonstrates a maximum measured fouling factor of 0.001117 hr* ft^2 *°F/BTU (Ref. 2). For conservatism, this value was doubled to 0.00223 hr* ft^2 *°F/BTU and simulated with 104°F service water inlet temperature. The result was a heat transfer of 8,237,000 BTU/hr for a 5.6% thermal margin at 100% power operating conditions [Attachment B].

E-FORM

CALCULATION PAGE**CALCULATION NO. 97-197****REV. NO. A00****PAGE NO. 6 of 6**Case 3

When additional conservatism was included by adding a plugging allowance of 4 tubes, 1% of the total, in the heat exchanger and running the model again at the above fouling factor (0.00223 hr* ft^2 *°F/BTU) and inlet temperature (104°F) for a 8,189,000 BTU/hr heat transfer rate, representing a 5% thermal margin at 100% power operating conditions [Attachment C].

This is judged to be a reasonably conservative fouling factor since it is slightly higher than the typical fouling factors stated in Ref. 3, page 215. The LaSalle lake water quality will meet or exceed the "River Water Fouling Factor" (at a velocity greater than 3 ft/sec) given in this reference. The lake water passes through strainers and is chemically treated for silt control and scale prevention.

7.0 SUMMARY AND CONCLUSIONS

The Diesel Generator Water Cooler Model was found to have adequate thermal margin for a maximum lake temperature of 104°F when operated at 100% rated power output with a fouling factor of less than or equal to 0.00223 hr* ft^2 *°F/BTU and a plugging allowance of 1% (4 tubes). This fouling factor has been determined to be an acceptable benchmark value that can be used in Generic Letter 89-13 testing evaluations of this model heat exchanger.

8.0 ATTACHMENTS:

Attachment "A" – Proto-Hx Calc. Report for DG01B

(CSCS=104 F @ Design Fouling)

Attachment "B" – Proto-Hx Calc. Report for DG01B

(CSCS=104 F @ 2X Max. Tested FF)

Attachment "C" – Proto-Hx Calc. Report for DG01B

(CSCS=104 F @ 2X Max. Tested FF, w/ 1% plugged)

Final Page
(Last Page)

E-FORM

Attachment "A"

Proto-Hx Calc. Report for DG01B
(CSCS=104 F @ Design Fouling)

E-FORM

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS = 104 F @ Design Fouling

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,064.46	795.25
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00193
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		241.70
Empirical Factor for Outside h		0.633693000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		468.17
Area Factor		0.973212339
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr·ft·°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS = 104 F @ Design Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	646.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Calculation No. 97-197
 Revision No. A00
 Attachment A
 Page No. A3 of A3

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft²-°F/BTU)	0.002732
Tube Mass Flow (lbm/hr)	3.232E+5	Shell-Side ho (BTU/hr-ft²-°F)	1,894.1
Heat Transferred (BTU/hr)	7.474E+6	Tube-Side hi (BTU/hr-ft²-°F)	1,372.6
LMTD	67.3	1/Wall Resis (BTU/hr-ft²-°F)	15,431.0
Effective Area (ft²)	468.2	LMTD Correction Factor	0.9880
Property	Shell-Side	Tube-Side	U Overall (BTU/hr-ft²-°F)
Velocity (ft/s)	5.58	4.34	240.0
Reynold's Number	7.746E+04	3.095E+04	Shell Temp In (°F)
Prandtl Number	2.12	3.81	190.0
Bulk Visc (lbm/ft-hr)	0.82	1.41	Shell Temp Out (°F)
Skin Visc (lbm/ft-hr)	0.87	1.24	176.0
Density (lbm/ft³)	60.51	61.78	Tav Shell (°F)
Cp (BTU/lbm-°F)	1.00	1.00	183.0
K (BTU/hr-ft-°F)	0.39	0.37	Shell Skin Temp (°F)
			174.5
			Tube Temp In (°F)
			104.0
			Tube Temp Out (°F)
			127.2
			Tav Tube (°F)
			115.6
			Tube Skin Temp (°F)
			129.2

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "B"

Proto-Hx Calc. Report for DG01B
(CSCS=104 F @ 2X Max. Tested FF)

E-FORM

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS = 104 F @ 2X NDIT FF

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor	*	0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,505,000
Design Heat Trans Coeff (BTU/hr-ft ² -°F)			241.70
Empirical Factor for Outside h			0.633693000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			420
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall Conductivity (BTU/hr-ft-°F)			58.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Calculation No. 97-197
Revision No. A00
Attachment B
Page No. B2 of B3

* Fouling Factor input on next page.

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS = 104 F @ 2X NDIT FF

Calculation Specifications

- Constant Inlet Temperature Method Was Used
- Extrapolation Was to User Specified Conditions
- * Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 646.1
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 104.0
 Shell Inlet Temp (°F) 190.0

* Input Fouling Factor 0.002230

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Calculation No. 97-197
 Revision No. A00
 Attachment β
 Page No. β3 of β3

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.232E+5
 Heat Transferred (BTU/hr) 8.237E+6
 LMTD 65.4
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002230
 Shell-Side ho (BTU/hr-ft²-°F) 1,889.3
 Tube-Side hi (BTU/hr-ft²-°F) 1,383.0
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9845

U Overall (BTU/hr-ft²-°F) 273.3

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.34
Reynold's Number	7.709E+04	3.130E+04
Prandtl Number	2.13	3.76
Bulk Visc (lbm/ft-hr)	0.82	1.39
Skin Visc (lbm/ft-hr)	0.88	1.21
Density (lbm/ft³)	60.52	61.76
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.6
 Tav Shell (°F) 182.3
 Shell Skin Temp (°F) 172.8
 Tube Temp In (°F) 104.0
 Tube Temp Out (°F) 129.5
 Tav Tube (°F) 116.8
 Tube Skin Temp (°F) 131.7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

Attachment "C"

Proto-Hx Calc. Report for DG01B
(CSCS=104 F @ 2X Max. Tested FF, w/ 1% plugged)

E-FORM

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS=104 F@ 2X NDIT FF, 1% plug

Shell and Tube Heat Exchanger Input Parameters			
--	--	--	--

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor	*	0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			241.70
Emprical Factor for Outside h			0.633693000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			416
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall Conductivity (BTU/hr·ft·°F)			58.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Calculation No. 97-197

Revision No. A00

Attachment CPage No. C2 of C3

* Fouling factor input on next page.

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS=104 F@ 2X NDIT FF, 1% plug

Calculation Specifications

- Constant Inlet Temperature Method Was Used
- Extrapolation Was to User Specified Conditions
- * Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	646.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	104.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	* Input Fouling Factor	0.002230

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft ³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)	Calculation No. 97-197
Shell Temp Out (°F)	Revision No. A00
Tav Shell (°F)	Attachment <u>C</u>
Shell Skin Temp (°F)	Page No. <u>C3</u> of <u>C3</u>
Tube Temp In (°F)	
Tube Temp Out (°F)	
Tav Tube (°F)	
Tube Skin Temp (°F)	

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002230
Tube Mass Flow (lbm/hr)	3.232E+5	Shell-Side ho (BTU/hr-ft ² -°F)	1,889.4
Heat Transferred (BTU/hr)	8.189E+6	Tube-Side hi (BTU/hr-ft ² -°F)	1,393.0
LMTD	65.5	1/Wall Resis (BTU/hr-ft ² -°F)	15,431.0
Effective Area (ft ²)	463.7	LMTD Correction Factor	0.9848

U Overall (BTU/hr-ft²-°F) 273.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.38
Reynold's Number	7.712E+04	3.158E+04
Prandtl Number	2.13	3.76
Bulk Visc (lbm/ft-hr)	0.82	1.39
Skin Visc (lbm/ft-hr)	0.88	1.21
Density (lbm/ft ³)	60.52	61.76
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	190.0
Shell Temp Out (°F)	174.7
Tav Shell (°F)	182.3
Shell Skin Temp (°F)	172.8
Tube Temp In (°F)	104.0
Tube Temp Out (°F)	129.4
Tav Tube (°F)	116.7
Tube Skin Temp (°F)	131.6

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achiev

**PROTO-POWER CORPORATION
CALCULATION TITLE SHEET**

CLIENT: Commonwealth Edison / LaSalle County Station

PROJECT: COMED / LaSalle Station GL 89-13 Program

CALCULATION TITLE: Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers.

CALCULATION NO.: 97-197

FILE NO.: 31-003

COMPUTER CODE & VERSION (if applicable): PROTO-HX™ ver 3.02

REV	TOTAL NO. OF PAGES	ORIGINATOR/DATE	VERIFIER/DATE	APPROVAL/DATE
A	58	<i>D. Phyfe</i> 6/26/98 D. Phyfe	<i>Scott M. Ingalls</i> 6/24/98 S. Ingalls	<i>L. Philpot</i> 6/30/98 L. Philpot

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE II OF V
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers.			

Revision History

Revision	Revision Description
A	Original Issue

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE III OF V
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers.			

CALCULATION VERIFICATION FORM

REVIEW METHOD:

- | | | | |
|--|-------------------------------------|-----|-------------------------------------|
| Approach Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Logic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Arithmetic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Alternate Method
(Attach Brief Summary) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Computer Program Used
(Attach Listing) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Other | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |

EXTENT OF VERIFICATION:

- | | |
|-------------------------|-------------------------------------|
| Complete Calculation: | <input checked="" type="checkbox"/> |
| Revised areas only: | <input type="checkbox"/> |
| Other (describe below): | <input type="checkbox"/> |

***Errors Detected**

Editorial Comments

References Need to be updated + Density Reference Added

ProtoHX density effects need to be accounted for

***Error Resolution**

Sections Revised as Necessary

References updated/Added

section Added to discuss ρ and PROTOHX runs re-run.

***Other Comments**

None

***Extra References Used**

*(Attach extra sheets if needed)

CALCULATION FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT AND REASONABLE:

IDV Signature: Scott M. Ingalls

Printed Name: Scott M. Ingalls

Initials: SI

Date: 6/26/98

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE IV OF V
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers.			

TABLE OF CONTENTS

CALC TITLE SHEET I

REVISION HISTORY II

CALC VERIFICATION SHEET III

TABLE OF CONTENTS IV

LIST OF ATTACHMENTS V

Total number of pages in Preface of Calc 5

1.0 PURPOSE 1

2.0 BACKGROUND 1

3.0 DESIGN INPUTS 1

 3.1. LASALLE STATION REFERENCE CONDITIONS 2

 3.2. CONSTRUCTION DETAILS 2

 3.3. PERFORMANCE DETAILS 3

4.0 APPROACH 4

 4.1. PROTO-HX™ PARAMETER CALCULATION 4

 4.2. PROTO-HX™ FLOW RATE INPUTS 5

 4.3. PROTO-HX™ EXTRAPOLATION METHOD 5

5.0 ASSUMPTIONS 5

6.0 ANALYSIS 6

 6.1. PROTO-HX™ MODEL 6

 6.2. HEAT EXCHANGER FOULING FACTOR LIMIT 6

 6.3. FOULING SENSITIVITY 8

 6.4. THERMAL MARGIN ASSESSMENT 9

 6.5. MINIMUM SERVICE WATER FLOW RATE 9

7.0 CONCLUSION 11

 7.1. PROTO-HX™ MODEL 11

 7.2. HEAT EXCHANGER FOULING FACTOR LIMIT 11

 7.3. FOULING SENSITIVITY 11

 7.4. THERMAL MARGIN ASSESSMENT 11

 7.5. MINIMUM SERVICE WATER FLOW RATE 11

8.0 REFERENCES 12

Total number of pages in Body of Calc 12

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC. NO. 97-197	REV A	PAGE V OF V
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station HPCS Diesel Generator Jacket Water Coolers.			

LIST OF ATTACHMENTS

<u>Attachment</u>	<u>Subject Matter</u>	<u>Total Pages</u>
A	Proto-Power Calc. 97-197, Rev. A; Vendor Data Sheet & Drawings	4
B	Proto-Power Calc. 97-197, Rev. A; LaSalle Station UFSAR Section: 9.5.5.1.1, and FSAR Q40.92	5
C	Proto-Power Calc. 97-197, Rev. A; PROTO-HX™ HPCS Model Development Calculation Reports	13
D	Proto-Power Calc. 97-197, Rev. A; PROTO-HX™ Calculation Reports for Fouling Sensitivity	7
E	Proto-Power Calc. 97-197, Rev. A; PROTO-HX™ Calculation Reports for Minimum Service Water Flow	10
F	Proto-Power Calc. 97-197, Rev. A; PROTO-HX™ Version 3.02 Model	2 (and disk)

Number of Attachment Pages: 41

Complete Calc (total number of pages) 58

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 1 OF 12
	ORIGINATOR D. Phye		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

1.0 PURPOSE

The purpose of this calculation is to develop a thermal performance analysis model for the Commonwealth Edison (ComEd) LaSalle Station, High Pressure Core Spray (HPCS) Diesel Generator heat exchanger. This model is to be used for the analysis of heat exchanger thermal performance test data as part of the LaSalle Station heat exchanger testing program.

Once developed, the model is used to evaluate the thermal margin of the heat exchanger at the LaSalle Station Reference Conditions as currently defined in the LaSalle design and licensing basis.

The thermal performance model documented in this calculation has been created and used with PROTO-HX, Version 3.02. The model can be used with previous versions of PROTO-HX and produce identical results as long as the following restrictions are upheld:

- Versions prior to version 3.02 will not calculate a negative fouling factor when calculating the fouling factor based on test data.
- Shell and tube heat exchangers analyzed in Version 3.0 or earlier must have a tube-side Reynolds Number greater than 10,000 (i.e., fully developed turbulent flow).

Current limitations of use for PROTO-HX are established by the limits on fluid properties included within the software. Fluid properties contained within PROTO-HX are currently limited to the following temperature ranges:

- Water (fresh and salt): 32-500°F

2.0 BACKGROUND

LaSalle Station is in the process of implementing a heat exchanger thermal performance monitoring program in response to the requirements of NRC Generic Letter 89-13 (Reference 8.2). Development of an analytical model in PROTO-HX™, Version 3.02, will allow timely analysis of data resulting from the test program.

3.0 DESIGN INPUTS

The PROTO-HX™ program was developed and validated in accordance with Proto-Power's Nuclear Software Quality Assurance Program (SQAP). This program meets the requirements of 10CFR50 Appendix B, 10CFR21, and ANSI NQA-1, and was developed in accordance with the guidelines and standards contained in ANSI/IEEE Standard 730/1984 and ANSI NQA-2b-1991. PROTO-HX™ Version 3.02 was verified and approved for use as documented in Reference 8.10.

The design inputs for this calculation consist of the LaSalle Station Reference Condition (Section 3.1), Construction Details (Section 3.2), and Performance Details (Section 3.3) provided by the heat exchanger vendor data sheets or design documents as referenced. Construction details give

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 2 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

the necessary information for model construction while performance specifications provided by the vendor are used to benchmark the model.

Thermal performance of the HPCS diesel generator heat exchanger is assessed in this calculation at the LaSalle Station Reference Conditions of Section 3.1 with all tubes active and 100% of rated load. No tube plugging margin or load conditions beyond 100% are considered.

3.1. LASALLE STATION REFERENCE CONDITIONS

Table 3-1 describes the performance requirement of the jacket water cooler. These conditions ensure that the engine operating temperature range will not be exceeded.

Table 3-1 LaSalle Station Reference Conditions

Parameter	Value	Reference
Heat Load at 100% power (BTU/hr)	7,800,000	8.1, 8.4
Shell-Side Flow Rate (gpm)	1,100	8.4
Shell-Side Inlet Temperature (°F)	190	8.4
Tube-Side Flow Rate (gpm)	650	8.1
Maximum Tube-Side Inlet Temperature (°F)	100	8.1

3.2. CONSTRUCTION DETAILS

Table 3-2 Vendor Construction Detail

Parameter	Value	Reference
Heat Exchanger Type	TEMA - E	8.7, 8.8
Number of Shells per unit	1	8.7
Total Effective Area per unit (ft ²)	482	8.6, See Below
Shell Velocity (ft/sec)	5.6	8.6
Baffle Thickness (in)	3/8 (min)	8.8
Fixed Tubesheet Thickness (in)	1	8.8
Floating Tubesheet Thickness (in)	1-1/4	8.8
Tube Passes per shell	2	8.7
U-Tubes (yes or no)	No	8.7
Total Number of Tubes	420	8.6, 8.8
Tube Length (ft)	7	8.6
Tube Inside Diameter (in)	0.541 (19 BWG)	8.6
Tube Outside Diameter (in)	5/8	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 3 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

Table 3-2 Vendor Construction Detail

Parameter	Value	Reference
Tube Wall Conductivity (BTU/hr-ft-°F)	58 (Admiralty Naval Brass)	8.6, 8.9
Tube Pitch (in)	3/4	8.6
Pitch Type	Triangle	8.8

The vendor data sheet shows the effective area as 482 ft², however, based on the outside tube diameter and tube length, this value is a gross area (A_{gr}) approximation:

$$A_{gr} = (\text{number of tubes}) \cdot (L_{\text{tube}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 1}$$

$$A_{gr} = 420 \cdot 7 \text{ ft} \cdot \pi \cdot \left(\frac{0.625 \text{ in}}{12 \text{ in/ft}} \right) = 481.056 \text{ ft}^2$$

The effective area (A_{eff}) can be approximated as follows:

$$A_{\text{eff}} = (\text{number of tubes}) \cdot (L_{\text{tube}} - T_{\text{fixed}} - T_{\text{floating}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 2}$$

$$A_{\text{eff}} = 420 \cdot \left(7 \text{ ft} - \frac{(1 \text{ in} + 1.25 \text{ in})}{12 \text{ in/ft}} \right) \cdot \pi \cdot \left(\frac{0.625 \text{ in}}{12 \text{ in/ft}} \right) = 468.171 \text{ ft}^2$$

where :

A_{gr} – Heat Exchanger Gross Area, ft²

A_{eff} – Heat Exchanger Effective Area, ft²

L_{tube} – Tube Length, ft

T_{fixed} – Fixed End Tubesheet Thickness, ft (1" per Reference 8.8)

T_{floating} – Floating End Tubesheet Thickness, ft (1.25" per Reference 8.8)

The data sheet value for the effective area will be used in the model benchmarking process. However, for PROTO-HX™ runs of the HPCS heat exchanger model the above calculated effective area will be used.

3.3. PERFORMANCE DETAILS

Table 3-3 Vendor Performance Detail

Parameter	Value	Reference
Shell Side Fluid Type	Water (Fresh)	8.6
Shell Side Fouling Factor (Design)	0.0005	8.6
Shell Side Fluid Flow Rate (gpm)	1100	8.6

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 4 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

Table 3-3 Vendor Performance Detail

Parameter	Value	Reference
Shell Side Inlet Temperature (°F)	190	8.6
Shell Side Outlet Temperature (°F)	175	8.6
Tube Side Fluid Type	Raw Water (Fresh)	8.6
Tube Side Fouling Factor (Design)	0.002	8.6
Tube Side Fluid Flow Rate (gpm)	800	8.6
Tube Side Inlet Temperature (°F)	100	8.6
Tube Side Outlet Temperature (°F)	121	8.6
Hx. Design Q - Service (BTU/hr)	8,505,000	8.6
Hx. Design U - Service (BTU/hr-ft ² -°F)	241.7	8.6
Corrected LMTD	73	8.6

4.0 APPROACH

This calculation utilizes plant/vendor fabrication specifications provided in Attachment A to develop a thermal performance prediction model for the LaSalle Station HPCS Diesel Generator Jacket Water Coolers. The calculation then benchmarks the model by comparing the heat transfer rate calculated by PROTO-HX™ Version 3.02 with the vendor's specifications for thermal performance.

4.1. PROTO-HX™ PARAMETER CALCULATION

Minimum Shell Area

The minimum shell area is calculated using either the shell side velocity or a shell geometry. The preferred method of calculation is using the shell side velocity. Reference 8.6 gives the shell side velocity to be 5.6 ft/sec at a flow of 1100 gpm. Based on this velocity and flow rate the minimum shell side area is calculated by PROTO-HX™ to be 0.438 ft².

Outside H Factor (Hoff)

The Outside H Factor is a multiplier, with value less than 1.0, used to reduce the ideal shell-side film heat transfer coefficient. The Outside H Factor accounts for inefficiency in the heat exchanger. Using the back calculation method based on the design overall heat transfer coefficient, the Outside H Factor was calculated by PROTO-HX™ to be 0.616913. Values of the Outside H Factor in the range of 0.6 are considered to be representative of a "well designed" heat exchanger.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 5 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

4.2. PROTO-HX™ FLOW RATE INPUTS

When the volumetric flow rates are entered into PROTO-HX™ they are converted to mass flow rates based on a set temperature of 60°F. Therefore, the actual PROTO-HX™ inputs have to be adjusted to give the correct mass flow rate. The PROTO-HX™ input is adjusted using the ratio of the actual water density and the density of water at 60°F.

$$Q_{phx} = Q_{temp} \cdot \frac{\rho_{temp}}{\rho_{60°F}} \quad \text{Equation 3}$$

Table 4-1 PROTO-HX™ Flow Rate Inputs

Parameter	Density (lb/ft ³)	Actual Flow (gpm)	PROTO-HX™ Input (gpm)
Tube-side, 100°F	61.994 (8.11)	800	795.25
	61.994 (8.11)	650	646.14
Shell-side, 190°F	60.349 (8.11)	1,100	1,064.495
PROTO-HX™, 60°F	62.364 (8.11)		

4.3. PROTO-HX™ EXTRAPOLATION METHOD

All calculations performed for this calculation are based on a constant cold inlet temperature. This allows the comparison of the heat transfer, outlet temperatures, log mean temperature difference (LMTD), and overall heat transfer coefficient. There is no comparison of the overall heat transfer coefficient in the design case since PROTO-HX™ used the data sheet value of the overall heat transfer coefficient to calculate the outside film heat transfer coefficient.

5.0 ASSUMPTIONS

- 5.1. The vendor data sheet (Reference 8.6) is considered to be an accurate reflection of the vendor's expectation for the heat exchanger's outside film heat transfer coefficient. Therefore, the benchmarking of the PROTO-HX™ model to the vendor data sheet will ensure that the PROTO-HX™ calculated outside film heat transfer coefficient is consistent with the vendor's expectation. The PROTO-HX™ model is benchmarked with the vendor data sheet effective area. However calculations performed with the model use the effective area determined in Section 3.2. Future validation of this assumption is not required.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 6 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

6.0 ANALYSIS

6.1. PROTO-HX™ MODEL

Table 6-1 shows the PROTO-HX™ benchmarking of the Jacket Water Cooler for the HPCS Diesel Generator. The PROTO-HX™ reports can be found in Attachment C.

Table 6-1 Model Benchmark Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	482	482	0.00 %
Shell Side Outlet Temp, °F	174.5	175	-0.29 %
Tube Side Outlet Temp, °F	120.8	121	-0.17 %
Heat Transferred, BTU/hr	8,277,000	8,505,000	-2.68 %
Corrected LMTD	71.0	73	-2.74 %

Table 6-2 shows the PROTO-HX™ results for the heat exchanger design conditions using the corrected effective area, Section 3.2. The PROTO-HX™ reports can be found in Attachment C.

Table 6-2 Model Design Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	468.17	482	-2.87 %
Shell Side Outlet Temp, °F	174.8	175	0.11 %
Tube Side Outlet Temp, °F	120.4	121	-0.50 %
Heat Transferred, BTU/hr	8,089,000	8,505,000	-4.89 %
Corrected LMTD	71.5	73	-2.05 %

All PROTO-HX™ calculations performed with the HPCS Jacket Water Cooler model will use the effective area of 468.17 ft². This change is made to the PROTO-HX™ heat exchanger data sheet as shown in Attachment C.

6.2. HEAT EXCHANGER FOULING FACTOR LIMIT

In order for the jacket water cooler to meet the Reference Conditions (Table 3-1) the fouling must be limited from the values listed on the vendor's data sheet (Reference 8.6). The overall fouling factor limit was determined by iterating on the overall fouling factor, a PROTO-HX™ input, until the required heat load was matched. Table 6-3 shows the results of the PROTO-HX™ runs for the limited fouling factor case, see Attachment C.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 7 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

Table 6-3 Fouling Factor Limit

Parameter	Design Fouling	Limited Fouling
Tube-side Fouling Factor	0.002	0.001932
Shell-side Fouling Factor	0.0005	0.0005
Total Fouling Factor	0.002811	0.002732
Overall Heat Transfer Coefficient	234.7	239.2
Heat Transfer Rate	7,718,000	7,801,000
Required Heat Transfer Rate	7,800,000	7,800,000
Thermal Margin	-82,000	1,000
% Thermal Margin	-1.05 %	0.01 %

The limitations on the fouling factor are placed on the tube-side fouling factor, since the tube-side is the most controllable via periodic tube-side cleaning. The tube-side fouling factor is calculated from the overall fouling found from the PROTO-HX™ iteration process. The area ratio is used to convert the overall fouling factor to a tube-side and shell-side fouling factor

$$f_{total} = f_{shell} + (\text{Area Ratio}) \cdot f_{tube} \quad \text{Equation 4}$$

$$\text{Area Ratio} = \frac{\text{Tube OD}}{\text{Tube ID}} \quad \text{Equation 5}$$

$$\text{Area Ratio} = \frac{0.625 \text{ in}}{0.541 \text{ in}} = 1.15527$$

From the vendor datasheet the design overall fouling factor is calculated

$$f_{shell} = 0.0005 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}} \quad \text{and} \quad f_{tube} = 0.002 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}}$$

$$f_{total} = 0.0005 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}} + 1.15527 \cdot 0.002 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}} = 0.002811 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}}$$

From the PROTO - HX iteration the adjusted overall fouling factor is found :

$$f_{adjusted} = 0.002732 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 8 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

From the new overall fouling factor the new tube - side fouling factor is calculated :

$$f_{\text{tube}} = \frac{(f_{\text{adjusted}} - f_{\text{shell}})}{\text{Area Ratio}} = \frac{(0.002732 - 0.0005) \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}}{1.15527} = 0.001932 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$


The PROTO-HX™ heat exchanger data sheet is changed to reflect the adjusted design fouling as calculated above. Like the effective area change in the heat exchanger data sheet, this change is made without recalculating the Hoff factor.

Attachment C includes a final model calculation report for the Reference Conditions and the adjusted tube-side fouling entered into the PROTO-HX™ data sheet.

6.3. FOULING SENSITIVITY

The fouling sensitivity of the jacket water cooler is shown in Figure 6-1. The fouling sensitivity was developed at 650 gpm CSCS flow, 100°F CSCS inlet temperature, 1100 gpm jacket water flow, and 190°F jacket water inlet temperature. The tube-side fouling factor was varied from 0.0000 to 0.001932 (hr ft² °F/Btu) by increments of 0.0005 (hr ft² °F/Btu). The shell-side fouling factor is held constant at the design value of 0.0005 (hr ft² °F/Btu). The PROTO-HX™ Calculation Reports for the fouling sensitivity can be found in Attachment D

Figure 6-1 Tube-side Fouling Sensitivity



PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 9 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

6.4. THERMAL MARGIN ASSESSMENT

The clean thermal margin is assessed by a comparison of the reference condition performance requirement (Table 3-1) to the heat exchanger performance capability with a zero (0) fouling factor. Using a zero (0) fouling factor shows the maximum available performance of the heat exchanger. Likewise the service thermal margin is assessed by comparing the reference condition performance requirement (Table 3-1) to the heat exchanger performance capability with the design fouling factor.

The margin is calculated directly and as a percentage compared to the required heat rate to perform the component's safety function. The PROTO-HX™ reports can be found in Attachment C.

$$\text{margin} = \text{Heat Rate} - \text{Heat Rate}_{\text{required}} \quad \text{Equation 6}$$

$$\% \text{ margin} = 100 \cdot \left(\frac{\text{margin}}{\text{Heat Rate}_{\text{required}}} \right) \quad \text{Equation 7}$$

Table 6-4 Thermal Margin

Parameter	Service (Design Fouling)	Clean (0 Fouling)
Overall Heat Transfer Coefficient	239.2	713.2
Heat Transfer Rate	7,801,000	15,420,000
Required Heat Transfer Rate	7,800,000	7,800,000
Thermal Margin	1,000	7,620,000
% Thermal Margin	0.01 %	97.69 %

6.5. MINIMUM SERVICE WATER FLOW RATE

The minimum service water flow rate for the adjusted design fouling condition is calculated with the shell-side inlet temperature at 190°F and a flow rate of 1,100 gpm. Iterating using the service water flow rate and inlet temperature, the minimum acceptable flow rate is found for each inlet temperature (Attachment E). The heat load for each iteration must be equal to or slightly above the required heat load of 7,800,000 BTU/hr, the diesel heat load at 100% power (reference 8.1).


The results of the model iterations are summarized in Table 6-5 and Figure 6-2. Density corrections of the PROTO-HX™ flow rates are made in accordance with Equation 3. Values for fluid density are obtained from Reference 8.11.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 10 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

Table 6-5 Minimum Required CSCS Flow Rate

CSCS Inlet Temperature (°F)	Density at Inlet Temperature (lbm/ft ³)	PROTO-HX™ Input Flow Rate (gpm)	Density Corrected Flow Rate (gpm)
35	62.41903	202.4	202.2
40	62.42184	209.1	208.9
50	62.40595	227.4	227.2
60	62.36445	255.0	255.0
70	62.30034	298.7	299.0
80	62.21603	362.9	363.8
90	62.11349	464.2	466.1
100	61.99437	646.1	650.0

Figure 6-2 Minimum CSCS Flow at Adjusted Design Fouling



PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 11 OF 12
	ORIGINATOR D. Phye		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

7.0 CONCLUSION

7.1. PROTO-HX™ MODEL

The HPCS Jacket Water Cooler model was developed using PROTO-HX™, Version 3.02. The model was benchmarked to the vendor data sheet. The benchmark model correlation to the vendor data sheet heat rate is 2.68 %. The benchmark model is for reference only based on the non-conservative approximation of heat exchanger effective area as discussed in Section 3.2 and Assumption 5.1. Calculations performed with the HPCS Jacket Water Cooler model are to use the effective area developed in Section 3.2.

This model should be considered suitable for use in the analysis of thermal performance test data.

The model database is saved under file name dg01b.phx, with a file size of 864 KB, and a file date and time of 6/26/98 at 11:25:36 AM. The saved database is set up to run the Reference Conditions with design fouling factor selected, the design fouling factor is a shell-side fouling of 0.002782. The database file is included as Attachment F.

7.2. HEAT EXCHANGER FOULING FACTOR LIMIT

For the HPCS Diesel Generator Jacket Water Cooler to provide adequate heat removal at the specified LaSalle Station Reference Conditions the overall fouling factor must be equal to or less than 0.002732 hr ft² °F/Btu. This overall fouling factor is broken down into a 0.001932 and 0.0005 hr ft² °F/Btu for the tube-side and shell-side fouling factors respectively and entered in the model as the design fouling factors.

7.3. FOULING SENSITIVITY

Given a constant shell-side fouling at the model design value, the sensitivity of the jacket water cooler to tube-side fouling effects is shown on Figure 6-1.

7.4. THERMAL MARGIN ASSESSMENT

The clean and service available thermal margins are 97.69 % and 0.01 % respectively.

7.5. MINIMUM SERVICE WATER FLOW RATE

As shown in Figure 6-2 the service water flow can be throttled down to account for lower service water inlet temperature conditions. The heat exchanger can remove the design heat load for the diesel at 100% rated power, 7,800,000 BTU/hr, by reducing service water flow rates as the service water temperature decreases.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-197	REV A	PAGE 12 OF 12
	ORIGINATOR D. Phyfe		DATE 6/26/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station 1B(2B) Diesel Generator Jacket Water Coolers.			

8.0 REFERENCES

- 8.1. LaSalle Station UFSAR, Sections: 9.2.1 and 9.5.5.1.1 (Attachment B)
- 8.2. NRC Generic Letter 89-13
- 8.3. GE Purchase Specification - 211872RO-SW9 Item 4.3.6.1
- 8.4. LaSalle Station FSAR Q40.92 (Attachment B)
- 8.5. Stewart & Stevens Vendor Manual, VM J-152 through VM J-157
- 8.6. O & M Manufacturing Hx Data Sheet (Attachment A)
- 8.7. LaSalle Station Drawing, VPF - 3411-080(1)-1, J-2500 (Attachment A)
- 8.8. LaSalle Station Drawing, VPF - 3411-080(2)-1, J-2500 (Attachment A)
- 8.9. Standard of the Tubular Exchanger Manufacturers Association
- 8.10. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.02 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision F, dated 2/17/98
- 8.11. Proto-Power Calculation 93-048, "Fluid Properties – Fresh Water – Range 32°F to 500°F", Rev. A

**Attachment A to
Proto-Power Calculation
97-197
Revision A**

REFERENCE 8.6

O & H MANUFACTURING COMPANY
Houston, Texas

RECEIVED
OCT 11 1974
ENGINEERING DEPT.

EXCHANGER SPECIFICATION SHEET

CUSTOMER	Stewart & Stevenson Services	REFERENCE NO.	F-64546-50583
ADDRESS	HOUSTON, TEXAS	APPROVAL NO.	J. E. APED
PLANT LOCATION		DATE	APRIL 11, 1974
SERVICE OF UNIT	Jacket Water Cooler	ITEM NO.	
SIZE	25-1607-2511	O & H DRAWING NO.	8980
GROSS SURFACE PER UNIT	482	O & H JOB NO.	82615
REV. #	9/26/74: added fouling factor		

PERFORMANCE OF UNIT

	SHELL SIDE		TUBE SIDE	
FLUID CIRCULATED	JACKET WATER		RAW WATER	
TOTAL FLUID EMERGING				
VAPOR				
LIQUID	1,100 GPM		100 GPM	
STEAM				
NON-CONDENSABLES				
FLUID VAPORIZED OR CONDENSED				
STEAM CONDENSED				
GRAVITY				
VISCOSITY				
MOLECULAR WEIGHT				
SPECIFIC HEAT		BTU/LB/°F		BTU/LB/°F
LATENT HEAT - VAPORS		BTU/LB/°F		BTU/LB/°F
TEMPERATURE IN	120	°F	100	°F
TEMPERATURE OUT	125	°F	121	°F
OPERATING PRESSURE		PSI		PSI
NUMBER OF PASSES PER SHELL	1		2	
VELOCITY	5.6	FT/SEC	5.3	FT/SEC
PRESSURE DROP	4.5	PSI	3.7	PSI
FOULING RESISTANCE	.005		.002	
HEAT EXCHANGED	1,505,000 BTU/HR	U.C.S. (CORRECTED)	77	
TRANSFER AREA - SERVICE	482.7	EFF. SURFACE/UNIT	1.87	

← *
Eff. Area

CONSTRUCTION

DESIGN PRESSURE	150	PSI	150	PSI
TEST PRESSURE	225	PSI	225	PSI
DESIGN TEMPERATURE	120	°F	120	°F
TUBES	ASTM A213	1.315" O.D. x .049" WALL	1.315" O.D. x .049" WALL	1.315" O.D. x .049" WALL
SHELL	C.S.	18"	C.S.	18"
SHELL COVER			FLANGING HEAD COVER	
CHANNEL	C.S.		FLANGING HEAD COVER	
TUBE SHEETS	STAINLESS STEEL		FLANGING HEAD COVER	
BAFFLES	CROSS		FLANGING HEAD COVER	
BAFFLES	CROSS		FLANGING HEAD COVER	
TUBE SUPPORTS			FLANGING HEAD COVER	
CONNECTIONS	BRASS	4"	FLANGING HEAD COVER	
CONNECTIONS	BRASS	4"	FLANGING HEAD COVER	
CORROSION ALLOWANCE	SHALL BE		FLANGING HEAD COVER	
CODE REQUIREMENTS	ASME SECTION VIII DIVISION 1		FLANGING HEAD COVER	
WEIGHT	3650 LBS		FLANGING HEAD COVER	

NOTE: INDICATE AFTER EACH PART WHETHER STRESS RELIEVED (S.R.) OR (N.R.)
 REMARKS: 9/26/74: Copy to Mr. Bill Phillips, Mr. Bob Evans
 10/10/74: Original to Mr. W. C. Philipp

Form #103



FOR


BY

NOTE: THIS DRAWING/DATA NOT RELEASED FOR MANUFACTURE OR REVIEW UNLESS SIGNED OFF BELOW			
ACTIVITY	RELEASED BY	DATE	RELEASE NO.
ENGINEERING			Proto-Power Calc: 97-197
QUALITY CONTROL			Attachment: A
RELEASED TO:			Rev. A Page 2 of 4
NOTE: ON RECEIPT OF THIS DRAWING/DATA DESTROY ALL PREVIOUSLY ISSUED COPIES			

HPCS

VDF-3411-080 (1)-1

REV	DATE	DESCRIPTION	BY	CHKD
A		REVIEW THE BILL 3338	J.M.W.	
B		ADDED DIMENSIONS & WEIGHTS PER S & L COMMENTS. ECM-3348		




FLOATING ENP DETAIL

REV	DATE	DESCRIPTION	BY	CHKD

REFERENCE 8.7

Proto-Power Calc: 97-197
Attachment: A
Rev. A Page 3 of 4



-SIDE VIEW-

-ENP VIEW-

SERVICE	PERMISSIBLE TEMPERATURE	PERMISSIBLE PRESSURE
150	180	180

NOTE:
 1 ASME CODE STAMP SECT VIII
 2 UNIT COMPLIANT TO TEMA 'C'
 3 WEIGHTS:
 DRW - 2800#
 NET - 1650#

ITEM NO.	QUANTITY	DESCRIPTION	UNIT
		STEWART & STEVENSON SERVICES	
		P.O. BOX 1437 HOUSTON, TEXAS, U.S.A.	
		(WAS O.C.M. OVER SEED)	
		(K.A.) EXCHANGE B	
		MODEL RB-1007-2321	
		D 01301	21498

**Attachment B to
Proto-Power Calculation
97-197
Revision A**

REFERENCE 8.1

LSCS-UFSAR

9.2 WATER SYSTEMS

The auxiliary water systems for the LaSalle County Station are as follows:

- a. CSCS equipment cooling water system,
- b. station service water system,
- c. reactor building closed cooling water system,
- d. demineralized water makeup system,
- e. potable and sanitary water system,
- f. ultimate heat sink,
- g. cycled condensate system and refueling water storage facilities,
- h. turbine building closed cooling water system (TBCCWS),
- i. primary containment chilled water system,
- j. station heat recovery system,
- k. suppression pool cleanup system, and
- l. chemical feed system.

9.2.1 CSCS Equipment Cooling Water System

The function of the core standby cooling system-equipment cooling water system (CSCS-ECWS) is to circulate lake water from the ultimate heat sink for cooling of the residual heat removal (RHR) heat exchangers, diesel-generator coolers, CSCS cubicle area cooling coils, RHR pump seal coolers, and low-pressure core spray (LPCS) pump motor cooling coils. This system also provides a source of emergency makeup water for fuel pool cooling and also provides containment flooding water for post-accident recovery. This CSCS-ECWS system is equivalent in purpose to the essential service water cooling systems at other stations.

9.2.1.1 Design Bases

9.2.1.1.1 Safety Design Bases

- a. The system is sized based on the following minimum equipment cooling water flow requirements:
 1. RHR heat exchanger - 7400 gpm
 2. diesel-generator cooler (division 1 and 2 only) - 800 gpm
 3. diesel-generator cooler (division 3) - 650 gpm

Proto-Power Calc: 97-197

Attachment: B

Rev: A Page 2 of 5

REFERENCE 8.1

LSCS-UFSAR

9.5.4.5 Instrumentation and Controls

Fuel levels in each day tank and storage tank are indicated locally, and storage tank levels are also indicated at each storage tank filling station. Control room alarms annunciate high or low levels in each day tank and low level in each storage tank. All day tank level instruments and diesel-generator transfer pump controls are Seismic Category I and Class 1E. A local pressure indicator is connected to the discharge of each transfer pump to monitor pump discharge head. A local differential pressure indicator is connected across the transfer pump suction strainer to identify a clogged strainer.

Each diesel engine gauge panel includes local gauges for monitoring the following diesel-generator skid-mounted system fuel oil parameters: fuel oil temperature, fuel pump suction strainer inlet and outlet pressure (Divisions 1 and 2 diesel generators only), fuel pump discharge pressure, fuel filter inlet pressure, and fuel filter outlet pressures (for the Division 3 diesel generators, filter inlet and outlet pressure gauges are mounted on the engine and not on the gauge panel). In addition, pressure switches are installed in the skid-mounted systems to annunciate high fuel filter differential pressure for the Divisions 1 and 2 diesel generators and low fuel pump discharge pressure for the Division 3 diesel generators. The entire skid-mounted fuel oil system, including instrumentation, is supplied by the engine manufacturer as a part of the diesel engine.

Each diesel-generator fuel transfer pump is started and stopped automatically by day tank level control switches. The diesel fire pump fuel transfer pump is started manually; however, it is automatically shut down by day tank high level. Elapsed time instrumentation monitors diesel-generator transfer pump running time and, when the diesel engine is operating, pump shutdown time. This instrumentation actuates control room alarm lights if pump running time is excessive or shutdown time is too short to permit remote detection of possible fuel oil leaks at the day tank or diesel generator.

9.5.5 Diesel-Generator Cooling Water System

The function of the diesel-generator cooling water system is to transfer the heat rejected from the engine water jacket, the lube oil cooler and the engine air aftercooler to the CSCS equipment cooling water system (CSCS-ECWS).

9.5.5.1 Design Bases

9.5.5.1.1 Safety Design Bases

Cooling capacity of this system is based on a diesel-generator output of 2860 kW with an environmental temperature of 122° F maximum and a minimum and maximum lake water temperature of 32° F and 100° F, respectively. Total heat transfer by this system is

REFERENCE 8.1

LSCS-UFSAR

approximately 7.8×10^6 Btu/hr per diesel-generator set at rated engine capacity. The diesel cooling water heat exchangers are sized based on operation of 110% of rated load.

High water temperature is alarmed at 200° F and the engine is automatically shut down if the cooling water temperature at the engine outlet exceeds 208° F in order to prevent engine damage due to overheating. This shutdown control is in effect only when the engine is started manually and bypassed when the diesel generator is started automatically during an emergency.

Heaters are installed in the cooling water piping below the lube oil cooler to maintain the engine water and lube oil in a warm standby condition while the engine is not operating; thus increasing the starting reliability of the diesel generator. Natural convection is employed to circulate the warm engine water through the lube oil cooler during standby.

Each system is designed based on Seismic Category I requirements and is protected from tornadoes, missiles, and flooding.

9.5.5.1.2 Power Generation Design Bases

The diesel-generator cooling water system is not required during power generation. Consequently, it possesses no power generation design bases.

9.5.5.2 System Description

Each diesel-generator cooling water system is a separate, independent closed loop system supplied with the diesel generator and located entirely on the diesel-generator skid. It consists of two parallel engine driven centrifugal circulating pumps, a low-pressure expansion tank, an AMOT temperature regulating valve, a lube oil cooler, and the engine cooling water heat exchanger. The expansion tank is fitted with a 7 psig relief cap which also will relieve vacuum. Engine coolant is demineralized water treated with chromate, borate-nitrite, or silicate-nitrite type corrosion inhibitors in accordance with the engine manufacturer's recommendations.

During operation, cooling water at a flow of 1100 gpm per diesel-generator set is circulated by the engine driven pumps through the diesel engine cooling water passages to the lube oil cooler, through the temperature regulating valve, and then to the engine cooling water heat exchanger. See Figure 9.5-5 for additional details.

The engine cooling water heat exchanger is a two-pass shell and tube type heat exchanger having admiralty tubes with a carbon steel water box and shell. Engine cooling water is circulated through the shell side while strained lake water is pumped through the tube side by the CSCS-ECWS (Subsection 9.2.1). Design pressure and temperature is 150 psig and 300° F for both

REFERENCE 8.4

LSCS-FSAR

AMENDMENT 29
JANUARY 1978

QUESTION 040.92

"In response to Question 040.16 you have provided in section 9.5.5.1.1 a total diesel generator cooling water heat rate of approximately 6.15 million Btu/hr. This heat is rejected in the heat exchanger interfacing with CSCS equipment cooling water system when the diesel generator is operating at rated capacity. Also, in section 9.5.5.2 you mention that the cooling waterflow rate in the diesel engine is 1,100 gpm. It is not clear whether these heat and flow rates are for the total five diesel generators or for a single diesel generator. Please provide the heat and flow rates for each of the five diesel generators. In addition, also provide the design temperature differential($^{\circ}$ F) for each diesel engine cooling water when operating at rated capacity."

RESPONSE

→ The design conditions for each diesel-generator cooling water system are:

→ Shell side flow	1100 gpm
→ Design shell side inlet temperature	190 $^{\circ}$ F
Shell side outlet temperature	175 $^{\circ}$ F
Tube side design flow	800 gpm
Tube side inlet temperature	100 $^{\circ}$ F
Tube side outlet temperature	122 $^{\circ}$ F
Heat exchanger design heat removal	8.6 x 10 ⁶ btu/hr
Diesel-generator set cooling requirement	7.8 x 10 ⁶ btu/hr

(The value of 6.15 x 10⁶ btu/hr heat removal specified in Subsection 9.5.5.1.1 has been corrected to read 7.8 x 10⁶ btu/hr in accordance with the above data).

**Attachment C to
Proto-Power Calculation
97-197
Revision A**

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,064.46	795.25
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00200
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr-ft ² -°F)		241.70
Emprical Factor for Outside h		0.633693000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		482.00
Area Factor		1.001961568
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr-ft-°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

VENDOR DATA SHEET VALUES

PROTO-HX CALCULATED @ BENCHMARK CONDITIONS

VENDOR DATA SHEET VALUE

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 Vendor Data - BENCHMARK

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.277E+6
 LMTD 71.8
 Effective Area (ft²) 482.0

COMPARE TO VENDOR DATA SHEET → 8.277E+6

Overall Fouling (hr-ft²-°F/BTU) 0.002811
 Shell-Side ho (BTU/hr-ft²-°F) 1,889.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,576.5
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9895

U Overall (BTU/hr-ft²-°F) 241.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	5.33
Reynold's Number	7.707E+04	3.620E+04
Prandtl Number	2.13	4.03
Bulk Visc (lbm/ft-hr)	0.82	1.48
Skin Visc (lbm/ft-hr)	0.88	1.31
Density (lbm/ft³)	60.53	61.85
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.5
 Tav Shell (°F) 182.2
 Shell Skin Temp (°F) 173.1
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 120.8
 Tav Tube (°F) 110.4
 Tube Skin Temp (°F) 123.1

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

Design Conditions - Adjusted Eff. Area

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,064.46	795.25
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00200
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		241.70
Empirical Factor for Outside h		0.633693000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		468.17
Area Factor		0.973212339
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr·ft·°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

CALCULATED
IN SECTION 3.2

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 Design Conditions - Adjusted Eff. Area

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 795.3
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.978E+5
 Heat Transferred (BTU/hr) 8.089E+6
 LMTD 72.2
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002811
 Shell-Side ho (BTU/hr-ft²-°F) 1,890.3
 Tube-Side hi (BTU/hr-ft²-°F) 1,574.7
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9901

U Overall (BTU/hr-ft²-°F) 241.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	5.33
Reynold's Number	7.717E+04	3.612E+04
Prandtl Number	2.13	4.04
Bulk Visc (lbm/ft-hr)	0.82	1.48
Skin Visc (lbm/ft-hr)	0.87	1.31
Density (lbm/ft³)	60.52	61.86
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 174.8
 Tav Shell (°F) 182.4
 Shell Skin Temp (°F) 173.2
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 120.4
 Tav Tube (°F) 110.2
 Tube Skin Temp (°F) 123.0

** Reynolds Number Outside Range of Equation Applicability
 * With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

LSCS Reference Cond. Vendor Fouling

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,100.00	800.00
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00200
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		241.70
Empirical Factor for Outside h		0.616913000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		468.17
Area Factor		0.973212339
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr·ft·°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 LSCS Reference Cond. Vendor Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data	Extrapolation Data
Data Date	Tube Flow (gpm) 650.0
Shell Flow (gpm)	Shell Flow (gpm) 1,100.0
Shell Temp In (°F)	Tube Inlet Temp (°F) 100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 190.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor

Property	Shell-Side	Tube-Side	Overall Fouling (hr-ft ² -°F/BTU)
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.503E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002811
Tube Mass Flow (lbm/hr)	3.252E+5	Shell-Side ho (BTU/hr-ft ² -°F)	1,880.7
Heat Transferred (BTU/hr)	7.718E+6	Tube-Side hi (BTU/hr-ft ² -°F)	1,354.4
LMTD	71.0	1/Wall Resis (BTU/hr-ft ² -°F)	15,431.0
Effective Area (ft ²)	468.2	LMTD Correction Factor	0.9890

LOWER THAN
LSCS REF.
CONDITION
REQUIRED.

Property	Shell-Side	Tube-Side	U Overall (BTU/hr-ft ² -°F)
Velocity (ft/s)	5.77	4.36	Shell Temp In (°F) 190.0
Reynold's Number	8.005E+04	3.003E+04	Shell Temp Out (°F) 176.0
Prandtl Number	2.12	3.96	Tav Shell (°F) 183.0
Bulk Visc (lbm/ft-hr)	0.82	1.46	Shell Skin Temp (°F) 174.1
Skin Visc (lbm/ft-hr)	0.87	1.27	Tube Temp In (°F) 100.0
Density (lbm/ft ³)	60.51	61.83	Tube Temp Out (°F) 123.8
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 111.9
K (BTU/hr-ft-°F)	0.39	0.37	Tube Skin Temp (°F) 126.1

Proto-Power Calc: 97-197
 Attachment: C

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

Reduced FF to meet LSCS Ref. Cond.

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor		0.00050	0.00200
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			241.70
Empirical Factor for Outside h			0.633693000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			420
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall Conductivity (BTU/hr·ft·°F)			58.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

VENDOR VALUES
NOT USED IN
FOLLOWING
CALCULATION

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 Reduced FF to meet LSCS Ref. Cond.

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

FOULING FACTOR REDUCED
 UNTIL REFERENCE HEAT RATE WAS REACHED.

Test Data

Data Date	
Shell Flow (gpm)	
Shell Temp In (°F)	
Shell Temp Out (°F)	
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Extrapolation Data

Tube Flow (gpm)	646.1
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	190.0
Input Fouling Factor	0.002732

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5
Tube Mass Flow (lbm/hr)	3.232E+5
Heat Transferred (BTU/hr)	7.801E+6
LMTD	70.5
Effective Area (ft²)	468.2

MEETS
 REFERENCE
 HEAT RATE

Overall Fouling (hr-ft²-°F/BTU)	0.002732
Shell-Side ho (BTU/hr-ft²-°F)	1,892.1
Tube-Side hi (BTU/hr-ft²-°F)	1,349.8
1/Wall Resis (BTU/hr-ft²-°F)	15,431.0
LMTD Correction Factor	0.9881
U Overall (BTU/hr-ft²-°F)	239.2

ADJUSTED
 OVERALL
 FOULING
 FACTOR

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.33
Reynold's Number	7.731E+04	2.991E+04
Prandtl Number	2.13	3.95
Bulk Visc (lbm/ft-hr)	0.82	1.45
Skin Visc (lbm/ft-hr)	0.87	1.27
Density (lbm/ft³)	60.52	61.83
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	190.0
Shell Temp Out (°F)	175.4
Tav Shell (°F)	182.7
Shell Skin Temp (°F)	173.8
Tube Temp In (°F)	100.0
Tube Temp Out (°F)	124.2
Tav Tube (°F)	112.1
Tube Skin Temp (°F)	126.5

Proto-Power Calc: 97-197

Attachment: C

Rev: A Page 9 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieve

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

LSCS Ref. Condition - FINAL MODEL

Shell and Tube Heat Exchanger Input Parameters

		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor		0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			241.70
Empirical Factor for Outside h			0.633693000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			420
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall Conductivity (BTU/hr·ft·°F)			58.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

REDUCED
TUBE-SIDE
FOULING
SECTION 6.2

ADJUSTED
AREA
SECTION 3.2

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 LSCS Ref. Condition - FINAL MODEL

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

DESIGN FOULING FACTOR
 INCLUDES REDUCED TUBE-SIDE FOULING.

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 646.1
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.232E+5
 Heat Transferred (BTU/hr) 7.801E+6
 LMTD 70.5
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002732
 Shell-Side ho (BTU/hr-ft²-°F) 1,892.1
 Tube-Side hi (BTU/hr-ft²-°F) 1,349.8
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9881
 U Overall (BTU/hr-ft²-°F) 239.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.33
Reynold's Number	7.731E+04	2.991E+04
Prandtl Number	2.13	3.95
Bulk Visc (lbm/ft-hr)	0.82	1.45
Skin Visc (lbm/ft-hr)	0.87	1.27
Density (lbm/ft³)	60.52	61.83
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.8
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 124.2
 Tav Tube (°F) 112.1
 Tube Skin Temp (°F) 126.5

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Proto-Power Calc: 97-197

Attachment: C

Rev: A Page 11 of 13

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CLEAN - FINAL MODEL

Shell and Tube Heat Exchanger Input Parameters			
		Shell-Side	Tube-Side
Fluid Quantity, Total	gpm	1,064.46	795.25
Inlet Temperature	°F	190.00	100.00
Outlet Temperature	°F	175.00	121.00
Fouling Factor		0.00050	0.00193
Shell Fluid Name			Fresh Water
Tube Fluid Name			Fresh Water
Design Heat Transfer (BTU/hr)			8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)			241.70
Empirical Factor for Outside h			0.633693000
Performance Factor (% Reduction)			0.00
Heat Exchanger Type			TEMA-E
Effective Area (ft ²)			468.17
Area Factor			0.973212339
Area Ratio			
Number of Shells per Unit			1
Shell Minimum Area			0.438000000
Shell Velocity (ft/s)			5.600
Tube Pitch (in)			0.7500
Tube Pitch Type			Triangular
Number of Tube Passes			2
U-Tubes			No
Total Number of Tubes			420
Number of Active Tubes			420
Tube Length (ft)			7.00
Tube Inside Diameter (in)			0.541
Tube Outside Diameter (in)			0.625
Tube Wall Conductivity (BTU/hr·ft·°F)			58.00
Ds, Shell Inside Diameter (in)			0.000
Lbc, Central Baffle Spacing (in)			0.000
Lbi, Inlet Baffle Spacing (in)			19.688
Lbo, Outlet Baffle Spacing (in)			19.688
Dotl, Tube circle diameter (in)			0.000
Bh, Baffle cut height (in)			0.000
Lsb, Diametral difference between Baffle and Shell (in)			0.000
Ltb, Diametral difference between Tube and Baffle (in)			0.000
Nss, Number Sealing Strips			0.000

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CLEAN - FINAL MODEL

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Ø FOULING FOR "CLEAN"
 Hx ANALYSIS - MAXIMUM HEAT RATE

Test Data

Extrapolation Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Tube Flow (gpm) 646.1
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0

Input Fouling Factor 0.000000

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

MAXIMUM HEAT RATE
 1.542E+7

5.325E+5
 3.232E+5
 51.1
 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.000000
 Shell-Side ho (BTU/hr-ft²-°F) 1,839.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,455.3
 1/Wall Resis (BTU/hr-ft²-°F) "CLEAN" 15,431.0
 LMTD Correction Factor 0.9039

U Overall (BTU/hr-ft²-°F) 713.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.57	4.34
Reynold's Number	7.363E+04	3.347E+04
Prandtl Number	2.24	3.49
Bulk Visc (lbm/ft-hr)	0.86	1.30
Skin Visc (lbm/ft-hr)	1.00	1.01
Density (lbm/ft³)	60.67	61.65
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 161.1
 Tav Shell (°F) 175.5
 Shell Skin Temp (°F) 155.5
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 147.8
 Tav Tube (°F) 123.9
 Tube Skin Temp (°F) 153.1

Proto-Power Calc: 97-197

Attachment: C

Rev: A Page 13 of 13

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment D to
Proto-Power Calculation
97-197
Revision A**

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

LSCS Ref. Condition - FINAL MODEL

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,064.46	795.25
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00193
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		241.70
Empirical Factor for Outside h		0.633693000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		468.17
Area Factor		0.973212339
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr·ft·°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
LSb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

Tube--side Fouling = 0.0000

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 646.1
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 100.0
 Shell Inlet Temp (°F) 190.0
 Input Fouling Factor 0.000500

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.232E+5
 Heat Transferred (BTU/hr) 1.316E+7
 LMTD 56.9
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.000500
 Shell-Side ho (BTU/hr-ft²-°F) 1,856.7
 Tube-Side hi (BTU/hr-ft²-°F) 1,423.4
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9458

U Overall (BTU/hr-ft²-°F) 522.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.57	4.34
Reynold's Number	7.471E+04	3.240E+04
Prandtl Number	2.20	3.62
Bulk Visc (lbm/ft-hr)	0.85	1.34
Skin Visc (lbm/ft-hr)	0.95	1.09
Density (lbm/ft³)	60.63	61.71
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 165.3
 Tav Shell (°F) 177.7
 Shell Skin Temp (°F) 161.6
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 140.8
 Tav Tube (°F) 120.4
 Tube Skin Temp (°F) 144.7

Proto-Power Calc: 97-197

Attachment: D

Rev: A Page 3 of 7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 Tube--side Fouling = 0.0005

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	646.1
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	190.0
Input Fouling Factor	0.001078

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.232E+5
 Heat Transferred (BTU/hr) 1.12E+7
 LMTD 61.9
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.001078
 Shell-Side ho (BTU/hr-ft²-°F) 1,870.2
 Tube-Side hi (BTU/hr-ft²-°F) 1,396.4
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9675
 U Overall (BTU/hr-ft²-°F) 399.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.57	4.34
Reynold's Number	7.566E+04	3.148E+04
Prandtl Number	2.18	3.74
Bulk Visc (lbm/ft-hr)	0.84	1.38
Skin Visc (lbm/ft-hr)	0.92	1.15
Density (lbm/ft³)	60.59	61.75
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 169.0
 Tav Shell (°F) 179.5
 Shell Skin Temp (°F) 166.2
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 134.7
 Tav Tube (°F) 117.3
 Tube Skin Temp (°F) 137.9

Proto-Power Calc: 97-197

Attachment: D

Rev: A Page 4 of 7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 Tube--side Fouling = 0.0010

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	646.1
Shell Flow (gpm)	1,064.5
Shell Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	190.0
Input Fouling Factor	0.001655

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr·ft²·°F)
 Shell-Side ho (BTU/hr·ft²·°F)
 Tube-Side hi (BTU/hr·ft²·°F)
 1/Wall Resis (BTU/hr·ft²·°F)
 LMTD Correction Factor

Overall Fouling (hr·ft²·°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft·hr)		
Skin Visc (lbm/ft·hr)		
Density (lbm/ft³)		
Cp (BTU/lbm·°F)		
K (BTU/hr·ft·°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 3.232E+5
 Heat Transferred (BTU/hr) 9.727E+6
 LMTD 65.6
 Effective Area (ft²) 468.2

Overall Fouling (hr·ft²·°F/BTU) 0.001655
 Shell-Side ho (BTU/hr·ft²·°F) 1,879.8
 Tube-Side hi (BTU/hr·ft²·°F) 1,376.2
 1/Wall Resis (BTU/hr·ft²·°F) 15,431.0
 LMTD Correction Factor 0.9784

U Overall (BTU/hr·ft²·°F) 323.5

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.34
Reynold's Number	7.637E+04	3.080E+04
Prandtl Number	2.15	3.83
Bulk Visc (lbm/ft·hr)	0.83	1.41
Skin Visc (lbm/ft·hr)	0.90	1.20
Density (lbm/ft³)	60.56	61.79
Cp (BTU/lbm·°F)	1.00	1.00
K (BTU/hr·ft·°F)	0.39	0.37

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 171.8
 Tav Shell (°F) 180.9
 Shell Skin Temp (°F) 169.6
 Tube Temp In (°F) 100.0
 Tube Temp Out (°F) 130.1
 Tav Tube (°F) 115.1
 Tube Skin Temp (°F) 132.9

Proto-Power Calc: 97-197

Attachment: D

Rev: A Page 5 of 7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

Tube--side Fouling = 0.0015

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	646.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.002233

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr·ft ² ·°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr·ft ² ·°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr·ft ² ·°F)		
LMTD	1/Wall Resis (BTU/hr·ft ² ·°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr·ft ² ·°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft·hr)			Tube Temp In (°F)
Skin Visc (lbm/ft·hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm·°F)			Tube Skin Temp (°F)
K (BTU/hr·ft·°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr·ft ² ·°F/BTU)	0.002233
Tube Mass Flow (lbm/hr)	3.232E+5	Shell-Side ho (BTU/hr·ft ² ·°F)	1,887.1
Heat Transferred (BTU/hr)	8.59E+6	Tube-Side hi (BTU/hr·ft ² ·°F)	1,360.6
LMTD	68.5	1/Wall Resis (BTU/hr·ft ² ·°F)	15,431.0
Effective Area (ft ²)	468.2	LMTD Correction Factor	0.9847
		U Overall (BTU/hr·ft ² ·°F)	272.0
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	5.58	4.33	Shell Temp Out (°F)
Reynold's Number	7.692E+04	3.027E+04	Tav Shell (°F)
Prandtl Number	2.14	3.90	Shell Skin Temp (°F)
Bulk Visc (lbm/ft·hr)	0.82	1.44	Tube Temp In (°F)
Skin Visc (lbm/ft·hr)	0.88	1.24	Tube Temp Out (°F)
Density (lbm/ft ³)	60.53	61.81	Tav Tube (°F)
Cp (BTU/lbm·°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr·ft·°F)	0.39	0.37	

Proto-Power Calc: 97-197

Attachment: D

Rev: A Page 6 of 7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

Tube--side Fouling = 0.001932 (LIMIT)

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	646.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F)	100.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)	Input Fouling Factor	0.002732

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)			Tube Temp In (°F)
Skin Visc (lbm/ft-hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm-°F)			Tube Skin Temp (°F)
K (BTU/hr-ft-°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002732
Tube Mass Flow (lbm/hr)	3.232E+5	Shell-Side ho (BTU/hr-ft ² -°F)	1,892.1
Heat Transferred (BTU/hr)	7.801E+6	Tube-Side hi (BTU/hr-ft ² -°F)	1,349.8
LMTD	70.5	1/Wall Resis (BTU/hr-ft ² -°F)	15,431.0
Effective Area (ft ²)	468.2	LMTD Correction Factor	0.9881
		U Overall (BTU/hr-ft ² -°F)	239.2
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	5.58	4.33	Shell Temp Out (°F)
Reynold's Number	7.731E+04	2.991E+04	Tav Shell (°F)
Prandtl Number	2.13	3.95	Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)	0.82	1.45	Tube Temp In (°F)
Skin Visc (lbm/ft-hr)	0.87	1.27	Tube Temp Out (°F)
Density (lbm/ft ³)	60.52	61.83	Tav Tube (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr-ft-°F)	0.39	0.37	

Proto-Power Calc: 97-197

Attachment: D

Rev: A Page 7 of 7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

**Attachment E to
Proto-Power Calculation
97-197
Revision A**

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

LSCS Ref. Condition - FINAL MODEL

Shell and Tube Heat Exchanger Input Parameters

	Shell-Side	Tube-Side
Fluid Quantity, Total	gpm 1,064.46	795.25
Inlet Temperature	°F 190.00	100.00
Outlet Temperature	°F 175.00	121.00
Fouling Factor	0.00050	0.00193
Shell Fluid Name		Fresh Water
Tube Fluid Name		Fresh Water
Design Heat Transfer (BTU/hr)		8,505,000
Design Heat Trans Coeff (BTU/hr·ft ² ·°F)		241.70
Emprical Factor for Outside h		0.633693000
Performance Factor (% Reduction)		0.00
Heat Exchanger Type		TEMA-E
Effective Area (ft ²)		468.17
Area Factor		0.973212339
Area Ratio		
Number of Shells per Unit		1
Shell Minimum Area		0.438000000
Shell Velocity (ft/s)		5.600
Tube Pitch (in)		0.7500
Tube Pitch Type		Triangular
Number of Tube Passes		2
U-Tubes		No
Total Number of Tubes		420
Number of Active Tubes		420
Tube Length (ft)		7.00
Tube Inside Diameter (in)		0.541
Tube Outside Diameter (in)		0.625
Tube Wall Conductivity (BTU/hr·ft·°F)		58.00
Ds, Shell Inside Diameter (in)		0.000
Lbc, Central Baffle Spacing (in)		0.000
Lbi, Inlet Baffle Spacing (in)		19.688
Lbo, Outlet Baffle Spacing (in)		19.688
Dotl, Tube circle diameter (in)		0.000
Bh, Baffle cut height (in)		0.000
Lsb, Diametral difference between Baffle and Shell (in)		0.000
Ltb, Diametral difference between Tube and Baffle (in)		0.000
Nss, Number Sealing Strips		0.000

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS=35°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 202.4
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 35.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.012E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 106.1
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002732
 Shell-Side ho (BTU/hr-ft²-°F) 1,891.5
 Tube-Side hi (BTU/hr-ft²-°F) 393.5
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9829

U Overall (BTU/hr-ft²-°F) 159.7

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	1.35
Reynold's Number	7.731E+04	6.041E+03
Prandtl Number	2.13	6.41
Bulk Visc (lbm/ft-hr)	0.82	2.25
Skin Visc (lbm/ft-hr)	0.87	1.29
Density (lbm/ft³)	60.52	62.27
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.35

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.5
 Tube Temp In (°F) 35.0
 Tube Temp Out (°F) 112.0
 Tav Tube (°F) 73.5
 Tube Skin Temp (°F) 124.7

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 3 of 10

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CSCS=40°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date	Tube Flow (gpm)	209.1
Shell Flow (gpm)	Shell Flow (gpm)	1,064.5
Shell Temp In (°F)	Shell Inlet Temp (°F)	40.0
Shell Temp Out (°F)	Shell Inlet Temp (°F)	190.0
Tube Flow (gpm)		
Tube Temp In (°F)		
Tube Temp Out (°F)		

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)		
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)		
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)		
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)		
Effective Area (ft ²)	LMTD Correction Factor		
	Overall Fouling (hr-ft ² -°F/BTU)		
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)			Shell Temp Out (°F)
Reynold's Number			Tav Shell (°F)
Prandtl Number			Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)			Tube Temp In (°F)
Skin Visc (lbm/ft-hr)			Tube Temp Out (°F)
Density (lbm/ft ³)			Tav Tube (°F)
Cp (BTU/lbm-°F)			Tube Skin Temp (°F)
K (BTU/hr-ft-°F)			

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002732
Tube Mass Flow (lbm/hr)	1.046E+5	Shell-Side ho (BTU/hr-ft ² -°F)	1,891.5
Heat Transferred (BTU/hr)	7.8E+6	Tube-Side hi (BTU/hr-ft ² -°F)	425.1
LMTD	102.5	1/Wall Resis (BTU/hr-ft ² -°F)	15,431.0
Effective Area (ft ²)	468.2	LMTD Correction Factor	0.9822
		U Overall (BTU/hr-ft ² -°F)	165.5
Property	Shell-Side	Tube-Side	Shell Temp In (°F)
Velocity (ft/s)	5.58	1.39	Shell Temp Out (°F)
Reynold's Number	7.731E+04	6.552E+03	Tav Shell (°F)
Prandtl Number	2.13	6.08	Shell Skin Temp (°F)
Bulk Visc (lbm/ft-hr)	0.82	2.15	Tube Temp In (°F)
Skin Visc (lbm/ft-hr)	0.87	1.29	Tube Temp Out (°F)
Density (lbm/ft ³)	60.52	62.24	Tav Tube (°F)
Cp (BTU/lbm-°F)	1.00	1.00	Tube Skin Temp (°F)
K (BTU/hr-ft-°F)	0.39	0.35	

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CSCS=50°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Tube Flow (gpm)	227.4
Shell Flow (gpm)	1,064.5
Shell Inlet Temp (°F)	50.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.138E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 95.9
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002732
 Shell-Side ho (BTU/hr-ft²-°F) 1,891.5
 Tube-Side hi (BTU/hr-ft²-°F) 497.6
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9813
 U Overall (BTU/hr-ft²-°F) 177.1

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	1.52
Reynold's Number	7.731E+04	7.772E+03
Prandtl Number	2.13	5.52
Bulk Visc (lbm/ft-hr)	0.82	1.97
Skin Visc (lbm/ft-hr)	0.87	1.29
Density (lbm/ft³)	60.52	62.17
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.5
 Tube Temp In (°F) 50.0
 Tube Temp Out (°F) 118.6
 Tav Tube (°F) 84.3
 Tube Skin Temp (°F) 124.8

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS=60°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data	Extrapolation Data
-----------	--------------------

Data Date	Tube Flow (gpm) 255.0
Shell Flow (gpm)	Shell Flow (gpm) 1,064.5
Shell Temp In (°F)	Tube Inlet Temp (°F) 60.0
Shell Temp Out (°F)	Shell Inlet Temp (°F) 190.0
Tube Flow (gpm)	
Tube Temp In (°F)	
Tube Temp Out (°F)	

Fouling Calculation Results

Shell Mass Flow (lbm/hr)	U Overall (BTU/hr-ft ² -°F)
Tube Mass Flow (lbm/hr)	Shell-Side ho (BTU/hr-ft ² -°F)
Heat Transferred (BTU/hr)	Tube-Side hi (BTU/hr-ft ² -°F)
LMTD	1/Wall Resis (BTU/hr-ft ² -°F)
Effective Area (ft ²)	LMTD Correction Factor
	Overall Fouling (hr-ft ² -°F/BTU)

Property	Shell-Side	Tube-Side	
Velocity (ft/s)			Shell Temp In (°F)
Reynold's Number			Shell Temp Out (°F)
Prandtl Number			Tav Shell (°F)
Bulk Visc (lbm/ft-hr)			Shell Skin Temp (°F)
Skin Visc (lbm/ft-hr)			Tube Temp In (°F)
Density (lbm/ft ³)			Tube Temp Out (°F)
Cp (BTU/lbm-°F)			Tav Tube (°F)
K (BTU/hr-ft-°F)			Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5	Overall Fouling (hr-ft ² -°F/BTU)	0.002732
Tube Mass Flow (lbm/hr)	1.276E+5	Shell-Side ho (BTU/hr-ft ² -°F)	1,891.6
Heat Transferred (BTU/hr)	7.8E+6	Tube-Side hi (BTU/hr-ft ² -°F)	583.3
LMTD	90.1	1/Wall Resis (BTU/hr-ft ² -°F)	15,431.0
Effective Area (ft ²)	468.2	LMTD Correction Factor	0.9812
		U Overall (BTU/hr-ft ² -°F)	188.5

Property	Shell-Side	Tube-Side	
Velocity (ft/s)	5.58	1.70	Shell Temp In (°F) 190.0
Reynold's Number	7.731E+04	9.385E+03	Shell Temp Out (°F) 175.4
Prandtl Number	2.13	5.09	Tav Shell (°F) 182.7
Bulk Visc (lbm/ft-hr)	0.82	1.83	Shell Skin Temp (°F) 173.5
Skin Visc (lbm/ft-hr)	0.87	1.29	Tube Temp In (°F) 60.0
Density (lbm/ft ³)	60.52	62.11	Tube Temp Out (°F) 121.2
Cp (BTU/lbm-°F)	1.00	1.00	Tav Tube (°F) 90.6
K (BTU/hr-ft-°F)	0.39	0.36	Tube Skin Temp (°F) 125.0

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 6 of 10

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CSCS=70°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 298.7
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 70.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.494E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 85.2
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002732
 Shell-Side ho (BTU/hr-ft²-°F) 1,891.7
 Tube-Side hi (BTU/hr-ft²-°F) 680.9
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9821

U Overall (BTU/hr-ft²-°F) 199.1

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	2.00
Reynold's Number	7.731E+04	1.170E+04
Prandtl Number	2.13	4.75
Bulk Visc (lbm/ft-hr)	0.82	1.72
Skin Visc (lbm/ft-hr)	0.87	1.28
Density (lbm/ft³)	60.52	62.04
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.6
 Tube Temp In (°F) 70.0
 Tube Temp Out (°F) 122.2
 Tav Tube (°F) 96.1
 Tube Skin Temp (°F) 125.4

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 7 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison

Calculation Report for DG01B - LSCS - HPCS DG Hx.

CSCS=80°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Shell Flow (gpm)
 Shell Temp In (°F)
 Shell Temp Out (°F)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm) 362.9
 Shell Flow (gpm) 1,064.5
 Tube Inlet Temp (°F) 80.0
 Shell Inlet Temp (°F) 190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr) 5.325E+5
 Tube Mass Flow (lbm/hr) 1.815E+5
 Heat Transferred (BTU/hr) 7.8E+6
 LMTD 80.4
 Effective Area (ft²) 468.2

Overall Fouling (hr-ft²-°F/BTU) 0.002732
 Shell-Side ho (BTU/hr-ft²-°F) 1,891.8
 Tube-Side hi (BTU/hr-ft²-°F) 814.6
 1/Wall Resis (BTU/hr-ft²-°F) 15,431.0
 LMTD Correction Factor 0.9835

U Overall (BTU/hr-ft²-°F) 210.8

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	2.43
Reynold's Number	7.731E+04	1.507E+04
Prandtl Number	2.13	4.45
Bulk Visc (lbm/ft-hr)	0.82	1.62
Skin Visc (lbm/ft-hr)	0.87	1.28
Density (lbm/ft³)	60.52	61.98
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.36

Shell Temp In (°F) 190.0
 Shell Temp Out (°F) 175.4
 Tav Shell (°F) 182.7
 Shell Skin Temp (°F) 173.6
 Tube Temp In (°F) 80.0
 Tube Temp Out (°F) 123.0
 Tav Tube (°F) 101.5
 Tube Skin Temp (°F) 125.8

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 8 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CSCS=90°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Extrapolation Data

Tube Flow (gpm)	464.2
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	90.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5
Tube Mass Flow (lbm/hr)	2.322E+5
Heat Transferred (BTU/hr)	7.8E+6
LMTD	75.5
Effective Area (ft²)	468.2

Overall Fouling (hr-ft²-°F/BTU)	0.002732
Shell-Side ho (BTU/hr-ft²-°F)	1,892.0
Tube-Side hi (BTU/hr-ft²-°F)	1,014.2
1/Wall Resis (BTU/hr-ft²-°F)	15,431.0
LMTD Correction Factor	0.9855

U Overall (BTU/hr-ft²-°F) 224.0

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	3.11
Reynold's Number	7.731E+04	2.037E+04
Prandtl Number	2.13	4.19
Bulk Visc (lbm/ft-hr)	0.82	1.53
Skin Visc (lbm/ft-hr)	0.87	1.27
Density (lbm/ft³)	60.52	61.90
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	190.0
Shell Temp Out (°F)	175.4
Tav Shell (°F)	182.7
Shell Skin Temp (°F)	173.7
Tube Temp In (°F)	90.0
Tube Temp Out (°F)	123.6
Tav Tube (°F)	106.8
Tube Skin Temp (°F)	126.2

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 9 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achie

Commonwealth Edison
 Calculation Report for DG01B - LSCS - HPCS DG Hx.
 CSCS=100°F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Extrapolation Data

Data Date
Shell Flow (gpm)
Shell Temp In (°F)
Shell Temp Out (°F)
Tube Flow (gpm)
Tube Temp In (°F)
Tube Temp Out (°F)

Tube Flow (gpm)	646.1
Shell Flow (gpm)	1,064.5
Tube Inlet Temp (°F)	100.0
Shell Inlet Temp (°F)	190.0

Fouling Calculation Results

Shell Mass Flow (lbm/hr)
 Tube Mass Flow (lbm/hr)
 Heat Transferred (BTU/hr)
 LMTD
 Effective Area (ft²)

U Overall (BTU/hr-ft²-°F)
 Shell-Side ho (BTU/hr-ft²-°F)
 Tube-Side hi (BTU/hr-ft²-°F)
 1/Wall Resis (BTU/hr-ft²-°F)
 LMTD Correction Factor

Overall Fouling (hr-ft²-°F/BTU)

Property	Shell-Side	Tube-Side
Velocity (ft/s)		
Reynold's Number		
Prandtl Number		
Bulk Visc (lbm/ft-hr)		
Skin Visc (lbm/ft-hr)		
Density (lbm/ft³)		
Cp (BTU/lbm-°F)		
K (BTU/hr-ft-°F)		

Shell Temp In (°F)
 Shell Temp Out (°F)
 Tav Shell (°F)
 Shell Skin Temp (°F)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Tav Tube (°F)
 Tube Skin Temp (°F)

Extrapolation Calculation Results

Shell Mass Flow (lbm/hr)	5.325E+5
Tube Mass Flow (lbm/hr)	3.232E+5
Heat Transferred (BTU/hr)	7.801E+6
LMTD	70.5
Effective Area (ft²)	468.2

Overall Fouling (hr-ft²-°F/BTU)	0.002732
Shell-Side ho (BTU/hr-ft²-°F)	1,892.1
Tube-Side hi (BTU/hr-ft²-°F)	1,349.8
1/Wall Resis (BTU/hr-ft²-°F)	15,431.0
LMTD Correction Factor	0.9881

U Overall (BTU/hr-ft²-°F) 239.2

Property	Shell-Side	Tube-Side
Velocity (ft/s)	5.58	4.33
Reynold's Number	7.731E+04	2.991E+04
Prandtl Number	2.13	3.95
Bulk Visc (lbm/ft-hr)	0.82	1.45
Skin Visc (lbm/ft-hr)	0.87	1.27
Density (lbm/ft³)	60.52	61.83
Cp (BTU/lbm-°F)	1.00	1.00
K (BTU/hr-ft-°F)	0.39	0.37

Shell Temp In (°F)	190.0
Shell Temp Out (°F)	175.4
Tav Shell (°F)	182.7
Shell Skin Temp (°F)	173.8
Tube Temp In (°F)	100.0
Tube Temp Out (°F)	124.2
Tav Tube (°F)	112.1
Tube Skin Temp (°F)	126.5

Proto-Power Calc: 97-197

Attachment: E

Rev: A Page 10 of 10

** Reynolds Number Outside Range of Equation Applicability
 !! With Minimum Fouling The Test Heat Load Could Not Be Achieved

**Attachment F to
Proto-Power Calculation
97-197
Revision A**

PROTO-HX™ Version 3.02 MODEL

LASALLE STATION HPCS DIESEL GENERATOR HEAT
EXCHANGER.

FILE NAME:	DG01B.PHX
DATE LAST MODIFIED:	6/26/98
TIME LAST MODIFIED:	11:25:36 AM
FILE SIZE:	864 KB

**ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet**

Design Analysis (Minor Revision)		Last Page No. ⁶ Attachment C, C8	
Analysis No.: ¹ 97-200	Revision: ² A05		
Title: ³ VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A			
EC/ECR No.: ⁴ 388666	Revision: ⁵ 000		
Station(s): ⁷ LaSalle			
Unit No.: ⁸ 01 & 02			
Safety/QA Class: ⁹ SR			
System Code(s): ¹⁰ VY			
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴ This revision evaluates a maximum cooling water inlet temperature of 107 °F. The previous temperature that was evaluated was 104 °F. This revision also raises the maximum room temperature of the Southwest corner room to 153 °F. Affected pages are Pages 1 - 3 and Attachment A, Pages A1-A8, Attachment B, Pages B1-B8, and Attachment C, Pages C1-C8.			
Disposition of Changes: ¹⁵ See attached pages. The changes made are acceptable.			
Preparer: ¹⁶	<u>Sean Tanton</u> <small>Print Name</small>	<u>Sean Tanton</u> <small>Sign Name</small>	<u>5/3/12</u> <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	<u>Steve Chon</u> <small>Print Name</small>	<u>Steve Chon</u> <small>Sign Name</small>	<u>5/7/12</u> <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>		
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Reviewer ²¹	<u>NA</u> <small>Print Name</small>	 <small>Sign Name</small>	 <small>Date</small>
Exelon Approver: ²²	<u>DAN SCHMIT</u> <small>Print Name</small>	<u>DJ Schmit</u> <small>Sign Name</small>	<u>5/18/12</u> <small>Date</small>

Purpose:

The purpose of this revision is to verify that the 1(2)VY01A and 1(2)VY02A coolers can remove the design heat load of 517,239 and 646,235 BTU/hr, respectively with a revised maximum cooling water temperature of 107 °F.

Assumptions:

There are no assumptions for this revision.

Inputs:

- Cooling water temperature = 107 °F (Reference 2)
- Air temperature for 1(2)VY01A = 148 °F (Reference 1)
- Air temperature for 1(2)VY02A = 153 °F*
- Water flow rate for 1(2)VY01A = 75 gpm (Reference 1)
- Water flow rate for 1(2)VY02A = 108 gpm (References 1, 3, and 4)**
- Air Flow rate for 1(2)VY01A = 17,100 cfm (Reference 1)
- Air Flow rate for 1(2)VY02A = 18,000 cfm (Reference 1)
- Fouling factor for both coolers = 0.02832467 hr·ft²·°F/BTU (design fouling factor) (Reference 1)
- 1 tube plugged for both coolers (5% tube plugging) (Reference 1)

*153 °F was chosen to achieve the desired heat transfer rate for the VY02 room cooler. As long as the heat transfer rate of at least 646,235 BTU/hr is achieved, the room will stay ≤ 153 °F. This temperature will be reflected in the EQ binders associated with the components in this room.

**Note that an additional 50 gpm was allocated to the 1(2)VY02A coolers per ECs 370853 and 384525. The results of the run with a 158 gpm flow rate on the water side is shown in Attachment C.

References:

1. Design analysis 97-200, Rev. A, up to and including Revs A00 through A04
2. EC 388666, Rev. 000
3. EC 370853, Rev. 000
4. EC 384525, Rev. 000

Identification of Computer Programs:

The computer program used in this analysis is Proto HX version 4.01. This program has been validated per DTSQA tracking number EX0000103.

Method of Analysis / Numeric Analysis:

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp" from 104 °F to 107 °F. Because the fan for the 1(2)VY01A and 1(2)VY02A coolers is at the exit of the cooler, the inlet air flow for the front cooler is iterated until the flow rate at the exit of the last row of the back cooler is approximately 17,100 cfm for the 1(2)VY01A cooler and 18,000 cfm for the 1(2)VY02A cooler. The iteration process is detailed in section 6.7 of revision A. The air flow values can be found on pages A8, B8, and C8 for each of the three cases considered.

Results / Conclusions:

The 1(2)VY01A coolers can remove the design heat load of 517,239 BTU/hr with the following conditions:

- 107 °F cooling water temperature
- 148 °F air temperature
- design fouling factor of 0.02832467 hr·ft²·°F/BTU
- 1 tube plugged
- air flow rate of 17,100 cfm
- water flow rate of 75 gpm

The total heat removed at these conditions is 560,505 BTU/hr, which provides 8.4% thermal margin over the design heat load. This thermal margin is enough to account for the 4.9% model uncertainty shown in Attachment J and is acceptable. Note that a maximum fouling factor was not calculated as was done in previous revisions because it is not practical to set up test conditions that would allow accurate measurement of the fouling factor

for these heat exchangers. The bounding fouling factor is the design fouling factor of $0.02832467 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$. This case is shown in Attachment A.

The 1(2)VY02A coolers can remove the design heat load of 646,235 BTU/hr with the following conditions:

- 107 °F cooling water temperature
- 153 °F air temperature
- design fouling factor of $0.02832467 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$
- 1 tube plugged
- air flow rate of 18,000 cfm
- water flow rate of 108 gpm

The total heat removed at these conditions is 681,320 BTU/hr, which provides 5.4% thermal margin over the design heat load. This thermal margin is enough to account for the 4.9% model uncertainty shown in Attachment J and is acceptable. Note that a maximum fouling factor was not calculated as was done in previous revisions because it is not practical to set up test conditions that would allow accurate measurement of the fouling factor for these heat exchangers. The bounding fouling factor is the design fouling factor of $0.02832467 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$. This case is shown in Attachment B.

Additionally, a case was run for the 1(2)VY02A coolers with a water flow rate of 158 gpm. All other input parameters listed above remained the same. The total heat removed at these conditions is 701,741 BTU/hr, which provides 8.6% thermal margin over the design heat load. This case is shown in Attachment C. As stated above, this cooling water flow is to be implemented with ECs 370853 and 384525 for Units 1 & 2, respectively. If this flow is to be used as the minimum equipment cooling water flow, an update to the UFSAR is required.

The above 2 cases used a Southwest corner room (1(2)VY02A coolers) maximum temperature of 153 °F. The previously analyzed temperature was 150 °F. As stated above, 153 °F was chosen to achieve the desired heat transfer rate for the VY02 room cooler. As long as the heat transfer rate of at least 646,235 BTU/hr is achieved, the room temperature will stay ≤ 153 °F. The EQ binders associated with the components in this room will be updated to qualify the components for this temperature.

Attachments:

- A. Data Report for 1(2)VY01A (8 pgs)
- B. Data Report for 1(2)VY02A (8 pgs)
- C. Data Report for 1(2)VY02A w/ 158 gpm (8 pgs)

ComEd -- LaSalle

Data Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Flow	21,179.00 acfm	150.00 gpm
Mass Flow	0.00 lbm/hr	0.00 lbm/hr
Dry Bulb (Inlet Temperature)	150.00 °F	105.00 °F
Inlet Wet Bulb Temperature	92.00 °F	
Inlet Relative Humidity	0.00 %	
Dry Bulb (Outlet Temperature)	109.40 °F	115.30 °F
Outlet Wet Bulb Temperature	84.10 °F	
Outlet Relative Humidity	0.00 %	
<hr/>		
Tube Fluid Name		Fresh Water
Tube-Side Fouling		0.001500
Air-Side Fouling		0.000000
Design Q (BTU/hr)		750,000
Atmospheric Pressure (psia)		14.315
Design Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Coil Flow Direction		Counter Flow
Fin Type		Circular Fins
Configuration (for Air-Side h)		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure (psia)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	18,098.00
Tube Inlet Temp (°F)	107.00
Air Inlet Temp (°F)	148.00
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure (psia)	14.315

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr·ft ² ·°F)	0.00
Inlet Temperature (°F)	148.00	107.00	j Factor	0.0000
Outlet Temperature (°F)	114.50	122.05	Air-Side ho (BTU/hr·ft ² ·°F)	0.00
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
			U Overall (BTU/hr·ft ² ·°F)	
			Effective Area (ft ²)	6,880.52
			LMTD	0.00
			Total Heat Transferred (BTU/hr)	560,505
			Surface Effectiveness (Eta)	0.0000
			Sensible Heat Transferred (BTU/hr)	560,505
			Latent Heat Transferred (BTU/hr)	
			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr·ft ² ·°F)	1,013.40
Inlet Temperature (°F)	148.00	118.98	j Factor	0.0082
Outlet Temperature (°F)	141.17	122.05	Air-Side ho (BTU/hr·ft ² ·°F)	8.22
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	144.58	120.5178	U Overall (BTU/hr·ft ² ·°F)	5.56
Skin Temperature (°F)	126.85	123.0132	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9125	LMTD	23.88
Reynold's Number	793**	21,205	Total Heat Transferred (BTU/hr)	114,284
Prandtl Number	0.7254	3.6151	Surface Effectiveness (Eta)	0.9188
Bulk Visc (lbm/ft·hr)	0.0490	1.3399	Sensible Heat Transferred (BTU/hr)	114,284
Skin Visc (lbm/ft·hr)	0.0000	1.3091	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0623	61.7036	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3702		
Relative Humidity In (%)	12.76			
Relative Humidity Out (%)	15.16			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment A
Page A3 of A8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr-ft ² -°F)	998.60
Inlet Temperature (°F)	141.17	116.36	j Factor	0.0082
Outlet Temperature (°F)	135.35	118.98	Air-Side ho (BTU/hr-ft ² -°F)	8.19
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	138.26	117.6724	U Overall (BTU/hr-ft ² -°F)	5.54
Skin Temperature (°F)	123.10	119.8303	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9105	LMTD	20.43
Reynold's Number	799**	20,641	Total Heat Transferred (BTU/hr)	97,394
Prandtl Number	0.7260	3.7235	Surface Effectiveness (Eta)	0.9190
Bulk Visc (lbm/ft-hr)	0.0486	1.3765	Sensible Heat Transferred (BTU/hr)	97,394
Skin Visc (lbm/ft-hr)	0.0000	1.3486	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0629	61.7474	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0161	0.3692		
Relative Humidity In (%)	15.16			
Relative Humidity Out (%)	17.62			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr-ft ² -°F)	985.92
Inlet Temperature (°F)	135.35	114.13	j Factor	0.0082
Outlet Temperature (°F)	130.38	116.36	Air-Side ho (BTU/hr-ft ² -°F)	8.17
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	132.86	115.2463	U Overall (BTU/hr-ft ² -°F)	5.53
Skin Temperature (°F)	119.90	117.1108	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9087	LMTD	17.48
Reynold's Number	805**	20,164	Total Heat Transferred (BTU/hr)	83,087
Prandtl Number	0.7264	3.8202	Surface Effectiveness (Eta)	0.9192
Bulk Visc (lbm/ft-hr)	0.0483	1.4091	Sensible Heat Transferred (BTU/hr)	83,087
Skin Visc (lbm/ft-hr)	0.0000	1.3839	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0634	61.7839	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0160	0.3684		
Relative Humidity In (%)	17.62			
Relative Humidity Out (%)	20.10			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment A
Page A4 of A8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr-ft ² -°F)	975.07
Inlet Temperature (°F)	130.38	112.22	j Factor	0.0081
Outlet Temperature (°F)	126.14	114.13	Air-Side ho (BTU/hr-ft ² -°F)	8.15
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	128.26	113.1757		
Skin Temperature (°F)	117.17	114.7854	U Overall (BTU/hr-ft ² -°F)	5.51
Velocity ***	3,364.26	2.9073	Effective Area (ft ²)	860.06
Reynold's Number	810**	19,760	LMTD	14.97
Prandtl Number	0.7268	3.9061	Total Heat Transferred (BTU/hr)	70,945
Bulk Visc (lbm/ft-hr)	0.0480	1.4379		
Skin Visc (lbm/ft-hr)	0.0000	1.4154	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0639	61.8144	Sensible Heat Transferred (BTU/hr)	70,945
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0159	0.3677	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	20.10			
Relative Humidity Out (%)	22.52			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr-ft ² -°F)	965.76
Inlet Temperature (°F)	126.14	110.59	j Factor	0.0081
Outlet Temperature (°F)	122.52	112.22	Air-Side ho (BTU/hr-ft ² -°F)	8.13
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	124.33	111.4071		
Skin Temperature (°F)	114.83	112.7959	U Overall (BTU/hr-ft ² -°F)	5.50
Velocity ***	3,364.26	2.9061	Effective Area (ft ²)	860.06
Reynold's Number	814**	19,417	LMTD	12.82
Prandtl Number	0.7271	3.9819	Total Heat Transferred (BTU/hr)	60,626
Bulk Visc (lbm/ft-hr)	0.0478	1.4633		
Skin Visc (lbm/ft-hr)	0.0000	1.4433	Surface Effectiveness (Eta)	0.9196
Density (lbm/ft ³)	0.0643	61.8400	Sensible Heat Transferred (BTU/hr)	60,626
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0158	0.3670	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	22.52			
Relative Humidity Out (%)	24.87			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment A
Page A5 of A8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr·ft ² ·°F)	957.79
Inlet Temperature (°F)	122.52	109.20	j Factor	0.0081
Outlet Temperature (°F)	119.42	110.59	Air-Side ho (BTU/hr·ft ² ·°F)	8.12
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	120.97	109.8952	U Overall (BTU/hr·ft ² ·°F)	5.49
Skin Temperature (°F)	112.83	111.0927	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9051	LMTD	10.99
Reynold's Number	818**	19,126	Total Heat Transferred (BTU/hr)	51,842
Prandtl Number	0.7273	4.0486	Surface Effectiveness (Eta)	0.9197
Bulk Visc (lbm/ft·hr)	0.0475	1.4856	Sensible Heat Transferred (BTU/hr)	51,842
Skin Visc (lbm/ft·hr)	0.0000	1.4679	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0646	61.8615	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0157	0.3665		
Relative Humidity In (%)	24.87			
Relative Humidity Out (%)	27.10			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr·ft ² ·°F)	950.95
Inlet Temperature (°F)	119.42	108.01	j Factor	0.0081
Outlet Temperature (°F)	116.77	109.20	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	118.09	108.6021	U Overall (BTU/hr·ft ² ·°F)	5.48
Skin Temperature (°F)	111.12	109.6340	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9042	LMTD	9.42
Reynold's Number	821**	18,878	Total Heat Transferred (BTU/hr)	44,357
Prandtl Number	0.7275	4.1072	Surface Effectiveness (Eta)	0.9198
Bulk Visc (lbm/ft·hr)	0.0474	1.5051	Sensible Heat Transferred (BTU/hr)	44,357
Skin Visc (lbm/ft·hr)	0.0000	1.4895	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0649	61.8797	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0156	0.3660		
Relative Humidity In (%)	27.10			
Relative Humidity Out (%)	29.18			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment A
Page A6 of A8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 - 148 °F air side, 17,100 cfm, 107 °F water side, 75 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,878.21	37,240.41	Tube-Side hi (BTU/hr-ft ² -°F)	945.09
Inlet Temperature (°F)	116.77	106.99	j Factor	0.0081
Outlet Temperature (°F)	114.50	108.01	Air-Side ho (BTU/hr-ft ² -°F)	8.09
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	115.63	107.4955	U Overall (BTU/hr-ft ² -°F)	5.47
Skin Temperature (°F)	109.66	108.3843	Effective Area (ft ²)	860.06
Velocity ***	3,364.26	2.9035	LMTD	8.08
Reynold's Number	824**	18,666	Total Heat Transferred (BTU/hr)	37,971
Prandtl Number	0.7277	4.1584	Surface Effectiveness (Eta)	0.9199
Bulk Visc (lbm/ft-hr)	0.0472	1.5221	Sensible Heat Transferred (BTU/hr)	37,971
Skin Visc (lbm/ft-hr)	0.0000	1.5084	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0652	61.8950	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9989		
K (BTU/hr-ft-°F)	0.0156	0.3656		
Relative Humidity In (%)	29.18			
Relative Humidity Out (%)	31.12			

** Reynolds Number Outside Range of Equation Applicability

Formulas from Section 6.7 for iteration process to determine inlet airflow for extrapolation conditions				
Total P:		$P =$	14.315	psia
Dry Bulb T OUT:		$T1 =$	114.5	F
Specific Hum.:		$W =$	0.0202	
H2O Vap. P:		$Pv = (W \cdot Rv \cdot P) / (Ra + (W \cdot Rv)) =$	0.450285048	psia
		$Rv =$	85.778	(ft-lbf)/(lbm-R)
		$Ra =$	53.352	(ft-lbf)/(lbm-R)
Dry Air P:		$Pa = P - Pv =$	13.864715	psia
Dry Air rho OUT:	$\rho_{o.out} = (144/Ra) \cdot (Pa / (459.67 + T1)) =$		0.065175	lbm/ft ³
Dry Air rho IN:	$\rho_{o.in} = (144/Ra) \cdot (Pa / (459.67 + T2)) =$		0.061582	lbm/ft ³
Dry Bulb T IN:		$T2 =$	148	F
Outlet Air Flow:		$V =$	17100	cfm
cfm.in		$cfm.in = V \cdot (\rho_{o.out} / \rho_{o.in}) =$	18097.70	acfm

ComEd -- LaSalle

Data Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Flow	21,179.00 acfm	150.00 gpm
Mass Flow	0.00 lbm/hr	0.00 lbm/hr
Dry Bulb (Inlet Temperature)	150.00 °F	105.00 °F
Inlet Wet Bulb Temperature	92.00 °F	
Inlet Relative Humidity	0.00 %	
Dry Bulb (Outlet Temperature)	109.40 °F	115.30 °F
Outlet Wet Bulb Temperature	84.10 °F	
Outlet Relative Humidity	0.00 %	
<hr/>		
Tube Fluid Name		Fresh Water
Tube-Side Fouling		0.001500
Air-Side Fouling		0.000000
Design Q (BTU/hr)		750,000
Atmospheric Pressure (psia)		14.315
Design Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Coil Flow Direction		Counter Flow
Fin Type		Circular Fins
Configuration (for Air-Side h)		LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure (psia)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,212.00
Tube Inlet Temp (°F)	107.00
Air Inlet Temp (°F)	153.00
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure (psia)	14.315

97-200
 Rev. A05
 Attachment B
 Page B2 of B8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Extrapolation Calculation Summary
--

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr·ft ² ·°F)	0.00
Inlet Temperature (°F)	153.00	107.00	j Factor	0.0000
Outlet Temperature (°F)	114.36	119.71	Air-Side ho (BTU/hr·ft ² ·°F)	0.00
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
			U Overall (BTU/hr·ft ² ·°F)	
			Effective Area (ft ²)	6,880.52
			LMTD	0.00
			Total Heat Transferred (BTU/hr)	681,320
			Surface Effectiveness (Eta)	0.0000
			Sensible Heat Transferred (BTU/hr)	681,320
			Latent Heat Transferred (BTU/hr)	
			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr·ft ² ·°F)	1,341.67
Inlet Temperature (°F)	153.00	116.88	j Factor	0.0081
Outlet Temperature (°F)	144.40	119.71	Air-Side ho (BTU/hr·ft ² ·°F)	8.49
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	148.70	118.2967	U Overall (BTU/hr·ft ² ·°F)	5.84
Skin Temperature (°F)	125.88	120.7965	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1917	LMTD	30.19
Reynold's Number	827**	29,901	Total Heat Transferred (BTU/hr)	151,661
Prandtl Number	0.7250	3.6993	Surface Effectiveness (Eta)	0.9164
Bulk Visc (lbm/ft·hr)	0.0493	1.3683	Sensible Heat Transferred (BTU/hr)	151,661
Skin Visc (lbm/ft·hr)	0.0000	1.3364	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0617	61.7379	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0163	0.3695		
Relative Humidity In (%)	12.76			
Relative Humidity Out (%)	15.80			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment B
Page B3 of B8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr-ft ² -°F)	1,323.45
Inlet Temperature (°F)	144.40	114.55	j Factor	0.0081
Outlet Temperature (°F)	137.31	116.88	Air-Side ho (BTU/hr-ft ² -°F)	8.46
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	140.86	115.7147	U Overall (BTU/hr-ft ² -°F)	5.82
Skin Temperature (°F)	121.99	117.8022	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1891	LMTD	24.96
Reynold's Number	835**	29,168	Total Heat Transferred (BTU/hr)	124,935
Prandtl Number	0.7258	3.8012	Surface Effectiveness (Eta)	0.9167
Bulk Visc (lbm/ft-hr)	0.0488	1.4027	Sensible Heat Transferred (BTU/hr)	124,935
Skin Visc (lbm/ft-hr)	0.0000	1.3748	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.7769	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0162	0.3686		
Relative Humidity In (%)	15.80			
Relative Humidity Out (%)	18.94			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr-ft ² -°F)	1,308.37
Inlet Temperature (°F)	137.31	112.62	j Factor	0.0080
Outlet Temperature (°F)	131.47	114.55	Air-Side ho (BTU/hr-ft ² -°F)	8.43
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	134.39	113.5865	U Overall (BTU/hr-ft ² -°F)	5.80
Skin Temperature (°F)	118.78	115.3281	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1869	LMTD	20.66
Reynold's Number	842**	28,569	Total Heat Transferred (BTU/hr)	103,055
Prandtl Number	0.7263	3.8888	Surface Effectiveness (Eta)	0.9169
Bulk Visc (lbm/ft-hr)	0.0484	1.4321	Sensible Heat Transferred (BTU/hr)	103,055
Skin Visc (lbm/ft-hr)	0.0000	1.4080	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0630	61.8084	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0160	0.3678		
Relative Humidity In (%)	18.94			
Relative Humidity Out (%)	22.09			

*** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment B
Page B4 of B8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr·ft ² ·°F)	1,295.89
Inlet Temperature (°F)	131.47	111.04	j Factor	0.0080
Outlet Temperature (°F)	126.64	112.62	Air-Side ho (BTU/hr·ft ² ·°F)	8.41
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	129.06	111.8301	U Overall (BTU/hr·ft ² ·°F)	5.78
Skin Temperature (°F)	116.14	113.2821	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1852	LMTD	17.11
Reynold's Number	848**	28,078	Total Heat Transferred (BTU/hr)	85,102
Prandtl Number	0.7268	3.9635	Surface Effectiveness (Eta)	0.9171
Bulk Visc (lbm/ft·hr)	0.0481	1.4571	Sensible Heat Transferred (BTU/hr)	85,102
Skin Visc (lbm/ft·hr)	0.0000	1.4364	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0636	61.8339	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0159	0.3672		
Relative Humidity In (%)	22.09			
Relative Humidity Out (%)	25.14			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr·ft ² ·°F)	1,285.54
Inlet Temperature (°F)	126.64	109.72	j Factor	0.0080
Outlet Temperature (°F)	122.66	111.04	Air-Side ho (BTU/hr·ft ² ·°F)	8.39
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	124.65	110.3790	U Overall (BTU/hr·ft ² ·°F)	5.77
Skin Temperature (°F)	113.95	111.5888	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1838	LMTD	14.17
Reynold's Number	853**	27,675	Total Heat Transferred (BTU/hr)	70,341
Prandtl Number	0.7271	4.0271	Surface Effectiveness (Eta)	0.9173
Bulk Visc (lbm/ft·hr)	0.0478	1.4784	Sensible Heat Transferred (BTU/hr)	70,341
Skin Visc (lbm/ft·hr)	0.0000	1.4606	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0640	61.8546	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0158	0.3667		
Relative Humidity In (%)	25.14			
Relative Humidity Out (%)	28.03			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment B
Page B5 of B8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr-ft ² -°F)	1,276.97
Inlet Temperature (°F)	122.66	108.64	j Factor	0.0080
Outlet Temperature (°F)	119.36	109.72	Air-Side ho (BTU/hr-ft ² -°F)	8.37
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	121.01	109.1793		
Skin Temperature (°F)	112.14	110.1867	U Overall (BTU/hr-ft ² -°F)	5.76
Velocity ***	3,527.02	4.1826	Effective Area (ft ²)	860.06
Reynold's Number	857**	27,343	LMTD	11.74
Prandtl Number	0.7273	4.0809	Total Heat Transferred (BTU/hr)	58,184
Bulk Visc (lbm/ft-hr)	0.0475	1.4963		
Skin Visc (lbm/ft-hr)	0.0000	1.4812	Surface Effectiveness (Eta)	0.9174
Density (lbm/ft ³)	0.0644	61.8716	Sensible Heat Transferred (BTU/hr)	58,184
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0157	0.3662	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	28.03			
Relative Humidity Out (%)	30.71			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr-ft ² -°F)	1,269.86
Inlet Temperature (°F)	119.36	107.74	j Factor	0.0080
Outlet Temperature (°F)	116.63	108.64	Air-Side ho (BTU/hr-ft ² -°F)	8.36
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	117.99	108.1866		
Skin Temperature (°F)	110.64	109.0251	U Overall (BTU/hr-ft ² -°F)	5.75
Velocity ***	3,527.02	4.1817	Effective Area (ft ²)	860.06
Reynold's Number	861**	27,069	LMTD	9.74
Prandtl Number	0.7275	4.1263	Total Heat Transferred (BTU/hr)	48,159
Bulk Visc (lbm/ft-hr)	0.0474	1.5115		
Skin Visc (lbm/ft-hr)	0.0000	1.4987	Surface Effectiveness (Eta)	0.9175
Density (lbm/ft ³)	0.0647	61.8854	Sensible Heat Transferred (BTU/hr)	48,159
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0156	0.3659	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	30.71			
Relative Humidity Out (%)	33.15			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment B
Page B6 of B8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 108 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,113.67	53,626.19	Tube-Side hi (BTU/hr·ft ² ·°F)	1,263.97
Inlet Temperature (°F)	116.63	106.99	j Factor	0.0080
Outlet Temperature (°F)	114.36	107.74	Air-Side ho (BTU/hr·ft ² ·°F)	8.35
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	115.49	107.3648	U Overall (BTU/hr·ft ² ·°F)	5.74
Skin Temperature (°F)	109.40	108.0624	Effective Area (ft ²)	860.06
Velocity ***	3,527.02	4.1809	LMTD	8.07
Reynold's Number	864**	26,843	Total Heat Transferred (BTU/hr)	39,883
Prandtl Number	0.7277	4.1645	Surface Effectiveness (Eta)	0.9176
Bulk Visc (lbm/ft·hr)	0.0472	1.5242	Sensible Heat Transferred (BTU/hr)	39,883
Skin Visc (lbm/ft·hr)	0.0000	1.5134	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0649	61.8968	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3656		
Relative Humidity In (%)	33.15			
Relative Humidity Out (%)	35.34			

** Reynolds Number Outside Range of Equation Applicability

Formulas from Section 6.7 for iteration process to determine inlet airflow for extrapolation conditions				
Total P:		$P =$		14.315 psia
Dry Bulb T OUT:		$T1 =$		114.36 F
Specific Hum.:		$W =$		0.023
H2O Vap. P:		$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$		0.510475042 psia
			$R_v =$	85.778 (ft-lbf)/(lbm-R)
			$R_a =$	53.352 (ft-lbf)/(lbm-R)
Dry Air P:		$P_a = P - P_v =$		13.80452 psia
Dry Air rho OUT:	$\rho_{o.out} = (144/R_a) \cdot (P_a / (459.67 + T1)) =$			0.064908 lbm/ft ³
Dry Air rho IN:	$\rho_{o.in} = (144/R_a) \cdot (P_a / (459.67 + T2)) =$			0.060814 lbm/ft ³
Dry Bulb T IN:		$T2 =$		153 F
Outlet Air Flow:		$V =$		18000 cfm
cfm.in		$cfm.in = V \cdot (\rho_{o.out} / \rho_{o.in}) =$		19211.64 acfm

ComEd -- LaSalle

Data Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Flow	21,179.00 acfm	150.00 gpm
Mass Flow	0.00 lbm/hr	0.00 lbm/hr
Dry Bulb (Inlet Temperature)	150.00 °F	105.00 °F
Inlet Wet Bulb Temperature	92.00 °F	
Inlet Relative Humidity	0.00 %	
Dry Bulb (Outlet Temperature)	109.40 °F	115.30 °F
Outlet Wet Bulb Temperature	84.10 °F	
Outlet Relative Humidity	0.00 %	
<hr/>		
Tube Fluid Name		Fresh Water
Tube-Side Fouling		0.001500
Air-Side Fouling		0.000000
Design Q (BTU/hr)		750,000
Atmospheric Pressure (psia)		14.315
Design Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Coil Flow Direction		Counter Flow
Fin Type		Circular Fins
Configuration (for Air-Side h)		LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure (psia)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	158.00
Air Flow (acfm)	19,248.00
Tube Inlet Temp (°F)	107.00
Air Inlet Temp (°F)	153.00
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure (psia)	14.315

97-200
 Rev. A05
 Attachment C
 Page C2 of C8

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Extrapolation Calculation Summary
--

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr·ft ² ·°F)	0.00
Inlet Temperature (°F)	153.00	107.00	j Factor	0.0000
Outlet Temperature (°F)	113.28	115.98	Air-Side ho (BTU/hr·ft ² ·°F)	0.00
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
			U Overall (BTU/hr·ft ² ·°F)	
			Effective Area (ft ²)	6,880.52
			LMTD	0.00
			Total Heat Transferred (BTU/hr)	701,741
			Surface Effectiveness (Eta)	0.0000
			Sensible Heat Transferred (BTU/hr)	701,741
			Latent Heat Transferred (BTU/hr)	
			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr·ft ² ·°F)	1,786.84
Inlet Temperature (°F)	153.00	113.82	j Factor	0.0081
Outlet Temperature (°F)	143.40	115.98	Air-Side ho (BTU/hr·ft ² ·°F)	8.50
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	148.20	114.9014	U Overall (BTU/hr·ft ² ·°F)	5.97
Skin Temperature (°F)	122.69	117.0014	Effective Area (ft ²)	860.06
Velocity ***	3,533.63	6.1272	LMTD	33.06
Reynold's Number	829**	42,337	Total Heat Transferred (BTU/hr)	169,688
Prandtl Number	0.7251	3.8343	Surface Effectiveness (Eta)	0.9163
Bulk Visc (lbm/ft·hr)	0.0492	1.4138	Sensible Heat Transferred (BTU/hr)	169,688
Skin Visc (lbm/ft·hr)	0.0000	1.3854	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0618	61.7890	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0163	0.3683		
Relative Humidity In (%)	12.76			
Relative Humidity Out (%)	16.21			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment C
Page C3 of C8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr-ft ² -°F)	1,767.91
Inlet Temperature (°F)	143.40	112.09	j Factor	0.0081
Outlet Temperature (°F)	135.75	113.82	Air-Side ho (BTU/hr-ft ² -°F)	8.46
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	139.57	112.9565		
Skin Temperature (°F)	119.18	114.6465	U Overall (BTU/hr-ft ² -°F)	5.95
Velocity ***	3,533.63	6.1244	Effective Area (ft ²)	860.06
Reynold's Number	838**	41,538	LMTD	26.43
Prandtl Number	0.7259	3.9153	Total Heat Transferred (BTU/hr)	135,127
Bulk Visc (lbm/ft-hr)	0.0487	1.4410		
Skin Visc (lbm/ft-hr)	0.0000	1.4173	Surface Effectiveness (Eta)	0.9166
Density (lbm/ft ³)	0.0626	61.8176	Sensible Heat Transferred (BTU/hr)	135,127
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0161	0.3676	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	16.21			
Relative Humidity Out (%)	19.73			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr-ft ² -°F)	1,752.78
Inlet Temperature (°F)	135.75	110.72	j Factor	0.0080
Outlet Temperature (°F)	129.65	112.09	Air-Side ho (BTU/hr-ft ² -°F)	8.43
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	132.70	111.4066		
Skin Temperature (°F)	116.38	112.7661	U Overall (BTU/hr-ft ² -°F)	5.93
Velocity ***	3,533.63	6.1222	Effective Area (ft ²)	860.06
Reynold's Number	846**	40,905	LMTD	21.14
Prandtl Number	0.7265	3.9819	Total Heat Transferred (BTU/hr)	107,769
Bulk Visc (lbm/ft-hr)	0.0483	1.4633		
Skin Visc (lbm/ft-hr)	0.0000	1.4437	Surface Effectiveness (Eta)	0.9169
Density (lbm/ft ³)	0.0632	61.8400	Sensible Heat Transferred (BTU/hr)	107,769
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0160	0.3670	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	19.73			
Relative Humidity Out (%)	23.19			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment C
Page C4 of C8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr-ft ² -°F)	1,740.68
Inlet Temperature (°F)	129.65	109.62	j Factor	0.0080
Outlet Temperature (°F)	124.78	110.72	Air-Side ho (BTU/hr-ft ² -°F)	8.41
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	127.21	110.1699		
Skin Temperature (°F)	114.15	111.2629	U Overall (BTU/hr-ft ² -°F)	5.91
Velocity ***	3,533.63	6.1204	Effective Area (ft ²)	860.06
Reynold's Number	852**	40,403	LMTD	16.92
Prandtl Number	0.7269	4.0364	Total Heat Transferred (BTU/hr)	86,054
Bulk Visc (lbm/ft-hr)	0.0479	1.4815		
Skin Visc (lbm/ft-hr)	0.0000	1.4654	Surface Effectiveness (Eta)	0.9171
Density (lbm/ft ³)	0.0638	61.8576	Sensible Heat Transferred (BTU/hr)	86,054
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0158	0.3666	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	23.19			
Relative Humidity Out (%)	26.45			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr-ft ² -°F)	1,730.99
Inlet Temperature (°F)	124.78	108.74	j Factor	0.0080
Outlet Temperature (°F)	120.88	109.62	Air-Side ho (BTU/hr-ft ² -°F)	8.39
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	122.83	109.1819		
Skin Temperature (°F)	112.37	110.0604	U Overall (BTU/hr-ft ² -°F)	5.90
Velocity ***	3,533.63	6.1191	Effective Area (ft ²)	860.06
Reynold's Number	857**	40,003	LMTD	13.55
Prandtl Number	0.7272	4.0807	Total Heat Transferred (BTU/hr)	68,781
Bulk Visc (lbm/ft-hr)	0.0477	1.4963		
Skin Visc (lbm/ft-hr)	0.0000	1.4831	Surface Effectiveness (Eta)	0.9173
Density (lbm/ft ³)	0.0642	61.8715	Sensible Heat Transferred (BTU/hr)	68,781
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0157	0.3662	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	26.45			
Relative Humidity Out (%)	29.44			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment C
Page C5 of C8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr·ft ² ·°F)	1,723.23
Inlet Temperature (°F)	120.88	108.04	j Factor	0.0080
Outlet Temperature (°F)	117.77	108.74	Air-Side ho (BTU/hr·ft ² ·°F)	8.38
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	119.33	108.3920	U Overall (BTU/hr·ft ² ·°F)	5.89
Skin Temperature (°F)	110.94	109.0979	Effective Area (ft ²)	860.06
Velocity ***	3,533.63	6.1180	LMTD	10.86
Reynold's Number	861**	39,684	Total Heat Transferred (BTU/hr)	55,019
Prandtl Number	0.7275	4.1168	Surface Effectiveness (Eta)	0.9174
Bulk Visc (lbm/ft·hr)	0.0474	1.5083	Sensible Heat Transferred (BTU/hr)	55,019
Skin Visc (lbm/ft·hr)	0.0000	1.4976	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0645	61.8826	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0157	0.3660		
Relative Humidity In (%)	29.44			
Relative Humidity Out (%)	32.10			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr·ft ² ·°F)	1,717.01
Inlet Temperature (°F)	117.77	107.48	j Factor	0.0080
Outlet Temperature (°F)	115.28	108.04	Air-Side ho (BTU/hr·ft ² ·°F)	8.36
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	116.52	107.7600	U Overall (BTU/hr·ft ² ·°F)	5.88
Skin Temperature (°F)	109.80	108.3270	Effective Area (ft ²)	860.06
Velocity ***	3,533.63	6.1171	LMTD	8.70
Reynold's Number	864**	39,430	Total Heat Transferred (BTU/hr)	44,037
Prandtl Number	0.7276	4.1460	Surface Effectiveness (Eta)	0.9175
Bulk Visc (lbm/ft·hr)	0.0473	1.5180	Sensible Heat Transferred (BTU/hr)	44,037
Skin Visc (lbm/ft·hr)	0.0000	1.5093	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0648	61.8914	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3657		
Relative Humidity In (%)	32.10			
Relative Humidity Out (%)	34.44			

** Reynolds Number Outside Range of Equation Applicability

97-200
Rev. A05
Attachment C
Page C6 of C8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 - 153 °F air side, 18,000 cfm, 107 °F water side, 158 gpm, Design FF, 1 tube plugged




Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,245.05	78,453.13	Tube-Side hi (BTU/hr·ft ² ·°F)	1,712.02
Inlet Temperature (°F)	115.28	107.03	j Factor	0.0080
Outlet Temperature (°F)	113.28	107.48	Air-Side ho (BTU/hr·ft ² ·°F)	8.35
Inlet Specific Humidity	0.023032		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.023032		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	114.28	107.2540	U Overall (BTU/hr·ft ² ·°F)	5.88
Skin Temperature (°F)	108.89	107.7094	Effective Area (ft ²)	860.06
Velocity ***	3,533.63	6.1164	LMTD	6.98
Reynold's Number	867**	39,226	Total Heat Transferred (BTU/hr)	35,265
Prandtl Number	0.7278	4.1697	Surface Effectiveness (Eta)	0.9176
Bulk Visc (lbm/ft·hr)	0.0471	1.5259	Sensible Heat Transferred (BTU/hr)	35,265
Skin Visc (lbm/ft·hr)	0.0000	1.5188	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0650	61.8983	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3655		
Relative Humidity In (%)	34.44			
Relative Humidity Out (%)	36.45			

** Reynolds Number Outside Range of Equation Applicability

Formulas from Section 6.7 for iteration process to determine inlet airflow for extrapolation conditions			
Total P:	$P =$		14.315 psia
Dry Bulb T OUT:	$T1 =$		113.28 F
Specific Hum.:	$W =$		0.023
H2O Vap. P:	$Pv = (W \cdot Rv \cdot P) / (Ra + (W \cdot Rv)) =$		0.510475042 psia
		$Rv =$	85.778 (ft-lbf)/(lbm-R)
		$Ra =$	53.352 (ft-lbf)/(lbm-R)
Dry Air P:	$Pa = P - Pv =$		13.80452 psia
Dry Air rho OUT:	$\rho_{o.out} = (144/Ra) \cdot (Pa / (459.67 + T1)) =$		0.065030 lbm/ft ³
Dry Air rho IN:	$\rho_{o.in} = (144/Ra) \cdot (Pa / (459.67 + T2)) =$		0.060814 lbm/ft ³
Dry Bulb T IN:	$T2 =$		153 F
Outlet Air Flow:	$V =$		18000 cfm
cfm.in	$cfm.in = V \cdot (\rho_{o.out} / \rho_{o.in}) =$		19247.86 acfm





**ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet**

Design Analysis (Minor Revision)		Last Page No. ⁶ 1	
Analysis No.: ¹ 97-200	Revision: ² A04		
Title: ³ VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A			
EC/ECR No.: ⁴ 384525	Revision: ⁵ 000		
Station(s): ⁷ LaSalle	Unit No.: ⁸ 02		
Safety/QA Class: ⁹ SR	System Code(s): ¹⁰ HP, E22, DG, VY		
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/> If yes, ATI/AR#: N/A
This Design Analysis SUPERCEDES: ¹³ N/A		in its entirety.	
Description of Changes (list affected pages): ¹⁴ EC 384525 revised the flows in Division 3 of the Unit 2 CSCS. This revision makes the changes made in Revision A03 applicable to both Units.			
Disposition of Changes: ¹⁵ As shown in Attachment A of Revision A03, the changes made are acceptable. The additional 50 gpm is acceptable. No formal heat transfer analysis will be performed.			
Preparer: ¹⁶	Sean Tanton <small>Print Name</small>	 <small>Sign Name</small>	3/20/12 <small>Date</small>
Method of Review: ¹⁷	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations <input type="checkbox"/>	Testing <input type="checkbox"/>
Reviewer: ¹⁸	Matthew Cosenza <small>Print Name</small>	 <small>Sign Name</small>	3/20/12 <small>Date</small>
Review Notes: ¹⁹	Independent review <input checked="" type="checkbox"/>	Peer review <input type="checkbox"/>	
<small>(For External Analyses Only)</small>			
External Approver: ²⁰	N/A <small>Print Name</small>	N/A <small>Sign Name</small>	N/A <small>Date</small>
Exelon Reviewer ²¹	N/A <small>Print Name</small>	N/A <small>Sign Name</small>	N/A <small>Date</small>
Exelon Approver: ²²	Dan Schmit <small>Print Name</small>	 <small>Sign Name</small>	3/28/12 <small>Date</small>

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet

Design Analysis (Minor Revision)		Last Page No. ' 1	
Analysis No.: ' 97-200	Revision: ' A03		
Title: ' VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A			
EC/ECR No.: ' 370853	Revision: ' 000		
Station(s): ' LaSalle			
Unit No.: ' 01			
Safety/QA Class: ' SR			
System Code(s): " HP, E22, DG			
Is this Design Analysis Safeguards Information? "		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes, see SY-AA-101-106
Does this Design Analysis contain Unverified Assumptions? "		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes, ATI/AR#: N/A
This Design Analysis SUPERCEDES: " N/A		In its entirety.	
Description of Changes (list affected pages): " To recover available margin in Division III of the CSCS, EC 370853 revises the flows of the 1VY02A cooler. To recover margin, 100 gpm will be diverted from the 1E22-S001 cooler. Of this 100 gpm, 50 gpm will be returned to the 1E22-C001 pump, while the other 50 gpm will be given to the 1VY02A cooler. This minor revision documents the change in flow.			
Note that this analysis covers the 1(2)VY02A and the 1(2)VY01A coolers. This revision only applies to Div. 3, Unit 1 (1VY02A cooler). The flows shown for the remaining coolers are not impacted by this revision.			
Disposition of Changes: " The minimum flow required to remove the design heat load of 646,235 Btu/hr has not changed. Because the flow through the coolers is increasing by 50 gpm, the heat transfer will be greater and the previous scenarios that have been run in this calculation will remain bounding. The increase in flow will not increase the velocity of the water through the tubes to a point that would exceed the limits established in ER-AA-340-2000. Therefore, the additional 50 gpm is acceptable.			
Preparer: " Sean Tanton	<small>Print Name</small>	<i>Sean Tanton</i>	<small>Sign Name</small>
			5/31/11 <small>Date</small>
Method of Review: " Detailed Review <input checked="" type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing <input type="checkbox"/>			
Reviewer: " Matthew Cosenza	<small>Print Name</small>	<i>Matthew Cosenza</i>	<small>Sign Name</small>
			6/1/11 <small>Date</small>
Review Notes: " Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>			
<small>(For External Analyses Only)</small>			
External Approver: " N/A	<small>Print Name</small>	N/A	<small>Sign Name</small>
			N/A <small>Date</small>
Exelon Reviewer: " N/A	<small>Print Name</small>	N/A	<small>Sign Name</small>
			N/A <small>Date</small>
Exelon Approver: " Dan Schmit	<small>Print Name</small>	<i>D Schmit</i>	<small>Sign Name</small>
			6/1/11 <small>Date</small>

ATTACHMENT 2
Design Analysis Minor Revision Cover Sheet
Page 1 of 13

Analysis No. 97-200	<i>* Plus A-H A Page A1 - A7 A-H B Page B1 - B7</i>	Last Page No. 3 rd
EC/ECR No. 356225		Revision A02
Title: VY Cooler Thermal Performance Model - 1(2)VY01A and 1(2)VY02A		Revision 0
Station(s) LaSalle	Is this Design Analysis Safeguards? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Does this Design Analysis Contain Unverified Assumptions? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ATI/AR#	
Unit No.: 01/02		
Safety Class SR		
System Code VY		
Description of Change This minor revision reduces the amount of air flow required into the 1(2)VY01A coolers by 5%, and determines a new maximum fouling factor at this reduced air flow. The 1(2)VY02A coolers were not changed.		
Disposition of Changes (include additional pages as required) See attached sheets. The change is acceptable.		
Preparer Terry Martin		7/6/05
Print Name	Sign Name	Date
Reviewer DAN SCHMIT		7/6/05
Print Name	Sign Name	Date
Method of Review <input checked="" type="checkbox"/> Detailed Review <input type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing		
Review Notes:		
Approver  W. Hilton 		7-6-05
Print Name	Sign Name	Date
<small>(For External Analyses Only)</small>		
Exelon Reviewer		
Print Name	Sign Name	Date
Approver		
Print Name	Sign Name	Date

Purpose:

The purpose of this minor revision is to revise the thermal model of the 1(2)VY01A coolers for a 5% reduction in airflow. This assessment will evaluate the adequacy of these heat exchangers with a maximum allowable inlet service water temperature of 104°F, using the design fouling factor of 0.02832467 hr*ft²*°F/BTU, and 5% tube plugging. Another case will be run to find the maximum fouling factor with the 5% reduction in air flow and 5% of the tubes plugged.

Inputs:

The design inputs consist of Reference 1 listed below.

Assumptions:

The assumptions indicated in section 5.0 of Reference 1 are still valid.

References:

1. Calculation No. 97-200, Rev. A, "VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A."

Identification of Computer Programs:

Proto Hx version 4.01 is used for this minor revision. The same software was used for the other revisions in this calculation.

Method of Analysis and Acceptance Criteria:

The existing heat exchanger model will be revised by changing the input of the air inlet flow rate. The 5% reduction is calculated on the exit of the cooler. This reduction in flow along with the 5% plugged tubes, design fouling factor, and 104°F incoming cooling water was used to determine the thermal margin of the coolers and the maximum fouling factor. The acceptance criteria will be for the calculated heat transfer to exceed the LaSalle design heat load of 517,239 BTU/hr for 1(2)VY01A coolers (See Reference 1, Table 1). The original benchmark model developed for these heat exchangers demonstrated a correlation to vendor performance specification within an assumed 5% margin.

Analysis:

All input parameters except for air flow rate have remained the same and will not change for this model. Proto HX requires the inlet air flow rate, but our flow device is located on the exit of the heat exchanger. The current analyzed exit flow rate is taken from the 8th row of the cooler (see Reference 1 Rev A00 Attachment B, page B8), which is 70,628.98 lbm/hr. Dividing this mass flow rate by the density (which is also on that same page) and converting to minutes gives an exit flow rate of 18,000 CFM. Reducing this number by 5% results in an exit flow rate of 17,100 CFM. Manipulation of the inlet flow rate was used until the exit flow rate is 17,100 CFM.

When the Service Water inlet temperature is 104°F for the limiting flow rate of 75gpm, a design fouling factor of 0.02832467 hr*ft²*°F/BTU, and a 5% tube plugging allowance, the new total heat transfer is 603,150 BTU/hr. The thermal margin is calculated as

$Q_{\text{calculated}} - Q_{\text{required}}$, which is $603,150 - 517,239 \text{ BTU/hr} = 85,911$ or 16.6% Gross Thermal Margin. Allowing for 5% model uncertainty, the net margin is $603,150(0.95) - 517,239 \text{ BTU/hr} = 55,754$ or 10.8% net Thermal Margin.

The maximum fouling factor with the same assumptions as above and a 5% model uncertainty is $0.07593245 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$.

Results / Conclusion:

The 1(2)VY01A coolers were found to have adequate thermal margin for a maximum lake temperature of 104°F when operated at design fouling conditions ($0.02832467 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$), a 5% tube plugging allowance, and a 5% reduction in air flow rate. The maximum fouling factor is $0.07593245 \text{ hr}\cdot\text{ft}^2\cdot^\circ\text{F}/\text{BTU}$. A reduced air flow rate of 17,100 ACFM (95% of 18,000) may therefore be used as acceptance criteria for airside flow rate testing (e.g. LTS-200-19).

Attachments:

Attachment "A" – Proto-Hx Calc. Report for 1(2)VY01A

(CSCS= 104°F @ design fouling, 5% tube plugged, 5% reduction in flow)

Attachment "B" – Proto-Hx Calc. Report for 1(2)VY01A

(CSCS= 104°F Max FF, 5% tube plugged, 5% reduction in flow)

97-200 #10/05
Rev A02
Page 3 of 3

ComEd -- LaSalle

Data Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Flow	21,179.00 acfm	150.00 gpm
Mass Flow	0.00 lbm/hr	0.00 lbm/hr
Dry Bulb (Inlet Temperature)	150.00 °F	105.00 °F
Inlet Wet Bulb Temperature	92.00 °F	
Inlet Relative Humidity	0.00 %	
Dry Bulb (Outlet Temperature)	109.40 °F	115.30 °F
Outlet Wet Bulb Temperature	84.10 °F	
Outlet Relative Humidity	0.00 %	
<hr/>		
Tube Fluid Name		Fresh Water
Tube-Side Fouling		0.001500
Air-Side Fouling		0.000000
Design Q (BTU/hr)		750,000
Atmospheric Pressure (psia)		14.315
Design Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Coil Flow Direction		Counter Flow
Fin Type		Circular Fins
Configuration (for Air-Side h)		LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Conductivity (BTU/hr-ft-°F)		225.00

*97-200 Rev 102
Att A
Page A1 of A7*

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure (psia)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	18,186.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.00
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure (psia)	14.315

97-200 Rev#02
 A44
 Page A2

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Extrapolation Calculation Summary
--

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	0.00
Inlet Temperature (°F)	148.00	104.00	j Factor	0.0000
Outlet Temperature (°F)	112.12	120.20	Air-Side ho (BTU/hr·ft ² ·°F)	0.00
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
			U Overall (BTU/hr·ft ² ·°F)	
			Effective Area (ft ²)	6,880.52
			LMTD	0.00
			Total Heat Transferred (BTU/hr)	603,150
			Surface Effectiveness (Eta)	0.0000
			Sensible Heat Transferred (BTU/hr)	603,150
			Latent Heat Transferred (BTU/hr)	
			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	1,004.28
Inlet Temperature (°F)	148.00	116.90	j Factor	0.0082
Outlet Temperature (°F)	140.70	120.20	Air-Side ho (BTU/hr·ft ² ·°F)	8.24
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	144.35	118.5507	U Overall (BTU/hr·ft ² ·°F)	5.57
Skin Temperature (°F)	125.37	121.2532	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9130	LMTD	25.60
Reynold's Number	797**	20,828	Total Heat Transferred (BTU/hr)	122,664
Prandtl Number	0.7255	3.6895	Surface Effectiveness (Eta)	0.9186
Bulk Visc (lbm/ft·hr)	0.0490	1.3650	Sensible Heat Transferred (BTU/hr)	122,664
Skin Visc (lbm/ft·hr)	0.0000	1.3307	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0623	61.7340	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3695		
Relative Humidity In (%)	12.76			
Relative Humidity Out (%)	15.34			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev. A
 Att A
 Page A3

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F. Design FF, 5% Plug, 5% Reduction in Flow

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	988.35
Inlet Temperature (°F)	140.70	114.09	j Factor	0.0082
Outlet Temperature (°F)	134.48	116.90	Air-Side ho (BTU/hr·ft ² ·°F)	8.21
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	137.59	115.4974	U Overall (BTU/hr·ft ² ·°F)	5.55
Skin Temperature (°F)	121.35	117.8395	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9108	LMTD	21.93
Reynold's Number	804**	20,226	Total Heat Transferred (BTU/hr)	104,623
Prandtl Number	0.7261	3.8100	Surface Effectiveness (Eta)	0.9188
Bulk Visc (lbm/ft·hr)	0.0486	1.4056	Sensible Heat Transferred (BTU/hr)	104,623
Skin Visc (lbm/ft·hr)	0.0000	1.3743	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0630	61.7801	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0161	0.3685		
Relative Humidity In (%)	15.34			
Relative Humidity Out (%)	18.03			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	974.69
Inlet Temperature (°F)	134.48	111.69	j Factor	0.0081
Outlet Temperature (°F)	129.17	114.09	Air-Side ho (BTU/hr·ft ² ·°F)	8.19
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	131.82	112.8918	U Overall (BTU/hr·ft ² ·°F)	5.53
Skin Temperature (°F)	117.92	114.9196	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9090	LMTD	18.79
Reynold's Number	810**	19,718	Total Heat Transferred (BTU/hr)	89,336
Prandtl Number	0.7265	3.9181	Surface Effectiveness (Eta)	0.9191
Bulk Visc (lbm/ft·hr)	0.0482	1.4419	Sensible Heat Transferred (BTU/hr)	89,336
Skin Visc (lbm/ft·hr)	0.0000	1.4136	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0636	61.8185	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0159	0.3676		
Relative Humidity In (%)	18.03			
Relative Humidity Out (%)	20.76			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 Act A
 Page 44

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr-ft ² -°F)	962.97
Inlet Temperature (°F)	129.17	109.64	j Factor	0.0081
Outlet Temperature (°F)	124.62	111.69	Air-Side ho (BTU/hr-ft ² -°F)	8.17
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	126.90	110.6660	U Overall (BTU/hr-ft ² -°F)	5.51
Skin Temperature (°F)	114.98	112.4202	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9075	LMTD	16.11
Reynold's Number	815**	19,287	Total Heat Transferred (BTU/hr)	76,356
Prandtl Number	0.7269	4.0144	Surface Effectiveness (Eta)	0.9192
Bulk Visc (lbm/ft·hr)	0.0479	1.4741	Sensible Heat Transferred (BTU/hr)	76,356
Skin Visc (lbm/ft·hr)	0.0000	1.4486	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0641	61.8506	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr-ft·°F)	0.0158	0.3668		
Relative Humidity In (%)	20.76			
Relative Humidity Out (%)	23.47			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr-ft ² -°F)	952.92
Inlet Temperature (°F)	124.62	107.89	j Factor	0.0081
Outlet Temperature (°F)	120.74	109.64	Air-Side ho (BTU/hr-ft ² -°F)	8.15
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	122.68	108.7629	U Overall (BTU/hr-ft ² -°F)	5.50
Skin Temperature (°F)	112.47	110.2792	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9062	LMTD	13.81
Reynold's Number	820**	18,921	Total Heat Transferred (BTU/hr)	65,316
Prandtl Number	0.7272	4.0998	Surface Effectiveness (Eta)	0.9194
Bulk Visc (lbm/ft·hr)	0.0477	1.5026	Sensible Heat Transferred (BTU/hr)	65,316
Skin Visc (lbm/ft·hr)	0.0000	1.4799	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0645	61.8774	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr-ft·°F)	0.0157	0.3661		
Relative Humidity In (%)	23.47			
Relative Humidity Out (%)	26.12			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 AH 4
 Page 45

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	944.29
Inlet Temperature (°F)	120.74	106.38	j Factor	0.0081
Outlet Temperature (°F)	117.41	107.89	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	119.08	107.1344		
Skin Temperature (°F)	110.32	108.4442	U Overall (BTU/hr·ft ² ·°F)	5.48
Velocity ***	3.380.62	2.9052	Effective Area (ft ²)	860.06
Reynold's Number	824**	18,610	LMTD	11.85
Prandtl Number	0.7275	4.1753	Total Heat Transferred (BTU/hr)	55,913
Bulk Visc (lbm/ft·hr)	0.0474	1.5278		
Skin Visc (lbm/ft·hr)	0.0000	1.5075	Surface Effectiveness (Eta)	0.9195
Density (lbm/ft ³)	0.0649	61.9000	Sensible Heat Transferred (BTU/hr)	55,913
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3655	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	26.12			
Relative Humidity Out (%)	28.66			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	936.89
Inlet Temperature (°F)	117.41	105.10	j Factor	0.0081
Outlet Temperature (°F)	114.56	106.38	Air-Side ho (BTU/hr·ft ² ·°F)	8.12
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	115.99	105.7400		
Skin Temperature (°F)	108.48	106.8708	U Overall (BTU/hr·ft ² ·°F)	5.47
Velocity ***	3.380.62	2.9043	Effective Area (ft ²)	860.06
Reynold's Number	827**	18,345	LMTD	10.17
Prandtl Number	0.7277	4.2417	Total Heat Transferred (BTU/hr)	47,894
Bulk Visc (lbm/ft·hr)	0.0472	1.5498		
Skin Visc (lbm/ft·hr)	0.0000	1.5319	Surface Effectiveness (Eta)	0.9197
Density (lbm/ft ³)	0.0652	61.9190	Sensible Heat Transferred (BTU/hr)	47,894
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3650	Heat to Condensate (BTU/hr)	
Relative Humidity In (%)	28.66			
Relative Humidity Out (%)	31.06			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 Att A
 Page A 6

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Design FF, 5% Plug, 5% Reduction in Flow

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	67,203.40	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	930.53
Inlet Temperature (°F)	114.56	103.99	j Factor	0.0081
Outlet Temperature (°F)	112.12	105.10	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	113.34	104.5452	U Overall (BTU/hr·ft ² ·°F)	5.47
Skin Temperature (°F)	106.90	105.5210	Effective Area (ft ²)	860.06
Velocity ***	3.380.62	2.9035	LMTD	8.73
Reynold's Number	830**	18,119	Total Heat Transferred (BTU/hr)	41,047
Prandtl Number	0.7278	4.3000	Surface Effectiveness (Eta)	0.9198
Bulk Visc (lbm/ft·hr)	0.0471	1.5692	Sensible Heat Transferred (BTU/hr)	41,047
Skin Visc (lbm/ft·hr)	0.0000	1.5534	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0655	61.9351	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0155	0.3645		
Relative Humidity In (%)	31.06			
Relative Humidity Out (%)	33.30			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
A# A
Page A 7 Final

ComEd -- LaSalle

Data Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Flow	21,179.00 acfm	150.00 gpm
Mass Flow	0.00 lbm/hr	0.00 lbm/hr
Dry Bulb (Inlet Temperature)	150.00 °F	105.00 °F
Inlet Wet Bulb Temperature	92.00 °F	
Inlet Relative Humidity	0.00 %	
Dry Bulb (Outlet Temperature)	109.40 °F	115.30 °F
Outlet Wet Bulb Temperature	84.10 °F	
Outlet Relative Humidity	0.00 %	
<hr/>		
Tube Fluid Name		Fresh Water
Tube-Side Fouling		0.004000
Air-Side Fouling		0.000400
Design Q (BTU/hr)		750,000
Atmospheric Pressure (psia)		14.315
Design Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Coil Flow Direction		Counter Flow
Fin Type		Circular Fins
Configuration (for Air-Side h)		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Conductivity (BTU/hr-ft-°F)		225.00

97-200 Rev A02
A4 B
Page B1 of B7

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure (psia)
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	18,075.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.00
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure (psia)	14.315

97-200 Rev 102
 A + B
 Page B7

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	0.00
Inlet Temperature (°F)	148.00	104.00	j Factor	0.0000
Outlet Temperature (°F)	114.87	118.87	Air-Side ho (BTU/hr·ft ² ·°F)	0.00
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
			U Overall (BTU/hr·ft ² ·°F)	
			Effective Area (ft ²)	6,880.52
			LMTD	0.00
			Total Heat Transferred (BTU/hr)	553,584
			Surface Effectiveness (Eta)	0.0000
			Sensible Heat Transferred (BTU/hr)	553,584
			Latent Heat Transferred (BTU/hr)	
			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	998.32
Inlet Temperature (°F)	148.00	116.10	j Factor	0.0082
Outlet Temperature (°F)	141.83	118.87	Air-Side ho (BTU/hr·ft ² ·°F)	8.21
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	144.91	117.4817	U Overall (BTU/hr·ft ² ·°F)	4.39
Skin Temperature (°F)	128.95	119.7606	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9122	LMTD	27.30
Reynold's Number	792**	20,617	Total Heat Transferred (BTU/hr)	103,117
Prandtl Number	0.7254	3.7310	Surface Effectiveness (Eta)	0.9189
Bulk Visc (lbm/ft·hr)	0.0490	1.3790	Sensible Heat Transferred (BTU/hr)	103,117
Skin Visc (lbm/ft·hr)	0.0000	1.3495	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0622	61.7503	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3692		
Relative Humidity In (%)	12.76			
Relative Humidity Out (%)	14.91			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 Att B
 Page B3

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr-ft ² -°F)	984.79
Inlet Temperature (°F)	141.83	113.66	j Factor	0.0082
Outlet Temperature (°F)	136.39	116.10	Air-Side ho (BTU/hr-ft ² -°F)	8.19
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.07593245
Average Temp (°F)	139.11	114.8760	U Overall (BTU/hr-ft ² -°F)	4.38
Skin Temperature (°F)	125.00	116.9114	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9104	LMTD	24.12
Reynold's Number	798**	20,105	Total Heat Transferred (BTU/hr)	90,846
Prandtl Number	0.7259	3.8354	Surface Effectiveness (Eta)	0.9191
Bulk Visc (lbm/ft·hr)	0.0487	1.4142	Sensible Heat Transferred (BTU/hr)	90,846
Skin Visc (lbm/ft·hr)	0.0000	1.3866	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0628	61.7894	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr-ft·°F)	0.0161	0.3683		
Relative Humidity In (%)	14.91			
Relative Humidity Out (%)	17.15			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr-ft ² -°F)	972.82
Inlet Temperature (°F)	136.39	111.50	j Factor	0.0082
Outlet Temperature (°F)	131.60	113.66	Air-Side ho (BTU/hr-ft ² -°F)	8.17
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.07593245
Average Temp (°F)	134.00	112.5798	U Overall (BTU/hr-ft ² -°F)	4.37
Skin Temperature (°F)	121.53	114.3961	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9088	LMTD	21.31
Reynold's Number	803**	19,657	Total Heat Transferred (BTU/hr)	80,084
Prandtl Number	0.7264	3.9313	Surface Effectiveness (Eta)	0.9193
Bulk Visc (lbm/ft·hr)	0.0484	1.4464	Sensible Heat Transferred (BTU/hr)	80,084
Skin Visc (lbm/ft·hr)	0.0000	1.4208	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0633	61.8230	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr-ft·°F)	0.0160	0.3675		
Relative Humidity In (%)	17.15			
Relative Humidity Out (%)	19.46			

** Reynolds Number Outside Range of Equation Applicability

97-700 Rev A02
 Att B
 Page 64

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F. Max FF, 5% Plug, reduction in air flow 7/6/05

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	962.23
Inlet Temperature (°F)	131.60	109.61	j Factor	0.0082
Outlet Temperature (°F)	127.37	111.50	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	129.48	110.5551	U Overall (BTU/hr·ft ² ·°F)	4.36
Skin Temperature (°F)	118.47	112.1747	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9074	LMTD	18.84
Reynold's Number	808**	19,265	Total Heat Transferred (BTU/hr)	70,636
Prandtl Number	0.7267	4.0193	Surface Effectiveness (Eta)	0.9194
Bulk Visc (lbm/ft·hr)	0.0481	1.4758	Sensible Heat Transferred (BTU/hr)	70,636
Skin Visc (lbm/ft·hr)	0.0000	1.4522	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0638	61.8521	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0159	0.3667		
Relative Humidity In (%)	19.46			
Relative Humidity Out (%)	21.79			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	952.85
Inlet Temperature (°F)	127.37	107.93	j Factor	0.0081
Outlet Temperature (°F)	123.64	109.61	Air-Side ho (BTU/hr·ft ² ·°F)	8.13
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	125.51	108.7689	U Overall (BTU/hr·ft ² ·°F)	4.35
Skin Temperature (°F)	115.76	110.2121	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9062	LMTD	16.66
Reynold's Number	812**	18,922	Total Heat Transferred (BTU/hr)	62,333
Prandtl Number	0.7270	4.0995	Surface Effectiveness (Eta)	0.9196
Bulk Visc (lbm/ft·hr)	0.0478	1.5026	Sensible Heat Transferred (BTU/hr)	62,333
Skin Visc (lbm/ft·hr)	0.0000	1.4809	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0642	61.8773	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0158	0.3661		
Relative Humidity In (%)	21.79			
Relative Humidity Out (%)	24.11			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 Att B
 Page 05

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	944.56
Inlet Temperature (°F)	123.64	106.45	j Factor	0.0081
Outlet Temperature (°F)	120.35	107.93	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	121.99	107.1924	U Overall (BTU/hr·ft ² ·°F)	4.34
Skin Temperature (°F)	113.38	108.4777	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9052	LMTD	14.73
Reynold's Number	816**	18,621	Total Heat Transferred (BTU/hr)	55,030
Prandtl Number	0.7273	4.1726	Surface Effectiveness (Eta)	0.9197
Bulk Visc (lbm/ft·hr)	0.0476	1.5269	Sensible Heat Transferred (BTU/hr)	55,030
Skin Visc (lbm/ft·hr)	0.0000	1.5070	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0645	61.8992	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0157	0.3655		
Relative Humidity In (%)	24.11			
Relative Humidity Out (%)	26.40			

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	937.22
Inlet Temperature (°F)	120.35	105.15	j Factor	0.0081
Outlet Temperature (°F)	117.44	106.45	Air-Side ho (BTU/hr·ft ² ·°F)	8.10
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	118.89	105.8003	U Overall (BTU/hr·ft ² ·°F)	4.34
Skin Temperature (°F)	111.27	106.9444	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9043	LMTD	13.03
Reynold's Number	819**	18,356	Total Heat Transferred (BTU/hr)	48,601
Prandtl Number	0.7275	4.2388	Surface Effectiveness (Eta)	0.9198
Bulk Visc (lbm/ft·hr)	0.0474	1.5489	Sensible Heat Transferred (BTU/hr)	48,601
Skin Visc (lbm/ft·hr)	0.0000	1.5308	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0649	61.9182	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0157	0.3650		
Relative Humidity In (%)	26.40			
Relative Humidity Out (%)	28.64			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
A + B
Page 36

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, Max FF, 5% Plug, reduction in air flow 7/6/05

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	66,793.22	37,264.79	Tube-Side hi (BTU/hr·ft ² ·°F)	930.72
Inlet Temperature (°F)	117.44	103.99	j Factor	0.0081
Outlet Temperature (°F)	114.87	105.15	Air-Side ho (BTU/hr·ft ² ·°F)	8.09
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.020268		Overall Fouling (hr·ft ² ·°F/BTU)	0.07593245
Average Temp (°F)	116.15	104.5707	U Overall (BTU/hr·ft ² ·°F)	4.33
Skin Temperature (°F)	109.41	105.5885	Effective Area (ft ²)	860.06
Velocity ***	3.359.98	2.9036	LMTD	11.53
Reynold's Number	822**	18,123	Total Heat Transferred (BTU/hr)	42,938
Prandtl Number	0.7277	4.2987	Surface Effectiveness (Eta)	0.9199
Bulk Visc (lbm/ft·hr)	0.0472	1.5688	Sensible Heat Transferred (BTU/hr)	42,938
Skin Visc (lbm/ft·hr)	0.0000	1.5523	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0651	61.9348	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3645		
Relative Humidity In (%)	28.64			
Relative Humidity Out (%)	30.79			

** Reynolds Number Outside Range of Equation Applicability

97-200 Rev A02
 Att B
 Page B7 of B7 Final

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

DESIGN ANALYSIS NO.: Calc. #97-200		PAGE NO. 1	
Major REV Number: A		Minor Rev Number: 01	
<input type="checkbox"/> BRAIDWOOD STATION <input type="checkbox"/> BYRON STATION <input type="checkbox"/> CLINTON STATION <input type="checkbox"/> DRESDEN STATION <input checked="" type="checkbox"/> LASALLE CO. STATION <input type="checkbox"/> QUAD CITIES STATION Unit: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3	DESCRIPTION CODE:(C018) <u> M10 </u> DISCIPLINE CODE: (C011) <u> M </u> SYSTEM CODE: (C011) <u> VY </u>		
TITLE: VY COOLER THERMAL PERFORMANCE MODEL – 1(2)VY01A and 1(2)VY02A			
<input checked="" type="checkbox"/> Safety Related		<input type="checkbox"/> Augmented Quality	
<input type="checkbox"/> Non-Safety Related			
ATTRIBUTES (C016)			
TYPE	VALUE	TYPE	VALUE
Elevation	694'		
Software	PROTO-HX		
COMPONENT EPN: (C014 Panel)		DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)	
EPN	TYPE	Type/Sub	Document Number Input (Y/N)
1VY01A	H15	DCD/ EVAL	EC#337494 Y
2VY01A	H15	/	
1VY02A	H15	/	
2VY02A	H15	/	
		/	
		/	
		/	
REMARKS:			

DESIGN ANALYSIS NO. 97-200

REV: A01 PAGE NO. 2

Revision Summary (including EC's incorporated): evaluated issues associated with 1) the impact of an error "flag" message on the printouts of Proto-Hx, which states that the Air Side Reynolds number is outside the range of equation applicability. 2) the "Data Report" output for the air coolers indicates a LOG (base 10) in the Fin Configuration equation for the Colburn 'j' factor, however the equation in the body of this calculation shows this as the natural log (Ln). The calc. has been evaluated to be acceptable as-is.

Electronic Calculation Data Files: Proto-Hx (This data is same as previous minor revision; no computer runs were performed for this minor revision)

(Program Name, Version, File Name extension/size/date/hour/min)

Design impact review completed? Yes N/A, Per EC#: 337494
(If yes, attach impact review sheet)

Prepared by: B. L. Davenport / [Signature] / 6-06-02
Print Sign Date

Reviewed by: D. J. Schmit / [Signature] / 6/10/02
Print Sign Date

Method of Review: Detailed Alternate Test

This Design Analysis supersedes: N/A in its entirety.

Supplemental Review Required? Yes No

Additional Review Special Review Team

Additional Reviewer or Special Review Team Leader: _____ / _____ / _____
Print Sign Date

Special Review Team: (N/A for Additional Review)

Reviewers: 1) _____ / _____ / _____ 2) _____ / _____ / _____
Print Sign Date Print Sign Date

3) _____ / _____ / _____ 4) _____ / _____ / _____
Print Sign Date Print Sign Date

Supplemental Review Results:

Approved by: [Signature] / [Signature] / 6/10/02
Print Sign Date

External Design Analysis Review (Attachment 3 Attached)

Reviewed by: _____ / _____ / _____
Print Sign Date

Approved by: _____ / _____ / _____
Print Sign Date

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? Yes No

Tracked By: AT#, EC# etc.)

Purpose/Objective

The purpose of this minor revision is to assess the following: 1) the impact of error "flag" message on the printouts of Proto-Hx, which states that the Air Side Reynolds number is outside the range of equation applicability. An example of this flag can be found on Attachment G, page 4. 2) the "Data Report" output for the air coolers (example Attachment G, page 2) indicates a LOG (base 10) in the Fin Configuration equation for the Colburn 'j' factor, however Equation 9 of this calculation shows this as the natural log (Ln).

Methodology and Acceptance Criteria

N/A, this is an assessment of the current calculation.

Assumptions / Engineering Judgments

Assumptions and engineering judgements are documented within this analysis.

Design Inputs

N/A, this minor revision utilizes those of the current calculation.

References

1. SEAG 02-000086 (copy attached)
2. Heat Transfer-Professional Version, Lindon C. Thomas, 2nd Ed., 1999.

Analysis

1) On page 13, the Colburn 'j' factor versus Reynolds Number (Re) relationship is given. This relationship was derived in this calculation to more closely match the manufacturer's heat transfer capability. The Colburn 'j' factor relationship is based on the information in Attachment D. This attachment shows the straight line relationship between the 'j' factor and Re number when plotted on a log-log scale, with Re number end points between 1000 and 8000. This relationship was used to derive Equation 9, which is input into the computer model with the two end points. Even though the calculated Re is less than 1000 in some cases (it is normally in the range of approx. 800 to 1000), the program still uses the Equation 9 relationship with the actual Re. The computer program in this case is flagging that it had to extrapolate past the 1000 end point it was given. Reference 2, page 553 shows this relationship to be linear down to a Re of 600 for a similar type of finned tube. Based on engineering judgement, it is therefore reasonable to extrapolate this line to a somewhat lower Re down to a Reynolds number of approximately 800. Thus the results of the calculations are acceptable.

2) Equation 9 in the body of the calculation, which indicates Ln, is correct and Ln is the function being used by the program. A check of the 'j' factor numbers indicated on the computer output in the calculation show that the program is using the natural log Ln. The program manufacturer, Proto-Power, was contacted on 4-03-02. They indicated that the LOG on the Data Report represents indefinite text output and they confirmed

that the program is indeed using the natural log (Ln) function for its calculations. (A ^(FINAL) letter/fax was obtained from Proto-Power on 4-03-02 confirming this discussion. The fax has been assigned file number SEAG 02-000086). A copy of this letter is attached (see Attachment A of this minor revision).

Summary and Conclusions

Based on the above discussion, the calculation results are acceptable as-is.



PROTO-POWER CORPORATION
A Utility Engineering Subsidiary

15 THAMES STREET
GRANTON, CT 06340
PH: 860.440.9725
FX: 860.440.8292
www.protopower.com

SEAG Number

02-000086

MEMORANDUM

File No. 908SOF/050119/M02001

To: Brian Davenport

From: Joseph G. Fayan

Date: April 3, 2002

Subject: PROTO-HX Air Coil Module

Brian,

The PROTO-HX Data Sheet Output Report for Air Coils shows the equation for "Configuration (for Air-Side h)" with the "LOG" term in the equation. This in fact represents the "Natural Log" and not "Log Base 10." The equation actually uses the Natural Log (LN) term, however, the output report is ambiguous in printing "LOG".

If you have any other questions, please feel free to give me a call.

Sorry for the confusion.

JGF:baj

CC: Joseph G. Fayan
Job File

LASALLE CALCULATION

EDITORIAL - COMMENT TO CALCULATION

Affecting

Calculation No.: 97-200

Rev:

ADD FOR REFERENCE

Page No. 1 of 1

The use of this form shall be limited to document corrections of editorial nature. Return to Sylvia Venecia

Prepared by:

Sylvia F. Venecia
Print

[Signature]
Sign

4/6/02

Date

Reviewed by:

Print

Sign

Date

Approved by:

Print

Sign

Date

Description of Correction:

1) Pages 3 thru 7, A1, B1 + C1 are on forms with the COMED logo which are not the most current forms.

Per J.T. Connor on 5/28/02 OK to Process. In the future the most current forms will be used.

When these comments are incorporated, return this form with the revised calculation.

Incorporated on Calc Rev.

By:

Date:

CC-AA-309 - ATTACHMENT 1 - Design Analysis Approval

Page 1 of 2

DESIGN ANALYSIS NO.: Calc. # 97-200		PAGE NO. 1	
Major REV Number: A		Minor Rev Number: 00	
<input type="checkbox"/> BRAIDWOOD STATION <input type="checkbox"/> BYRON STATION <input type="checkbox"/> CLINTON STATION <input type="checkbox"/> DRESDEN STATION <input checked="" type="checkbox"/> LASALLE CO. STATION <input type="checkbox"/> QUAD CITIES STATION	DESCRIPTION CODE: (C018) M010	<i>st</i>	
	DISCIPLINE CODE: (C011) M		
Unit: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3	SYSTEM CODE: (C011) VY		
TITLE: VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A			
<input checked="" type="checkbox"/> Safety Related <input type="checkbox"/> Augmented Quality <input type="checkbox"/> Non-Safety Related			
ATTRIBUTES (C016)			
TYPE	VALUE	TYPE	VALUE
Elevation	694'		
Software	Proto-HX		
COMPONENT EPN: (C014 Panel)		DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)	
EPN	TYPE	Type/Sub	Document Number
1VY01A	H15	<i>DED</i> EC/DCP	EC# 334017
2VY01A	H15	/	
1VY02A	H15	/	
2VY02A	H15	/	
		/	
		/	
		/	
REMARKS: NA			

DESIGN ANALYSIS NO. 97-200

REV: A00 PAGE NO. 2

Revision Summary (including EC's incorporated): Updated ProtoHX model for 104°F Service Water inlet temperature and calculated thermal margins with the design fouling factor and 5% tubes plugged for the Unit 1 and 2 A RHR Pump Room Coolers (1/2VY01A) and HPCS Pump Room Coolers (1/2VY02A).

Electronic Calculation Data Files: ProtoHX 3.02, vy-0102a.phx, 1152 KB, 11/02/2001, 2:14 am
(Program Name, Version, File Name extension/size/date/hour/min)

Design impact review completed? Yes N/A, Per EC#: 334017
(If yes, attach impact review sheet)

Prepared by: Jeff W. VanStrien / [Signature] / 1-3-7-02
- Print Sign Date

Reviewed by: Brian L. Davenport / [Signature] / 1-5-10-02
- Print Sign Date

Method of Review: Detailed Alternate Test

This Design Analysis supersedes: N/A in its entirety.

Supplemental Review Required? Yes No

Additional Review Special Review Team

Additional Reviewer or Special Review Team Leader: _____
- Print Sign Date

Special Review Team: (N/A for Additional Review)

Reviewers: 1) _____ 2) _____
- Print Sign Date Print Sign Date

3) _____ 4) _____
- Print Sign Date Print Sign Date

Supplemental Review Results:

Approved by: J.T. [Signature] / [Signature] / 1-5/24/02
- Print Sign Date

External Design Analysis Review (Attachment 3 Attached)

Reviewed by: _____ / _____ / _____
- Print Sign Date

Approved by: _____ / _____ / _____
- Print Sign Date

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? Yes No
Tracked By: AT#, EC# etc.) _____

CALCULATION TABLE OF CONTENTS

CALCULATION NO. 97-200		REV. NO. A00 PAGE NO. 3
SECTION:	PAGE NO.	SUB-PAGE NO.
DESIGN ANALYSIS APPROVAL / TITLE PAGE	1	
DESIGN ANALYSIS APPROVAL / REVISION SUMMARY	2	
TABLE OF CONTENTS	3	
1.0 PURPOSE / OBJECTIVE	4	
2.0 METHODOLOGY AND ACCEPTANCE CRITERIA	4	
3.0 ASSUMPTIONS / ENGINEERING JUDGEMENTS	4	
4.0 DESIGN INPUT	4	
5.0 REFERENCES	4	
6.0 CALCULATIONS	5	
7.0 SUMMARY AND CONCLUSIONS	7	
8.0 ATTACHMENTS:	7	
Attachment "A" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A (CSCS=104°F @ Design Fouling)	A1 to A17	
Attachment "B" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A (CSCS=104°F @ Design FF, 5% Plugged)	B1 to B17	
Attachment "C" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A (For VY01, CSCS=104°F @ Max. Allowable FF, w/ 5% plugged) (For VY02, CSCS=104°F @ Design FF, Room Temp. = 150°F)	C1 to C17	

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-200

REV. NO. A00

PAGE NO. 4 of 7

1.0 PURPOSE/OBJECTIVE

The purpose of this minor revision is to revise the thermal model of the A RHR Pump Room Coolers (1/2VY01A) and the HPCS Pump Room Coolers (1/2VY02A) using a 104°F Service Water inlet temperature. This assessment will evaluate the adequacy of these heat exchangers during a maximum allowable inlet service water temperature of 104°F. Also a maximum design fouling factor will be determined.

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

The existing heat exchanger model will be revised by changing the input of the "Tube Inlet Temp." from 100°F to 104°F and simulated for the following conditions: design fouling factor and design fouling factor with a 5% tube plugging allowance. The acceptance criteria will be for the thermal margin at each stated condition to exceed the LaSalle design heat load of 517,239 BTU/hr for 1/2VY01A and 646,235 BTU/hr for 1/2VY02A (Ref. 1, table 1). Additional conservatism was built into this acceptance criteria by assuming a 5% uncertainty in the Proto-HX heat transfer calculations. The original benchmark model developed for these heat exchangers demonstrated a correlation to vendor performance specification well within this assumed 5% margin.

A final case will be evaluated which determines the maximum acceptable fouling factor at which the design heat load can be accommodated including heat transfer model uncertainty and a 5% tube plugging allowance.

3.0 ASSUMPTIONS / ENGINEERING JUDGMENTS

The assumptions indicated in section 5.0 of Reference 1 are still valid.

4.0 DESIGN INPUTS

The design inputs consist of References 1 listed below.

5.0 REFERENCES

1. Calculation No. 97-200, Rev. A, "VY Cooler Thermal Performance Model – 1(2)VY01A and 1(2)VY02A."
2. Calculation No. L-002457, Rev. 4, "LaSalle County Station Ultimate Heat Sink Analysis".

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-200

REV. NO. A00

PAGE NO. 5 of 7

6.0 CALCULATIONS

The current calculation model is based on a Service Water inlet temperature of 100°F with a varying service water flow rates. Based on Reference 1 Calculations, the limiting flow rates, heat transfer rates, and thermal margins are as follows:

Table 1: At Limiting Flow rates, 100°F Service Water Inlet Temp. and Overall FF = 0.03976622 hr*ft²*°F/BTU (Ref. 1, table 9).

Cooler	Limiting Flow Rate (gpm)	Q _{required} (BTU/hr)	Q _{available} (BTU/hr)	Thermal Margin (%)
1(2)VY01A	75	517,239	675,177	30.5%
1(2)VY02A	108	646,235	707,030	9.4%

Thermal margin is calculated by the following method:

$$\text{Required Heat Load} - \text{Calculated Heat Transfer} = \text{Thermal Margin} \quad [\text{Equation 1}]$$

To express this as a percent of the required heat load, the following method is used:

$$\frac{\text{Thermal Margin}}{\text{Required Heat Load}} \times 100\% = \% \text{Thermal Margin} \quad [\text{Equation 2}]$$

When the Service Water inlet temperature is increased to 104°F for the same limiting flow rate, but with a design overall fouling factor of 0.02832467 hr*ft²*°F/BTU, the new thermal margins are shown in Table 2.

Table 2: At Limiting Flow rates, 104°F Service Water Inlet Temp. and Design Overall FF = 0.02832467 hr*ft²*°F/BTU [Attachment A].

Cooler	Limiting Flow Rate (gpm)	Q _{required} (BTU/hr)	Q _{available} (BTU/hr)	Thermal Margin (%)
1(2)VY01A	75	517,239	629,279	21.7%
1(2)VY02A	108	646,235	659,062	2.0%

E-FORM

CALCULATION PAGE

CALCULATION NO. 97-200

REV. NO. A00

PAGE NO. 6 of 7

Furthermore, if we consider the above conditions (in Table 2) and factor in a 5% tube plugging allowance the following Thermal Margins are calculated in Attachment B.

Table 3: At Limiting Flow rates, 104°F Service Water Inlet Temp., Design FF = 0.02832467 hr*ft²*°F/BTU and 5% plugged [Attachment B].

Cooler	Limiting Flow Rate (gpm)	Q _{required} (BTU/hr)	Q _{available} (BTU/hr)	Thermal Margin (%)
1(2)VY01A	75	517,239	625,070	20.8%
1(2)VY02A	108	646,235	653,739	1.2%

In addition, the maximum allowable Fouling Factors for each cooler, while maintaining at least a 5% thermal margin at 104°F inlet service water temperature with a 5% tube plugging allowance, are listed in Table 4.

Table 4: Maximum Allowable Fouling Factors at 104°F Service Water inlet temp. and 5% plugged. [Attachment C].

Cooler	Maximum Overall FF
1(2)VY01A	0.0949
1(2)VY02A	Note 1

Note 1: As demonstrated by the results in tables 2 and 3, air cooler 1(2)VY02A does not have analytical thermal margin in excess of the assumed 5% model uncertainty at the elevated inlet service water temperature of 104°F, room air temperature of 148°F and the design overall fouling factor of 0.02832467 hr*ft²*°F/BTU. However an additional Proto-HX run at a room air temperature of 150°F, service water inlet temperature of 104°F, no tubes plugged and the design overall fouling factor of 0.02832467 hr*ft²*°F/BTU demonstrated in excess of the 5% thermal margin needed to account for analytical uncertainty [Attachment C]. This is discussed further in the summary and conclusion section below.

CALCULATION PAGE**CALCULATION NO. 97-200****REV. NO. A00****PAGE NO. 7 of 7****7.0 SUMMARY AND CONCLUSIONS**

The A RHR Pump Room Coolers (1/2VY01A) and HPCS Pump Room Coolers (1/2VY02A) were found to have adequate thermal margin for a maximum lake temperature of 104°F when operated at design fouling conditions (the design overall fouling factor of 0.02832467 hr*ft²*°F/BTU). The maximum allowable overall fouling factor for the 1(2)VY01A coolers is 0.0949 hr*ft²*°F/BTU (includes an allowance for 5% of the tubes to be plugged).

For the 1(2)VY02A coolers the maximum allowable fouling factor is equal to the design overall fouling factor of 0.02832467 hr*ft²*°F/BTU (this does NOT include a 5% tube plugging allowance). It should be noted that the inlet air temperature was increased 2°F (from 148°F to 150°F) to achieve the desired thermal margin of 5%. A review of the EQ equipment in the room determined that all EQ components are qualified for temperature exceeding 150°F for the first 24 hours of the LOCA. The time at which the service water inlet temperature could experience 104°F is short term in nature and bounded by the 24-hour period specified above. The post LOCA peak service water temperature profile is documented within reference 2. Figure G7.1 within reference 2 demonstrates that the maximum post accident service water temperatures remain well below 100 °F except for a short period of time within the first day after the SCRAM occurs.

8.0 ATTACHMENTS:

Attachment "A" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(CSCS=104°F @ Design Fouling)

Attachment "B" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(CSCS=104°F @ Design FF, 5% Plugged)

Attachment "C" – Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(For VY01, CSCS=104°F @ Max. Allowable FF, w\ 5% plugged)
(For VY02, CSCS=104°F @ Design FF, Room Temp. = 150°F)

Final Page
(Last Page)

E-FORM

Attachment "A"

Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(CSCS=104°F @ Design Fouling)

E-FORM

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	

Tube Fluid Name	Fresh Water
Tube Fouling Factor	0.001500
Air-Side Fouling	0.000000

Design Heat Transfer (BTU/hr)	750,000
Atmospheric Pressure	14.315
Sensible Heat Ratio	1.00
Performance Factor (% Reduction)	0.000

Heat Exchanger Type	Counter Flow
Fin Type	Circular Fins
Fin Configuration	LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$

Coil Finned Length (in)	104.250
Fin Pitch (Fins/Inch)	10.000
Fin Conductivity (BTU/hr·ft·°F)	128.000
Fin Tip Thickness (inches)	0.0120
Fin Root Thickness (inches)	0.0120
Circular Fin Height (inches)	1.495

Number of Coils Per Unit	2
Number of Tube Rows	8
Number of Tubes Per Row	20.00
Active Tubes Per Row	20.00

Tube Inside Diameter (in)	0.5270
Tube Outside Diameter (in)	0.6250
Longitudinal Tube Pitch (in)	1.500
Transverse Tube Pitch (in)	1.452

Number of Serpentine	1.000
Tube Wall Conductivity (BTU/hr·ft·°F)	225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,120.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	
Inlet Temperature (°F)	148.00	104.00	j Factor	
Outlet Temperature (°F)	112.40	120.93	Air-Side ho (BTU/hr-ft ² -°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	629,279
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr)	629,279
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)				
K (BTU/hr-ft-°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	967.24
Inlet Temperature (°F)	148.00	117.56	j Factor	0.0082
Outlet Temperature (°F)	140.90	120.93	Air-Side ho (BTU/hr-ft ² -°F)	8.24
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	144.45	119.24	U Overall (BTU/hr-ft ² -°F)	5.55
Skin Temperature (°F)	125.98	121.97	Effective Area (ft ²)	905.33
Velocity ***	3,376.53	2.77	LMTD	25.01
Reynold's Number	796**	19,916	Total Heat Transferred (BTU/hr)	125,565
Prandtl Number	0.7254	3.6630	Surface Effectiveness (Eta)	0.9186
Bulk Visc (lbm/ft-hr)	0.0490	1.3561	Sensible Heat Transferred (BTU/hr)	125,565
Skin Visc (lbm/ft-hr)		1.3218	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0623	61.7233	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0162	0.3698		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment A
 Page No. A4 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	951.58
Inlet Temperature (°F)	140.90	114.66	j Factor	0.0082
Outlet Temperature (°F)	134.79	117.56	Air-Side ho (BTU/hr·ft ² ·°F)	8.21
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	137.84	116.11		
Skin Temperature (°F)	121.93	118.49	U Overall (BTU/hr·ft ² ·°F)	5.52
Velocity ***	3,376.53	2.77	Effective Area (ft ²)	905.33
Reynold's Number	803**	19,327	LMTD	21.57
Prandtl Number	0.7260	3.7855	Total Heat Transferred (BTU/hr)	107,856
Bulk Visc (lbm/ft·hr)	0.0486	1.3974		
Skin Visc (lbm/ft·hr)		1.3658	Surface Effectiveness (Eta)	0.9189
Density (lbm/ft ³)	0.0630	61.7710	Sensible Heat Transferred (BTU/hr)	107,856
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0161	0.3687	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	938.05
Inlet Temperature (°F)	134.79	112.17	j Factor	0.0082
Outlet Temperature (°F)	129.55	114.66	Air-Side ho (BTU/hr·ft ² ·°F)	8.18
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	132.17	113.41		
Skin Temperature (°F)	118.45	115.49	U Overall (BTU/hr·ft ² ·°F)	5.50
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	809**	18,827	LMTD	18.61
Prandtl Number	0.7265	3.8961	Total Heat Transferred (BTU/hr)	92,745
Bulk Visc (lbm/ft·hr)	0.0483	1.4346		
Skin Visc (lbm/ft·hr)		1.4057	Surface Effectiveness (Eta)	0.9191
Density (lbm/ft ³)	0.0635	61.8109	Sensible Heat Transferred (BTU/hr)	92,745
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0160	0.3678	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment APage No. A5 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	926.37
Inlet Temperature (°F)	129.55	110.02	j Factor	0.0081
Outlet Temperature (°F)	125.03	112.17	Air-Side ho (BTU/hr·ft ² ·°F)	8.16
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	127.29	111.09		
Skin Temperature (°F)	115.45	112.90	U Overall (BTU/hr·ft ² ·°F)	5.49
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	814**	18,399	LMTD	16.07
Prandtl Number	0.7269	3.9956	Total Heat Transferred (BTU/hr)	79,826
Bulk Visc (lbm/ft·hr)	0.0479	1.4679		
Skin Visc (lbm/ft·hr)		1.4417	Surface Effectiveness (Eta)	0.9193
Density (lbm/ft ³)	0.0640	61.8445	Sensible Heat Transferred (BTU/hr)	79,826
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3669	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	916.28
Inlet Temperature (°F)	125.03	108.17	j Factor	0.0081
Outlet Temperature (°F)	121.14	110.02	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	123.08	109.10		
Skin Temperature (°F)	112.87	110.67	U Overall (BTU/hr·ft ² ·°F)	5.47
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	818**	18,034	LMTD	13.88
Prandtl Number	0.7272	4.0846	Total Heat Transferred (BTU/hr)	68,762
Bulk Visc (lbm/ft·hr)	0.0477	1.4976		
Skin Visc (lbm/ft·hr)		1.4740	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0644	61.8727	Sensible Heat Transferred (BTU/hr)	68,762
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3662	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment A
 Page No. A6 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	907.56
Inlet Temperature (°F)	121.14	106.58	j Factor	0.0081
Outlet Temperature (°F)	117.79	108.17	Air-Side ho (BTU/hr-ft ² -°F)	8.13
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	119.46	107.38		
Skin Temperature (°F)	110.64	108.75	U Overall (BTU/hr-ft ² -°F)	5.46
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	822**	17,722	LMTD	11.99
Prandtl Number	0.7274	4.1639	Total Heat Transferred (BTU/hr)	59,274
Bulk Visc (lbm/ft·hr)	0.0474	1.5240		
Skin Visc (lbm/ft·hr)		1.5028	Surface Effectiveness (Eta)	0.9196
Density (lbm/ft ³)	0.0648	61.8966	Sensible Heat Transferred (BTU/hr)	59,274
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	900.01
Inlet Temperature (°F)	117.79	105.21	j Factor	0.0081
Outlet Temperature (°F)	114.89	106.58	Air-Side ho (BTU/hr-ft ² -°F)	8.12
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	116.34	105.89		
Skin Temperature (°F)	108.72	107.09	U Overall (BTU/hr-ft ² -°F)	5.45
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	826**	17,454	LMTD	10.37
Prandtl Number	0.7276	4.2343	Total Heat Transferred (BTU/hr)	51,127
Bulk Visc (lbm/ft·hr)	0.0473	1.5474		
Skin Visc (lbm/ft·hr)		1.5285	Surface Effectiveness (Eta)	0.9197
Density (lbm/ft ³)	0.0651	61.9169	Sensible Heat Transferred (BTU/hr)	51,127
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0156	0.3650	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment A
 Page No. A1 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,654.85	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	893.49
Inlet Temperature (°F)	114.89	104.02	j Factor	0.0081
Outlet Temperature (°F)	112.40	105.21	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	113.64	104.61		
Skin Temperature (°F)	107.06	105.65	U Overall (BTU/hr·ft ² ·°F)	5.44
Velocity ***	3,376.53	2.76	Effective Area (ft ²)	905.33
Reynold's Number	829**	17,224	LMTD	8.96
Prandtl Number	0.7278	4.2966	Total Heat Transferred (BTU/hr)	44,124
Bulk Visc (lbm/ft·hr)	0.0471	1.5680		
Skin Visc (lbm/ft·hr)		1.5513	Surface Effectiveness (Eta)	0.9198
Density (lbm/ft ³)	0.0654	61.9342	Sensible Heat Transferred (BTU/hr)	44,124
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3646	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment APage No. A7 of A17

Inlet Air Flowrate Calculator - 1(2)VY01A

Total P:	P=	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T=	112.4 F	19120 acfm
Specific Hum.:	W =	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0654 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T=	148 F	
Outlet Air Flow:	V =	18000 cfm	

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ 104 F, DESIGN FF

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,173.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)
Inlet Temperature (°F)	148.00	104.00	j Factor
Outlet Temperature (°F)	110.81	116.29	Air-Side ho (BTU/hr-ft ² -°F)
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU) 0.02832467
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 659,062
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr) 659,062
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)			
K (BTU/hr-ft-°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F) 1,266.21
Inlet Temperature (°F)	148.00	113.53	j Factor 0.0082
Outlet Temperature (°F)	139.65	116.29	Air-Side ho (BTU/hr-ft ² -°F) 8.25
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU) 0.02832467
Average Temp (°F)	143.82	114.91	U Overall (BTU/hr-ft ² -°F) 5.70
Skin Temperature (°F)	122.08	117.36	Effective Area (ft ²) 905.33
Velocity ***	3,385.89	3.98	LMTD 28.70
Reynold's Number	799**	27,510	Total Heat Transferred (BTU/hr) 148,029
Prandtl Number	0.7255	3.8340	Surface Effectiveness (Eta) 0.9185
Bulk Visc (lbm/ft-hr)	0.0490	1.4137	Sensible Heat Transferred (BTU/hr) 148,029
Skin Visc (lbm/ft-hr)		1.3806	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0624	61.7889	Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)	0.2402	0.9988	
K (BTU/hr-ft-°F)	0.0162	0.3683	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment APage No. 12 of 17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,249.06
Inlet Temperature (°F)	139.65	111.26	j Factor	0.0082
Outlet Temperature (°F)	132.79	113.53	Air-Side ho (BTU/hr-ft ² -°F)	8.22
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	136.22	112.39		
Skin Temperature (°F)	118.31	114.44	U Overall (BTU/hr-ft ² -°F)	5.67
Velocity ***	3,385.89	3.98	Effective Area (ft ²)	905.33
Reynold's Number	807**	26,839	LMTD	23.65
Prandtl Number	0.7262	3.9393	Total Heat Transferred (BTU/hr)	121,509
Bulk Visc (lbm/ft·hr)	0.0485	1.4490		
Skin Visc (lbm/ft·hr)		1.4202	Surface Effectiveness (Eta)	0.9188
Density (lbm/ft ³)	0.0632	61.8258	Sensible Heat Transferred (BTU/hr)	121,509
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0160	0.3674	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,234.94
Inlet Temperature (°F)	132.79	109.40	j Factor	0.0081
Outlet Temperature (°F)	127.16	111.26	Air-Side ho (BTU/hr-ft ² -°F)	8.19
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	129.97	110.33		
Skin Temperature (°F)	115.21	112.03	U Overall (BTU/hr-ft ² -°F)	5.66
Velocity ***	3,385.89	3.98	Effective Area (ft ²)	905.33
Reynold's Number	813**	26,293	LMTD	19.50
Prandtl Number	0.7267	4.0293	Total Heat Transferred (BTU/hr)	99,875
Bulk Visc (lbm/ft·hr)	0.0481	1.4791		
Skin Visc (lbm/ft·hr)		1.4543	Surface Effectiveness (Eta)	0.9190
Density (lbm/ft ³)	0.0638	61.8554	Sensible Heat Transferred (BTU/hr)	99,875
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0159	0.3667	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment APage No. A13 of A17*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,223.28
Inlet Temperature (°F)	127.16	107.86	j Factor	0.0081
Outlet Temperature (°F)	122.52	109.40	Air-Side ho (BTU/hr·ft ² ·°F)	8.17
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	124.84	108.63		
Skin Temperature (°F)	112.66	110.04	U Overall (BTU/hr·ft ² ·°F)	5.64
Velocity ***	3,385.89	3.98	Effective Area (ft ²)	905.33
Reynold's Number	819**	25,847	LMTD	16.09
Prandtl Number	0.7271	4.1059	Total Heat Transferred (BTU/hr)	82,183
Bulk Visc (lbm/ft·hr)	0.0478	1.5047		
Skin Visc (lbm/ft·hr)		1.4834	Surface Effectiveness (Eta)	0.9192
Density (lbm/ft ³)	0.0643	61.8793	Sensible Heat Transferred (BTU/hr)	82,183
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3660	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,213.65
Inlet Temperature (°F)	122.52	106.60	j Factor	0.0081
Outlet Temperature (°F)	118.70	107.86	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	120.61	107.23		
Skin Temperature (°F)	110.56	108.40	U Overall (BTU/hr·ft ² ·°F)	5.63
Velocity ***	3,385.89	3.97	Effective Area (ft ²)	905.33
Reynold's Number	823**	25,481	LMTD	13.28
Prandtl Number	0.7274	4.1707	Total Heat Transferred (BTU/hr)	67,688
Bulk Visc (lbm/ft·hr)	0.0475	1.5263		
Skin Visc (lbm/ft·hr)		1.5081	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0647	61.8987	Sensible Heat Transferred (BTU/hr)	67,688
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3655	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment APage No. A14 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,205.71
Inlet Temperature (°F)	118.70	105.56	j Factor	0.0081
Outlet Temperature (°F)	115.55	106.60	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	117.13	106.08	U Overall (BTU/hr·ft ² ·°F)	5.62
Skin Temperature (°F)	108.83	107.05	Effective Area (ft ²)	905.33
Velocity ***	3,385.89	3.97	LMTD	10.97
Reynold's Number	827**	25,182	Total Heat Transferred (BTU/hr)	55,792
Prandtl Number	0.7276	4.2254	Surface Effectiveness (Eta)	0.9195
Bulk Visc (lbm/ft·hr)	0.0473	1.5444	Sensible Heat Transferred (BTU/hr)	55,792
Skin Visc (lbm/ft·hr)		1.5291	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0651	61.9144	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3651		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,199.14
Inlet Temperature (°F)	115.55	104.70	j Factor	0.0081
Outlet Temperature (°F)	112.96	105.56	Air-Side ho (BTU/hr·ft ² ·°F)	8.12
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	114.26	105.13	U Overall (BTU/hr·ft ² ·°F)	5.61
Skin Temperature (°F)	107.40	105.94	Effective Area (ft ²)	905.33
Velocity ***	3,385.89	3.97	LMTD	9.06
Reynold's Number	830**	24,935	Total Heat Transferred (BTU/hr)	46,015
Prandtl Number	0.7278	4.2713	Surface Effectiveness (Eta)	0.9196
Bulk Visc (lbm/ft·hr)	0.0471	1.5597	Sensible Heat Transferred (BTU/hr)	46,015
Skin Visc (lbm/ft·hr)		1.5467	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0654	61.9273	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0156	0.3647		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment A
 Page No. A15 of A17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,850.70	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,193.72
Inlet Temperature (°F)	112.96	103.99	j Factor	0.0081
Outlet Temperature (°F)	110.81	104.70	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	111.89	104.35		
Skin Temperature (°F)	106.22	105.01	U Overall (BTU/hr·ft ² ·°F)	5.60
Velocity ***	3,385.89	3.97	Effective Area (ft ²)	905.33
Reynold's Number	833**	24,733	LMTD	7.49
Prandtl Number	0.7279	4.3099	Total Heat Transferred (BTU/hr)	37,972
Bulk Visc (lbm/ft·hr)	0.0470	1.5725		
Skin Visc (lbm/ft·hr)		1.5615	Surface Effectiveness (Eta)	0.9197
Density (lbm/ft ³)	0.0656	61.9378	Sensible Heat Transferred (BTU/hr)	37,972
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3644	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment A
Page No. A16 of A17

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

Inlet Air Flowrate Calculator - 1(2)VY02A

Total P:	P=	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T=	110.81 F	19173 acfm
Specific Hum.:	W =	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0656 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T=	148 F	
Outlet Air Flow:	V =	18000 cfm	

Attachment "B"

Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(CSCS=104°F @ Design FF, 5% Plugged)

E-FORM

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF, 5% PLUG

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF, 5% PLUG

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,113.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	
Inlet Temperature (°F)	148.00	104.00	j Factor	
Outlet Temperature (°F)	112.62	120.76	Air-Side ho (BTU/hr-ft ² -°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)	
Skin Temperature (°F)			Effective Area (ft ²)	6,880.52
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	625,070
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr)	625,070
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)				
K (BTU/hr-ft-°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	1,007.00
Inlet Temperature (°F)	148.00	117.44	j Factor	0.0081
Outlet Temperature (°F)	141.01	120.76	Air-Side ho (BTU/hr-ft ² -°F)	8.52
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	144.50	119.10	U Overall (BTU/hr-ft ² -°F)	5.70
Skin Temperature (°F)	125.96	121.81	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.91	LMTD	25.22
Reynold's Number	838**	20,935	Total Heat Transferred (BTU/hr)	123,549
Prandtl Number	0.7254	3.6685	Surface Effectiveness (Eta)	0.9162
Bulk Visc (lbm/ft-hr)	0.0490	1.3580	Sensible Heat Transferred (BTU/hr)	123,549
Skin Visc (lbm/ft-hr)		1.3238	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0623	61.7256	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0162	0.3697		

** Reynolds Number Outside Range of Equation Applicability

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 2(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	990.92
Inlet Temperature (°F)	141.01	114.58	j Factor	0.0080
Outlet Temperature (°F)	134.98	117.44	Air-Side ho (BTU/hr-ft ² -°F)	8.49
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	137.99	116.01	U Overall (BTU/hr-ft ² -°F)	5.67
Skin Temperature (°F)	121.96	118.38	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.91	LMTD	21.82
Reynold's Number	845**	20,325	Total Heat Transferred (BTU/hr)	106,500
Prandtl Number	0.7260	3.7895	Surface Effectiveness (Eta)	0.9164
Bulk Visc (lbm/ft-hr)	0.0486	1.3987	Sensible Heat Transferred (BTU/hr)	106,500
Skin Visc (lbm/ft-hr)		1.3672	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0629	61.7725	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0161	0.3687		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	976.99
Inlet Temperature (°F)	134.98	112.11	j Factor	0.0080
Outlet Temperature (°F)	129.78	114.58	Air-Side ho (BTU/hr-ft ² -°F)	8.46
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	132.38	113.34	U Overall (BTU/hr-ft ² -°F)	5.65
Skin Temperature (°F)	118.50	115.42	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.91	LMTD	18.90
Reynold's Number	851**	19,804	Total Heat Transferred (BTU/hr)	91,897
Prandtl Number	0.7265	3.8991	Surface Effectiveness (Eta)	0.9166
Bulk Visc (lbm/ft-hr)	0.0483	1.4355	Sensible Heat Transferred (BTU/hr)	91,897
Skin Visc (lbm/ft-hr)		1.4067	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0635	61.8119	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0160	0.3677		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment 3
 Page No. 85 of 817

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 4(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	964.92
Inlet Temperature (°F)	129.78	109.98	j Factor	0.0080
Outlet Temperature (°F)	125.29	112.11	Air-Side ho (BTU/hr-ft ² -°F)	8.44
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	127.53	111.04	U Overall (BTU/hr-ft ² -°F)	5.64
Skin Temperature (°F)	115.52	112.86	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.91	LMTD	16.37
Reynold's Number	856**	19,358	Total Heat Transferred (BTU/hr)	79,368
Prandtl Number	0.7269	3.9979	Surface Effectiveness (Eta)	0.9168
Bulk Visc (lbm/ft-hr)	0.0480	1.4686	Sensible Heat Transferred (BTU/hr)	79,368
Skin Visc (lbm/ft-hr)		1.4424	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0640	61.8452	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0159	0.3669		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	954.45
Inlet Temperature (°F)	125.29	108.13	j Factor	0.0080
Outlet Temperature (°F)	121.40	109.98	Air-Side ho (BTU/hr-ft ² -°F)	8.42
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	123.34	109.05	U Overall (BTU/hr-ft ² -°F)	5.62
Skin Temperature (°F)	112.94	110.64	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.91	LMTD	14.19
Reynold's Number	861**	18,975	Total Heat Transferred (BTU/hr)	68,601
Prandtl Number	0.7272	4.0866	Surface Effectiveness (Eta)	0.9170
Bulk Visc (lbm/ft-hr)	0.0477	1.4982	Sensible Heat Transferred (BTU/hr)	68,601
Skin Visc (lbm/ft-hr)		1.4745	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0644	61.8733	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0158	0.3662		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment BPage No. 36 of 81*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	945.37
Inlet Temperature (°F)	121.40	106.54	j Factor	0.0080
Outlet Temperature (°F)	118.05	108.13	Air-Side ho (BTU/hr·ft ² ·°F)	8.41
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	119.72	107.33		
Skin Temperature (°F)	110.71	108.72	U Overall (BTU/hr·ft ² ·°F)	5.61
Velocity ***	3,552.94	2.91	Effective Area (ft ²)	860.06
Reynold's Number	865**	18,646	LMTD	12.30
Prandtl Number	0.7274	4.1659	Total Heat Transferred (BTU/hr)	59,336
Bulk Visc (lbm/ft·hr)	0.0475	1.5246		
Skin Visc (lbm/ft·hr)		1.5033	Surface Effectiveness (Eta)	0.9171
Density (lbm/ft ³)	0.0648	61.8972	Sensible Heat Transferred (BTU/hr)	59,336
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	937.50
Inlet Temperature (°F)	118.05	105.16	j Factor	0.0080
Outlet Temperature (°F)	115.14	106.54	Air-Side ho (BTU/hr·ft ² ·°F)	8.39
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	116.59	105.85		
Skin Temperature (°F)	108.78	107.06	U Overall (BTU/hr·ft ² ·°F)	5.60
Velocity ***	3,552.94	2.90	Effective Area (ft ²)	860.06
Reynold's Number	869**	18,364	LMTD	10.67
Prandtl Number	0.7276	4.2365	Total Heat Transferred (BTU/hr)	51,352
Bulk Visc (lbm/ft·hr)	0.0473	1.5481		
Skin Visc (lbm/ft·hr)		1.5290	Surface Effectiveness (Eta)	0.9172
Density (lbm/ft ³)	0.0651	61.9176	Sensible Heat Transferred (BTU/hr)	51,352
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3650	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment 8 Page No. 81 of 817

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,628.98	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	930.67
Inlet Temperature (°F)	115.14	103.96	j Factor	0.0079
Outlet Temperature (°F)	112.62	105.16	Air-Side ho (BTU/hr·ft ² ·°F)	8.38
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	113.88	104.56	U Overall (BTU/hr·ft ² ·°F)	5.59
Skin Temperature (°F)	107.11	105.62	Effective Area (ft ²)	860.06
Velocity ***	3,552.94	2.90	LMTD	9.25
Reynold's Number	872**	18,120	Total Heat Transferred (BTU/hr)	44,466
Prandtl Number	0.7278	4.2992	Surface Effectiveness (Eta)	0.9173
Bulk Visc (lbm/ft·hr)	0.0471	1.5689	Sensible Heat Transferred (BTU/hr)	44,466
Skin Visc (lbm/ft·hr)		1.5518	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0654	61.9349	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0155	0.3645		

** Reynolds Number Outside Range of Equation Applicability

Inlet Air Flowrate Calculator - 1(2)VY01A

Total P:	P=	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T=	112.62 F	19113 acfm
Specific Hum.:	W=	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0654 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T=	148 F	
Outlet Air Flow:	V=	18000 cfm	

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ 104 F, DESIGN FF, 5% PLUG

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ 104 F, DESIGN FF, 5% PLUG

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,164.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation Summary
--

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	
Inlet Temperature (°F)	148.00	104.00	j Factor	
Outlet Temperature (°F)	111.10	116.20	Air-Side ho (BTU/hr-ft ² -°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)	
Skin Temperature (°F)			Effective Area (ft ²)	6,880.52
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	653,739
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr)	653,739
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)				
K (BTU/hr-ft-°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,318.81
Inlet Temperature (°F)	148.00	113.50	j Factor	0.0080
Outlet Temperature (°F)	139.81	116.20	Air-Side ho (BTU/hr-ft ² -°F)	8.53
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	143.90	114.85	U Overall (BTU/hr-ft ² -°F)	5.85
Skin Temperature (°F)	122.15	117.28	Effective Area (ft ²)	860.06
Velocity ***	3,562.42	4.19	LMTD	28.85
Reynold's Number	841**	28,941	Total Heat Transferred (BTU/hr)	145,141
Prandtl Number	0.7255	3.8364	Surface Effectiveness (Eta)	0.9161
Bulk Visc (lbm/ft-hr)	0.0490	1.4145	Sensible Heat Transferred (BTU/hr)	145,141
Skin Visc (lbm/ft-hr)		1.3817	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.7897	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0162	0.3683		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment β
Page No. 012 of 012

*** Air Mass Velocity (Lbm/hr-ft²). Tube Fluid Velocity (ft/sec); Air Density at Inlet T. Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,301.27
Inlet Temperature (°F)	139.81	111.26	j Factor	0.0080
Outlet Temperature (°F)	133.05	113.50	Air-Side ho (BTU/hr·ft ² ·°F)	8.50
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	136.43	112.38		
Skin Temperature (°F)	118.43	114.41	U Overall (BTU/hr·ft ² ·°F)	5.83
Velocity ***	3,562.42	4.19	Effective Area (ft ²)	860.06
Reynold's Number	849**	28,248	LMTD	23.88
Prandtl Number	0.7262	3.9400	Total Heat Transferred (BTU/hr)	119,696
Bulk Visc (lbm/ft·hr)	0.0485	1.4493		
Skin Visc (lbm/ft·hr)		1.4206	Surface Effectiveness (Eta)	0.9163
Density (lbm/ft ³)	0.0631	61.8260	Sensible Heat Transferred (BTU/hr)	119,696
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0161	0.3674	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,286.74
Inlet Temperature (°F)	133.05	109.42	j Factor	0.0080
Outlet Temperature (°F)	127.47	111.26	Air-Side ho (BTU/hr·ft ² ·°F)	8.47
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	130.26	110.34		
Skin Temperature (°F)	115.35	112.04	U Overall (BTU/hr·ft ² ·°F)	5.81
Velocity ***	3,562.42	4.19	Effective Area (ft ²)	860.06
Reynold's Number	855**	27,680	LMTD	19.78
Prandtl Number	0.7267	4.0288	Total Heat Transferred (BTU/hr)	98,838
Bulk Visc (lbm/ft·hr)	0.0481	1.4790		
Skin Visc (lbm/ft·hr)		1.4541	Surface Effectiveness (Eta)	0.9166
Density (lbm/ft ³)	0.0637	61.8552	Sensible Heat Transferred (BTU/hr)	98,838
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0159	0.3667	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment 8
Page No. 813 of 817

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,274.71
Inlet Temperature (°F)	127.47	107.89	j Factor	0.0080
Outlet Temperature (°F)	122.86	109.42	Air-Side ho (BTU/hr-ft ² -°F)	8.45
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	125.17	108.65		
Skin Temperature (°F)	112.81	110.07	U Overall (BTU/hr-ft ² -°F)	5.79
Velocity ***	3,562.42	4.18	Effective Area (ft ²)	860.06
Reynold's Number	861**	27,214	LMTD	16.40
Prandtl Number	0.7270	4.1047	Total Heat Transferred (BTU/hr)	81,701
Bulk Visc (lbm/ft·hr)	0.0478	1.5043		
Skin Visc (lbm/ft·hr)		1.4829	Surface Effectiveness (Eta)	0.9168
Density (lbm/ft ³)	0.0642	61.8789	Sensible Heat Transferred (BTU/hr)	81,701
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0158	0.3661	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,264.72
Inlet Temperature (°F)	122.86	106.63	j Factor	0.0080
Outlet Temperature (°F)	119.04	107.89	Air-Side ho (BTU/hr-ft ² -°F)	8.43
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	120.95	107.26		
Skin Temperature (°F)	110.71	108.44	U Overall (BTU/hr-ft ² -°F)	5.78
Velocity ***	3,562.42	4.18	Effective Area (ft ²)	860.06
Reynold's Number	866**	26,831	LMTD	13.59
Prandtl Number	0.7273	4.1693	Total Heat Transferred (BTU/hr)	67,596
Bulk Visc (lbm/ft·hr)	0.0475	1.5258		
Skin Visc (lbm/ft·hr)		1.5075	Surface Effectiveness (Eta)	0.9169
Density (lbm/ft ³)	0.0647	61.8982	Sensible Heat Transferred (BTU/hr)	67,596
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0157	0.3655	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment B
 Page No. B14 of B17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,256.44
Inlet Temperature (°F)	119.04	105.59	j Factor	0.0080
Outlet Temperature (°F)	115.88	106.63	Air-Side ho (BTU/hr-ft ² -°F)	8.41
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	117.46	106.11		
Skin Temperature (°F)	108.97	107.09	U Overall (BTU/hr-ft ² -°F)	5.77
Velocity ***	3,562.42	4.18	Effective Area (ft ²)	860.06
Reynold's Number	870**	26,515	LMTD	11.28
Prandtl Number	0.7276	4.2239	Total Heat Transferred (BTU/hr)	55,967
Bulk Visc (lbm/ft-hr)	0.0473	1.5440		
Skin Visc (lbm/ft-hr)		1.5284	Surface Effectiveness (Eta)	0.9171
Density (lbm/ft ³)	0.0650	61.9140	Sensible Heat Transferred (BTU/hr)	55,967
Cp (BTU/lbm-°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0156	0.3651	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,249.57
Inlet Temperature (°F)	115.88	104.72	j Factor	0.0079
Outlet Temperature (°F)	113.27	105.59	Air-Side ho (BTU/hr-ft ² -°F)	8.40
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	114.58	105.15		
Skin Temperature (°F)	107.53	105.97	U Overall (BTU/hr-ft ² -°F)	5.76
Velocity ***	3,562.42	4.18	Effective Area (ft ²)	860.06
Reynold's Number	873**	26,255	LMTD	9.36
Prandtl Number	0.7278	4.2701	Total Heat Transferred (BTU/hr)	46,367
Bulk Visc (lbm/ft-hr)	0.0471	1.5593		
Skin Visc (lbm/ft-hr)		1.5461	Surface Effectiveness (Eta)	0.9172
Density (lbm/ft ³)	0.0653	61.9269	Sensible Heat Transferred (BTU/hr)	46,367
Cp (BTU/lbm-°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0156	0.3648	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment BPage No. B15 of B12*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ 104 F, DESIGN FF, 5% PLUG

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,817.44	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,243.87
Inlet Temperature (°F)	113.27	104.01	j Factor	0.0079
Outlet Temperature (°F)	111.10	104.72	Air-Side ho (BTU/hr·ft ² ·°F)	8.39
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	112.18	104.36		
Skin Temperature (°F)	106.34	105.05	U Overall (BTU/hr·ft ² ·°F)	5.75
Velocity ***	3,562.42	4.18	Effective Area (ft ²)	860.06
Reynold's Number	876**	26,039	LMTD	7.76
Prandtl Number	0.7279	4.3090	Total Heat Transferred (BTU/hr)	38,433
Bulk Visc (lbm/ft·hr)	0.0470	1.5722		
Skin Visc (lbm/ft·hr)		1.5610	Surface Effectiveness (Eta)	0.9173
Density (lbm/ft ³)	0.0656	61.9375	Sensible Heat Transferred (BTU/hr)	38,433
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3645	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Inlet Air Flowrate Calculator - 1(2)VY02A

Total P:	P =	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T =	111.1 F	19164 acfm
Specific Hum.:	W =	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0656 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T =	148 F	
Outlet Air Flow:	V =	18000 cfm	

Attachment "C"

Proto-Hx Calc. Report for 1(2)VY01A & 1(2)VY02A
(For VY01, CSCS=104°F @ Max. Allowable FF, w\ 5% plugged)
(For VY02, CSCS=104°F @ Design FF, Room Temp. = 150°F)

E-FORM

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ MAX FF, w\ 5% PLUG

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.005000
Air-Side Fouling		0.000500
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		19.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ MAX FF, w\ 5% PLUG

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	18,982.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ MAX FF, w\ 5% PLUG

Extrapolation Calculation Summary
--

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	104.00	j Factor	
Outlet Temperature (°F)	116.55	118.87	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.09491556
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	6,880.52
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	551,834
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	551,834
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	998.47
Inlet Temperature (°F)	148.00	116.24	j Factor	0.0081
Outlet Temperature (°F)	142.44	118.87	Air-Side ho (BTU/hr·ft ² ·°F)	8.48
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.09491556
Average Temp (°F)	145.22	117.56	U Overall (BTU/hr·ft ² ·°F)	4.12
Skin Temperature (°F)	130.56	119.71	Effective Area (ft ²)	860.06
Velocity ***	3,528.59	2.91	LMTD	27.55
Reynold's Number	831**	20,630	Total Heat Transferred (BTU/hr)	97,604
Prandtl Number	0.7254	3.7281	Surface Effectiveness (Eta)	0.9165
Bulk Visc (lbm/ft·hr)	0.0491	1.3780	Sensible Heat Transferred (BTU/hr)	97,604
Skin Visc (lbm/ft·hr)		1.3501	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0622	61.7492	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3692		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment c
Page No. c4 of c17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ MAX FF, w\ 5% PLUG

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	985.60
Inlet Temperature (°F)	142.44	113.89	j Factor	0.0081
Outlet Temperature (°F)	137.45	116.24	Air-Side ho (BTU/hr-ft ² -°F)	8.46
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.09491556
Average Temp (°F)	139.94	115.07	U Overall (BTU/hr-ft ² -°F)	4.11
Skin Temperature (°F)	126.76	117.03	Effective Area (ft ²)	860.06
Velocity ***	3,528.59	2.91	LMTD	24.78
Reynold's Number	837**	20,141	Total Heat Transferred (BTU/hr)	87,561
Prandtl Number	0.7259	3.8275	Surface Effectiveness (Eta)	0.9167
Bulk Visc (lbm/ft-hr)	0.0487	1.4115	Sensible Heat Transferred (BTU/hr)	87,561
Skin Visc (lbm/ft-hr)		1.3851	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0627	61.7865	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0161	0.3683		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	974.02
Inlet Temperature (°F)	137.45	111.78	j Factor	0.0080
Outlet Temperature (°F)	132.97	113.89	Air-Side ho (BTU/hr-ft ² -°F)	8.44
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.09491556
Average Temp (°F)	135.21	112.84	U Overall (BTU/hr-ft ² -°F)	4.10
Skin Temperature (°F)	123.35	114.61	Effective Area (ft ²)	860.06
Velocity ***	3,528.59	2.91	LMTD	22.28
Reynold's Number	842**	19,705	Total Heat Transferred (BTU/hr)	78,587
Prandtl Number	0.7263	3.9205	Surface Effectiveness (Eta)	0.9169
Bulk Visc (lbm/ft-hr)	0.0484	1.4427	Sensible Heat Transferred (BTU/hr)	78,587
Skin Visc (lbm/ft-hr)		1.4178	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0632	61.8193	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9988		
K (BTU/hr-ft-°F)	0.0160	0.3676		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment C
Page No. CS of C17

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ MAX FF, w\ 5% PLUG

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	963.58
Inlet Temperature (°F)	132.97	109.88	j Factor	0.0080
Outlet Temperature (°F)	128.95	111.78	Air-Side ho (BTU/hr-ft ² -°F)	8.42
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.09491556
Average Temp (°F)	130.96	110.83		
Skin Temperature (°F)	120.29	112.45	U Overall (BTU/hr-ft ² -°F)	4.09
Velocity ***	3,528.59	2.91	Effective Area (ft ²)	860.06
Reynold's Number	846**	19,317	LMTD	20.05
Prandtl Number	0.7266	4.0071	Total Heat Transferred (BTU/hr)	70,561
Bulk Visc (lbm/ft·hr)	0.0482	1.4717		
Skin Visc (lbm/ft·hr)		1.4483	Surface Effectiveness (Eta)	0.9170
Density (lbm/ft ³)	0.0636	61.8482	Sensible Heat Transferred (BTU/hr)	70,561
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0159	0.3668	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	954.18
Inlet Temperature (°F)	128.95	108.18	j Factor	0.0080
Outlet Temperature (°F)	125.34	109.88	Air-Side ho (BTU/hr-ft ² -°F)	8.40
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.09491556
Average Temp (°F)	127.14	109.03		
Skin Temperature (°F)	117.54	110.50	U Overall (BTU/hr-ft ² -°F)	4.09
Velocity ***	3,528.59	2.91	Effective Area (ft ²)	860.06
Reynold's Number	851**	18,971	LMTD	18.04
Prandtl Number	0.7269	4.0875	Total Heat Transferred (BTU/hr)	63,378
Bulk Visc (lbm/ft·hr)	0.0479	1.4986		
Skin Visc (lbm/ft·hr)		1.4766	Surface Effectiveness (Eta)	0.9172
Density (lbm/ft ³)	0.0640	61.8736	Sensible Heat Transferred (BTU/hr)	63,378
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0158	0.3662	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment c Page No. 46 of 17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY01 @ MAX FF, w\ 5% PLUG

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	945.71
Inlet Temperature (°F)	125.34	106.65	j Factor	0.0080
Outlet Temperature (°F)	122.09	108.18	Air-Side ho (BTU/hr·ft ² ·°F)	8.39
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.09491556
Average Temp (°F)	123.71	107.42		
Skin Temperature (°F)	115.07	108.74	U Overall (BTU/hr·ft ² ·°F)	4.08
Velocity ***	3,528.59	2.91	Effective Area (ft ²)	860.06
Reynold's Number	855**	18,662	LMTD	16.23
Prandtl Number	0.7272	4.1621	Total Heat Transferred (BTU/hr)	56,946
Bulk Visc (lbm/ft·hr)	0.0477	1.5234		
Skin Visc (lbm/ft·hr)		1.5029	Surface Effectiveness (Eta)	0.9173
Density (lbm/ft ³)	0.0643	61.8961	Sensible Heat Transferred (BTU/hr)	56,946
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr·ft ² ·°F)	938.08
Inlet Temperature (°F)	122.09	105.28	j Factor	0.0080
Outlet Temperature (°F)	119.17	106.65	Air-Side ho (BTU/hr·ft ² ·°F)	8.37
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.09491556
Average Temp (°F)	120.63	105.96		
Skin Temperature (°F)	112.86	107.17	U Overall (BTU/hr·ft ² ·°F)	4.07
Velocity ***	3,528.59	2.90	Effective Area (ft ²)	860.06
Reynold's Number	858**	18,386	LMTD	14.61
Prandtl Number	0.7274	4.2309	Total Heat Transferred (BTU/hr)	51,182
Bulk Visc (lbm/ft·hr)	0.0475	1.5463		
Skin Visc (lbm/ft·hr)		1.5273	Surface Effectiveness (Eta)	0.9174
Density (lbm/ft ³)	0.0647	61.9160	Sensible Heat Transferred (BTU/hr)	51,182
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3651	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200

Revision No. A00

Attachment CPage No. 51 of 117

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY01 @ MAX FF, w\ 5% PLUG

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,144.89	37,262.20	Tube-Side hi (BTU/hr-ft ² -°F)	931.21
Inlet Temperature (°F)	119.17	104.04	j Factor	0.0080
Outlet Temperature (°F)	116.55	105.28	Air-Side ho (BTU/hr-ft ² -°F)	8.36
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.09491556
Average Temp (°F)	117.86	104.66		
Skin Temperature (°F)	110.86	105.75	U Overall (BTU/hr-ft ² -°F)	4.07
Velocity ***	3,528.59	2.90	Effective Area (ft ²)	860.06
Reynold's Number	861**	18,138	LMTD	13.15
Prandtl Number	0.7276	4.2944	Total Heat Transferred (BTU/hr)	46,015
Bulk Visc (lbm/ft·hr)	0.0473	1.5673		
Skin Visc (lbm/ft·hr)		1.5497	Surface Effectiveness (Eta)	0.9175
Density (lbm/ft ³)	0.0650	61.9336	Sensible Heat Transferred (BTU/hr)	46,015
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0156	0.3646	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment c
 Page No. 68 of 117

*** Air Mass Velocity (Lbm/hr-ft²). Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

Inlet Air Flowrate Calculator - 1(2)VY01A

Total P:	P=	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T=	116.55 F	18982 acfm
Specific Hum.:	W =	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0649 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T=	148 F	
Outlet Air Flow:	V =	18000 cfm	

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ CSCS=104 F, ROOM T=150 F

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	

Tube Fluid Name	Fresh Water
Tube Fouling Factor	0.001500
Air-Side Fouling	0.000000
Design Heat Transfer (BTU/hr)	750,000
Atmospheric Pressure	14.315
Sensible Heat Ratio	1.00
Performance Factor (% Reduction)	0.000

Heat Exchanger Type	Counter Flow
Fin Type	Circular Fins
Fin Configuration	LaSalle VY Coolers 01A/02A $j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$

Coil Finned Length (in)	104.250
Fin Pitch (Fins/Inch)	10.000
Fin Conductivity (BTU/hr·ft·°F)	128.000
Fin Tip Thickness (inches)	0.0120
Fin Root Thickness (inches)	0.0120
Circular Fin Height (inches)	1.495

Number of Coils Per Unit	2
Number of Tube Rows	8
Number of Tubes Per Row	20.00
Active Tubes Per Row	20.00

Tube Inside Diameter (in)	0.5270
Tube Outside Diameter (in)	0.6250
Longitudinal Tube Pitch (in)	1.500
Transverse Tube Pitch (in)	1.452

Number of Serpentine	1.000
Tube Wall Conductivity (BTU/hr·ft·°F)	225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ CSCS=104 F, ROOM T=150 F

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,162.00
Tube Inlet Temp (°F)	104.00
Air Inlet Temp (°F)	150.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ CSCS=104 F, ROOM T=150 F

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	150.00	104.00	j Factor
Outlet Temperature (°F)	111.14	116.85	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.02832467
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 686,379
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 686,379
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F) 1,269.63
Inlet Temperature (°F)	150.00	113.97	j Factor 0.0082
Outlet Temperature (°F)	141.26	116.85	Air-Side ho (BTU/hr·ft ² ·°F) 8.23
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU) 0.02832467
Average Temp (°F)	145.63	115.41	U Overall (BTU/hr·ft ² ·°F) 5.69
Skin Temperature (°F)	122.89	117.96	Effective Area (ft ²) 905.33
Velocity ***	3,367.24	3.98	LMTD 30.00
Reynold's Number	793**	27,644	Total Heat Transferred (BTU/hr) 154,454
Prandtl Number	0.7253	3.8137	Surface Effectiveness (Eta) 0.9187
Bulk Visc (lbm/ft·hr)	0.0491	1.4069	Sensible Heat Transferred (BTU/hr) 154,454
Skin Visc (lbm/ft·hr)		1.3727	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0622	61.7815	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0163	0.3685	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment C
 Page No. 12 of 17

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ CSCS=104 F, ROOM T=150 F

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,251.77
Inlet Temperature (°F)	141.26	111.60	j Factor	0.0082
Outlet Temperature (°F)	134.08	113.97	Air-Side ho (BTU/hr·ft ² ·°F)	8.19
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	137.67	112.78	U Overall (BTU/hr·ft ² ·°F)	5.66
Skin Temperature (°F)	118.95	114.91	Effective Area (ft ²)	905.33
Velocity ***	3,367.24	3.98	LMTD	24.70
Reynold's Number	801**	26,943	Total Heat Transferred (BTU/hr)	126,678
Prandtl Number	0.7260	3.9226	Surface Effectiveness (Eta)	0.9190
Bulk Visc (lbm/ft·hr)	0.0486	1.4434	Sensible Heat Transferred (BTU/hr)	126,678
Skin Visc (lbm/ft·hr)		1.4137	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0629	61.8201	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0161	0.3675		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,237.05
Inlet Temperature (°F)	134.08	109.66	j Factor	0.0082
Outlet Temperature (°F)	128.19	111.60	Air-Side ho (BTU/hr·ft ² ·°F)	8.17
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	131.14	110.63	U Overall (BTU/hr·ft ² ·°F)	5.65
Skin Temperature (°F)	115.71	112.40	Effective Area (ft ²)	905.33
Velocity ***	3,367.24	3.98	LMTD	20.36
Reynold's Number	808**	26,373	Total Heat Transferred (BTU/hr)	104,043
Prandtl Number	0.7266	4.0159	Surface Effectiveness (Eta)	0.9193
Bulk Visc (lbm/ft·hr)	0.0482	1.4746	Sensible Heat Transferred (BTU/hr)	104,043
Skin Visc (lbm/ft·hr)		1.4490	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0636	61.8510	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0159	0.3668		

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment C
Page No. 213 of 217

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T. Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils
 VY02 @ CSCS=104 F, ROOM T=150 F

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,224.91
Inlet Temperature (°F)	128.19	108.06	j Factor	0.0081
Outlet Temperature (°F)	123.35	109.66	Air-Side ho (BTU/hr-ft ² -°F)	8.14
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	125.77	108.86		
Skin Temperature (°F)	113.06	110.33	U Overall (BTU/hr-ft ² -°F)	5.63
Velocity ***	3,367.24	3.98	Effective Area (ft ²)	905.33
Reynold's Number	813**	25,908	LMTD	16.79
Prandtl Number	0.7270	4.0953	Total Heat Transferred (BTU/hr)	85,551
Bulk Visc (lbm/ft·hr)	0.0478	1.5011		
Skin Visc (lbm/ft·hr)		1.4791	Surface Effectiveness (Eta)	0.9195
Density (lbm/ft ³)	0.0641	61.8760	Sensible Heat Transferred (BTU/hr)	85,551
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0158	0.3661	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr-ft ² -°F)	1,214.90
Inlet Temperature (°F)	123.35	106.75	j Factor	0.0081
Outlet Temperature (°F)	119.36	108.06	Air-Side ho (BTU/hr-ft ² -°F)	8.12
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	121.36	107.41		
Skin Temperature (°F)	110.87	108.63	U Overall (BTU/hr-ft ² -°F)	5.62
Velocity ***	3,367.24	3.97	Effective Area (ft ²)	905.33
Reynold's Number	818**	25,527	LMTD	13.85
Prandtl Number	0.7273	4.1625	Total Heat Transferred (BTU/hr)	70,414
Bulk Visc (lbm/ft·hr)	0.0476	1.5235		
Skin Visc (lbm/ft·hr)		1.5047	Surface Effectiveness (Eta)	0.9196
Density (lbm/ft ³)	0.0645	61.8962	Sensible Heat Transferred (BTU/hr)	70,414
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
 Revision No. A00
 Attachment C
 Page No. 014 of 011

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ CSCS=104 F, ROOM T=150 F

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,206.63
Inlet Temperature (°F)	119.36	105.67	j Factor	0.0081
Outlet Temperature (°F)	116.08	106.75	Air-Side ho (BTU/hr·ft ² ·°F)	8.11
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	117.72	106.21		
Skin Temperature (°F)	109.07	107.22	U Overall (BTU/hr·ft ² ·°F)	5.61
Velocity ***	3,367.24	3.97	Effective Area (ft ²)	905.33
Reynold's Number	822**	25,215	LMTD	11.43
Prandtl Number	0.7276	4.2192	Total Heat Transferred (BTU/hr)	58,002
Bulk Visc (lbm/ft·hr)	0.0473	1.5424		
Skin Visc (lbm/ft·hr)		1.5264	Surface Effectiveness (Eta)	0.9198
Density (lbm/ft ³)	0.0649	61.9126	Sensible Heat Transferred (BTU/hr)	58,002
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3651	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,199.81
Inlet Temperature (°F)	116.08	104.78	j Factor	0.0081
Outlet Temperature (°F)	113.37	105.67	Air-Side ho (BTU/hr·ft ² ·°F)	8.10
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	114.73	105.22		
Skin Temperature (°F)	107.58	106.06	U Overall (BTU/hr·ft ² ·°F)	5.60
Velocity ***	3,367.24	3.97	Effective Area (ft ²)	905.33
Reynold's Number	825**	24,959	LMTD	9.43
Prandtl Number	0.7278	4.2668	Total Heat Transferred (BTU/hr)	47,809
Bulk Visc (lbm/ft·hr)	0.0471	1.5582		
Skin Visc (lbm/ft·hr)		1.5447	Surface Effectiveness (Eta)	0.9199
Density (lbm/ft ³)	0.0652	61.9260	Sensible Heat Transferred (BTU/hr)	47,809
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3648	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Calculation No. 97-200
Revision No. A00
Attachment C
Page No. 15 of 17

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

VY02 @ CSCS=104 F, ROOM T=150 F

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,460.57	53,657.57	Tube-Side hi (BTU/hr·ft ² ·°F)	1,194.18
Inlet Temperature (°F)	113.37	104.04	j Factor	0.0081
Outlet Temperature (°F)	111.14	104.78	Air-Side ho (BTU/hr·ft ² ·°F)	8.09
Inlet Specific Humidity	0.0213		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0213		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	112.26	104.41	U Overall (BTU/hr·ft ² ·°F)	5.59
Skin Temperature (°F)	106.36	105.10	Effective Area (ft ²)	905.33
Velocity ***	3,367.24	3.97	LMTD	7.79
Reynold's Number	828**	24,749	Total Heat Transferred (BTU/hr)	39,429
Prandtl Number	0.7279	4.3068	Surface Effectiveness (Eta)	0.9200
Bulk Visc (lbm/ft·hr)	0.0470	1.5714	Sensible Heat Transferred (BTU/hr)	39,429
Skin Visc (lbm/ft·hr)		1.5601	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0655	61.9369	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0155	0.3645		

** Reynolds Number Outside Range of Equation Applicability

Inlet Air Flowrate Calculator - 1(2)VY02A

Total P:	P=	14.315 psia	Inlet Air Flow
Dry Bulb T OUT:	T=	111.14 F	19162 acfm
Specific Hum.:	W =	0.020274	
H2O Vap P:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451875 psia	
		Rv = 85.778 (ft-lbf)/(lbm-R)	
		Ra = 53.352 (ft-lbf)/(lbm-R)	
Dry Air P:	$P_a = P - P_v =$	13.86313 psia	
Dry Air rho OUT:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.0656 lbm/ft ³	
Dry Air rho IN:	$\rho_a = (144/R_a) \cdot (P_a / (459.67 + T)) =$	0.061575 lbm/ft ³	
Dry Bulb T IN:	T=	148 F	
Outlet Air Flow:	V =	18000 cfm	

**PROTO-POWER CORPORATION
CALCULATION TITLE SHEET**

CLIENT: Commonwealth Edison

PROJECT: LaSalle Station GL 89-13 Heat Exchanger Testing Program

CALCULATION TITLE: VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A

CALCULATION NO.: 97-200

FILE NO.: 31-003

COMPUTER CODE & VERSION (if applicable): PROTO-HX™, Version 3.01

REV	TOTAL NO. OF PAGES	ORIGINATOR/DATE	VERIFIER/DATE	APPROVAL/DATE
A	205	Lloyd Philpot <i>Lloyd Philpot 6/24/98</i>	Merid Aboye <i>Merid Aboye 6/24/98</i>	<i>Joe Connelly 6-24-98</i>

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE ii OF vi
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Revision History

Revision	Revision Description
A	Original Issue

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE iii OF vi
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

CALCULATION VERIFICATION FORM

REVIEW METHOD:

- | | | | |
|--|-------------------------------------|-----|-------------------------------------|
| Approach Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Logic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Arithmetic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Alternate Method
(Attach Brief Summary) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Computer Program Used
(Attach Listing) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Other | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |

EXTENT OF VERIFICATION:

- | | |
|-------------------------|-------------------------------------|
| Complete Calculation: | <input checked="" type="checkbox"/> |
| Revised areas only: | <input type="checkbox"/> |
| Other (describe below): | <input type="checkbox"/> |

***Errors Detected**

- 1) Section 7.3: Bounding Uncertainty
is not used.
- 2) Clarification suggested in
Section 7.4

***Other Comments**

***Error Resolution**

- 1) Uncertainty of 4.5% used instead
of 4.3%.
- 2) Last 2 sentences in section
7.4 added to clarify issue
of analytical uncertainty.

***Extra References Used**

*(Attach extra sheets if needed)

CALCULATION FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT AND REASONABLE:

IDV Signature:

M. Aboye

Initials:

MA

Printed Name:

MERED ABOTE

Date:

6/24/98

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE iv OF vi
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

TABLE OF CONTENTS

CALCULATION TITLE SHEET.....i

CALCULATION REVISION HISTORY.....ii

CALCULATION VERIFICATION SHEET.....iii

TABLE OF CONTENTS.....iv

LIST OF ATTACHMENTS.....vi

Total Number of Pages in Preface of Calculation: 6

1. PURPOSE.....1

2. BACKGROUND1

3. DESIGN INPUTS2

4. APPROACH.....5

5. ASSUMPTIONS.....5

6. ANALYSIS6

 6.1 Tube Pitch6

 6.2 Coil Configuration6

 6.3 Sensible Heat Ratio7

 6.4 Derivation of Benchmarking Inputs.....7

 6.5 Model Benchmarking.....10

 6.6 Effective Coil Finned Length.....14

 6.7 Extrapolation Conditions14

 6.8 Thermal Margin Assessment16

 6.9 Limiting Cooling Water Flow Analysis.....17

 6.10 Fouling Sensitivity Analysis.....17

7. RESULTS18

 7.1 Model Benchmarking.....18

 7.2 Thermal Margin Analysis19

 7.3 Limiting Cooling Water Flow Rate Analysis19

 7.4 Fouling Sensitivity Analysis.....21

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE v OF vi
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

8. CONCLUSIONS22

9. REFERENCES.....22

Total Number of Pages in Body of Calculation: 23

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE vi OF vi
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

LIST OF ATTACHMENTS

<u>Attachment</u>	<u>Subject Matter</u>	<u>Total Pages</u>
A	Attachment A to Proto-Power Calculation 97-200 Rev. A: Design Input Data -- Selected References	13
B	Attachment B to Proto-Power Calculation 97-200 Rev. A: Cooler Inspection Photographs -- 1VY01A and 1VY02A	3
C	Attachment C to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Initial Benchmark Case	8
D	Attachment D to Proto-Power Calculation 97-200 Rev. A: Excerpt from <i>Compact Heat Exchangers</i> , Kays and London	2
E	Attachment E to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Final Benchmark Case	15
F	Attachment F to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Thermal Margin Assessment (Clean)	8
G	Attachment G to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Thermal Margin Assessment (Service)	8
H	Attachment H to Proto-Power Calculation 97-200 Rev. A: Derivation of Moist Air Properties	13
I	Attachment I to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Limiting Flow Analysis	22
J	Attachment J to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Analytical Uncertainty Analysis	40
K	Attachment K to Proto-Power Calculation 97-200 Rev. A: Comparing Surface Areas of Spiral and Circular Fins	4
L	Attachment L to Proto-Power Calculation 97-200 Rev. A: Walkdown Data for Coil Physical Dimensions	6
M	Attachment M to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Reports -- Fouling Sensitivity Analysis	32
N	Attachment N to Proto-Power Calculation 97-200 Rev. A: PROTO-HX™ Model Database Disk	2 (plus disk)

Complete Calculation (total number of pages): 205

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 1 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

1. PURPOSE

The purpose of this calculation is to develop a thermal performance analysis model for the Commonwealth Edison (ComEd) LaSalle Station NW and SW cubicle area coolers 1(2)VY01A and 1(2)VY02A. This model can be used for the analysis of heat exchanger thermal performance test data as part of the LaSalle Station GL 89-13 heat exchanger testing program or for any other engineering analysis subject to the limitations itemized below.

Once developed, the model is used to identify the thermal margin of the heat exchanger at specified performance conditions as follows:

- at LaSalle Station Reference Conditions as currently defined in the LaSalle Station design and licensing basis; and
- at lower service water flow rates (with increased fouling) to support service water system re-balancing efforts.

The thermal performance model documented in this calculation has been created and used with PROTO-HX, Version 3.01. The model can be used with previous versions of PROTO-HX and produce identical results as long as the following restriction is upheld:

- Air coils analyzed in Version 3.0 or earlier can be analyzed only in non-condensing modes of operation.

Current limitations of use for PROTO-HX are established by the limits on fluid properties included within the software. Fluid properties contained within PROTO-HX are currently limited to the following temperature ranges:

- Air: 32-320°F
- Water: 32-500°F

2. BACKGROUND

LaSalle Station is in the process of implementing a heat exchanger thermal performance monitoring program and a service water system flow balancing program in response to the requirements of NRC Generic Letter 89-13. Development of an analytical model in PROTO-HX™, Version 3.01, will allow timely analysis of data resulting from the test program and will ensure the limiting flow requirements for the coolers are adequately defined.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO 97-200	REV A	PAGE 2 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

3. DESIGN INPUTS

The thermal performance model is developed using PROTO-HX™, Version 3.01. PROTO-HX™ was developed and validated in accordance with Proto-Power's Nuclear Software Quality Assurance Program (SQAP). This program meets the requirements of 10CFR50 Appendix B, 10CFR21, and ANSI NQA-1, and was developed in accordance with the guidelines and standards contained in ANSI/IEEE Standard 730/1984 and ANSI NQA-2b-1991. PROTO-HX™ Version 3.01 was verified and approved for use as documented in Reference (1).

The design inputs for this calculation consist of the heat exchanger design basis performance requirements (Table 1), performance specifications (Table 2) and construction details (Table 3) provided by the heat exchanger manufacturer data sheet (Attachment A) or other design documents as referenced. Construction details give the necessary information for model construction while performance specifications are used to benchmark the model.

VY cooler thermal performance in this calculation will be assessed only with respect to the nominal accident conditions (i.e., design basis LOCA) with no tubes plugged. Condensing modes of operation and tube plugging margins are not addressed.

Table 1: LaSalle Station Reference Conditions

Parameter	Value	Reference*
Heat Rate -- 1(2)VY01A (BTU/hr)	517,239	2
Heat Rate -- 1(2)VY02A (BTU/hr)	646,235	3
Atmospheric Pressure (in-w.g.)	-0.4	4
Air-Side Inlet Temperature -- Dry Bulb (°F)	148	4
Fan Volumetric Flow Rate (cfm)	18,000	18,19
Tube-Side Flow Rate (gpm)	150	5
Tube-Side Inlet Temperature (°F)	100	6

*Selected references included as Attachment A

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 3 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Table 2: Vendor Specified Performance

Parameter	Value	Reference*
Air-Side Fouling Factor (Design)	0	Assumption (1)
Air-Side Entering Fluid Flow Rate (scfm)	17,330	7
Air-Side Inlet Dry Bulb Temperature (°F)	150	7
Air-Side Inlet Wet Bulb Temperature (°F)	92	7
Air-Side Outlet Dry Bulb Temperature (°F)	109.4	7
Air-Side Outlet Wet Bulb Temperature (°F)	84.1	7
Tube Side Fouling Factor (Design)	0.0015	8
Tube Side Fluid Type	Service Water (Fresh)	9,10
Tube Side Fluid Flow Rate, Total (gpm)	150	7
Tube Side Inlet Temperature (°F)	105	7
Tube Side Outlet Temperature (°F)	115.3	7
Design Q (BTU/hr)	750,000	7

*Selected references included as Attachment A

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 4 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Table 3: Construction Details

Parameter	Value	Reference ⁽¹⁾
Heat Exchanger Type and relative direction of Tube-side and Air flow .	Carrier Air Coil Counter flow	7,11
Fin Type	Spiral	7,8
Coil Finned Length (in)	108.00 -- specified (2) 104.25 -- effective (2)	7 20
Fin Pitch (fins/in)	10.0	7
Fin Material	ASTM B209 Aluminum	7
Fin Conductivity (BTU/hr-ft-°F)	128	16
Fin Thickness (in)	0.012	7
Fin Height (in)	1.495	20
Number of Coils per Unit	2	7
Number of Tube Rows	8	7
Number of Tubes per Row	20	7
Number of Plugged Tubes	0	-
Tube Outside Diameter (in)	0.625 (3)	7
Tube Wall Thickness (in)	0.049	7
Tube Inside Diameter (in)	0.527	7
Longitudinal (horizontal) Tube Pitch (in)	Unavailable - see Section 6	-
Transverse (vertical) Tube Pitch (in)	1.452	20
Tube Layout	Staggered	20
Number of Serpentes	1 (i.e., "Full Circuiting")	7
Tube Wall Material	SB75 Copper	7
Tube Wall Conductivity (BTU/hr-ft-°F)	225	12
Sensible Heat Ratio	1	(Section 6.3)

Notes: (1) Selected references included as Attachment A

(2) The Reference 7 coil finned length will be used for benchmarking to vendor performance data per Section 6.0. The Reference 20 effective coil finned length will be used for subsequent analyses.

(3) The Reference 7 tube OD is within the tolerance of Reference 20 and will be used in lieu of Ref. 20.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 5 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

4. APPROACH

This calculation utilizes plant/vendor fabrication specifications provided in Section 3.0 to develop a thermal performance prediction model for the 1(2)VY01A/02A coolers. The calculation then benchmarks the model by comparing the heat transfer rate calculated by PROTO-HX™ Version 3.01 with the manufacturer's specifications for thermal performance. The Colburn j-factor vs. Reynolds Number relationship is adjusted as necessary to meet the manufacturer's performance specifications. After the model is benchmarked, it will be used to determine the margin between the available and required heat removal rates and to establish a revised limiting flow rate in support of service water system re-balancing efforts.

5. ASSUMPTIONS

1. The fouling factor specified in Reference (8) is for the tube-side only and design air-side fouling is zero. Future validation of this assumption is not required.
2. The slope of the "Colburn j-factor vs. Reynolds Number" curve is the same for the current coil and the standard coil represented by curve "CF-9.05-3/4 J-A" in the PROTO-HX™ "h-configurations" Library. This assumption is based on physical similarities between the VY coolers and the standard configuration represented by "CF-9.05-3/4 J-A" as elaborated in Section 6, below. The model benchmarking process described in Section 6 brings the model into precise agreement with the vendor performance data making initial configuration selection immaterial. The only difference caused by initial configuration selection that would be detectable in analysis results is when analyses are performed over a very wide range (orders of magnitude) of air-side Reynolds numbers. A wide range of Reynolds numbers causes the slight variation in slopes of the j-factor equations of different configurations to become more obvious. Given the fixed fan flow rate and a relatively tight band of normal operating and Reference conditions, along with the fact that benchmarking conditions are extremely close to Reference conditions, such wide variations in Reynolds numbers are not anticipated. Future validation of this assumption is not required.
3. The vendor-supplied performance specifications of Reference (7) (included as Attachment A) are considered to be an accurate reflection of the as-built performance of each VY Cooler. Future validation of this assumption is not required.
4. The VY cooler spiral fin geometry is closely approximated by the PROTO-HX™ circular fin configuration. This is due to the relatively tight fin pitch configuration resulting in a

PROTO-POWER CORPORATION GROTON, CONNECTICUT		CALC NO. 97-200	REV A	PAGE 6 OF 23
		ORIGINATOR L. Philpot		DATE 6/24/98
		VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT	Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A				

negligible difference in fin/tube outside surface area. This assumption is supported in Attachment K. Future validation of this assumption is not required.

- In transitioning from the original vendor specified inlet air temperature of 150°F to the current licensing limit of 148°F, the inlet air vapor density is assumed to have remained unchanged. This increases the inlet relative humidity causing a slight reduction in the air mass flow rate. Future validation of this assumption is not required.

6. ANALYSIS

6.1 Tube Pitch

The longitudinal tube pitch is not directly available from the coil data sheet or Reference 20. It can be estimated based on the geometry of the coil. Per Reference (7), the coil stack depth is 12.00 inches. Dividing the stack depth evenly between 8 tube rows yields a longitudinal (horizontal) tube pitch of 1.500 inches.


6.2 Coil Configuration

The coil configuration for modeling coolers 1(2)VY01A and 1(2)VY02A is selected based on the physical characteristics of the coil. There are no coils in the PROTO-HX™ library that exactly match the configuration of the VY coolers. The configuration "CF-9.05-3/4 J-A" shown in Figure 1 provides the closest match based on similarities of layout geometry: staggered tube rows, horizontal tube pitch slightly greater than vertical tube pitch, similar fin height, identical fin thickness and similar fin pitch. The "CF-9.05-3/4 J-A" configuration also represents a relatively compact coil which correlates well to the VY coils as evidenced in the coil photographs included as Attachment B.

PROTO-HX™ does not include spiral fin configurations in the analytical methodology employed. However, for the given fin pitch, the difference in calculated fin surface area between the VY cooler spiral fin configuration and the PROTO-HX™ circular fin configuration is negligible. The negligible difference is illustrated further in Attachment K using a simplified area comparison.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 7 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Figure 1 Coil Configuration CF-9.05-3/4 J-A



6.3 Sensible Heat Ratio

The value input in the model for the Sensible Heat Ratio (SHR) is used only when one of the “Constant Heat Load” calculation/extrapolation methods of PROTO-HX™ is used (i.e., “Constant Heat and Cold Inlet Temperature” or “Constant Heat and Hot Outlet Temperature”). The SHR can be assigned any value between 0 and 1 and represents the fraction of the total specified (constant) heat load that is due to sensible cooling alone. An input of 1.0 in the SHR field tells PROTO-HX™ that the specified constant heat is 100% sensible heat with no condensation occurring. Use of any value less than 1.0 presumes some knowledge as to what fraction of the specified heat load is due to condensation (i.e., latent heat transfer). The value of SHR currently in the model is 1.0, but like any other model input, the SHR can be changed at any time.

6.4 Derivation of Benchmarking Inputs

The PROTO-HX™ model is benchmarked using the performance data provided by the cooler manufacturer. In order to benchmark the model, the vendor specified conditions must be converted into appropriate units for PROTO-HX™ input. The only input requiring adjustment is the specified air-side flow rate of 17,330 *scfm*. PROTO-HX™ requires air-side flow rate to be given at actual inlet air conditions (units of *acfm*).

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 8 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

The correction of *scfm* to *acfm* is made as follows (holding mass flow rate constant for the defining case):

$$\dot{m} = (\text{scfm}) \times (\rho_{\text{std}}) \times \left(\frac{60 \text{ min}}{1 \text{ hr}} \right) = (\text{acfm}) \times (\rho_{\text{actual}}) \times \left(\frac{60 \text{ min}}{1 \text{ hr}} \right) \quad \text{Equation (1)}$$

where:

\dot{m} = mass flow (lbm/hr)

scfm = volumetric flow rate at standard conditions (ft³/min)

ρ_{std} = standard density of 0.075 lbm/ft³

acfm = volumetric flow rate at specified (non-standard) conditions (ft³/min)

ρ_{actual} = density of dry air at specified inlet temperature and humidity (lbm/ft³)

Rearranging terms yields the following correction factor for converting scfm to inlet acfm:

$$(\text{acfm}) = (\text{scfm}) \times \frac{(\rho_{\text{std}})}{(\rho_{\text{actual}})} \quad \text{Equation (2)}$$

Local Standard Atmospheric Pressure

To derive the dry air density for the inlet air conditions, the amount of moisture in the air and the local atmospheric pressure must be accounted for. Per Reference (13), local atmospheric pressure was accounted for by specifying a flow at standard density (17,330 scfm) as well as an actual flow (18,000 acfm at 70°F and 40% relative humidity at site elevation). The difference between the two flow rates will provide the assumed air density as follows:

$$(\rho_{\text{actual}}) = (\text{scfm}) \times \frac{(\rho_{\text{std}})}{(\text{acfm})} = (17,330) \times \frac{0.07500}{18,000} = 0.0722 \text{ lbm/ft}^3$$

The local atmospheric pressure is found by iterative solution using Reference (14) as shown in Attachment H. Pressure input is varied with the specified temperature and humidity conditions

PROTO-POWER CORPORATION GROTON, CONNECTICUT		CALC NO. 97-200	REV A	PAGE 9 OF 23
		ORIGINATOR L. Philpot		DATE 6/24/98
		VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing			
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A				

held constant until a dry air density of 0.0722 lbm/ft³ is reached. The result of the iterative process is as follows:

Given per Reference (13)

Dry Bulb Temperature: 70.00°F
 Relative Humidity: 40.00 %

Derived above

Dry Air Density: 0.0722 lbm/ft³

Derived per Attachment H

Specific Humidity: 0.00638 lbmv/lbma
 Atmospheric Pressure: **14.3150 psia**
 Dry Air Pressure: 14.1697 psia
 Vapor Pressure: 0.1453 psia
 Vapor Density: 0.00046 lbm/ft³

The result is that an atmospheric pressure of 14.315 psia at 70°F and 40% relative humidity will give the requisite air density.

Actual Air Flow Rate

The next step is to define the actual air flow rate at the inlet conditions included by the vendor in the Reference (7) performance specification (Table 2).

The moist air conditions corresponding to the vendor specified performance conditions are as follows:

Given per Reference (7)

Dry Bulb Temperature: 150.00°F
 Wet Bulb Temperature: 92.00°F

Derived above

Atmospheric Pressure: 14.315 psia

Derived per Attachment H

Relative Humidity: 12.18 %
 Specific Humidity: 0.02034 lbmv/lbma

PROTO-POWER CORPORATION		CALC NO. 97-200	REV A	PAGE 10 OF 23
GROTON, CONNECTICUT		ORIGINATOR L. Philpot		DATE 6/24/98
		VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT	Commonwealth Edison		PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing	
TITLE	VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Dry Air Pressure: 13.8617 psia
 Vapor Pressure: 0.4533 psia
 Dry Air Density: 0.06137 lbm/ft³
 Vapor Density: 0.001248 lbm/ft³

The actual volumetric flow rate at vendor specified inlet conditions is then calculated as:

$$(\text{acfm}) = (\text{scfm}) \times \frac{(\rho_{\text{std}})}{(\rho_{\text{actual}})} = (17,330) \times \frac{0.07500}{0.06137} = 21,179 \text{ ft}^3/\text{min}$$

Summary of PROTO-HXTM Inputs for Model Benchmarking

Tube-Side Flow Rate 150 gpm
 Tube-Side Inlet Temperature 105°F
 Air-Side Flow Rate 21,179 acfm
 Air-Side Inlet Temperature -- Dry Bulb 150°F
 Air-Side Inlet Temperature -- Wet Bulb 92°F
 Atmospheric Pressure 14.315 psia

6.5 Model Benchmarking

Model benchmarking is performed to compare thermal performance as predicted by the model to thermal performance specified by the cooler vendor. A significant impact on the model predicted performance is the outside (air-side) heat transfer coefficient. The benchmarking process adjusts the model correlation for outside heat transfer coefficient to match vendor performance data.

An extensive source of information pertaining to the outside heat transfer coefficient for air coolers is provided by Reference (15). This widely-recognized publication provides heat transfer correlations for specific coil configurations. The format used in Reference (15), and subsequently adopted by other researchers, is to provide a plot of the Colburn j-factor vs. Reynolds Number for each configuration.

Alternatively, to permit modeling of coils which do not adequately fit the library configurations and for which no test data correlation is available, PROTO-HXTM allows the generation of a coil unique formulation for outside heat transfer coefficient. This is done through establishing a unique Colburn j-factor for the coil.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC. NO. 97-200	REV A	PAGE 11 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Reference (15) defines the Colburn j-factor as follows.

Let:

- c_{pa} = Specific heat of air (Btu/lb_m-°F)
- k_a = Thermal conductivity of air (Btu/hr-ft-°F)
- m_a = Absolute viscosity of air (lb_m/ft-hr)
- r_a = Density of air (lb_m/ft³)
- A_{min} = Minimum air-side flow area (Section 3.3.8) (in²)
- A_I = Frontal Area (Section 3.3.8) (in²)
- D_H = Hydraulic diameter (Section 3.3.8) (ft)
- d_o = Tube outside diameter (in)
- j = Colburn j-Factor
- N_C = Number of coils per unit
- N_L = Number of active tube rows
- Q_a = Specified air flow rate (acfm)
- S_L = Longitudinal Tube Pitch (in)
- S_T = Transverse Tube Pitch (in)

The Prandtl Number for air, Pr_a (a dimensionless parameter), is given by:

$$Pr_a = \frac{c_{pa} \mu_a}{k_a} \quad \text{Equation (3)}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 12 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

The mass flow rate of air per coil, M_a (lb_m/hr), is calculated based on the input total air flow and the number of coils per unit:

$$M_a = \frac{60 \rho_a Q_a}{N_c} \quad \text{Equation (4)}$$

The bulk-stream mass flux, G (lb_m/hr-ft²), is:

$$G = \frac{144 M_a}{A_{MIN}} \quad \text{Equation (5)}$$

The Colburn j -factor is defined in terms of the Stanton Number, St_a , as:

$$j = St_a Pr_a^{2/3} = \left(\frac{h_o}{G c_{pa}} \right) Pr_a^{2/3} \quad \text{Equation (6)}$$

Therefore, the outside heat transfer coefficient, h_o (Btu/hr-ft²-°F), may be defined in terms of the j -factor:

$$h_o = \frac{j G c_{pa}}{Pr_a^{2/3}} \quad \text{Equation (7)}$$

Per Reference (15), the j -factor for the various coil configurations tested are provided as functions of the Reynolds Number based on hydraulic diameter, D_H (in):

$$j = f(Re_a) \quad \text{where: } Re_a = \frac{G D_H}{\mu_a} \quad \text{Equation (8)}$$

The standard air-side configuration for coil type CF-9.05-3/4 J-A, provided in PROTO-HX™'s Library, was initially selected based on the physical similarities between the present coil and that represented by CF-9.05-3/4 J-A as described in Section 6.2. However, the heat transfer rate under design operating conditions using the standard configuration was slightly greater than the value specified by the manufacturer (see performance run in Attachment C). For this reason, a

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 13 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

new curve relating the Colburn j-factor and Reynolds Number was generated according to the following procedure:

- The slope of the linear standard curve was calculated.
- A new curve, parallel to the standard curve, was defined such that the new j-intercept is slightly lower.
- A design performance run was then executed using the new Colburn j-factor versus Reynolds Number curve, and the resulting heat transfer rate was compared to the manufacturer's value.
- The above two steps were repeated until the calculated heat transfer rate closely matched the manufacturer's value.

The resulting relationship between Reynolds Number and Colburn j-Factor is represented by the following table and associated equation:

Table 4: Reynolds Number and Colburn j-Factor

Reynolds Number	Colburn j-Factor (Standard)	Colburn j-Factor (Custom)
1000	0.009	0.00758
8000	0.0044	0.00371

$$j = e^{[-2.5088 - 0.3436 * \ln(\text{Re})]} \quad \text{Equation (9)}$$

Equation (9) was added to the PROTO-HX™ Library for use in conjunction with Area Coolers 1(2)VY01A and 1(2)VY02A.

As noted in Assumption (2) and implemented above, the slope of the "Colburn j-factor vs. Reynolds Number" curve is assumed to be the same for the VY coolers and the standard coil represented by curve CF-9.05-3/4 J-A in the PROTO-HX™ "h-configurations" Library. This assumption is considered reasonable based on the following:

- there are only minor variations in the slope of different j-factor correlations; and,
- there is only a slight variation in the air-side Reynolds Number between anticipated test conditions and the extrapolated accident conditions. The only variation is

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 14 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

expected to be caused by air inlet temperature variations (i.e., volumetric flow rate in cfm will be nearly constant, while air flow in acfm will vary with temperature and inlet humidity).

An excerpt from Reference (15), illustrating the j-factor relationship with Reynolds number, is included as Attachment D.

6.6 Effective Coil Finned Length

Reference 20 identified the fact that the finned coil length exposed to air flow was less than that specified by the coil vendor in Reference 7. Model benchmarking used the vendor specified length to be consistent with the vendor specified performance. The effective length is entered into the model for all subsequent analysis. An effective coil finned length of 104.25 inches is used per Reference 20.

6.7 Extrapolation Conditions

The LaSalle Station Reference Conditions defined in Table 1 are slightly different than the vendor specified performance conditions listed in Table 2 and require conversion to units for input into PROTO-HX™.

Air-Side Pressure

Air-side pressure should account for the local elevation above sea level. Chapter 26, Table 1A, of Reference (16) provides elevation and standard atmospheric pressure data for the local area around La Salle.

Interpolating between data points to derive the pressure associated with the elevation of the VY coolers given by Reference (17) provides the following:

Elevation (feet above sea level)	Pressure (psia)	
682	14.337	Reference (16)
738	14.308	Reference (16)
698	14.329	Interpolation between above points at VY elevation

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 15 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Per Reference (4), the coil pressure is -0.4 inches of water gauge. Using the density of water at 60°F, the specified pressure is calculated as illustrated below:

Coil Pressure (inwg)	Water Density (lbm/ft ³)	Coil Pressure (psig)	Atm Pressure (psia)	Coil Pressure (psia)
-0.4	62.36445	-0.014	14.329	14.315

This pressure matches the pressure derived from the original coil specification in Section 6.4.

Air-Side Flow Rate

In order for PROTO-HX™ to calculate the air mass flow rate for a given extrapolation condition, the inlet dry bulb temperature, total pressure, and relative humidity or wet bulb temperature must be specified. The inlet dry bulb temperature and pressure for the LaSalle Station Reference Conditions are listed in Table 1. The inlet relative humidity is adjusted by holding the vapor density constant from the vendor specified condition to the LaSalle Station Reference Condition (i.e., 148°F in lieu of 150°F per Assumption 5).

Given per Section 6.4

Vapor Density: 0.001248 lbm/ft³

Reference Condition

Dry Bulb Temperature: 148.00°F
 Atmospheric Pressure: 14.315 psia

Derived per Attachment H

Wet Bulb Temperature: 91.6°F
 Relative Humidity: 12.76 %

Since fans are constant volume equipment, the air volumetric flow rate of 18,000 cfm specified in References (18) and (19) remains the same for all coil outlet conditions. The air mass flow rate through the coil, however, will vary with the temperature of the air going through the fan (i.e., at coil outlet temperature). Deriving the inlet air flow rate for input to PROTO-HX™ requires an iterative solution as follows:

- take an initial guess at the coil outlet air temperature at the same specific humidity as the coil inlet;
- calculate the dry air density at the selected coil outlet air temperature;

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 16 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

- calculate the coil inlet air flow rate by multiplying the fan capacity (cfm) by the ratio of the coil outlet dry air density to the coil inlet dry air density (to maintain constant mass flow across the coil) [Equation (2)];
- run the model with the inlet air flow rate derived above;
- check the predicted coil outlet air temperature; and
- repeat the process (substituting the predicted coil outlet air temperature for the initial guess) until the coil outlet air temperature does not change from one iteration to the next

The iteration process described above was completed twice for this model for a clean ($f = 0.0$) and service ($f = \text{design}$) condition with results as follows:

Clean:

$$(\text{cfm}_{\text{in}}) = (\text{cfm}_{\text{out}}) \times \frac{(\rho_{\text{out}})}{(\rho_{\text{in}})} = (18,000) \times \frac{(0.06631929)}{(0.061575103)} = 19,387 \text{ (Fan Temperature} = 104.53)$$

Service:

$$(\text{cfm}_{\text{in}}) = (\text{cfm}_{\text{out}}) \times \frac{(\rho_{\text{out}})}{(\rho_{\text{in}})} = (18,000) \times \frac{(0.06609320)}{(0.061575103)} = 19,321 \text{ (Fan Temperature} = 106.46)$$

Summary of PROTO-HX™ Inputs for Extrapolation to Reference Conditions

The Extrapolation conditions are defined as the vendor data sheet conditions without high energy line break modified for ultimate heat sink temperature and room limiting temperature per the LaSalle Station UFSAR Reference (4). The required PROTO-HX™ inputs for these conditions are as follows:

Tube-Side Flow Rate	150 gpm
Tube-Side Inlet Temperature	100°F
Air-Side Flow Rate	(varies with temperature)
Air-Side Inlet Temperature -- Dry Bulb	148°F
Air-Side Inlet Humidity	12.76%
Atmospheric Pressure	14.315 psia

6.8 Thermal Margin Assessment

The available thermal margin is defined as the difference between the available and the required heat removal rates at reference conditions. The maximum available heat removal rate (q_{clean}) is calculated using the benchmarked PROTO-HX™ model and the inlet conditions defined in

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 17 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Section 6.7 with zero fouling. By comparing the available heat removal rate calculated with zero fouling to the required heat removal rate, the maximum available margin is determined. A similar comparison is made between the required heat load to the available heat load at design fouling conditions ($q_{service}$).

For the purposes of this thermal margin assessment, thermal margin is defined as follows:

$$\text{Margin (BTU / hr)} = q_{\text{available}} - q_{\text{required}} \quad \text{Equation (10)}$$

$$\text{Margin (\%)} = \left(\frac{q_{\text{available}} - q_{\text{required}}}{q_{\text{required}}} \right) \times 100 \quad \text{Equation (11)}$$

where:

$q_{\text{available}}$ = the predicted heat capacity of the cooler at the specified conditions (BTU/hr)

q_{required} = the heat capacity required of the cooler to fulfill design basis requirements (BTU/hr)

6.9 Limiting Cooling Water Flow Analysis

In support of the LaSalle Station efforts to re-balance the CSCS Equipment Cooling Water System, specification of a minimum acceptable cooling water flow to the VY coolers is desired. For conservatism, the design fouling factors associated with the limiting flow analysis are increased to 0.002 on both the tube and air sides of the cooler. Increasing the design fouling factors increases the fouling margin of the cooler at the reduced flow rates.

Limiting flows are established by iterating with the performance model. The cooling water flow rate is incrementally reduced with each iteration until the target thermal margin is achieved. For the case of 1(2)VY01A, the target thermal margin is approximately 30% with the increased design fouling factors. For the case of 1(2)VY02A, the target thermal margin is approximately 10% with the increased design fouling factors.

6.10 Fouling Sensitivity Analysis

To assess the sensitivity of the 1(2)VY01A and 1(2)VY02A coolers to tube-side fouling accumulations, a series of iterations are performed. With each iteration, the design tube-side fouling factor is incrementally increased from a value of 0.0000 to 0.0040. The heat removal

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 18 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

capability resulting from each fouling increment is compared to the required heat load to assess the thermal margin. Thermal margin is calculated using Equations (10) and (11).

7. RESULTS

7.1 Model Benchmarking

The first model case was based on the standard CF-9.05-3/4 J-A configuration available from the PROTO-HX™ library. The results of this initial benchmarking case are presented in Table 5. The PROTO-HX™ reports associated with the initial benchmark case are included as Attachment C.

Table 5: Initial Benchmark Case -- Standard CF-9.05-3/4 J-A Configuration

Cooler	Design $q^{(1)}$ (BTU/hr)	PROTO-HX™ Predicted q (BTU/hr)	Percent Difference
1(2)VY01A 1(2)VY02A	750,000	775,120	+3.35%

(1) Heat rate specified by cooler vendor

Based on the results of the initial benchmark case with the standard CF-9.05-3/4 J-A configuration, another case was completed using a customized Colburn J-Factor. This case demonstrated adequate benchmarking of the model to the vendor specified performance. A subsequent comparison run was made following the adjustment of the coil finned length to match the length identified in Reference 20. The results of the final benchmarking cases are presented in Table 6. The PROTO-HX™ reports associated with the final benchmarking cases are included as Attachment E.

Table 6: Final Benchmark Case -- Customized Colburn J-Factor

Cooler	Design $q^{(1)}$ (BTU/hr)	Predicted q (BTU/hr)	Percent Difference
1(2)VY01A 1(2)VY02A	750,000	749,965 (2)	-0.0047%
1(2)VY01A 1(2)VY02A	750,000	746,297 (3)	-0.49%

Notes:

(1) Heat rate specified by cooler vendor

(2) With specified coil finned length per Reference 7 (benchmarking basis)

(3) With effective coil finned length per Reference 20 (subsequent analysis basis)

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 19 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

7.2 Thermal Margin Analysis

Prior to defining margin, the predicted heat transfer capacity of the cooler ($q_{available}$) is defined. The predicted heat transfer capacities at LaSalle Station Reference Conditions for both clean (zero fouling) and service (design fouling) conditions are summarized in Table 7 below.

Table 7: Heat Transfer Capacity

Fouling Condition	Heat Transfer Capacity (BTU/hr)
Clean ($f = 0.0000$)	779,018
Service ($f = 0.0015$)	741,876

The thermal margin assessment relates the predicted capacity of the cooler at clean and service conditions to the required capacity under reference conditions. The comparison is provided in Table 8. The PROTO-HX™ reports associated with the thermal margin assessment are included as Attachments F and G for zero and design fouling conditions, respectively.

Table 8: Thermal Margin at LaSalle Station Reference Conditions ($f = 0.0000/0.0015$)

Cooler	Fouling (f)	$q_{required}$ (BTU/hr)	$q_{available}$ (BTU/hr)	Margin (BTU/hr)	Margin (%)
1(2)VY01A	zero	517,239	779,018	261,779	50.61
	design	517,239	741,876	224,637	43.43
1(2)VY02A	zero	646,235	779,018	132,783	20.55
	design	646,235	741,876	95,641	14.80

7.3 Limiting Cooling Water Flow Rate Analysis

The limiting cooling water flow analysis calculated the lowest possible cooling water flow that would provide a thermal margin of approximately 30% for the 1(2)VY01A coolers and a thermal margin of 10% for the 1(2)VY02A coolers with an adjusted design fouling of 0.002 air-side and 0.002 tube-side. The results of the iterations to identify the limiting flow rate are summarized in

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 20 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

Table 9. The 108 gpm Case was added as a limiting flow case for 1(2)VY02A since available system flow is limited by pump capability. The PROTO-HX™ reports associated with the limiting flow analysis for both coolers are included as Attachment I.

Table 9: Limiting Cooling Water Flow Rate at Reference Conditions ($f = 0.0020/0.0020$)

Cooler	Limiting Flow Rate	$Q_{required}$ (BTU/hr)	$Q_{available}$ (BTU/hr)	Margin (BTU/hr)	Margin (%)
1(2)VY01A	75 gpm	517,239	675,177	157,938	30.53
1(2)VY02A	115 gpm	646,235	710,964	64,729	10.02
1(2)VY02A	108 gpm	646,235	707,030	60,795	9.41

The uncertainty in the analytical methodology used to identify the limiting flow for 1(2)VY02A is presented in Attachment J. The result of the uncertainty assessment is that the uncertainty in the PROTO-HX™ extrapolated heat transfer rate ranges from ± 4.27 to $\pm 4.88\%$ for the ranges of cooling water flow evaluated. An uncertainty of $\pm 4.90\%$ is used to conservatively bound the analysis of Attachment J. The adjusted thermal margin is calculated using Equation (11) after subtracting the uncertainty from the available heat rate. The results are presented in Table 10 below.

Table 10: Limiting Cooling Water Flow Rate at Reference Conditions ($f = 0.0020/0.0020$)

Cooler	Limiting Flow Rate	$Q_{required}$ (BTU/hr)	$Q_{available}$ (BTU/hr)	Nominal Margin (%)	Adjusted Margin (%)
1(2)VY01A	75 gpm	517,239	675,177	30.53	24.14
1(2)VY02A	115 gpm	646,235	710,964	10.02	4.62
1(2)VY02A	108 gpm	646,235	707,030	9.41	4.05

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 21 OF 23
	ORIGINATOR L. Philpot		DATE 6/24/98
	VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

7.4 Fouling Sensitivity Analysis

The results of the fouling sensitivity analysis are included in Tables 11 and 12. The PROTO-HX™ reports associated with the fouling sensitivity analysis for both coolers and a graphical presentation of the results are included as Attachment M. The 108 gpm Case is used to represent the 1(2)VY02A coolers since this flow rate will bound that of the 115 gpm Case. It should be noted that neither the Tables below or the figure in Attachment M have taken analytical uncertainty into account since the intent of this exercise is to assess the change in thermal margin (i.e., the slope of the curves in Attachment M). Analytical uncertainty treated as a bias on the results will have a negligible effect on the slope of the curves. Consideration of uncertainty would, however, change the point at which a thermal margin of 0% is reached.

Table 11: Fouling Sensitivity Analysis -- 1(2)VY01A at 75 gpm

Air-Side f	Tube-Side f	Required q	Available q	%Margin
0.0020	0.0000	517,239	723,937	39.96%
0.0020	0.0010	517,239	698,599	35.06%
0.0020	0.0020	517,239	675,177	30.53%
0.0020	0.0030	517,239	651,570	25.97%
0.0020	0.0040	517,239	630,961	21.99%

Table 12: Fouling Sensitivity Analysis -- 1(2)VY02A at 108 gpm

Air-Side f	Tube-Side f	Required q	Available q	%Margin
0.0020	0.0000	646,235	756,011	16.99%
0.0020	0.0010	646,235	731,028	13.12%
0.0020	0.0020	646,235	707,030	9.41%
0.0020	0.0030	646,235	683,298	5.74%
0.0020	0.0040	646,235	660,999	2.28%

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-200	REV A	PAGE 22 OF 23
	ORIGINATOR L. Philpot	DATE 6/24/98	
	VERIFIED BY M. Aboye	JOB NO. 31-003	
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing		
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A			

8. CONCLUSIONS

A model for the LaSalle County Station Units 1 & 2 NW and SW Cubicle Area Coolers was developed using PROTO-HX™ Version 3.01. The model was benchmarked and validated using the performance specifications provided by the cooler vendor. The close correlation with vendor specified and model predicted thermal performance confirms that the model is to be considered acceptable for use in the GL 89-13 heat exchanger testing program and related performance analyses.

The available thermal margin for the coolers has been defined for the nameplate rated flow of 150 gpm and for reduced flow rates of 75 gpm, 108 gpm, and 115 gpm in support of service water system flow requirements. Inclusion of a conservative assessment of the uncertainty in the analytical methods of PROTO-HX™ has provided high confidence in the thermal margins defined by the model for all cases.

The model database is saved under file name vy-0102a.phx, with a file size of 1,146,880 bytes, and a file date and time of 6/24/98 at 2:25:30 pm. The saved database is set up to run the 108 gpm case with adjusted design fouling factors of 0.002 air-side and 0.002 tube-side. The database file is included as Attachment N.

9. REFERENCES

1. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.01 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision E, dated 11/5/97
2. LaSalle Calculation L-001078, Revision 2, RHR Pump A Cubicle Cooler Ventilation System
3. LaSalle Calculation L-001221, Revision 2, HPCS Pump Cubicle Cooler Ventilation System
4. LaSalle Station Updated Final Safety Analysis Report, Table 3.11-8, Harsh Environment Zone H6 -- Bounding Environmental Conditions Inside the ECCS Cubicles (Attachment A)
5. LaSalle Station Updated Final Safety Analysis Report, Section 9.2.1, ECCS Equipment Cooling Water System (Attachment A)
6. LaSalle Station Updated Final Safety Analysis Report, Section 9.2.6, Ultimate Heat Sink (Attachment A)

PROTO-POWER CORPORATION GROTON, CONNECTICUT		CALC NO. 97-200	REV A	PAGE 23 OF 23
		ORIGINATOR L. Philpot		DATE 6/24/98
		VERIFIED BY M. Aboye		JOB NO. 31-003
CLIENT Commonwealth Edison	PROJECT LaSalle Station GL 89-13 Heat Exchanger Testing			
TITLE VY Cooler Thermal Performance Model -- 1(2)VY01A and 1(2)VY02A				

7. Drawing 28SW404543, "CSCS Equipment Area Cooling Coils," original issue, 7/21/76 (Attachment A)
8. LaSalle Calculation L-000581, Revision 0, Evaluation of the CSCS Cubicle Area Coolers Operation with a Reduced Cooling Water Inlet Temperature
9. Drawing M-87, Sheet 3, "CSCS Equipment Cooling Water System," Revision F dated 5/4/88
10. Drawing M-134, Sheet 3, "CSCS Equipment Cooling Water System," Revision F dated 5/25/82
11. Bahnson Drawings 2605-1-11,12,13, & 14 (Attachment A)
12. Standards of the Tubular Exchanger Manufacturers Association (TEMA), Seventh Edition, 1988
13. Specification Number J-2582, Heat Exchange Coils and Cabinets, La Salle County - Units 1 and 2, Revision 1, dated 1/16/75 (Attachment A)
14. Proto-Power Calculation 96-069, Revision -, Fluid Properties - Moist Air - Range 8° to 300°F
15. *Compact Heat Exchangers*, W.M. Kays and A.L. London, McGraw Hill, Third Edition, 1984. (excerpt - Attachment C)
16. 1997 ASHRAE Handbook -- Fundamentals, inch pound Edition, American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., Atlanta, GA (excerpt - Attachment A)
17. Drawing M-1366, Sheet 2, "Reactor Building Ventilation System -- Elevation 694'-6" West," Revision F dated 5/17/82
18. Drawing M-1464, "CSCS Equipment Cooling System," Revision B dated 5/12/88
19. Drawing M-1465, "CSCS Equipment Cooling System," Revision B dated 5/12/88
20. Coil Walkdown Data, ComEd NDIT No. LS-0835 (Attachment L)

**Attachment A to
Proto-Power Calculation
97-200
Revision A**

Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 1 of 1213

FEB 6/22/98

Reference 4

LSCS-UFSAR

TABLE 3.11-8

HARSH ENVIRONMENT ZONE H6 - BOUNDING ENVIRONMENTAL
CONDITIONS INSIDE THE ECCS CUBICLES
(EXCLUDING LPCS/RCIC CUBICLE) IN THE REACTOR BUILDING

WHEN THE ECCS EQUIPMENT IS OPERATING



The maximum cubicle temperature is 148°F, 90% relative humidity and at atmospheric pressure for the duration of 100 days. The total number of hours the cubicle is at 148°F will be ~22,110 hours (~921 days). The 100 days accident conditions are included.

Radiation: 1×10^7 rads gamma (integrated)

Pressure: -0.4 inch W.G.

1(2) VY01A
1(2) VY02A

NOTE: The bounding radiation dose \geq (normal service radiation dose integrated over 40 years + accident does + 10% margin on the accident dose per IEEE 323-1974, Section 6.3.2.5).


Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 2 of ~~12~~¹³ *FEL 6/22/98*

TABLE 3.11-8

REV. 6 - APRIL 1990

- 
4. RHR pump seal cooler ('A' and 'B' RHR pumps only) - 20 gpm
 5. LPCS pump motor cooling coil - 4 gpm
 6. northwest cubicle area cooling coil - 150 gpm
 7. southwest cubicle area cooling coil - 150 gpm
 8. northeast cubicle area cooling coil - 200 gpm
 9. southeast cubicle area cooling coil - 180 gpm
 10. emergency makeup to fuel pool - 50 gpm minimum
 11. containment flood - 300 gpm maximum.

- b. System classifications are as shown in Section 3.2. All portions of this system are protected from the effects of tornados, missiles, pipe whip, and flooding.
- c. To meet single failure criteria, the CSCS-ECWS for each unit is designed as three independent subsystems, one of which is shared between units (Drawing Nos. M-87 and M-134).
- d. Strainers are provided to prevent plugging of cooled component heat transfer passages. All strainers include provisions for backwashing without significantly affecting system operation.

Organic fouling of heat transfer surfaces will be minimized by the chemical feed system which will treat the service water tunnel inlet flow with oxidizing biocides. However, the chemical feed system should not be considered auxiliary equipment required for the CSCS-ECW systems to perform their function. Therefore, the operability of the CSCS-ECW systems should not be tied to the operability of the chemical feed system. Connections and isolation valves are also provided immediately upstream and downstream of each cooled component for injection and circulation of biocidal agents, if necessary.

- e. To detect leakage of radioactivity to the environment, radiation monitors are installed in the CSCS-ECWS immediately downstream of cooled components that contain radioactive fluids. The CSCS-ECWS discharge lines from these components are capable of remote manual isolation from the main control room.
- f. Design of system piping and components is based on a 40-year life. Exterior surfaces of all buried system piping is protected by bituminous coatings and wrappings and provisions for cathodic protection are installed where such protection is found to be required based on electrical potential measurements. The design of all system piping includes a corrosion allowance of at least 0.08 inches.

Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 3 of 13 *JEP 6/22/78*

the normally closed portions the integrity and operability are checked.


9.2.6 Ultimate Heat Sink

The ultimate heat sink (UHS) provides sufficient cooling water to permit the safe shutdown and cooldown of the station for 30 days with no makeup for both normal and accident conditions.

9.2.6.1 Design Bases

9.2.6.1.1 Safety Design Bases

The ultimate heat sink has the following design bases:

- 
- a. to provide sufficient water volume permitting a safe shutdown and cooldown of the station for 30 days with no water makeup for both normal operating and accident conditions - the maximum permissible water temperature supplied to the plant is taken as 100° F;
 - b. to withstand the most severe postulated natural phenomenon as discussed in Chapter 2.0;
 - c. to withstand the postulated site-related incidents as discussed in Subsection 2.5.5; and
 - d. to provide water for fire protection equipment.

A more detailed physical description of the ultimate heat sink is provided in Sections 2.4 and 2.5.

9.2.6.1.2 Power Generation Design Bases

The ultimate heat sink, as a safety system, is not used during normal plant operations. Therefore, the ultimate heat sink has no power generation bases.

9.2.6.2 System Description

In the unlikely event that the main dike is breached, the cooling lake for the La Salle County Station is designed to hold 460 acre-feet of water with a surface area of 83 acres. This remaining water constitutes the ultimate heat sink for the station, and has a depth of approximately 5 feet and a top water elevation established at 690 feet. Figures 2.4-4 and 9.2-1 illustrate the physical layout and area capacity of the ultimate heat sink.

9.2.6.3 Safety Evaluation

The station's ultimate water requirements (Units 1 and 2) in gpm are summarized below.

Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 4 of 12

72P 6/22/98
12/13

INDIVIDUAL COIL				PER COIL							TOTAL (TOTAL FOR BOTH COILS)							
TUBE FACE	ROWS	CIRCUIT -ING	FACE AREA (SQ. FT.)	MARK FOR	SCFM	ENT. AIR TEMP (°F) DB/WB	LVG. AIR TEMP (°F) DB/WB	ENT. WATER TEMP (°F)	LVG. WATER TEMP (°F)	WATER GPM	TOTAL HEAT TRANSFER (BTU/H/10 ⁴)	AIR SIDE PRESS. DROP (IN. W2O)	TUBE SIDE PRESS. DROP (FT. OF 1120)	DESIGN PRESSURE (PSIG)	DESIGN TEMP (°F)	COIL QTY. PER UNIT	SHIPPING WGT. (LBS) PER COIL	OPERATING WGT. (LBS) PER COIL
20	8	FULL	21.4	1VY01A, 1VY02A 2VY01A, 2VY02A	17330	150./92.	109A/84.1	105.0	115.3	150.	.75	.42	27.0	250	200	2	875	1025


MATERIAL SPECIFICATIONS

TUBES - 3/8" O.D. ASME SB75 COPPER, .049 WALL THICKNESS.


FINS - ASTM B209 ALUM. 0.012 IN. THK. SPIRAL TYPE MECHANICAL BOND, 10.0 FINS/INCH.

HEADERS - 2 1/2" NOM. SCH. 80 BLACK STEEL PIPE ASTM A53

CASING - ASTM A326, 14 GA. GALV. STEEL



COIL MOUNTING CONFIGURATION



Reference 7



The drawings of the property of Carrier Corporation - Syracuse, New York are not to be reproduced or used in any way without the written consent of Carrier Corporation.

Proto-Power Calc: 97-200
Attachment: A
Rev: A Page 5 of 12 1/3
250 C/W/H

GENERAL TOLERANCES
DECIMALS ±.12
UNLESS OTHERWISE SPECIFIED
DIMENSIONS IN INCHES

JOB NAME: LASALLE COUNTY POWER STATION-UNIT #1/2
 JOB LOCATION: SENECA, ILLINOIS
 BUYER: COMMONWEALTH EDISON COMPANY
 BUYER NO. 194871 CARRIER NO. 690002059
 DIMENSIONS CERTIFIED BY: *A. Schuler* DATE 7-21-76







DRAWN BY	THOMSON	6-17-76
CHECKED BY	RDB	7-21-76

DATE: _____ SUPERSEDES: _____

CSCS EQUIPMENT AREA COOLING COILS

EQUIPMENT NO. (S)	DWG. NO.	REV.
1VY01A, 1VY02A 2VY01A, 2VY02A	28SW404543	

LASALLE COUNTY BOARD STA. UNIT 5-62
 ANTHONY W. SENECA, III
 PUBLIC HEALTH DEPARTMENT
 1111 S. 1ST ST. ST. LOUIS, MO. 63102




- BILL OF MATERIALS**
- UNIT COOLER DESIGNED TO COOL 17,770 CFM FOR 150°F TO 75°F WITH 17 WHP. 150 GPM OF WATER FROM 80°F TO 115°F COMPLETE WITH THE FOLLOWING CONSTRUCTION AND EQUIPMENT. FACTORY ORDER NO. B-08512-130.
 - GROUP OF INTERNAL STRUCTURAL FRAMING (SPEC. 2), FACTORY ORDER NO. B-08512-132A.
 - GROUP OF ENCLOSURE PANELS (SPEC. 3), FACTORY ORDER NO. B-08512-130B.
 - STRUCTURAL STEEL BASE WITH LIFTING (BOLTS (SPEC. 5), FACTORY ORDER NO. B-08512-130C).
 - ACCESS DOORS (SPEC. 4), FACTORY ORDER NO. B-08512-130D.
 - COOLING COILS 20 FT. X 40 FT. 8 ROWS FULL (SPEC. 6) WATER PRESSURE DROP 0.42 TO 0.45 PSI, WATER PRESSURE DROP 20 FT. WATER (SPEC. 6 & 6A), FACTORY ORDER NO. B-08512-130E.
 - COOLING COIL DRAP PANELS CONSTRUCTED FROM 16 GA. 304 STAINLESS STEEL, FACTORY ORDER NO. B-08512-130F.

(SARGENT & LUNDY SPEC. J2582)
SAFETY RELATED

SEE DWG 2505-1-6 FOR MAT'L SPEC'S
 SHIPPING WEIGHT 3150#
 OPERATING WEIGHT 3450#

LEFT HAND UNIT
 ALL DIMENSIONS ± 1/8"



Reference 11

Proto-Power Calc: 97-200





Attachment: A
 Rev: A Page 6 of 12/13

DATE	REVISED	BY
5-4-77	BBC-100-9	REVI


BCOA	DATE	BAHNSON DWG. NO.	2805-11
CSCS EQUIPMENT AREA AIR HANDLING UNIT			UNIT NO. 1VY01A

DRAWN BY	DATE	CHECKED BY	DATE
BBC	5-1-76	BBC	5-1-76
BBC-100-9			


Handwritten signature/initials




ELEVATION
 Proto-Power Calc: 97-200
 Attachment: A
 Rev: A Page 7 of 1213
 JEP 6/22/98



INLET DUCT CONNECTION PLAN



ANCHOR BOLT PLAN




PIPING CONNECTION DETAIL
 NOT TO SCALE
 CSCS EQUIPMENT AND AIR HANDLING UNIT
 ZVY01A

- ALL OF INTERIOR
1. UNIT COILER DESIGNED TO COOL 17,700 BTU/HR AT 100% LOAD BY USING 150 GPM OF WATER FROM 60°F TO 55.5°F COMPLETE WITH THE FOLLOWING CONSTRUCTION AND EQUIPMENT, FACTORY ORDER NO. 0-00510-1300
 2. GROUP OF INTERNAL STAINLESS STEEL (SPEL. 2), FACTORY ORDER NO. 0-00510-1300
 3. GROUP OF EXCLUSIVE PANELS (SPEL. 1), FACTORY ORDER NO. 0-00510-1300
 4. STRUCTURAL STEEL BASE WITH LIFTING LUGS (SPEL. 3), FACTORY ORDER NO. 0-00510-1300
 5. ACCESS DOORS (SPEL. 0), FACTORY ORDER NO. 0-00510-1300
 6. COILING GAUGE 20 078 000 000 0 0000 FULL (SPEL. 0) 750,000 BTU/HR AIR PRESSURE 0.50 IN. WATER, WATER PRESSURE 100 PSIG, WATER (SPEL. 0) 1 GA., FACTORY ORDER NO. 0-00510-1300
 7. COILING COIL BRP FULL CONTAINER FROM 60 G. 200 STAINLESS STEEL, FACTORY ORDER NO. 0-00510-1300

SARGENT & LUNDY SPEC J-2502
 SAFETY RELATED

SEE DWG. 2605-1-B FOR MAIL SPECS
 SHIPPING WEIGHT 5450
 OPERATING WEIGHT 5450





LEFT HAND UNIT
 ALL DIMENSIONS ± 1/8"



DRAWN BY: [Signature]
 CHECKED BY: [Signature]

Reference II

LASALLE COUNTY POWER STA. UNITS 1&2
 SENECA, ILLINOIS
 CHRYSLER HEALTH EPSON, CO
 DRAWING NO. 2605-1-B




- BILL OF MATERIALS**
- UNIT COOLER DESIGNED TO COOL 17,500 CFM OF AIR AT 80°F TO 55°F USING 150 GPM OF WATER FROM 105.0°F TO 100.0°F. COMPLETE WITH THE FOLLOWING CONSTRUCTION AND EQUIPMENT. FACTORY ORDER NO. 0-00524-130A.
 - GROUP OF INTERNAL STRUCTURAL FRAMING (SPEC. 27). FACTORY ORDER NO. 0-00524-130A.
 - GROUP OF ENCLOSURE PANELS (SPEC. 31). FACTORY ORDER NO. 0-00524-130B.
 - STRUCTURAL STEEL BASE WITH LIFTING LUGS (SPEC. 32). FACTORY ORDER NO. 0-00524-130C.
 - ACCESS DOORS (SPEC. 41). FACTORY ORDER NO. 0-00524-130D.
 - COILING COILS TO FIT THE 100 H.P. 8 WIND FULL CURRENT MOTOR 750,000 BTU/HR AIR PRESSURE DROP 0.42 IN. WATER. WATER PRESSURE DROP 27 FT. WATER (SPEC. 8 & 9A). FACTORY ORDER NO. 0-00524-130E.
 - COILING COIL W/UP FANS CONSTRUCTED FROM 30 GA. 304 STAINLESS STEEL. FACTORY ORDER NO. 0-00524-130F.

ARGENT & LUNDY SPEC J-2542
SAFETY RELATED

SHIPPING WEIGHT 5150"
OPERATING WEIGHT 5450"

SEE DWG. 26054-6 FOR MATL SPECS

RIGHT HAND UNIT
ALL DIMENSIONS



DATE	REV	DESCRIPTION	BY	DATE	BY	DATE	BY	DATE	BY
11/17	1	REV 1	BBC	11/17	BBC	11/17	BBC	11/17	BBC
CSCS EQUIPMENT AREA AIR HANDLING UNIT			UNIT NO 1V102A		BAHNSON DWG. NO 2605-112		DRAWN BY J. J. B. K.		CHECKED BY J. J. B. K.
BBC-100-10								2	

Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 8 of 12/13

JEP 11/22/13



Reference 11

LABALLE COUNTY WATER SYSTEMS & UTILITIES
SERVISE, MISSISSIPPI
COMMUNITY HEALTH EPIDEMIOLOGY
LABORATORY
PO BOX 1187
SERVISE, MISSISSIPPI 39075


ALL DIMENSIONS UNLESS NOTED OTHERWISE

Calliper


PLAN



INLET DUCT CONNECTION PLAN



ANCHOR BOLT PLAN



PIPING CONNECTION DETAIL

NOT TO SCALE


- LIST OF MATERIALS
1. UNIT COILED DESIGN TO (ENR 17) SPECIFICATIONS FOR AIR HANDLING UNITS USING 100 MPH OF WIND SPEED WITH 125 MPH EXCESSIVE WINDS FOLLOWING CONSTRUCTION AND EQUIPMENT FACTORY TESTS TO BE CONDUCTED.
 2. GAUGE OF EXTERIOR STRUCTURAL PLATE (SPEC. 11) FACTORY ORDER NO. 0-750P-1700.
 3. GAUGE OF EXTERIOR FRIG. (SPEC. 11) FACTORY ORDER NO. 0-750P-1700.
 4. STRUCTURAL STEEL BRACE INTO LIFTING LINES (SPEC. 11) FACTORY ORDER NO. 0-750P-1700.
 5. ACCESS BRIMS (SPEC. 11) FACTORY ORDER NO. 0-750P-1700.
 6. COILING COILS TO BE 100% 1/2 & 3/4 INCH DIA. COILING COILS PER 1000 SQ. IN. PRESSURE DROP 0.42 IN. WATER, WIND SPEED 125 MPH. WIND SPEED 0 & 100. FACTORY ORDER NO. 0-750P-1700.
 7. COILING COIL BRACE PLATE CONSTRUCTED FROM 1/4 IN. DIA. 304 STAINLESS STEEL.

SARGENT & Lundy SPEC. 100122 RELATED

SHIPPING WEIGHT 5450
OPERATING WEIGHT 5450

SEE DWG 2605-4-6 FOR MATL. SPEC'S

RIGHT HAND UNIT ALL DIMENSIONS ± 1/8"




GRAPHIC SCALE

DATE	REV	BY	CHKD BY
02/04		BAHNSON DWG NO 2605-4-6	
DATE	REV	BY	CHKD BY

CSCS EQUIPMENT AREA AIR HANDLING UNIT UNIT NO 2102A

Reference 11

LASSALLE COUNTY INDEPENDENT CONTRACTORS ASSOCIATION
1000 S. W. 10th St., Ft. Lauderdale, FL 33304
Tel: (305) 555-1100
Fax: (305) 555-1101
www.lcica.com
LASSALLE COUNTY INDEPENDENT CONTRACTORS ASSOCIATION
1000 S. W. 10th St., Ft. Lauderdale, FL 33304
Tel: (305) 555-1100
Fax: (305) 555-1101
www.lcica.com



Reference 13

"SAFETY RELATED ITEMS ARE PART OF THIS SPECIFICATION"

Client CECO

Specification Title Heat Exchange Coils and Cabinets

Specification Number J-2582

Project Identification La Salle County - Units 1 and 2

Project Number 4266-00/4267-00

Department Mechanical/HVAC

REV	DATE	PREPARER	APPROVER	PURPOSE OF ISSUE
1	1-16-75	P. N. Mehrotra	W. C. Brown	Issue to CECO for bids.

Proto-Power Calc: 97-200

Attachment: A

Rev: A Page 10 of 1213

JEP 6/22/98

Function or Service.....

Equipment Numbers.....

Safety related or Nonsafety related (SR or NSR).....

403. PERFORMANCE DATA (HEAT EXCHANGE COIL CABINETS)

403.1 Mode of Operation.....

- a. Entering Air Dry Bulb.....(°F)
- b. Entering Air Wet Bulb.....(°F)
- c. Leaving Air Dry Bulb.....(°F)
- d. Leaving Air Wet Bulb.....(°F)
- e. Actual Air Quantity at 70°F, 40% RH and Site Elevation,(ft³/min)
- f. Standard Air Quantity at .075 lb/ft³.....(Std ft³/min)
- g. Cooling Medium.....
- h. Evaporator Refrigerant Temperature.....(°F)
- i. Entering Water Temperature.(°F)
- j. Maximum Water Quantity(gal/min)
- k. Minimum Total Heat Exchange Capacity(Btu/h)
- l. Minimum Sensible Heat Exchange Capacity(Btu/h)
- m. Maximum Coil Face Velocity(ft/min)

Control Room	Auxiliary Electric Equipment	Primary Containment Vent.	CSCS Eqpt. Area Cooling	CSCS Eqpt. Area Cooling	CSCS Eqpt. Area Cooling
OVC02AA OVC02AB	OVE01AA OVE01AB	1VP03AA 1VP03AB 2VP03AA 2VP03AB	1VY01A 1VY02A 2VY01A 2VY02A	1VY03A 2VY03A	1VY04A 2VY04A
SR	SR	NSR	SR and ASME III	SR and ASME III	SR and ASME III
Cooling	Cooling	Cooling	Cooling	Cooling	Cooling
81.8	81.9	135	150	150	150
63.1	63.2	92	---	---	---
54.3	54.9	65	110	110	110
52.8	53.2	63	---	---	---
26340	31300	50000	18000	26400	28500
25380	30100	48150	17330	25420	27450
R-22	R-22	Chilled Water	Water	Water	Water
42	42	---	---	---	---
---	---	46	105.	105.	105.
---	---	1200	150.	220.	240
797,000	936,000	6.55x10 ⁶	748,700	1.1 x 10 ⁶	1.19 x 10 ⁶
725,000	847,000	3.63x10 ⁶	748,700	1.1 x 10 ⁶	1.19 x 10 ⁶
600	600	600	700	700	700

Add.1
Add.1
Add.1
Add.1
Add.1

Reference 13

J-2582
Add. 1



Proto-Power Calc: 97-200
Attachment: A
Rev. A Page 11 of 12/13
JSP 6/22/98

Table IA Heating and Wind Design Conditions—United States

Station	WMO#	Lat.	Long.	Elev. ft	StdP psia	Dates	Heating DB					Extreme Wind Speed		Coldest Month WS/MB		Annual Extreme Daily							
							99.6%	99%	1%	2.5%	5%	WS	MB	WS	MB	MWS	PWD	MWS	PWD	Max	Min	Max	Min
West Palm Beach	722130	26.68	80.12	20	14.685	6193	43	47	24	21	19	24	60	21	70	9	320	12	110	94	15	2.0	5.0
GEORGIA																							
Albany	722160	31.53	84.18	194	14.591	8293	27	30	19	17	15	19	50	18	50	4	360	9	250	100	17	2.2	7.2
Atlanta	722110	33.95	83.32	810	14.270	6193	20	25	19	17	15	20	40	18	40	10	290	9	270	98	11	3.5	6.6
Atlanta	722190	33.65	84.42	1033	14.155	6193	18	24	22	19	17	23	37	21	36	12	320	9	300	96	9	3.5	7.3
Augusta	722180	33.37	81.97	148	14.617	6193	21	25	20	18	15	21	48	19	46	5	290	9	250	100	13	3.7	5.6
Brunswick	722137	31.15	81.38	20	14.685	8293	30	34	18	17	16	19	49	18	49	8	350	10	250	98	22	2.5	7.0
Columbus, Fort Benning	722140	32.33	85.00	233	14.572	8293	23	27	16	15	11	17	46	15	46	3	320	8	240	100	14	2.9	6.7
Columbus, Mearns Airport	722255	32.52	84.93	397	14.486	6193	23	27	17	15	14	18	44	16	46	7	310	9	310	99	14	2.3	6.1
Macon	722170	32.70	83.65	361	14.503	6193	23	27	19	17	15	20	46	18	45	7	320	9	270	100	14	2.7	6.4
Marietta, Dobbins AFB	722270	33.92	84.52	1070	14.136	8293	21	26	18	16	13	20	35	18	38	9	340	6	300	97	12	3.6	6.7
Roswell	723200	34.35	85.17	643	14.357	8293	15	21	14	12	10	14	42	13	42	5	340	6	270	98	4	3.8	7.0
Savannah	722070	32.13	81.20	49	14.669	6193	26	29	20	17	15	21	49	19	49	7	270	9	270	98	18	3.0	5.4
Valdosta, Moody AFB	747810	30.97	83.20	233	14.572	8293	30	34	15	13	12	16	53	14	52	4	360	5	300	99	21	2.5	7.6
Valdosta, Regional Airport	722166	30.78	83.28	203	14.588	8293	28	31	17	15	14	18	55	16	56	4	340	8	300	99	17	3.2	7.7
Waycross	722130	31.25	82.40	151	14.615	8293	29	32	16	14	12	16	52	14	52	4	250	7	240	98	21	7	7.6
HAWAII																							
Ewa, Barbers Point NAS	911780	21.32	158.07	49	14.609	8293	59	61	20	18	16	22	73	19	75	5	40	11	60	93	35	1.6	21.4
Hilo	912850	19.72	155.07	36	14.676	6193	61	63	19	16	14	21	76	18	76	7	230	12	110	88	58	1.6	1.8
Honolulu	911820	21.35	157.93	16	14.687	6193	61	63	23	21	20	23	74	21	75	5	320	15	60	91	58	1.9	2.2
Kahului	911900	20.90	156.43	66	14.661	6193	59	61	27	25	24	32	76	28	76	6	160	19	50	92	54	1.5	4.7
Kaneohe, MCAS	911760	21.45	157.77	10	14.690	8293	67	68	20	18	17	21	74	19	74	7	190	10	70	88	40	1.4	29.0
Lihue	911650	21.98	159.35	148	14.617	6193	60	62	26	24	21	25	73	23	73	8	270	14	60	87	57	1.4	1.0
Molokai	911860	21.15	157.10	449	14.458	8293	60	61	24	22	21	22	74	21	74	4	70	13	60	92	43	4	22.0
IDAHO																							
Boise	726810	43.57	116.22	2867	13.235	6193	2	9	24	21	18	22	37	19	37	6	130	11	320	104	-4	2.7	9.1
Burley	725867	42.55	113.77	4150	12.621	8293	-5	2	23	21	19	23	30	22	28	7	60	8	280	98	-11	4	8.5
Idaho Falls	725785	43.52	112.07	4741	12.346	8293	-12	-6	27	23	21	28	32	23	29	7	360	12	180	96	-20	3.6	9.0
Lewiston	727830	46.38	117.02	1437	13.948	8293	6	15	20	17	14	24	38	20	40	5	280	7	310	103	3	2.7	9.9
Mountain Home, AFB	726815	43.05	115.87	2995	13.173	8293	0	5	23	21	18	23	33	21	31	2	90	8	350	105	-6	3.2	8.5
Mullan	727836	47.47	115.80	3317	13.017	8293	-1	7	10	10	9	11	18	9	21	2	10	4	10	92	-7	2	7.9
Pocatello	725780	42.92	112.60	4478	12.468	6193	-7	0	29	25	23	30	36	27	36	6	50	11	250	98	-15	2.3	9.1
ILLINOIS																							
Belleville, Scott AFB	724338	38.55	89.85	453	14.457	8293	3	10	21	18	15	23	32	20	31	7	360	7	190	100	-3	3.1	7.2
Chicago, Meigs Field	725340	41.78	87.75	623	14.367	8293	-4	3	23	22	19	26	17	23	30	12	240	13	220	97	-10	3.2	8.1
Chicago, O'Hare Int'l A	725300	41.98	87.90	673	14.342	6193	-6	-1	26	23	21	27	24	23	23	10	270	12	230	96	-12	2.8	6.5
Decatur	725316	39.83	88.87	682	14.337	8293	-2	3	24	22	20	27	24	24	27	13	310	12	210	99	-10	5.8	8.2
Glenview, NAS	725306	42.08	87.82	653	14.352	8293	-3	4	22	19	17	23	17	20	25	11	250	10	240	98	-10	3.1	7.7
Marseilles	744600	41.37	88.68	738	14.308	8293	-5	1	26	22	20	28	18	25	21	12	290	10	250	96	-11	4	5.9
Moline/Deavenport IA	725440	41.45	90.52	594	14.383	6193	-8	-3	26	23	20	28	16	24	18	9	290	12	200	97	-14	2.7	6.0
Peoria	725320	40.67	89.68	663	14.347	6193	-6	-1	25	22	20	26	16	23	19	9	290	11	180	96	-12	3.3	6.1
Quincy	724396	39.95	91.20	768	14.292	8293	-4	2	26	23	20	28	23	24	22	12	330	12	210	97	-10	3.6	8.0
Rockford	725430	42.20	89.10	741	14.306	6193	-10	-4	26	23	21	26	18	23	20	9	290	13	200	95	-16	3.1	5.5
Springfield	724390	39.85	89.67	614	14.373	6193	-4	2	25	23	21	27	25	24	27	10	270	12	230	97	-11	2.8	5.5
West Chicago	725305	41.92	88.25	758	14.297	8293	-7	0	23	21	19	25	13	23	20	11	290	11	240	96	-14	3.2	7.7
INDIANA																							
Evansville	724320	38.05	87.53	387	14.491	6193	3	9	22	19	17	22	33	20	34	7	320	9	240	97	-4	2.7	8.5
Fort Wayne	725330	41.00	85.20	827	14.262	6193	-4	2	25	23	20	27	19	24	22	10	250	12	230	95	-11	3.6	5.2
Indianapolis	724380	39.73	86.27	807	14.272	6193	-3	3	24	21	19	25	26	22	27	8	230	11	230	94	-10	2.8	6.8
Lafayette, Purdue Univ	724386	40.42	86.93	607	14.376	8293	-5	3	22	20	18	24	26	22	27	9	270	12	220	97	-11	3.8	7.7
Peru, Grissom AFB	725335	40.65	86.15	810	14.270	8293	-3	4	24	21	18	29	20	24	22	11	270	9	210	96	-8	3.8	7.4
South Bend	725350	41.70	86.32	774	14.289	6193	-2	3	25	23	20	26	22	23	23	13	230	12	230	95	-10	3.3	5.8
Terre Haute	724373	39.45	87.32	584	14.388	8293	-3	5	23	20	18	23	31	21	32	8	150	11	230	96	-10	3.2	7.9
IOWA																							
Burlington	725455	40.78	91.13	699	14.328	8293	-4	1	21	19	17	24	12	21	18	9	310	11	200	98	10	4	6.8
Cedar Rapids	725450	41.88	91.70	869	14.240	8293	-11	-5	25	22	20	29	12	26	14	10	300	11	180	96	-15	3.6	5.4
Des Moines	725460	41.53	93.65	965	14.190	6193	-9	-4	27	24	21	28	14	24	19	11	320	12	180	98	-15	3.4	5.1
Fort Dodge	725490	42.55	94.18	1165	14.087	8293	-13	-7	27	23	21	29	10	26	10	11	340	11	190	96	-17	4.9	4.9
Lamoni	725466	40.62	93.95	1122	14.109	8293	-6	0	19	17	15	21	23	19	20	7	320	9	210	97	-12	4.3	6.8
Atason City	725485	43.15	93.33	1214	14.062	6193	-15	-10	27	23													

Table 3 Properties of Solids

Material Description	Specific Heat, Btu/lb-°F	Density, lb/ft ³	Thermal Conductivity, Btu/ft-°F	Emissivity	
				Ratio	Surface Condition
Aluminum (alloy 1100)	0.214 ^b	171 ^a	128 ^a	0.09 ^a 0.20 ^a	Commercial sheet Heavily oxidized
Aluminum bronze (76% Cu, 22% Zn, 2% Al)	0.09 ^a	517 ^a	58 ^a		
Asbestos: Fiber Insulation	0.25 ^b 0.20 ^f	150 ^a 36 ^b	0.097 ^a 0.092 ^b	0.93 ^b	"Paper"
Ashes, wood	0.20 ^f	40 ^b	0.041 ^b (122)		
Asphalt	0.22 ^b	132 ^b	0.43 ^b		
Bakelite	0.35 ^b	81 ^a	9.7 ^a		
Bell metal	0.086 ^f (122)				
Bismuth tin	0.040 ^a		37.6 ^a		
Brick, building	0.2 ^b	123 ^a	0.4 ^b	0.93 ^a	
Brass: Red (85% Cu, 15% Zn) Yellow (65% Cu, 35% Zn)	0.09 ^a 0.09 ^a	548 ^a 519 ^a	87 ^a 69 ^a	0.030 ^b 0.033 ^b	Highly polished Highly polished
Bronze	0.104 ^f	530 ^f	17 ^d (32)		
Cadmium	0.055 ^a	540 ^f	53.7 ^b	0.02 ^d	
Carbon (gas retort)	0.17 ^a		0.20 ^b (2)	0.81 ^a	
Cardboard			0.04 ^b		
Cellulose	0.32 ^b	3.4 ^f	0.033 ^f		
Cement (portland clinker)	0.16 ^b	120 ^f	0.017 ^f		
Chalk	0.215 ^f	143 ^f	0.48 ^a	0.34 ^a	About 250°F
Charcoal (wood)	0.20 ^f	15 ^a	0.03 ^a (392)		
Chrome brick	0.17 ^b	200 ^b	0.67 ^b		
Clay	0.22 ^b	63 ^f			
Coal	0.3 ^b	90 ^f	0.098 ^f (32)		
Coal tars	0.35 ^b (104)	75 ^b	0.07 ^b		
Coke (petroleum, powdered)	0.36 ^b (752)	62 ^b	0.55 ^b (752)		
Concrete (stone)	0.156 ^b (392)	144 ^b	0.54 ^b		
Copper (electrolytic)	0.092 ^a	556 ^a	227 ^a	0.072 ^a	Commercial, shiny
Cork (granulated)	0.485 ^f	5.4 ^f	0.028 ^f (23)		
Cotton (fiber)	0.319 ^a	95 ^a	0.024 ^a		
Cryolite (AlF ₃ ·3NaF)	0.253 ^b	181 ^b			
Diamond	0.147 ^b	151 ^f	27 ^f		
Earth (dry and packed)		95 ^f	0.037 ^a	0.41 ^a	
Felt		20.6 ^b	0.03 ^b		
Fireclay brick	0.198 ^b (212)	112 ^f	0.58 ^b (392)	0.75 ^b	At 1832°F
Fluorspar (CaF ₂)	0.21 ^b	199 ^a	0.63 ^a		
German silver (nickel silver)	0.09 ^a	545 ^a	19 ^a	0.135 ^a	Polished
Glass: Crown (soda-lime)	0.18 ^b	154 ^a	0.59 ^f (200)	0.94 ^a	Smooth
Flint (lead)	0.117 ^b	267 ^a	0.79 ^f		
Heat-resistant "Wool"	0.20 ^b 0.157 ^b	139 ^f 3.25 ^f	0.59 ^f (200) 0.022 ^f		
Gold	0.0312 ^a	1208 ^a	172 ^a	0.02 ^a	Highly polished
Graphite: Powder Impervious	0.165 ^a 0.16 ^a		0.106 ^a 75 ^a	0.75 ^a	
Gypsum	0.259 ^b	78 ^b	0.25 ^b	0.903 ^b	On a smooth plate
Hemp (fiber)	0.323 ^a	93 ^a			
Ice: 32°F -4°F	0.487 ^f 0.465 ^f	57.5 ^b	1.3 ^b 1.41 ^a	0.95 ^a	
Iron: Cast Wrought	0.12 ^a (212)	450 ^b 485 ^b	27.6 ^b (129) 34.9 ^b	0.435 ^b 0.94 ^b	Freshly turned Dull, oxidized
Lead	0.0309 ^a	707 ^a	20.1 ^a	0.28 ^a	Gray, oxidized
Leather (sole)		62.4 ^b	0.092 ^b		
Limestone	0.217 ^b	103 ^b	0.54 ^b	0.36 ^a to 0.90	At 145 to 380°F
Linen			0.05 ^b		
Litharge (lead monoxide)	0.055 ^b	490 ^b			
Magnesia: Powdered Light carbonate	0.234 ^b (212)	49.7 ^b 13 ^b	0.35 ^b (117) 0.034 ^b		
Magnesite brick	0.222 ^b (212)	158 ^b	2.2 ^b (400)		
Magnesium	0.241 ^b	108 ^a	91 ^a	0.55 ^a	Oxidized
Marble	0.21 ^b	162 ^b	1.5 ^b	0.93 ^b	Light gray, polished
Nickel, polished	0.105 ^a	555 ^a	34.4 ^a	0.045 ^a	Electroplated
Paints: White lacquer White enamel Black lacquer Black shellac Flat black lacquer Aluminum lacquer				0.80 ^a 0.91 ^a 0.80 ^a 0.91 ^a 0.96 ^a 0.39 ^a	On rough plate "Matte" finish On rough plate

* Data source unknown.

Notes: 1. Values are for room temperature unless otherwise noted in parentheses

2. Superscript letters indicate data source from the section on References.


Proto. Power Calc: 97-100
Attachment: A
Rev: A Page 13 of 13

**Attachment B to
Proto-Power Calculation
97-200
Revision A**


LA SALLE COUNTY STATION
HEAT EXCHANGER
(WATER TO AIR)
DATABASE

EQUIPMENT NUMBER/ NAME	INSPECT DATE	B A S E	P H O T O	PHOTO STORAGE LOCATION	GENERAL APPEARANCE	TUBE CONDITION	FINS CONDITION	DEFECTS	CORRECTIVE	ACTIONS
									RECOMMENDED	ACTUAL
VY01C "A" RNR AREA COOLER	09/15/92	N	Y	BTM/XAPSHOT HX#1	VERY CLEAN. NO DEBRIS.	NO DAMAGE OR LEAKS FOUND.	CLEAN NO DEBRIS. A FEW FINS BENT.	NONE.	NONE NEEDED.	N/A

VY01A - Cooler
VY01C - Cooler Fan



VY01C OUTLET SIDE 9/15/92



VY01C INLET SIDE 9/15/92

LA SALLE COUNTY STATION
HEAT EXCHANGER
(WATER TO AIR)
DATABASE


EQUIPMENT NUMBER/ NAME	INSPECT DATE	B P A H S O E T	PHOTO STORAGE LOCATION	GENERAL APPEARANCE	TUBE CONDITION	FINS CONDITION	DEFECTS	CORRECTIVE	ACTIONS
								RECOMMENDED	ACTUAL
1VY02C HPCS AREA COOLER	09/01/92	N Y	BTN / XAPSHOT HX#1	VERY CLEAN. NO DEBRIS FOUND.	CLEAN. NO DAMAGE NOTICED.	JUST A FEW FINS BENT. GENERAL CONDITION IS VERY CLEAN.	NONE.	NONE.	N/A

VY02A - Cooler
VY02C - Cooler Fan



1VY02C INLET SIDE

9/1/92



1VY02C OUTLET SIDE

9/1/92

**Attachment C to
Proto-Power Calculation
97-200
Revision A**

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		CF-9.05-3/4J A
	$j = \text{EXP}[-2.3333 + -0.3441 * \text{LOG}(\text{Re})]$	
Coil Finned Length (in)		108.000
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	150.00
Air Flow (acfm)	21,179.00
Tube Inlet Temp (°F)	105.00
Air Inlet Temp (°F)	150.0
Inlet Relative Humidity (%)	0.00
Inlet Wet Bulb Temp (°F)	92.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Extrapolation Calculation Summary

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	150.00	105.00	j Factor	
Outlet Temperature (°F)	110.28	115.42	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,503.18
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	775,120
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	775,120
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,639.65
Inlet Temperature (°F)	150.00	112.82	j Factor	0.0095
Outlet Temperature (°F)	140.10	115.42	Air-Side ho (BTU/hr·ft ² ·°F)	10.20
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	145.05	114.12	U Overall (BTU/hr·ft ² ·°F)	6.72
Skin Temperature (°F)	122.46	116.51	Effective Area (ft ²)	937.90
Velocity ***	3,598.07	5.53	LMTD	30.66
Reynold's Number	848**	37,906	Total Heat Transferred (BTU/hr)	193,146
Prandtl Number	0.7254	3.8666	Surface Effectiveness (Eta)	0.9017
Bulk Visc (lbm/ft·hr)	0.0491	1.4247	Sensible Heat Transferred (BTU/hr)	193,146
Skin Visc (lbm/ft·hr)		1.3920	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.8006	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3680		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: C

Rev: A Page 4 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,618.86
Inlet Temperature (°F)	140.10	110.78	j Factor	0.0095
Outlet Temperature (°F)	132.32	112.82	Air-Side ho (BTU/hr-ft ² -°F)	10.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	136.21	111.80		
Skin Temperature (°F)	118.38	113.70	U Overall (BTU/hr-ft ² -°F)	6.69
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	857**	37,051	LMTD	24.20
Prandtl Number	0.7262	3.9648	Total Heat Transferred (BTU/hr)	151,828
Bulk Visc (lbm/ft-hr)	0.0485	1.4576		
Skin Visc (lbm/ft-hr)		1.4304	Surface Effectiveness (Eta)	0.9020
Density (lbm/ft ³)	0.0632	61.8343	Sensible Heat Transferred (BTU/hr)	151,828
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0160	0.3672	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,602.43
Inlet Temperature (°F)	132.32	109.17	j Factor	0.0095
Outlet Temperature (°F)	126.20	110.78	Air-Side ho (BTU/hr-ft ² -°F)	10.12
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	129.26	109.98		
Skin Temperature (°F)	115.17	111.49	U Overall (BTU/hr-ft ² -°F)	6.67
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	865**	36,382	LMTD	19.11
Prandtl Number	0.7267	4.0450	Total Heat Transferred (BTU/hr)	119,548
Bulk Visc (lbm/ft-hr)	0.0481	1.4844		
Skin Visc (lbm/ft-hr)		1.4620	Surface Effectiveness (Eta)	0.9024
Density (lbm/ft ³)	0.0639	61.8603	Sensible Heat Transferred (BTU/hr)	119,548
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0159	0.3665	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: C

Rev: A Page 5 of 8

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Extrapolation Calculation for Row 4(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,589.45
Inlet Temperature (°F)	126.20	107.91	j Factor	0.0094
Outlet Temperature (°F)	121.37	109.17	Air-Side ho (BTU/hr·ft ² ·°F)	10.09
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	123.78	108.54		
Skin Temperature (°F)	112.65	109.74	U Overall (BTU/hr·ft ² ·°F)	6.65
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	871**	35,858	LMTD	15.11
Prandtl Number	0.7271	4.1100	Total Heat Transferred (BTU/hr)	94,256
Bulk Visc (lbm/ft·hr)	0.0477	1.5061		
Skin Visc (lbm/ft·hr)		1.4878	Surface Effectiveness (Eta)	0.9026
Density (lbm/ft ³)	0.0644	61.8805	Sensible Heat Transferred (BTU/hr)	94,256
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3660	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,579.19
Inlet Temperature (°F)	121.37	106.91	j Factor	0.0094
Outlet Temperature (°F)	117.55	107.91	Air-Side ho (BTU/hr·ft ² ·°F)	10.07
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	119.46	107.41		
Skin Temperature (°F)	110.65	108.36	U Overall (BTU/hr·ft ² ·°F)	6.64
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	876**	35,447	LMTD	11.95
Prandtl Number	0.7274	4.1625	Total Heat Transferred (BTU/hr)	74,393
Bulk Visc (lbm/ft·hr)	0.0474	1.5235		
Skin Visc (lbm/ft·hr)		1.5087	Surface Effectiveness (Eta)	0.9028
Density (lbm/ft ³)	0.0648	61.8962	Sensible Heat Transferred (BTU/hr)	74,393
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: C

Rev: A Page 6 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,571.08
Inlet Temperature (°F)	117.55	106.12	j Factor	0.0094
Outlet Temperature (°F)	114.54	106.91	Air-Side ho (BTU/hr·ft ² ·°F)	10.05
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	116.05	106.51		
Skin Temperature (°F)	109.08	107.27	U Overall (BTU/hr·ft ² ·°F)	6.63
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	880**	35,123	LMTD	9.45
Prandtl Number	0.7277	4.2047	Total Heat Transferred (BTU/hr)	58,765
Bulk Visc (lbm/ft·hr)	0.0472	1.5376		
Skin Visc (lbm/ft·hr)		1.5256	Surface Effectiveness (Eta)	0.9029
Density (lbm/ft ³)	0.0652	61.9085	Sensible Heat Transferred (BTU/hr)	58,765
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3653	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,564.65
Inlet Temperature (°F)	114.54	105.49	j Factor	0.0094
Outlet Temperature (°F)	112.16	106.12	Air-Side ho (BTU/hr·ft ² ·°F)	10.03
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	113.35	105.81		
Skin Temperature (°F)	107.84	106.41	U Overall (BTU/hr·ft ² ·°F)	6.62
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	884**	34,868	LMTD	7.48
Prandtl Number	0.7278	4.2386	Total Heat Transferred (BTU/hr)	46,450
Bulk Visc (lbm/ft·hr)	0.0471	1.5488		
Skin Visc (lbm/ft·hr)		1.5392	Surface Effectiveness (Eta)	0.9031
Density (lbm/ft ³)	0.0654	61.9181	Sensible Heat Transferred (BTU/hr)	46,450
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3650	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: C

Rev: A Page 7 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Initial Benchmark Case -- Standard Coil

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,559.57
Inlet Temperature (°F)	112.16	105.00	j Factor	0.0094
Outlet Temperature (°F)	110.28	105.49	Air-Side ho (BTU/hr-ft ² -°F)	10.02
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	111.22	105.25		
Skin Temperature (°F)	106.86	105.72	U Overall (BTU/hr-ft ² -°F)	6.61
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	886**	34,667	LMTD	5.92
Prandtl Number	0.7280	4.2656	Total Heat Transferred (BTU/hr)	36,735
Bulk Visc (lbm/ft-hr)	0.0469	1.5578		
Skin Visc (lbm/ft-hr)		1.5501	Surface Effectiveness (Eta)	0.9032
Density (lbm/ft ³)	0.0657	61.9257	Sensible Heat Transferred (BTU/hr)	36,735
Cp (BTU/lbm-°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0155	0.3648	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: C


Rev: A Page 8 of 8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment D to
Proto-Power Calculation
97-200
Revision A**

268 Compact Heat Exchangers

Fig. 10-89 Finned circular tubes, surface CF-9.05-3/4J. (Data of Jameson.)



Tube outside diameter = 0.774 in = 19.66×10^{-3} m

Fin pitch = 9.05 per in = 356 per m

Fin thickness = 0.012 in = 0.305×10^{-3} m

Fin area/total area = 0.835

Flow passage hydraulic diameter, $4r_h$	A	B	C	D	E
=	0.01681	0.02685	0.0445	0.01587	0.02108 ft
=	5.131×10^{-3}	8.179×10^{-3}	13.59×10^{-3}	4.846×10^{-3}	6.426×10^{-2} m

Free-flow area/frontal area, σ	A	B	C	D	E
=	0.455	0.572	0.688	0.537	0.572

Heat transfer area/total volume, α	A	B	C	D	E
=	108	85.1	61.9	135	108 ft ² /ft ³
=	354	279	203	443	354 m ² /m ³

Note: Minimum free-flow area in all cases occurs in the spaces transverse to the flow, except for D, in which the minimum area is in the diagonals.

**Attachment E to
Proto-Power Calculation
97-200
Revision A**

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		108.000
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	150.00
Air Flow (acfm)	21,179.00
Tube Inlet Temp (°F)	105.00
Air Inlet Temp (°F)	150.0
Inlet Relative Humidity (%)	0.00
Inlet Wet Bulb Temp (°F)	92.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	150.00	105.00	j Factor
Outlet Temperature (°F)	111.57	115.11	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.02832467
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,503.18
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 749,965
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 749,965
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F) 1,637.56
Inlet Temperature (°F)	150.00	112.75	j Factor 0.0080
Outlet Temperature (°F)	140.99	115.11	Air-Side ho (BTU/hr·ft ² ·°F) 8.59
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.02832467
Average Temp (°F)	145.50	113.93	U Overall (BTU/hr·ft ² ·°F) 5.98
Skin Temperature (°F)	121.51	116.10	Effective Area (ft ²) 937.90
Velocity ***	3,598.07	5.53	LMTD 31.35
Reynold's Number	847**	37,836	Total Heat Transferred (BTU/hr) 175,742
Prandtl Number	0.7253	3.8745	Surface Effectiveness (Eta) 0.9155
Bulk Visc (lbm/ft·hr)	0.0491	1.4273	Sensible Heat Transferred (BTU/hr) 175,742
Skin Visc (lbm/ft·hr)		1.3974	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0623	61.8034	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0163	0.3679	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 4 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Extrapolation Calculation for Row 2(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,618.52
Inlet Temperature (°F)	140.99	110.84	j Factor	0.0080
Outlet Temperature (°F)	133.73	112.75	Air-Side ho (BTU/hr·ft ² ·°F)	8.56
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	137.36	111.79		
Skin Temperature (°F)	117.93	113.57	U Overall (BTU/hr·ft ² ·°F)	5.95
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	856**	37,048	LMTD	25.39
Prandtl Number	0.7261	3.9651	Total Heat Transferred (BTU/hr)	141,802
Bulk Visc (lbm/ft·hr)	0.0486	1.4577		
Skin Visc (lbm/ft·hr)		1.4323	Surface Effectiveness (Eta)	0.9158
Density (lbm/ft ³)	0.0631	61.8344	Sensible Heat Transferred (BTU/hr)	141,802
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0161	0.3672	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,603.09
Inlet Temperature (°F)	133.73	109.30	j Factor	0.0080
Outlet Temperature (°F)	127.86	110.84	Air-Side ho (BTU/hr·ft ² ·°F)	8.53
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	130.79	110.07		
Skin Temperature (°F)	115.04	111.52	U Overall (BTU/hr·ft ² ·°F)	5.94
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	863**	36,416	LMTD	20.58
Prandtl Number	0.7266	4.0408	Total Heat Transferred (BTU/hr)	114,578
Bulk Visc (lbm/ft·hr)	0.0482	1.4830		
Skin Visc (lbm/ft·hr)		1.4616	Surface Effectiveness (Eta)	0.9161
Density (lbm/ft ³)	0.0637	61.8590	Sensible Heat Transferred (BTU/hr)	114,578
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0159	0.3666	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 5 of 15

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,590.59
Inlet Temperature (°F)	127.86	108.06	j Factor	0.0080
Outlet Temperature (°F)	123.11	109.30	Air-Side ho (BTU/hr·ft ² ·°F)	8.50
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	125.48	108.68		
Skin Temperature (°F)	112.71	109.86	U Overall (BTU/hr·ft ² ·°F)	5.92
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	869**	35,909	LMTD	16.69
Prandtl Number	0.7270	4.1037	Total Heat Transferred (BTU/hr)	92,686
Bulk Visc (lbm/ft·hr)	0.0478	1.5039		
Skin Visc (lbm/ft·hr)		1.4861	Surface Effectiveness (Eta)	0.9163
Density (lbm/ft ³)	0.0642	61.8786	Sensible Heat Transferred (BTU/hr)	92,686
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3661	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,580.44
Inlet Temperature (°F)	123.11	107.05	j Factor	0.0079
Outlet Temperature (°F)	119.26	108.06	Air-Side ho (BTU/hr·ft ² ·°F)	8.48
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	121.18	107.55		
Skin Temperature (°F)	110.82	108.51	U Overall (BTU/hr·ft ² ·°F)	5.91
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	874**	35,499	LMTD	13.54
Prandtl Number	0.7273	4.1558	Total Heat Transferred (BTU/hr)	75,047
Bulk Visc (lbm/ft·hr)	0.0476	1.5213		
Skin Visc (lbm/ft·hr)		1.5065	Surface Effectiveness (Eta)	0.9164
Density (lbm/ft ³)	0.0646	61.8943	Sensible Heat Transferred (BTU/hr)	75,047
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 6 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,572.22
Inlet Temperature (°F)	119.26	106.23	j Factor	0.0079
Outlet Temperature (°F)	116.14	107.05	Air-Side ho (BTU/hr·ft ² ·°F)	8.47
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	117.70	106.64		
Skin Temperature (°F)	109.29	107.42	U Overall (BTU/hr·ft ² ·°F)	5.90
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	878**	35,169	LMTD	10.99
Prandtl Number	0.7276	4.1987	Total Heat Transferred (BTU/hr)	60,810
Bulk Visc (lbm/ft·hr)	0.0473	1.5356		
Skin Visc (lbm/ft·hr)		1.5233	Surface Effectiveness (Eta)	0.9166
Density (lbm/ft ³)	0.0650	61.9068	Sensible Heat Transferred (BTU/hr)	60,810
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3653	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,565.54
Inlet Temperature (°F)	116.14	105.57	j Factor	0.0079
Outlet Temperature (°F)	113.62	106.23	Air-Side ho (BTU/hr·ft ² ·°F)	8.46
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	114.88	105.90		
Skin Temperature (°F)	108.05	106.54	U Overall (BTU/hr·ft ² ·°F)	5.89
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	882**	34,902	LMTD	8.92
Prandtl Number	0.7277	4.2341	Total Heat Transferred (BTU/hr)	49,305
Bulk Visc (lbm/ft·hr)	0.0472	1.5473		
Skin Visc (lbm/ft·hr)		1.5372	Surface Effectiveness (Eta)	0.9167
Density (lbm/ft ³)	0.0653	61.9169	Sensible Heat Transferred (BTU/hr)	49,305
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3650	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 7 of 15

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark Case -- Custom Coil

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,560.11
Inlet Temperature (°F)	113.62	105.03	j Factor	0.0079
Outlet Temperature (°F)	111.57	105.57	Air-Side ho (BTU/hr·ft ² ·°F)	8.45
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	112.59	105.30		
Skin Temperature (°F)	107.05	105.82	U Overall (BTU/hr·ft ² ·°F)	5.89
Velocity ***	3,598.07	5.52	Effective Area (ft ²)	937.90
Reynold's Number	885**	34,686	LMTD	7.24
Prandtl Number	0.7279	4.2631	Total Heat Transferred (BTU/hr)	39,996
Bulk Visc (lbm/ft·hr)	0.0470	1.5569		
Skin Visc (lbm/ft·hr)		1.5486	Surface Effectiveness (Eta)	0.9168
Density (lbm/ft ³)	0.0655	61.9250	Sensible Heat Transferred (BTU/hr)	39,996
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3648	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 8 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 9 of 15

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	150.00
Air Flow (acfm)	21,179.00
Tube Inlet Temp (°F)	105.00
Air Inlet Temp (°F)	150.0
Inlet Relative Humidity (%)	0.00
Inlet Wet Bulb Temp (°F)	92.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	150.00	105.00	j Factor	
Outlet Temperature (°F)	111.76	115.02	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)				
Skin Temperature (°F)			U Overall (BTU/hr·ft ² ·°F)	
Velocity ***			Effective Area (ft ²)	7,242.65
Reynold's Number			LMTD	
Prandtl Number			Total Heat Transferred (BTU/hr)	746,297
Bulk Visc (lbm/ft·hr)				
Skin Visc (lbm/ft·hr)			Surface Effectiveness (Eta)	
Density (lbm/ft ³)			Sensible Heat Transferred (BTU/hr)	746,297
Cp (BTU/lbm·°F)			Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,637.06
Inlet Temperature (°F)	150.00	112.69	j Factor	0.0079
Outlet Temperature (°F)	141.13	115.02	Air-Side ho (BTU/hr·ft ² ·°F)	8.79
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	145.56	113.86		
Skin Temperature (°F)	121.59	116.08	U Overall (BTU/hr·ft ² ·°F)	6.07
Velocity ***	3,727.50	5.53	Effective Area (ft ²)	905.33
Reynold's Number	878**	37,810	LMTD	31.49
Prandtl Number	0.7253	3.8775	Total Heat Transferred (BTU/hr)	173,186
Bulk Visc (lbm/ft·hr)	0.0491	1.4283		
Skin Visc (lbm/ft·hr)		1.3978	Surface Effectiveness (Eta)	0.9137
Density (lbm/ft ³)	0.0623	61.8044	Sensible Heat Transferred (BTU/hr)	173,186
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0163	0.3679	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 11 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,618.25
Inlet Temperature (°F)	141.13	110.81	j Factor	0.0079
Outlet Temperature (°F)	133.94	112.69	Air-Side ho (BTU/hr-ft ² -°F)	8.76
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	137.53	111.75		
Skin Temperature (°F)	118.04	113.57	U Overall (BTU/hr-ft ² -°F)	6.05
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	887**	37,032	LMTD	25.61
Prandtl Number	0.7261	3.9670	Total Heat Transferred (BTU/hr)	140,305
Bulk Visc (lbm/ft-hr)	0.0486	1.4583		
Skin Visc (lbm/ft-hr)		1.4323	Surface Effectiveness (Eta)	0.9140
Density (lbm/ft ³)	0.0630	61.8350	Sensible Heat Transferred (BTU/hr)	140,305
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0161	0.3672	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,602.95
Inlet Temperature (°F)	133.94	109.28	j Factor	0.0079
Outlet Temperature (°F)	128.10	110.81	Air-Side ho (BTU/hr-ft ² -°F)	8.73
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.02832467
Average Temp (°F)	131.02	110.04		
Skin Temperature (°F)	115.16	111.53	U Overall (BTU/hr-ft ² -°F)	6.03
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	894**	36,406	LMTD	20.84
Prandtl Number	0.7266	4.0420	Total Heat Transferred (BTU/hr)	113,821
Bulk Visc (lbm/ft-hr)	0.0482	1.4834		
Skin Visc (lbm/ft-hr)		1.4614	Surface Effectiveness (Eta)	0.9143
Density (lbm/ft ³)	0.0637	61.8594	Sensible Heat Transferred (BTU/hr)	113,821
Cp (BTU/lbm-°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0159	0.3666	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 12 of 15

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,590.49
Inlet Temperature (°F)	128.10	108.04	j Factor	0.0079
Outlet Temperature (°F)	123.37	109.28	Air-Side ho (BTU/hr·ft ² ·°F)	8.70
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	125.73	108.66		
Skin Temperature (°F)	112.82	109.88	U Overall (BTU/hr·ft ² ·°F)	6.02
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	900**	35,901	LMTD	16.96
Prandtl Number	0.7270	4.1046	Total Heat Transferred (BTU/hr)	92,439
Bulk Visc (lbm/ft·hr)	0.0478	1.5043		
Skin Visc (lbm/ft·hr)		1.4858	Surface Effectiveness (Eta)	0.9145
Density (lbm/ft ³)	0.0642	61.8789	Sensible Heat Transferred (BTU/hr)	92,439
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3661	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,580.35
Inlet Temperature (°F)	123.37	107.03	j Factor	0.0078
Outlet Temperature (°F)	119.52	108.04	Air-Side ho (BTU/hr·ft ² ·°F)	8.68
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	121.44	107.53		
Skin Temperature (°F)	110.92	108.53	U Overall (BTU/hr·ft ² ·°F)	6.01
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	905**	35,491	LMTD	13.82
Prandtl Number	0.7273	4.1567	Total Heat Transferred (BTU/hr)	75,142
Bulk Visc (lbm/ft·hr)	0.0476	1.5216		
Skin Visc (lbm/ft·hr)		1.5062	Surface Effectiveness (Eta)	0.9147
Density (lbm/ft ³)	0.0646	61.8945	Sensible Heat Transferred (BTU/hr)	75,142
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3656	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 13 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,572.09
Inlet Temperature (°F)	119.52	106.20	j Factor	0.0078
Outlet Temperature (°F)	116.38	107.03	Air-Side ho (BTU/hr·ft ² ·°F)	8.67
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	117.95	106.62		
Skin Temperature (°F)	109.38	107.43	U Overall (BTU/hr·ft ² ·°F)	6.00
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	910**	35,160	LMTD	11.26
Prandtl Number	0.7275	4.1998	Total Heat Transferred (BTU/hr)	61,127
Bulk Visc (lbm/ft·hr)	0.0474	1.5359		
Skin Visc (lbm/ft·hr)		1.5231	Surface Effectiveness (Eta)	0.9148
Density (lbm/ft ³)	0.0650	61.9071	Sensible Heat Transferred (BTU/hr)	61,127
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3653	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,565.36
Inlet Temperature (°F)	116.38	105.54	j Factor	0.0078
Outlet Temperature (°F)	113.83	106.20	Air-Side ho (BTU/hr·ft ² ·°F)	8.66
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	115.11	105.87		
Skin Temperature (°F)	108.12	106.54	U Overall (BTU/hr·ft ² ·°F)	5.99
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	913**	34,892	LMTD	9.18
Prandtl Number	0.7277	4.2354	Total Heat Transferred (BTU/hr)	49,756
Bulk Visc (lbm/ft·hr)	0.0472	1.5478		
Skin Visc (lbm/ft·hr)		1.5372	Surface Effectiveness (Eta)	0.9149
Density (lbm/ft ³)	0.0653	61.9172	Sensible Heat Transferred (BTU/hr)	49,756
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3650	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: E

Rev: A Page 14 of 15

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Final Benchmark - Effective Coil Length

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	77,999.05	74,508.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,559.87
Inlet Temperature (°F)	113.83	104.99	j Factor	0.0078
Outlet Temperature (°F)	111.76	105.54	Air-Side ho (BTU/hr·ft ² ·°F)	8.65
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	112.79	105.26		
Skin Temperature (°F)	107.10	105.81	U Overall (BTU/hr·ft ² ·°F)	5.98
Velocity ***	3,727.50	5.52	Effective Area (ft ²)	905.33
Reynold's Number	916**	34,673	LMTD	7.48
Prandtl Number	0.7279	4.2648	Total Heat Transferred (BTU/hr)	40,520
Bulk Visc (lbm/ft·hr)	0.0470	1.5575		
Skin Visc (lbm/ft·hr)		1.5487	Surface Effectiveness (Eta)	0.9150
Density (lbm/ft ³)	0.0655	61.9254	Sensible Heat Transferred (BTU/hr)	40,520
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3648	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: E
Rev: A Page 15 of 15

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment F to
Proto-Power Calculation
97-200
Revision A**

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 2 of 8

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Fouling Was Input by User

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	150.00
Air Flow (acfm)	19,387.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315
Input Fouling Factor	0.000000

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	104.53	110.41	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 779,018
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 779,018
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F) 1,598.27
Inlet Temperature (°F)	148.00	107.62	j Factor 0.0082
Outlet Temperature (°F)	136.42	110.41	Air-Side ho (BTU/hr·ft ² ·°F) 8.30
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)
Average Temp (°F)	142.21	109.01	U Overall (BTU/hr·ft ² ·°F) 6.98
Skin Temperature (°F)	111.82	111.75	Effective Area (ft ²) 905.33
Velocity ***	3,423.68	5.53	LMTD 32.85
Reynold's Number	810**	36,069	Total Heat Transferred (BTU/hr) 207,508
Prandtl Number	0.7256	4.0884	Surface Effectiveness (Eta) 0.9181
Bulk Visc (lbm/ft·hr)	0.0489	1.4988	Sensible Heat Transferred (BTU/hr) 207,508
Skin Visc (lbm/ft·hr)		1.4583	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0628	61.8739	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0162	0.3662	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 4 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Extrapolation Calculation for Row 2(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,575.85
Inlet Temperature (°F)	136.42	105.50	j Factor	0.0081
Outlet Temperature (°F)	127.59	107.62	Air-Side ho (BTU/hr·ft ² ·°F)	8.26
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	
Average Temp (°F)	132.01	106.56	U Overall (BTU/hr·ft ² ·°F)	6.94
Skin Temperature (°F)	108.73	108.68	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	25.19
Reynold's Number	820**	35,177	Total Heat Transferred (BTU/hr)	158,199
Prandtl Number	0.7265	4.2025		
Bulk Visc (lbm/ft·hr)	0.0482	1.5368	Surface Effectiveness (Eta)	0.9184
Skin Visc (lbm/ft·hr)		1.5040	Sensible Heat Transferred (BTU/hr)	158,199
Density (lbm/ft ³)	0.0637	61.9079	Latent Heat Transferred (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989	Heat to Condensate (BTU/hr)	
K (BTU/hr·ft·°F)	0.0160	0.3653		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,558.67
Inlet Temperature (°F)	127.59	103.87	j Factor	0.0081
Outlet Temperature (°F)	120.85	105.50	Air-Side ho (BTU/hr·ft ² ·°F)	8.23
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	
Average Temp (°F)	124.22	104.69	U Overall (BTU/hr·ft ² ·°F)	6.91
Skin Temperature (°F)	106.36	106.32	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	19.34
Reynold's Number	829**	34,502	Total Heat Transferred (BTU/hr)	120,920
Prandtl Number	0.7271	4.2930		
Bulk Visc (lbm/ft·hr)	0.0478	1.5669	Surface Effectiveness (Eta)	0.9187
Skin Visc (lbm/ft·hr)		1.5406	Sensible Heat Transferred (BTU/hr)	120,920
Density (lbm/ft ³)	0.0645	61.9332	Latent Heat Transferred (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989	Heat to Condensate (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3646		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 5 of 8

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,545.48
Inlet Temperature (°F)	120.85	102.63	j Factor	0.0081
Outlet Temperature (°F)	115.68	103.87	Air-Side ho (BTU/hr·ft ² ·°F)	8.20
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	
Average Temp (°F)	118.26	103.25	U Overall (BTU/hr·ft ² ·°F)	6.88
Skin Temperature (°F)	104.55	104.52	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	14.86
Reynold's Number	835**	33,989	Total Heat Transferred (BTU/hr)	92,611
Prandtl Number	0.7275	4.3645		
Bulk Visc (lbm/ft·hr)	0.0474	1.5905	Surface Effectiveness (Eta)	0.9190
Skin Visc (lbm/ft·hr)		1.5697	Sensible Heat Transferred (BTU/hr)	92,611
Density (lbm/ft ³)	0.0650	61.9522	Latent Heat Transferred (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989	Heat to Condensate (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3640		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,535.34
Inlet Temperature (°F)	115.68	101.68	j Factor	0.0080
Outlet Temperature (°F)	111.72	102.63	Air-Side ho (BTU/hr·ft ² ·°F)	8.18
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	
Average Temp (°F)	113.70	102.15	U Overall (BTU/hr·ft ² ·°F)	6.87
Skin Temperature (°F)	103.15	103.13	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	11.43
Reynold's Number	840**	33,597	Total Heat Transferred (BTU/hr)	71,038
Prandtl Number	0.7278	4.4206		
Bulk Visc (lbm/ft·hr)	0.0471	1.6091	Surface Effectiveness (Eta)	0.9191
Skin Visc (lbm/ft·hr)		1.5926	Sensible Heat Transferred (BTU/hr)	71,038
Density (lbm/ft ³)	0.0655	61.9666	Latent Heat Transferred (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9990	Heat to Condensate (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3636		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 6 of 8

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Extrapolation Calculation for Row 6(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr-ft ² -°F)	1,527.56
Inlet Temperature (°F)	111.72	100.95	j Factor	0.0080
Outlet Temperature (°F)	108.67	101.68	Air-Side ho (BTU/hr-ft ² -°F)	8.16
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	
Average Temp (°F)	110.19	101.31	U Overall (BTU/hr-ft ² -°F)	6.85
Skin Temperature (°F)	102.08	102.06	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	8.79
Reynold's Number	844**	33,298	Total Heat Transferred (BTU/hr)	54,554
Prandtl Number	0.7280	4.4644	Surface Effectiveness (Eta)	0.9193
Bulk Visc (lbm/ft-hr)	0.0469	1.6236	Sensible Heat Transferred (BTU/hr)	54,554
Skin Visc (lbm/ft-hr)		1.6106	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0659	61.9776	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9990		
K (BTU/hr-ft-°F)	0.0155	0.3633		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr-ft ² -°F)	1,521.56
Inlet Temperature (°F)	108.67	100.38	j Factor	0.0080
Outlet Temperature (°F)	106.33	100.95	Air-Side ho (BTU/hr-ft ² -°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	
Average Temp (°F)	107.50	100.66	U Overall (BTU/hr-ft ² -°F)	6.84
Skin Temperature (°F)	101.26	101.25	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	6.77
Reynold's Number	848**	33,069	Total Heat Transferred (BTU/hr)	41,933
Prandtl Number	0.7282	4.4985	Surface Effectiveness (Eta)	0.9194
Bulk Visc (lbm/ft-hr)	0.0467	1.6348	Sensible Heat Transferred (BTU/hr)	41,933
Skin Visc (lbm/ft-hr)		1.6247	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0661	61.9859	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm-°F)	0.2402	0.9990		
K (BTU/hr-ft-°F)	0.0154	0.3630		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 7 of 8

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Zero Fouling

Extrapolation Calculation for Row 8(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,641.50	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,516.95
Inlet Temperature (°F)	106.33	99.95	j Factor	0.0080
Outlet Temperature (°F)	104.53	100.38	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	
Average Temp (°F)	105.43	100.17	U Overall (BTU/hr·ft ² ·°F)	6.84
Skin Temperature (°F)	100.63	100.61	Effective Area (ft ²)	905.33
Velocity ***	3,423.68	5.52	LMTD	5.21
Reynold's Number	850**	32,893	Total Heat Transferred (BTU/hr)	32,255
Prandtl Number	0.7283	4.5250	Surface Effectiveness (Eta)	0.9195
Bulk Visc (lbm/ft·hr)	0.0465	1.6436	Sensible Heat Transferred (BTU/hr)	32,255
Skin Visc (lbm/ft·hr)		1.6357	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0663	61.9922	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9990		
K (BTU/hr·ft·°F)	0.0154	0.3628		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: F

Rev: A Page 8 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment G to
Proto-Power Calculation
97-200
Revision A**

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001500
Air-Side Fouling		0.000000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	150.00
Air Flow (acfm)	19,321.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	100.00	j Factor	
Outlet Temperature (°F)	106.46	109.94	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	741,876
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	741,876
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,595.06
Inlet Temperature (°F)	148.00	107.53	j Factor	0.0082
Outlet Temperature (°F)	137.97	109.94	Air-Side ho (BTU/hr·ft ² ·°F)	8.29
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	142.99	108.74	U Overall (BTU/hr·ft ² ·°F)	5.82
Skin Temperature (°F)	116.80	111.10	Effective Area (ft ²)	905.33
Velocity ***	3,412.02	5.53	LMTD	34.00
Reynold's Number	806**	35,968	Total Heat Transferred (BTU/hr)	179,064
Prandtl Number	0.7256	4.1010	Surface Effectiveness (Eta)	0.9182
Bulk Visc (lbm/ft·hr)	0.0489	1.5030	Sensible Heat Transferred (BTU/hr)	179,064
Skin Visc (lbm/ft·hr)		1.4678	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0626	61.8778	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9989		
K (BTU/hr·ft·°F)	0.0162	0.3661		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: G

Rev: A Page 4 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,575.52
Inlet Temperature (°F)	137.97	105.62	j Factor	0.0081
Outlet Temperature (°F)	129.99	107.53	Air-Side ho (BTU/hr·ft ² ·°F)	8.25
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	133.98	106.58		
Skin Temperature (°F)	113.03	108.48	U Overall (BTU/hr·ft ² ·°F)	5.79
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	815**	35,184	LMTD	27.20
Prandtl Number	0.7264	4.2016	Total Heat Transferred (BTU/hr)	142,681
Bulk Visc (lbm/ft·hr)	0.0484	1.5365		
Skin Visc (lbm/ft·hr)		1.5070	Surface Effectiveness (Eta)	0.9185
Density (lbm/ft ³)	0.0635	61.9076	Sensible Heat Transferred (BTU/hr)	142,681
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0160	0.3653	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,559.89
Inlet Temperature (°F)	129.99	104.09	j Factor	0.0081
Outlet Temperature (°F)	123.61	105.62	Air-Side ho (BTU/hr·ft ² ·°F)	8.22
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	126.80	104.85		
Skin Temperature (°F)	110.02	106.39	U Overall (BTU/hr·ft ² ·°F)	5.77
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	823**	34,563	LMTD	21.78
Prandtl Number	0.7269	4.2848	Total Heat Transferred (BTU/hr)	113,876
Bulk Visc (lbm/ft·hr)	0.0479	1.5641		
Skin Visc (lbm/ft·hr)		1.5395	Surface Effectiveness (Eta)	0.9188
Density (lbm/ft ³)	0.0642	61.9309	Sensible Heat Transferred (BTU/hr)	113,876
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3646	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: G

Rev: A Page 5 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Extrapolation Calculation for Row 4(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,547.37
Inlet Temperature (°F)	123.61	102.87	j Factor	0.0081
Outlet Temperature (°F)	118.51	104.09	Air-Side ho (BTU/hr·ft ² ·°F)	8.19
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	121.06	103.48		
Skin Temperature (°F)	107.62	104.72	U Overall (BTU/hr·ft ² ·°F)	5.76
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	829**	34,070	LMTD	17.46
Prandtl Number	0.7273	4.3531	Total Heat Transferred (BTU/hr)	91,006
Bulk Visc (lbm/ft·hr)	0.0476	1.5868		
Skin Visc (lbm/ft·hr)		1.5664	Surface Effectiveness (Eta)	0.9190
Density (lbm/ft ³)	0.0647	61.9493	Sensible Heat Transferred (BTU/hr)	91,006
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3641	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,537.35
Inlet Temperature (°F)	118.51	101.89	j Factor	0.0081
Outlet Temperature (°F)	114.44	102.87	Air-Side ho (BTU/hr·ft ² ·°F)	8.17
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	116.48	102.38		
Skin Temperature (°F)	105.70	103.38	U Overall (BTU/hr·ft ² ·°F)	5.75
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	834**	33,678	LMTD	13.99
Prandtl Number	0.7276	4.4089	Total Heat Transferred (BTU/hr)	72,805
Bulk Visc (lbm/ft·hr)	0.0473	1.6052		
Skin Visc (lbm/ft·hr)		1.5885	Surface Effectiveness (Eta)	0.9192
Density (lbm/ft ³)	0.0652	61.9637	Sensible Heat Transferred (BTU/hr)	72,805
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3637	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: G

Rev: A Page 6 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,529.34
Inlet Temperature (°F)	114.44	101.11	j Factor	0.0081
Outlet Temperature (°F)	111.17	101.89	Air-Side ho (BTU/hr·ft ² ·°F)	8.16
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	112.81	101.50		
Skin Temperature (°F)	104.17	102.32	U Overall (BTU/hr·ft ² ·°F)	5.74
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	839**	33,365	LMTD	11.22
Prandtl Number	0.7279	4.4545	Total Heat Transferred (BTU/hr)	58,294
Bulk Visc (lbm/ft·hr)	0.0470	1.6203		
Skin Visc (lbm/ft·hr)		1.6063	Surface Effectiveness (Eta)	0.9193
Density (lbm/ft ³)	0.0656	61.9751	Sensible Heat Transferred (BTU/hr)	58,294
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3634	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,522.84
Inlet Temperature (°F)	111.17	100.48	j Factor	0.0080
Outlet Temperature (°F)	108.56	101.11	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	109.87	100.80		
Skin Temperature (°F)	102.93	101.44	U Overall (BTU/hr·ft ² ·°F)	5.73
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	842**	33,115	LMTD	9.01
Prandtl Number	0.7280	4.4916	Total Heat Transferred (BTU/hr)	46,707
Bulk Visc (lbm/ft·hr)	0.0468	1.6325		
Skin Visc (lbm/ft·hr)		1.6213	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0659	61.9842	Sensible Heat Transferred (BTU/hr)	46,707
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3631	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: G

Rev: A Page 7 of 8

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Margin Assessment -- Design Fouling

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,397.61	74,586.94	Tube-Side hi (BTU/hr·ft ² ·°F)	1,517.67
Inlet Temperature (°F)	108.56	99.98	j Factor	0.0080
Outlet Temperature (°F)	106.46	100.48	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02832467
Average Temp (°F)	107.51	100.23		
Skin Temperature (°F)	101.94	100.75	U Overall (BTU/hr·ft ² ·°F)	5.72
Velocity ***	3,412.02	5.52	Effective Area (ft ²)	905.33
Reynold's Number	845**	32,915	LMTD	7.23
Prandtl Number	0.7282	4.5216	Total Heat Transferred (BTU/hr)	37,443
Bulk Visc (lbm/ft·hr)	0.0467	1.6424		
Skin Visc (lbm/ft·hr)		1.6333	Surface Effectiveness (Eta)	0.9195
Density (lbm/ft ³)	0.0661	61.9914	Sensible Heat Transferred (BTU/hr)	37,443
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0154	0.3629	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: G

Rev: A Page 8 of 8

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment H to
Proto-Power Calculation
97-200
Revision A**

Moist Air Properties

Equations for calculating moist air properties are compiled and/or derived in Proto-Power Calculation 96-069, Reference (1), relying on References (2) and (3) as the principal sources of information. This attachment summarizes the equations pertinent to the moist air conditions calculated for heat exchanger model development. The applicable material has been extracted from Reference (1) leaving equation numbering as it appears in Reference (1) for ease of cross reference.

1. NOMENCLATURE

m_a = Mass of Dry Air, lbm
 m_v = Mass of Water Vapor, lbm
 P = Atmospheric Pressure, lbf/in²
 P_a = Dry Air Pressure, lbf/in²
 P_s = Saturated Air Pressure, lbf/in²
 P_v = Water Vapor Pressure, lbf/in²
 R_a = Gas constant of Dry Air
 R_v = Gas constant of Water Vapor
 T = Dry Bulb Temperature, °F
 T_w = Wet Bulb Temperature, °F
 V = Moist air Volume, ft³
 W = Moist air Specific Humidity
 x_v = Mole Fraction of Water Vapor in Moist Air
 x_s = Mole Fraction of Water Vapor in Saturated Air
 ϕ = Moist Air Relative Humidity
 ρ = Moist air Density, lbm/ft³
 ρ_a = Dry Air Density, lbm/ft³
 ρ_v = Water Vapor Density, lbm/ft³

2. REFERENCES

- (1) Proto-Power Calculation 96-069, Fluid Properties - Moist Air - Range 8°F to 300°F, Revision -, dated 12/2/96
- (2) Heating Ventilating, and Air Conditioning Analysis and Design, F. C. McQuiston and J. D. Parker, Second Edition, John Wiley & Sons, Inc., 1982
- (3) ASHRAE Handbook 1981 Fundamentals, American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1982

3. MOIST AIR DENSITY

For dry air:

$$P_a = P - P_v \quad \text{Equation [4]}$$

$$\rho_a = \left(\frac{144}{R_a} \right) \frac{P_a}{(459.67 + T)} \quad \text{Equation [5]}$$

where:

$$R_a = 53.352 \text{ (ft-lbf)/(lbm-}^\circ\text{R)}$$

For water vapor:

$$\rho_v = \left(\frac{144}{R_v} \right) \frac{P_v}{(459.67 + T)} \quad \text{Equation [6]}$$

where:

$$R_v = 85.778 \text{ (ft-lbf)/(lbm-}^\circ\text{R)}$$

For moist air:

$$\rho = \rho_a + \rho_v \quad \text{Equation [7]}$$

4. SATURATED WATER VAPOR PRESSURE

$$P_s(T) = a + bT + cT^2 + dT^3 + eT^4 + fT^5 \quad \text{Equation [8]}$$

Where;

$$a = 0.02358607$$

$$b = 0.001007276$$

$$c = 0.00001888033$$

$$d = 0.0000003775047$$

$$e = 4.871208\text{E-}10$$

$$f = 2.109071\text{E-}11$$

5. WATER VAPOR PRESSURE

$$f(T_w) = a + bT_w + cT_w^2 + dT_w^3 + eT_w^4 + fT_w^5 \quad \text{Equation [9]}$$

$$P_v(P, T, T_w) = \frac{[(2T_w - T - 2800)f(T_w)] - P(T_w - T)}{(T_w - 2800)} \quad \text{Equation [10]}$$

Where:

$$a = 0.02358607$$

$$b = 0.001007276$$

$$c = 0.00001888033$$

$$d = 0.0000003775047$$

$$e = 4.871208E-10$$

$$f = 2.109071E-11$$

$$P_v = \frac{WR_v P}{R_a + (WR_v)} \quad \text{Equation [11]}$$

6. MOIST AIR SPECIFIC HUMIDITY

$$W = \frac{m_v}{m_a} = \frac{\rho_v}{\rho_a} \quad \text{Equation [12]}$$

Where:

$$m_v = \frac{P_v V}{R_v (459.67 + T)} \quad \text{Equation [13]}$$

$$m_a = \frac{P_a V}{R_a (459.67 + T)} \quad \text{Equation [14]}$$

7. MOIST AIR RELATIVE HUMIDITY

$$\phi = \frac{x_v}{x_s} = \frac{P_v}{P_s} \quad \text{Equation [15]}$$

Moist Air Properties -- Given Dry Bulb and Relative Humidity *

Total Pressure:	P =	14.315	psia	
Dry Bulb Temperature:	T =	70	°F	
Moist Air Relative Humidity:	RH =	40	%	
Saturated Air Pressure:	$P_s = a+(b*T)+(c*T^2)+(d*T^3)+(e*T^4)+(f*T^5) =$	0.363236046	psia	Equation [8]
Vapor Pressure:	$P_v = RH*P_s$	0.145294418	psia	Equation [15]
Dry Air Pressure:	$P_a = P - P_v =$	14.16970558	psia	Equation [4]
Dry Air Density:	$Rho_a = (144/53.352)*(P_a/(459.67+T)) =$	0.072204994	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144/85.778)*(P_v/(459.67+T)) =$	0.000460501	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.072665495	lbm/ft ³	Equation [7]
Specific Humidity:	$W = Rho_v / Rho_a =$	0.006377682		Equation [12]
Equation Coefficients:	a =	2.358607E-02		
	b =	1.007276E-03		
	c =	1.888033E-05		
	d =	3.775047E-07		
	e =	4.871208E-10		
	f =	2.109071E-11		

* Coil Specification Conditions

Moist Air Properties -- Given Dry Bulb and Wet Bulb Temperatures *

Total Pressure:	$P =$	14.315	psia	
Dry Bulb Temperature:	$T =$	150	°F	
Wet Bulb Temperature:	$T_w =$	92.00	°F	
Wet Bulb Temp. Function:	$F(T_w) = a+(b*T_w)+(c*T_w^2)+(d*T_w^3)+(e*T_w^4)+(f*T_w^5) =$	0.743918919		Equation [9]
Water Vapor Pressure:	$P_v = (((2*T_w-T-2800)*F(T_w))-P*(T_w-T))/(T_w-2800) =$	0.453253224	psia	Equation [10]
Dry Air Pressure:	$P_a = P - P_v =$	13.86174678	psia	Equation [4]
Dry Air Density:	$Rho_a = (144/53.352)*(P_a/(459.67+T)) =$	0.061367004	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144/85.778)*(P_v/(459.67+T)) =$	0.001248052	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.062615056	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a+(b*T)+(c*T^2)+(d*T^3)+(e*T^4)+(f*T^5) =$	3.721743953	psia	Equation [8]
Moist Air Specific Humidity:	$W = Rho_v / Rho_a =$	0.020337508		Equation [12]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	12.17852	%	Equation [15]
Equation Coefficients:	$a =$	2.358607E-02		
	$b =$	1.007276E-03		
	$c =$	1.888033E-05		
	$d =$	3.775047E-07		
	$e =$	4.871208E-10		
	$f =$	2.109071E-11		

* Coil Benchmark Conditions

Moist Air Properties -- Given Dry Bulb and Wet Bulb Temperatures *

Total Pressure:	$P =$	14.315	psia	
Dry Bulb Temperature:	$T =$	148	°F	
Wet Bulb Temperature:	$T_w =$	91.60	°F	
Wet Bulb Temp. Function:	$F(T_w) = a+(b*T_w)+(c*T_w^2)+(d*T_w^3)+(e*T_w^4)+(f*T_w^5) =$	0.734713202		Equation [9]
Water Vapor Pressure:	$P_v = (((2*T_w-T-2800)*F(T_w))-P*(T_w-T))/(T_w-2800) =$	0.451915914	psia	Equation [10]
Dry Air Pressure:	$P_a = P - P_v =$	13.86308409	psia	Equation [4]
Dry Air Density:	$Rho_a = (144/53.352)*(P_a/(459.67+T)) =$	0.061574919	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144/85.778)*(P_v/(459.67+T)) =$	0.001248465	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.062823384	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a+(b*T)+(c*T^2)+(d*T^3)+(e*T^4)+(f*T^5) =$	3.541336347	psia	Equation [8]
Moist Air Specific Humidity:	$W = Rho_v / Rho_a =$	0.020275546		Equation [12]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	12.76117	%	Equation [15]
Equation Coefficients:	$a =$	2.358607E-02		
	$b =$	1.007276E-03		
	$c =$	1.888033E-05		
	$d =$	3.775047E-07		
	$e =$	4.871208E-10		
	$f =$	2.109071E-11		

Proto-Power Calc: 97-200
 Attachment: H
 Rev: A Page 7 of 13

* LaSalle Station Reference Conditions

Moist Air Properties -- Given Dry Bulb and Relative Humidity *

Total Pressure:	P =	14.315	psia	
Dry Bulb Temperature:	T =	148	°F	
Moist Air Relative Humidity:	RH =	12.76	%	
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	3.541336347	psia	Equation [8]
Vapor Pressure:	$P_v = RH \cdot P_s$	0.451874518	psia	Equation [15]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$Rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.061575103	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001248351	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.062823454	lbm/ft ³	Equation [7]
Specific Humidity:	$W = Rho_v / Rho_a =$	0.020273629		Equation [12]
Equation Coefficients:	a =	2.358607E-02		
	b =	1.007276E-03		
	c =	1.888033E-05		
	d =	3.775047E-07		
	e =	4.871208E-10		
	f =	2.109071E-11		

* LaSalle Station Reference Conditions (RH = 12.76%)

Moist Air Properties -- Given Dry Bulb and Specific Humidity *

Total Pressure:	$P =$	14.315	psia	
Dry Bulb Temperature:	$T =$	104.53	°F	Inlet Air Flow 19386.84858
Specific Humidity:	$W =$	0.020273629		
Water Vapor Pressure:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451874518	psia	Equation [11]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$Rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.066319289	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001344533	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.067663821	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	1.087702551	psia	Equation [8]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	41.54394211	%	Equation [15]
Equation Coefficients:	$a =$	2.358607E-02		
	$b =$	1.007276E-03		
	$c =$	1.888033E-05		
	$d =$	3.775047E-07		
	$e =$	4.871208E-10		
	$f =$	2.109071E-11		

* Coil Outlet Conditions (clean)

Moist Air Properties -- Given Dry Bulb and Specific Humidity *

Total Pressure:	$P =$	14.315	psia	
Dry Bulb Temperature:	$T =$	106.46	°F	Inlet Air Flow 19320.75666
Specific Humidity:	$W =$	0.020273629		
Water Vapor Pressure:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451874518	psia	Equation [11]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$Rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.066093199	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001339949	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.067433148	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	1.15128943	psia	Equation [8]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	39.24942818	%	Equation [15]
Equation Coefficients:	$a =$	2.358607E-02		
	$b =$	1.007276E-03		
	$c =$	1.888033E-05		
	$d =$	3.775047E-07		
	$e =$	4.871208E-10		
	$f =$	2.109071E-11		

* Coil Outlet Conditions (Service)

Moist Air Properties -- Given Dry Bulb and Specific Humidity *

Total Pressure:	$P =$	14.315	psia	
Dry Bulb Temperature:	$T =$	109.96	°F	Inlet Air Flow 19202.04338
Specific Humidity:	$W =$	0.020273629		
Water Vapor Pressure:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451874518	psia	Equation [11]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$Rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.0656871	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001331716	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.067018816	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	1.274809374	psia	Equation [8]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	35.44643829	%	Equation [15]
Equation Coefficients:	$a =$	2.358607E-02		
	$b =$	1.007276E-03		
	$c =$	1.888033E-05		
	$d =$	3.775047E-07		
	$e =$	4.871208E-10		
	$f =$	2.109071E-11		

* Coil Outlet Conditions (Limiting Flow - 75 gpm)

Moist Air Properties -- Given Dry Bulb and Specific Humidity *

Total Pressure:	P =	14.315	psia	
Dry Bulb Temperature:	T =	108.29	°F	Inlet Air Flow 19258.50406
Specific Humidity:	W =	0.020273629		
Water Vapor Pressure:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451874518	psia	Equation [11]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$\rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.065880243	lbm/ft ³	Equation [5]
Water Vapor Density:	$\rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001335632	lbm/ft ³	Equation [6]
Moist Air Density:	$\rho = \rho_a + \rho_v =$	0.067215874	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	1.214518345	psia	Equation [8]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	37.20606771	%	Equation [15]
Equation Coefficients:	a =	2.358607E-02		
	b =	1.007276E-03		
	c =	1.888033E-05		
	d =	3.775047E-07		
	e =	4.871208E-10		
	f =	2.109071E-11		

* Coil Outlet Conditions (Limiting Flow - 108 gpm)

Moist Air Properties -- Given Dry Bulb and Specific Humidity *

Total Pressure:	P =	14.315	psia	
Dry Bulb Temperature:	T =	108.08	°F	Inlet Air Flow 19265.62742
Specific Humidity:	W =	0.020273629		
Water Vapor Pressure:	$P_v = (W \cdot R_v \cdot P) / (R_a + (W \cdot R_v)) =$	0.451874518	psia	Equation [11]
Dry Air Pressure:	$P_a = P - P_v =$	13.86312548	psia	Equation [4]
Dry Air Density:	$Rho_a = (144 / 53.352) \cdot (P_a / (459.67 + T)) =$	0.065904611	lbm/ft ³	Equation [5]
Water Vapor Density:	$Rho_v = (144 / 85.778) \cdot (P_v / (459.67 + T)) =$	0.001336126	lbm/ft ³	Equation [6]
Moist Air Density:	$Rho = Rho_a + Rho_v =$	0.067240736	lbm/ft ³	Equation [7]
Saturated Air Pressure:	$P_s = a + (b \cdot T) + (c \cdot T^2) + (d \cdot T^3) + (e \cdot T^4) + (f \cdot T^5) =$	1.207113757	psia	Equation [8]
Moist Air Relative Humidity:	$RH = P_v / P_s =$	37.43429442	%	Equation [15]
Equation Coefficients:	a =	2.358607E-02		
	b =	1.007276E-03		
	c =	1.888033E-05		
	d =	3.775047E-07		
	e =	4.871208E-10		
	f =	2.109071E-11		

Proto-Power Calc: 97-200
 Attachment: H
 Rev: A Page 13 of 13

* Coil Outlet Conditions (Limiting Flow - 115 gpm)

**Attachment I to
Proto-Power Calculation
97-200
Revision A**

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 2 of 22

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date

Air Flow (acfm)

Air Dry Bulb Temp In (°F)

Air Dry Bulb Temp Out (°F)

Relative Humidity In (%)

Relative Humidity Out (%)

Wet Bulb Temp In (°F)

Wet Bulb Temp Out (°F)

Atmospheric Pressure

Tube Flow (gpm)

Tube Temp In (°F)

Tube Temp Out (°F)

Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
-----------------	-------

Air Flow (acfm)	19,202.00
-----------------	-----------

Tube Inlet Temp (°F)	100.00
----------------------	--------

Air Inlet Temp (°F)	148.0
---------------------	-------

Inlet Relative Humidity (%)	12.76
-----------------------------	-------

Inlet Wet Bulb Temp (°F)	0.00
--------------------------	------

Atmospheric Pressure	14.315
----------------------	--------

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	109.96	118.09	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 675,177
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 675,177
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F) 953.95
Inlet Temperature (°F)	148.00	114.57	j Factor 0.0082
Outlet Temperature (°F)	140.61	118.09	Air-Side ho (BTU/hr·ft ² ·°F) 8.26
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)	144.30	116.33	U Overall (BTU/hr·ft ² ·°F) 5.22
Skin Temperature (°F)	125.07	119.22	Effective Area (ft ²) 905.33
Velocity ***	3,391.01	2.77	LMTD 27.78
Reynold's Number	800**	19,386	Total Heat Transferred (BTU/hr) 131,195
Prandtl Number	0.7255	3.7764	Surface Effectiveness (Eta) 0.9184
Bulk Visc (lbm/ft·hr)	0.0490	1.3943	Sensible Heat Transferred (BTU/hr) 131,195
Skin Visc (lbm/ft·hr)		1.3564	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0623	61.7676	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0162	0.3688	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 4 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Extrapolation Calculation for Row 2(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	937.48
Inlet Temperature (°F)	140.61	111.52	j Factor	0.0082
Outlet Temperature (°F)	134.20	114.57	Air-Side ho (BTU/hr·ft ² ·°F)	8.23
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	137.40	113.04	U Overall (BTU/hr·ft ² ·°F)	5.20
Skin Temperature (°F)	120.67	115.59	Effective Area (ft ²)	905.33
Velocity ***	3,391.01	2.77	LMTD	24.19
Reynold's Number	807**	18,774	Total Heat Transferred (BTU/hr)	113,794
Prandtl Number	0.7261	3.9116	Surface Effectiveness (Eta)	0.9187
Bulk Visc (lbm/ft·hr)	0.0486	1.4398	Sensible Heat Transferred (BTU/hr)	113,794
Skin Visc (lbm/ft·hr)		1.4043	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0630	61.8163	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0161	0.3676		

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	923.12
Inlet Temperature (°F)	134.20	108.86	j Factor	0.0081
Outlet Temperature (°F)	128.63	111.52	Air-Side ho (BTU/hr·ft ² ·°F)	8.20
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	131.42	110.19	U Overall (BTU/hr·ft ² ·°F)	5.18
Skin Temperature (°F)	116.84	112.44	Effective Area (ft ²)	905.33
Velocity ***	3,391.01	2.76	LMTD	21.08
Reynold's Number	813**	18,249	Total Heat Transferred (BTU/hr)	98,800
Prandtl Number	0.7266	4.0355	Surface Effectiveness (Eta)	0.9189
Bulk Visc (lbm/ft·hr)	0.0482	1.4812	Sensible Heat Transferred (BTU/hr)	98,800
Skin Visc (lbm/ft·hr)		1.4484	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0636	61.8573	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0159	0.3666		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 5 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Extrapolation Calculation for Row 4(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	910.59
Inlet Temperature (°F)	128.63	106.56	j Factor	0.0081
Outlet Temperature (°F)	123.80	108.86	Air-Side ho (BTU/hr·ft ² ·°F)	8.18
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	126.21	107.71		
Skin Temperature (°F)	113.52	109.69	U Overall (BTU/hr·ft ² ·°F)	5.16
Velocity ***	3,391.01	2.76	Effective Area (ft ²)	905.33
Reynold's Number	819**	17,797	LMTD	18.38
Prandtl Number	0.7270	4.1483	Total Heat Transferred (BTU/hr)	85,857
Bulk Visc (lbm/ft·hr)	0.0479	1.5188		
Skin Visc (lbm/ft·hr)		1.4886	Surface Effectiveness (Eta)	0.9191
Density (lbm/ft ³)	0.0641	61.8920	Sensible Heat Transferred (BTU/hr)	85,857
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3657	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	899.66
Inlet Temperature (°F)	123.80	104.55	j Factor	0.0081
Outlet Temperature (°F)	119.59	106.56	Air-Side ho (BTU/hr·ft ² ·°F)	8.16
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	121.69	105.56		
Skin Temperature (°F)	110.63	107.30	U Overall (BTU/hr·ft ² ·°F)	5.15
Velocity ***	3,391.01	2.76	Effective Area (ft ²)	905.33
Reynold's Number	823**	17,408	LMTD	16.03
Prandtl Number	0.7273	4.2505	Total Heat Transferred (BTU/hr)	74,667
Bulk Visc (lbm/ft·hr)	0.0476	1.5528		
Skin Visc (lbm/ft·hr)		1.5252	Surface Effectiveness (Eta)	0.9193
Density (lbm/ft ³)	0.0646	61.9215	Sensible Heat Transferred (BTU/hr)	74,667
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3649	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 6 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Extrapolation Calculation for Row 6(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	890.12
Inlet Temperature (°F)	119.59	102.81	j Factor	0.0081
Outlet Temperature (°F)	115.93	104.55	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	117.76	103.68		
Skin Temperature (°F)	108.11	105.21	U Overall (BTU/hr·ft ² ·°F)	5.13
Velocity ***	3,391.01	2.76	Effective Area (ft ²)	905.33
Reynold's Number	828**	17,071	LMTD	13.98
Prandtl Number	0.7276	4.3429	Total Heat Transferred (BTU/hr)	64,980
Bulk Visc (lbm/ft·hr)	0.0473	1.5834		
Skin Visc (lbm/ft·hr)		1.5583	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0650	61.9466	Sensible Heat Transferred (BTU/hr)	64,980
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3642	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	881.79
Inlet Temperature (°F)	115.93	101.29	j Factor	0.0081
Outlet Temperature (°F)	112.74	102.81	Air-Side ho (BTU/hr·ft ² ·°F)	8.13
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	114.33	102.05		
Skin Temperature (°F)	105.92	103.40	U Overall (BTU/hr·ft ² ·°F)	5.12
Velocity ***	3,391.01	2.76	Effective Area (ft ²)	905.33
Reynold's Number	832**	16,780	LMTD	12.20
Prandtl Number	0.7278	4.4260	Total Heat Transferred (BTU/hr)	56,584
Bulk Visc (lbm/ft·hr)	0.0471	1.6109		
Skin Visc (lbm/ft·hr)		1.5881	Surface Effectiveness (Eta)	0.9196
Density (lbm/ft ³)	0.0654	61.9680	Sensible Heat Transferred (BTU/hr)	56,584
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3636	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: I
Rev: A Page 7 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 75 gpm Case

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	874.52
Inlet Temperature (°F)	112.74	99.97	j Factor	0.0081
Outlet Temperature (°F)	109.96	101.29	Air-Side ho (BTU/hr·ft ² ·°F)	8.12
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	111.35	100.63		
Skin Temperature (°F)	104.01	101.81	U Overall (BTU/hr·ft ² ·°F)	5.11
Velocity ***	3,391.01	2.76	Effective Area (ft ²)	905.33
Reynold's Number	835**	16,528	LMTD	10.65
Prandtl Number	0.7280	4.5004	Total Heat Transferred (BTU/hr)	49,300
Bulk Visc (lbm/ft·hr)	0.0469	1.6354		
Skin Visc (lbm/ft·hr)		1.6149	Surface Effectiveness (Eta)	0.9197
Density (lbm/ft ³)	0.0657	61.9863	Sensible Heat Transferred (BTU/hr)	49,300
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3630	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 8 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 9 of 22

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,258.50
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	108.29	113.17	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)			
Skin Temperature (°F)			U Overall (BTU/hr·ft ² ·°F)
Velocity ***			Effective Area (ft ²) 7,242.65
Reynold's Number			LMTD
Prandtl Number			Total Heat Transferred (BTU/hr) 707,030
Bulk Visc (lbm/ft·hr)			
Skin Visc (lbm/ft·hr)			Surface Effectiveness (Eta)
Density (lbm/ft ³)			Sensible Heat Transferred (BTU/hr) 707,030
Cp (BTU/lbm·°F)			Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)			Heat to Condensate (BTU/hr)

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F) 1,246.55
Inlet Temperature (°F)	148.00	110.31	j Factor 0.0082
Outlet Temperature (°F)	139.36	113.17	Air-Side ho (BTU/hr·ft ² ·°F) 8.27
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)	143.68	111.74	
Skin Temperature (°F)	121.18	114.33	U Overall (BTU/hr·ft ² ·°F) 5.35
Velocity ***	3,400.99	3.98	Effective Area (ft ²) 905.33
Reynold's Number	803**	26,688	LMTD 31.73
Prandtl Number	0.7255	3.9675	Total Heat Transferred (BTU/hr) 153,749
Bulk Visc (lbm/ft·hr)	0.0490	1.4585	
Skin Visc (lbm/ft·hr)		1.4217	Surface Effectiveness (Eta) 0.9183
Density (lbm/ft ³)	0.0625	61.8352	Sensible Heat Transferred (BTU/hr) 153,749
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)	0.0162	0.3672	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 11 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,228.62
Inlet Temperature (°F)	139.36	107.92	j Factor	0.0081
Outlet Temperature (°F)	132.18	110.31	Air-Side ho (BTU/hr·ft ² ·°F)	8.24
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	135.77	109.11		
Skin Temperature (°F)	116.99	111.30	U Overall (BTU/hr·ft ² ·°F)	5.33
Velocity ***	3,400.99	3.98	Effective Area (ft ²)	905.33
Reynold's Number	811**	25,996	LMTD	26.49
Prandtl Number	0.7262	4.0838	Total Heat Transferred (BTU/hr)	127,833
Bulk Visc (lbm/ft·hr)	0.0485	1.4973		
Skin Visc (lbm/ft·hr)		1.4649	Surface Effectiveness (Eta)	0.9186
Density (lbm/ft ³)	0.0632	61.8725	Sensible Heat Transferred (BTU/hr)	127,833
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0160	0.3662	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,213.64
Inlet Temperature (°F)	132.18	105.94	j Factor	0.0081
Outlet Temperature (°F)	126.21	107.92	Air-Side ho (BTU/hr·ft ² ·°F)	8.21
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	129.19	106.93		
Skin Temperature (°F)	113.51	108.77	U Overall (BTU/hr·ft ² ·°F)	5.31
Velocity ***	3,400.99	3.98	Effective Area (ft ²)	905.33
Reynold's Number	818**	25,424	LMTD	22.12
Prandtl Number	0.7267	4.1849	Total Heat Transferred (BTU/hr)	106,417
Bulk Visc (lbm/ft·hr)	0.0481	1.5310		
Skin Visc (lbm/ft·hr)		1.5025	Surface Effectiveness (Eta)	0.9189
Density (lbm/ft ³)	0.0639	61.9028	Sensible Heat Transferred (BTU/hr)	106,417
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0159	0.3654	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 12 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,201.11
Inlet Temperature (°F)	126.21	104.29	j Factor	0.0081
Outlet Temperature (°F)	121.22	105.94	Air-Side ho (BTU/hr·ft ² ·°F)	8.19
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	123.72	105.11		
Skin Temperature (°F)	110.61	106.66	U Overall (BTU/hr·ft ² ·°F)	5.30
Velocity ***	3,400.99	3.98	Effective Area (ft ²)	905.33
Reynold's Number	824**	24,952	LMTD	18.48
Prandtl Number	0.7272	4.2722	Total Heat Transferred (BTU/hr)	88,681
Bulk Visc (lbm/ft·hr)	0.0477	1.5600		
Skin Visc (lbm/ft·hr)		1.5352	Surface Effectiveness (Eta)	0.9191
Density (lbm/ft ³)	0.0644	61.9275	Sensible Heat Transferred (BTU/hr)	88,681
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3647	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,190.65
Inlet Temperature (°F)	121.22	102.91	j Factor	0.0081
Outlet Temperature (°F)	117.07	104.29	Air-Side ho (BTU/hr·ft ² ·°F)	8.17
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	119.15	103.60		
Skin Temperature (°F)	108.20	104.90	U Overall (BTU/hr·ft ² ·°F)	5.29
Velocity ***	3,400.99	3.97	Effective Area (ft ²)	905.33
Reynold's Number	829**	24,560	LMTD	15.45
Prandtl Number	0.7275	4.3472	Total Heat Transferred (BTU/hr)	73,965
Bulk Visc (lbm/ft·hr)	0.0474	1.5848		
Skin Visc (lbm/ft·hr)		1.5634	Surface Effectiveness (Eta)	0.9192
Density (lbm/ft ³)	0.0649	61.9477	Sensible Heat Transferred (BTU/hr)	73,965
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3642	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 13 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Extrapolation Calculation for Row 6(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,181.90
Inlet Temperature (°F)	117.07	101.76	j Factor	0.0081
Outlet Temperature (°F)	113.60	102.91	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	115.34	102.33		
Skin Temperature (°F)	106.18	103.43	U Overall (BTU/hr·ft ² ·°F)	5.28
Velocity ***	3,400.99	3.97	Effective Area (ft ²)	905.33
Reynold's Number	833**	24,235	LMTD	12.92
Prandtl Number	0.7277	4.4115	Total Heat Transferred (BTU/hr)	61,737
Bulk Visc (lbm/ft·hr)	0.0472	1.6061		
Skin Visc (lbm/ft·hr)		1.5876	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0653	61.9643	Sensible Heat Transferred (BTU/hr)	61,737
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3637	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,174.58
Inlet Temperature (°F)	113.60	100.79	j Factor	0.0081
Outlet Temperature (°F)	110.71	101.76	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	112.15	101.27		
Skin Temperature (°F)	104.49	102.20	U Overall (BTU/hr·ft ² ·°F)	5.27
Velocity ***	3,400.99	3.97	Effective Area (ft ²)	905.33
Reynold's Number	837**	23,965	LMTD	10.81
Prandtl Number	0.7279	4.4663	Total Heat Transferred (BTU/hr)	51,562
Bulk Visc (lbm/ft·hr)	0.0470	1.6242		
Skin Visc (lbm/ft·hr)		1.6084	Surface Effectiveness (Eta)	0.9195
Density (lbm/ft ³)	0.0656	61.9780	Sensible Heat Transferred (BTU/hr)	51,562
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3633	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 14 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 108 gpm Case

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,168.45
Inlet Temperature (°F)	110.71	99.99	j Factor	0.0080
Outlet Temperature (°F)	108.29	100.79	Air-Side ho (BTU/hr·ft ² ·°F)	8.13
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	109.50	100.39		
Skin Temperature (°F)	103.09	101.17	U Overall (BTU/hr·ft ² ·°F)	5.26
Velocity ***	3,400.99	3.97	Effective Area (ft ²)	905.33
Reynold's Number	840**	23,740	LMTD	9.05
Prandtl Number	0.7281	4.5129	Total Heat Transferred (BTU/hr)	43,086
Bulk Visc (lbm/ft·hr)	0.0468	1.6396		
Skin Visc (lbm/ft·hr)		1.6261	Surface Effectiveness (Eta)	0.9196
Density (lbm/ft ³)	0.0659	61.9893	Sensible Heat Transferred (BTU/hr)	43,086
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0154	0.3629	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: I
Rev: A Page 15 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 16 of 22

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	115.00
Air Flow (acfm)	19,266.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	108.08	112.47	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 710,964
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 710,964
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F) 1,306.21
Inlet Temperature (°F)	148.00	109.72	j Factor 0.0082
Outlet Temperature (°F)	139.18	112.47	Air-Side ho (BTU/hr·ft ² ·°F) 8.27
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)	143.59	111.09	U Overall (BTU/hr·ft ² ·°F) 5.37
Skin Temperature (°F)	120.62	113.62	Effective Area (ft ²) 905.33
Velocity ***	3,402.31	4.24	LMTD 32.29
Reynold's Number	803**	28,236	Total Heat Transferred (BTU/hr) 157,023
Prandtl Number	0.7255	3.9956	Surface Effectiveness (Eta) 0.9183
Bulk Visc (lbm/ft·hr)	0.0490	1.4678	Sensible Heat Transferred (BTU/hr) 157,023
Skin Visc (lbm/ft·hr)		1.4317	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0625	61.8444	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0162	0.3669	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: I
Rev: A Page 18 of 22

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Extrapolation Calculation for Row 2(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,288.13
Inlet Temperature (°F)	139.18	107.45	j Factor	0.0081
Outlet Temperature (°F)	131.90	109.72	Air-Side ho (BTU/hr-ft ² -°F)	8.24
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.03976622
Average Temp (°F)	135.54	108.58		
Skin Temperature (°F)	116.48	110.70	U Overall (BTU/hr-ft ² -°F)	5.35
Velocity ***	3,402.31	4.24	Effective Area (ft ²)	905.33
Reynold's Number	811**	27,532	LMTD	26.78
Prandtl Number	0.7262	4.1080	Total Heat Transferred (BTU/hr)	129,763
Bulk Visc (lbm/ft-hr)	0.0485	1.5054		
Skin Visc (lbm/ft-hr)		1.4737	Surface Effectiveness (Eta)	0.9186
Density (lbm/ft ³)	0.0633	61.8799	Sensible Heat Transferred (BTU/hr)	129,763
Cp (BTU/lbm-°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0160	0.3660	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr-ft ² -°F)	1,273.11
Inlet Temperature (°F)	131.90	105.57	j Factor	0.0081
Outlet Temperature (°F)	125.87	107.45	Air-Side ho (BTU/hr-ft ² -°F)	8.21
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU)	0.03976622
Average Temp (°F)	128.88	106.51		
Skin Temperature (°F)	113.06	108.28	U Overall (BTU/hr-ft ² -°F)	5.33
Velocity ***	3,402.31	4.23	Effective Area (ft ²)	905.33
Reynold's Number	818**	26,955	LMTD	22.23
Prandtl Number	0.7268	4.2049	Total Heat Transferred (BTU/hr)	107,371
Bulk Visc (lbm/ft-hr)	0.0480	1.5376		
Skin Visc (lbm/ft-hr)		1.5101	Surface Effectiveness (Eta)	0.9189
Density (lbm/ft ³)	0.0639	61.9086	Sensible Heat Transferred (BTU/hr)	107,371
Cp (BTU/lbm-°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.0159	0.3653	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 19 of 22

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Extrapolation Calculation for Row 4(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,260.64
Inlet Temperature (°F)	125.87	104.01	j Factor	0.0081
Outlet Temperature (°F)	120.87	105.57	Air-Side ho (BTU/hr·ft ² ·°F)	8.19
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	123.37	104.79		
Skin Temperature (°F)	110.23	106.27	U Overall (BTU/hr·ft ² ·°F)	5.32
Velocity ***	3,402.31	4.23	Effective Area (ft ²)	905.33
Reynold's Number	824**	26,480	LMTD	18.46
Prandtl Number	0.7272	4.2880	Total Heat Transferred (BTU/hr)	88,937
Bulk Visc (lbm/ft·hr)	0.0477	1.5652		
Skin Visc (lbm/ft·hr)		1.5414	Surface Effectiveness (Eta)	0.9191
Density (lbm/ft ³)	0.0645	61.9318	Sensible Heat Transferred (BTU/hr)	88,937
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0158	0.3646	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,250.27
Inlet Temperature (°F)	120.87	102.72	j Factor	0.0081
Outlet Temperature (°F)	116.73	104.01	Air-Side ho (BTU/hr·ft ² ·°F)	8.17
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	118.80	103.36		
Skin Temperature (°F)	107.89	104.60	U Overall (BTU/hr·ft ² ·°F)	5.31
Velocity ***	3,402.31	4.23	Effective Area (ft ²)	905.33
Reynold's Number	829**	26,089	LMTD	15.34
Prandtl Number	0.7275	4.3589	Total Heat Transferred (BTU/hr)	73,733
Bulk Visc (lbm/ft·hr)	0.0474	1.5887		
Skin Visc (lbm/ft·hr)		1.5682	Surface Effectiveness (Eta)	0.9192
Density (lbm/ft ³)	0.0649	61.9508	Sensible Heat Transferred (BTU/hr)	73,733
Cp (BTU/lbm·°F)	0.2402	0.9989	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0157	0.3641	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 20 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Extrapolation Calculation for Row 6(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,241.66
Inlet Temperature (°F)	116.73	101.65	j Factor	0.0081
Outlet Temperature (°F)	113.30	102.72	Air-Side ho (BTU/hr·ft ² ·°F)	8.15
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	115.02	102.18		
Skin Temperature (°F)	105.94	103.22	U Overall (BTU/hr·ft ² ·°F)	5.30
Velocity ***	3,402.31	4.23	Effective Area (ft ²)	905.33
Reynold's Number	834**	25,766	LMTD	12.75
Prandtl Number	0.7277	4.4190	Total Heat Transferred (BTU/hr)	61,173
Bulk Visc (lbm/ft·hr)	0.0472	1.6086		
Skin Visc (lbm/ft·hr)		1.5911	Surface Effectiveness (Eta)	0.9194
Density (lbm/ft ³)	0.0653	61.9663	Sensible Heat Transferred (BTU/hr)	61,173
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0156	0.3636	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,234.50
Inlet Temperature (°F)	113.30	100.76	j Factor	0.0081
Outlet Temperature (°F)	110.45	101.65	Air-Side ho (BTU/hr·ft ² ·°F)	8.14
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	111.87	101.20		
Skin Temperature (°F)	104.33	102.07	U Overall (BTU/hr·ft ² ·°F)	5.29
Velocity ***	3,402.31	4.23	Effective Area (ft ²)	905.33
Reynold's Number	837**	25,499	LMTD	10.60
Prandtl Number	0.7279	4.4700	Total Heat Transferred (BTU/hr)	50,784
Bulk Visc (lbm/ft·hr)	0.0470	1.6254		
Skin Visc (lbm/ft·hr)		1.6106	Surface Effectiveness (Eta)	0.9195
Density (lbm/ft ³)	0.0656	61.9789	Sensible Heat Transferred (BTU/hr)	50,784
Cp (BTU/lbm·°F)	0.2402	0.9990	Latent Heat Transferred (BTU/hr)	
K (BTU/hr·ft·°F)	0.0155	0.3633	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 21 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Limiting Flow Analysis -- 115 gpm Case

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,194.37	57,183.32	Tube-Side hi (BTU/hr·ft ² ·°F)	1,228.54
Inlet Temperature (°F)	110.45	100.02	j Factor	0.0080
Outlet Temperature (°F)	108.08	100.76	Air-Side ho (BTU/hr·ft ² ·°F)	8.13
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.03976622
Average Temp (°F)	109.26	100.39	U Overall (BTU/hr·ft ² ·°F)	5.28
Skin Temperature (°F)	102.99	101.11	Effective Area (ft ²)	905.33
Velocity ***	3,402.31	4.23	LMTD	8.82
Reynold's Number	840**	25,278	Total Heat Transferred (BTU/hr)	42,181
Prandtl Number	0.7281	4.5130	Surface Effectiveness (Eta)	0.9196
Bulk Visc (lbm/ft·hr)	0.0468	1.6396	Sensible Heat Transferred (BTU/hr)	42,181
Skin Visc (lbm/ft·hr)		1.6270	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0659	61.9894	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9990		
K (BTU/hr·ft·°F)	0.0154	0.3629		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: I

Rev: A Page 22 of 22

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment J to
Proto-Power Calculation
97-200
Revision A**

Proto-HX Analytical Uncertainty Calculation [Circular Fin Air Coil Application]

Purpose

The purpose of the following calculation is to evaluate the analytical uncertainty associated with the analysis of test data and the computation of heat transfer rate at a given extrapolation condition. This calculation focuses only on the parameters that are not measured during the thermal performance test but factor into the analysis of the test results. Test parameter measurement uncertainty is treated separately in the test uncertainty analysis. The calculation of analytical uncertainty is derived for a typical eight-row Air Cooler.

Governing Heat Transfer Equations

Heat transfer calculations associated with a heat exchanger generally reduce to satisfying the following equations:

$$1) \quad q = U A_o \text{ LMTD}$$

Where:

- q = Heat transfer rate at test conditions (BTU/hr)
- U = Overall heat transfer coefficient at test conditions (BTU/hr-°F-ft²)
- A_o = Heat transfer surface area referenced to outside (air-side) surface (ft²)
- LMTD = Log Mean Temperature Difference at test conditions (°F)

and

$$2) \quad q = \dot{m} c_p (T_{c_o} - T_{c_i}) = \rho Q c_p \Delta T$$

Where:

- q = Heat transfer rate at test conditions (BTU/hr)
- \dot{m} = Mass flow rate at test conditions (lbm/hr)
- c_p = Specific heat of cooling water at test conditions (Btu/lb_m-°F)
- T_{c_i} = Tube-side inlet temperature at test conditions (°F)
- T_{c_o} = Tube-side outlet temperature at test conditions (°F)
- ρ = Density of tube-side fluid at average bulk temperature at test conditions (lb_m/ft³)
- Q = Volumetric flow rate of tube-side fluid at test conditions (gpm)

The first equation is used, in Proto-HX, to evaluate the heat transfer rate from test data. The analytical uncertainties associated with evaluating the fluid properties are usually the only contributors to the overall uncertainty when using this equation. For a given test condition, the right hand side of the second equation is evaluated such that it matches the measured heat

transfer rate, “q”. In Proto-HX, this means iterating on fouling factor, and therefore “U”, until the heat transfer equation is satisfied.

The following equations are used for this iteration:

$$3) \quad R = \frac{1}{U} = \frac{A_o \text{ LMTD}_{\text{Test}}}{q_{\text{Test}}}$$

Where:

- R = Overall heat transfer thermal resistance at test conditions (hr-°F-ft²/ BTU)
- U = Overall heat transfer coefficient at test conditions (BTU/hr-°F-ft²)
- A_o = Outside heat transfer surface area (ft²)
- LMTD = Log Mean Temperature Difference at test conditions (°F)
- q = Heat transfer rate at test conditions (BTU/hr)

and

$$4) \quad R_f = R - \frac{1}{h_o \eta_s} - R_w - \left(\frac{A_o}{A_i} \right) \frac{1}{h_i}$$

Where:

- R_f = Fouling resistance (hr-°F-ft²/ BTU)
- R = Overall heat transfer thermal resistance at test conditions (hr-°F-ft²/ BTU)
- h_o = Outside convection film coefficient at test conditions (BTU/hr-°F-ft²)
- η_s = Fin surface effectiveness
- R_w = Wall thermal resistance at test conditions (hr-°F-ft²/ BTU)
- A_o = Outside heat transfer surface area (ft²)
- A_i = Inside heat transfer surface area (ft²)
- h_i = Inside convection film coefficient at test conditions (BTU/hr-°F-ft²)

These same equations must be satisfied when evaluating the capacity of a heat exchanger at a given fouling condition (i.e., when extrapolating to the limiting thermal condition). The following equations are used for the extrapolation process:

$$5) \quad R^* = R_f + \frac{1}{h_o^* \eta_s} + R_w^* + \left(\frac{A_o}{A_i} \right) \frac{1}{h_i^*}$$

Where:

- R* = Overall thermal resistance at extrapolation conditions (hr-°F-ft²/ BTU)
- R_f = Calculated fouling resistance (hr-°F-ft²/ BTU)
- h_o* = Outside convection film coefficient at extrapolation conditions (BTU/hr-°F-ft²)
- η_s = Fin surface effectiveness
- R_w* = Wall thermal resistance at extrapolation conditions (hr-°F-ft²/ BTU)
- A_o = Outside heat transfer surface area (ft²)
- A_i = Inside heat transfer surface area (ft²)

h_i^* = Inside convection film coefficient at extrapolation conditions (BTU/hr-°F-ft²)

and

$$6) \quad q^* = (1/R^*) A_o \text{ LMTD}^* = U^* A_o \text{ LMTD}^*$$

where:

q^* = Heat transfer rate at extrapolation conditions (BTU/hr)

R^* = Overall thermal resistance at extrapolation conditions (hr-°F-ft²/ BTU)

U^* = Overall heat coefficient at extrapolation conditions (BTU/hr-°F-ft²)

A_o = Heat transfer surface area referenced to outside surface (ft²)

LMTD^* = Log Mean Temperature Difference at extrapolation conditions (°F)

Analytical Uncertainty Calculation Methodology

The method for calculating the analytical uncertainty associated with this performance analysis method is illustrated as follows:

Given a function $D = f(A,B,C)$

The effect on D of slight changes in the independent variables A , B , and C may be calculated by taking the partial derivatives of D with respect to each of the independent variables.

Accordingly, the change in the value of D (i.e., ΔD) due to changes in each of the independent variables (ΔA , ΔB , ΔC) may be represented by the following equation:

$$\Delta D = \frac{\partial D}{\partial A} \Delta A + \frac{\partial D}{\partial B} \Delta B + \frac{\partial D}{\partial C} \Delta C$$

If ΔA , ΔB , ΔC are the known (or estimated) errors of the independent variables, then the error, ΔD , associated with the derived value, D , is calculated. The most probable one standard deviation error representative of ΔD would be the statistical root mean squared value derived as follows:

$$\Delta D = \left[\left(\frac{\partial D}{\partial A} \Delta A \right)^2 + \left(\frac{\partial D}{\partial B} \Delta B \right)^2 + \left(\frac{\partial D}{\partial C} \Delta C \right)^2 \right]^{1/2} = U_D$$

Expressing the uncertainty in terms of a percentage of the value of D is simply a matter of including division by the value of D as follows:

$$\frac{U_D}{D} = \left[\left(\frac{\partial D}{\partial A} \right)^2 \left(\frac{\Delta A}{D} \right)^2 + \left(\frac{\partial D}{\partial B} \right)^2 \left(\frac{\Delta B}{D} \right)^2 + \left(\frac{\partial D}{\partial C} \right)^2 \left(\frac{\Delta C}{D} \right)^2 \right]^{1/2}$$

The next six sections of this document provide a step by step approach to calculating the analytical uncertainty associated with the six thermal performance equations outlined above. The specific terms to be evaluated from these equations are as follows:

- 1) Heat transfer area, A_o and area uncertainty, U_{A_o}
- 2) Test condition heat transfer rate, q and heat transfer uncertainty, U_q
- 3) Test condition thermal resistance, R and thermal resistance uncertainty, U_R
- 4) Observed overall fouling resistance, R_f fouling resistance uncertainty, U_{R_f}
- 5) Extrapolation condition thermal resistance, R^* and thermal resistance uncertainty, U_{R^*}
- 6) Extrapolation condition heat transfer rate, q^* and heat transfer rate uncertainty, U_{q^*}

All uncertainty equations used in this calculation are based on the methods of Reference [1]. It is assumed that all independent variables in each equation have no influence on each other. For example, in Equation (6), $LMTD^*$ and the overall heat transfer coefficient, U^* , are independent of each other. More specific assumptions are stated in each section as applicable.

1) Uncertainty in Calculation of Heat Transfer Area (A_o)

Governing Equation

$$q = U A_o \text{ LMTD}$$

For Air Coolers with circular fins, the outside tube surface area, the fin surface area and the total outside surface area are given by the following expressions:

$$A_{o_{\text{Tube}}} = \pi N_T N_L L_C d_o (1 - \lambda t_{FR})$$

$$A_{o_{\text{Fin}}} = \pi \lambda N_T N_L L_C \left[H_F t_{FT} + (H_F + d_o) \sqrt{\left(\frac{H_F - d_o}{2}\right)^2 + \left(\frac{t_{FR} - t_{FT}}{2}\right)^2} \right]$$

$$A_{o_{\text{Total}}} = \pi N_T N_L L_C \left\{ d_o (1 - \lambda t_{FR}) + \lambda \left[H_F t_{FT} + (H_F + d_o) \sqrt{\left(\frac{H_F - d_o}{2}\right)^2 + \left(\frac{t_{FR} - t_{FT}}{2}\right)^2} \right] \right\}$$

where:

- N_T = Number of tubes per row
- N_L = Number of active tube rows
- L_C = Effective tube (coil) length (in)
- d_o = Tube outside diameter (in)
- λ = Fin pitch (fins/inch)
- H_F = Fin height (in)
- t_{FR} = Thickness of fin at root (in)
- t_{FT} = Thickness of fin at tip (in)

For the case where $t_{FR} = t_{FT} = t_F$, the total area equation reduces to the following:

$$A_{o_{\text{Total}}} = \pi N_T N_L L_C \left\{ d_o (1 - \lambda t_F) + \lambda \left[H_F t_F + (H_F + d_o) \frac{(H_F - d_o)}{2} \right] \right\}$$

$$A_{o_{\text{Total}}} = \pi N_T N_L L_C \left\{ d_o - \lambda d_o t_F + \frac{\lambda}{2} [2H_F t_F + H_F^2 - d_o^2] \right\}$$

Assumptions

$$U_{N_T} = 0$$

$$U_{N_L} = 0$$

$$U_{\lambda} = 0$$

Analysis

$$\frac{U_{A_o}}{A_o} = \left\{ \left(\frac{\partial A_o}{\partial d_o} \right)^2 \left(\frac{U_{d_o}}{A_o} \right)^2 + \left(\frac{\partial A_o}{\partial L_c} \right)^2 \left(\frac{U_{L_c}}{A_o} \right)^2 + \left(\frac{\partial A_o}{\partial t_F} \right)^2 \left(\frac{U_{t_F}}{A_o} \right)^2 + \left(\frac{\partial A_o}{\partial H_F} \right)^2 \left(\frac{U_{H_F}}{A_o} \right)^2 \right\}^{1/2}$$

where,

$$\left(\frac{\partial A_o}{\partial d_o} \right) = \pi N_T N_L L_c \{ (1 - \lambda t_F) - \lambda d_o \}$$

$$\left(\frac{\partial A_o}{\partial L_c} \right) = \pi N_T N_L \left\{ d_o - \lambda d_o t_F + \frac{\lambda}{2} [2H_F t_F + H_F^2 - d_o^2] \right\}$$

$$\left(\frac{\partial A_o}{\partial t_F} \right) = \pi N_T N_L L_c \lambda \{ H_F - d_o \}$$

$$\left(\frac{\partial A_o}{\partial H_F} \right) = \pi N_T N_L L_c \lambda \{ t_F + H_F \}$$

2) Uncertainty in Calculation of Heat Transfer Rate at Test Conditions

Governing Equation

$$q_{\text{Test}} = \dot{m} c_p (T_{c_o} - T_{c_i}) = \rho Q c_p \Delta T$$

Assumptions

$$U_{\Delta T} = 0$$

$$U_{Q_{\text{SW}}} = 0$$

(i.e., temperature and flow rate in the governing equation are measured values with no analytical uncertainties)

Analysis

$$\frac{U_{q_{\text{test}}}}{q_{\text{test}}} = \left[\left(\frac{\partial q_{\text{test}}}{\partial \rho} \right)^2 \left(\frac{U_{\rho}}{q_{\text{test}}} \right)^2 + \left(\frac{\partial q_{\text{test}}}{\partial Q_{\text{SW}}} \right)^2 \left(\frac{U_{Q}}{q_{\text{test}}} \right)^2 + \left(\frac{\partial q_{\text{test}}}{\partial c_p} \right)^2 \left(\frac{U_{c_p}}{q_{\text{test}}} \right)^2 + \left(\frac{\partial q_{\text{test}}}{\partial \Delta T} \right)^2 \left(\frac{U_{\Delta T}}{q_{\text{test}}} \right)^2 \right]^{1/2}$$

$$\frac{U_{q_{\text{test}}}}{q_{\text{test}}} = \left[(Q_{\text{SW}} c_p \Delta T)^2 \left(\frac{U_{\rho}}{q_{\text{test}}} \right)^2 + (\rho Q_{\text{SW}} \Delta T)^2 \left(\frac{U_{c_p}}{q_{\text{test}}} \right)^2 \right]^{1/2}$$

3) Uncertainty in Calculation of Thermal Resistance at Test Conditions

Governing Equation

$$R = \frac{1}{U} = \frac{A_o \text{ LMTD}_{\text{Test}}}{q_{\text{Test}}}$$

Assumptions

U_{LMTD} is negligible

Analysis

$$\frac{U_R}{R} = \left[\left(\frac{\partial R}{\partial A_o} \right)^2 \left(\frac{U_{A_o}}{R} \right)^2 + \left(\frac{\partial R}{\partial \text{LMTD}} \right)^2 \left(\frac{U_{\text{LMTD}}}{R} \right)^2 + \left(\frac{\partial R}{\partial q_{\text{test}}} \right)^2 \left(\frac{U_{q_{\text{test}}}}{R} \right)^2 \right]^{1/2}$$

$$\frac{U_R}{R} = \left[\left(\frac{\text{LMTD}}{q_{\text{test}}} \right)^2 \left(\frac{U_{A_o}}{R} \right)^2 + \left(\frac{-A_o \text{LMTD}}{q_{\text{test}}^2} \right)^2 \left(\frac{U_{q_{\text{test}}}}{R} \right)^2 \right]^{1/2}$$

U_{A_o} (Evaluated in Section 1)

$U_{q_{\text{test}}}$ (Evaluated in Section 2)

4) Uncertainty in Calculation of Fouling Factor at Test Conditions

Governing Equation

$$R_f = R - \frac{1}{h_o \eta_s} - R_w - \left(\frac{A_o}{A_i} \right) \frac{1}{h_i} = R - \frac{1}{h_{o,eff}} - R_w - \left(\frac{A_o}{A_i} \right) \frac{1}{h_i}$$

Where,

$$h_{o,eff} = \text{effective outside film coefficient} = (h_o) \times (\eta_s)$$

Assumptions

$$\left(\frac{\partial R_f}{\partial A_o} \right)^2 \left(\frac{U_{A_o}}{R_f} \right)^2 \approx 0$$

$$\left(\frac{\partial R_f}{\partial A_i} \right)^2 \left(\frac{U_{A_i}}{R_f} \right)^2 \approx 0$$

(i.e., the uncertainty in dimensions is negligible compared to the thermal resistance and convection coefficient uncertainties)

Analysis

$$\frac{U_{R_f}}{R_f} = \left[\left(\frac{\partial R_f}{\partial R} \right)^2 \left(\frac{U_R}{R_f} \right)^2 + \left(\frac{\partial R_f}{\partial h_{o,eff}} \right)^2 \left(\frac{U_{h_{o,eff}}}{R_f} \right)^2 + \left(\frac{\partial R_f}{\partial R_w} \right)^2 \left(\frac{U_{R_w}}{R_f} \right)^2 + \left(\frac{\partial R_f}{\partial h_i} \right)^2 \left(\frac{U_{h_i}}{R_f} \right)^2 \right]^{1/2}$$

$$\frac{U_{R_f}}{R_f} = \left[\left(\frac{U_R}{R_f} \right)^2 + \left(\frac{1}{h_{o,eff}^2} \right)^2 \left(\frac{U_{h_{o,eff}}}{R_f} \right)^2 + \left(\frac{U_{R_w}}{R_f} \right)^2 + \left(\frac{A_o}{A_i} \frac{1}{h_i^2} \right)^2 \left(\frac{U_{h_i}}{R_f} \right)^2 \right]^{1/2}$$

U_R (Evaluated in Section 3)

5) Uncertainty in Calculation of Heat Transfer Resistance at Extrapolation Conditions

Governing Equation

$$R^* = R_f + \frac{1}{h_{o,eff}^*} + R_w + \left(\frac{A_o}{A_i}\right) \frac{1}{h_i^*}$$

Assumptions

$$\left(\frac{\partial R^*}{\partial A_o}\right)^2 \left(\frac{U_{A_o}}{R^*}\right)^2 \approx 0$$

$$\left(\frac{\partial R^*}{\partial A_i}\right)^2 \left(\frac{U_{A_i}}{R^*}\right)^2 \approx 0$$

(i.e., the uncertainty in dimensions is negligible compared to the thermal resistance and convection coefficient uncertainties)

Analysis

$$\frac{U_{R^*}}{R^*} = \left[\left(\frac{\partial R^*}{\partial R_f}\right)^2 \left(\frac{U_{R_f}}{R^*}\right)^2 + \left(\frac{\partial R^*}{\partial h_{o,eff}^*}\right)^2 \left(\frac{U_{h_{o,eff}^*}}{R^*}\right)^2 + \left(\frac{\partial R^*}{\partial R_w}\right)^2 \left(\frac{U_{R_w}}{R^*}\right)^2 + \left(\frac{\partial R^*}{\partial h_i^*}\right)^2 \left(\frac{U_{h_i^*}}{R^*}\right)^2 \right]^{1/2}$$

$$\frac{U_{R^*}}{R^*} = \left[\left(\frac{U_{R_f}}{R^*}\right)^2 + \left(-\frac{1}{h_{o,eff}^{*2}}\right)^2 \left(\frac{U_{h_{o,eff}^*}}{R^*}\right)^2 + \left(\frac{U_{R_w}}{R^*}\right)^2 + \left(-\frac{A_o}{A_i} \frac{1}{h_i^{*2}}\right)^2 \left(\frac{U_{h_i^*}}{R^*}\right)^2 \right]^{1/2}$$

$$U_{R_f} \quad \text{(Evaluated in Section 4)}$$

$$U_{R_f} = 0 \quad \text{(for extrapolation calculations only, i.e., no fouling calculation)}$$

6) Uncertainty in Calculation of Heat Transfer Rate at Extrapolation Conditions

Governing Equation

$$q^* = (1/R^*) (A_o) (LMTD^*)$$

Assumptions

$$U_{LMTD} \approx 0.0$$

Analysis

$$\frac{U_{q^*}}{q^*} = \left[\left(\frac{\partial q^*}{\partial R^*} \right)^2 \left(\frac{U_{R^*}}{q^*} \right)^2 + \left(\frac{\partial q^*}{\partial A_o} \right)^2 \left(\frac{U_{A_o}}{q^*} \right)^2 + \left(\frac{\partial q^*}{\partial (LMTD^*)} \right)^2 \left(\frac{U_{LMTD^*}}{q^*} \right)^2 \right]^{1/2}$$

$$\frac{U_{q^*}}{q^*} = \left[\left(-R^{*-2} A_o LMTD^* \right)^2 \left(\frac{U_{R^*}}{q^*} \right)^2 + \left(\frac{1}{R^*} LMTD^* \right)^2 \left(\frac{U_{A_o}}{q^*} \right)^2 \right]^{1/2}$$

U_{R^*} (Evaluated in Section 5)

U_{A_o} (Evaluated in Section 1)

7) Uncertainty in Calculation of Extrapolated Heat Transfer for Entire Unit

The uncertainties in extrapolated heat transfer, computed for each tube row, are combined in the following manner to yield an overall uncertainty value for the entire air cooler.

$$q_{tot} = q_1 + q_2 + q_3 \dots + q_n$$

where, " n " is the number of tube rows in the unit.

$$\frac{Uq_{tot}}{q_{tot}} = \left[\left(\frac{\partial q_{tot}}{\partial q_1} \right)^2 \left(\frac{Uq_1}{q_{tot}} \right)^2 + \left(\frac{\partial q_{tot}}{\partial q_2} \right)^2 \left(\frac{Uq_2}{q_{tot}} \right)^2 + \left(\frac{\partial q_{tot}}{\partial q_3} \right)^2 \left(\frac{Uq_3}{q_{tot}} \right)^2 + \dots + \left(\frac{\partial q_{tot}}{\partial q_n} \right)^2 \left(\frac{Uq_n}{q_{tot}} \right)^2 \right]^{1/2}$$

Assuming that the extrapolated heat transfer rates of the various rows do not depend on each other, the above expression becomes:

$$\frac{Uq_{tot}}{q_{tot}} = \left[\left(\frac{Uq_1}{q_{tot}} \right)^2 + \left(\frac{Uq_2}{q_{tot}} \right)^2 + \left(\frac{Uq_3}{q_{tot}} \right)^2 + \dots + \left(\frac{Uq_n}{q_{tot}} \right)^2 \right]^{1/2}$$

Definition of Analytical Uncertainty Analysis Terms

$A_o/A_i =$	Heat transfer area ratio
d_i (in) =	Tube inside diameter
A_o (ft ²) =	Outside heat transfer area
d_o (in) =	Tube outside diameter
U_{do}/d_o (%) =	Uncertainty in tube outside diameter (as a percentage)
$U_{do} =$	Uncertainty in tube outside diameter (absolute)
$N_t =$	Number of tubes in given row
$N_l =$	Number of rows in heat exchanger
Λ (fins/in) =	Fin pitch
L (Ft) =	Tube length
U_L/L (%) =	Uncertainty in tube length (as a percentage)
U_L (ft) =	Uncertainty in tube length (absolute)
t_{fin} (in) =	Fin thickness
U_{tfin}/t_{fin} (%) =	Uncertainty in fin thickness (as a percentage)
U_{tfin} (in) =	Uncertainty in fin thickness (absolute)
h_{fin} (in) =	Fin height
U_{hfin}/h_{fin} (%) =	Uncertainty in fin height (as a percentage)
U_{hfin} (in) =	Uncertainty in fin height (absolute)
\dot{M} (lbm/hr) =	Cooling water mass flow rate
Q (Ft ³ /hr) =	Cooling water volumetric flow rate
ΔT (DegF) =	Cooling water temperature difference (inlet to outlet)
ρ (lbm/ft ³) =	Cooling water density
U_{ρ}/ρ (%) =	Uncertainty in cooling water density (as a percentage)
$U_{\rho} =$	Uncertainty in cooling water density (absolute)
C_p (Btu/lbm/DegF) =	Cooling water specific heat
U_{Cp}/C_p (%) =	Uncertainty in cooling water specific heat (as a percentage)
$U_{Cp} =$	Uncertainty in cooling water specific heat (absolute)
q_{test} (Btu/hr) =	Calculated test heat transfer for coil section
$LMTD$ (DegF) =	Calculated log mean temperature difference
$U_o =$	Heat transfer coefficient
$R = (1/U_o) =$	Heat transfer resistance
$R_f [(hr-DegF-ft^2)/Btu] =$	Fouling resistance
$E_{tas} =$	
$h_o [Btu/(hr-DegF-ft^2)] =$	Outside film coefficient
$h_o(eff) [Btu/(hr-DegF-ft^2)] =$	Effective outside film coefficient
U_{ho}/h_o (%) =	Uncertainty in outside film coefficient (as a percentage)
$U_{ho} =$	Uncertainty in outside film coefficient (absolute)
$h_i [Btu/(hr-DegF-ft^2)] =$	Inside film coefficient
U_{hi}/h_i (%) =	Uncertainty in inside film coefficient (as a percentage)
$U_{hi} =$	Uncertainty in inside film coefficient (absolute)
$R_w [(hr-DegF-ft^2)/Btu] =$	Wall thermal resistance
U_{Rw}/R_w (%) =	Uncertainty in wall resistance (as a percentage)
$U_{Rw} =$	Uncertainty in wall resistance (absolute)

Proto-Power Calc: 97-200

Attachment: J

Rev: A Page 14 of 40

Analytical Uncertainty Analysis -- Uncertainty Inputs

Parameter	Definition	Value (%)	
Udo/do	Uncertainty in tube outside diameter	8.00	(1)
ULc/Lc	Uncertainty in coil (tube) length	0.24	(2)
U _{tfin} /t _{fin}	Uncertainty in fin thickness	4.17	(3)
U _{hfin} /h _{fin}	Uncertainty in circular fin height	1.34	(4)
U _{rho} /rho	Uncertainty in cooling water density	2.00	(5)
UC _p /C _p	Uncertainty in cooling water specific heat	2.00	(5)
U _{ho} /h _o	Uncertainty in outside film coefficient	15.00	(6)
U _{hi} /h _i	Uncertainty in inside film coefficient	15.00	(7)
UR _w /R _w	Uncertainty in wall resistance	2.00	(5)

Notes:

- (1) Measurement of 5/8" +/- 0.05" yields an uncertainty of 8.0%
- (2) Measurement of 104.25" +/- 0.25" yields an uncertainty of 0.24%
- (3) Specified as 0.012" with estimated tolerance of 0.0005" yields an uncertainty of 4.17%
- (4) Measurement of 1.495" +/- 0.02" yields an uncertainty of 1.34%
- (5) Uncertainty in property values is estimated as 2%
- (6) Uncertainty in outside film coefficient is estimated as 15%
- (7) Uncertainty in inside film coefficient is estimated as 15%

PROTO-HX Report -- Model Inputs

09:09:14

PROTO-HX 3.01 by Proto-Power Corporation (SN#PHX-0000) 06/22/98
 ComEd -- LaSalle
 Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21179 acfm	150 gpm
Inlet Dry Bulb Temp	150 °F	105 °F
Inlet Wet Bulb Temp	92 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.4 °F	115.3 °F
Outlet Wet Bulb Temp	84.1 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002
Air-Side Fouling		0.002
Design Heat Transfer (BTU/hr)		750000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1
Performance Factor (% Reduction)		0
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A j = EXP[-2.5088 + -0.3436 * LOG(Re)]
Coil Finned Length (in)		104.25
Fin Pitch (Fins/Inch)		10
Fin Conductivity (BTU/hr-ft-°F)		128
Fin Tip Thickness (inches)		0.012
Fin Root Thickness (inches)		0.012
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2.000
Number of Tube Rows		8.000
Number of Tubes Per Row		20
Active Tubes Per Row		20
Tube Inside Diameter (in)		0.527
Tube Outside Diameter (in)		0.625
Longitudinal Tube Pitch (in)		1.5
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1
Tube Wall Conductivity (BTU/hr-ft-°F)		225

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 16 of 40

PROTO-HX Report -- Fouling Calculation Output

Fouling Calculation Summary

There is no fouling calculation for the rating analysis case.

Uncertainty in use of design fouling in rating analysis is zero.

Blacked-out areas in the sheets that follow are related to the fouling factor calculation and are not applicable

PROTO-HX Report -- Extrapolation Calculation Output for Limiting Flow Case

Extrapolation Calculation Summary

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	
Inlet Temperature (°F)	148	100	j Factor	
Outlet Temperature (°F)	108.2854	113.1719	Air-Side ho (BTU/hr-ft ² -°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)				
Skin Temperature (°F)			U Overall (BTU/hr-ft ² -°F)	
Velocity ***			Effective Area (ft ²)	7242.652
Reynold's Number			LMTD	
Prandtl Number			Total Heat Transferred (BTU/hr)	707030.5
Bulk Visc (lbm/ft-hr)				
Skin Visc (lbm/ft-hr)			Surface Effectiveness (Eta)	
Density (lbm/ft ³)			Sensible Heat Transferred (BTU/hr)	707030.5
Cp (BTU/lbm-°F)			Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)			Heat to Condensate (BTU/hr)	

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1246.549
Inlet Temperature (°F)	148	110.3055	j Factor	0.008175
Outlet Temperature (°F)	139.3637	113.1719	Air-Side ho (BTU/hr-ft ² -°F)	8.272452
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)	143.6819	111.7387		
Skin Temperature (°F)	121.1797	114.3282	U Overall (BTU/hr-ft ² -°F)	5.351471
Velocity ***	3400.987	3.981516	Effective Area (ft ²)	905.3315
Reynold's Number	802.6572	**	26688.33 LMTD	31.73459
Prandtl Number	0.725515	3.967489	Total Heat Transferred (BTU/hr)	153749.5
Bulk Visc (lbm/ft-hr)	0.048968	1.45846		
Skin Visc (lbm/ft-hr)		1.421732	Surface Effectiveness (Eta)	0.918316
Density (lbm/ft ³)	0.062477	61.83519	Sensible Heat Transferred (BTU/hr)	153749.5
Cp (BTU/lbm-°F)	0.240245	0.99882	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.016215	0.367165	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 2(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1228.617
Inlet Temperature (°F)	139.3637	107.9223	j Factor	0.008146
Outlet Temperature (°F)	132.1832	110.3055	Air-Side ho (BTU/hr-ft ² -°F)	8.238629
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)	135.7735	109.114		
Skin Temperature (°F)	116.9946	111.2983	U Overall (BTU/hr-ft ² -°F)	5.330976
Velocity ***	3400.987	3.979115	Effective Area (ft ²)	905.3315
Reynold's Number	810.7773	**	25995.7 LMTD	26.48671
Prandtl Number	0.726209	4.083826	Total Heat Transferred (BTU/hr)	127832.8
Bulk Visc (lbm/ft-hr)	0.048477	1.497319		
Skin Visc (lbm/ft-hr)		1.464863	Surface Effectiveness (Eta)	0.918616
Density (lbm/ft ³)	0.063235	61.8725	Sensible Heat Transferred (BTU/hr)	127832.8
Cp (BTU/lbm-°F)	0.240245	0.998845	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.016037	0.366218	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 3(Dry)

Air-Side Tube-Side

Proto-Power Calc: 97-200

Attachment: J

Rev: A Page 18 of 40

PROTO-HX Report -- Extrapolation Calculation Output for Limiting Flow Case

Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1213.64
Inlet Temperature (°F)	132.1832	105.9385	j Factor	0.008123
Outlet Temperature (°F)	126.2057	107.9223	Air-Side ho (BTU/hr-ft ² -°F)	8.210501
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)	129.1941	106.9309		
Skin Temperature (°F)	113.5129	108.7712	U Overall (BTU/hr-ft ² -°F)	5.313799
Velocity ***	3400.987	3.977169	Effective Area (ft ²)	905.3315
Reynold's Number	817.7239	**	25424.42 LMTD	22.12061
Prandtl Number	0.726741	4.184867	Total Heat Transferred (BTU/hr)	106416.7
Bulk Visc (lbm/ft-hr)	0.048065	1.530964		
Skin Visc (lbm/ft-hr)		1.502521	Surface Effectiveness (Eta)	0.918865
Density (lbm/ft ³)	0.063881	61.90278	Sensible Heat Transferred (BTU/hr)	106416.7
Cp (BTU/lbm-°F)	0.240245	0.998873	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.015889	0.365416	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 4(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1201.114
Inlet Temperature (°F)	126.2057	104.2853	j Factor	0.008103
Outlet Temperature (°F)	121.2244	105.9385	Air-Side ho (BTU/hr-ft ² -°F)	8.187088
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)	123.7151	105.1112		
Skin Temperature (°F)	110.6127	106.6611	U Overall (BTU/hr-ft ² -°F)	5.299401
Velocity ***	3400.987	3.975581	Effective Area (ft ²)	905.3315
Reynold's Number	823.6471	**	24951.62 LMTD	18.48393
Prandtl Number	0.72715	4.272217	Total Heat Transferred (BTU/hr)	88680.63
Bulk Visc (lbm/ft-hr)	0.04772	1.559974		
Skin Visc (lbm/ft-hr)		1.535208	Surface Effectiveness (Eta)	0.919073
Density (lbm/ft ³)	0.064428	61.9275	Sensible Heat Transferred (BTU/hr)	88680.63
Cp (BTU/lbm-°F)	0.240245	0.998902	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.015766	0.364737	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 5(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1190.652
Inlet Temperature (°F)	121.2244	102.9065	j Factor	0.008086
Outlet Temperature (°F)	117.0697	104.2853	Air-Side ho (BTU/hr-ft ² -°F)	8.167578
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² -°F/BTU)	0.000314
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² -°F/BTU)	0.039766
Average Temp (°F)	119.1471	103.5958		
Skin Temperature (°F)	108.1955	104.8999	U Overall (BTU/hr-ft ² -°F)	5.287339
Velocity ***	3400.987	3.974283	Effective Area (ft ²)	905.3315
Reynold's Number	828.6851	**	24560.25 LMTD	15.45193
Prandtl Number	0.727467	4.347231	Total Heat Transferred (BTU/hr)	73965.21
Bulk Visc (lbm/ft-hr)	0.04743	1.584832		
Skin Visc (lbm/ft-hr)		1.563402	Surface Effectiveness (Eta)	0.919246
Density (lbm/ft ³)	0.064893	61.94772	Sensible Heat Transferred (BTU/hr)	73965.21
Cp (BTU/lbm-°F)	0.240245	0.998929	Latent Heat Transferred (BTU/hr)	
K (BTU/hr-ft-°F)	0.015664	0.364166	Heat to Condensate (BTU/hr)	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 19 of 40

Extrapolation Calculation for Row 6(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² -°F)	1181.899
Inlet Temperature (°F)	117.0697	101.7556	j Factor	0.008071
Outlet Temperature (°F)	113.6019	102.9065	Air-Side ho (BTU/hr-ft ² -°F)	8.151309

PROTO-HX Report -- Extrapolation Calculation Output for Limiting Flow Case

Inlet Specific Humidity	0.020268	Tube Wall Resistance (hr-ft ² ·°F/BTU)	0.000314
Outlet Specific Humidity	0.020268	Overall Fouling (hr-ft ² ·°F/BTU)	0.039766
Average Temp (°F)	115.3358	102.3309	
Skin Temperature (°F)	106.1782	103.4274	U Overall (BTU/hr-ft ² ·°F)
Velocity ***	3400.987	3.973217	Effective Area (ft ²)
Reynold's Number	832.9599	**	24235.25
Prandtl Number	0.727713	4.411482	Total Heat Transferred (BTU/hr)
Bulk Visc (lbm/ft-hr)	0.047186	1.606085	61737.04
Skin Visc (lbm/ft-hr)		1.587634	Surface Effectiveness (Eta)
Density (lbm/ft ³)	0.065285	61.96434	Sensible Heat Transferred (BTU/hr)
Cp (BTU/lbm·°F)	0.240244	0.998954	Latent Heat Transferred (BTU/hr)
K (BTU/hr-ft·°F)	0.015578	0.363684	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 7(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² ·°F)
Inlet Temperature (°F)	113.6019	100.7945	j Factor
Outlet Temperature (°F)	110.7056	101.7556	Air-Side ho (BTU/hr-ft ² ·°F)
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² ·°F/BTU)
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² ·°F/BTU)
Average Temp (°F)	112.1537	101.2749	
Skin Temperature (°F)	104.4937	102.1964	U Overall (BTU/hr-ft ² ·°F)
Velocity ***	3400.987	3.972339	Effective Area (ft ²)
Reynold's Number	836.5802	**	23965.08
Prandtl Number	0.727905	4.466304	Total Heat Transferred (BTU/hr)
Bulk Visc (lbm/ft-hr)	0.046982	1.624191	51562.15
Skin Visc (lbm/ft-hr)		1.608373	Surface Effectiveness (Eta)
Density (lbm/ft ³)	0.065617	61.97803	Sensible Heat Transferred (BTU/hr)
Cp (BTU/lbm·°F)	0.240244	0.998977	Latent Heat Transferred (BTU/hr)
K (BTU/hr-ft·°F)	0.015506	0.363278	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

Extrapolation Calculation for Row 8(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71166.65	53702.59	Tube-Side hi (BTU/hr-ft ² ·°F)
Inlet Temperature (°F)	110.7056	99.99134	j Factor
Outlet Temperature (°F)	108.2854	100.7945	Air-Side ho (BTU/hr-ft ² ·°F)
Inlet Specific Humidity	0.020268		Tube Wall Resistance (hr-ft ² ·°F/BTU)
Outlet Specific Humidity	0.020268		Overall Fouling (hr-ft ² ·°F/BTU)
Average Temp (°F)	109.4955	100.3927	
Skin Temperature (°F)	103.0865	101.1668	U Overall (BTU/hr-ft ² ·°F)
Velocity ***	3400.987	3.971615	Effective Area (ft ²)
Reynold's Number	839.6409	**	23740.2
Prandtl Number	0.728057	4.512945	Total Heat Transferred (BTU/hr)
Bulk Visc (lbm/ft-hr)	0.046811	1.639576	43086.43
Skin Visc (lbm/ft-hr)		1.626064	Surface Effectiveness (Eta)
Density (lbm/ft ³)	0.065896	61.98934	Sensible Heat Transferred (BTU/hr)
Cp (BTU/lbm·°F)	0.240244	0.998987	Latent Heat Transferred (BTU/hr)
K (BTU/hr-ft·°F)	0.015447	0.362937	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 20 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 1)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =
 A_i (ft²) =
 A_o (ft²) =
 A_o/A_i =
 d_o (ft) =
 U_{do}/d_o (%) =
 U_{do} (ft) =

 N_t =
 N_i =
 λ (fins/ft) =
 L (ft) =
 UL/L (%) =
 UL (ft) =

 t_{fin} (ft) =
 U_{tfin}/t_{fin} (%) =
 U_{tfin} (ft) =

 h_{fin} (ft) =
 U_{hfin}/h_{fin} (%) =
 U_{hfin} (ft) =

 \dot{M} (lbm/hr) =
 Q (Ft³/hr) =
 DT (DegF) =
 ρ (lbm/ft³) =
 U_{ρ}/ρ (%) =
 U_{ρ} =

 C_p (Btu/lbm/DegF) =
 U_{Cp}/C_p (%) =
 U_{Cp} =

 q (Btu/hr) =
 $LMTD$ (DegF) =
 U_o =
 $R = (1/U_o)$ =
 R_f [(hr-DegF-ft²)/Btu] =
 ϵ_{tas} =
 h_o [Btu/(hr-DegF-ft²)] =
 $h_o(eff)$ [Btu/(hr-DegF-ft²)] =
 U_{h_o}/h_o (%) =
 U_{h_o} =

 h_i [Btu/(hr-DegF-ft²)] =
 U_{h_i}/h_i (%) =
 U_{h_i} =

 R_w [(hr-DegF-ft²)/Btu] =
 U_{R_w}/R_w (%) =
 U_{R_w} =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043910667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667
N_t =	20
N_i =	2
λ (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001689417
\dot{M} (lbm/hr) =	53702.59431
Q (Ft ³ /hr) =	858.4794234
DT (DegF) =	2.86638485
ρ (lbm/ft ³) =	61.83519479
U_{ρ}/ρ (%) =	2
U_{ρ} =	1.236703896
C_p (Btu/lbm/DegF) =	0.998820251
U_{Cp}/C_p (%) =	2
U_{Cp} =	0.019978405
q (Btu/hr) =	153749.4783
$LMTD$ (DegF) =	31.73458665
U_o =	5.351471122
$R = (1/U_o)$ =	0.186864506
R_f [(hr-DegF-ft ²)/Btu] =	0.039766224
ϵ_{tas} =	0.918316031
h_o [Btu/(hr-DegF-ft ²)] =	8.27245205
$h_o(eff)$ [Btu/(hr-DegF-ft ²)] =	7.596725335
U_{h_o}/h_o (%) =	15
U_{h_o} =	1.1395088
h_i [Btu/(hr-DegF-ft ²)] =	1246.548746
U_{h_i}/h_i (%) =	15
U_{h_i} =	186.9823119
R_w [(hr-DegF-ft ²)/Btu] =	0.0003143
U_{R_w}/R_w (%) =	2
U_{R_w} =	6.28601E-08

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 21 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 1)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	hfin	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	ho*	U _{ho} *	hi*	U _{hi} *	R _w *	U _{R_w} *	R _f	U _{R_f}	U _R */R*	U _R *
0.18686	7.59673	1.13951	1246.54875	186.98231	0.00031	0.00001	0.03977	0.00000	0.10843	0.02026

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	U _R *	Ao	UAo	LMTD*	U _q */q*	U _q *
153749.4783	0.18686	0.02026	905.33147	36.82236	31.73459	0.11581	17805.20662

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 22 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 2)

I. PROTO-HX Output -- Fouling Calculation

di (ft) =	
Ai (ft^2) =	
Ao (ft^2) =	
Ao/Ai =	
do (ft) =	
Udo/do (%) =	
	Udo (ft) =
Nt =	
NI =	
Lambda (fins/ft) =	
L (ft) =	
UL/L (%) =	
	UL(ft) =
tfin (ft) =	
Utfin/tfin (%) =	
	Utfin (ft) =
hfin (ft) =	
Uhhfin/hfin (%) =	
	Uhhfin (ft) =
Mdotc (lbm/hr) =	
Q (Ft^3/hr) =	
DT (DegF) =	
rho (lbm/ft^3) =	
Urho/rho (%) =	
	Urho =
Cp (Btu/lbm/DegF) =	
UCp/Cp (%) =	
	UCp =
q (Btu/hr) =	
LMTD (DegF) =	
Uo =	
R = (1/Uo) =	
Rf [(hr-DegF-ft^2)/Btu] =	
Etas =	
ho [Btu/(hr-DegF-ft^2)] =	
ho(eff) [Btu/(hr-DegF-ft^2)] =	
Uho/ho (%) =	
	Uho =
hi [Btu/(hr-DegF-ft^2)] =	
Uhi/hi (%) =	
	Uhi =
Rw [(hr-DegF-ft^2)/Btu] =	
URw/Rw (%) =	
	URw =

II. PROTO-HX Output -- Extrapolation Calculation

di (ft) =	0.043916667
Ai (ft^2) =	23.97198819
Ao (ft^2) =	905.3314736
Ao/Ai =	37.76622301
do (ft) =	0.052083333
Udo/do (%) =	8
	Udo (ft) = 0.004166667
Nt =	20
NI =	2
Lambda (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
	UL(ft) = 0.02085
tfin (ft) =	0.001
Utfin/tfin (%) =	4.17
	Utfin (ft) = 0.0000417
hfin (ft) =	0.124583333
Uhhfin/hfin (%) =	1.34
	Uhhfin (ft) = 0.001669417
Mdotc* (lbm/hr) =	53702.59431
Q* (Ft^3/hr) =	867.9558527
DT* (DegF) =	2.383163429
rho* (lbm/ft^3) =	61.87249518
Urho*/rho* (%) =	2
	Urho* = 1.237449904
Cp* (Btu/lbm/DegF) =	0.996845052
UCp*/Cp* (%) =	2
	UCp* = 0.019976901
q* (Btu/hr) =	127832.8305
LMTD* (DegF) =	26.4867136
Uo* =	5.3309758
R* = (1/Uo*) =	0.187582919
Rf [(hr-DegF-ft^2)/Btu] =	0.039766224
Etas =	0.918615579
ho* [Btu/(hr-DegF-ft^2)] =	8.238629585
ho*(eff) [Btu/(hr-DegF-ft^2)] =	7.568132571
Uho*/ho* (%) =	15
	Uho* = 1.135219886
hi* [Btu/(hr-DegF-ft^2)] =	1228.617186
Uhi*/hi* (%) =	15
	Uhi* = 184.2925778
Rw* [(hr-DegF-ft^2)/Btu] =	0.0003143
URw*/Rw* (%) =	2
	URw* = 6.28601E-06

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 23 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 2)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	h _{fin}	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed R_f



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	h _o *	U _{h_o} *	h _i *	U _{h_i} *	R _w *	U _{R_w} *	R _f	U _{R_f}	U _R */R*	U _R *
0.18758	7.56813	1.13522	1228.61719	184.29258	0.00031	0.00001	0.03977	0.00000	0.10848	0.02035

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	U _R *	Ao	UAo	LMTD*	U _q */q*	U _q *
127832.8305	0.18758	0.02035	905.33147	36.82236	26.48671	0.11586	14810.09844

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 24 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 3)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =	
A_i (ft ²) =	
A_o (ft ²) =	
A_o/A_i =	
d_o (ft) =	
U_{do}/d_o (%) =	
U_{do} (ft) =	
N_t =	
N_l =	
Lambda (fins/ft) =	
L (ft) =	
UL/L (%) =	
UL (ft) =	
t_{fin} (ft) =	
U_{tfin}/t_{fin} (%) =	
U_{tfin} (ft) =	
h_{fin} (ft) =	
U_{hfin}/h_{fin} (%) =	
U_{hfin} (ft) =	
M_{dotc} (lbm/hr) =	
Q (Ft ³ /hr) =	
DT (DegF) =	
ρ (lbm/ft ³) =	
U_{rho}/ρ (%) =	
U_{rho} =	
C_p (Btu/lbm/DegF) =	
U_{Cp}/C_p (%) =	
U_{Cp} =	
q (Btu/hr) =	
$LMTD$ (DegF) =	
U_o =	
$R = (1/U_o)$ =	
R_f [(hr-DegF-ft ²)/Btu] =	
E_{tas} =	
h_o [Btu/(hr-DegF-ft ²)] =	
$h_o^{(eff)}$ [Btu/(hr-DegF-ft ²)] =	
U_{ho}/h_o (%) =	
U_{ho} =	
h_i [Btu/(hr-DegF-ft ²)] =	
U_{hi}/h_i (%) =	
U_{hi} =	
R_w [(hr-DegF-ft ²)/Btu] =	
U_{Rw}/R_w (%) =	
U_{Rw} =	

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667
N_t =	20
N_l =	2
Lambda (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001669417
M_{dotc}^* (lbm/hr) =	53702.59431
Q^* (Ft ³ /hr) =	867.5312111
DT^* (DegF) =	1.98378479
ρ^* (lbm/ft ³) =	61.9027807
U_{rho^*}/ρ^* (%) =	2
U_{rho^*} =	1.238055614
C_p^* (Btu/lbm/DegF) =	0.998873053
U_{Cp^*}/C_p^* (%) =	2
U_{Cp^*} =	0.019977461
q^* (Btu/hr) =	106416.6914
$LMTD^*$ (DegF) =	22.12060653
U_o^* =	5.313798755
$R^* = (1/U_o^*)$ =	0.188189287
R_f^* [(hr-DegF-ft ²)/Btu] =	0.039766224
E_{tas}^* =	0.91886488
h_o^* [Btu/(hr-DegF-ft ²)] =	8.210500587
$h_o^{*(eff)}$ [Btu/(hr-DegF-ft ²)] =	7.544340639
U_{ho^*}/h_o^* (%) =	15
U_{ho^*} =	1.131651096
h_i^* [Btu/(hr-DegF-ft ²)] =	1213.639786
U_{hi^*}/h_i^* (%) =	15
U_{hi^*} =	182.0459679
R_w^* [(hr-DegF-ft ²)/Btu] =	0.0003143
U_{Rw^*}/R_w^* (%) =	2
U_{Rw^*} =	6.28601E-06

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 25 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 3)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	h _{fin}	U _{h_{fin}}	UA _o /Ao	UA _o
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	ho*	Uho*	hi*	Uhi*	Rw*	URw*	Rf	URf	UR*/R*	UR*
0.18819	7.54434	1.13165	1213.63979	182.04597	0.00031	0.00001	0.03977	0.00000	0.10852	0.02042

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	UR*	Ao	UAo	LMTD*	Uq*/q*	Uq*
106416.6914	0.18819	0.02042	905.33147	36.82236	22.12061	0.11590	12333.18129

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 26 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 4)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =
 A_i (ft²) =
 A_o (ft²) =
 A_o/A_i =
 d_o (ft) =
 U_{do}/d_o (%) =
 U_{do} (ft) =

 N_t =
 N_f =
 Λ (fins/ft) =
 L (ft) =
 UL/L (%) =
 UL (ft) =

 t_{fin} (ft) =
 U_{tfin}/t_{fin} (%) =
 U_{tfin} (ft) =

 h_{fin} (ft) =
 U_{hfin}/h_{fin} (%) =
 U_{hfin} (ft) =

 \dot{M} (lbm/hr) =
 Q (Ft³/hr) =
 DT (DegF) =
 ρ (lbm/ft³) =
 U_{ρ}/ρ (%) =
 U_{ρ} =

 C_p (Btu/lbm/DegF) =
 U_{Cp}/C_p (%) =
 U_{Cp} =

 q (Btu/hr) =
 $LMTD$ (DegF) =
 U_o =
 $R = (1/U_o)$ =
 R_f [(hr-DegF-ft²)/Btu] =
 E_{tas} =
 h_o [Btu/(hr-DegF-ft²)] =
 $h_o(eff)$ [Btu/(hr-DegF-ft²)] =
 U_{h_o}/h_o (%) =
 U_{h_o} =

 h_i [Btu/(hr-DegF-ft²)] =
 U_{h_i}/h_i (%) =
 U_{h_i} =

 R_w [(hr-DegF-ft²)/Btu] =
 U_{Rw}/R_w (%) =
 U_{Rw} =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667
N_t =	20
N_f =	2
Λ (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001689417
\dot{M} (lbm/hr) =	53702.59431
Q (Ft ³ /hr) =	887.1848829
DT (DegF) =	1.653237217
ρ (lbm/ft ³) =	61.82750285
U_{ρ}/ρ (%) =	2
U_{ρ} =	1.238550057
C_p (Btu/lbm/DegF) =	0.998901516
U_{Cp}/C_p (%) =	2
U_{Cp} =	0.01997803
q (Btu/hr) =	88680.6339
$LMTD$ (DegF) =	18.48393207
U_o =	5.29940128
$R = (1/U_o)$ =	0.188700562
R_f [(hr-DegF-ft ²)/Btu] =	0.039766224
E_{tas} =	0.919072522
h_o [Btu/(hr-DegF-ft ²)] =	8.187087926
$h_o(eff)$ [Btu/(hr-DegF-ft ²)] =	7.524527551
U_{h_o}/h_o (%) =	15
U_{h_o} =	1.128679133
h_i [Btu/(hr-DegF-ft ²)] =	1201.114277
U_{h_i}/h_i (%) =	15
U_{h_i} =	180.1671416
R_w [(hr-DegF-ft ²)/Btu] =	0.0003143
U_{Rw}/R_w (%) =	2
U_{Rw} =	6.28601E-08

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 27 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 4)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	h _{fin}	U _{hfin}	UA _o /Ao	UA _o
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	h _o *	U _{h_o} *	h _i *	U _{h_i} *	R _w *	U _{R_w} *	R _f	U _{R_f}	U _R */R*	U _R *
0.18870	7.52453	1.12868	1201.11428	180.16714	0.00031	0.00001	0.03977	0.00000	0.10856	0.02049

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	U _R *	A _o	UA _o	LMTD*	U _q */q*	U _q *
88680.6339	0.18870	0.02049	905.33147	36.82236	18.48393	0.11593	10280.57880

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 28 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 5)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =
 A_i (ft²) =
 A_o (ft²) =
 A_o/A_i =
 d_o (ft) =
 U_{do}/d_o (%) =
 U_{do} (ft) =

 N_t =
 N_I =
 λ (fins/ft) =
 L (ft) =
 UL/L (%) =
 UL (ft) =

 t_{fin} (ft) =
 U_{tfin}/t_{fin} (%) =
 U_{tfin} (ft) =

 h_{fin} (ft) =
 U_{hfin}/h_{fin} (%) =
 U_{hfin} (ft) =

 \dot{M} (lbm/hr) =
 Q (Ft³/hr) =
 DT (DegF) =
 ρ (lbm/ft³) =
 U_{rho}/ρ (%) =
 U_{rho} =

 C_p (Btu/lbm/DegF) =
 U_{Cp}/C_p (%) =
 U_{Cp} =

 q (Btu/hr) =
 $LMTD$ (DegF) =
 U_o =
 $R = (1/U_o)$ =
 R_f [(hr-DegF-ft²)/Btu] =
 $Etas$ =
 h_o [Btu/(hr-DegF-ft²)] =
 $h_o(eff)$ [Btu/(hr-DegF-ft²)] =
 U_{ho}/h_o (%) =
 U_{ho} =

 h_i [Btu/(hr-DegF-ft²)] =
 U_{hi}/h_i (%) =
 U_{hi} =

 R_w [(hr-DegF-ft²)/Btu] =
 U_{Rw}/R_w (%) =
 U_{Rw} =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667
N_t =	20
N_I =	2
λ (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001669417
\dot{M} (lbm/hr) =	53702.59431
Q (Ft ³ /hr) =	868.9018227
DT (DegF) =	1.378817728
ρ (lbm/ft ³) =	61.94772338
U_{rho}/ρ (%) =	2
U_{rho} =	1.238954468
C_p (Btu/lbm/DegF) =	0.99892883
U_{Cp}/C_p (%) =	2
U_{Cp} =	0.019978577
q (Btu/hr) =	73965.20571
$LMTD$ (DegF) =	15.45192966
U_o =	5.287338658
$R = (1/U_o)$ =	0.189131087
R_f [(hr-DegF-ft ²)/Btu] =	0.039766224
$Etas$ =	0.919245643
h_o [Btu/(hr-DegF-ft ²)] =	8.167578221
$h_o(eff)$ [Btu/(hr-DegF-ft ²)] =	7.508010691
U_{ho}/h_o (%) =	15
U_{ho} =	1.126201604
h_i [Btu/(hr-DegF-ft ²)] =	1190.652195
U_{hi}/h_i (%) =	15
U_{hi} =	178.5978293
R_w [(hr-DegF-ft ²)/Btu] =	0.0003143
U_{Rw}/R_w (%) =	2
U_{Rw} =	6.28601E-06

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 29 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 5)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	hfin	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	ho*	Uho*	hi*	Uhi*	Rw*	URw*	Rf	URf	UR*/R*	UR*
0.18913	7.50801	1.12620	1190.65220	178.59783	0.00031	0.00001	0.03977	0.00000	0.10859	0.02054

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	UR*	Ao	UAo	LMTD*	Uq*/q*	Uq*
73965.2057	0.18913	0.02054	905.33147	36.82236	15.45193	0.11596	8576.66300

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 30 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 6)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =	
A_i (ft ²) =	
A_o (ft ²) =	
A_o/A_i =	
d_o (ft) =	
U_{do}/d_o (%) =	U_{do} (ft) =
N_t =	
N_l =	
λ (fins/ft) =	
L (ft) =	
U_L/L (%) =	U_L (ft) =
t_{fin} (ft) =	
U_{tfin}/t_{fin} (%) =	U_{tfin} (ft) =
h_{fin} (ft) =	
U_{hfin}/h_{fin} (%) =	U_{hfin} (ft) =
$\dot{M}dot_c$ (lbm/hr) =	
Q (Ft ³ /hr) =	
DT (DegF) =	
ρ (lbm/ft ³) =	
U_{rho}/rho (%) =	U_{rho} =
C_p (Btu/lbm/DegF) =	
U_{Cp}/Cp (%) =	U_{Cp} =
q (Btu/hr) =	
$LMTD$ (DegF) =	
U_o =	
$R = (1/U_o)$ =	
R_f [(hr-DegF-ft ²)/Btu] =	
E_{tas} =	
h_o [Btu/(hr-DegF-ft ²)] =	
$h_o(eff)$ [Btu/(hr-DegF-ft ²)] =	
U_{ho}/h_o (%) =	U_{ho} =
h_i [Btu/(hr-DegF-ft ²)] =	
U_{hi}/h_i (%) =	U_{hi} =
R_w [(hr-DegF-ft ²)/Btu] =	
U_{Rw}/R_w (%) =	U_{Rw} =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916687
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166687
N_t =	20
N_l =	2
λ (fins/ft) =	120
L (ft) =	8.6875
U_L/L (%) =	0.24
U_L (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124563333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001669417
$\dot{M}dot_c^*$ (lbm/hr) =	53702.59431
Q^* (Ft ³ /hr) =	866.6693232
DT^* (DegF) =	1.150842416
ρ^* (lbm/ft ³) =	61.96434196
U_{rho^*}/rho^* (%) =	2
U_{rho^*} =	1.239286839
C_p^* (Btu/lbm/DegF) =	0.998954126
U_{Cp^*}/Cp^* (%) =	2
U_{Cp^*} =	0.019979083
q^* (Btu/hr) =	61737.04355
$LMTD^*$ (DegF) =	12.92207564
U_o^* =	5.277228882
$R^* = (1/U_o^*)$ =	0.189493392
R_f [(hr-DegF-ft ²)/Btu] =	0.039768224
E_{tas} =	0.919390072
h_o^* [Btu/(hr-DegF-ft ²)] =	8.151309092
$h_o^*(eff)$ [Btu/(hr-DegF-ft ²)] =	7.494232656
U_{ho^*}/h_o^* (%) =	15
U_{ho^*} =	1.124134898
h_i^* [Btu/(hr-DegF-ft ²)] =	1181.899042
U_{hi^*}/h_i^* (%) =	15
U_{hi^*} =	177.2848562
R_w^* [(hr-DegF-ft ²)/Btu] =	0.0003143
U_{Rw^*}/R_w^* (%) =	2
U_{Rw^*} =	6.28601E-08

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 31 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 6)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	hfin	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:		-5862.45	104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	ho*	Uho*	hi*	Uhi*	Rw*	URw*	Rf	URf	UR*/R*	UR*
0.18949	7.49423	1.12413	1181.89904	177.28486	0.00031	0.00001	0.03977	0.00000	0.10861	0.02058

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	UR*	Ao	UAo	LMTD*	Uq*/q*	Uq*
61737.0435	0.18949	0.02058	905.33147	36.82236	12.92208	0.11598	7160.13511

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 32 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 7)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =
 A_i (ft²) =
 A_o (ft²) =
 A_o/A_i =
 d_o (ft) =
 U_{do}/d_o (%) =
 U_{do} (ft) =

 N_t =
 N_i =
 λ (fins/ft) =
 L (ft) =
 UL/L (%) =
 UL (ft) =

 t_{fin} (ft) =
 U_{tfin}/t_{fin} (%) =
 U_{tfin} (ft) =

 h_{fin} (ft) =
 U_{hfin}/h_{fin} (%) =
 U_{hfin} (ft) =

 $Mdot_c$ (lbm/hr) =
 Q (Ft³/hr) =
 DT (DegF) =
 ρ (lbm/ft³) =
 $Urho/\rho$ (%) =
 $Urho$ =

 C_p (Btu/lbm/DegF) =
 UCp/C_p (%) =
 UCp =

 q (Btu/hr) =
 $LMTD$ (DegF) =
 U_o =
 $R = (1/U_o)$ =
 R_f [(hr-DegF-ft²)/Btu] =
 E_{tas} =
 h_o [Btu/(hr-DegF-ft²)] =
 $h_o(eff)$ [Btu/(hr-DegF-ft²)] =
 U_{ho}/h_o (%) =
 U_{ho} =

 h_i [Btu/(hr-DegF-ft²)] =
 U_{hi}/h_i (%) =
 U_{hi} =

 R_w [(hr-DegF-ft²)/Btu] =
 URw/R_w (%) =
 URw =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622391
d_o (ft) =	0.052063333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667
N_t =	20
N_i =	2
λ (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085
t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417
h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001669417
$Mdot_c^*$ (lbm/hr) =	53702.59431
Q^* (Ft ³ /hr) =	866.4778558
DT^* (DegF) =	0.961153774
ρ^* (lbm/ft ³) =	61.97803436
$Urho^*/\rho^*$ (%) =	2
$Urho^*$ =	1.239560687
C_p^* (Btu/lbm/DegF) =	0.998976998
UCp^*/C_p^* (%) =	2
UCp^* =	0.01997954
q^* (Btu/hr) =	51562.15469
$LMTD^*$ (DegF) =	10.80974049
U_o^* =	5.268757019
$R^* = (1/U_o^*)$ =	0.189798086
R_f^* [(hr-DegF-ft ²)/Btu] =	0.039765224
E_{tas}^* =	0.919510644
h_o^* [Btu/(hr-DegF-ft ²)] =	8.137732539
$h_o^*(eff)$ [Btu/(hr-DegF-ft ²)] =	7.482731685
U_{ho^*}/h_o^* (%) =	15
U_{ho^*} =	1.122409753
h_i^* [Btu/(hr-DegF-ft ²)] =	1174.576497
U_{hi^*}/h_i^* (%) =	15
U_{hi^*} =	178.1864745
R_w^* [(hr-DegF-ft ²)/Btu] =	0.0003143
URw^*/R_w^* (%) =	2
URw^* =	6.28601E-06

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 33 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 7)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	hfin	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives:	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed R_f



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	h _o *	U _{h_o} *	h _i *	U _{h_i} *	R _w *	U _{R_w} *	R _f	U _{R_f}	U _{R*/R*}	U _{R*}
0.18980	7.48273	1.12241	1174.57650	176.18647	0.00031	0.00001	0.03977	0.00000	0.10863	0.02062

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	U _{R*}	Ao	UAo	LMTD*	U _{q*/q*}	U _{q*}
51562.1547	0.18980	0.02062	905.33147	36.82236	10.80974	0.11600	5981.03791

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 34 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 8)

I. PROTO-HX Output -- Fouling Calculation

d_i (ft) =
 A_i (ft²) =
 A_o (ft²) =
 A_o/A_i =
 d_o (ft) =
 U_{do}/d_o (%) =
 U_{do} (ft) =

N_t =
 N_i =
 Λ (fins/ft) =
 L (ft) =
 UL/L (%) =
 UL (ft) =

t_{fin} (ft) =
 U_{tfin}/t_{fin} (%) =
 U_{tfin} (ft) =

h_{fin} (ft) =
 U_{hfin}/h_{fin} (%) =
 U_{hfin} (ft) =

$Mdot_c$ (lbm/hr) =
 Q (Ft³/hr) =
 DT (DegF) =
 ρ (lbm/ft³) =
 $Urho/\rho$ (%) =
 $Urho$ =

C_p (Btu/lbm/DegF) =
 UC_p/C_p (%) =
 UC_p =

q (Btu/hr) =
 $LMTD$ (DegF) =
 U_o =
 $R = (1/U_o)$ =
 R_f [(hr-DegF-ft²)/Btu] =
 $Etas$ =
 h_o [Btu/(hr-DegF-ft²)] =
 $h_o(eff)$ [Btu/(hr-DegF-ft²)] =
 U_{ho}/h_o (%) =
 U_{ho} =

h_i [Btu/(hr-DegF-ft²)] =
 U_{hi}/h_i (%) =
 U_{hi} =

R_w [(hr-DegF-ft²)/Btu] =
 UR_w/R_w (%) =
 UR_w =

II. PROTO-HX Output -- Extrapolation Calculation

d_i (ft) =	0.043916667
A_i (ft ²) =	23.97198819
A_o (ft ²) =	905.3314736
A_o/A_i =	37.76622301
d_o (ft) =	0.052083333
U_{do}/d_o (%) =	8
U_{do} (ft) =	0.004166667

N_t =	20
N_i =	2
Λ (fins/ft) =	120
L (ft) =	8.6875
UL/L (%) =	0.24
UL (ft) =	0.02085

t_{fin} (ft) =	0.001
U_{tfin}/t_{fin} (%) =	4.17
U_{tfin} (ft) =	0.0000417

h_{fin} (ft) =	0.124583333
U_{hfin}/h_{fin} (%) =	1.34
U_{hfin} (ft) =	0.001669417

$Mdot_c^*$ (lbm/hr) =	53702.59431
Q^* (Ft ³ /hr) =	866.3197684
DT^* (DegF) =	0.803149924
ρ^* (lbm/ft ³) =	61.9893442
$Urho^*/\rho^*$ (%) =	2
$Urho^*$ =	1.239786884

C_p^* (Btu/lbm/DegF) =	0.998987031
UC_p^*/C_p^* (%) =	2
UC_p^* =	0.019979741

q^* (Btu/hr) =	43086.42909
$LMTD^*$ (DegF) =	9.045035483
U_o^* =	5.261657907
$R^* = (1/U_o^*)$ =	0.190054185
R_f [(hr-DegF-ft ²)/Btu] =	0.039766224
$Etas$ =	0.919611352
h_o^* [Btu/(hr-DegF-ft ²)] =	8.126396117
$h_o^*(eff)$ [Btu/(hr-DegF-ft ²)] =	7.47312612
U_{ho^*}/h_o^* (%) =	15
U_{ho^*} =	1.120968918

h_i^* [Btu/(hr-DegF-ft ²)] =	1168.449288
U_{hi^*}/h_i^* (%) =	15
U_{hi^*} =	175.2673932

R_w^* [(hr-DegF-ft ²)/Btu] =	0.0003143
UR_w^*/R_w^* (%) =	2
UR_w^* =	6.28601E-06

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 35 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate (Row 8)

1 Analytical Uncertainty in Heat Transfer Surface Area

Ao	Do	Ud	L	UL	tfin	U _{tfin}	h _{fin}	U _{hfin}	UAo/Ao	UAo
905.33147	0.05208	0.00417	8.68750	0.02085	0.00100	0.00004	0.12458	0.00167	0.04067	36.82236
Derivatives	-5862.45		104.21		9497.82		16451.97			

2 Analytical Uncertainty in Test Heat Transfer Rate



3 Analytical Uncertainty in Observed Heat Transfer Resistance (R):



4 Analytical Uncertainty in Observed Rf



5 Analytical Uncertainty in Overall Extrapolation Heat Transfer Resistance:

R*	ho*	Uho*	hi*	Uhi*	Rw*	URw*	Rf	URf	UR*/R*	UR*
0.19005	7.47313	1.12097	1168.44929	175.26739	0.00031	0.00001	0.03977	0.00000	0.10865	0.02065

6 Analytical Uncertainty in Extrapolated Heat Transfer

q*	R*	UR*	Ao	UAo	LMTD*	Uq*/q*	Uq*
43086.4291	0.19005	0.02065	905.33147	36.82236	9.04504	0.11601	4998.55238

Proto-Power Calc: 97-200
Attachment: J
Rev: A Page 36 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate

	Extrapolated Heat Transfer (Btu/hr)	Calculated Uncertainty (Btu/hr)	(Uq/q)^2
Row1	153749.4783	17805.2066	0.000634
Row2	127832.8305	14810.0984	0.000439
Row3	106416.6914	12333.1813	0.000304
Row4	88680.6339	10280.5788	0.000211
Row5	73965.2057	8576.6630	0.000147
Row6	61737.0435	7160.1351	0.000103
Row7	51562.1547	5981.0379	0.000072
Row8	43086.4291	4998.5524	0.000050

707030.4672 31300.9119 0.044271

qtot SRSS SRSS

Uqtot/qtot = 4.43%

Proto-Power Calc: 97-200
 Attachment: J
 Rev: A Page 37 of 40

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate

	Extrapolated Heat Transfer (Btu/hr)	Calculated Uncertainty (Btu/hr)	(Uq/q)^2
Row1	131195.3801	15103.9427	0.000500
Row2	113794.4455	13105.2568	0.000377
Row3	98799.9660	11381.9018	0.000284
Row4	85856.6718	9893.4811	0.000215
Row5	74666.9011	8606.0900	0.000162
Row6	64980.1137	7491.1472	0.000123
Row7	56584.3908	6524.4468	0.000093
Row8	49299.5662	5685.3828	0.000071

675177.4352 28850.9888 0.042731

qtot SRSS SRSS

Uqtot/qtot = 4.27% (75 gpm case)

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate

	Extrapolated Heat Transfer (Btu/hr)	Calculated Uncertainty (Btu/hr)	(Uq/q)^2
Row1	157023.2342	18206.8532	0.000656
Row2	129762.6061	15052.6614	0.000448
Row3	107370.6351	12459.6780	0.000307
Row4	88936.6170	10323.5976	0.000211
Row5	73732.6242	8560.8359	0.000145
Row6	61173.2629	7104.0420	0.000100
Row7	50784.0800	5898.5258	0.000069
Row8	42180.9535	4899.9514	0.000047

710964.0130 31661.4879 0.044533

qtot SRSS SRSS

Uqtot/qtot = 4.45% (115 gpm case)

Analytical Uncertainty Calculation for Extrapolation Heat Transfer Rate

	Extrapolated Heat Transfer (Btu/hr)	Calculated Uncertainty (Btu/hr)	(Uq/q)^2
Row1	179064.4002	22100.0999	0.000887
Row2	142681.0988	17616.1725	0.000564
Row3	113876.2648	14063.8438	0.000359
Row4	91005.7384	11241.8723	0.000230
Row5	72805.1411	8995.1889	0.000147
Row6	58293.7569	7203.3185	0.000094
Row7	46706.6938	5772.1632	0.000061
Row8	37443.1718	4627.7663	0.000039

741876.2658 36200.1472 0.048795

qtot SRSS SRSS


Uqtot/qtot = 4.88% (150 gpm case)

**Attachment K to
Proto-Power Calculation
97-200
Revision A**

COMPARING SPIRAL AND CIRCULAR FINNS

Area Calculation

A view of the spiral fin layout as compared to the circular fin layout is provided below. Let angle α represent the angle between the plane of the circular fin and the plane of the spiral fin.



A differential area in the circular fin is given as:

$$dA = r dr d\theta$$

The expression for circular fin surface area (times 2 for both sides and disregarding the edge area) taken over a complete traverse of the tube is given as:

$$A_{cf} = 2 \int_{r_i}^{r_o} \int_0^{2\pi} r dr d\theta = 2\pi (r_o^2 - r_i^2)$$

Where:

- r_o = the fin outside radius which is one half the fin height
- r_i = the inside fin radius which is the tube outside radius

The spiral fin surface area (times 2 for both sides and disregarding the edge area) can be approximated by the expression:

$$A_{sf} = \left(\frac{1}{\cos \alpha} \right) 2\pi (r_o^2 - r_i^2)$$

The ratio of the two areas becomes:

$$\frac{A_{sf}}{A_{cf}} = \left(\frac{1}{\cos \alpha} \right)$$

Angle α is approximated by the expression:

$$\tan \alpha = \frac{\frac{1}{4} (\text{fin separation})}{r_o} = \frac{1}{4r_o \lambda}$$

$$\alpha = \tan^{-1} \left(\frac{1}{4r_o \lambda} \right)$$

where:

λ = fin pitch

Substituting fin height into the expression yields the following:

$$\alpha = \tan^{-1} \left(\frac{2}{4H_f \lambda} \right) = \tan^{-1} \left(\frac{1}{2H_f \lambda} \right)$$

As the angle α goes to zero, the spiral fin area approaches that of the circular fin. It can be seen that for very small fin separations (i.e., high fin pitch) the smaller the resulting angle α .

For the case of the VY cooler fin geometry:

$$\alpha = \tan^{-1} \left(\frac{1}{2H_f \lambda} \right) = \tan^{-1} \left(\frac{1}{2(1.487)(10)} \right) = \tan^{-1}(0.033625) = 1.93^\circ$$

The resulting area ratio is then:

$$\frac{A_{sf}}{A_{cf}} = \left(\frac{1}{\cos \alpha} \right) = \left(\frac{1}{\cos(1.93^\circ)} \right) = 1.00057$$

This difference is negligible and is bounded by the uncertainty in the analysis presented in Attachment J.

Heat Transfer Coefficient

The fin geometry affects the calculation of the outside heat transfer film coefficient (h_o) for condensing modes of operation. Vertical (circular) fins provide for better condensation heat transfer since the condensate falls away from the fins at a faster rate than if the fin were inclined (i.e., spiral geometry). As shown in the area discussion above, the angular difference between the circular fin geometry and the spiral fin geometry for the VY coils with a fin pitch of 10 fins per inch is very small (i.e., $<2^\circ$). The angle of incline, therefore, is deemed to be sufficiently small as to make the difference between circular and spiral fin geometries negligible even for condensing modes of operation. In other words, as far as condensation removal from the fin surfaces is concerned, the 10 fin per inch fin pitch of the VY coils results in a fin orientation that is sufficiently close to vertical as to make differences in condensation heat transfer predictions negligible.

**Attachment L to
Proto-Power Calculation
97-200
Revision A**



A Unicom Company

LASALLE STATION FAX TRANSMITTAL

FAX: (815) 357-1262 or (815) 357-6761 EXT. 2268

TO: LLOYD PHILPOT

DEPARTMENT: PROTO-POWER

PHONE NUMBER: (860) 446-9725

FAX NUMBER: (860) 448-4860

FROM: BOB AYER

DEPARTMENT: SYS. ENGR

PHONE NUMBER: (815) 357-6761 EXT 3277

FAX NUMBER: _____

NUMBER OF PAGES FAXED 5 (including cover sheet)

NOTES:

DIRECT TELEPHONE LINE: 815-357-6761 / TIE LINE 8-527-DESIRED EXT.

p:\wptdocs\corr\admin\faxcs.doc

COMED NUCLEAR DESIGN INFORMATION TRANSMITTAL

- SAFETY-RELATED
 NON-SAFETY-RELATED
 REGULATORY RELATED




Originating Organization
 Section: SEB
 Company: ComEd

NDIIT No.: LS-0835
 Upgrade: 0
 Page: 1 of 2

Station: LaSalle County Units: 1
 Design Change Authority No: N/A

System: VY
 To: Lloyd Phipot, Proto-Power

Subject:
 Dimensional Verification for Tubing and Fins for Cooler 1VY02A

Ayer, Robert A. Preparer	Engineer Position		6/19/98 Date
Friedrich, Rich Reviewer	Engineer Position		6/19/98 Date
Hall, Rich Approver	DE- Mech. Supv. Position		6/19/98 Date

Status of Information: Approved for Use Unverified Verification Method: N/A
 Engineering Judgement Schedule:

Purpose of Issuance
 Transmittal of Dimensions to Proto-Power for Heat Exchanger Analysis

Source of Information
 Walkdown performed on the 1VY02A cooler by R. Ayer (System Engineering) and R. Friedrich (Design Engineering) on 6/19/98.

Description of Information
 The following measurements were obtained for the 1VY02A room cooler at the request of Proto-Power Corporation via fax on 6/13/98. These measurements were obtained at ambient conditions with the system shutdown. Attached is a hard copy of the request and measurements obtained in the field.

Tube Outside Diameter: 0.630 +/- 0.05 in.
 Fin Height: 1.495 +/- 0.02 in.
 Transverse Tube Pitch: 1.452 +/- 0.02 in.
 Effective Finned Tube Length: 104.25 +/- 0.25 in.

The first three of these measurements were taken with a calibrated set of calipers (MMD Id. No. 8049, cal due date 9/98). The tube length measurements was taken with a metal tape measure. The uncertainties listed above are engineering best estimates based on the the measurement techniques used.

Distribution: SEAG
 Wilhelmsen, George R. - ComEd, SES-BOP
 Miller, William J. - ComEd, SE
 Szumski, Daniel R. - ComEd, SES-BOP

WIN No.

FROM: CENTRAL FILE FROM: NDIT 013 007 1202 90-12720 02-11-83 P.03

COMED NUCLEAR DESIGN INFORMATION TRANSMITTAL

<input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY-RELATED <input type="checkbox"/> REGULATORY RELATED	Originating Organization Section: SEB Company: ComEd	NDIT No.: LS-0835 Upgrade: 0 Page 2 of 2
--	---	---

It is not possible to obtain a measurement for longitudinal tube pitch without partial disassembly of the cooler, thus this information is not included in this transmittal. It was, however, verified that successive rows of tubes/fins are offset as shown on page two of Attachment 1 of this NDIT.

Attachments:
Proto-Power Request for Information and Associated Measurements - 2 pages

ComEd - Nuclear Operations Division

Proto-Power Calc: 97-200
Attachment: L
Rev: A Page 4 of 6

I need walkdown confirmation in what ever format is suitable for design input for the following coil layout dimensions (refer to attached sketch) :

d_o - tube outside diameter

h_{fin} - fin height (outside diameter of circle cut by outside fin edge)

S_T - transverse tube pitch (the dimension is actually tube center to tube center but the top fin edge to top fin edge dimension shown in sketch should be the same, or top tube edge to top tube edge as well).

S_L - longitudinal tube pitch (tube center to tube center but front fin edge to front fin edge or front tube edge to front tube edge will work as well)

L_c - finned length of coil (outer fin to outer fin)


Obviously VVO2A is the most important but the info would be good to have for all 4 coolers

NDIT No. LS-0835 P.03

PAGE ~~3~~ OF ~~3~~ 2 OF 2

PREPARED BY RE 6/19/95

REVIEWED BY Paul F... 6/19/95




Proto-Power Calc: 97-200

Attachment: L

Rev: A Page 6 of 6

**Attachment M to
Proto-Power Calculation
97-200
Revision A**

Thermal Margin as a function of Tube-Side Fouling
1(2)VY01A at 75 gpm and 1(2)VY02A at 108 gpm



Proto-Power Calc: 97-200
Attachment: M
Rev: A Page 2 of 32

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$f = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at $f=0.000$

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,289.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.000

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,279.36	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	100.00	j Factor	
Outlet Temperature (°F)	107.40	119.41	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.00200000
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	723,937
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	723,937
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,279.36	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	959.48
Inlet Temperature (°F)	148.00	115.28	j Factor	0.0082
Outlet Temperature (°F)	139.38	119.41	Air-Side ho (BTU/hr·ft ² ·°F)	8.28
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.00200000
Average Temp (°F)	143.69	117.34	U Overall (BTU/hr·ft ² ·°F)	6.51
Skin Temperature (°F)	121.12	120.72	Effective Area (ft ²)	905.33
Velocity ***	3,406.37	2.77	LMTD	26.07
Reynold's Number	804**	19,575	Total Heat Transferred (BTU/hr)	153,767
Prandtl Number	0.7255	3.7364	Surface Effectiveness (Eta)	0.9182
Bulk Visc (lbm/ft·hr)	0.0490	1.3809	Sensible Heat Transferred (BTU/hr)	153,767
Skin Visc (lbm/ft·hr)		1.3374	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0625	61.7524	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3691		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 5 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.001

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.001

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,244.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.001

Extrapolation Calculation Summary

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,113.07	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	100.00	j Factor	
Outlet Temperature (°F)	108.73	118.75	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.02088311
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	698,599
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	698,599
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side		
Mass Flow (lbm/hr)	71,113.07	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)	956.76
Inlet Temperature (°F)	148.00	114.96	j Factor	0.0082
Outlet Temperature (°F)	140.05	118.75	Air-Side ho (BTU/hr·ft ² ·°F)	8.27
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.02088311
Average Temp (°F)	144.03	116.85	U Overall (BTU/hr·ft ² ·°F)	5.79
Skin Temperature (°F)	123.30	119.96	Effective Area (ft ²)	905.33
Velocity ***	3,398.43	2.77	LMTD	26.95
Reynold's Number	802**	19,483	Total Heat Transferred (BTU/hr)	141,344
Prandtl Number	0.7255	3.7557	Surface Effectiveness (Eta)	0.9183
Bulk Visc (lbm/ft·hr)	0.0490	1.3874	Sensible Heat Transferred (BTU/hr)	141,344
Skin Visc (lbm/ft·hr)		1.3469	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.7598	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3690		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 8 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.002

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 9 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.002

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,202.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.002

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr-ft ² -°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	109.96	118.09	Air-Side ho (BTU/hr-ft ² -°F)
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU) 0.03976622
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 675,177
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr) 675,177
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)			
K (BTU/hr-ft-°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,957.87	37,293.47	Tube-Side hi (BTU/hr-ft ² -°F) 953.95
Inlet Temperature (°F)	148.00	114.57	j Factor 0.0082
Outlet Temperature (°F)	140.61	118.09	Air-Side ho (BTU/hr-ft ² -°F) 8.26
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU) 0.03976622
Average Temp (°F)	144.30	116.33	U Overall (BTU/hr-ft ² -°F) 5.22
Skin Temperature (°F)	125.07	119.22	Effective Area (ft ²) 905.33
Velocity ***	3,391.01	2.77	LMTD 27.78
Reynold's Number	800**	19,386	Total Heat Transferred (BTU/hr) 131,195
Prandtl Number	0.7255	3.7764	Surface Effectiveness (Eta) 0.9184
Bulk Visc (lbm/ft-hr)	0.0490	1.3943	Sensible Heat Transferred (BTU/hr) 131,195
Skin Visc (lbm/ft-hr)		1.3564	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0623	61.7676	Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)	0.2402	0.9988	
K (BTU/hr-ft-°F)	0.0162	0.3688	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 11 of 32

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.003

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.003000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at $f=0.003$

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,160.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.003

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,802.66	37,293.47	Tube-Side hi (BTU/hr-ft ² -°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	111.21	117.53	Air-Side ho (BTU/hr-ft ² -°F)
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU) 0.05864934
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 651,570
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr) 651,570
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)			
K (BTU/hr-ft-°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,802.66	37,293.47	Tube-Side hi (BTU/hr-ft ² -°F) 951.56
Inlet Temperature (°F)	148.00	114.25	j Factor 0.0082
Outlet Temperature (°F)	141.09	117.53	Air-Side ho (BTU/hr-ft ² -°F) 8.25
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU) 0.05864934
Average Temp (°F)	144.55	115.89	U Overall (BTU/hr-ft ² -°F) 4.74
Skin Temperature (°F)	126.60	118.59	Effective Area (ft ²) 905.33
Velocity ***	3,383.59	2.77	LMTD 28.49
Reynold's Number	798**	19,303	Total Heat Transferred (BTU/hr) 122,373
Prandtl Number	0.7254	3.7942	Surface Effectiveness (Eta) 0.9185
Bulk Visc (lbm/ft-hr)	0.0490	1.4003	Sensible Heat Transferred (BTU/hr) 122,373
Skin Visc (lbm/ft-hr)		1.3646	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0623	61.7743	Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)	0.2402	0.9988	
K (BTU/hr-ft-°F)	0.0162	0.3686	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 14 of 32

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.004

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.004000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentes		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 15 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.004

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	75.00
Air Flow (acfm)	19,123.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 75 gpm at f=0.004

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,665.94	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	112.31	116.92	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.07753245
Average Temp (°F)			
Skin Temperature (°F)			U Overall (BTU/hr·ft ² ·°F)
Velocity ***			Effective Area (ft ²) 7,242.65
Reynold's Number			LMTD
Prandtl Number			Total Heat Transferred (BTU/hr) 630,961
Bulk Visc (lbm/ft·hr)			
Skin Visc (lbm/ft·hr)			Surface Effectiveness (Eta)
Density (lbm/ft ³)			Sensible Heat Transferred (BTU/hr) 630,961
Cp (BTU/lbm·°F)			Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)			Heat to Condensate (BTU/hr)

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	70,665.94	37,293.47	Tube-Side hi (BTU/hr·ft ² ·°F) 948.87
Inlet Temperature (°F)	148.00	113.83	j Factor 0.0082
Outlet Temperature (°F)	141.49	116.92	Air-Side ho (BTU/hr·ft ² ·°F) 8.24
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.07753245
Average Temp (°F)	144.74	115.38	
Skin Temperature (°F)	127.86	117.92	U Overall (BTU/hr·ft ² ·°F) 4.35
Velocity ***	3,377.06	2.77	Effective Area (ft ²) 905.33
Reynold's Number	796**	19,208	LMTD 29.23
Prandtl Number	0.7254	3.8149	Total Heat Transferred (BTU/hr) 115,100
Bulk Visc (lbm/ft·hr)	0.0490	1.4073	
Skin Visc (lbm/ft·hr)		1.3733	Surface Effectiveness (Eta) 0.9186
Density (lbm/ft ³)	0.0623	61.7819	Sensible Heat Transferred (BTU/hr) 115,100
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)	0.0162	0.3684	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 17 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.000

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentes		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 18 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at $f=0.000$

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,347.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.000

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,493.69	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	105.73	114.11	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.00200000
Average Temp (°F)			
Skin Temperature (°F)			U Overall (BTU/hr·ft ² ·°F)
Velocity ***			Effective Area (ft ²) 7,242.65
Reynold's Number			LMTD
Prandtl Number			Total Heat Transferred (BTU/hr) 756,011
Bulk Visc (lbm/ft·hr)			
Skin Visc (lbm/ft·hr)			Surface Effectiveness (Eta)
Density (lbm/ft ³)			Sensible Heat Transferred (BTU/hr) 756,011
Cp (BTU/lbm·°F)			Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)			Heat to Condensate (BTU/hr)

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,493.69	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F) 1,251.72
Inlet Temperature (°F)	148.00	110.69	j Factor 0.0082
Outlet Temperature (°F)	137.73	114.11	Air-Side ho (BTU/hr·ft ² ·°F) 8.29
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.00200000
Average Temp (°F)	142.87	112.40	
Skin Temperature (°F)	115.96	115.49	U Overall (BTU/hr·ft ² ·°F) 6.72
Velocity ***	3,416.62	3.98	Effective Area (ft ²) 905.33
Reynold's Number	807**	26,863	LMTD 30.16
Prandtl Number	0.7256	3.9391	Total Heat Transferred (BTU/hr) 183,607
Bulk Visc (lbm/ft·hr)	0.0489	1.4490	
Skin Visc (lbm/ft·hr)		1.4058	Surface Effectiveness (Eta) 0.9181
Density (lbm/ft ³)	0.0626	61.8257	Sensible Heat Transferred (BTU/hr) 183,607
Cp (BTU/lbm·°F)	0.2402	0.9988	Latent Heat Transferred (BTU/hr)
K (BTU/hr·ft·°F)	0.0162	0.3674	Heat to Condensate (BTU/hr)

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: M
Rev: A Page 20 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at $f=0.001$

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.001000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentes		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 21 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.001

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,301.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.001

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,323.71	53,702.59	Tube-Side hi (BTU/hr-ft ² -°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	107.03	113.64	Air-Side ho (BTU/hr-ft ² -°F)
Inlet Specific Humidity			Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr-ft ² -°F/BTU) 0.02088311
Average Temp (°F)			U Overall (BTU/hr-ft ² -°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 731,028
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft-hr)			Sensible Heat Transferred (BTU/hr) 731,028
Skin Visc (lbm/ft-hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)			
K (BTU/hr-ft-°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,323.71	53,702.59	Tube-Side hi (BTU/hr-ft ² -°F) 1,249.18
Inlet Temperature (°F)	148.00	110.52	j Factor 0.0082
Outlet Temperature (°F)	138.63	113.64	Air-Side ho (BTU/hr-ft ² -°F) 8.28
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr-ft ² -°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr-ft ² -°F/BTU) 0.02088311
Average Temp (°F)	143.32	112.08	U Overall (BTU/hr-ft ² -°F) 5.96
Skin Temperature (°F)	118.84	114.90	Effective Area (ft ²) 905.33
Velocity ***	3,408.49	3.98	LMTD 30.98
Reynold's Number	805**	26,780	Total Heat Transferred (BTU/hr) 167,164
Prandtl Number	0.7255	3.9527	Surface Effectiveness (Eta) 0.9182
Bulk Visc (lbm/ft-hr)	0.0489	1.4535	Sensible Heat Transferred (BTU/hr) 167,164
Skin Visc (lbm/ft-hr)		1.4139	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0626	61.8302	Heat to Condensate (BTU/hr)
Cp (BTU/lbm-°F)	0.2402	0.9988	
K (BTU/hr-ft-°F)	0.0162	0.3673	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 23 of 32

*** Air Mass Velocity (Lbm/hr-ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.002

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.002000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr·ft·°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr·ft·°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 24 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.002

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,258.50
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.002

Extrapolation Calculation Summary

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)
Inlet Temperature (°F)	148.00	100.00	j Factor
Outlet Temperature (°F)	108.29	113.17	Air-Side ho (BTU/hr·ft ² ·°F)
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)
Skin Temperature (°F)			Effective Area (ft ²) 7,242.65
Velocity ***			LMTD
Reynold's Number			Total Heat Transferred (BTU/hr) 707,030
Prandtl Number			Surface Effectiveness (Eta)
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr) 707,030
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)			
K (BTU/hr·ft·°F)			

Extrapolation Calculation for Row 1(Dry)

	Air-Side	Tube-Side	
Mass Flow (lbm/hr)	71,166.65	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F) 1,246.55
Inlet Temperature (°F)	148.00	110.31	j Factor 0.0082
Outlet Temperature (°F)	139.36	113.17	Air-Side ho (BTU/hr·ft ² ·°F) 8.27
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU) 0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU) 0.03976622
Average Temp (°F)	143.68	111.74	U Overall (BTU/hr·ft ² ·°F) 5.35
Skin Temperature (°F)	121.18	114.33	Effective Area (ft ²) 905.33
Velocity ***	3,400.99	3.98	LMTD 31.73
Reynold's Number	803**	26,688	Total Heat Transferred (BTU/hr) 153,749
Prandtl Number	0.7255	3.9675	Surface Effectiveness (Eta) 0.9183
Bulk Visc (lbm/ft·hr)	0.0490	1.4585	Sensible Heat Transferred (BTU/hr) 153,749
Skin Visc (lbm/ft·hr)		1.4217	Latent Heat Transferred (BTU/hr)
Density (lbm/ft ³)	0.0625	61.8352	Heat to Condensate (BTU/hr)
Cp (BTU/lbm·°F)	0.2402	0.9988	
K (BTU/hr·ft·°F)	0.0162	0.3672	

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: M
Rev: A Page 26 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.003

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
<hr/>		
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.003000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 27 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.003

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,216.50
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,011.45	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	100.00	j Factor	
Outlet Temperature (°F)	109.53	112.75	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.05864934
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	683,298
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	683,298
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	71,011.45	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,244.16
Inlet Temperature (°F)	148.00	110.10	j Factor	0.0082
Outlet Temperature (°F)	139.98	112.75	Air-Side ho (BTU/hr·ft ² ·°F)	8.26
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.05864934
Average Temp (°F)	143.99	111.42	U Overall (BTU/hr·ft ² ·°F)	4.86
Skin Temperature (°F)	123.15	113.82	Effective Area (ft ²)	905.33
Velocity ***	3,393.57	3.98	LMTD	32.39
Reynold's Number	801**	26,605	Total Heat Transferred (BTU/hr)	142,406
Prandtl Number	0.7255	3.9812	Surface Effectiveness (Eta)	0.9184
Bulk Visc (lbm/ft·hr)	0.0490	1.4630	Sensible Heat Transferred (BTU/hr)	142,406
Skin Visc (lbm/ft·hr)		1.4288	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.8397	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3671		

** Reynolds Number Outside Range of Equation Applicability

ComEd -- LaSalle

Data Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.004

Air Coil Heat Exchanger Input Parameters

	Air-Side	Tube-Side
Fluid Quantity, Total	21,179.00 acfm	150.00 gpm
Inlet Dry Bulb Temp	150.00 °F	105.00 °F
Inlet Wet Bulb Temp	92.00 °F	
Inlet Relative Humidity	%	
Outlet Dry Bulb Temperature	109.40 °F	115.30 °F
Outlet Wet Bulb Temp	84.10 °F	
Outlet Relative Humidity	%	
Tube Fluid Name		Fresh Water
Tube Fouling Factor		0.004000
Air-Side Fouling		0.002000
Design Heat Transfer (BTU/hr)		750,000
Atmospheric Pressure		14.315
Sensible Heat Ratio		1.00
Performance Factor (% Reduction)		0.000
Heat Exchanger Type		Counter Flow
Fin Type		Circular Fins
Fin Configuration		LaSalle VY Coolers 01A/02A
		$j = \text{EXP}[-2.5088 + -0.3436 * \text{LOG}(\text{Re})]$
Coil Finned Length (in)		104.250
Fin Pitch (Fins/Inch)		10.000
Fin Conductivity (BTU/hr-ft-°F)		128.000
Fin Tip Thickness (inches)		0.0120
Fin Root Thickness (inches)		0.0120
Circular Fin Height (inches)		1.495
Number of Coils Per Unit		2
Number of Tube Rows		8
Number of Tubes Per Row		20.00
Active Tubes Per Row		20.00
Tube Inside Diameter (in)		0.5270
Tube Outside Diameter (in)		0.6250
Longitudinal Tube Pitch (in)		1.500
Transverse Tube Pitch (in)		1.452
Number of Serpentine		1.000
Tube Wall Conductivity (BTU/hr-ft-°F)		225.00

Proto-Power Calc: 97-200

Attachment: M

Rev: A Page 30 of 32

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.004

Calculation Specifications

Constant Inlet Temperature Method Was Used
 Extrapolation Was to User Specified Conditions
 Design Fouling Factors Were Used

Test Data

Data Date
 Air Flow (acfm)
 Air Dry Bulb Temp In (°F)
 Air Dry Bulb Temp Out (°F)
 Relative Humidity In (%)
 Relative Humidity Out (%)
 Wet Bulb Temp In (°F)
 Wet Bulb Temp Out (°F)
 Atmospheric Pressure
 Tube Flow (gpm)
 Tube Temp In (°F)
 Tube Temp Out (°F)
 Condensate Temperature (°F)

Extrapolation Data

Tube Flow (gpm)	108.00
Air Flow (acfm)	19,177.00
Tube Inlet Temp (°F)	100.00
Air Inlet Temp (°F)	148.0
Inlet Relative Humidity (%)	12.76
Inlet Wet Bulb Temp (°F)	0.00
Atmospheric Pressure	14.315

ComEd -- LaSalle

Calculation Report for: 1(2)VY01A & 02A - CSCS Equipment Area Cooling Coils

Fouling Sensitivity: 108 gpm at f=0.004

Extrapolation Calculation Summary

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,865.48	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	
Inlet Temperature (°F)	148.00	100.00	j Factor	
Outlet Temperature (°F)	110.71	112.33	Air-Side ho (BTU/hr·ft ² ·°F)	
Inlet Specific Humidity			Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity			Overall Fouling (hr·ft ² ·°F/BTU)	0.07753245
Average Temp (°F)			U Overall (BTU/hr·ft ² ·°F)	
Skin Temperature (°F)			Effective Area (ft ²)	7,242.65
Velocity ***			LMTD	
Reynold's Number			Total Heat Transferred (BTU/hr)	660,999
Prandtl Number			Surface Effectiveness (Eta)	
Bulk Visc (lbm/ft·hr)			Sensible Heat Transferred (BTU/hr)	660,999
Skin Visc (lbm/ft·hr)			Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)			Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)				
K (BTU/hr·ft·°F)				

Extrapolation Calculation for Row 1(Dry)

	<u>Air-Side</u>	<u>Tube-Side</u>		
Mass Flow (lbm/hr)	70,865.48	53,702.59	Tube-Side hi (BTU/hr·ft ² ·°F)	1,241.70
Inlet Temperature (°F)	148.00	109.85	j Factor	0.0082
Outlet Temperature (°F)	140.51	112.33	Air-Side ho (BTU/hr·ft ² ·°F)	8.25
Inlet Specific Humidity	0.0203		Tube Wall Resistance (hr·ft ² ·°F/BTU)	0.00031430
Outlet Specific Humidity	0.0203		Overall Fouling (hr·ft ² ·°F/BTU)	0.07753245
Average Temp (°F)	144.25	111.09	U Overall (BTU/hr·ft ² ·°F)	4.44
Skin Temperature (°F)	124.81	113.33	Effective Area (ft ²)	905.33
Velocity ***	3,386.59	3.98	LMTD	33.01
Reynold's Number	799**	26,517	Total Heat Transferred (BTU/hr)	132,834
Prandtl Number	0.7255	3.9957	Surface Effectiveness (Eta)	0.9185
Bulk Visc (lbm/ft·hr)	0.0490	1.4679	Sensible Heat Transferred (BTU/hr)	132,834
Skin Visc (lbm/ft·hr)		1.4357	Latent Heat Transferred (BTU/hr)	
Density (lbm/ft ³)	0.0624	61.8445	Heat to Condensate (BTU/hr)	
Cp (BTU/lbm·°F)	0.2402	0.9988		
K (BTU/hr·ft·°F)	0.0162	0.3669		

** Reynolds Number Outside Range of Equation Applicability

Proto-Power Calc: 97-200
Attachment: M
Rev: A Page 32 of 32

*** Air Mass Velocity (Lbm/hr·ft²), Tube Fluid Velocity (ft/sec); Air Density at Inlet T, Other Properties at Average T

**Attachment N to
Proto-Power Calculation
97-200
Revision A**

Proto-HX Model Database

Saved on attached disk as:

Name: vy-0102a.phx

Size: 1,146,880 bytes

Date: 6/24/98

Time: 2:25:30 pm

**PROTO-POWER CORPORATION
CALCULATION TITLE SHEET**

CLIENT: Commonwealth Edison / LaSalle County Station

PROJECT: COMED / LaSalle Station GL 89-13 Program

CALCULATION TITLE: Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers

CALCULATION NO.: 97-195

FILE NO.: 31-003

COMPUTER CODE & VERSION (if applicable): PROTO-HX ver 3.02

REV	TOTAL NO. OF PAGES	ORIGINATOR/DATE	VERIFIER/DATE	APPROVAL/DATE
A	73	<i>D. Phyfe 6/29/98</i> D. Phyfe	<i>Scott M. Ingalls 6/29/98</i> S. Ingalls	<i>L. Philpot 6/30/98</i> L. Philpot

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE ii OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Revision History

Revision	Revision Description
A	Original Issue

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE iii OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

CALCULATION VERIFICATION FORM

REVIEW METHOD:

- | | | | |
|--|-------------------------------------|-----|-------------------------------------|
| Approach Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Logic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Arithmetic Checked: | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> |
| Alternate Method
(Attach Brief Summary) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Computer Program Used
(Attach Listing) | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |
| Other | <input type="checkbox"/> | N/A | <input checked="" type="checkbox"/> |

EXTENT OF VERIFICATION:

- Complete Calculation:
- Revised areas only:
- Other (describe below):

***Errors Detected**

Minor Editorial

***Error Resolution**

Corrected

***Other Comments**

***Extra References Used**

*(Attach extra sheets if needed)

CALCULATION FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT AND REASONABLE:

IDV Signature: Scott M. Ingalls

Printed Name: Scott M. Ingalls

Initials: SMI

Date: 6/29/98

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE iv OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

TABLE OF CONTENTS

CALC TITLE SHEETI
REVISION HISTORY II
CALC VERIFICATION SHEETIII
TABLE OF CONTENTSIV
LIST OF ATTACHMENTS V

Total number of pages in Preface of Calc 5

1. **PURPOSE** 1
2. **BACKGROUND**..... 1
3. **DESIGN INPUTS** 1
 3.1.LASALLE STATION REFERENCE CONDITIONS..... 2
 3.2.CONSTRUCTION DETAILS 2
 3.3.PERFORMANCE DETAILS 3
4. **APPROACH** 4
 4.1.PROTO-HX™ PARAMETER CALCULATION 4
 4.2.PROTO-HX™ FLOW RATE INPUTS 4
 4.3.PROTO-HX™ EXTRAPOLATION METHOD..... 5
5. **ASSUMPTIONS** 5
6. **ANALYSIS**..... 5
 6.1.PROTO-HX™ MODEL 5
 6.2.HEAT EXCHANGER FOULING FACTOR LIMIT..... 6
 6.3.FOULING SENSITIVITY 7
 6.4.THERMAL MARGIN ASSESSMENT..... 8
 6.5.MINIMUM SERVICE WATER FLOW RATE..... 9
7. **CONCLUSION**..... 11
 7.1.PROTO-HX™ MODEL 11
 7.2.HEAT EXCHANGER FOULING FACTOR LIMIT..... 11
 7.3.FOULING SENSITIVITY 11
 7.4.THERMAL MARGIN ASSESSMENT..... 11
 7.5.MINIMUM SERVICE WATER FLOW RATE..... 11
8. **REFERENCES** 12

Total number of pages in Body of Calc 12

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE v OF v
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

LIST OF ATTACHMENTS		
Attachment	Subject Matter	Total Pages
A	Proto-Power Calc. 97-195, Rev. A; Vendor Supplied Hx. Information	3
B	Proto-Power Calc. 97-195, Rev. A; Sargent & Lundy Specification J-2544	3
C	Proto-Power Calc. 97-195, Rev. A; Form N-1 Manufacturer's Data Report for Nuclear Vessels	7
D	Proto-Power Calc. 97-195, Rev. A; LaSalle Station UFSAR Sections: 9.2.1.1.1, 9.5.5.1.1, FSAR Q40.92	5
E	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports and Model Data Sheets	13
F	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports for Fouling Sensitivity	6
G	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Calculation Reports for Minimum Service Water Flow	17
H	Proto-Power Calc. 97-195, Rev. A; PROTO-HX™ Version 3.02 Model	2 (and disk)

Complete Calc (total number of pages)

73

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 1 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

1. PURPOSE

The purpose of this calculation is to develop a thermal performance analysis model for the Commonwealth Edison (ComEd) LaSalle Station, Standby Diesel Generator heat exchanger. This model is to be used for the analysis of heat exchanger thermal performance test data as part of the LaSalle Station heat exchanger testing program.

Once developed, the model is used to evaluate the thermal margin of the heat exchanger at the LaSalle Station Reference Conditions as currently defined in the LaSalle design and licensing basis.

The thermal performance model documented in this calculation has been created and used with PROTO-HX, Version 3.02. The model can be used with previous versions of PROTO-HX and produce identical results as long as the following restrictions are upheld:

- Versions prior to version 3.02 will not calculate a negative fouling factor when calculating the fouling factor based on test data.
- Shell and tube heat exchangers analyzed in Version 3.0 or earlier must have a tube-side Reynolds Number greater than 10,000 (i.e., fully developed turbulent flow).

Current limitations of use for PROTO-HX are established by the limits on fluid properties included within the software. Fluid properties contained within PROTO-HX are currently limited to the following temperature ranges:

- Water (fresh and salt): 32-500°F

2. BACKGROUND

LaSalle Station is in the process of implementing a heat exchanger thermal performance monitoring program in response to the requirements of NRC Generic Letter 89-13 (Reference 8.2). Development of an analytical model in PROTO-HX™, Version 3.02, will allow timely analysis of data resulting from the test program.

3. DESIGN INPUTS

The PROTO-HX™ program was developed and validated in accordance with Proto-Power's Nuclear Software Quality Assurance Program (SQAP). This program meets the requirements of 10CFR50 Appendix B, 10CFR21, and ANSI NQA-1, and was developed in accordance with the guidelines and standards contained in ANSI/IEEE Standard 730/1984 and ANSI NQA-2b-1991. PROTO-HX™ Version 3.02 was verified and approved for use as documented in Reference 8.10.

The design inputs for this calculation consist of the heat exchanger design basis requirement (Section 3.1), construction details (Section 3.2), and performance specifications (Section 3.3) provided by the Hx manufacturer data sheets or design documents as referenced. Construction

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 2 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

details give the necessary information for model construction while performance specifications provided by the manufacturer are used to benchmark the model.

Thermal performance of the Standby diesel generator heat exchanger is assessed in this calculation at the LaSalle Station Reference Conditions of Section 3.1 with all tubes active at 100% and 110% of rated load. No tube plugging margin is considered.

3.1. LASALLE STATION REFERENCE CONDITIONS

Table 3-1 describes the performance requirement of the jacket water cooler. These conditions ensure that the engine operating temperature range will not be exceeded.

Table 3-1 LaSalle Station Reference Conditions

Parameter	Value	Reference
Heat Load at 100% power/110% power (BTU/hr)	7,800,000 / 8,600,000	8.1, 8.4
Shell-Side Flow Rate (gpm)	1,100	8.4
Shell-Side Inlet Temperature (°F)	190	8.4
Tube-Side Flow Rate (gpm)	800	8.1, 8.4
Tube-Side Inlet Temperature (°F)	100	8.1

3.2. CONSTRUCTION DETAILS

Table 3-2 Construction Details

Parameter	Value	Reference
Heat Exchanger Type	AEW	8.11
Total Effective Area per unit (ft ²)	479	8.11
Number of Shells per unit	1	8.11
Shell Velocity (ft/sec)	5	8.11
Tube Passes per shell	2	8.11
U-Tubes (yes or no)	No	8.11
Total Number of Tubes	188	8.11
Tube Length (ft)	13	8.11
Tube Inside Diameter (in)	0.652 (18 BWG)	8.11
Tube Outside Diameter (in)	0.750	8.11
Stationary Tubesheet Thickness (in)	0.938	8.3
Floating Tubesheet Thickness (in)	1.875	8.3
Tube Wall Conductivity (BTU/hr-ft-°F)	112 (Arsenical Cooper)	8.9, (8.11)
Tube Pitch (in)	0.750	8.11

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 3 OF 12
	ORIGINATOR D. Phye		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 3-2 Construction Details

Parameter	Value	Reference
Pitch Type	Triangle	8.11

The vendor data sheet shows the effective area as 479 ft², however, based on the outside tube diameter and tube length, this value is a gross area (A_{gr}) approximation:

$$A_{gr} = (\text{number of tubes}) \cdot (L_{\text{tube}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 1}$$

$$A_{gr} = 188 \cdot 13 \text{ ft} \cdot \pi \cdot \left(\frac{0.750 \text{ in}}{12 \text{ in/ft}} \right) = 479.878 \text{ ft}^2$$

The effective area (A_{eff}) can be approximated as follows:

$$A_{\text{eff}} = (\text{number of tubes}) \cdot (L_{\text{tube}} - T_{\text{fixed}} - T_{\text{floating}}) \cdot (\text{tube outside circ.}) \quad \text{Equation 2}$$

$$A_{\text{eff}} = 188 \cdot \left(13 \text{ ft} - \frac{(0.938 \text{ in} + 1.875 \text{ in})}{12 \text{ in/ft}} \right) \cdot \pi \cdot \left(\frac{0.750 \text{ in}}{12 \text{ in/ft}} \right) = 471.2251 \text{ ft}^2$$

where :

- A_{gr} - Heat Exchanger Gross Area, ft²
- A_{eff} - Heat Exchanger Effective Area, ft²
- L_{tube} - Tube Length, ft
- T_{fixed} - Fixed End Tubesheet Thickness, ft (0.938" per Reference 8.3)
- T_{floating} - Floating End Tubesheet Thickness, ft (1.875" per Reference 8.3)

The data sheet value for the effective area will be used in the model benchmarking process. However, for PROTO-HX™ runs of the Standby heat exchanger model the above calculated effective area will be used.

3.3. PERFORMANCE DETAILS

Table 3-3 Performance Details

Parameter	Value	Reference
Shell Side Fluid Type	Jacket Water (Fresh)	8.11
Total Fouling Factor (Design)	0.00285	8.11
Shell Side Fluid Flow Rate (lb/hr)	550,000	8.11
Shell Side Inlet Temperature (°F)	190	8.11
Shell Side Outlet Temperature (°F)	174.4	8.11
Tube Side Fluid Type	Service Water (Fresh)	8.1/8.7

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 4 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 3-3 Performance Details

Parameter	Value	Reference
Tube Side Fluid Flow Rate (lb/hr)	388,000	8.11
Tube Side Inlet Temperature (°F)	100	8.11
Tube Side Outlet Temperature (°F)	122.2	8.11
Hx. Design Q - Service (BTU/hr)	8,600,000	8.11
Hx. Design U - Service (BTU/hr-ft ² -°F)	255.2	8.11

4. APPROACH

This calculation utilizes plant/vendor fabrication specifications provided in Attachment (A) to develop a thermal performance prediction model for the LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers. The calculation then benchmarks the model by comparing the heat transfer rate calculated by PROTO-HX™ Version 3.02 with the manufacturer's specifications for thermal performance.

4.1. PROTO-HX™ PARAMETER CALCULATION

Minimum Shell Area

The minimum shell area is calculated using either the shell side velocity or a shell geometry. The preferred method of calculation is using the shell side velocity. Reference 8.11 gives the shell side velocity to be 5 ft/sec at a flow rate of 1100 gpm. Based on this velocity and flow rate the minimum shell side area is calculated by PROTO-HX™ to be 0.490 ft².

Outside H Factor (Hoff)

The Outside H Factor is a multiplier, with value less than 1.0, used to reduce the ideal shell side film heat transfer coefficient. The Outside H Factor accounts for inefficiency in the heat exchanger. Using the back calculation method, based on the design overall heat transfer coefficient, the Outside H Factor was calculated by PROTO-HX™ to be 0.780.

4.2. PROTO-HX™ FLOW RATE INPUTS

Volumetric flow rates are converted to mass flow rates based on a set temperature of 60°F in PROTO-HX™. Therefore, the actual PROTO-HX™ inputs have to be adjusted to give the correct mass flow rate. The PROTO-HX™ input is adjusted using the ratio of the actual water density and the density of water at 60°F.

$$Q_{phx} = Q_{temp} \cdot \frac{\rho_{temp}}{\rho_{60°F}} \quad \text{Equation 3}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 5 OF 12
	ORIGINATOR D. Phyfe	DATE 6/29/98	
	VERIFIED BY S. Ingalls	JOB NO. 31-003	
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 4-1 PROTO-HX™ Flow Rate Inputs

Parameter	Density (lb/ft ³)	Actual Flow (gpm)	PROTO-HX™ Input (gpm)
Tube-side, 100°F	61.994 (8.12)	800	795.25
Shell-side, 190°F	60.349 (8.12)	1,100	1,064.495
PROTO-HX™, 60°F	62.364 (8.12)		

4.3. PROTO-HX™ EXTRAPOLATION METHOD

All calculations performed for this calculation are based on a constant cold inlet temperature. This allows the comparison of the heat transfer, outlet temperatures, log mean temperature difference (LMTD), and overall heat transfer coefficient. There is no comparison of the overall heat transfer coefficient in the design case since PROTO-HX™ used the data sheet value of the overall heat transfer coefficient to calculate the shell side film heat transfer coefficient.

5. ASSUMPTIONS

5.1. The vendor data sheet (Reference 8.11) is considered an accurate reflection of the vendor's expectation for the heat exchanger's outside film heat transfer coefficient. Therefore, the benchmarking of the PROTO-HX™ model to the vendor data sheet will ensure that the PROTO-HX™ calculated outside film heat transfer coefficient is consistent with the vendor's expectation. The PROTO-HX™ model is benchmarked with the vendor data sheet effective area. However, calculations performed with the model use the effective area determined in Section 3.2. Future validation of this assumption is not required.

6. ANALYSIS

6.1. PROTO-HX™ MODEL

Table 6-1 shows the PROTO-HX™ benchmarking of the Jacket Water Cooler for the Standby Diesel Generator. The PROTO-HX™ reports can be found in Attachment E.

Table 6-1 Model Benchmark Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	479	479	0.00 %
Shell Side Outlet Temp, °F	174.4	174.4	0.00 %
Tube Side Outlet Temp, °F	122.2	122.2	0.00 %
Heat Transferred, BTU/hr	8,589,000	8,600,000	-0.13 %
Corrected LMTD	70.3	70.2	0.14 %

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 6 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-2 shows the PROTO-HX™ results for the heat exchanger design conditions using the corrected effective area, Section 3.2. The PROTO-HX™ reports can be found in Attachment E.

Table 6-2 Model Design Correlation

Parameter	PROTO-HX™	Data Sheet	Percent Difference
Effective Area, ft ²	471.2	479	-1.63 %
Shell Side Outlet Temp, °F	174.6	174.4	0.11 %
Tube Side Outlet Temp, °F	121.9	122.2	-0.25 %
Heat Transferred, BTU/hr	8,481,000	8,600,000	-1.38 %
Corrected LMTD	70.5	70.2	0.43 %

All PROTO-HX™ calculations performed with the Standby Jacket Water Cooler model will use the effective area of 471.23 ft². This change is made to the PROTO-HX™ heat exchanger data sheet as shown in Attachment E.

6.2. HEAT EXCHANGER FOULING FACTOR LIMIT

In order for the jacket water cooler to meet the Reference Conditions (Table 3-1) the fouling must be limited from the values listed on the vendor's data sheet (Reference 8.11). The overall fouling factor limit was determined by iterating on the overall fouling factor, a PROTO-HX™ input, until the required heat load was matched. Table 6-3 shows the results of the PROTO-HX™ runs for the limited fouling factor case, see Attachment E.

Table 6-3 Fouling Factor Limit

Parameter	Design Fouling	Limited Fouling
Overall Fouling Factor	0.00285	0.002782
Overall Heat Transfer Coefficient	255.2	259.7
Heat Transfer Rate	8,484,000	8,600,000
Required Heat Transfer Rate	8,600,000	8,600,000
Thermal Margin	-116,000	0.0
% Thermal Margin	--1.35 %	0.00 %

The limitations on the fouling factor are placed on the tube-side fouling factor, since the tube-side is the most controllable via periodic tube-side cleaning. To be consistent with the HPCS Diesel the shell-side fouling factor will be set to 0.0005 hr ft² °F/Btu for this analysis. The tube-side fouling factor is calculated from the overall fouling found from the PROTO-HX™ iteration process.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 7 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

The area ratio is used to convert the overall fouling factor to a tube-side and shell-side fouling factor

$$f_{\text{total}} = f_{\text{shell}} + (\text{Area Ratio}) \cdot f_{\text{tube}} \quad \text{Equation 4}$$

$$\text{Area Ratio} = \frac{\text{Tube OD}}{\text{Tube ID}} \quad \text{Equation 5}$$

$$\text{Area Ratio} = \frac{0.750 \text{ in}}{0.652 \text{ in}} = 1.150$$

From the vendor datasheet the design overall fouling factor is

$$f_{\text{Total}} = 0.002850 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

From the PROTO - HX iteration the adjusted overall fouling factor is found :

$$f_{\text{adjusted}} = 0.002782 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

From the new overall fouling factor the new tube - side fouling factor is calculated :

$$f_{\text{tube}} = \frac{(f_{\text{adjusted}} - f_{\text{shell}})}{\text{Area Ratio}} = \frac{(0.002782 - 0.0005) \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}}{1.150} = 0.001984 \text{ hr ft}^2 \text{ }^\circ\text{F} / \text{Btu}$$

The PROTO-HX™ heat exchanger data sheet is changed to reflect the adjusted design fouling as calculated above. Like the effective area change in the heat exchanger data sheet, this change is made without recalculating the Hoff factor.


Attachment E includes a final model calculation report for the Reference Conditions and the adjusted tube-side fouling entered into the PROTO-HX™ data sheet.

6.3. FOULING SENSITIVITY

The fouling sensitivity of the jacket water cooler is shown in Figure 6-1. The fouling sensitivity was developed at 800 gpm CSCS flow, 100°F CSCS inlet temperature, 1100 gpm jacket water flow, and 190°F jacket water inlet temperature. The tube-side fouling factor was varied from 0.0000 to 0.001984 (hr ft² °F/Btu) by increments of 0.0005 (hr ft² °F/Btu). As in Section 6.2, the shell-side fouling factor is held constant at 0.0005 (hr ft² °F/Btu). The PROTO-HX™ Calculation Reports for the fouling sensitivity can be found in Attachment F.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 8 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Figure 6-1



6.4. THERMAL MARGIN ASSESSMENT

The clean thermal margin is assessed by a comparison of the reference condition performance requirements to the heat exchanger performance capability with a zero (0) fouling factor. Using a zero (0) fouling factor shows the maximum available performance of the heat exchanger. Likewise, the service thermal margin is assessed by comparing the reference condition performance requirements to the heat exchanger performance capability with the design fouling factor.

The margin is calculated directly and as a percentage compared to the required heat rate to perform the component's safety function. The PROTO-HX™ reports can be found in Attachment E.

$$\text{margin} = \text{Heat Rate} - \text{Heat Rate}_{\text{required}} \quad \text{Equation 6}$$

$$\% \text{ margin} = 100 \cdot \left(\frac{\text{margin}}{\text{Heat Rate}_{\text{required}}} \right) \quad \text{Equation 7}$$

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 9 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-4 Thermal Margin

Parameter	Service (Design Fouling)	Clean (0 Fouling)
Overall Heat Transfer Coefficient	259.7	955.9
Heat Transfer Rate	8,600,000	18,850,000
Required Heat Transfer Rate	8,600,000	8,600,000
Thermal Margin	0.0	10,250,000
% Thermal Margin	0.00 %	119.19 %

6.5. MINIMUM SERVICE WATER FLOW RATE

The minimum service water flow rate for the adjusted design fouling condition is calculated with the shell-side inlet temperature at 190°F and a flow rate of 1,100 gpm. Iterating using the service water flow rate and inlet temperature, the minimum acceptable flow rate is found for each inlet temperature (Attachment G). The heat load for each iteration must be equal to or slightly above the required heat load of 7,800,000 BTU/hr and 8,600,000 BTU/hr, the diesel heat load at 100% and 110% power, respectively (Reference 8.1). Figure 6-2 shows the results of this iteration process.

The results of the model iterations are summarized in Table 6-5 and Table 6-6 along with Figure 6-2. Density corrections of the PROTO-HX™ flow rates are made in accordance with Equation 3. Values for fluid density are obtained from Reference 8.12.

Table 6-5 Minimum CSCS Flow Rate at 100% Power


CSCS Inlet Temperature (°F)	Density at Inlet Temperature (lbm/ft³)	PROTO-HX™ Input Flow Rate (gpm)	Density Corrected Flow Rate (gpm)
35	62.41903	161.1	161.0
40	62.42184	169.8	169.6
50	62.40595	190.5	190.3
60	62.36445	217.5	217.5
70	62.30034	254.2	254.5
80	62.21603	307.0	307.7
90	62.11349	389.3	390.9
100	61.99437	534.5	537.7

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 10 OF 12
	ORIGINATOR D. Phyfe		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

Table 6-6 Minimum CSCS Flow Rate at 110% Power

CSCS Inlet Temperature (°F)	Density at Inlet Temperature (lbm/ft ³)	PROTO-HX™ Input Flow Rate (gpm)	Density Corrected Flow Rate (gpm)
35	62.41903	193.5	193.3
40	62.42184	204.8	204.6
50	62.40595	232.2	232.1
60	62.36445	269.1	269.1
70	62.30034	321.0	321.3
80	62.21603	399.3	400.3
90	62.11349	530.9	533.1
100	61.99437	795.3	800.0

Figure 6-2 Minimum Service Water Flow



PROTO-POWER CORPORATION		CALC NO. 97-195	REV A	PAGE 11 OF 12
GROTON, CONNECTICUT		ORIGINATOR D. Phyfe		DATE 6/29/98
		VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT	COMED / LaSalle County Station		PROJECT COMED / LaSalle Station GL 89-13 Program	
TITLE	Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

7. CONCLUSION

7.1. PROTO-HX™ MODEL

The Standby Jacket Water Cooler model was developed using PROTO-HX™, Version 3.02. The model was benchmarked to the vendor data sheet. The benchmark model correlation to the vendor data sheet is -0.13 %. The benchmark model is for reference only based on the non-conservative approximation of heat exchanger effective area as discussed in Section 3.2 and Assumption 5.1. Calculations performed with the Standby Jacket Water Cooler model are to use the effective area developed in Section 3.2.

This model should be considered suitable for use in the analysis of thermal performance test data.

The model database is saved under file name dg01a.phx, with a file size of 640 KB, and a file date and time of 6/29/98 at 1:50:34 PM. The saved database is set up to run the Reference Conditions with design fouling factor selected, the design fouling factor is a shell-side fouling of 0.002782. The database file is included as Attachment H.

7.2. HEAT EXCHANGER FOULING FACTOR LIMIT

For the Standby Diesel Generator Jacket Water Cooler to provide adequate heat removal at the specified LaSalle Station Reference Conditions the overall fouling factor must be equal to or less than 0.002782 hr ft² °F/Btu. This overall fouling factor is entered in the model as the shell-side design fouling factor.

7.3. FOULING SENSITIVITY

Given a constant shell-side fouling at the model design value, the sensitivity of the jacket water cooler to tube-side fouling effects is shown on Figure 6-1.

7.4. THERMAL MARGIN ASSESSMENT

Assuming the adjusted heat exchanger effective area and maximum overall fouling factor, the clean and service available thermal margins are 119.19 % and 0.00 % respectively.

7.5. MINIMUM SERVICE WATER FLOW RATE

As shown in Figure 6-2 the service water flow can be throttled down to account for lower service water inlet temperature conditions. The heat exchanger can remove the design heat load for the diesel at 100% (7,800,000 BTU/hr) and 110% (8,600,000 BTU/hr) rated power, by reducing service water flow rates as the service water temperature decreases.

PROTO-POWER CORPORATION GROTON, CONNECTICUT	CALC NO. 97-195	REV A	PAGE 12 OF 12
	ORIGINATOR D. Phye		DATE 6/29/98
	VERIFIED BY S. Ingalls		JOB NO. 31-003
CLIENT COMED / LaSalle County Station	PROJECT COMED / LaSalle Station GL 89-13 Program		
TITLE Thermal Model of COMED / LaSalle Station Unit 0, 1, and 2 Diesel Generator Jacket Water Coolers			

8. REFERENCES

- 8.1. LaSalle Station UFSAR, Sections: 9.2.1.1.1, 9.5.5.1.1 (Attachment D)
- 8.2. NRC Generic Letter 89-13
- 8.3. The National Board of Boiler and Pressure Vessel Inspectors, Form N-1 Manufacturers' Data Report for nuclear Vessels (Attachment C)
- 8.4. LaSalle Station FSAR Q40.92 (Attachment D)
- 8.5. Stewart & Stevens Vendor Manual, VM J-152 through VM J-157
- 8.6. LaSalle Station Drawing, D-22079
- 8.7. Sargent and Lundy Specification J-2544 (Selected Pages, Attachment B)
- 8.8. Not used
- 8.9. Standard of the Tubular Exchanger Manufacturers Association
- 8.10. Heat Exchanger Thermal Performance Modeling Software Program PROTO-HX™ Version 3.02 Software Validation and Verification Report (SVVR) SQA No. SVVR-93948-02, Revision F, dated 2/17/98
- 8.11. American Standard Heat Exchanger Data Sheet for the LaSalle Station Standby Diesel Generator Jacket Water Coolers. (Attachment A)
- 8.12. Proto-Power Calculation 93-048, "Fluid Properties – Fresh Water – Range 32°F to 500°F", Rev. A

**Attachment A to
Proto-Power Calculation
97-197
Revision A**



STEWART & STEVENSON
JUN - 5 1998

STEWART & STEVENSON SERVICES, INC.
RECIPROCATING ENGINE SALES
8631 EAST FREEWAY
HOUSTON, TEXAS 77029

WE ARE TRANSMITTING 2 PAGE(S) INCLUDING COVER. IF INCOMPLETE, PLEASE CALL, 713/671-6218 OR 713/671-6152

PLEASE DELIVER TO:

DATE:

NAME: Duncan Phyfe

FROM:

6/4/98
Robert E. Mitcham

FIRM: COMED

PHONE:

713/671-6 137

FAX: 868-446-8292

FAX:

713/671-6127

REF: LaSalle Heat Exchanger Data Sheets

Please find enclosed data sheets
you requested

- Robert Mitcham

Proto-Power Calc: 97-195
Attachment: A
Rev: A Page 2 of 3



HEAT TRANSFER DIVISION
BUFFALO, N. Y. 14240

HEAT EXCHANGER SPECIFICATION SHEET

1	P. 0400 NO. F-68683-77339	
2	CUSTOMER	Stewart & Stevenson for Commonwealth Edison
3	ADDRESS	LaSalle County Station Units 1 and 2
4	PLANT LOCATION	INQUIRY NO. June 27, 1975
5	SERVICE OF UNIT	Jacket Water Cooler
6	SIZE	15156 CPK
7	TYPE	TEMA AEW#
8	CONNECTED IN	(HORIZ.) (VERT.)
9	SQ. FT. SURF./UNIT (GROSS) (EFF.)	479
10	SHELLS/UNIT	One
11	SQ. FT. SURF./SHELL (GROSS) (EFF.)	479

PERFORMANCE OF ONE UNIT		
	SHELL SIDE	TUBE SIDE
10	FLUID CIRCULATED	Jacket Water
11	TOTAL FLUID ENTERING	550,000 #/Hr
12	VAPOR	
13	LIQUID	388,000 #/Hr
14	STEAM	
15	NON-CONDENSABLES	
16	FLUID VAPORIZED OR CONDENSED	Raw Water
17	STEAM CONDENSED	388,000 #/Hr
18	GRAVITY	
19	VISCOSITY	
20	MOLECULAR WEIGHT	
21	SPECIFIC HEAT	BTU/LB-°F
22	THERMAL CONDUCTIVITY	BTU/HR-FT-°F
23	LATENT HEAT	BTU/LB
24	TEMPERATURE IN	190 °F
25	TEMPERATURE OUT	174.4 °F
26	OPERATING PRESSURE	PSIG
27	NO. PASSES PER SHELL	One
28	VELOCITY	5 FT/SEC
29	PRESSURE DROP	6.1 PSI
30	FOULING RESISTANCE (MIN.)	.00285 Total
31	HEAT EXCHANGED-BTU/HR	8.6 x 10 ⁶
32	TRANSFER RATE-SERVICE	255.2
33	MTD CORRECTED-°F	70.2
34	CLEAN	

CONSTRUCTION OF ONE SHELL		
34	DESIGN PRESSURE	150 PSI
35	TEST PRESSURE	225 PSI
36	DESIGN TEMPERATURE	300 °F
37	TUBES	ARS Copper Alloy 142 No. 188 D. 3/4" BWG. 18 LENGTH 156" PITCH 3/4" Tri.
38	SHELL	Steel I.D. O.D. 16" SHELL COVER None INTEG (REMOV)
39	CHANNEL	Muntz CHANNEL COVER Steel
40	TUBESHEET	STATIONARY Muntz TUBESHEET-FLOATING Muntz
41	BAFFLES-CROSS	Steel TYPE FLOATING HEAD COVER
42	BAFFLES-LONG	TYPE IMPINGEMENT PROTECTION No
43	TUBE SUPPORTS	Steel
44	TUBE TO TUBESHEET JOINT	Rolled
45	GASKETS	Comp. Asbestos Packing - Neoprene
46	CONNECTIONS-SHELL SIDE	IN 10" OUT 10" RATING 150# ANSI
47	CHANNEL SIDE	IN 8" OUT 8" RATING 150# ANSI
48	CORROSION ALLOWANCE-SHELL SIDE	1/16" on C. Steel
49	TUBE SIDE	1/16" on C. Steel
50	CODE REQUIREMENTS	ASME Code III - 3 Stamped TEMA CLASS 11C
51	WEIGHTS-EACH SHELL	3260
52	BUNDLE	1860
53	FULL OF WATER	4410
54	NOTE:	INDICATE AFTER EACH PART WHETHER STRESS RELIEVED (S.R.) AND WHETHER RADIOGRAPHED (X-R)
55	REMARKS:	"Removable Tube Bundle
56	American Standard P/N	5-046-15-156-001
57	American Standard Serial No.	8-20005
58	Proto-Power Calc:	97-195
59	Attachment:	A
60	Rev:	A Page 3 of 3

FORM 100-7 M.T.
REVISED 1-70

JUN 04 '98 19:01

**Attachment B to
Proto-Power Calculation
97-195
Revision A**

REFERENCE 8.7

include a shell and tube heat exchanger which will be supplied with cooling water from the Purchaser's cooling water system.

- b. The closed cooling water system pump shall be of the centrifugal type and shall be driven by the engine.
- c. The shell and the tube heat exchanger shall be of the capacity required for 110 percent of rated power with a fouling factor of 0.0005 on shell side and .002 on the tube side. The heat exchanger shall be in accordance with the requirements of ITEM A, TEMA (Tube Exchanger Manufacturers' Association) Class C and the ASME Code Section III. The type bundle shall be removable without removing shell from its mounting. The tubes shall be 5/8 inch minimum and be of admiralty metal.
- d. The circulating water system shall be provided with controls which will sense and maintain optimum jacket water temperature.
- e. Cooling water supply for the heat exchangers will be at a maximum inlet temperature of 100° F and a minimum of 32° F. The coolers shall be designed for a 150 psig water working pressure and tested at a hydraulic pressure of 225 psig.

F. Starting System

- a. Each engine shall be equipped with an independent pneumatic starting system complete with all valves, integral piping, controls, etc.
- b. The reliability of the starting system is paramount and no compromise of the starting capability shall be made with other basic requirements of the equipment design. Any special devices or auxiliaries required to insure successful starting shall be provided, except any equipment of an experimental type will be unacceptable. Contractor shall describe in his proposal what occurrences are possible to preclude successful starting, and what remedies would be necessary that are not already provided for in the equipment design.
- c. The compressed air starting system shall consist of two redundant sets of equipment, each completely independent of the other for successful operation. A cross-connecting line with a normally closed valve shall be provided between sets. The accumulator furnished with each set of equipment shall have the capacity for a minimum of three normal cranking cycles in rapid succession without the use of its air compressor. Each accumulator shall be furnished with a shut-off cock, pressure gauge drain valve, safety valve, and sensing element for low pressure alarm.

Proto-Power Calc: 97-195

Attachment: B

REFERENCE 8.7

Name of Bidder: Stewart & Stevenson Services, Inc.

ENGINE-GENERATOR DATA, Cont.

(Insert all data in these columns)

(Contractor to furnish complete information for starting system furnished)

E. Engine Cooling System:

	BASE BID		ALTERNATE 1
	DIESEL GEN. 0	DIESEL GEN. 1A AND 2A	DIESEL GEN. 0, 1A AND 2A
a. Cooling system capacity. (gal)	545		
b. Pipe size for cooling water connections..... (in)	8		
c. Heat exchanger dimensions:			
(1) Length..... (in)	179.5		
(2) Diam..... (in)	16"		
(3) Height..... (in)	19.5"		
d. Quantity of cooling water at rated load, required at 80°F..... (gal/min)	550		
at 95°F..... (gal/min)	750		
at 100°F..... (gal/min)	840		
e. Tube material.....	Arsenical Copper (SB111)		
f. Diameter and thickness of tubes..... (in)	3/4" x 18 BWG		
g. Total tube cooling surface..... (ft ²)	479		
h. Water box material.....	Carbon Steel		
	Weights: 3050 lbs Dry 4350 lbs Wet		

PTD-15

76

**Attachment C to
Proto-Power Calculation
97-195
Revision A**

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION - BUFFALO, NEW YORK 14240
(Name and address of Manufacturer)

2. Manufactured for STEWART-STEVENSON SERVICES; HOUSTON, TEXAS
(Name and address of Purchaser)

3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-01-1 Nat'l Id. No. 29386 Yr. Built 1976
(Horiz. or Vert.) (Kind & Spec. No.) (Min. of range specified) (Subject to press.) (State & State No.)

3a. Applicable ASME Code: Section III, Edition 1974, Addenda date WINTER 1974, Case No. _____
Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SMLS STL Nominal Thickness 375 Corrosion Allowance 063 Dia. 16.000 Length 152.438
(Kind & Spec. No.) (Min. of range specified) (in.) (in.) (ft. in.) (ft. in.)

5. Seams: Long SMLS H.T.¹ NO R.T. NONE Efficiency 100 %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses 1

6. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a)								
(b)								

If removable, bolts used _____ (Material, Spec. No., T.S., Size, Number) Other fastening _____ (Describe or attach sketch)

7. Jacket Closure _____ (Describe as open & weld, bar, etc. If bar give dimensions, describe or sketch)
Drop Weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure _____

8. Design Pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____ Pressure 225 psi

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material MUNTZ SB7 Dia. 17.250 in. Thickness 938 in. Attachment BOLTED
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)

Floating. Material MUNTZ SB7 Dia. 15.000 in. Thickness 875 in. Attachment BOLTED
(Kind & Spec. No.)

10. Tubes: Material ARS. COPPER O.D. 3/4 in. Thickness 18 inches or gage _____ Number 188 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material CHANNEL SMLS STL Nominal Thickness 375 Corrosion Allowance 063 Dia. 16.000 Length 14.000
(Kind & Spec. No.) (Min. of range specified) (in.) (in.) (ft. in.) (ft. in.)

12. Seams: Long SMLS H.T.¹ NO R.T. NONE Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses 1

13. Heads: (a) Material F.Q. STL T.S. 55,000 (b) Material _____ T.S. _____ (c) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top, bottom, ends	<u>1.250</u>						<u>19.500</u>	<u>FLAT</u>
(b) Channel								
(c) Floating								

If removable, bolts used (a) ALLOY STL SA193 B7 T.S. 125,000 (b) _____ (c) _____ (Describe or attach sketch)
(Material, Spec. No., T.S., Size, Number) Drop weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure _____

14. Design pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____ Pressure 225 psi

FORM N-1 (back)

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
SHELL IN & OUT	2	10" - 150# ASA PIPE	FIG. SA 106 B		.307		WELDED
TUBE IN & OUT	2	8" - 150# ASA PIPE	FIG. SA 106 B		.277		WELDED

17. Inspection Manholes, No. Size Location
Openings: Handholes, No. Size Location
Threaded, No. Size Location

18. Supports: Skirt NO. Lugs Legs Other CRADLES Attached WELDED TO SHELL
(Yes or No) (Number) (Number) (Describe) (Where & How)

19. Remarks: JACKET WATER COOLER

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file AMERICAN STD. HEAT TRANS. DIV. BUFFALO N.Y.
 Stress analysis report on file at NOT APPLICABLE TO SECTION III CLASS 3 VESSEL
 Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21850
 Stress analysis report certified by NOT APPLICABLE Prof. Eng. State Reg. No.

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III. **AMERICAN STANDARD HEAT TRANSFER DIVISION**
 Date 2/26/76 1976 Signed R. P. Warner By R. P. Warner - Manager, Q.C.
 (Manufacturer)
 Certificate of authorization Expires AUGUST 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois
 have inspected the pressure vessel described in this Manufacturer's Data Report on February 26 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date February 26 1976
J. R. Thomas Inspector's Signature Commission NB 7710
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of psi.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 19
 Inspector's Signature Commission
 National Board, State, Province and No.

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION - BUFFALO, NEW YORK 14240
(Name and address of Manufacturer)
2. Manufactured for STEWART-STEVENSON SERVICES; HOUSTON, TEXAS
(Name and address of Purchaser)
3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-01-2 Net'l Id. No. 29387 Yr. Built 1976
(HORIZ. or VERT.) (SHELL OR BOILER HEAT EX.) (Mfg. Serial No.) (State & State No.)
3a. Applicable ASME Code: Section III, Edition 1974, Addenda date WINTER 1974, Case No. _____
Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell Material SMUS 5TL SA106-B T.S. 60,000 Nominal Thickness 375 Corrosion Allowance 0.03 Dia. 16.000 Length 152.438
(Kind & Spec. No.) (Min. of range specified) in. in. in. ft. in. ft. in.
5. Seams: Long SMLS H.T.¹ NO R.T. NONE Efficiency 100 %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses 1

6. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(Top, bottom, ends)
(a) _____
(b) _____
If removable, bolts used _____ (Material, Spec. No., T.S., Size, Number) Other fastening _____ (Describe or attach sketch)

7. Jacket Closure _____ (Describe as edges & weld, bar, etc. If bar give dimensions, describe or sketch)
Drop Weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure 225 psi
8. Design Pressure ²150 psi at 300 °F at temp. of _____ °F. Combination _____

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material MUNTZ SB7 Dia. 17.250 in. Thickness 0.375 in. Attachment BOLTED
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)
Floating. Material MUNTZ SB7 Dia. 15.000 in. Thickness 0.375 in. Attachment BOLTED
(Kind & Spec. No.)
10. Tubear Material ARG. COPPER SB111 O.D. 3/4 in. Thickness 18 inches or gage Number 188 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

CHANNEL: SMUS 5TL
11. Shell Material SA106-B T.S. 60,000 Nominal Thickness 375 Corrosion Allowance 0.03 Dia. 16.000 Length 14.000
(Kind & Spec. No.) (Min. of range specified) in. in. in. ft. in. ft. in.
12. Seams: Long SMLS H.T.¹ NO R.T. NONE Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses 1

F.Q. 5TL
13. Heads: (a) Material SA385-C T.S. 55,000 (b) Material _____ T.S. _____ (c) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(Top, bottom, ends) 1.250 _____ 19.500 FLAT
(b) Channel _____
(c) Flanging _____
If removable, bolts used (a) 25,000 5/8-16 (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)
Drop weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or _____ Test Pressure 225 psi
14. Design pressure ²150 psi at 300 °F at temp. of _____ °F. Combination _____

¹ If Postweld Heat-Treated
² List other internal or external pressures with coincident temperature when applicable.

Proto-Power Calc 97199
Attachment: C
Rev. A Page 4 of 7

FORM N-1 (back)

NB# 29387

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
SHELLING OUT	2	10"-150#	ASA PIPE	(FLG. SA106B	.307	---	WELDED
TUBING OUT	2	8"-150#	ASA PIPE	(RG. SA106B	.277	---	WELDED

17. Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt NO Lugs _____ Legs _____ Other CRADLES Attached WELDED TO SHELL
 (Yes or No) (Number) (Number) (Describe) (Where & How)

19. Remarks: JACKET WATER COOLER

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file at AMERICAN S.T.A. HEAT TRANS. DIV. BUFFALO N.Y.
 Stress analysis report on file at NOT APPLICABLE TO SECTION III CLASS 3 VESSELS
 Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21854
 Stress analysis report certified by NOT APPLICABLE Prof. Eng. State _____ Reg. No. _____

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.

Date 2/26/76 1976 Signed R. R. Warner By R. R. Warner
 (Manufacturer) (Manager, Q.C.)

Certificate of authorization Expires AUGUST 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois

have inspected the pressure vessel described in this Manufacturer's Data Report on February 26 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date February 26 1976
 Inspector's Signature J. A. Thomas Commissions NB 7710
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____

have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of _____ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19_____
 Inspector's Signature _____ Commissions _____
 National Board, State, Province and No.

5-046-15-156-001

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by AMERICAN STANDARD HEAT TRANSFER DIVISION - BUFFALO, NEW YORK 14240
(Name and address of Manufacturer)
2. Manufactured for STEWART-STEVENSON SERVICES; HOUSTON, TEXAS
(Name and address of Purchaser)
3. Type HORIZ. Kind Heat Exch. Vessel No. 8-20005-PI-9 (Mfr. serial No.) (Store & state No.)
Natl. Id. No. 29388 Yr. Built 1974
3a. Applicable ASME Code: Section III, Edition 1974, Addenda date WINTER 1974, Case No. _____
Class 3

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shells Material SMLS-5TL SA106-B T.S. 60,000 Nominal Thickness 3/16 in. Corrosion Allowance 0.03 in. Dia. 16,000 ft. Length 152.438 ft.
(Kind & Spec. No.) (Min. of range specified)
5. Seams: Long SMLS H.T. NO R.T. NONE Efficiency 100 %
Girth _____ H.T. _____ R.T. _____ No. of Courses 1
6. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(a) _____
(b) _____
If removable, bolts used _____ (Material, Spec. No., T.S., Size, Number) Other fastening _____ (Describe or attach sketch)
7. Jacket Closure _____ (Describe as cage & weld, bar, etc. If bar give dimensions, describe or sketch)
Drop Weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or Test Pressure 225 psi
8. Design Pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material HUNTZSB7 Dia. 11.250 in. Thickness 3/32 in. Attachment BOLTED
(Kind & Spec. No.) (Subject to press.)
Floating. Material HUNTZSB7 Dia. 15.000 in. Thickness 1/8 in. Attachment BOLTED
(Kind & Spec. No.)
10. Tubes: Material ARS. COPPER SA111 O.D. 3/4 in. Thickness 18 inches Number 188 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shells Material CHANNEL SMLS 5TL SA106-B T.S. 60,000 Nominal Thickness 3/16 in. Corrosion Allowance 0.03 in. Dia. 16,000 ft. Length 14,000 ft.
(Kind & Spec. No.) (Min. of range specified)
12. Seams: Long SMLS H.T. NO R.T. NONE Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)
Girth _____ H.T. _____ R.T. _____ No. of Courses 1
13. Headers (a) Material F.Q. 5TL SA385-C T.S. 55,000 (b) Material _____ T.S. _____ (c) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Convex or Concave)
(a) Top, bottom, ends 1.250 _____ _____ _____ 19.500 FLAT
(b) Channel _____
(c) Floating _____
If removable, bolts used (a) ALLOY 6TL SA193 B7 1.250 5/8-16 (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)
Drop weight _____ Pneumatic _____
Charpy Impact _____ ft-lb Hydrostatic or Test Pressure 225 psi
14. Design pressure 150 psi at 300 °F at temp. of _____ °F. Combination _____

¹ If Postweld Heat-Treated
² List other internal or external pressures with coincident temperature when applicable.

Power Code 97-1-125
Attachment: C
Rev: A Page 6 of 7

NB# 29388

FORM N-1 (back)

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
SHELL IN & OUT	2	10"-150# ASA PIPE	FG	SA 106 B	.307	---	WELDED
TUBE IN & OUT	2	8"-150# ASA PIPE	FG	SA 106 B	.277	---	WELDED

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt NO Lugs _____ Legs _____ Other CRADLES Attached WELDED TO SHELL
(Yes or No) (Number) (Number) (Describe) (Where & How)

19. Remarks: JACKET WATER COOLER

(Brief description of service for which vessel was designed)

CERTIFICATION OF DESIGN

Design information on file AMERICAN STD. HEAT TRANS. DIV. BUFFALO N.Y.
 Stress analysis report on file NOT APPLICABLE TO SECTION III CLASS 3 VESSEL C
 Design specifications certified by R. J. MAZZA Prof. Eng. State ILL Reg. No. 62-21850
 Stress analysis report certified by NOT APPLICABLE Prof. Eng. State _____ Reg. No. _____

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.
 Date 2/26/76 Signed TRANSFER DIVISION By R. R. Warner
 (Manufacturer) K. R. Warner - Manager, Q.C.
 Certificate of authorization Expires August 4, 1978 Certificate of Authorization No. 1164

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMERICAN STANDARD HEAT TRANSFER DIVISION at Buffalo, New York
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of New York and employed by Lumbermens Mutual Casualty Co. Chicago, Illinois
 have inspected the pressure vessel described in this Manufacturer's Data Report on February 26 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 My signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date February 26 1976
J. A. Thomas Inspector's Signature Commission NB 7710
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of _____ and employed by _____
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of _____ psi.
 My signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ 19_____
 Inspector's Signature _____ Commission _____
 National Board, State, Province and No. _____