



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 24, 2013

LICENSEE: Exelon Generation Company, LLC

FACILITY: LaSalle County Station, Units 1 and 2

SUBJECT: SUMMARY OF MAY 1, 2013, PUBLIC MEETING WITH EXELON GENERATION COMPANY, LLC REGARDING THE PROPOSED EXTENDED POWER UPRATE LICENSE AMENDMENT REQUEST FOR LASALLE COUNTY STATION, UNITS 1 AND 2 (TAC NOS. ME9903 AND ME9904)

On May 1, 2012, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Exelon Generation Company, LLC (EGC, the licensee), at the NRC Headquarters, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss a planned Extended Power Uprate (EPU) licensee amendment requested (LAR) for LaSalle County Station (LaSalle), Units 1 and 2. A list of attendees is provided as Enclosure 1.

During the meeting, EGC discussed with the NRC staff their plan to submit an EPU LAR, requesting a 12.5 percent increase in licensed thermal power for LaSalle. The targeted submittal date was May 2013. The meeting discussion focused on licensee plans to defer implementation of the EPU following NRC approval. The planned dates for EPU implementation are 2019 and 2020, for Unit 2 and Unit 1, respectively.

The licensee discussed how they would maintain control of the facility licensing and design bases and meet other regulatory requirements in the interim period between approval and implementation. Enclosure 2, Slide 8, discussed planned configuration control enhancements associated with future revisions of the updated final safety analysis report.

During the meeting, the NRC staff advised the licensee that given current agency priorities for completing Fukushima lessons-learned activities and given the planned implementation dates, consistent with SECY-11-0137, "Prioritization of Recommended Actions to be Taken in Response to Fukushima Lessons Learned," the LaSalle EPU review may be delayed for several months.

Subsequently on June 11, 2013, EGC announced the cancellation of the project due to economic considerations. Accordingly, the staff has closed Task Assignment Control (TAC) Nos. ME9903 AND ME9904 which supported pre-application activities.

No regulatory decisions were made during this meeting.

The meeting notice and agenda are available under Agencywide Documents Access and Management System (ADAMS) Accession No. ML13097A002.

The public was invited to observe the meeting and several members of the public were in attendance. Two Public Meeting Feedback forms were received and reviewed by the staff. Please direct any inquiries to me at 301-415-1115, or Nicholas.DiFrancesco@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Nicholas DiFrancesco", with a long horizontal flourish extending to the right.

Nicholas DiFrancesco, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosures:

1. List of Attendees
2. Licensee Handouts
3. Handout of Draft LaSalle Operating License and Technical Specification Changes

cc w/encl: Distribution via ListServ

LIST OF ATTENDEES

May 1, 2013, PUBLIC MEETING WITH EXELON GENERATION COMPANY, LLC

REGARDING LASALLE EXTENDED POWER UPRATE PRESUMBITAL MEETING

Name	Organization
John Monninger	NRC/NRR/DORL ₁
Jeremy Bowen	NRC/NRR/DORL/LPL 3-2 ₁
Dennis Morey	NRC/NRR/DLR/ RPB1 ₂
Nick DiFrancesco	NRC/NRR/DORL/LPL 3-2
John Bozga	NRC/R-III/ DRS/EB1 ₃ [#]
Blake Purnell	NRC/NRR/DORL/LPL 3-2
John Jandovitz	NRC/R-III/ DRP/BR5 ₄ [#]
Kevin Borton	Exelon Nuclear – Power Uprate
John Rommel	Exelon Nuclear – Power Uprate
Vikram Shah	Exelon Nuclear – Power Uprate
Leslie Holden	Exelon Nuclear – Power Uprate
William Hilton	Exelon Nuclear – LaSalle Station
Guy Ford	Exelon Nuclear – LaSalle Station
James Spieler	Exelon Nuclear – LaSalle Station
Christopher Wilson	Exelon Nuclear – License Renewal
Lisa Simpson	Exelon Nuclear – Corp Licensing [#]
Ken Anger	Exelon Nuclear – Power Uprate
TJ Kim	Nuclear Energy Institute [#]
Gail Snyder	Nuclear Energy Information Service [#]
Carol Kurz	Nuclear Energy Information Service [#]
Brittany Theis	Whitt Law LLC [#]
Bruce Hagemeier	GE Hitachi Nuclear Energy [#]
Linda Lewison	Energy Policy Consultant [#]

1. DORL - Division of Operating Reactor Licensing / LPL 3-2 – Licensing Plant
 2. DLR – Division of License Renewal / RPB1 – Renewal Projects Branch 1
 3. R-III – Region III / DRS – Division of Reactor Safety / EB1 – Engineering Branch 1
 4. R-III – Region III / DRP – Division of Reactor Projects / B5 –Branch 5
- #. Via Teleconference Bridgeline

Enclosure

LaSalle County Generating Station

Extended Power Uprate Implementation

NRC Meeting – May 1, 2013



Exelon Generation[®]

Meeting Purpose and Agenda

- ✓ **Overview and Purpose**
- ✓ **Definitions**
- ✓ **OL and TS Control**
- ✓ **Configuration Control**
 - **Design**
 - **UFSAR**
 - **10 CFR 50.59**
- ✓ **NRC Inspection Activities**

Overview and Meeting Purpose

✓ **LaSalle LAR Licensing Strategy**

- Physical implementation of EPU will occur approximately four years following NRC approval:
 - EPU License Amendment Request (LAR) submittal May 2013
 - NRC requested to approve EPU LAR by February 2015
 - Implement EPU following completion of refueling outages at each unit
 - Unit 2 (L2R17) in February 2019
 - Unit 1 (L1R18) in February 2020
- Advantages
 - Provides flexibility to implement sooner if economic conditions change
 - Avoids significant overlap of License Renewal LAR review (Submittal 2015)
 - Assures continuity of project knowledge and contracts
 - Leverages Peach Bottom EPU Review synergies

✓ **Meeting Purpose**

- Describe the Exelon processes that assure proper licensing and design controls between LAR approval and plant implementation

Definitions

Current Licensed Thermal Power (CLTP) – 3546 MWt

EPU Maximum Power Level – 3988 MWt

Current Licensing Basis (CLB) – Consistent with 10 CFR 54.3 and 10 CFR 50.2

The CLB is the set of NRC requirements applicable to LaSalle Units 1 and 2

- Exelon's written commitments
- The plant specific design basis docketed and in effect
- The plant specific design bases information as documented in the updated FSAR

EPU Licensing Basis – The licensing basis and design bases following NRC approval

- **Pre-Implementation** – The licensing and design basis of U1 and U2 after receipt of NRC approval of the EPU LAR, but prior to implementation
- **Post-Implementation** – The licensing and design basis of U1 and U2 following implementation where all EPU license conditions and restrictions of the EPU OL amendments are met

Operating License (OL) and Technical Specifications (TS) Control

- ✓ Following NRC approval, both U1 and U2 OL pages will be revised to reflect the approved amendment and will contain any EPU license conditions
- ✓ Upon approval three versions of TS pages will be issued – The versions will be incorporated as they apply as follows:
 - **Following NRC Approval and Pre-Implementation on both units**
The TS will reflect the CLB but an annotation will be made on each EPU-affected TS stating that it is the “Prior to EPU Implementation” version of that TS, and the bottom of each affected page will indicate the EPU amendment number
 - **Post-Implementation on U2 following the 2019 outage**
Each EPU-affected TS will have a separate TS page for each unit. The U1 TS will have an annotation stating that it is “Prior to EPU Implementation” version and the U2 TS will have an annotation stating that it is the “Following EPU Implementation” version
 - **Post-Implementation on both units**
The EPU-affected TS for U1 and U2 will be combined again with the EPU values

Operating License (OL) and Technical Specifications (TS) Control

✓ Technical Specifications Page Controls

– EPU LAR

- EPU implementation schedule described in cover letter
- Provide the final version Mark-Up of TS pages with LAR
- NRC issues the OL and three versions of TS pages with the EPU amendment number on each page
- The revised OL and “Prior to EPU Implementation” TS pages will be implemented within 45-60 days after receiving NRC approval

– Subsequent LARs

- If subsequent change TS markups include EPU affected pages - all three versions of EPU pages will be marked-up and submitted

Operating License (OL) and Technical Specifications (TS) Control

✓ Advantages

- The CLB and EPU Licensing Basis are readily apparent in OL and TS
- No impact to TS page document control process
- Aligns with ITS Writer's Guide
- It will be clear to Operators which TS applies as phased EPU is implemented on each Unit
- Minimum additional Operator training required

Engineering Configuration Control Process Description

- ✓ Configuration control is maintained in accordance within existing processes with enhancements added for EPU
 - EPU Task Reports are treated as design basis calculations and included in the pending change process,
 - Pending change Impact Reviews are performed,
 - A Power Uprate “Responsible Engineer” will be designated to manage and assess configuration changes against the EPU related changes, and
 - Exelon will perform an annual self-assessment to ensure there are no gaps regarding station-proposed changes and EPU related changes
 - Configuration changes for the previous year will be reviewed to determine if EPU was properly considered for each change
 - If discrepancies are identified they will be entered into and addressed by the Corrective Action Program

UFSAR Control Process Description

- ✓ UFSAR sections requiring change as a result of EPU will be identified and posted against the UFSAR Change Log
- ✓ Additional configuration control enhancements following NRC approval and prior to EPU Implementation changes:
 - The UFSAR will be updated to reflect that EPU has been approved, and sections of the UFSAR that have pending EPU changes will be identified
 - A Power Uprate Responsible Engineer will be designated to manage and assess UFSAR changes for their impact on the EPU Licensing Basis
 - The EPU annotated UFSAR sections will identify to future reviewers that there are EPU changes pending implementation to ensure that EPU changes are considered
- ✓ The UFSAR will be updated to reflect EPU modifications and analyses after they are implemented

Example – Configuration, UFSAR and 50.59 Controls

In 2017 LaSalle decides to modify main steam piping to resolve plant dose issue (Mod A):

- Mod A Responsible Engineer (RE) reviews pending changes (electronic system) for potential impacted design basis documents (e.g., MS calculations and UFSAR sections)
- Mod A identifies that MS piping will be changed as part of EPU (added SRVs) and that EPU calculations/UFSAR sections are pending
- Mod A RE works with the Power Uprate RE to determine if Mod A design impacts EPU calculations, UFSAR sections, or Technical Specifications as part of design development
 - Mod A RE ensures that an “Impact Review” of Mod A is performed by Power Uprate RE and documented as part of design change for Mod A
 - If Mod A impacts EPU design basis documents, calculations, or UFSAR sections, then an action tracking item is issued to track Mod A inclusion in EPU implementation
 - If the Mod A 50.59 review indicates an impact to an EPU SE/TS/OL license condition and prior NRC approval is required then a License Amendment will be required before Mod A can be completed
- Mod A design change completed and impacts of EPU are understood and addressed
- During annual “Check-In” self-assessment, Power Uprate personnel verify that the impact of Mod A on EPU has been identified, properly documented, and captured as necessary in an UFSAR change/update as appropriate
- Prior to EPU-Implementation, EPU calculations/UFSAR sections updated to reflect Mod A as appropriate

NRC Inspections

- ✓ Coordination and scope of routine or special inspections do not differ from other modification or LAR implementation activities
- ✓ Following EPU LAR Approval
 - Inspections will be performed against the CLB as well as the impact of any subsequent Pre-EPU period changes to the EPU Licensing Basis
 - There is a clear understanding of the design and licensing basis, including pending EPU changes (similar to today's inspections)
- ✓ EPU Implementation
 - Implementation plan will allow NRC to coordinate inspection of any implementation activities
- ✓ Post-EPU Implementation
 - Once implemented, routine inspections will include the EPU Licensing Basis

Conclusions

- ✓ Licensing Strategy Allows Flexibility
- ✓ Operating License, TS, and UFSAR Reflect Pending Changes
- ✓ Configuration Control is Enhanced Within Existing Processes
- ✓ No Change to Existing NRC Inspection Activities

Handout

DRAFT LaSalle OL and TS Changes

Following NRC Approval

Am. 146
01/12/01 (4) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and

Am. 146
01/12/01 (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

~~Am. 198~~
~~09/16/10~~ (1) Maximum Power Level
The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (~~3988~~ megawatts thermal).

~~Am. 199~~
~~01/28/11~~ (2) Technical Specifications and Environmental Protection Plan
The Technical Specifications contained in Appendix A, as revised through Amendment No. ~~499~~, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

Am. 194
08/28/09 (3) DELETED

Am. 194
08/28/09 (4) DELETED

Am. 194
08/28/09 (5) DELETED

Am. 194
08/28/09 (6) DELETED

Am. 194
08/28/09 (7) DELETED

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation (Prior to EPU Implementation per License Condition 2.C(X))

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: Prior to Extended Power Uprate (EPU) implementation, according to Table 3.3.1.1-1.

ACTIONS

----- NOTES -----

1. Separate condition entry is allowed for each channel.
 2. When Functions 2.b and 2.c channels are inoperable due to the APRM indication not within limits, entry into associated Conditions and Required Actions may be delayed for up to 2 hours if the APRM is indicating a lower power value than the calculated power, and for up to 12 hours if the APRM is indicating a higher power value than the calculated power.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	<u>OR</u> A.2 Place associated trip system in trip.	12 hours
B. One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	<u>OR</u> B.2 Place one trip system in trip.	6 hours

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 25% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.2 -----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP. ----- verify the absolute difference between the average power range monitor (APRM) channels and the calculated power \leq 2% RTP while operating at \geq 25% RTP.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.3 Adjust the channel to conform to a calibrated flow signal.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.4	<p>-----NOTE----- Not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. -----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.5	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.6	Verify the source range monitor (SRM) and intermediate range monitor (IRM) channels overlap.	Prior to fully withdrawing SRMs
SR 3.3.1.1.7	<p>-----NOTE----- Only required to be met during entry into MODE 2 from MODE 1. -----</p> <p>Verify the IRM and APRM channels overlap.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.8	Calibrate the local power range monitors.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.9 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.10 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.11 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.12 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.13 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.14 Verify the APRM Flow Biased Simulated Thermal Power-Upscale time constant is ≤ 7 seconds.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.15 Perform LOGIC SYSTEM FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.16 Verify Turbine Stop Valve-Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure-Low Functions are not bypassed when THERMAL POWER is $\geq 25\%$ RTP.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.17 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 9, the RPS RESPONSE TIME is measured from start of turbine control valve fast closure. ----- verify the RPS RESPONSE TIME is within limits.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation
(Prior to EPU Implementation per License Condition 2.c(x))

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux-High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux-High, Setdown	2	2	G	SR 3.3.1.1.1	≤ 20% RTP
				SR 3.3.1.1.4	
				SR 3.3.1.1.7	
				SR 3.3.1.1.8	
				SR 3.3.1.1.11 SR 3.3.1.1.15	
b. Flow Biased Simulated Thermal Power-upscale	1	2	F	SR 3.3.1.1.1	≤ 0.61 W + 68.2% RTP and ≤ 115.5% RTP ^(d)
				SR 3.3.1.1.2	
				SR 3.3.1.1.3	
				SR 3.3.1.1.8	
				SR 3.3.1.1.9	
				SR 3.3.1.1.11 ^{(b) (c)} SR 3.3.1.1.14 SR 3.3.1.1.15	
c. Fixed Neutron Flux-High	1	2	F	SR 3.3.1.1.1	≤ 120% RTP
				SR 3.3.1.1.2	
				SR 3.3.1.1.8	
				SR 3.3.1.1.9	
				SR 3.3.1.1.11 SR 3.3.1.1.15 SR 3.3.1.1.17	

(continued)

- (a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) If the as-found channel setpoint is outside its predefined as-found tolerance, then the channel shall be evaluated to verify that it is functioning as required before returning the channel to service.
- (c) The instrument channel setpoint shall be reset to a value that is within the as-left tolerance around the nominal trip setpoint (NTSP) at the completion of the surveillance; otherwise, the channel shall be declared inoperable. Setpoints more conservative than the NTSP are acceptable provided that the as-found and as-left tolerances apply to the actual setpoint implemented in the surveillance procedures (field setting) to confirm channel performance. The NTSP and the methodologies used to determine the as-found and the as-left tolerances are specified in the Technical Requirements Manual.
- (d) Allowable Value is ≤ 0.54 W + 55.9% RTP and ≤ 112.3% RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
d. Inop	1,2	2	G	SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.15	NA
3. Reactor Vessel Steam Dome Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1059.0 psig
4. Reactor Vessel Water Level-Low, Level 3	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≥ 11.0 inches
5. Main Steam Isolation Valve-Closure	1	8	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 13.7% closed
6. Drywell Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 1.93 psig
7. Scram Discharge Volume Water Level-High					
a. Transmitter/Trip Unit	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation

(continued)

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level-High (continued)					
b. Float Switch	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
8. Turbine Stop Valve-Closure	≥ 25% RTP	4	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ 8.9% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure-Low	≥ 25% RTP	2	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ 425.5 psig
10. Reactor Mode Switch-Shutdown Position	1,2	2	G	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	2	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

Handout

DRAFT LaSalle TS Changes

Following Unit 2 Implementation

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation (Unit 1 Only Prior to EPU Implementation per License Condition 2.C(X))

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: Prior to Extended Power Uprate (EPU) implementation, according to Table 3.3.1.1-1.

ACTIONS

----- NOTES -----

1. Separate Condition entry is allowed for each channel.
 2. When Functions 2.b and 2.c channels are inoperable due to the APRM indication not within limits, entry into associated Conditions and Required Actions may be delayed for up to 2 hours if the APRM is indicating a lower power value than the calculated power, and for up to 12 hours if the APRM is indicating a higher power value than the calculated power.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	<u>OR</u> A.2 Place associated trip system in trip.	12 hours
B. One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	<u>OR</u> B.2 Place one trip system in trip.	6 hours

(continued)

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation (Unit 2 Only -
Following EPU Implementation per License Condition 2.C (X))

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: Following Extended Power Uprate (EPU) implementation, according to Table 3.3.1.1-1.

ACTIONS

----- NOTES -----

1. Separate Condition entry is allowed for each channel.
 2. When Functions 2.b and 2.c channels are inoperable due to the APRM indication not within limits, entry into associated Conditions and Required Actions may be delayed for up to 2 hours if the APRM is indicating a lower power value than the calculated power, and for up to 12 hours if the APRM is indicating a higher power value than the calculated power.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	<u>OR</u> A.2 Place associated trip system in trip.	12 hours
B. One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	<u>OR</u> B.2 Place one trip system in trip.	6 hours

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 25% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 23% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.2 -----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP. ----- Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power \leq 2% RTP while operating at \geq 25% RTP.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.3 Adjust the channel to conform to a calibrated flow signal.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
2. When a channel is placed in an inoperable status solely for performance of required surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.2 -----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 23% RTP. ----- Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power \leq 2% RTP while operating at \geq 23% RTP.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.3 Adjust the channel to conform to a calibrated flow signal.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.4 -----NOTE----- Not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.5 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.6 Verify the source range monitor (SRM) and intermediate range monitor (IRM) channels overlap.	Prior to fully withdrawing SRMS
SR 3.3.1.1.7 -----NOTE----- Only required to be met during entry into MODE 2 from MODE 1. ----- Verify the IRM and APRM channels overlap.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.8 Calibrate the local power range monitors.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.9 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.10 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.11 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.12 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.13 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.14 Verify the APRM Flow Biased Simulated Thermal Power-Upscale time constant is ≤ 7 seconds.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.15 Perform LOGIC SYSTEM FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.16 Verify Turbine Stop Valve-Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure-Low Functions are not bypassed when THERMAL POWER is $\geq 25\%$ RTP.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.13 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.14 Verify the APRM Flow Biased Simulated Thermal Power-Upscale time constant is ≤ 7 seconds.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.15 Perform LOGIC SYSTEM FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.16 Verify Turbine Stop Valve-Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure-Low Functions are not bypassed when THERMAL POWER is $\geq 23\%$ RTP.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.17 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 9, the RPS RESPONSE TIME is measured from start of turbine control valve fast closure. ----- Verify the RPS RESPONSE TIME is within limits.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation
(Unit 1 Only Prior to EPU Implementation per License Condition 2.C(X))

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux-High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux-High, Setdown	2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 20% RTP
				SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 ^(b) (c) SR 3.3.1.1.14 SR 3.3.1.1.15	≤ 0.61 W + 68.2% RTP and ≤ 115.5% RTP ^(d)
b. Flow Biased Simulated Thermal Power-Upscale	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 ^(b) (c) SR 3.3.1.1.14 SR 3.3.1.1.15	≤ 0.61 W + 68.2% RTP and ≤ 115.5% RTP ^(d)
				SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 120% RTP
c. Fixed Neutron Flux-High	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 120% RTP

(continued)

- (a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.
 (b) If the as-found channel setpoint is outside its predefined as-found tolerance, then the channel shall be evaluated to verify that it is functioning as required before returning the channel to service.
 (c) The instrument channel setpoint shall be reset to a value that is within the as-left tolerance around the nominal trip setpoint (NTSP) at the completion of the surveillance; otherwise, the channel shall be declared inoperable. Setpoints more conservative than the NTSP are acceptable provided that the as-found and as-left tolerances apply to the actual setpoint implemented in the surveillance procedures (field setting) to confirm channel performance. The NTSP and the methodologies used to determine the as-found and the as-left tolerances are specified in the Technical Requirements Manual.
 (d) Allowable value is ≤ 0.54 W + 55.9% RTP and ≤ 112.3% RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation
Unit 2 Only, Following EPU Implementation per License Condition 2.C(X)

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux-High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux-High, Setdown	2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 22.6% RTP
	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 ^{(b) (c)} SR 3.3.1.1.14 SR 3.3.1.1.15	≤ 0.55 W + 63.5% RTP and ≤ 118.0% RTP ^(d)
c. Fixed Neutron Flux-High	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 120% RTP

(continued)

- (a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) If the as-found channel setpoint is outside its predefined as-found tolerance, then the channel shall be evaluated to verify that it is functioning as required before returning the channel to service.
- (c) The instrument channel setpoint shall be reset to a value that is within the as-left tolerance around the nominal trip setpoint (NTSP) at the completion of the surveillance; otherwise, the channel shall be declared inoperable. Setpoints more conservative than the NTSP are acceptable provided that the as-found and as-left tolerances apply to the actual setpoint implemented in the surveillance procedures (field setting) to confirm channel performance. The NTSP and the methodologies used to determine the as-found and the as-left tolerances are specified in the Technical Requirements Manual.
- (d) Allowable value is ≤ 0.48 W + 49.6% RTP and ≤ 112.3% RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
d. Inop	1,2	2	G	SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.15	NA
3. Reactor Vessel Steam Dome Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1059.0 psig
4. Reactor Vessel Water Level-Low, Level 3	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≥ 11.0 inches
5. Main Steam Isolation Valve-Closure	1	8	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 13.7% closed
6. Drywell Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 1.93 psig
7. Scram Discharge Volume Water Level-High					
a. Transmitter/Trip Unit	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation

(continued)

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level-High (continued)					
b. Float Switch	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
8. Turbine Stop Valve-Closure	≥ 25% RTP	4	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ 8.9% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure-Low	≥ 25% RTP	2	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ 425.5 psig
10. Reactor Mode Switch-Shutdown Position	1,2	2	G	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	2	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

Handout

DRAFT LaSalle TS Changes

Final - Following U1 and U2 Implementation

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.1-1.

ACTIONS

NOTES

1. Separate Condition entry is allowed for each channel.
2. When Functions 2.b and 2.c channels are inoperable due to the APRM indication not within limits, entry into associated Conditions and Required Actions may be delayed for up to 2 hours if the APRM is indicating a lower power value than the calculated power, and for up to 12 hours if the APRM is indicating a higher power value than the calculated power.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	<u>OR</u> A.2 Place associated trip system in trip.	12 hours
B. One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	<u>OR</u> B.2 Place one trip system in trip.	6 hours

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 23% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTES -----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
 2. When a channel is placed in an inoperable status solely for performance of required surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.2	-----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 23% RTP. Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power \leq 2% RTP while operating at \geq 23% RTP.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.3	Adjust the channel to conform to a calibrated flow signal.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.4 -----NOTE----- Not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.5 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.6 Verify the source range monitor (SRM) and intermediate range monitor (IRM) channels overlap.	Prior to fully withdrawing SRMs
SR 3.3.1.1.7 -----NOTE----- Only required to be met during entry into MODE 2 from MODE 1. ----- Verify the IRM and APRM channels overlap.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.8 Calibrate the local power range monitors.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.9 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.10 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.11 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.12 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.13 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 24 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.14 Verify the APRM Flow Biased Simulated Thermal Power-Upscale time constant is ≤ 7 seconds.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.15 Perform LOGIC SYSTEM FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.1.16 Verify Turbine Stop Valve-Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure-Low Functions are not bypassed when THERMAL POWER is $\geq 23\%$ RTP.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.1.17 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Function 9, the RPS RESPONSE TIME is measured from start of turbine control valve fast closure. <p>-----</p> <p>Verify the RPS RESPONSE TIME is within limits.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux-High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 123/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux-High, Setdown	2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 22.6% RTP
b. Flow Biased Simulated Thermal Power-Upscale	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 ^(b) ^(c) SR 3.3.1.1.14 SR 3.3.1.1.15	≤ 0.55 W + 63.5% RTP and ≤ 118.0% RTP ^(d)
c. Fixed Neutron Flux-High	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 120% RTP

(continued)

- (a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) If the as-found channel setpoint is outside its predefined as-found tolerance, then the channel shall be evaluated to verify that it is functioning as required before returning the channel to service.
- (c) The instrument channel setpoint shall be reset to a value that is within the as-left tolerance around the nominal trip setpoint (NTSP) at the completion of the surveillance; otherwise, the channel shall be declared inoperable. Setpoints more conservative than the NTSP are acceptable provided that the as-found and as-left tolerances apply to the actual setpoint implemented in the surveillance procedures (field setting) to confirm channel performance. The NTSP and the methodologies used to determine the as-found and the as-left tolerances are specified in the Technical Requirements Manual.
- (d) Allowable Value is ≤ 0.48 W + 49.6% RTP and ≤ 112.3% RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
d. Inop	1,2	2	G	SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.15	NA
3. Reactor Vessel Steam Dome Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1059.0 psig
4. Reactor Vessel Water Level-Low, Level 3	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≥ 11.0 inches
5. Main Steam Isolation Valve-Closure	1	8	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 13.7% closed
6. Drywell Pressure-High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 1.93 psig
7. Scram Discharge Volume Water Level-High					
a. Transmitter/Trip Unit	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation

(continued)

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level-High (continued)					
b. Float Switch	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 767 ft 8.55 inches elevation
8. Turbine Stop Valve-Closure	≥ 23% RTP	4	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ 8.9% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure-Low	≥ 23% RTP	2	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ 425.5 psig
10. Reactor Mode Switch-Shutdown Position	1,2	2	G	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	2	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) with any control rod withdrawn from a core cell containing one or more fuel assemblies.

The meeting notice and agenda are available under Agencywide Documents Access and Management System (ADAMS) Accession No. ML13097A002.

The public was invited to observe the meeting and several members of the public were in attendance. Two Public Meeting Feedback forms were received and reviewed by the staff. Please direct any inquiries to me at 301-415-1115, or Nicholas.DiFrancesco@nrc.gov.

Sincerely,

/ RA /

Nicholas DiFrancesco, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosures:

1. List of Attendees
2. Licensee Handouts
3. Handout of Draft LaSalle Operating License and Technical Specification Changes

cc w/encl: Distribution via ListServ

DISTRIBUTION:

PUBLIC RidsNrrDorLpl3-2 Resource RidsRgn3MailCenter Resource
LPL3-2 R/F RidsNrrPMLasalle Resource John Bozga RIII
RidsNrrAdro Resource RidsOgcMailCenter Resource
RidsNrrDorl Resource RidsOpaMail Resource
EDO Doug Huyck

Accession Number: ML13164A379

OFFICE	DORL/LPL3-2 PM	DORL/LPL3-2/LA	DORL/LPL3-2/BC	DORL/LPL3-2/PM
NAME	NDiFrancesco	SRohrer	JBowen	NDiFrancesco
DATE	6/19/13	6/17/13	6/20/13	6/24/13

OFFICIAL RECORD COPY