

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

JPM A.1-1

RO

Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam

DATA SHEET

Task: Calculate RHT and BAT Addition to the FWST

Alternate Path: N/A

Facility JPM #: New

Safety Function: N/A

K/A G2.1.20 Ability to interpret and execute procedure steps.

Importance: 4.6 / 4.6 **CFR:** 41.10 / 43.5 / 45.12

Preferred Evaluation Location:

Preferred Evaluation Method:

Simulator _____ Classroom Perform Simulate _____

References: OP/2/A/6200/014 (Refueling Water System) revision 077

Task Standard: Applicant determines:
1) RHT volume added = 5153 gallons (5150 – 5262)
2) BAT volume added = 2747 gallons (2738 – 2750)

Validation Time: 15 minutes **Time Critical:** Yes _____ No

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____
SAT _____ UNSAT _____

Examiner: _____ / _____
NAME SIGNATURE DATE

COMMENTS

**Catawba Nuclear Station
RO A.1-1
Sep. 2013 NRC Exam**

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Unit 2 is in Mode 5
- FWST 1% = 3,950 gals
- BAT = 7500 ppmB
- RHT = 1038 ppmB
- FWST is currently 97% at 2790 ppmB

INITIATING CUES:

The CRS has directed you to determine the amount of BAT addition and RHT addition necessary to raise FWST level to 99% and 2800 ppmB per OP/2/A/6200/014 (Refueling Water System), Enclosure 4.9 (FWST Makeup From RHT) steps 3.5 and 3.6.

CV has been waived for this JPM.

Amount of BAT addition - _____ gallons

Amount of RHT addition - _____ gallons

EXAMINER NOTE: Provide the applicant a copy of OP/2/A/6200/014 Enclosure 4.9 completed through step 3.4.

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
-----------------	-------------

START TIME: _____

<p>3.5 Determine the required boron concentration ($C_{m/u}$) of the makeup to raise the FWST to the desired level as follows:</p> <p>NOTE: Final FWST level and boron concentration shall comply with COLR requirements.</p> <p><u>STEP 1:</u> 3.5.1 Record the following:</p> <ul style="list-style-type: none"> <input type="checkbox"/> desired final FWST boron concentration (C_{FWST}) _____ ppm <input type="checkbox"/> desired final FWST volume (V_{FWST}) _____ gallons <input type="checkbox"/> initial FWST boron concentration (C_i) _____ ppm <input type="checkbox"/> initial FWST volume (V_i) _____ gallons <input type="checkbox"/> makeup volume ($V_{m/u}$) = (V_{FWST}) - (V_i) = () - () = _____ gallons <p><u>STANDARD:</u></p> <div style="background-color: #f0f0f0; padding: 5px; margin: 10px 0;"> <p>Applicant determines :</p> <p>C_{FWST} = <u>2800</u> ppm (from initiating cue)</p> <p>V_{FWST} = <u>391,050</u> gallons (calculated from init cue and init conditions)</p> <p>C_i = <u>2790</u> ppm (from initial conditions)</p> <p>V_i = <u>383,150</u> gallons (calculated from initial conditions)</p> <p>$V_{m/u}$ = <u>7900</u> gallons</p> </div> <p><u>EXAMINER NOTE:</u> The applicant may decide to round down the volumes of the FWST, in which case V_{FWST} = <u>391,000</u> gallons, V_i = <u>383,000</u> gallons, and $V_{m/u}$ = <u>8000</u> gallons.</p> <p>This step is critical to calculate total makeup volume.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
---	---

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>STEP 2: 3.5.2 Calculate $C_{m/u}$ as follows:</p> $C_{m/u} = \frac{C_{FWST}V_{FWST} - C_i V_i}{V_{m/u}}$ $C_{m/u} = \frac{(\quad)(\quad) - (\quad)(\quad)}{(\quad)}$ $C_{m/u} = \underline{\hspace{2cm}} \text{ ppm}$ <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 5px;">Applicant calculates $C_{m/u}$ to be <u>3285</u> ppm.</p> <p>EXAMINER NOTE: If the applicant used rounding for the FWST volume in the previous step, then $C_{m/u}$ will be <u>3278</u> ppm.</p> <p>This step is critical to calculate required ppm to raise FWST boron concentration to the desired value.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>3.6 Determine the amount of boric acid ($V_{b/a}$) and RHT contents (V_{RHT}) that must be added to the FWST to achieve the desired final FWST concentration as follows:</p> <p><u>STEP 3:</u> 3.6.1 Record the following:</p> <ul style="list-style-type: none"> <input type="checkbox"/> makeup volume from Step 3.5.1 ($V_{m/u}$) _____ gallons <input type="checkbox"/> makeup boron concentration from Step 3.5.2 ($C_{m/u}$) _____ ppm <input type="checkbox"/> current RHT boron concentration (C_{RHT}) _____ ppm <input type="checkbox"/> current BAT boron concentration ($C_{b/a}$) _____ ppm <p><u>STANDARD:</u></p> <div style="background-color: #e0e0e0; padding: 5px;"> <p>Applicant records:</p> <p>$V_{m/u} = 7900$ gallons (from step 3.5.1) $C_{m/u} = 3285$ ppm (from step 3.5.2) $C_{RHT} = 1038$ ppm (from the initiating cues) $C_{b/a} = 7500$ ppm (from the initiating cues)</p> </div> <p><u>EXAMINER NOTE:</u> If the applicant used rounding in step 3.5.1, the $V_{m/u}$ will be <u>8000</u> gallons and $C_{m/u}$ will be <u>3278</u> ppm.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>STEP 4: 3.6.2 Calculate $V_{b/a}$ as follows:</p> $V_{b/a} = \frac{V_{m/u}(C_{m/u} - C_{RHT})}{C_{b/a} - C_{RHT}}$ $V_{b/a} = \frac{(\quad)(\quad - \quad)}{(\quad - \quad)}$ $V_{b/a} = \underline{\hspace{2cm}} \text{ gallons}$ <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 2px;">Applicant calculates $V_{b/a}$ to be <u>2,747</u> gallons.</p> <p>EXAMINER NOTE: If the applicant used rounding in step 3.5.1, then $V_{b/a}$ will be <u>2,773</u> gallons.</p> <p>EXAMINER NOTE: The applicant may decide to round up and record 2,750 gallons for conservatism.</p> <p>This step is critical to determine the amount of boric acid addition required to achieve the desired final boron concentration and level.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>STEP 5: 3.6.3 Calculate V_{RHT} as follows:</p> <p style="text-align: center;">$V_{RHT} = V_{m/u} - V_{b/a} = (\quad) - (\quad) = \underline{\hspace{2cm}}$ gallons</p> <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 5px;">Applicant calculates V_{RHT} to be 5,153 gallons.</p> <p>EXAMINER NOTE: If the applicant used rounding in step 3.5.1, then V_{RHT} will be <u>5,227</u> gallons.</p> <p>EXAMINER NOTE: If the applicant used rounding in step 3.6.2, then V_{RHT} will be <u>5,150</u> gallons.</p> <p>This step is critical to determine the amount of water addition from the RHT that will be required to achieve the desired final boron concentration and level.</p> <p>COMMENTS:</p> <p style="text-align: center;">END OF TASK</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Unit 2 is in Mode 5
- FWST 1% = 3,950 gals
- BAT = 7500 ppmB
- RHT = 1038 ppmB
- FWST is currently 97% at 2790 ppmB

INITIATING CUES:

The CRS has directed you to determine the amount of BAT addition and RHT addition necessary to raise FWST level to 99% and 2800 ppmB per OP/2/A/6200/014 (Refueling Water System), Enclosure 4.9 (FWST Makeup From RHT) steps 3.5 and 3.6.

CV has been waived for this JPM.

Amount of BAT addition - _____ gallons

Amount of RHT addition - _____ gallons

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

JPM A.1-2

RO / SRO

Catawba Nuclear Station

RO/SRO JPM A.1-2

Sep. 2013 NRC Exam

DATA SHEET

Task: Calculate Unit Vent flow manually per PT/1/A/4450/017 (Unit Vent Flow Manual Calculation).

Alternate Path: N/A

Facility JPM #: WG-002

Safety Function: N/A

K/A G2.1.23 Ability to perform specific system and integrated plant procedures during all modes of plant operation.

Importance: 4.3 / 4.4 **CFR:** 41.10 / 43.5 / 45.2 / 45.6

Preferred Evaluation Location:

Preferred Evaluation Method:

Simulator In-Plant Perform Simulate

References: PT/1/A/4450/017 (Unit Vent Flow Manual Calculation) Rev 013
SLC 16.11-7 (Radioactive Gaseous Effluent Monitoring Instrumentation)

Task Standard: Unit Vent flow is calculated to be 117450 scfm +/- 1000.

Validation Time: 15 minutes **Time Critical:** Yes No

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____

SAT UNSAT

Examiner: _____ / _____
NAME SIGNATURE DATE

=====

COMMENTS

Catawba Nuclear Station RO/SRO JPM A.1-2 Sep. 2013 NRC Exam

SIMULATOR OPERATOR INSTRUCTIONS:

1. ENSURE NRC Examination Security has been established.
2. Reset to IC #168
3. Enter the password.
4. Select "Yes" on the INITIAL CONDITION RESET pop-up window.
5. Ensure simulator setup per table below.
6. Place simulator in RUN and acknowledge any alarms.
7. ENSURE "Extra Operator" is present in the simulator.
8. Place simulator in FREEZE until Examiner cue is given.
9. May need a footstool for applicants to access and read VA system flow indicator.

✓	Instructor Action	Final	Delay	Ramp	Delete In	Event
	XMT-VA001 (FVA_5280 ABFXU-1 AIR FLOW MTR)	56000				
	XMT-VA002 (FVF_5310 OUTLET AIRFLOW TRN A MTR)	0				
Place OOS sticker on 1VFP5310 (VF OTLT AIR FLOW TRN A)						

Catawba Nuclear Station

RO/SRO JPM A.1-2

Sep. 2013 NRC Exam

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Both Units are at 100% power.
- No VQ release is in progress.
- No GWRs are in progress.
- The Waste Evaporator and Recycle Evaporator are secured.
- The Unit Vent Stack Flow Rate Meter is INOPERABLE.
- Auxiliary Building NLO has called the control room to report 1ABUXF Discharge Air Flow (1ABUX-AFMD-1) is reading 27000 scfm.

INITIATING CUES:

Calculate Unit Vent flow per PT/1/A/4450/017 (Unit Vent Flow Manual Calculation) Enclosure 13.1.

EXAMINER NOTE:

When applicant locates PT/1/A/4450/017, hand out a copy of the PT, Enclosure 13.1.

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
-----------------	-------------

START TIME: _____

<p><u>STEP 1:</u> Applicant locates and records VA (Auxiliary Building Ventilation) System flow.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant locates 1VAP5280 on 1MC-3 and records 56,000 scfm.</p> <p><u>EXAMINER NOTE:</u> May provide a picture of the control board gauge instead of locating in the simulator.</p> <p><u>EXAMINER NOTE:</u> Range of <u>55000 to 57000 scfm</u> is acceptable.</p> <p>This step is critical to obtain VA (Auxiliary Building Ventilation) flow required to complete the calculation.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
---	---

<p><u>STEP 2:</u> Applicant locates and records VE (Annulus Ventilation) 1A flow to stack.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant locates 1VEP5180, notes VE (Annulus Ventilation) train 1A is shutdown and records 0 scfm.</p> <p><u>EXAMINER NOTE:</u> May provide a picture of the control board gauge instead of locating in the simulator.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
--	---------------------------------

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 3:</u> Applicant locates and records VE (Annulus Ventilation) 1B flow to stack.</p> <p><u>STANDARD:</u></p> <p>Applicant locates 1VEP5200, notes VE (Annulus Ventilation) train 1B is shutdown and records 0 scfm.</p> <p><u>EXAMINER NOTE:</u> May provide a picture of the control board gauge instead of locating in the simulator.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4:</u> Applicant locates and records VF (Fuel Pool Ventilation) 1A flow to stack.</p> <p><u>STANDARD:</u></p> <p>Applicant locates 1VFP5310, notes VF (Fuel Pool Ventilation) reading is OOS and uses 33130 scfm from enclosure 13.2.</p> <p><u>EXAMINER NOTE:</u> May provide a picture of the control board gauge instead of locating in the simulator.</p> <p>This step is critical to ensure the correct value is included in the calculation.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 5:</u> Applicant locates and records VF (Fuel Pool Ventilation) 1B flow to stack.</p> <p><u>STANDARD:</u></p> <p>Applicant locates 1VFP5340, notes VF (Fuel Pool Ventilation) train 1B is shutdown and records 0 scfm.</p> <p><u>EXAMINER NOTE:</u> May provide a picture of the control board gauge instead of locating in the simulator.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 6:</u> Applicant records 1ABUX-AFMD-1 flow.</p> <p><u>STANDARD:</u></p> <p>Applicant records 27000 scfm based on initial cue.</p> <p>This step is critical to ensure the value is added to the calculation.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 7:</u> Applicant records VP (Containment Purge) flows.</p> <p><u>STANDARD:</u></p> <p>Based on initial cues VP (Containment Purge) is secured. Applicant records flow as 0 scfm or N/A.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 8:</u> Applicant records WG (Waste Gas) flow and VQ (Containment Air Release and Addition) flow.</p> <p><u>STANDARD:</u></p> <p>Based on initial cues, applicant records flow as 0 scfm or N/A</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 9:</u> Applicant records TL (Main Turbine Seals) flow</p> <p><u>STANDARD:</u></p> <p>Based on initial cue and procedure notes, applicant records 1260 scfm.</p> <p>This step is critical to ensure TL (Main Turbine Seals) flow is added to the calculation.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 10:</u> Applicant records NB (Reactor Makeup) and WL (Liquid Waste) flows.</p> <p><u>STANDARD:</u></p> <p>Based on initial cues, applicant records flow as 0 scfm or N/A.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 11:</u> Applicant records ZJ (Condensate Steam Air Ejectors) flow to stack.</p> <p><u>STANDARD:</u></p> <p>Based on initial cue and procedure notes, applicant records 60 scfm.</p> <p>This step is critical to ensure ZJ (Condensate Steam Air Ejectors) flow is added to the calculation.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 12:</u> Calculate total vent flow.</p> <p><u>STANDARD:</u></p> <p>Applicant calculates total vent flow to stack as 117450 scfm.</p> <p><u>EXAMINER NOTE:</u> Due to reading instruments, <u>116450 -118450 scfm</u> is considered acceptable.</p> <p>This step is critical to calculate total vent flow.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO/SRO JPM A.1-2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 13:</u> Complete the PT.</p> <p><u>STANDARD:</u></p> <p>Applicant records that acceptance criteria is met and signs off remaining procedure steps.</p> <p><u>EXAMINER NOTE:</u> Applicant may create a Discrepancy Sheet based on gauge VFP5310 having an OOS sticker on it. Although not required, it is not incorrect to submit one.</p> <p>This step is critical to verify that acceptance criteria is met.</p> <p><u>COMMENTS:</u></p> <p style="text-align: center;">END OF TASK</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Both Units are at 100% power.
- No VQ release is in progress.
- No GWRs are in progress.
- The Waste Evaporator and Recycle Evaporator are secured.
- The Unit Vent Stack Flow Rate Meter is INOPERABLE.
- Auxiliary Building NLO has called the control room to report 1ABUXF Discharge Air Flow (1ABUX-AFMD-1) is reading 27000 scfm.

INITIATING CUES:

Calculate Unit Vent flow per PT/1/A/4450/017 (Unit Vent Flow Manual Calculation) Enclosure 13.1.

**Catawba Nuclear Station
RO-SRO JPM A.2
Sep. 2013 NRC Exam**

JPM A.2

RO-SRO

**Catawba Nuclear Station
RO-SRO JPM A.2
Sep. 2013 NRC Exam**

DATA SHEET

Task: Classify a D/G Start and Complete a Logbook Entry

Alternate Path: N/A

Facility JPM #: DG3-010

Safety Function: N/A

K/A 2.2.12 Knowledge of surveillance procedures.

Importance: 3.7 / 4.1 **CFR:** 41.10 / 45.13

Preferred Evaluation Location:

Preferred Evaluation Method:

Simulator _____ Classroom X Perform X Simulate _____

References: OMP 2-28 (Diesel Generator Logbook) rev 026
PT/2/A/4350/002 B, (Diesel Generator 2B Operability Test), Rev. 101

Task Standard: Classify the D/G start as a VALID FAILURE and correctly enter data into the logbook.

Validation Time: 14 minutes **Time Critical:** Yes _____ No X

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____

SAT _____ UNSAT _____

Examiner: _____ / _____
NAME SIGNATURE DATE

COMMENTS

Catawba Nuclear Station

RO-SRO JPM A.2

Sep. 2013 NRC Exam

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Unit 2 is in Mode 1.
- You were an extra operator on shift and assisting the Operation Test Group in a scheduled surveillance test of the 2B Emergency Diesel Generator.
- The test was conducted using procedure PT/2/A/4350/002B (D/G Operability Test).
- Prior to completing the scheduled surveillance test, the 2B D/G tripped due to a malfunction of the low-low lube oil pressure switch at 0905.
- PT/2/A/4350/002B has been completed up to step 12.75 for completing Diesel Generator Logbook entries per OMP 2-28.

INITIATING CUES:

Using the information provided in Initial Conditions, classify the test and fill in all available Diesel Generator Logbook data on Attachments 10.1 and 10.2 of OMP 2-28 and submit to the CRS for review.

EXAMINER NOTE:

The applicant may ask for a name for the MCE Rotating Equipment Supervisor and a PIP # when completing the logbook entries. If necessary, this may be done in another room to prevent the possible compromise of the exam.

**Catawba Nuclear Station
RO-SRO JPM A.2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
------------------------	------------------------

START TIME: _____

<p><u>STEP 1:</u> Based on initial conditions, applicant refers to OMP Section 6 to determine the TEST CLASSIFICATION.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant determines that the test is a VALID FAILURE based on criteria 6.4.A.</p> <p><u>EXAMINER NOTE:</u> When student is ready to fill out the logbook provide a blank copy of Enclosure 10.1 and a filled out copy of Enclosure 10.2 as provided.</p> <p>This step is critical to determine the correct classification.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
---	---

Catawba Nuclear Station RO-SRO JPM A.2 Sep. 2013 NRC Exam

STEP / STANDARD	SAT / UNSAT
<p>STEP 2: Applicant enters appropriate information on Attachment 10.1 using information from the initial conditions.</p> <p>STANDARD:</p> <div style="background-color: #f0f0f0; padding: 10px; border: 1px solid #ccc;"> <ul style="list-style-type: none"> <input type="checkbox"/> Enters 2B D/G. <input type="checkbox"/> Enters their name. <input type="checkbox"/> Enters start attempt based on last entry on 8/2 (2013-8). <input type="checkbox"/> Enters today's date. <input type="checkbox"/> Marks PT/1(2)/4350/002A(B) as procedure used. <input type="checkbox"/> Marks SCHEDULED SURVEILLANCE as Reason for D/G Operation. <input type="checkbox"/> Enters TURBO PRELUBE for type of start. <input type="checkbox"/> Enters engine start time 0820. <input type="checkbox"/> Enters engine shutdown time 0905. <input type="checkbox"/> Enters run time as 0.75 hours. <input type="checkbox"/> Calculates total run time as 20.55 hours (19.8+0.75). <input type="checkbox"/> Enters classification (VALID FAILURE). <input type="checkbox"/> Enters reason D/G start was not a valid success: (2B D/G tripped on a malfunction of the LOLO Lube Oil Pressure switch prior to being loaded > 2875 KW for > 1 hour). <input type="checkbox"/> Marks MCE Rotating Equipment supervisor or designee. </div> <p>EXAMINER CUE: CRS will contact MCE Rotating Equipment supervisor.</p> <div style="background-color: #f0f0f0; padding: 5px; border: 1px solid #ccc; margin-top: 10px;"> <p>Marks PIP block since a PIP is required for this start.</p> </div> <p>EXAMINER CUE: PIP # C-13-0001</p> <p>The steps in bold are critical because all other entries are required regardless of the classification.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO-SRO JPM A.2
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 3:</u> Logs the start into the Index Sheet (Enclosure 10.2)</p> <p><u>STANDARD:</u></p> <div style="background-color: #e0e0e0; padding: 5px;"> <ul style="list-style-type: none"> <input type="checkbox"/> Enters Start # as 2013-8 or - 8. <input type="checkbox"/> Enters Date as today's date. <input type="checkbox"/> Enters Test Classification as "VALID FAILURE". <input type="checkbox"/> Enters run time as 0.75 hrs. <input type="checkbox"/> Enters yearly run time as 20.55 hrs. <input type="checkbox"/> Indicates PIP # will be written in space provided. </div> <p>The items in bold are critical based on OMP 2-28 section 3 criteria.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Unit 2 is in Mode 1.
- You were an extra operator on shift and assisting the Operation Test Group in a scheduled surveillance test of the 2B Emergency Diesel Generator.
- The test was conducted using procedure PT/2/A/4350/002B (D/G Operability Test).
- Prior to completing the scheduled surveillance test, the 2B D/G tripped due to a malfunction of the low-low lube oil pressure switch at 0905.
- PT/2/A/4350/002B has been completed up to step 12.75 for completing Diesel Generator Logbook entries per OMP 2-28.

INITIATING CUES:

Using the information provided in Initial Conditions, classify the test and fill in all available Diesel Generator Logbook data on Attachments 10.1 and 10.2 of OMP 2-28 and submit to the CRS for review.

**Catawba Nuclear Station
RO-SRO JPM A.3
Sep. 2013 NRC Exam**

JPM A.3

RO - SRO

Catawba Nuclear Station

RO-SRO JPM A.3

Sep. 2013 NRC Exam

DATA SHEET

Task: Calculate Low Pressure Service Water Discharge flow for a liquid radioactive release.

Alternate Path: N/A

Facility JPM #: 2010 NRC Initial License Exam SRO-D Admin.

Safety Function: N/A

K/A 2.3.11 Ability to control radiation releases

Importance: 3.8 / 4.3 **CFR:** 41.11 / 43.4 / 45.10

Preferred Evaluation Location:

Preferred Evaluation Method:

Simulator _____ Classroom Perform Simulate _____

References: PT/0/A/4250/011 (RL Temperature And Discharge Flow Determination) rev 050

Task Standard: Applicant obtains needed data, correctly calculates total discharge flow, and determines that the liquid waste release can NOT continue.

Validation Time: 15 minutes **Time Critical:** Yes _____ No

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____

SAT _____ UNSAT _____

Examiner: _____ / _____
NAME SIGNATURE DATE

COMMENTS

Catawba Nuclear Station

RO - SRO JPM A.3

Sep. 2013 NRC Exam

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

1. Unit 1 is currently performing a liquid waste release from the Monitor Tank Building.
2. Low Pressure Service Water (RL) Flow transmitter 0RLP5080 (RL Disch Flow) and OAC points C1P0903 and C2P0903 (RL Line A Disch Flow-Hourly Average) are INOPERABLE and have been removed from service.
3. The RN system is aligned to the RL discharge header.
4. PT/0/A/4250/011 (RL Temperature and Discharge Flow Determination) was last completed at 0700.
5. Current time is 1030.
6. Units 1 and 2 are both at 100% power.

INITIATING CUES:

You are directed to calculate the total RL discharge flow using Enclosure 13.2 (Total Discharge Flow Calculation Sheet) of PT/0/A/4250/011 and determine if adequate flow exists to continue the release per the LWR currently in progress. Record your answer in the spaces below.

Total RL Discharge Flow _____ GPM.

Adequate Flow Exists _____
Yes/No

EXAMINER NOTE:

After reading initiating cue, provide applicant with a copy of PT/0/A/4250/011 Enclosures 13.1 signed off up to step to perform Encl. 13.2, Enclosures 13.2 and 13.7, appropriate data sheet, and a copy of the LWR permit report.

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
-----------------	-------------

START TIME: _____

<p><u>STEP 1:</u> 1.1.2 Perform the following calculations to obtain Total Discharge Head:</p> <p style="margin-left: 40px;">RL Disch Pressure = ORLP5030 + 3.9 psi</p> <p style="margin-left: 40px;">RL Disch Pressure = <u>66</u> + 3.9 psi = <u>69.9</u> psig</p> <p style="margin-left: 40px;">Lake Elevation = <u>569</u> ORNP7380 (Lake Wylie Level) or obtained from hydro central per Step 1.1.4.2 of Enclosure 13.1.</p> <p style="margin-left: 40px;">(<u>69.9</u> psig x 2.311ft/psig) + (571.75 - <u>569</u> ft) = <u>164.3</u> ft RL Disch Pressure Lake Elev Total Disch Head</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0; padding: 2px; margin-left: 20px;">Applicant calculates RL Discharge pressure.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p>EXAMINER NOTE: Step 1.1.1 is N/A because ORLP5030 indicator IS available.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
---	---

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 2:</u> 1.1.3 Using Total Discharge Head from Step 1.1.2 obtain the RL Pump Flow value using <u>one</u> of the following:</p> <ul style="list-style-type: none"> <input type="checkbox"/> Enclosure 13.7 (RL Pumps Head / Capacity Table) <p style="text-align: center;">OR</p> <ul style="list-style-type: none"> <input type="checkbox"/> OAC Databook in "Secondary Systems Databook Calcs" using "RL Total Discharge Head vs. RL Pump Flow Rate". <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0; padding: 5px;">Applicant determines that RL Pump Flow per Enclosure 13.7 is 38,354 GPM.</p> <p><u>EXAMINER NOTE:</u> Range of 37,405 – 39,219 GPM is acceptable.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;">CRITICAL STEP</p> <p style="text-align: center;">___ SAT</p> <p style="text-align: center;">___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 3:</u> 1.1.4 Once RL Pump Flow value is obtained, calculate Total RL Supply based on number of RL pumps in operation:</p> $\frac{38354}{\text{RL Pump Flow}} \times \frac{1}{\# \text{ of pumps in op.}} = \frac{38354}{\text{Total RL Supply (A)}}$ <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant calculates Total RL Supply to be 38,354 GPM.</p> <p><u>EXAMINER NOTE:</u> Range carried forward is 37,405 to 39,219 GPM.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4:</u> 1.1.5 Enter Total RL supply (A) value in Step 1.4.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant enters value calculated for Total RL Supply in blank (A) on page 3 of 3 of Enclosure 13.2.</p> <p><u>EXAMINER NOTE:</u> Steps 1.2.1 and 1.2.2 are not applicable per initiating cue.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>STEP 5: 1.2.3 IF either C1P5854 (RN Train A Calculated Total Flow) OR C1P5855 (RN Train B Calculated Total Flow) is NOT available, perform the following to obtain total RN flow:</p> <p>1.2.3.1 Calculate RN Pump Train A flow: $\frac{0}{1RNP7520} + \frac{0}{2RNP7520} = \frac{0}{\text{RN Pump Train A flow}} \text{ gpm}$</p> <p>1.2.3.2 Calculate RN Pump Train B flow: $\frac{17,000}{1RNP7510} + \frac{0}{2RNP7510} = \frac{17,000}{\text{RN Pump Train B flow}} \text{ gpm}$</p> <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 2px;">Applicant calculates total RN flow to be 17,000 GPM.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p>STEP 6: 1.2.4 Perform the following calculations to obtain Total RN Flow:</p> $\frac{0}{\text{RN Pump Train A Flow}} + \frac{17,000}{\text{RN Pump Train B Flow}} = \frac{17,000}{\text{Total RN Flow}} \text{ gpm (B)}$ <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 2px;">Applicant calculates total RN flow to be 17,000 GPM.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p>STEP 7: 1.2.5 Enter Total RN Flow (B) in Step 1.4.</p> <p>STANDARD:</p> <p style="background-color: #e0e0e0;">Applicant enters Total RN Flow calculated in previous step in blank (B) on page 3 of 3.</p> <p>EXAMINER NOTE: Steps 1.3.1 and 1.3.2 are not applicable per data sheet.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p>STEP 8: 1.3.3 Calculate Cooling Tower Total Evaporation as follows:</p> $\frac{13,500}{(C1P5853)} + \frac{14,000}{(C2P5853)} = \frac{27,500}{\text{Total Evaporation}} \text{ gpm (C)}$ <p>STANDARD:</p> <p style="background-color: #e0e0e0;">Applicant calculates Total Cooling Tower Evaporation to be 27,500 GPM and enters this value in blank (C) of step 1.4.</p> <p>This step is critical because improper entry affects the calculation for Total RL Discharge Flow.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 9:</u> 1.4 Perform the following calculation to obtain Total RL Disch Flow:</p> $\frac{38354}{(A)} + \frac{17,000}{(B)} - \frac{27,500}{(C)} = \underline{27,854} \text{ gpm}$ <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant calculates Total RL discharge flow to be 27,854 GPM.</p> <p><u>EXAMINER NOTE:</u> Calculation range carried forward would be 26,905 to 28,219 GPM.</p> <p>This step is critical to ensure that enough RL flow exists to dilute the liquid waste release that is in progress.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p>NOTE: Due to problems with current RL instrumentation (PIP C-10-4540) and discrepancies between calculated and OAC RL flow (PIP C-12-1399), a safety factor is applied to the Calculated Total RL Disch Flow of Step 1.4 to ensure conservative Total RL Disch Flow rates are used for dilution purposes. This is a temporary conservative action for use till RL discharge flow instrumentation problems are resolved.</p> </div> <p>STEP 10: 1.5 Apply dilution safety factor to obtain Total RL Discharge flow from the Calculated Total RL Discharge Flow from Step 1.4 as follows:</p> <p style="text-align: center;"><u>(27,854 gpm) X 0.65 = 18,105 gpm</u></p> <p>STANDARD:</p> <p style="background-color: #e0e0e0; padding: 2px;">Applicant calculates Total RL Discharge flow to be 18,105 GPM.</p> <p>EXAMINER NOTE: Calculation range carried forward would be 17,488 to 18,667 GPM.</p> <p>This step is critical to ensure that enough RL flow exists to dilute the liquid waste release that is in progress.</p> <p>COMMENTS:</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
RO - SRO JPM A.3
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 11</u> Determination of adequate RL flow.</p> <p><u>STANDARD:</u></p> <div style="background-color: #e0e0e0; padding: 5px; margin: 10px 0;"> <p>Applicant determines that Total RL Discharge Flow is LESS than the "Minimum RL Flow interlock setpoint for radionuclides (gpm)" required by and listed on the Liquid Waste Release Permit Report, and that the release may NOT continue.</p> </div> <p>This step is critical for ensuring termination of a release with inadequate dilution flow.</p> <p><u>EXAMINER NOTE:</u></p> <p>The Liquid Waste release Permit Report requires at least 27,600 gpm RL flow in order for the release to continue. If the applicant does NOT apply the dilution safety factor (listed in STEP 10 of this JPM), it will appear that adequate RL flow DOES exist (27,854 gpm). But with the required dilution safety factor, RL flow can only be calculated as 18,105 gpm: inadequate for the release to continue.</p> <p><u>COMMENTS:</u></p> <p style="text-align: center; margin-top: 20px;">END OF TASK</p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

1. Unit 1 is currently performing a liquid waste release from the Monitor Tank Building.
2. Low Pressure Service Water (RL) Flow transmitter 0RLP5080 (RL Disch Flow) and OAC points C1P0903 and C2P0903 (RL Line A Disch Flow-Hourly Average) are INOPERABLE and have been removed from service.
3. The RN system is aligned to the RL discharge header.
4. PT/0/A/4250/011 (RL Temperature and Discharge Flow Determination) was last completed at 0700.
5. Current time is 1030.
6. Units 1 and 2 are both at 100% power.

INITIATING CUES:

You are directed to calculate the total RL discharge flow using Enclosure 13.2 (Total Discharge Flow Calculation Sheet) of PT/0/A/4250/011 and determine if adequate flow exists to continue the release per the LWR currently in progress. Record your answer in the spaces below.

Total RL Discharge Flow _____ GPM.

Adequate Flow Exists _____.
Yes/No

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

Unit 1 and Unit 2 Data Sheet for 1030

Unit 1 Cooling Tower Evaporation (PID C1P5853) – 13,500 GPM

Unit 2 Cooling Tower Evaporation (PID C2P5853) – 14,000 GPM

Low Pressure Service Water (RL) Status

RL pump A only is in service.

RL Header Pressure (0RLP5030) – 66 PSIG

Lake Wylie Level (0RNP7380) – 569 Feet

Nuclear Service Water (RN) Status

1B RN pump is in service

OAC points C1P5854, C1P5855, and C1P5856 are removed from service

RN Pump Train A flow (1RNP7520) – 0 GPM

RN Pump Train A flow (2RNP7520) – 0 GPM

RN Pump Train B flow (1RNP7510) – 17,000 GPM

RN Pump Train B Flow (2RNP7510) – 0 GPM

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

JPM A.1-1

SRO

Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam
DATA SHEET

Task: Quantify steam leak size

Alternate Path: N/A

Facility JPM #: RXM-004

Safety Function: N/A

K/A G2.1.20 Ability to interpret and execute procedure steps.

Importance: 4.6 / 4.6 **CFR:** 41.10 / 43.5 / 45.12

Preferred Evaluation Location:

Preferred Evaluation Method:

Simulator In-Plant _____ Perform Simulate _____

References: AP/1/A/5500/028 (Secondary Steam Leak), Revision 007
EP/1/A/5000/E-0, (Reactor Trip or Safety Injection), Revision 041

Task Standard: Applicant determines steam leak size exceeds 5% (approx. 7%) and requires a reactor trip. MSIVs are closed, and transition to E-0 is made.

Validation Time: 15 minutes **Time Critical:** Yes _____ No

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____
SAT _____ UNSAT _____

Examiner: _____ / _____
NAME SIGNATURE DATE

=====

COMMENTS

Catawba Nuclear Station

SRO JPM A.1-1

Sep. 2013 NRC Exam

SIMULATOR OPERATOR INSTRUCTIONS:

1. ENSURE NRC Examination Security has been established.
2. Reset to IC #
3. Enter the password.
4. Select "Yes" on the INITIAL CONDITION RESET pop-up window.
5. Ensure simulator setup per table below.
6. Do NOT go to RUN.

✓	Instructor Action	Final	Delay	Ramp	Delete In	Event
	MAL-SM009 (SM HEADER BREAK)	9.5e+5				
	Take actions of AP/28 up to step 16.					

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

A steam leak has occurred on the Main Steam header, AP/1/A/5500/028 (Secondary Steam Leak) has been entered and is complete through step 15.

INITIATING CUES:

Begin at step 16 and determine:

1) Size of steam leak - _____ %

2) Reactor Trip required - _____ YES / NO

EXAMINER NOTE: After reading Initiating Cue, provide the applicant with a copy of AP/1/A/5500/028 complete through step 15.

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
-----------------	-------------

START TIME: _____

<p><u>STEP 1:</u> 16. Determine approximate steam leak size as follows:</p> <p style="margin-left: 40px;">a. Verify - TURBINE ONLINE.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0; padding: 5px;">Applicant determines turbine is online by indication of MWs and/or generator breakers closed.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
--	---------------------------------

<p><u>STEP 2:</u> 16. b. Ensure stable plant conditions:</p> <p style="margin-left: 40px;"><input type="checkbox"/> Stable T-Avg</p> <p style="margin-left: 40px;"><input type="checkbox"/> Condenser dump valves closed.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0; padding: 5px;">Applicant determines T-Avg is stable and condenser dumps closed by GREEN closed lights lit.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
--	---------------------------------

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>NOTE</u></p> <ul style="list-style-type: none"> • In the following step, "turbine power" is the calculated value obtained from the X axis, using indicated Turbine Impulse Pressure as the Y axis value. • OAC turn on code "DBK" can be used. <p><u>STEP 3:</u> 16. c. Determine turbine power level. <u>REFER TO</u> OAC Data Book file "TURB_IMP.XYP Turbine Impulse Pressure" located under "Secondary Systems" tab.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant uses indications from OAC Data Book file to determine turbine power is approx ____%. (Value specific to IC.)</p> <p>This step is critical to determine turbine power, which is necessary to calculate the size of the steam leak.</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;">CRITICAL STEP</p> <p style="text-align: center;">___ SAT</p> <p style="text-align: center;">___ UNSAT</p>

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>NOTE</u> Secondary plant configuration can affect Thermal Power Best Estimate. Diverse reactor power indications should be used to determine reactor power.</p> <p><u>STEP 4:</u> 16. d. Determine reactor power by evaluating the following indications:</p> <ul style="list-style-type: none"> • Thermal Power Best Estimate • Nuclear instrumentation • NC Loop delta Ts <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant determines reactor power is approx ____%. (Value is specific to IC.)</p> <p>This step is critical to determine Reactor power which is necessary to calculate the size of the steam leak.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 5:</u> 16. e. Verify difference between reactor power and turbine power - LESS THAN 5%.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant determines the difference between reactor power and turbine power is 6% - 7%.</p> <p>This step is critical to determine steam leak size and subsequent actions.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL TASK</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 6:</u> 16. e. RNO Perform the following:</p> <p style="padding-left: 40px;">1) Notify RP of leak size.</p> <p style="padding-left: 40px;">2) <u>GO TO</u> Step 19.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant notifies RP, and then proceeds to step 19.</p> <p><u>Examiner Cue:</u> Repeat back information as required. 'This is Tad in RP; I understand the leak size is ____'.</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;">___ SAT</p> <p style="text-align: center;">___ UNSAT</p>
<p><u>STEP 7:</u> 19. Perform the following:</p> <p style="padding-left: 40px;">a. Verify steam leak - KNOWN TO BE ISOLABLE BY TURBINE TRIP.</p> <p><u>STANDARD:</u></p> <p style="background-color: #e0e0e0;">Applicant determines the leak is on the SM header per the initiating cue and that it is not isolable by a turbine trip.</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;">___ SAT</p> <p style="text-align: center;">___ UNSAT</p>

**Catawba Nuclear Station
SRO JPM A.1-1
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 8:</u> 19. a. RNO Perform the following:</p> <p style="padding-left: 40px;">1) Trip reactor.</p> <p><u>STANDARD:</u></p> <p>Applicant determines that the reactor needs to tripped.</p> <p>This step is critical to initiate actions to address the steam leak.</p> <p><u>Examiner Cue:</u> When applicant determines that the reactor needs to be tripped, "This JPM is complete."</p> <p><u>COMMENTS:</u></p> <p style="text-align: center;">END OF TASK</p>	<p style="text-align: center;">CRITICAL STEP</p> <p style="text-align: center;">___ SAT</p> <p style="text-align: center;">___ UNSAT</p>

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

A steam leak has occurred on the Main Steam header, AP/1/A/5500/028 (Secondary Steam Leak) has been entered and is complete through step 15.

INITIATING CUES:

Begin at step 16 and determine:

1) Size of steam leak - _____ %

2) Reactor Trip required - _____ YES / NO

**Catawba Nuclear Station
SRO JPM A.4
Sep. 2013 NRC Exam**

JPM A.4

SRO

Catawba Nuclear Station

SRO JPM A.4

Sep. 2013 NRC Exam

DATA SHEET

Task: Make Emergency Classification and Complete the Initial Emergency Notification Form

Alternate Path: N/A

Facility JPM #: SEP-018

Safety Function: N/A

K/A 2.4.40 Knowledge of SRO responsibilities in emergency plan implementation.

Importance: 2.7 / 4.5 **CFR:** 41.10 / 43.5 / 45.11

Preferred Evaluation Location:		Preferred Evaluation Method:	
Simulator _____	Classroom <input checked="" type="checkbox"/>	Perform _____	Simulate <input checked="" type="checkbox"/>

References: RP/0/A/5000/001 (Classification of Emergency), revision 029

Task Standard: Event classified as a "Site Area Emergency" based on the criteria in 4.1.C.4 and 4.1.N.2 (or N.3).
Obtain the preprinted Emergency Notification sheet or complete a blank one for 4.1.S.3. Fill out the sheet within 15 minutes from the time the classification is made.

Validation Time: 22 minutes **Time Critical:** Yes No _____

Applicant: NAME _____ Docket # _____ Time Start: _____
Time Finish: _____

Performance Rating: Performance Time _____
SAT _____ UNSAT _____

Examiner: _____ / _____
NAME SIGNATURE DATE

COMMENTS

Catawba Nuclear Station

SRO JPM A.4

Sep. 2013 NRC Exam

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- A Unit 1 transient initially caused an OP Delta T Reactor Trip signal.
- The reactor failed to automatically trip.
- The crew successfully completed a manual reactor trip 10 minutes ago.
- Almost immediately, the unit safety injected.
- The crew entered EP/1/A/5000/E-0 (Reactor Trip or Safety Injection).
- 1C Steam Generator has a stuck open S/G safety.
- The crew is transitioning to EP/1/A/5000/E-2 (Faulted Steam Generator Isolation).

The transition brief contained the following additional information:

- NC pumps had to be tripped due to a loss of subcooling.
- NC pressure is 600 psig and stable.
- 1ETB has an unknown fault and is currently de-energized.
- EMF Trip 2 alarms are in:
 - 1EMF-28 (Steam Line Monitor)
 - 1EMF-33 (Condenser Air Ejector Monitor)
 - 1EMF-72, 73 (N-16 Steam Line Monitors)

Current meteorological data:

- Clear conditions.
- Wind speed is 5 mph.
- Wind direction is 270°.

INITIATING CUES:

Classify the event and fill out the initial Emergency Notification form through the date and time that you approve it.

This JPM is time critical.

**Catawba Nuclear Station
SRO JPM A.4
Sep. 2013 NRC Exam**

EXAMINER NOTE:

If applicant asks for instructions on filling out the Emergency Notification Form, provide a copy of:

- RP/0/A/5000/006 A (Notifications to States and Counties from the Control Room), Enclosure 4.1, "Emergency Notification Form Completion", 7 pages

**Catawba Nuclear Station
SRO JPM A.4
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
------------------------	------------------------

START TIME: _____

<p><u>STEP 1:</u> Classify the event using RP/0/A/5000/001, Classification of Emergency.</p> <p><u>STANDARD:</u></p> <p>Applicant classifies the event as a “Site Area Emergency” due to: Event #4.1.C.4 and #4.1.N.2 or 3.</p> <p>3 points 4.1.C.4 (SG Secondary Side Release With Primary to Secondary Leakage).</p> <p>AND</p> <p>5 points 4.1.N.2 (Greater than available makeup capacity as indicated by a loss of NCS Subcooling).</p> <p>OR</p> <p>5 points 4.1.N.3 (Indication that a SG is ruptured and has a Non-Isolable secondary side fault.).</p> <p><u>EXAMINER NOTE:</u> It is critical that the classification be made and the emergency be declared within 15 minutes of the recorded start time.</p> <p style="text-align: center;">TIME EMERGENCY DECLARED _____.</p> <p>This step is critical to ensure the proper classification will be communicated.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>
---	---

**Catawba Nuclear Station
SRO JPM A.4
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 2:</u> Obtain Emergency Notification form.</p> <p><u>STANDARD:</u></p> <p style="background-color: #cccccc;">Applicant obtains a blank Emergency Notification form (provided by Examiner).</p> <p>This step is critical to ensure that the proper form is transmitted.</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

Catawba Nuclear Station

SRO JPM A.4

Sep. 2013 NRC Exam

STEP / STANDARD	SAT / UNSAT
<p>STEP 3: Complete the Emergency Notification Form.</p> <p><u>EXAMINER NOTE:</u> For actual events, Lines 1, 3, 4, 5, 6, 9, 10 and 11 are critical entries based on the NRC Performance Indicator, but for <u>exam purposes</u>, CRITICAL STEPS are in BOLD below. Also see attached completed Emergency Notification Form KEY.</p> <p><u>STANDARD:</u></p> <div style="background-color: #f0f0f0; padding: 5px;"> <ul style="list-style-type: none"> <input type="checkbox"/> Line 1: "Drill" is marked. <input type="checkbox"/> Line 2: "Initial" is marked. <input type="checkbox"/> Line 3: Catawba Nuclear Site (pre-printed). <input type="checkbox"/> Line 4: Per attached KEY. <input type="checkbox"/> Line 5: "None" is marked. <input type="checkbox"/> Line 6: Emergency release "is occurring" due to 1EMF-33 indication of S/G tube leakage. <input type="checkbox"/> Line 7: "Under evaluation" marked. </div> <p><u>EXAMINER CUE:</u> "RP is determining release significance."</p> <div style="background-color: #f0f0f0; padding: 5px;"> <ul style="list-style-type: none"> <input type="checkbox"/> Line 8: "Stable " marked. <input type="checkbox"/> Line 9: Not required for initial notifications, and NOT critical. If entered, wind direction is 270° and wind speed 5 mph. <input type="checkbox"/> Line 10: "Declaration" marked and enters current date and time. <input type="checkbox"/> Line 11: Affected Unit(s) marked as "1". <input type="checkbox"/> Line 12: Marks box "A" and 0% power. </div> <p><u>EXAMINER CUE:</u> "The reactor was tripped 10 minutes ago."</p> <div style="background-color: #f0f0f0; padding: 5px;"> <p>Enters time minus 10 minutes and enters today's date.</p> <ul style="list-style-type: none"> <input type="checkbox"/> Line 13: Includes information on the loss of power and the ATWS. <input type="checkbox"/> Lines 14,15 and 16 - see Examiner Cue below. </div> <p>IF ASKED,</p> <p><u>EXAMINER CUE:</u> "RP has not determined any release data."</p> <p><u>COMMENTS:</u></p>	<p>CRITICAL STEP</p> <p>___ SAT</p> <p>___ UNSAT</p>

**Catawba Nuclear Station
SRO JPM A.4
Sep. 2013 NRC Exam**

STEP / STANDARD	SAT / UNSAT
<p><u>STEP 3 (cont.)</u></p> <p><u>EXAMINER NOTE:</u> These steps are not required for initial notifications.</p> <p><input type="checkbox"/> Line 17: Signs as Emergency Coordinator. Date and time on line 17 is based on time of approval.</p> <p>See attached, completed, Emergency Notification sheet for a key.</p> <p>Time Emergency Notification Form is completed: _____</p> <p>It is critical that the total time from the declaration time recorded in Step 1 to completing the Emergency Notification Form is \leq 15 minutes.</p> <p><u>COMMENTS:</u></p>	

STOP TIME _____

APPLICANT CUE SHEET

(RETURN TO EXAMINER UPON COMPLETION OF TASK)

READ TO APPLICANT

DIRECTION TO APPLICANT:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- A Unit 1 transient initially caused an OP Delta T Reactor Trip signal.
- The reactor failed to automatically trip.
- The crew successfully completed a manual reactor trip 10 minutes ago.
- Almost immediately, the unit safety injected.
- The crew entered EP/1/A/5000/E-0 (Reactor Trip or Safety Injection).
- 1C Steam Generator has a stuck open S/G safety.
- The crew is transitioning to EP/1/A/5000/E-2 (Faulted Steam Generator Isolation).

The transition brief contained the following additional information:

- NC pumps had to be tripped due to a loss of subcooling.
- NC pressure is 600 psig and stable.
- 1ETB has an unknown fault and is currently de-energized.
- EMF Trip 2 alarms are in:
 - 1EMF-28 (Steam Line Monitor)
 - 1EMF-33 (Condenser Air Ejector Monitor)
 - 1EMF-72, 73 (N-16 Steam Line Monitors)

Current meteorological data:

- Clear conditions.
- Wind speed is 5 mph.
- Wind direction is 270°.

INITIATING CUES:

Classify the event and fill out the initial Emergency Notification form through the date and time that you approve it.

This JPM is time critical.