

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
610th Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, December 4, 2013

Work Order No.: NRC-473

Pages 1-70

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

610TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

DECEMBER 4, 2013

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 1:30 p.m., J. Sam
Armijo, Chairman, presiding.

COMMITTEE MEMBERS:

- J. SAM ARMIJO, Chairman
- JOHN W. STETKAR, Vice Chairman
- HAROLD B. RAY, Member-at-Large
- RONALD G. BALLINGER, Member
- SANJOY BANERJEE, Member
- DENNIS C. BLEY, Member
- CHARLES H. BROWN, JR. Member
- MICHAEL L. CORRADINI, Member

1 DANA A. POWERS, Member
2 JOY REMPE, Member
3 PETER RICCARDELLA, Member
4 MICHAEL T. RYAN, Member
5 STEPHEN P. SCHULTZ, Member
6 GORDON R. SKILLMAN, Member

7

8 ACRS CONSULTANT:

9 WILLIAM J. SHACK

10

11 DESIGNATED FEDERAL OFFICIAL:

12 CHRISTOPHER L. BROWN

13

14 ALSO PRESENT:

15 EDWIN M. HACKETT, Executive Director, ACRS

16 MIKE CALL, NMSS

17 PATRICK CASTLEMAN, OCM

18 GREG CASTO, NRR

19 AMY CUBBAGE, OCM

20 HOSSEIN ESMAILI, RES

21 KATHY HALVEY GIBSON, RES

22 DON HELTON, RES

23 JOHN HULL, OGC

24 STEVEN JONES, NRR

25 IAN JUNG, OEDO

1 MARVIN LEWIS*
2 TIM MCGINTY, NRR
3 JOSE PIRES, RES
4 BILL RECKLEY, NRR
5 FRED SCHOFER, NRR
6 DAVE SKEEN, NRR
7 ROB TAYLOR, NRR
8 KEVIN WITT, NRR

9

10 *Present via telephone

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

I. OPENING REMARKS BY THE ACRS CHAIRMAN

Chairman Armijo 5

II. JAPAN LESSONS LEARNED TIER 3 ISSUE:

1. Opening remarks

Chairman Armijo 6

2. Staff opening remarks and introduction

Tim McGinty 6

III JAPAN LESSONS LEARNED TIER 3 ISSUE:

EXPEDITED TRANSFER OF SPENT FUEL TO DRY CASK
STORAGE

Kevin Witt 7

Steve Jones 15

IV PUBLIC COMMENT

Marvin Lewis 68

P-R-O-C-E-E-D-I-N-G-S

(1:30 p.m.)

CHAIRMAN ARMIJO: The meeting will now come to order. This is the first day of the 610th meeting of the Advisory Committee on reactor safe guards.

During today's meeting the committee will consider the following. Japan Lessons Learned Tier 3 issue, expedited transfer of spent fuel to dry cask storage.

Second, draft report on the bi-annual ACRS review of the NRC safety research program. And third, preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Christopher Brown is the designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests to make oral statements from the members of the public regarding today's sessions.

There will be a phone bridge line. To preclude interruption of the meeting, the phone will be placed in a listen in mode during the presentations and committee discussion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 A transcript of portions of the meeting is
2 being kept and it is requested that the speakers use
3 one of the microphones, identify themselves and speak
4 with sufficient clarity and volume so that they can be
5 readily heard.

6 So we'll start with the first topic and
7 the purpose of the meeting, briefing is to receive,
8 the purpose of the meeting is to receive a briefing
9 from the Office of Nuclear Reactor Regulation on the
10 staff evaluation and recommendation for Japan Lessons
11 Learned Tier 3 issue on expedited transfer spent fuel.

12 Our materials metal urging reactor fuel
13 subcommittee reviewed this matter on June 9th,
14 September 19th and November 19th of 2013. Our full
15 committee also reviewed this matter on October the
16 2nd, 2013.

17 We will now proceed with the meeting and
18 I call upon Tim McGinty of the NRR to give a brief
19 introduction and introduce the presenters. Tim.

20 MR. MCGINTY: Thank you. Good afternoon,
21 my name is Tim McGinty and am the direct of the
22 division of safety systems in the Office of Nuclear
23 Regulation at the NRC.

24 I would like to thank the Chairman and the
25 members of the ACRS for the opportunity to hear the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff's presentation of the near Term Task Force Tier
2 3 action to recommend whether further regulatory
3 action is recommended or additional study would be
4 warranted regarding the expedited transfer of spent
5 fuel from wet to dry storage.

6 To determine whether regulatory action
7 might be warranted, we followed our regulatory
8 decision making procedures to determine whether there
9 is a substantial safety enhancement. Additionally, to
10 provide information to the Commission, the staff
11 performed additional cost-benefit analysis as well as
12 additional sensitivity studies of cases beyond the
13 current regulatory framework.

14 Based on the feedback that you provided in
15 prior subcommittee meetings, the staff has made
16 improvements to their analysis and updated COMSECY-13-
17 0030. Which was initially sent to the Commission on
18 November 12th.

19 For our meeting with you today, Kevin Witt
20 will be covering the Tier 3 plan background and
21 evaluation process, Steve Jones will be covering the
22 Tier 3 analysis and Fred Schofer will supporting the
23 discussions on the cost-benefit analysis. And with
24 that I turn it over to Kevin Witt please.

25 MR. WITT: Thank you, Tim. As Tim

1 mentioned my name is Kevin Witt, I'm a project manager
2 and the Japan lessons learned projector director in
3 the Officer of Nuclear Reactor Regulation.

4 I was responsible for coordinating staff
5 activities on this issue. I'll be going through a bit
6 of the background and then I'll turn it over to Steve.

7 For the agenda today we're going to go
8 really quickly through a background on this issue.
9 You probably heard it before, we've presented this to
10 you a number of times so we're going to try to focus
11 more on the technical aspects of this analysis.

12 We're also going to give a brief recap of
13 the spent fuel pool study which was reviewed by the
14 ACRS at their July meeting. And just to give you a
15 little bit of history with how we used that.

16 And then we're going to talk about the
17 analysis we did, we're calling it the regulatory
18 analysis on this issue. We'll talk about the
19 assumptions we made and the results then we'll talk
20 about the conclusion.

21 A little bit of background, after
22 Fukushima happened the Japan Lessons Steering
23 Committee decided to initiate a lessons learned item
24 on this issue of whether expedited transfer of spent
25 fuel, whether regulatory action might be needed on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this issue.

2 And as first step in that issue to
3 determine how to progress on that, we initiated a
4 study on that that was conducted by the Office of
5 Nuclear Regulatory research. And that evaluated the
6 difference, it's the spent fuel pool study.

7 That was provided at the Commission in
8 October. It evaluated the differences and
9 consequences between high-density and low-density
10 spent fuel pools at a reference plant, specific
11 reference plant.

12 And then on the Tier 3 plan what we did
13 was, we tried to determine what the best way to figure
14 out whether regulatory action is needed on this issue.
15 And so there's a broad history of research on this
16 topic of spent fuel safety.

17 And we so kind of formulated a plan to
18 take all that information into consideration and
19 process it through our regulatory framework utilizing
20 the regulatory analysis guidelines. And that's in
21 NUREG Brochure 0058. And that's the enclosure to the
22 Tier 3 COMSECY which was just sent up to the
23 Commission on this issue.

24 We provided an update to the Commission on
25 this plan on how we propose to pursue it. That was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provided in May of 2013 and we just sent that up to
2 the Commission, the final paper in November.

3 The Tier 3 plan, the objective of what we
4 were doing with this first phase, what we're calling
5 the first phase of this plan, was to determine whether
6 we needed additional study on this matter. And
7 depending on how the analysis would turn out, we would
8 come up with a decision on whether regulatory action
9 might be warranted. And if that would be the case
10 then we would proceed to Phase 2.

11 So Phase 1 was really a high level look at
12 whether more study is needed on this issue. And
13 that's what was provided to the Commission.

14 Now Phase 2, obviously our recommendation
15 is to not go to that point, but if we did get to Phase
16 2 we would be doing additional analysis such as doing
17 research on risks associated with an expedited
18 transfer as well as conservatism that we've made in
19 this analysis to try to put more, less on certainty in
20 that analysis.

21 And then Phase 3 would be inclusion of all
22 these other factors that are currently ongoing.
23 Probably take a number of years for all that be
24 completed. So that would be our plan.

25 We've had a number of stakeholder

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interactions on this issue. We had two public
2 meetings, August 22nd and September 18th of this year.

3 We received a number of letters from
4 stakeholders about our analysis as well as the spent
5 fuel pool study. We responded to those letters.

6 In addition we've also included responses
7 to the comments we received in the documents in the
8 spent fuel pool study. They included an appendix in
9 the final study with responses to comments they
10 received on the study as well as in this Tier 3
11 analysis, we included at the back of our analysis, we
12 included responses to some of the questions or
13 comments we received on how we did this.

14 As I mentioned, the spent fuel pool study
15 that was just, there was a public comment period on
16 that in July, June and July. And the final report was
17 sent to the Commission in October.

18 Now on this Tier 3 analysis we did release
19 a draft version of the analysis back in September.
20 And really the content of the analysis, the way we did
21 the analysis hasn't really changed from what we issued
22 back in September to what we have now.

23 It's more about the format and the layout
24 of how we explained the analysis. And we'll go
25 through that in a little bit more detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We did have the ACRS full committee
2 presentation on this in October. And we did take some
3 feedback to that to improve the COMSECY which was
4 reflected in the final version that was sent up to the
5 Commission.

6 We also received a nonconcurrency from NRC
7 staff on this that was attached to the back of the
8 COMSECY. We have a response to that, we also have a
9 slide on some of those issues that we'll talk about.

10 Now from the subcommittee meeting we did
11 receive some questions and comments about the content
12 of our analysis. We did make some corrections, I sent
13 that to Christopher. I believe, that was sent to you
14 all.

15 The final version of the COMSECY was
16 updated. These are basically typographical errors.
17 They did not change the analysis that we did. So this
18 is just, gives an overview of what we have changed.

19 I think we captured all the things that
20 you mentioned and made sure that everything else was
21 correct. So we appreciate the feedback on that.

22 VICE CHAIRMAN STETKAR: Kevin, just to get
23 it on the record, you didn't make all of the
24 corrections in Table 2. And in particular you say for
25 the high case, the liner fragility is set to a 100

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent and it's not.

2 And the changes that you made to Tables
3 44, 56 and 60 did indeed bring two of the base case
4 evaluations into alignment with two others. But it
5 kept two of them consistently now out of alignment
6 with the other four.

7 So what I propose, just to avoid getting
8 into excruciating detail in this meeting, is I'd like
9 to sit down with the staff offline and try to
10 understand what's going on in those, the 44, 56, 64
11 detail tables. Because I still can't figure out a
12 couple of them.

13 Table 2, it's just you missed one of the,
14 on the right hand column where you say for the high
15 estimate 100 percent fragility is used for all the
16 cases, that's not true. You use 25 percent fragility
17 for the high cases, for two, three and four.

18 MR. WITT: Okay.

19 VICE CHAIRMAN STETKAR: So you still got
20 a little bit of typos to look at.

21 MR. WITT: Okay.

22 VICE CHAIRMAN STETKAR: You really off two
23 or three things.

24 MR. WITT: I apologize for that. We'll
25 certainly make sure that everything is correct and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 afterwards we'll be happy to talk to you.

2 VICE CHAIRMAN STETKAR: Okay, thanks.

3 MR. WITT: About those things. Okay, just
4 to talk a little bit about how we went through this
5 process.

6 As I mentioned, the first step of this
7 process was the spent fuel pool study. And that was
8 a consequence study for a specific plant, a reference
9 plant, based on the Peach Bottom spent fuel pool. And
10 of course specific scenario that was a seismic event
11 that impacted the spent fuel there. Spent fuel pool.

12 From that study we took the consequences
13 and we did an example of how that would fit into our
14 regulatory framework. So we added in Appendix D to
15 the spent fuel pool study which took the consequences
16 from the spent fuel pool accident and applied it to
17 the framework to see whether there would be a
18 substantial increase in safety.

19 And we expanded it out a little bit. We
20 included some other initiating events that had
21 analysis in the spent fuel pool study.

22 And then from there, that really laid the
23 basis for how we did the Tier 3. We took the same
24 process and we extended that out even more and we
25 applied that same analysis to all the plants.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We tried to capture them in different
2 groupings and we'll talk about that a little bit
3 later. That's all for the study.

4 MR. JONES: Good afternoon, my name is
5 Steve Jones, I'm the technical lead for spent fuel
6 storage and handling in division of safety divisions.
7 I'd like to briefly recap the results of the spent
8 fuel pool study that you heard about a few months back
9 from the Office of Research.

10 Just covering some of the highlights with
11 respect to this study. One, the spent fuel pools, it
12 does support a robust spent fuel pool construction and
13 that the study confirmed that the, at least for the
14 reference plant, that the pool at the low likelihood
15 of leakage.

16 And in the study they made a conservative
17 assumption really of a 90 percent of the time the pool
18 would not leak.

19 CHAIRMAN ARMIJO: Steve, I just want to
20 bring up a point. Bill Shack and I had breakfast
21 today and we talked about the spent fuel pool study
22 and it actually did, the analysis, the detailed
23 analysis was not limited to the 0.7 g PGA earthquake.

24 It also did an analysis of the 1.2. And
25 could you remind us of what the liner leakage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probability was for that analysis?

2 MR. JONES: I'd have to look for --

3 VICE CHAIRMAN STETKAR: I have it. For
4 June?

5 MR. WITT: I don't believe that we did a
6 structural analysis for the 1.2 g earthquake.

7 VICE CHAIRMAN STETKAR: Right.

8 CHAIRMAN ARMIJO: Is that --

9 MR. WITT: We did it for the 0.7 g. What
10 we did in the regulatory analysis was we included the
11 1.2 g consideration in the regulatory analysis and we
12 assumed 100 percent liner --

13 CHAIRMAN ARMIJO: Okay --

14 VICE CHAIRMAN STETKAR: For only the BWR
15 --

16 MR. WITT: For the Peach Bottom.

17 VICE CHAIRMAN STETKAR: -- for only Peach
18 Bottom.

19 CHAIRMAN ARMIJO: Only Peach Bottom?

20 MR. WITT: Correct.

21 VICE CHAIRMAN STETKAR: For the others you
22 assume 0.5.

23 MR. WITT: Right.

24 VICE CHAIRMAN STETKAR: Just for the base
25 case.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: Just maybe I
2 misunderstood.

3 CONSULTANT SHACK: This is Bill Shack.
4 What I was explaining to Sam is, if you looked at the
5 Vermont Yankee and you looked at that fragility and
6 you used the same law of normal distribution, you
7 would get a, you would not get a hundred percent for
8 the failure at the 1.2 g earthquake.

9 VICE CHAIRMAN STETKAR: Right.

10 CONSULTANT SHACK: You'd get closer to
11 0.5.

12 CHAIRMAN ARMIJO: Okay.

13 CONSULTANT SHACK: So although they didn't
14 do the calculation, if you assumed it, followed the
15 law of normal similar to the Vermont Yankee one then
16 we would conclude that you roughly have a factor of 2.

17 CHAIRMAN ARMIJO: Okay, I misheard. Yes.
18 Okay, thank you.

19 MR. JONES: Okay, and then if leakage were
20 to occur that would fully drain the pool, the study
21 concluded that spent fuel in the pool would air-
22 coolable within two months after discharge from the
23 fuel for at least 72 hours.

24 And in both case, both the high-density
25 and low-density storage cases, the frequency of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 release was identical. Essentially all cases that
2 lead to a release from a low-density, for a high-
3 density pool configuration also lead to a release for
4 a low-density. However the magnitude of the release
5 was different.

6 Next slide. And then in general these
7 statements support that the previous spent fuel pool
8 study's conclusions were valid. And I think we'll
9 move onto the next slide.

10 Okay, what changed in Appendix D to the
11 spent fuel pool study, it examined or included
12 initiating events that were not specifically analyzed
13 in the main body of the report. Including a more
14 severe earthquake, the cask drop event, and other
15 initiators such as loss of power or loss of coolant
16 inventory.

17 Then the Tier 3 regulatory analysis
18 included all these additional initiating events and
19 examined groups of pools representing the entire
20 operating fleet in the Eastern and Central U.S. and
21 new reactors under construction. The API-1000 plants
22 in South Carolina and Georgia.

23 The security --

24 CONSULTANT SHACK: Steve, this is Bill
25 Shack, can I ask a question again --

1 MR. JONES: Yes.

2 CONSULTANT SHACK: -- about this? If I
3 look at the regulatory analysis for the spent fuel
4 pool study in Appendix D, and it's Table 108 so I'm
5 looking beyond 500 miles and \$4,000 per person-rem, I
6 get in the high case of benefit of like minus \$25
7 million.

8 If I look at the high analysis in the Tier
9 3 regulatory analysis for the Group 1 plants for the
10 high analysis, I get a plus \$500 million. I think the
11 difference in the assumption is that the, in the Peach
12 Bottom one you did not assume mitigation for one and
13 not the other and you did in the Tier 3.

14 Is that the difference or, what makes this
15 enormous difference from minus \$25 million to plus
16 \$500 million?

17 MR. SCHOFER: As far as the mitigation,
18 the mitigation assumption was the same for Appendix D.
19 So --

20 CONSULTANT SHACK: So the low one always
21 had mitigation and the high one didn't?

22 MR. SCHOFER: That is correct.

23 MR. WITT: Well, and what we did in the
24 Tier 3 analysis was we tried to pick the highest
25 cases, generally, for the assumption. So we didn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 always use the Peach Bottom assumptions in that
2 analysis. For instance --

3 CONSULTANT SHACK: That would seem to
4 indicate that you're grouping them is still too
5 course. I mean if you're going to minus \$25 million
6 to plus \$500 million, that's, you know, steering an
7 awful lot of information.

8 MR. SCHOFER: I mean, you know, a major
9 difference between the two analyses is, for the
10 reference plant all we had to do was address the high
11 and low for that particular plant. When I went to the
12 grouping to address all the pools, there's more
13 variability from pool to pool to pool, even within a
14 group.

15 And so when, you know, you have the high
16 estimate cases, those high estimate values --

17 CONSULTANT SHACK: Then you can't argue
18 that the high estimate case is conservative. I mean
19 you're arguing that it covers a lot of variabilities.
20 So if I did a real case for one of those, you know,
21 would I end up with something that looked like \$500
22 million?

23 MR. WITT: Well I think that, how we've
24 characterized the high cases is that we view it as
25 more of a bounding type analysis and we viewed the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 basis --

2 VICE CHAIRMAN STETKAR: Please don't use
3 the word bounding. They are not bound, people
4 interpret bounding as it cannot be any worse than
5 that. And that is not true.

6 They are high estimate cases. They don't
7 use bounding values for all parameters. So you're
8 high estimates cases are not conservatively bounding.
9 They are simply high estimate cases.

10 CHAIRMAN ARMIJO: Everywhere where they
11 are not --

12 VICE CHAIRMAN STETKAR: They are not
13 bounding.

14 CHAIRMAN ARMIJO: Everywhere where the
15 table says 100 percent, that is bounding.

16 VICE CHAIRMAN STETKAR: That is a bounding
17 value of the fragility.

18 CHAIRMAN ARMIJO: Right.

19 VICE CHAIRMAN STETKAR: Period. That is
20 correct. Other values that are used in those high
21 estimate cases are not.

22 CHAIRMAN ARMIJO: Sure. Right.

23 CONSULTANT SHACK: But there are bounding
24 values in the Appendix D analysis too where you used
25 a hundred percent for the 1.2 g earthquake --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WITT: Correct.

2 CONSULTANT SHACK: -- and you still came
3 up with minus \$25 million versus the \$500 million.
4 I'm still looking for the --

5 CHAIRMAN ARMIJO: Where's the pony?

6 CONSULTANT SHACK: Yes, I just, I need
7 somehow to sort that out a little bit.

8 CHAIRMAN ARMIJO: I think, have
9 demographics changed at all?

10 MR. WITT: Demographics went down.

11 VICE CHAIRMAN STETKAR: You'll have to get
12 back to him.

13 MR. WITT: Well, I'll get back to you on
14 that. Still have a lot of questions, but not that,
15 okay.

16 All right, I do want to point out once
17 more that the security events are handled separately.
18 We did consider the regulatory changes specifically
19 those implemented under 10 CFR 50.54(hh) and those are
20 included in the regulatory baseline.

21 The regulatory analysis really comes in
22 two parts. First, the safety goal screening that
23 evaluates the effect of early transfer of fuel with
24 respect to this commission safety goal policy
25 statement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And specifically we used the quantitative
2 health objectives to evaluate whether or not or to
3 what degree the safety goals were satisfied. Also
4 there's a cost-benefit analysis.

5 This was designed to really look at the
6 maximum potential benefit for the particular cases
7 evaluated. And it analyses those benefits in terms of
8 representative groups of spent fuel pools.

9 Next slide please. The safety goal
10 screening used, basically done in three steps. One
11 was determining a release frequency. We used the
12 highest release frequency among the high estimate
13 cases. In that case it was Group 4.

14 And then applied a conditional probability
15 of a fatal cancer from the spent fuel pool study
16 derived for a large release at the Peach Bottom site,
17 specifically, and that considered a linear no-
18 threshold model with protective actions implemented.

19 And from that determined that the
20 individual latent cancer fatality risk was less than
21 one percent of the quantitative health objective goal.
22 Any questions? Next slide I guess.

23 So based on that result we concluded there
24 was a marginal safety benefit. We also considered the
25 quantitative health objective related to top

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fatalities and determine that there was no risk of
2 early fatalities due to the nature of the release from
3 the spent fuel pool accident.

4 A potential benefit here was a very,
5 again, a very small fraction of the latent cancer
6 goal. I do want to highlight that the cancer risk
7 however is relatively insensitive to the magnitude of
8 the release due to the predominantly, due to the
9 effective protective actions but also the slow
10 evolution of the accident.

11 Because we're so far from the quantitative
12 health objective goal, the safety benefit was low
13 enough that it easily did not pass the safety goal
14 screening to proceed on to a bio-impact analysis.
15 Although we did continue to provide information to
16 the, addition information for this particular study.

17 CHAIRMAN ARMIJO: Have you ever just
18 stopped the analysis with the evaluation of meeting
19 the QHO criteria?

20 Simply said, you know, we're spinning our
21 wheels spending money and the answer isn't going to
22 get any better. Do you have history of doing that in
23 this staff?

24 MR. SCHOFER: When we did a safety goal
25 screening, you know, typically we're evaluating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactors for core damage frequency or, you know, if
2 we're well below the 10-5 --

3 CHAIRMAN ARMIJO: So for that case you've
4 done it enough that you feel that you can just stop
5 right there?

6 MR. SCHOFER: And prior NUREGs that
7 evaluated the spent fuel pools, you know, did look at
8 the QHOs and never did a detailed cost evaluation.

9 CHAIRMAN ARMIJO: Okay, it's been done
10 before then? You've actually stopped at the QHO.

11 MR. JONES: Sorry. The cost-benefit
12 analysis was conducted with an effort to maximize the
13 calculated benefit predominately through selection of
14 the release fractions from the spent fuel pool and
15 also treatment of mitigation.

16 Probably jump back on this slide. I'm
17 sorry, I jumped ahead one slide on the presentation in
18 front of you.

19 Okay, for the cost-benefit analysis we
20 selected one alternative. That was expedited
21 transfer.

22 So all fuel if more than four years decay
23 was assumed to be moved to dry cask and the remaining
24 fuel be stored in a low-density configuration in the
25 existing racks. That is 1x4 with each recently

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discharged assemblies surrounded by four empty slots
2 on each face.

3 And the established spent fuel pool
4 groups, there's four groups that are specifically
5 considered in this analysis. The first group was the
6 BWRs with elevated pools.

7 Second group was PWRs and BWR Marked IIIs
8 where they are separate buildings for the spent fuel
9 pool from the reactor. And the pools are generally at
10 or near plant grade.

11 The third group was the, represented the
12 new reactors. The AP-1000 plants under construction.

13 And the fourth group is a set of plants
14 that share a spent fuel pool and therefore would have
15 higher decay heat loadings. And also a greater
16 fraction of the time potentially with high decay heat
17 loads represent in the pool.

18 The major assumptions used in the cost-
19 benefit analysis were provided in Table 2 of the
20 analysis. Some of these included the spent fuel pool
21 event frequencies and accident progression
22 assumptions, the economic modeling and also the timing
23 with respect to when dry casks were loaded and
24 therefore how the, I'm sorry, how the discount rates
25 were applied to determine the cost for those actions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They also established the base case so we
2 consider representative of the bulk of the plants and
3 somewhat conservative with respect to what we consider
4 the average plant and perform sensitivity and studies.

5 CHAIRMAN ARMIJO: Steve, I just want to
6 make sure I have this straight. The decision not to
7 credit mitigation capabilities that would result from
8 orders EA-12-049 and EA-12-051, you consider that an
9 assumption or different than an assumption or what is
10 it? Is it just a decision or an assumption that the
11 equipment, even if it was there, wouldn't work?

12 MR. SCHOFFER: It certainly was not that.

13 CHAIRMAN ARMIJO: Well so we just did a
14 decision not apply, but you didn't, that equipment was
15 not credited for either alternative, right? The base
16 case.

17 I mean the Alternative 1 or Alternative 2,
18 so. It was an evenhanded, we're not going to credit
19 that for either alternative?

20 MR. WITT: We have a slide on that, Slide
21 20. We can talk about it now if you want?

22 CHAIRMAN ARMIJO: Just say yes or no. Did
23 you --

24 MR. WITT: Well they're analysis did not
25 credit mitigation for the baseline case. But we do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have a slide that talks about what would happen if you
2 did credit for both cases or if you did not credit for
3 both cases.

4 CHAIRMAN ARMIJO: That's new then?

5 MR. WITT: That's new information that
6 we're presenting to you.

7 CHAIRMAN ARMIJO: Oh, okay. All right.

8 MR. SCHOFER: To answer your question
9 directly, it was an assumption that was made to
10 develop the maximum delta between the two cases to
11 demonstrate that whether we could show the low-density
12 alternative to be cost-beneficial.

13 CHAIRMAN ARMIJO: Yes, I understand, I
14 understand.

15 MR. SCHOFER: But it was just an
16 assumption made because of other results that came out
17 of Appendix D.

18 CHAIRMAN ARMIJO: Okay.

19 MR. JONES: Okay, we are talking about
20 these assumptions. We did assume for the regulatory
21 baseline case relatively high release fractions.

22 We used for the BWRs the elevated pools.
23 Since there was somewhat less uncertainty with that
24 value, the spent fuel pool study value of about 40
25 percent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For the pools at or near grade, or the
2 remainder actually of the groups, we assumed a higher
3 value that was used in NUREG-1738 of 75 percent. And
4 then when considering the low-density spent fuel
5 configuration, the alternative, the value used was
6 three percent for all groups. That was representative
7 of the low-density releases from the spent fuel pool
8 study.

9 And with consideration of mitigation, that
10 release fraction has both a lower frequency and a much
11 lower magnitude. Obviously greater than one order of
12 magnitude lower release for the alternative case.

13 Next slide please. For the base case
14 analysis, as I mentioned before, we did believe that's
15 the correct case to use to decide whether or not to
16 pursue additional studies to refer the refine of our
17 assumptions.

18 The base case includes some conservative
19 but not bounding values for the following items. One
20 was the initiating event frequencies.

21 The seismic event frequency was derived
22 from USGS 2008 information. And we used predominately
23 the Peach Bottom seismic hazard for all the base cases
24 actually. And that is near the upper end of the
25 estimated frequencies for plants in the Central and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Eastern United States.

2 Okay. The liner fragilities were based on
3 the spent fuel pool study for the elevated pools and
4 used previous study information for the remainder of
5 the pools. Weather is really a lot more uncertainty
6 with respect to the specific plant configuration.

7 Cesium inventories were based on the
8 actual amount of spent fuel present. The cooling
9 periods and the fuel burn up that's typical for the
10 plants in the group.

11 The releases were calculated using a
12 MACCS2 code in the Peach Bottom meteorology
13 information. However the population density was
14 assumed for the Surry plant which is representative of
15 the mean of all the U.S. plants therefore it's
16 somewhat lower than Peach Bottom.

17 And for the industry implementation cost
18 it was based predominately on Electric Power Research
19 Institute information. Next slide.

20 One major assumption that was intended to
21 address stakeholder comments regarding the ability to
22 accurately represent partially drain down states or
23 the fact that racks may interfere with natural
24 circulation cooling of the fuel and the actual
25 distribution of the fuel. Most of the cases include,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most of the initiating events include a bounding
2 assumption that heat removal would be inadequate due
3 to natural circulation effects.

4 This is, we consider this conservative
5 because the spent fuel pool study indicated that
6 there's substantial potential for air-cooling when the
7 pool is drained or the decay heat is low. And we made
8 an exception in that case for the Mark I and II BWRs
9 covered by the spent fuel pool study because again,
10 there was less uncertainty with that information.

11 And for that case we used eight percent
12 representative of the fraction of the operating cycle
13 where the heat in the hottest assemblies was too high
14 to support adequate natural circulation cooling there.

15 Okay, next slide please. These
16 assumptions resulted in this table for the initiating,
17 for release frequency determination. This does not
18 consider any mitigation effects.

19 For Bin 3, for Bin 1 in particular. I do
20 want to point out again the inadequate pooling eighth
21 percent. That substantially reduces the contribution
22 from the Bin 3 earthquake to the overall results
23 there.

24 And for Bin 4, for the at-grade pools
25 which represent Groups 2 through 4, there's a 50

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent assumption of pool liner fragility which
2 somewhat reduces the contribution of Bin 4 to that
3 overall total. Nevertheless, for both plants about 90
4 percent of the overall release frequency is based on
5 the seismic initiators. And that's consistent with
6 past studies and other information.

7 VICE CHAIRMAN STETKAR: Steve?

8 MR. JONES: Yes.

9 VICE CHAIRMAN STETKAR: I hate to pick at
10 numbers but this table, this report is so full of
11 numbers that --

12 MR. JONES: Right.

13 VICE CHAIRMAN STETKAR: These numbers that
14 you're showing on this slide are not the same as the
15 numbers that are in Table 43 in the report. Many of
16 them are but some of them are not.

17 MR. JONES: Should they be?

18 VICE CHAIRMAN STETKAR: Yes they should.

19 MR. JONES: They should be the same.

20 VICE CHAIRMAN STETKAR: Yes, okay.

21 MR. JONES: I guess that was what I was
22 struggling with.

23 VICE CHAIRMAN STETKAR: One of the things
24 that I look on this slide, for example, if I look at
25 the, you know, what are, there's a five percent pool

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 liner fragility, let's see, maybe some of, yes, maybe
2 they are. I'm sorry. I'm sorry maybe they are.

3 MR. JONES: Okay.

4 VICE CHAIRMAN STETKAR: 4.9, they're
5 organized a little differently but --

6 MR. JONES: Yes, they are organized a
7 little different, I'm sorry.

8 VICE CHAIRMAN STETKAR: Yes, I'm sorry
9 you're right. I retract all of that. These are.

10 MR. JONES: Okay.

11 VICE CHAIRMAN STETKAR: These are. The
12 base case, these, I'm sorry.

13 MR. JONES: Yes.

14 VICE CHAIRMAN STETKAR: Never mind.

15 MR. JONES: Okay.

16 (Simultaneous speaking)

17 MEMBER CORRADINI: How far back do you
18 want to retract on the statement?

19 VICE CHAIRMAN STETKAR: No, that's not --

20 (Simultaneous speaking)

21 MEMBER CORRADINI: I just want to be
22 clear.

23 MR. JONES: Okay, I hope I got that one.

24 VICE CHAIRMAN STETKAR: It happens.

25 MR. JONES: Using those frequencies and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applying the release fractions and cesium inventories
2 identified for the different groups and then the
3 overall consequence results from the MACCS2 analysis,
4 the cost-benefit analysis presents the resulting
5 economic and health consequences.

6 And predominately the base case is looking
7 at benefits within 50 miles considering the current
8 regulatory guidelines of \$2,000 per person-rem. And
9 then all cases for the, for all groups within the base
10 case, the cost outweigh the benefits for that
11 particular analysis.

12 Sensitivity analysis were performed to
13 consider the potential increase in the dollar per
14 person-rem factor to \$4,000 and also extended the
15 analysis to consider consequences beyond 50 miles. In
16 that case, again for Groups 1 and 2, the cost outweigh
17 the benefits for those plants.

18 However, for the Groups 3 and 4, the
19 benefits marginally outweigh the cost. And that's due
20 in part, for Group 3 predominately due to the longer
21 period of operation expected. And for Group 4,
22 there's somewhat higher consequences resulting from
23 the fact that two reactors are discharging to a single
24 pool.

25 CHAIRMAN ARMIJO: Steve?

1 MR. JONES: Yes.

2 CHAIRMAN ARMIJO: You know, beyond 50
3 miles, where do you stop? You know, you wind up over
4 the ocean or I mean, a few months ago there was a
5 Stanford study that basically covered the earth with
6 fallout from Fukushima. And of course they got a huge
7 population and they use the LNT and they got all sorts
8 of latent cancer fatalities.

9 In this analysis, where is, what's, you
10 know, greater than 50, does it take me around the
11 world or does it stop at the Atlantic Coast? Exactly
12 how did you do that?

13 MR. JONES: I guess I'd have to --

14 MR. WITT: If I could offer my thought on
15 it? I understood that the way that, out of
16 consequences beyond 50 miles are generally impacted as
17 by people repopulating the area. And so depending on
18 where they're repopulating I think is where the
19 consequences may rely.

20 CHAIRMAN ARMIJO: But people are
21 repopulating the area within 50 miles also.

22 MR. JONES: Correct.

23 CHAIRMAN ARMIJO: So I'm just trying to
24 find, you know, the population, number of people
25 exposed gets bigger the further out you go and then at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some point you run out of people. Maybe over the
2 ocean or something. How do you do that?

3 MR. JONES: Don may be able to address the
4 truncation that was --

5 MR. HELTON: Hi, this is Don Helton of the
6 Office of Nuclear Regulatory Research. We'd have to
7 get back to you with a very precise answer but you
8 should be thinking in terms of out to 500, either 500
9 or 1,000 miles.

10 So in the direction of the Atlantic Ocean
11 for a site like Peach Bottom, you would reach the
12 Atlantic Ocean and the other three directions you
13 would not have. And for other sites obviously
14 different situations. But that's the mental notion
15 you should have.

16 CHAIRMAN ARMIJO: So as far as out as
17 there are people?

18 MR. HELTON: No, it would be 500. Like I
19 said, if it was pre-coded calculation, we'd have to
20 check to whether, partially due to calculations as to
21 whether it was done to 500 or 1,000.

22 CHAIRMAN ARMIJO: Okay.

23 MR. HELTON: But I think also, I think
24 it's 500. But so the point being, no, it's not as far
25 out as it could go, it's to that distance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: Okay.

2 VICE CHAIRMAN STETKAR: We're roughly
3 picking up about a factor of six and a half to seven
4 depending on the group in terms of addition, you know,
5 latent cancer fatalities, avoided person-rem or
6 something like that.

7 MR. SCHOFER: Averted dose.

8 VICE CHAIRMAN STETKAR: Averted dose,
9 thank you, Fred.

10 CHAIRMAN ARMIJO: Okay, I just want to
11 know where it ended.

12 MR. JONES: Okay, based on these results
13 the staff does not recommend that additional studies
14 be pursued to further refine the assumptions that went
15 into this based on the relative cost here and the
16 benefits that could be achieved. Next slide please.

17 They want to hit specifically on
18 mitigation sensitivities. That was a major component
19 of our subcommittee discussions.

20 And then as we mentioned before, we made
21 a conservative assumption going in that the base case
22 would assume effective mitigation only for the
23 alternative of low-density storage and ineffective
24 mitigation for the baseline to maximize the delta
25 among the four different, basically four different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cases that were considered in this spent fuel pool
2 study. And that's really what provided the
3 information that allows us to differentiate between
4 low and high-density storage cases.

5 For the, if we assumed ineffective
6 mitigation for both, that would slightly reduce the
7 calculated benefits because you would have somewhat
8 greater consequences from the low-density storage
9 case. However, because we are already, as I mentioned
10 earlier I guess, there's a greater than factor of ten
11 difference in the magnitude of the release fraction
12 that's assumed between the low-density and high-
13 density cases.

14 And overall that dominates and therefore
15 there would not be a substantial change in the, net
16 benefits and the resulting conclusion.

17 CHAIRMAN ARMIJO: Do you have numbers,
18 like the release fractions, when you, this case?

19 MR. JONES: The release fractions we'd,
20 would remain silent.

21 CHAIRMAN ARMIJO: Excuse me?

22 MR. JONES: The release fractions remain
23 silent.

24 CHAIRMAN ARMIJO: Right.

25 MR. JONES: The release fractions constant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for all the events that are determined to lead to
2 release. And on Slide 15 we showed that the, for the
3 elevated pools, Group 1 plants, the assumption was a
4 40 percent release fraction for the high-density
5 storage and three percent for the low-density.

6 MR. SCHOFER: Yes, what changes is the
7 release frequency if you have successful mitigation
8 you're changing release frequency and then the delta
9 between the two.

10 CHAIRMAN ARMIJO: Okay. What were the
11 values for release frequency with and without
12 mitigation before the --

13 MR. JONES: Right. The release
14 frequencies as I've mentioned before, from the Spent
15 Fuel Pool Study, both the low density and high density
16 cases assumed to have the same release frequency prior
17 to assuming any effective mitigation.

18 If you assume mitigation you basically
19 reduce the frequency shown here at the bottom by a
20 factor of 20 for the respective groups. The top
21 number, so it would be about one times ten to the
22 minus seven for the elevated pool case and a little
23 bit less than that for Groups 2, 3, and 4, for the low
24 density case.

25 And then for the high density case it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the fraction shown here, or did I, I didn't do that
2 right.

3 (Simultaneous speaking)

4 MR. JONES: I'm sorry. It's about --

5 CHAIRMAN ARMIJO: Is that a backup chart
6 or do we have --

7 MR. JONES: Well if you take 2.7, roughly,
8 2.7 times ten to the minus seven for the Group 1 case
9 assuming mitigation and it would be 1.8, roughly,
10 times ten to the minus seven for the Groups 2, 3, and
11 4.

12 CHAIRMAN ARMIJO: For Alternative 1?

13 MR. JONES: For the low density storage
14 case, assuming effective mitigation.

15 CHAIRMAN ARMIJO: Alternative 2?

16 MR. JONES: I'm just --

17 CHAIRMAN ARMIJO: And when you --

18 MR. JONES: -- dividing the numbers on the
19 bottom by 20.

20 CHAIRMAN ARMIJO: All right. Well I'm
21 lost, but maybe when --

22 MEMBER RICCARDELLA: Let me ask a
23 question. On Slide 20 on your second bullet you said
24 that "assuming ineffective mitigation would not change
25 the conclusion."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What conclusion are we talking about? Are
2 we talking about the conclusion that there's no
3 benefit or are we talking about the conclusion
4 regarding that specific case that says one, you know,
5 you had some cases that came through, but, yes, the
6 low density option is preferable, does it change that
7 conclusion for that case?

8 MR. JONES: All the conclusions, the
9 conclusion we're referring to is the overall result of
10 the Cost Benefit Analysis --

11 MEMBER RICCARDELLA: Okay.

12 MR. JONES: -- and all the conclusions on
13 Slide 19 remain the same. The change is too small to
14 affect any of those numbers.

15 CHAIRMAN ARMIJO: I think Pete was asking
16 whether it changes the benefits?

17 MEMBER RICCARDELLA: Yes.

18 MR. JONES: It does change the benefits.

19 CHAIRMAN ARMIJO: And that's really where
20 we're at, you know, if it changes the benefit
21 substantially then we'd like to know by how much.

22 MR. SCHOFER: It reduces the delta benefit
23 and the conclusion he's talking about, it remains not
24 cost beneficial, so at the bottom the net is negative.
25 So when he says the conclusion doesn't change, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 remains negative and it goes a little bit more
2 negative because the net benefit is smaller.

3 CONSULTANT SHACK: What happens to the
4 \$500 billion benefit in a high case?

5 CHAIRMAN ARMIJO: Yes. Those are the
6 things that, you know, really worries --

7 MR. WITT: Well, for the high case, it
8 wouldn't have changed for ineffective because that's
9 already --

10 MR. JONES: That doesn't have mitigation
11 --

12 MR. SCHOFER: If you assume effective
13 mitigation for both cases to the same amount -
14 significant, you know, it reduces your benefits
15 significantly --

16 CHAIRMAN ARMIJO: Which is more consistent
17 with your conclusion.

18 MR. SCHOFER: -- one or millions to --

19 MEMBER RICCARDELLA: That's what bothers
20 us. It's consistent with your conclusion whereas when
21 you do this effective mitigation for the Alternative
22 2 and no effective mitigation for Alternative 1, you
23 wind up in some of the high cases of sensitivity
24 studies with enormous or very attractive benefits for
25 an alternative that you then say it's not worth

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pursuing.

2 So it's a big problem that, you know,
3 you're kind of contradicting yourself.

4 CHAIRMAN ARMIJO: That's the crux of our
5 concern.

6 MR. JONES: That is the --

7 MEMBER RICCARDELLA: Yes. That's not the
8 overall conclusion, it's that when you run some cases
9 with apples and oranges, you come out with results
10 that don't support your overall conclusion.

11 CHAIRMAN ARMIJO: That's a big concern not
12 necessarily that, you know, a specialist who do cost
13 benefit analysis and know the rules of the game and
14 that this is really the basis for the decision.

15 It may be okay, but, you know, the general
16 public out there --

17 MEMBER RICCARDELLA: They're going to want
18 to understand this.

19 CHAIRMAN ARMIJO: -- and they're going to
20 say, gee, these guys show really big benefits. Well,
21 and then they chose to ignore them. You know, I'll
22 tell you if I, the people that I talk to really look
23 at these things and they say, you guys are ignoring
24 your own analysis.

25 MEMBER RAY: Yes, it's the people who do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understand it who have an agenda and use it in the way
2 that you're supposed --

3 (Laughter)

4 MEMBER RAY: Plus they have biggest risk,
5 Sam, is that people will use the information out of
6 context to advance an agenda.

7 CHAIRMAN ARMIJO: I agree with you,
8 Harold, but there are people who don't understand at
9 all.

10 (Simultaneous speaking)

11 CHAIRMAN ARMIJO: People being in good
12 faith look at the tables, would look at a bar chart
13 that shows low case, base case, high case, and then
14 sensitivity study.

15 And the Alternative 2 look wonderful in
16 the high case and incredibly good in the sensitivity
17 study, and then we say but don't pay attention to
18 that.

19 Just there's a, if nothing else, a
20 communication problem, but it just is very difficult
21 to understand. I know you were trying not to
22 undermine, not to hide any benefit that might be
23 inherent in the alternative, that was a good thing.

24 But if you try too hard you can justify
25 anything and I think you tried too hard and so when --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Crediting mitigation for both cases and comparing them
2 apples and apples is the right way to go.

3 I believe that would support your
4 conclusion much more and it's also logical. So --

5 MEMBER BANERJEE: Would it support your
6 conclusion more? So what would be, if you did an
7 apples to apples calculation how would the benefits be
8 impacted for the high case?

9 MR. JONES: I think the main issue there
10 is determining what, you know, what success fraction
11 you would give for mitigation implementation.

12 MALE PARTICIPANT: Just make it apples to
13 apples.

14 MEMBER RICCARDELLA: Or use a bunch of
15 different success ratios, but use the same for both
16 options.

17 MR. SCHOFER: If you use the same success
18 rate as the low case you get roughly a factor of 20
19 decrease in benefits.

20 MR. JONES: Your higher case is the one.

21 (Simultaneous speaking)

22 MEMBER BANERJEE: It's the high case which
23 we are interested in. How would it -- oh, that was
24 for the high case.

25 VICE CHAIRMAN STETKAR: He meant to say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for the load, if they used the same success rate, 95
2 percent successful mitigation, for the high density
3 loading case you get a factor of 20 reduction.

4 I mean it's 5 percent failure.

5 MEMBER BANERJEE: Let's, yes, but that's
6 okay. Reverse and say if you had no mitigation in --

7 MR. SCHOFER: In either case.

8 MEMBER BANERJEE: -- either case, yes. I
9 mean that's the more --

10 MR. SCHOFER: You get like a 10 percent
11 reduction.

12 MEMBER BANERJEE: Only a 10 percent?

13 MR. SCHOFER: Yes.

14 MEMBER BANERJEE: That's what I think if
15 you do an apples to apples, what is the benefit in the
16 worst scenarios, that's really what, and you're saying
17 it's not that much, 10 percent or times ten?

18 MEMBER SCHULTZ: It would not change the
19 conclusion, that's the important --

20 MR. SCHOFER: 10 percent.

21 CHAIRMAN ARMIJO: But it changes the
22 numbers in the benefits, but it wouldn't change the --

23 MEMBER BANERJEE: How would it change the
24 numbers?

25 CHAIRMAN ARMIJO: -- conclusion of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specific case.

2 MEMBER RICCARDELLA: Right. That's what
3 we're really asking.

4 MEMBER BANERJEE: But that hits you
5 immediately when you read this. The high case has a
6 big benefit, looks like anyway.

7 MEMBER RICCARDELLA: I don't know what big
8 is, but a few hundred million or whatever.

9 VICE CHAIRMAN STETKAR: It seems like a --

10 MR. JONES: There's no doubt, I guess
11 there's a big, there's a difference in consequences,
12 but when you assume effective, when mitigation is
13 effective it dramatically reduces those or basically
14 eliminates the difference between the two cases.

15 MEMBER BANERJEE: But if mitigation was
16 not effective in both cases, does the difference stay
17 ineffective or -- is it substantiative?

18 MR. JONES: Yes, that's about a 10 percent
19 change in the benefits, but that doesn't change any of
20 conclusions really, but -

21 CHAIRMAN ARMIJO: I understand what you're
22 saying in comparison cost, cost benefit comparison.

23 MR. JONES: So the problem is determining
24 where between zero and 95 percent effective.

25 CHAIRMAN ARMIJO: Well I don't think it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 matters as long as it's even-handed. Unless you have
2 reason to believe that in the low density loading your
3 mitigation is likely to be much more effective than in
4 the high density loading and what would drive that?

5 Certainly not the liner vagility,
6 certainly not the fact whether a pump would work or
7 instrumentation would work, they're independent of a
8 density of loading.

9 Certainly not the heat loads because if
10 they, you know, you still have plenty of heat load
11 with a low density loading. So it all adds up, but,
12 you know, they would be about the same.

13 MEMBER RICCARDELLA: Is there a difference
14 in time to respond?

15 VICE CHAIRMAN STETKAR: That's about the
16 only factor that I could think of is some small
17 difference in the time for human response.

18 But it's -

19 CHAIRMAN ARMIJO: But it's not out -

20 VICE CHAIRMAN STETKAR: I mean as long as
21 you're out into hours it doesn't, differences don't
22 make much difference.

23 MEMBER SCHULTZ: There's ample time to
24 effect mitigation --

25 VICE CHAIRMAN STETKAR: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SCHULTZ: -- in both cases.

2 CHAIRMAN ARMIJO: Well you understand our
3 view, but I'm just coming back from a standpoint. As
4 specialists you understand this technology and you
5 understand the issues, you understand the practice,
6 and you can read these charts and you can say
7 obviously there's not benefit here.

8 We don't recommend it. But for people who
9 are less experienced, it looks like there's a huge
10 benefit, okay, and you're ignoring it. So it's,
11 sorry, that's the way it goes.

12 MEMBER BALLINGER: And, of course, sort
13 of, horses out the barn with a lot of this. Is there
14 a reason not to include another section --

15 VICE CHAIRMAN STETKAR: Yes.

16 MEMBER BALLINGER: -- in the document that
17 says, okay, if you compare apples to apples, well
18 these are the results that you get.

19 MR. WITT: Well, what the objective of our
20 paper was is to determine whether we need more
21 research or not and I don't think by including that
22 you would change that conclusion at all, but --

23 MEMBER BALLINGER: I'll agree with you,
24 but put your neighbors hat on.

25 MR. RECKLEY: This is Bill Reckley, and

1 part of the difficulty that you'll have is that this
2 discussion is likely to come up whenever we're dealing
3 with very large consequence, low frequency type of
4 events.

5 And we understand exactly what you're
6 saying, share the concern that it could be
7 misrepresented. The same could be said even if we
8 didn't have the discussions of the cost benefit.

9 Whenever you are doing an analysis which
10 needs to be done to support a calculation like this
11 where you're calculating those large consequences,
12 there is a concern that those consequences are going
13 to be brought out without the context of the frequency
14 in some of the other discussions we're having.

15 So I think we do share your view, but as
16 what Kevin was saying, really to, the purpose of this
17 was to make these simplifying assumptions to then
18 determine whether we needed to spend more resources
19 and more time to go and answer a question like, is the
20 mitigation of a high density pool one out of 20, one
21 out of 15?

22 Yes, we said it was zero which is, you
23 know, one extreme. We still come out saying it's not
24 cost beneficial to us, meaning it's not worth studying
25 whether it's one out 15, one out 17, or one out of 19,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to refine the process.

2 So we do understand the concern. I think
3 at this point, as someone else has said, this Report,
4 both the previous draft, this one, the Spent Fuel Pool
5 Study, all of this material is out there and to the
6 degree it's going to be misunderstood or even
7 misrepresented that, the barn door has been left open.

8 CHAIRMAN ARMIJO: I didn't worry about
9 misrepresentation because that's, it's the same people
10 that will do that, but I'm talking about people who in
11 good faith look at the Report and get, as minimum,
12 they get confused and at worst they say, they're just
13 ignoring their own analysis because they're determined
14 to come to that conclusion.

15 That's what I'm worried about and I see
16 what you've done and I understand what you've done,
17 but it's not going to play well in Peoria.

18 MEMBER SCHULTZ: I know we're moving
19 forward to discuss this in many different ways, but it
20 seems to me that for this particular situation we're
21 in fact, as you said, Bill, that we're talking about
22 low probability, high consequence events is the exact
23 reason why you shouldn't take one of the scenarios and
24 penalize it by a factor of 20, the frequency by a
25 factor of 20.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, therefore, be presenting that you
2 have one case that you've increased the frequency by
3 a factor of 20 for no reason except to see what the
4 sensitivity would be and present those as the results
5 of the analysis because of what we've been discussing
6 in terms of the perception that it can create.

7 And it would be better to say emphatically
8 that we can think of no reason, if you're going to do
9 that, then you also have to say we can think of no
10 reason why the mitigation between the high density and
11 low density would be different, but just to see what
12 would happen we're going to examine it.

13 Why would one do that, I don't know, but
14 you ought to at least say that, we can think of no
15 reason why the mitigation would be different, but our
16 results have been calculated in that way, and when we
17 do that we draw the same conclusion we do if we, we
18 draw this conclusion that we should not study this any
19 further.

20 So we have penalized it by a factor of 20.
21 You have to describe what a factor of 20 means
22 especially when you're talking about consequences to
23 a large population of people.

24 You have to describe what that means and
25 then you'll have an opportunity to make this case.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Even in that case we draw the same conclusion, but
2 it's difficult to have presented it in a way that we
3 have because of just that fact.

4 We're talking about low probability, high
5 consequences and we've put ourselves in a position
6 where we've calculated a difference that, as
7 engineers, we don't think is real.

8 The difference is not real. We can't
9 think of a reason why it would be this different, it's
10 not one in 17 or one in 19, it's one to one and a
11 half, or one to one and a quarter, I mean, they're
12 about the same.

13 CHAIRMAN ARMIJO: Okay. Well I guess
14 we've communicated our concern here, so I think it's
15 probably best just to keep going unless members want
16 to, let's just keep going.

17 MR. JONES: Okay. I did want to go over
18 the overall safety perspectives of the staff. The
19 spent fuel pools provide adequate protection and
20 defense in depth.

21 I want to point out the base case release
22 frequencies that we're using here are on the order of
23 a few times in a million years, a very low frequency.

24 And they don't consider the effective
25 deployment of mitigation capability if mitigation was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 effective most times that would dramatically reduce
2 that frequency to well below one in a million years.

3 Also, the spent fuel pools have defense in
4 depth. The pools are designed to have a very low
5 frequency of coolant loss and they are robust
6 structures. The Spent Fuel Pool Study and past
7 studies support that conclusion.

8 Also, actions taken since 2001 in
9 particular, but haven't provided additional measures
10 of protection against releases should the pool drain,
11 including dispersing the fuel to enhance the
12 capability for air cooling.

13 Provision of coolant makeup under cases
14 where there's damage to the plant or other causes
15 result in unavailability of the installed makeup
16 systems, and plants have a provided capability to
17 spray water on the pool to provide additional cooling
18 under cases where all ability to cool the fuel has
19 been lost.

20 CHAIRMAN ARMIJO: In those cases I want to
21 make, another issue that came up in preparing for the
22 meeting is, the fact that you didn't do, go further on
23 these other alternatives as far as regulatory analysis
24 or more analysis, was that something because you were
25 constrained by an SRM or some other thing or you just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 chose not to do it?

2 Because there's no question that, at least
3 for the plants that can do it, that one by eight
4 loading isn't very beneficial and can't be very
5 costly, certainly not like expedited fuel transfer.

6 And so I'm trying to understand why you
7 chose not to do it. Yes, it may still not be cost
8 beneficial in the strict sense of the word, but it's
9 awfully inexpensive and the benefits if you ever got
10 into trouble would be enormous.

11 I'm just trying to understand why the
12 staff didn't say, hey, there's simpler things we can
13 do that can take the heart out of the problem and less
14 costly things.

15 They may not apply to every plant in the
16 United States, it may be only certain kinds of plants
17 and certain kinds of pools, just didn't understand why
18 that wasn't pursued.

19 MR. WITT: Well I think our view is that
20 the benefits may not be as great either as obviously
21 moving to low density storage, so even though the cost
22 may be reduced, the benefits may be reduced as well.

23 CHAIRMAN ARMIJO: The benefits seem huge
24 from the Spent Fuel Pool Study.

25 MR. JONES: I guess what I would address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is that not all pools have the capacity to actually
2 reach a one by eight configuration with the existing
3 --

4 CHAIRMAN ARMIJO: I understand that.

5 MR. JONES: -- storage capacity. I think
6 we could look at this a --

7 (Simultaneous speaking)

8 MR. JONES: -- for voluntary initiative on
9 the part of industry, however, we're in the same
10 position where we look at probably greater benefits
11 from discharging and achieving a low density storage
12 and still not really seeing a substantial benefit in
13 terms of measurements with respect to the quantitative
14 health objectives and the cost benefit analysis
15 imposing a requirement to do that than --

16 CHAIRMAN ARMIJO: Yes. I understand that
17 point --

18 MR. SCHOFER: If I can just piggyback
19 Steve, if we would be imposing we would have to meet
20 the backfit criteria again, do a safety screen, verify
21 that you have a substantial safety enhancement.

22 If you don't meet that screen then, you
23 know, you can't do the backfit per se, and as the
24 paper indicates that, you know, we have in there that
25 we could discuss this with licensees who could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 voluntarily evaluate this for their own particular
2 plant and, you know, implement this if it's feasible.

3 MEMBER BANERJEE: But in all cases the
4 mitigation had a large effect if I remember. That was
5 the major way you could get benefits, right? And
6 you're saying that's not feasible for all the plants
7 or they don't have mitigation --

8 MR. SCHOFER: No, we're talking about the
9 one by eight.

10 MEMBER BANERJEE: Oh.

11 CHAIRMAN ARMIJO: Plant loading or
12 supplementary cooling capabilities --

13 MEMBER BANERJEE: I mean once you start
14 draining the damn pools --

15 MR. WITT: This talks about enhancement
16 and mitigation strategy. There were a couple cases in
17 the Spent Fuel Pool Study where the mitigation
18 capacities weren't sufficient to keep the fuel cool.

19 But it was only one or two scenarios,
20 right?

21 MR. JONES: That they were --

22 (Simultaneous speaking)

23 MR. JONES: And that was very early and
24 that was based on just the existing equipment that's
25 currently at the site. The next order does call for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 greater redundancy and components.

2 CHAIRMAN ARMIJO: So the expectation it
3 should be that we have a very high confidence that
4 we'll be able to mitigate these kinds of accidents and
5 --

6 MEMBER CORRADINI: So can I get a
7 clarification? So an answer to Sam's question about
8 the one by eight, you said you have to do a backfit
9 analysis.

10 What number would you use in the backfit
11 analysis, the 2000 or the 4000?

12 MR. SCHOFER: We do the substantial safety
13 enhancement screen first, which is the QHO -

14 MEMBER CORRADINI: Oh.

15 MR. SCHOFER: -- and if you don't meet
16 that hurdle then you're done. I mean --

17 MEMBER CORRADINI: Okay.

18 MEMBER BANERJEE: So the main effect is
19 that you just have less hot fuel in there? I mean it
20 leaves less, but won't the cool fuel be even hotter at
21 the end --

22 MR. SCHOFER: You have the same --

23 (Simultaneous speaking)

24 MR. SCHOFER: The hottest fuels fill in
25 the pool. The cooler fuel has been moved onto the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: But what I'm saying is
2 wouldn't the cool fuel also eventually burn?

3 MR. SCHOFER: Yes.

4 MEMBER BANERJEE: Well what difference
5 does that --

6 MR. SCHOFER: It may not, depends on the
7 --

8 CHAIRMAN ARMIJO: It may not reach the
9 condition that required to start fire. You know, it
10 may be the inherent benefit is in the event that you
11 have no mitigation at all, there's an advantage in
12 having less stuff to heat up and burn and release.
13 But there's a number there and that's okay, but we do
14 everything weird since we've learned from Fukushima is
15 put in better mitigation instrumentation, things like
16 that.

17 MEMBER BANERJEE: If you have a --

18 MR. JONES: I think that's what -

19 MEMBER BANERJEE: -- factual drain down
20 and, you know, you have no air cooling possible, it's
21 going to get too hot eventually and the stuff can, I
22 won't say burn, let's say it goes through rapid
23 chemical reaction.

24 MR. SCHOFER: All right. The Spent Fuel
25 Pool Study looked at the one by eight and saw that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one by eight looked similar to the low density.

2 MR. JONES: I think basically what we're
3 dealing with is the further you spread apart the high
4 heat sources the less likely, in certain sections the
5 zirconium are to reach the initiation temperature
6 required for either steam, you know, oxidation with
7 steam or oxidation with air, depending on the
8 circumstances.

9 MEMBER BANERJEE: But given enough time
10 they will, right? In a --

11 CHAIRMAN ARMIJO: Presumably you're -

12 MR. JONES: Not necessarily, it depends.

13 CHAIRMAN ARMIJO: -- if you're doing
14 something during that time.

15 MEMBER CORRADINI: The analysis says no.

16 MR. JONES: Hold on. The analysis -

17 MEMBER CORRADINI: You have to believe the
18 analysis, but the analysis says under those
19 conditions, no.

20 MR. JONES: The analysis did stop at 72
21 hours and I guess under marginal conditions there may
22 still be some potential for, if no action is taken for
23 that fuel to reach the initiation temperature.

24 MEMBER CORRADINI: I guess where I'm, I've
25 been listening to this and we're talking about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 numbers, I guess I'm kind of, at least at this point,
2 I'm with Sam.

3 If you're showing delay and you delay for
4 days and you're not trying to mitigate, I don't, I'm
5 lost. To me that's the obvious thing.

6 CHAIRMAN ARMIJO: Yes. That's
7 unrealistic.

8 MEMBER CORRADINI: And the only reason I
9 bring it up now is I've heard this argument before
10 about partial drain down, but if I've got partial
11 drain down dye extended, and as you said you've
12 stopped the calculation, you could invent some
13 condition at about the right elevation, in about the
14 right time, that if you just sat there and watched it
15 eventually it would cook.

16 But who in their right mind are going to
17 sit there and watch it? It gives you extended for
18 days to mitigate. That's where I guess when you were
19 asking the question that's what made me want to say
20 something, is that their analysis shows not
21 conclusively that it never is going to start not
22 reacting, but in so long of time --

23 MEMBER BANERJEE: But eventually it'll get
24 there. It takes longer.

25 MEMBER CORRADINI: Well it's all, I'm sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's all a function of some quantitative number, but
2 it's so late in time that if we take the one
3 historical event, days later they came back and
4 refilled.

5 So it's the mitigation, it's always the
6 mitigation.

7 CHAIRMAN ARMIJO: Okay. Any other
8 comments? Well I guess we should come to the
9 conclusion chart, we haven't quite got there.

10 MR. JONES: Yes. We skipped over one
11 slide, but --

12 CHAIRMAN ARMIJO: If we know what that is.
13 (Simultaneous speaking)

14 MR. JONES: There's one slide we skipped
15 over I think on quantitative health objectives, and we
16 did want to acknowledge that they were developed
17 predominantly for reactor accidents and the main thing
18 is that they're reflective of individual risk and that
19 spent fuel accidents could result in impact to larger
20 areas, I think as we discussed.

21 MEMBER RICCARDELLA: Why is this?

22 MR. JONES: Predominantly because there is
23 no robust containment around the spent fuel pools and
24 it is a high temperature event so the release could be
25 somewhat more energetic than a reactor at least with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 respect to the cesium and, therefore, go a little
2 further.

3 And while the staff could develop
4 alternative societal measures, I think the cost
5 benefit analysis plus the comparison, the large margin
6 to the QHOs, provides sufficient basis to not pursue
7 further analysis.

8 And that really gets to our conclusion
9 which is again the spent fuel pool accident results we
10 found less than, well less than 1 percent of the
11 quantitative health objectives, the costs of expedited
12 transfer generally outweigh the benefits we'd get for
13 reduced storage density and, therefore, we don't
14 recommend pursuing additional studies or pursuing any
15 regulatory action for those issues.

16 MEMBER SKILLMAN: Steve, I do have a
17 question on your second bullet. You do have within
18 the study the recognition that there is risk
19 associated with moving fuel, so I don't understand why
20 that second bullet doesn't include a phrase that, not
21 only the cost, but the risks have been considered?

22 Because the operator risk is not minimal.
23 There is a huge amount of activity to accomplish what
24 one might think this activity will give in terms of
25 benefit. Seems that that needs to be communicated in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that second bullet, and it is in your study.

2 MR. JONES: Okay.

3 MR. WITT: In our analysis we assume that
4 the expedited transfer was handled completely, safely
5 so that there was no negative impact on the benefits
6 or change, so --

7 MEMBER SKILLMAN: Well I understand that,
8 but I've just got to tell you, I think that that's a
9 flawed assumption. I think that, you know, if you're
10 going to say, like Ron says, to the people next door
11 there isn't any benefit, there needs to be at least a
12 token, comment about what the impact is on the staff
13 that might have to do this work because I think
14 there's this latent idea, well, gee whiz, if we just
15 move all the stuff offsite everything's going to be
16 Kumbaya.

17 And I believe that that is a flawed
18 assumption.

19 MR. RECKLEY: This is Bill Reckley again.
20 And we'll acknowledge that, we didn't call it
21 "flawed," we would simply say it was another
22 simplifying, conservative assumption that bias the
23 results and if this had come out a different way we
24 would have modeled that and many other things more
25 exactly in Phase II of our assessment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But, yes, we know it's a know it's a non-
2 physical thing and it was simply simplifying --

3 MEMBER SKILLMAN: Well, but you did get
4 etched in your studies, it's in the studies.

5 CHAIRMAN ARMIJO: It's mentioned.

6 MR. WITT: There's a number of things, the
7 qualitative aspects of this that kind of support our
8 conclusion that nothing else needs to be done here.
9 For instance, the costs associated with doing this,
10 we've had that discussion before, that the costs could
11 be significantly higher than what we assumed in here.

12 CHAIRMAN ARMIJO: Well we know for sure
13 that NRC costs would not be zero, and that was in your
14 whatever, your assumption in the cost for doing the
15 Alternative 2 and I think it would be enormous.

16 I think it would be such an enormous
17 distraction from the staff from things that are really
18 more important for safety and it would also cost
19 money, and that was not in the study, but you said
20 it's simplifying and it doesn't make --

21 MR. WITT: Well we added in qualitatively
22 to say that there's these other issues that we didn't
23 include in the analysis but it would support our
24 conclusion.

25 MEMBER REMPE: And one of those that we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 brought up in prior meetings is the fact that you
2 attribute the costs, or the casks to the EPRI Study
3 and we all have discussed numerous times about how the
4 costs would increase.

5 Although I noticed in the COMSECY that it
6 says "costs might be higher or lower," they don't
7 really say, imply that they could be higher. So if
8 you were presuming this again it might be good to
9 mention, too, as another item.

10 CHAIRMAN ARMIJO: We all have our views on
11 cost estimates and that it's a function of how many
12 times we've been wrong in the cost estimates.

13 (Laughter)

14 MEMBER REMPE: Well --

15 CHAIRMAN ARMIJO: And I've had my share.

16 MEMBER RAY: Nobody can possibly can see
17 that costs would be lower to accelerate because of the
18 supply of --

19 MEMBER CORRADINI: I think that was Joy.

20 MEMBER RAY: Yes, that is her point.

21 MEMBER REMPE: Yes.

22 MEMBER RAY: It isn't a matter of well, it
23 might be higher or it might be lower.

24 MEMBER REMPE: Which is what the COMSECY
25 says --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: It's going to be higher,
2 that's not true. It's going to higher.

3 MEMBER SCHULTZ: Yes. Well there's also
4 the nuclear safety aspect here. Sam, you mentioned
5 that it's going to divert, if we move in this
6 direction it would divert attention of the NRC.

7 It will also divert attention of reactor
8 staff. And that, both of those have a direct impact
9 on reactor safety.

10 CHAIRMAN ARMIJO: Okay. Any other
11 questions or comments from the staff? Well we're
12 ahead of schedule and I suggest we'll take 15 minutes
13 -- oh, yes, Dick?

14 MEMBER SKILLMAN: I think we ought to
15 thank this team. You've been in front of us a couple
16 times --

17 CHAIRMAN ARMIJO: Okay.

18 MEMBER REMPE: It's the same story.

19 CHAIRMAN ARMIJO: We're part of the team.

20 (Laughter)

21 (Simultaneous speaking)

22 MEMBER CORRADINI: I should've -- you are
23 dismissed.

24 CHAIRMAN ARMIJO: Please don't take our
25 difficult questioning and everything else, we really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 appreciate the amount of work you did in a very short
2 time and, again, you know what worries us and, so
3 we'll go from there.

4 We're going to check to see if there's
5 anybody on the line, on the bridge line. Does anyone
6 in the audience wish to make a comment?

7 Okay. The bridge line's open. Is there
8 anyone on the bridge line there?

9 MR. LEWIS: Yes there is. I am Marvin
10 Lewis, L-E-W-I-S.

11 CHAIRMAN ARMIJO: Mr. Lewis, please go
12 ahead.

13 MR. LEWIS: Well I was listening to you
14 talking about these assumptions and the what have you.
15 Not problematical, but I was just wondering why,
16 discuss the costs of accidents have increased with
17 time, even suggesting that as your frequency instead
18 of using the frequency assumptions that you did?

19 I hope I'm making myself clear, over.

20 VICE CHAIRMAN STETKAR: Actually, no, Mr.
21 Lewis. If you could, this is John Stetkar, and I'm
22 kind of PRA frequency guy, so if you could elaborate
23 a little bit your notion I'd certainly appreciate it
24 to better understand your concern.

25 MR. LEWIS: Well take a look at, we had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Chalk River, we've had Three Mile Island, we've had
2 this, we've had that, now we come to Fukushima which
3 is much worse than anything we've had previously,
4 including Chernobyl, as far as I can tell, and they're
5 very, very costly.

6 See and it's one thing to mess up the
7 backwoods of the Ukraine, it's another thing to mess
8 up a few miles from Tokyo, it's very, very expensive
9 and is so I figure, and that's what I'm pointing at.

10 I mean, yes, Three Mile Island, we had one
11 reactor, Chalk River we had one reactor. Even
12 Chernobyl, we had one reactor, now, we have three
13 reactors. Is this the way accidents are going to be
14 trending?

15 More and more reactors involved per
16 accident? Also, take a look at the frequency, back at
17 Chalk River we had one accident back in the backwoods,
18 not too costly as we got into Chernobyl, again
19 backwoods, at the Ukraine.

20 We get into Three Mile Island a few miles
21 from Harrisburg and a little more costly. I forget,
22 what 100 miles from Tokyo even more costly and more
23 reactors involved.

24 VICE CHAIRMAN STETKAR: Thanks a lot.
25 That helps.

1 MR. LEWIS: So accidents increase.

2 VICE CHAIRMAN STETKAR: Okay, we --

3 MR. LEWIS: Also the frequency increases.

4 We had Chalk River, we had Three Mile Island -

5 VICE CHAIRMAN STETKAR: I think we
6 understand your point, Mr. Lewis. Thanks for
7 elaborating that clarifies it I think quite a bit.
8 Thank you.

9 CHAIRMAN ARMIJO: Is there anyone else on
10 the bridge line that cares to make a comment? Okay,
11 hearing none, I think what we're going to do is take
12 a break for 15 minutes and reconvene at 3:10 p.m. and
13 we'll start on our discussion on the biannual ACRS
14 Report.

15 (Whereupon, the meeting in the above-
16 entitled matter was concluded at 2:55 p.m.)

17

18

19

20

21

22

23

24

25



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Japan Lessons Learned Tier 3 Issue: Expedited Transfer of Spent Fuel to Dry Cask Storage

Kevin Witt, NRR/JLD/PSB

Steven Jones, NRR/DSS/SBPB

Fred Schofer, NRR/DPR/PRMB

ACRS Full Committee Briefing

December 4, 2013

Agenda

- Background
- Tier 3 Evaluation Process
- Regulatory Analysis Modeling, Assumptions, and Results
- Conclusion

Background

- Spent Fuel Pool Study initiated in July 2011
 - Evaluates difference in consequences between high and low density SFP loadings at a reference plant
- Tier 3 Project Plan:
 - Determine whether the NRC should consider expedited transfer of spent fuel to dry casks
 - Utilizes information from past SFP studies and SFPS
 - Follows normal regulatory process utilizing Regulatory Analysis Guidelines (NUREG/BR-0058)
 - May 2013 Memo provided updated plan to Commission

Tier 3 Plan

- Phase 1 – Evaluate whether additional studies are needed to determine if regulatory action might be warranted (COMSECY-13-0030, November 12, 2013)
- Phase 2 – If directed, perform additional analysis (i.e., additional research on expedited transfer risk and minimize conservatisms)
- Phase 3 – If directed, consider other factors (criticality, mitigating strategies, solar storms, economic consequences, new regulatory framework, etc.)

Stakeholder Interactions

- Two public meetings held (August 22 and September 18)
 - Questions involving both SFPS and Expedited Fuel Transfer
 - Responding to letters received from stakeholders
- Spent Fuel Pool Study
 - Draft issued for public comment - June 2013
 - Written comments addressed in final report - October 2013
- Expedited Transfer Memorandum and Regulatory Analysis
 - Draft issued for public review - September 2013
 - ACRS Full Committee Presentation – October 2013
 - Non-concurrence from NRC staff
 - In response to stakeholder feedback, the staff provided additional detail addressing specific issues and reformatted analysis for clarity

COMSECY-13-0020 Revisions

- Table 2 – corrected liner fragility value
- Table 10 – corrected base case benefits
- Table 44 – corrected dose calculations for groups 2-4
- Table 56 – corrected dose calculations for group 1
- Table 60 – corrected dose calculations for groups 1-4
- Table 64 – corrected dose calculations for groups 2-4

Overview

Generic Regulatory Analysis

- Regulatory Assessment
- Expanded Plants (Generic by Groups)
- Expanded Scenarios

Regulatory Analysis for Reference Plant (Appendix D)

- Regulatory Assessment
- Specific Plant
- Expanded Scenarios

Spent Fuel Pool Study

- Consequence Study
- Specific Plant
- Specific Scenario

SFP Study Results

- The pool in this study survives the severe earthquake with no liner leakage 90 percent of the time
- Even if a leak occurs, spent fuel is only hot enough to cause a radiological release within a few months after the fuel is moved into the pool; otherwise the spent fuel is air-coolable for at least 72 hours
- Both high- and low-density pool loads generate a release with similar (but very low) frequency; high-density loading can lead to a larger release

SFP Study Results (continued)

- Public health and environmental effect estimates are generally the same or smaller than earlier studies
- The SFPS, together with previous research, confirms spent fuel pools adequately protect public health and safety
- The regulatory analysis for the reference plant indicates that expedited spent fuel transfer does not substantially enhance safety

SFPS and Tier 3 Regulatory Analysis

- **Spent Fuel Pool Study (Appendix D) and Tier 3 Regulatory Analysis consider initiating events beyond the event in SFPS:**
 - more severe earthquake
 - cask drop
 - loss of power/loss of coolant inventory events
- **Tier 3 Regulatory Analysis covers all SFP designs used with operating reactors in the Eastern and Central U.S.**
 - PWRs and BWRs with Mark III containments (spent fuel stored in at-grade pool separate from reactor building)
 - Western plants to be revisited following seismic re-evaluations
 - New reactors (AP-1000)
- **Assessment of security events handled separately**
 - regulatory changes implemented (e.g., 10 CFR 50.54(hh))
 - effect of security changes reflected in regulatory baseline

Tier 3 Evaluation Process

- **Safety Goal Screening Evaluation**
 - Based on the Commission Safety Goal Policy Statement
 - Used the Quantitative Health Objectives to evaluate achievement of the safety goals
- **Cost/Benefit Analysis**
 - Intended to identify maximum potential benefit
 - Analyzes costs and benefits for representative pool design groups

Safety Goal Screening

Bounding Release Frequency

- Bounding frequency of SFP release about 1 in 29,000 years (3.46×10^{-5} per year)
- Regulatory Analysis Table 43, High Estimate for Group 4 (highest total release frequency)

Conditional Probability of Fatal Cancer

- Conditional probability of an individual developing a fatal latent cancer within a ten-mile radius calculated to be 4.4×10^{-4} given a large SFP release from high-density pool (SFPS Table 34)
- Linear–no-threshold model with protective actions implemented

Individual Latent Cancer Fatality Risk

- Conservative latent cancer fatality risk estimate to an average individual within ten miles of 1 in 66 million (1.52×10^{-8} per year)
- Less than one percent of the individual risk goal of less than one-tenth of one percent of the average chance of developing a fatal cancer in the U.S. (2×10^{-6} per year)

Safety Goal Screening Results

- Marginal safety benefit based on comparison with QHOs
 - No risk of fatalities due to nature of release
 - Potential benefit is a very small fraction (0.76%) of latent cancer goal
 - Cancer risk relatively insensitive to magnitude of release due to slow accident progression and effective protective actions (SFPS)
- Minor or limited safety benefit below threshold of safety goal screening

Cost-Benefit Analysis Overview

- Evaluated one alternative - Expedited Transfer
 - Transfer fuel with more than 5 years decay to dry casks
 - Store remaining fuel in low-density configuration in existing racks
- Established SFP Groups
 - Four groups evaluated representing operating and new plants
- Major Assumptions (Regulatory Analysis Table 2)
 - Initiating SFP Event Frequencies and Accident Progression
 - Economic modeling (e.g., definition of representative plants, future spent fuel discharge projections)
 - Timing (e.g., dry cask storage loading, occupational dose)
- Established a base case
- Performed sensitivity studies

Assumptions to Maximize Calculated Benefit

- Release fraction and mitigation effectiveness assumptions provide conservative estimate of potential benefit
- Regulatory Baseline – Maintain the Existing Spent Fuel Storage Requirements
 - High cesium release fractions (SFPS value of ~40% for Elevated Pools and NUREG-1738 value of 75% for other groups in base case)
 - Assumed ineffective mitigation for this alternative
- Expedited Transfer Alternative - Low-density Spent Fuel Pool Storage
 - Low cesium release fractions (SFPS value of 3% for all groups in base case)
 - Assumed effective mitigation for this alternative

Base Case Analysis

- Staff considers base case appropriate for decision whether to pursue additional studies to refine assumptions
- Base case includes appropriately conservative assumptions, but not bounding values, for the following:
 - Initiating events (USGS 2008 information for Peach Bottom seismic hazard, and NUREG-1738 and NUREG-1353 for other initiators)
 - Seismic liner fragilities (based on results of SFPS and NUREG-1738)
 - Cesium inventories for each group (based on SFP capacity , amount of uranium, cooling periods, and fuel burnup for reactors in group)
 - Plume dispersion (used MAACS2 and Peach Bottom Meteorology)
 - Population density and economic activity (used data for Surry)
 - Industry implementation costs (used EPRI information)

Base Case Analysis (Continued)

- Uncertainty regarding spent fuel pool conditions (i.e., pool water level, fuel distribution, and location of liner tears)
 - Generally make bounding assumption of inadequate heat removal if fuel is uncovered for base case
 - Conservative because SFPS and other studies indicate substantial potential for air cooling when pool is drained or decay heat is low
 - Exception for Mark I and II BWRs
 - SFPS reduces uncertainty for specific scenario evaluated
 - Used SFPS information of 8% inadequate cooling for 0.7g PGA earthquake

Base Case Frequencies

Event	Base Case Frequency	Pool Liner Fragility	Inadequate Cooling	Release Frequency	Comments
Seismic Bin 3 (0.7g PGA)	Peach Bottom				
Elevated Pool	1.65×10^{-5}	10%	8%	1.35×10^{-7}	SFPS result
At-Grade Pool	1.65×10^{-5}	5%	100%	8.25×10^{-7}	
Seismic Bin 4 (1.2g PGA)	Peach Bottom				
Elevated Pool	4.90×10^{-6}	100%	100%	4.90×10^{-6}	
At-Grade Pool	4.90×10^{-6}	50%	100%	2.45×10^{-6}	
Cask Drop All Pools	2.0×10^{-7}	100%	100%	2.0×10^{-7}	Not always credible
Other Initiators					
Elevated Pool	2.37×10^{-7}	Not	100%	2.37×10^{-7}	
At-Grade Pool	2.67×10^{-7}	Applicable	100%	2.67×10^{-7}	
Total					
Elevated Pool				5.47×10^{-6}	About 90% seismic contribution
At-Grade Pool				3.74×10^{-6}	

Cost-Benefit Analysis Results

- Base case costs outweigh benefits
 - Benefits based on \$2000/person-rem within 50 miles
 - Changes in discount rate do not change conclusion
- Sensitivity Analyses (\$4000/person-rem and analysis beyond 50 miles) produce marginal benefits
 - Sensitivity base case costs outweigh benefits for Groups 1 & 2
 - Sensitivity base case benefits marginally outweigh costs for Groups 3 & 4
- The staff considers the base case an appropriately conservative analysis for use as the primary basis for the staff's recommendation that additional studies not be pursued and Tier 3 issue be closed

Mitigation Sensitivity

- Base case assumes effective mitigation for alternative and ineffective mitigation for baseline
 - Conservative assumption
- Assuming ineffective mitigation for both slightly reduces the benefits and would not change the conclusion
- Assuming effective mitigation for both significantly reduces benefits for all cases

Safety Perspectives

- Spent Fuel Pools provide adequate protection and defense-in-depth
- Overall estimated frequency of damage to stored fuel is low
 - Base case release frequencies for existing pools are on the order of a few times in a million years
 - These frequencies exclude effective deployment of mitigation capability and generally exclude consideration of air cooling
- Spent Fuel Pool Maintains Defense-in-Depth
 - Defense-in-depth consists of layers of protection with reliability of each layer commensurate with the frequency of challenges
 - SFP designed to prevent coolant inventory loss under accident conditions, which results in a low frequency of coolant inventory loss
 - Fuel dispersal, coolant makeup, and spray capability have reliability commensurate with the low frequency of coolant inventory loss

Use of QHOs for Screening

- Acknowledge that current safety goal screening, including QHOs, developed for reactor accidents
- Recognize that SFP accidents could result in larger areas and populations being affected than for reactor accidents
- Could develop alternative societal measures but with continued focus on public health and safety (SRM for SECY-12-0110)

Other Alternatives

- Examples include:
 - Alternative loading patterns
 - Direct offload of fuel into more coolable patterns
 - Enhancement of mitigation strategies
- Staff has considered these possible changes but determined that they do not provide a substantial safety enhancement such that generic regulatory action would be warranted

Conclusion

- Risks from SFP accidents are less than 1% of the Quantitative Health Objectives
- The costs of expedited transfer of spent fuel to dry cask storage outweigh the benefits
- Additional studies are not needed
- **No further regulatory action is recommended for the resolution of this issue and this Tier 3 item should be closed**



UNISTAR NUCLEAR ENERGY

**Presentation to ACRS Full Committee
U.S. EPR™
Calvert Cliffs Nuclear Power Plant Unit 3
FSAR Chapters 2.4, 2.5, 3, 9, 13 and 14
December 5, 2013**



Introduction



- Today Mark Finley, UniStar - President, CEO and CNO, will lead the Calvert Cliffs Unit 3 presentation.
- Presentation was prepared by UniStar and is supported by:
 - Robert Randall, UniStar –Engineering Manager
 - Antonio Fernandez, PhD, PE, UniStar – Structural/Seismic Engineering
 - Mark Hunter, UniStar – Director Operations and Maintenance
 - Onur Tastan, Rizzo Associates – Structural/Seismic Engineering
 - Todd Oswald, AREVA — U.S. EPR Technical Consultant Civil Structural
 - Ahmed “Jemie” Dababneh, PhD, Rizzo Associates –Technical Director
 - Shankar Rao, Bechtel – Project Engineer
 - Mustafa Samad, PhD, Bechtel – Sr. Engineering Specialist-Hydrology
 - Stephen Huddleston, AREVA – Engineering Manager, BOP Systems
 - Kelly Knight, PhD, Bechtel - Engineering Manager

Calvert Cliffs Unit 3
Chapters 2.4, 2.5, 3, 9, 13 and 14
Overview




<u>Calvert Cliffs Unit 3 Summary</u>				
<u>Chapter</u>	<u># Departures</u>	<u>#Exemptions</u>	<u># SER Open Items</u>	<u># SER Open Items Responses Submitted</u>
2.4	0	0	2	1
2.5	4	4	8	8
3	0	0	36	36
9	3	0	4	4
13	0	0	6	6
14	0	0	37	37
Totals	7	4	93	92



Calvert Cliffs Unit 3 ACRS Full Committee Meeting Introduction

- UNE is responsible for the design of Calvert Cliffs Unit 3 and develops the design primarily through contracts with Bechtel and AREVA.
- Reference Combined License Application (RCOLA) authored using 'Incorporate by Reference' (IBR) methodology.
- The focus of today's presentation will be a summary of the third set (4½) of FSAR Chapters that have been presented to the U.S. EPR ACRS Subcommittee.
- The first Calvert Cliffs Unit 3 ACRS Full Committee meeting, addressing the first set (9½) of FSAR Chapters, was conducted on April 7, 2011.
- The second Calvert Cliffs Unit 3 ACRS Full Committee meeting, addressing the second set (4) of FSAR Chapters, was conducted on April 12, 2012.
- For today's presentation only supplemental information, or site-specific information, departures or exemptions from the U.S. EPR FSAR are discussed.





List of Chapters



- Chapter 2.4, Hydrologic Engineering
- Chapter 2.5, Geology, Seismology, and Geotechnical Engineering
- Chapter 3, Design of Structures, Components, Equipment, and Systems, (except Section 3.7, Seismic Design)
- Chapter 9, Auxiliary Systems
- Chapter 13, Conduct of Operations
- Chapter 14, Verification Programs



Chapter 2.4 Hydrologic Engineering

2.4 HYDROLOGIC ENGINEERING

2.4 Hydrologic Engineering

Hydrologic Description

➤ Hydrological Characteristics

- The Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 3 site is located on the Calvert peninsula within the Chesapeake Bay watershed, adjacent to and southeast of CCNPP Units 1 and 2.
- The Chesapeake Bay constitutes the main water body influencing the siting of CCNPP Unit 3.
- The Calvert peninsula is formed by the Chesapeake Bay to the east and the Patuxent River to the west.
- Drainage in the vicinity of the CCNPP site includes several small streams and creeks, which fall within two sub-watersheds of the Chesapeake Bay with the drainage divide running nearly parallel to the shoreline.
- All streams and creeks near the CCNPP Unit 3 site east of Maryland State Highway (MD) 2/4 are non-tidal.

2.4 Hydrologic Engineering

Hydrologic Description



➤ Plant Siting

- The CCNPP Unit 3 safety-related structures, systems and components (SSCs) will be located within the Maryland Western Shore Watershed at the Power Block area and at the Ultimate Heat Sink (UHS) Makeup Water Intake Structure (MWIS) area.
- Access to safety-related structures, systems and components (SSCs) in the power block area will be located at or above Elevation 84.6 ft.
- The deck of the UHS MWIS will be at approximately Elevation 11.5 ft with openings or entrances to the MWIS located at or above Elevation 36.5 ft.

2.4 Hydrologic Engineering Hydrologic Description


Aerial View of CCNPP Unit 3 Site on the Calvert Peninsula



2.4 Hydrologic Engineering

Hydrologic Description

CCNPP Unit 3 Site Area



2.4 Hydrologic Engineering

Probable Maximum Surge and Seiche Flooding




- Probable Maximum Storm Surge (PMSS) and Seiche Flooding
 - The Sea, Lake, and Overland Surges from Hurricanes (SLOSH) model predicted a maximum surge elevation at the site of 11.0 ft from a water level of 0.0 NGVD 29. The simulated surge height was then adjusted to take into account the 20% margin (SLOSH model uncertainties) suggested in Technical Report National Weather Service (NWS) 48 (Jelesnianski, 1992) and the antecedent water level of 4.4 ft NGVD 29. The final PMSS elevation thus obtained is 17.6 ft NGVD 29.
 - The maximum wave runup on the intake structure was computed to be 15.6 ft. This runup, combined with the PMSS, will reach an elevation of 33.2 ft NGVD 29 as shown on Figure 2.4-33.
 - Because the effects of seiche oscillation are eliminated by a change in sustained wind direction, any existing seiche oscillation in the Chesapeake Bay prior to the arrival of any hurricane will be eliminated by the strong and changing wind field of the hurricane. Hence, resonance of seiche oscillation with PMSS is precluded.

2.4 Hydrologic Engineering

Probable Maximum Surge and Seiche Flooding

Figure 2.4-33— {Schematic Diagram Wave Runup on the UHS Makeup Water Intake Structure (MWIS)}




Drawing not to scale

2.4 Hydrologic Engineering

Probable Maximum Surge and Seiche Flooding

UHS MWIS Cross Section



UHS MAKEUP WATER INTAKE STRUCTURE
ELEVATION LOOKING EAST



2.4 Hydrologic Engineering

Probable Maximum Tsunami Flooding



- Probable Maximum Tsunami (PMT) Flooding
 - The PMT amplitude and drawdown at the CCNPP site were computed for the three potential tsunami sources using the maximum and minimum tsunami-induced water surface elevations.
 - The maximum simulated amplitude and drawdown at the CCNPP site were obtained from the postulated submarine landslide at the Virginia-North Carolina continental shelf off the coast of Norfolk, Virginia.
 - The PMT amplitude was estimated to be 1.71 ft above the antecedent water level. Combining with the antecedent water level of 4.34 ft and tsunami runup of 5.13 ft, the PMT high water level is estimated as 11.18 ft or rounded up to 11.5 ft.
 - The PMT drawdown was estimated to be 1.24 ft below the antecedent water level. Combining with the mean lower-low water antecedent water level, the PMT low water level is estimated as -1.23 ft or rounded down to -1.5 ft.
 - Because the maximum and the minimum water levels at the CCNPP site would be affected by storm surges, the maximum and minimum water levels from the PMT did not represent limiting flood or low water design bases for the CCNPP site.

2.4 Hydrologic Engineering Groundwater




- Groundwater in the surficial aquifer at the Calvert Cliffs Unit 3 site is aggressive (pH ~5.2).
 - This affects the portions of structures that are below the water table (at least 30' below power block grade) but not at MWIS.
 - Waterproofing system will protect the portions of the Nuclear Island (NI) and Essential Service Water Buildings (ESWBs) that are below the groundwater water table.
 - Water level will be monitored behind waterproofing system with the capability to dewater if necessary.
 - Dampproofing system will protect the Emergency Power Generating Buildings (EPGBs) that are above groundwater table.
- UHS Makeup water (from Chesapeake Bay) is brackish.
 - Concrete structures subject to brackish water (MWIS and ESWB) will use concrete with a maximum water-cementitious materials ratio of 0.4 and a minimum compressive strength of 5000 pounds per square inch (psi).

2.4 Hydrologic Engineering Groundwater

Waterproofing system will protect the portions of the NI and Essential Service Water Buildings (ESWBs) below the groundwater table.

- Waterproofing system
 - Primary and secondary membranes
 - Groundwater monitor system
 - Vertical drainage system placed between primary and secondary systems to facilitate flow of leaked groundwater down to sump pumps



Chapter 2.4 Hydrologic Engineering Summary



- Fifteen (15) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 2.4
- No ASLB Contentions
- No Departures or exemptions from the U.S. EPR
- Two (2) SER Open Items
- One SER Open Item Request for Additional Information (RAI) has been responded to, and the other is scheduled for early 2014.



**Chapter 2.5 Geology, Seismology,
and Geotechnical Engineering**

**2.5 GEOLOGY, SEISMOLOGY, AND
GEOTECHNICAL ENGINEERING**

2.5 Geology, Seismology, and Geotechnical Engineering Vibratory Ground Motion



- Vibratory Ground Motion
 - A detailed review of the vibratory ground motion assessment was carried out for the CCNPP Unit 3 site, resulting in the development of the CCNPP Unit 3 Ground Motion Response Spectra.
 - As the first step in this process, a Probabilistic Seismic Hazard Assessment (PSHA) for a hard rock condition was performed taking into account guidance in NRC Regulatory Guide 1.208.
 - ✓ The recently developed seismic source characterization (SSC) for the Central and Eastern United States (CEUS SSC) (EPRI/DOE/NRC, 2012)
 - ✓ The EPRI (2004, 2006) ground motion characterization (GMC) model.

2.5 Geology, Seismology, and Geotechnical Engineering Vibratory Ground Motion




➤ Mineral Virginia Earthquake

- August 23, 2011, M 5.8 from the Central Virginia Seismic Zone (CVSZ)
- CEUS SSC catalog predates the Mineral Virginia Earthquake (MVE).
- UniStar has performed the necessary evaluations to verify that the CEUS 2012 SSC catalog adequately accounts for events such as the MVE.
- Mineral Virginia Earthquake and Aftershocks (SER-Open Item RAI 385)


2.5 Geology, Seismology, and Geotechnical Engineering Vibratory Ground Motion

IMPACT OF 2012 CEUS SSC



2.5 Geology, Seismology, and Geotechnical Engineering Vibratory Ground Motion

Safe Shutdown Earthquake (SSE) & Certified Seismic Design Response Spectra (CSDRS)



The site specific soil structure interaction (SSI) analysis is performed with the use of the CCNPP Unit 3 SSE, therefore, the exceedance will be directly accounted for in the design of structures, systems, and components.

2.5 Geology, Seismology, and Geotechnical Engineering Departure/Exemption

Departure/Exemption from Minimum Shear Wave Velocity

- Departure/Exemption: Low Strain Shear Wave Velocity
 - The shear wave velocity (LOW STRAIN), at the foundation elevation of the Emergency Power Generation Buildings (EPGBs), is lower than 1000 fps, which is the minimum requirement defined by the U.S. EPR.
 - This departure/exemption is reconciled in FSAR Section 3.7 with a site-specific soil structure (SSI) interaction analysis.

Departure/Exemption from Safe Shutdown Earthquake

- Departure/Exemption: Safe Shutdown Earthquake (SSE) exceeds the US EPR Certified Design Response Spectra (CSDRS) at low frequencies (< 0.3 Hz)
 - This departure/exemption is reconciled in FSAR Section 3.7 with a site-specific soil structure (SSI) interaction analysis that uses the SSE as the seismic input

2.5 Geology, Seismology, and Geotechnical Engineering Departure/Exemption

Departure/Exemption from Soil Properties

- Departure/Exemption: soil properties that fall beyond the analysis bounds of the U.S. EPR (Minimum dynamic bearing capacity, Maximum angle of internal friction, Soil Density, Minimum Coefficient of Static Friction: 0.47, NAB Coefficients of Friction (μ): 0.47)
 - This departure/exemption is reconciled in FSAR Section 3.7 with soil structure interaction and stability analyses that use the site-specific soil properties

Departure/Exemption from Maximum Differential Settlement of 1/2 inch/50 ft (1/1200) Any Direction Across the Basemat


- Emergency Power Generating Buildings (EPGBs) & Essential Service Water Buildings (ESWBs) estimated site-specific tilt is higher than the allowable value.
 - Evaluation of the effects of the higher tilt, a finite element analysis of the EPGB & ESWB
 - ✓ Results show that increase in design moment based on the additional tilt is less than the U.S. EPR FSAR maximum design moment.
- Therefore, EPGB & ESWB basemats are structurally adequate to resist the increased moments.

2.5 Geology, Seismology, and Geotechnical Engineering Settlement



- The settlement (total settlement and tilt) and excavation related heave of the CCNPP Powerblock Area was carried out under the following premises:
 - Develop a 3D finite element model capable of capturing irregular subsurface conditions, realistic foundation footprint shapes, and asymmetric building loads.
 - Perform a time-dependent simulation, that provides settlement and tilt estimates as a function of time through and after construction.
 - Incorporate a construction sequence and examine the behavior of settlement and tilt as buildings are erected.
 - Account for asymmetric topography, by recognizing that reloading time to original consolidation pressure after excavation, will be variable throughout the foundation footprint.
 - Perform the settlement analysis simultaneously for the NI and adjacent facilities, including the detached safety related structures (EPGB and ESWB).
- The settlement model in the Intake Area is developed in a similar form. The model is much simpler and the influence of neighboring structures is negligible.

2.5 Geology, Seismology, and Geotechnical Engineering Settlement



Notes:

- Low Elevation: revert to loading modulus at the end of the 2nd load step (140 days)
- Medium Elevation (1): revert to loading modulus at the end of the 3rd load step (300 days)
- Medium Elevation (2): revert to loading modulus at the end of the 4th load step (500 days)
- High Elevation: revert to loading modulus at the end of the 5th load step (800 days)
- Long term settlement estimate due to creep and rewatering offset each other and are not significant

Chapter 2.5 Geology, Seismology, and Geotechnical Engineering Summary



- Eleven (11) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 2.5
- No ASLB Contentions
- Four (4) Departures and four (4) Exemptions from the U.S. EPR FSAR for Calvert Cliffs Unit 3, Chapter 2.5
- Eight (8) SER Open Items
- All RAI responses have been submitted



**Chapter 3 Design of Structures,
Components, Equipment and Systems
(except 3.7, Seismic Design)**



3.8 Design of Category I Structures

Design of Structures, Components, Equipment and Systems Other Seismic Category I Structures



Description of the Structures

- The standard plant layout and design of other Seismic Category I Structures is as described in the U.S. EPR FSAR without departures.
- The site-specific Seismic Category I structures are:
 - Forebay and UHS Makeup Water Intake Structure (MWIS)
 - Buried Conduit Duct banks
 - Buried Pipe


Design of Structures, Components, Equipment and Systems Foundations




Forebay and UHS Makeup Water Intake Structure

- The Seismic Category I Forebay and UHS MWIS are reinforced concrete structures situated along Chesapeake Bay.
- The UHS MWIS is integrally connected with the Forebay basemat.
- Seismic Category II Circulating Water System (CWS) Makeup Water Intake Structure and Seismic Category I Forebay and UHS Makeup Water Intake Structure share a 5 ft thick common basemat.
- Forebay and UHS Makeup Water Intake Structure
 - Reinforced concrete shear wall and slabs are designed for seismic (including hydrodynamic loads) and non-seismic load combinations.
 - Exterior walls are designed to withstand
 - ✓ Tornado missile impact and
 - ✓ Wave pressures of the Probable Maximum Hurricane (PMH)
 - ✓ Standard Project Hurricane (SPH) severe environmental event
 - Checked for sliding, overturning, and flotation using the stability load combination.

Design of Structures, Components, Equipment and Systems Foundations






Chapter 3

Design of Structures, Components, Equipment and Systems

Summary

- Seventy-six (76) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 3
- No ASLB Contentions
- No Departures or exemptions from the U.S. EPR FSAR for Calvert Cliffs Unit 3, Chapter 3
- Thirty-six (36) SER Open Items
- All RAI responses have been submitted



Chapter 9

Auxiliary Systems

9.2 WATER SYSTEMS

9.2 WATER SYSTEMS

Ultimate Heat Sink (UHS) Makeup System Supplemental Information



- Ultimate Heat Sink (UHS) Makeup System
 - Normal nonsafety-related Essential Service Water makeup provides desalinated water to replenish UHS inventory losses.
 - UHS cooling tower normal blowdown discharges water to the retention basin.
 - Emergency safety-related UHS Makeup Water system provides Chesapeake Bay makeup water to each operating UHS cooling tower basin, starting 72 hours post-accident, at a maximum flow rate of 750 gpm and approximately 510 gpm of makeup when the screen wash is operating (300 gpm is required to the basin).
 - Emergency safety-related blowdown is provided, if the normal path is unavailable.
 - The UHS Makeup Water System is designed to permit periodic inspection of components necessary to maintain the integrity and capability of the system to comply with 10 CFR 50 Appendix A, General Design Criterion (GDC) 45.
 - The UHS Makeup Water System is designed to permit operational functional testing of safety-related components to ensure operability and performance of the system to comply with 10 CFR 50 Appendix A, GDC 46.

9.2 WATER SYSTEMS

Post-DBA UHS Makeup Keep-Fill Piping Departure



- Departure: Post-Design Basis Accident (DBA) UHS Makeup Keep-Fill Piping
 - The U.S. EPR Figure 9.2.5-1 does not contain a provision to compensate for the UHS Makeup Water System leakage and maintain the water level in the piping full at all times.
 - The normal UHS makeup keep fill system is designed to provide desalinated water to maintain UHS makeup system full during normal plant operation.
 - The Post-DBA UHS Makeup Keep-Fill line is added to deliver makeup water from the Essential Service Water System (ESWS) to the UHS Makeup Water System to compensate for the leakage loss due to pressure boundary isolation valves, and to keep the UHS Makeup Water System piping full of water at all times.
 - Therefore, the ESWS Emergency Makeup Water line piping and the ESW System return line piping are modified from the configuration in the design certification.
 - The UHS Makeup Water System pressure boundary is maintained through the safety-related Post-DBA UHS Makeup Keep-Fill line check valve.

9.2 WATER SYSTEMS

Ultimate Heat Sink (UHS) Makeup System Cooling Tower Basin



- Maximum Evaporation and Drift in the Ultimate Heat Sink
 - The U.S. EPR and CCNPP Unit 3 utilize the same 72-hour period of temperature data to determine maximum evaporation of water from the UHS. Therefore, the worst CCNPP Unit 3 meteorological conditions resulting in maximum evaporation and drift loss of water for the UHS over a 72 hour period are bounded by U.S. EPR FSAR Table 9.2.5-3.
 - The Technical Specification required UHS Cooling Tower basin minimum inventory is sufficient to provide 72 hours of cooling following a DBA without makeup.
 - The CCNPP Unit 3 UHS Makeup Water System provides ≥ 300 gpm (required by USEPR FSAR), of makeup water to the each of the four UHS Cooling Tower basin starting 72 hours post DBA.
 - The CCNPP Unit 3 UHS Makeup Water pumps are sized to provide a maximum of approximately 750 gpm to the UHS Cooling Tower basin to maintain adequate Net Positive Suction Head (NPSH) for the ESWS pump for up to 30 days after the DBA and providing for intermittent operation of the screen wash system.

9.2 WATER SYSTEMS

Ultimate Heat Sink (UHS) Makeup System Cooling Tower Basin

- The maximum non-coincident wet bulb temperature plus the site-specific wet bulb correction factor for Calvert Cliffs 3 exceeds the value provided in U.S. EPR FSAR Table 9.2.5-2, and, therefore, a site specific analysis was done:
 - The U.S. EPR FSAR Table 9.2.5-2 value is 81°F, and the correction factor is 2.5°F.
 - The site-specific maximum (0% exceedance) non-coincident wet bulb temperature is 85.3°F.
 - The site-specific wet bulb correction factor was determined by computational fluid dynamics analysis, considering the meteorology of the site, to be less than 2.5°F.
 - UHS cooling tower performance was verified by showing that the maximum UHS cold water return temperature was less than 95°F, assuming the worst combination of 24-hour temperature conditions from the perspective of minimum cooling from a 30-year hourly regional climatological data set, and assuming a correction factor of 2.5°F.

9.2 WATER SYSTEMS

Ultimate Heat Sink (UHS) Makeup System Mechanical Draft Cooling Towers



- UHS Cooling Tower Interference on Safety-Related Intakes
 - An evaluation has been performed of the interference effects of the UHS cooling tower plumes on nearby safety-related air intakes.
 - The evaluation concluded that there are no adverse effects on the safety functions of the systems, either due to insensitivity to higher wet bulb temperatures or design features that isolate the fresh air intake of the system.
 - For Main Control Room (MCR) and Safeguard Building (SB) Heating Ventilation & Air Conditioning (HVAC), there is sufficient margin in the system to accommodate the minor effects of a small wet bulb temperature increase – determined to be less than 2.5°F by computational fluid dynamics analysis.

Chapter 9 Auxiliary Systems Summary



- Thirty Five (35) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 9
- No ASLB Contentions
- Three (3) Departures and No Exemptions from the U.S. EPR FSAR Chapter 9
- Four (4) SER Open Items
- All RAI responses have been submitted



Chapter 13 Conduct of Operations

13.2 TRAINING


13.2 Training Training Programs



- Training
 - Follows NEI 06-13A “Template for an Industry Training Program Description” including Appendix A (Cold License Training plan) of NEI 06-13A
 - Non-licensed Plant Staff Training Program
 - ✓ 18 months prior to scheduled date of initial fuel load
 - Reactor Operator Training Program
 - ✓ 18 months prior to scheduled date of initial fuel load

13.2 Training Training Programs

Hiring and Training Schedule of Plant Staff





Chapter 13 Conduct of Operations

13.3 EMERGENCY PLANNING

13.3 Emergency Planning Emergency Planning



- Emergency Planning
 - A comprehensive Emergency Plan is provided in COLA Part 5, Emergency Plan.
 - Emergency Plan, Revision 8, for CC3 was issued April 30, 2013.
 - Emergency Plan incorporates new EP Rule Hostile action requirements.
 - NEI 10-05 for staffing analysis has been addressed.
 - NUREG 0654\FEMA Rep-1 requirements have been incorporated.

Chapter 13

Conduct of Operations

Summary




- Twelve (12) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 13
- No ASLB Contentions
- No Departures/Exemptions from the U.S. EPR FSAR Chapter 13
- Six (6) SER Open Items
- All RAI responses have been submitted



Chapter 14, Verification Programs

14.3 INSPECTIONS, TESTS, ANALYSES, AND ACCEPTANCE CRITERIA (ITAAC)



Verification Programs Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC)

- ITAAC sets (Total: 1521) consist of:
 - Design Certification ITAAC (DC-ITAAC) (1275)
 - COLA ITAAC (246)
 - Site Specific system ITAAC (SS-ITAAC)
 - Emergency Planning ITAAC (EP-ITAAC)
 - Physical Security ITAAC (PS-ITAAC)

Chapter 14

Verification Programs

Summary



- Sixteen (16) COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 14
- No ASLB Contentions
- No Departures and no Exemptions from the U.S. EPR FSAR
- Thirty-seven (37) SER Open Items
- All RAI responses have been submitted



CONCLUSIONS

Chapters 2.4, 2.5, 3, 9, 13 and 14 Conclusions



- No ASLB Contentions
- There are seven (7) departures and four (4) exemptions.
- Responses have been submitted to 92 of the 93 SER Open Items.
- As of December 05, 2013, eighteen (18) of the nineteen (19) Chapters of the Calvert Cliffs Unit 3 FSAR have completed Phase 3 (all but Chapter 1, which does not require ACRS review).

Acronyms

- **ACRS – Advisory Committee on Reactor Safeguards**
- **ASLB – Atomic Safety & Licensing Board**
- **CCNPP – Calvert Cliffs Nuclear Power Plant**
- **CSDRS – Certified Seismic Design Response Spectra**
- **CEUS – Central and Eastern United States**
- **COL – Combined License**
- **COLA – COL Application**
- **CVSZ – Central Virginia Seismic Zone**
- **CWS – Circulating Water System**
- **DBA – Design Basis Accident**
- **EPGB – Emergency Power Generating Building**
- **ESWB – Essential Service Water Building**
- **ESWS – Essential Service Water System**
- **FSAR – Final Safety Analysis Report**
- **GDC – General Design Criterion**
- **GMC – ground motion characterization**
- **HVAC – Heating Ventilation & Air Conditioning**
- **IBR – Incorporate by Reference**
- **ITAAC – Inspections, Tests, Analyses, and Acceptance Criteria**
- **MCR – Main Control Room**
- **MVE– Mineral Virginia Earthquake**
- **MWIS – Makeup Water Intake Structure**
- **NI – Nuclear Island**
- **NPSH – Net Positive Suction Head**
- **NWS – National Weather Service**
- **PMH – Probable Maximum Hurricane**
- **PMSS – Probable Maximum Storm Surge**
- **PMT – Probable Maximum Tsunami**
- **PSHA – Probabilistic Seismic Hazard Assessment**
- **RAI – Request for Additional Information**
- **RCOLA – Reference COL Application**
- **SB – Safeguards Building**
- **SER – Safety Evaluation Report**
- **SLOSH – Sea, Lake, and Overland Surges from Hurricanes**
- **SPH – Standard Project Hurricane**
- **SSC – seismic source characterization**
- **SSCs – Structures, Systems and Components**
- **SSE – Safe Shutdown Earthquake**
- **SSI – soil structure interaction**
- **UHS – Ultimate Heat Sink**



Presentation to the ACRS Full Committee – 610th Meeting

**Briefing on Calvert Cliffs Unit 3 COL Application Safety Evaluation
with Open Items for FSAR Chapters/sections 2.4, 2.5, 3 (except 3.7) 9,
13, and 14**

**Mike Takacs - Presenter
Surinder Arora – Lead Project Manager**

December 5, 2013

Major Milestones - Chronology

07/13/2007	Part 1 of the COL Application (Partial) submitted
12/14/2007	Part 1, Rev. 1, submitted
03/14/2008	Part 1, Rev. 2, & Part 2 of the Application submitted
08/01/2008	Revision 3 submitted
03/09/2009	Revision 4 submitted
06/30/2009	Revision 5 submitted
09/30/2009	Revision 6 submitted
12/20/2010	Revision 7 submitted
03/27/2012	Revision 8 submitted
03/28/13	Revision 9 submitted
11/6/13	ACRS subcommittee review complete for the remaining Phase 2 Chapters.

Review Schedule

Phase - Activity	Target Date
Phase 1 - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI)	April 2010 (Actual)
Phase 2 - SER with Open Items	October 9, 2013
Phase 3 – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items	December 2013
Phase 4 - Advanced SER with No Open Items	Schedule under Review
Phase 5 - ACRS Review of Advanced SER with No Open Items	Schedule under Review
Phase 6 – Final SER with No Open Items	Schedule under Review

Summary of SE with OI: Section 2.4 Hydrologic Engineering



SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
2.4	Hydrologic Engineering	3	2
Totals		3	2

Summary of SE with OI: Section 2.4 Hydrologic Engineering



- **RAI 400, Question 2.4-1:** Inconsistent Depiction of CCNPP Unit 3 Site Boundary - FSAR Revision 9 Figure 2.4-1 shows the outline of the CCNPP Unit 3 site boundary that appears to be inconsistent with FSAR Figures 2.4-17 and 2.4-25.
- **RAI 400, Question 2.4-2:** Estimate of Bounding Value for Subsidence Resulting from Plant Groundwater Use - verify that the estimate of drawdown and subsidence remains bounding given the potential operational use of groundwater identified in the COL FSAR.

Summary of SE with OI: Section 2.5 - Geological, Seismology, and Geotechnical Engineering



SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
2.5.1	Basic Geologic and Seismic Information	74	0
2.5.2	Vibratory Ground Motion	26	2
2.5.3	Surface Faulting	1	0
2.5.4	Stability of Subsurface Materials and Foundations	33	2
2.5.5	Stability of Slopes	1	0
Totals		135	4

Summary of SE with OI: Section 2.5.2 - Vibratory Ground Motion



- **RAI 381, Question 02.05.02-25:** the staff requested hazard contributions of individual seismic sources to conduct an independent confirmatory study. The staff has not finalized its confirmatory study.
- **RAI 386, Question 02.05.02-26:** the staff requested further information on the sensitivity study conducted to analyze the impact of the Mineral, VA earthquake on the seismicity rate increases.

Summary of SE with OI: Chapter 3 - Design of Structures, Components Equipment and Systems

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
3.2	Classification of Structures, Systems, and Components	13	0
3.3	Wind and Tornado Loadings	4	0
3.4	Water Level (Flood) Design	1	0
3.5	Missile Protection	33	3
3.6	Protection Against Dynamic Effects Associated with Postulated Rupture of Piping	2	0
3.7	Seismic Design	n/a	n/a
3.8	Design of Category I Structures	51	7
3.9	Mechanical Systems and Components	15	2
3.10	Seismic and Dynamic Qualification of Mechanical and Electrical Equipment	1	0
3.11	Environmental Qualification of Mechanical and Electrical Equipment	11	1
3.12	ASME Code Class 1, 2, and 3 Piping Systems, Piping Components, and their Associated Supports	1	1
3.13	Threaded Fasteners (ASME Code Class 1, 2, and 3)	0	0
Totals		132	14

Summary of SE with OI: Section 3.5 – Missile Protection



- **RAI 376, Question 03.05.01.03-23:** requests the applicant to provide justification on how the Jaquet electronic turbine overspeed protection system reliability data would be equivalent to that provided by a different supplier, and to evaluate how the associated ITAAC commitment is impacted by a different supplier's reliability data.
- **RAI 376, Question 03.05.01.03-24:** requests that applicant to explain how Alstom Document 75C10001 includes all the relevant information such as valve types, valve control, and overspeed protection systems etc. that is included in the U.S. EPR FSAR standard steam turbine.
- **RAI 376, Question 03.05.01.03-25:** requests that the applicant reference all of the reports associated with the turbine missile probability analysis, probability of fatigue, and probability of destructive overspeed in the COL FSAR.

Summary of SE with OI: Section 3.8 – Design of Category I Structures

- **RAI 301, Question 03.08.04-21:** requests a detailed description of the sliding analysis for each SC-I structure. The description should include the values of itemized lateral forces applied and values of itemized shear resistance.
- **RAI 333, Question 03.08.04-32:** requests additional information to justify the assumption that only the East Wall of the UHS MWIS is subject to breaking wave pressure. Requests information on the consideration of the run-up water elevation in the design of the exterior walls of the UHS MWIS.
- **RAI 339, Question 03.08.04-33:** requests the technical basis that the CCNPP method to determine the design member forces due to seismic loads is at least as conservative as the U.S. EPR method or more detailed methods.

Summary of SE with OI: Section 3.8 – Design of Category I Structures

- **RAI 339, Question 03.08.04-34:** requests the values of the maximum soil pressures considering all locations of the CBIS basemat design, explanation on how these pressures are obtained, and explanation whether the CCNPP Unit 3 bearing capacities provided in the FSAR are the bearing capacities for localized pressure.
- **RAI 308, Question 03.08.05-9:** requests to explain how the new and updated COL Items regarding settlement of the ESWBs will be addressed and what site-specific conditions will be considered. Also requests to provide additional information on the methodology and procedures used for the settlement evaluation of the CBIS foundation.

Summary of SE with OI: Chapter 9 Auxiliary Systems

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
9.1	Fuel Storage and Handling	2	0
9.2	Water Systems	36	1
9.3	Process Auxiliaries	IBR	0
9.4	Air Conditioning, Heating, Cooling, and Ventilation Systems	8	0
9.5	Other Auxiliary Systems	23	0
Totals		69	1

Summary of SE with OI: Section 9.2 Water Systems

- **RAI 398, Question 09.02.05-32:** Clarification related to the CFD computer model uncertainties, meteorological conditions, and boundary scenarios regarding UHS cooling towers.

Summary of SE with OI: Chapter 13 Conduct of Operations

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
13.1	Organizational Structure of Applicant	1	0
13.2	Training	1	0
13.3	Emergency Planning	66	8
13.4	Operational Program Implementation	1	0
13.5	Plant Procedures	0	0
13.6	Security	109	0
13.7	Fitness for Duty	4	0
13.8	Cyber Security	4	0
Totals		186	8

Summary of SE with OI: Chapter 14 Verification Programs

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
14.1	Specific Information for the Initial Plant Test Program	0	0
14.2	Initial Plant Test Program	60	0
14.3	Inspections, Tests, Analyses, and Acceptance Criteria	0	0
14.3.1	Selection Criteria and Methodology	45	0
14.3.2	Structural and Systems Engineering	20	1
14.3.3	Piping Systems and Components	5	1
14.3.4	Reactor Systems	0	0
14.3.5	Instrumentation and Controls	0	0

Summary of SE with OI: Chapter 14 Verification Programs (cont.)

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
14.3.6	Electrical Systems	2	0
14.3.7	Plant Systems	1	0
14.3.8	Radiation Protection	0	0
14.3.9	Human Factors Engineering	0	0
14.3.10	Emergency Planning	3	0
14.3.11	Containment Systems	0	0
14.3.12	Physical Security Hardware	8	0
Totals		146	2

Summary of SE with OI: Sections 14.3.2, Structural and Systems Engineering and 14.3.3, Piping Systems and Components



- **RAI 367, Question 14.03.02-20:** Request to provide design information for seismic Category-II structures to meet ITAAC requirements for ensuring that failure of non-Seismic Category I structures will not impair the safety capability of adjacent safety-related SSCs.
- **RAI 161, Question 14.03.03-02:** For clarity and inspectability, the staff determined that three ITAAC covering 1) design, 2) fabrication and installation, and 3) as-built reconciliation are necessary and sufficient to ensure the piping systems and components are properly designed and constructed in accordance with the ASME Code Section III requirements.

ACRONYMS

- ASME - American Society of Mechanical Engineers
- EAL - Emergency Action Level
- EPGB - Emergency Power Generating Buildings
- ESWB - Essential Service Water Buildings
- CBIS - Common Basemat Intake Structure
- UHS MWIS - Ultimate Heat Sink Makeup Water Intake Structure
- CWS MWIS - Circulating Water System Makeup Water Intake Structure
- PMH - Probable Maximum Hurricane
- SPH - Standard Project Hurricane
- CS - Conventional Seismic
- CCNPP - Calvert Cliff Nuclear Power Plant
- CFD - Computational Fluid Dynamics
- NI - Nuclear Island



US-APWR

Design Certification Application

Chapters 6 and 7
Topical Report supporting Chapter 6
LTCC / GSI-191

ACRS Full Committee Presentation

December 5, 2013

Mitsubishi Heavy Industries, Ltd.

Presenters



- **Ryan Sprengel**
 - ✓ DCD Licensing Manager
- **Rebecca Steinman**
 - ✓ DCD Licensing Engineer, Ch 6
- **Erin Wisler**
 - ✓ DCD Licensing Engineer, Ch 7

➤ Previous ACRS Full Committee meetings

- ✓ September 9, 2011 – Chapters covered: 2, 5, 8, 10, 11, 12, 13, 16
- ✓ September 6, 2012 – Chapter 9 covered
- ✓ April 11, 2013 – Chapters 4, 15, 17, 19; Topical Reports supporting Chapters 4 and 15, respectively

➤ Significant upcoming submittals

- ✓ Ch 6 MUAP-07031 Rev. 2 to be submitted, Dec 2013
- ✓ Ch 7 MUAP-07005 Rev. 9 to be submitted, Dec 2013
- ✓ Ch 15 LB and SB LOCA topical reports revisions submitted, Dec 2013

➤ Adjustment of ongoing US-APWR DC Activities

- ✓ Letter (UAP-HF-13256) submitted to NRC 11/5/2013
- ✓ Coordinated slowdown of DCD Licensing Activities, while maintaining a commitment to US-APWR

- **ACRS Subcommittee meeting held September 17, 2013**
- **Remaining SE Open Items**
 - ✓ Items in which MHI submitted response that is awaiting staff review / confirmation of closure
 - Sparger hydrodynamic loading
 - Design change impact on M&E release analysis under secondary system piping rupture
 - Ch 15 RAIs tied to debris impacts on boron precipitation / LTCC
 - ✓ Other open items have alignment with NRC Staff and closure path is confirmation of changes in DCD Rev. 4
- **Written responses to ACRS SC questions to be submitted, December 2013**
- **No current RAIs**

- **ACRS Subcommittee meeting held October 1, 2013**
- **Remaining SE Open Item**
 - ✓ Tier 2* designation of debris amounts
- **Written responses to 12 ACRS questions to be submitted, December 2013**
- **No current RAIs**

➤ **MUAP-07001, The Advanced Accumulator**

- ✓ ACRS Subcommittee meeting held September 18, 2013
- ✓ Staff issued public version of advance TRSE on 11/14/13
- ✓ MHI submitted ACC scaling revisions to the LB LOCA (MUAP-07011) 12/4/13 and SB LOCA (MUAP-07013) topical reports on 12/5/13

- **ACRS Subcommittee meeting held April 2013**
 - ✓ 14 questions requiring follow-up
 - ✓ Subsequent discussions held with Staff
- **Written responses to 14 ACRS questions submitted September 2013**
- **RAI responses corresponding to SE Open Items submitted and under Staff review**
 - ✓ Common cause failure, D3 coping analysis, post accident monitoring variables, and others
- **No current RAIs requiring MHI response**



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Full Committee – 610th Meeting

**United States – Advanced Pressurized Water Reactor (US-APWR)
Design Certification**

**Safety Evaluation Report with Open Items
for
Chapters 6 & 7**

**Safety Evaluation Report
for
Advanced Accumulator Topical Report**

**Perry Buckberg
US-APWR Design Certification Lead Project Manager**

December 5, 2013

US-APWR Design Certification Review Schedule

	COMPLETION DATE
Phase 1 – Preliminary Safety Evaluation Report (SER)	Completed
Phase 2 – SER with Open Items	May 2014
Phase 3 – ACRS Review of SER with Open Items	August 2014
Phase 4 – Advanced SER with No Open Items	February 2015
Phase 5 – ACRS Review of Advanced SER with No Open Items	April 2015
Phase 6 – Final SER with No Open Items	September 2015
Rulemaking	February 2016

Summary of the US-APWR Safety Evaluation Reports

- The staff has issued Safety Evaluation Reports (SERs) with Open Items for Chapters 2, 3 (partial), 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 15, 16, 17 and 19 (partial).
- Of the issued chapters, all but Chapter 3 (partial) have been presented to the ACRS Full Committee.
- The staff has also issued SERs for five US-APWR Topical Reports.

US-APWR Chapter 6

Engineered Safety Systems

- The SE for Chapter 6 addresses the engineered safety systems, engineered safety feature material, containment systems, emergency core cooling systems, habitability systems, fission product removal control systems, inservice inspection (ISI) of Class 2 and Class 3 components
- The following Chapter 6 Open Items were discussed during the September SC Meeting
 - ♦ **Open Item RAI 923-6420, Question 06.02.01-21:** Containment Internal Design Changes in the DCD
 - ♦ **Open Item RAI 1036-7079, Question 06.02.02-94:** Tube-side and Shell-side Fouling Factors Used for the CS/RHR HX Design
 - ♦ **Open Item RAI 597-4590, Question 06.03-85:** SI and RHR/CS Pump Testing
 - ♦ **Open Item RAI 881-6203, Question 06.03-104:** ITAAC for SI and RHR/CS Pump Testing

US-APWR Chapter 6

Engineered Safety Systems

- Open Items continued:
 - ♦ **Open Item RAI 391-2974, Question 06.03-35:** Lack of an Advance Accumulator Small Injection Flow Rate ITAAC
 - ♦ **Open Item RAI 982-6036, Question 06.03-111:** Emergency Letdown Sparger Design
 - ♦ **Open Item RAI 559-4387, Question 06.04-11:** Flood Barriers
 - ♦ **Open Item RAI 927-6460, Question 06.04-16:** Condensate equipment drain lines
 - ♦ **Open Item RAI 955-6585, Question 06.04-17:** Refrigerant Leak
- There were no staff action items from the September Subcommittee meeting related to Chapter 6.

US-APWR Advanced Accumulator Topical Report

- The following ACC Subjects were discussed during the September SC Meeting
 - ♦ Overview of Advanced Accumulator Design
 - Principle of Advanced Accumulator
 - ACC role in ECCS performance during LOCAs
 - ♦ ACC Scaled Testing/ Test Results Summary
 - ♦ ACC Characteristic Equations
 - ♦ Applicability of ACC Characteristic Equations
 - ♦ Uncertainty Evaluation and Treatment
 - ♦ CFD Scaling Analysis of the Advanced Accumulator
 - Scaling Bias
- There were no staff action items from the September Subcommittee meeting related to the AAC.

US-APWR Long Term Core Cooling

- The following LTCC Subjects were discussed during the October SC Meeting
 - ♦ GSI-191 Evaluation for Sump Performance
 - Break Selection
 - Debris Generation/Zone of Influence (ZOI)
 - Latent Debris
 - Debris Transport
 - Chemical Effects
 - Debris Source Term Control
 - ♦ Strainer Head Loss Evaluation
 - ♦ Ex-Vessel Downstream Effects

US-APWR Long Term Core Cooling

- ♦ In-Vessel Downstream Effects
 - Debris Bypass
 - Core Blockage Acceptance Criteria
 - Fuel Bundle Head Loss Testing
 - Debris Deposition Analysis
- ♦ Structural Design of Strainer/Debris Interceptors
- ♦ Net Positive Suction Head (NPSH)
- The following Chapter 6 Open Items related to LTCC were discussed during the October SC Meeting
 - ♦ **Open Item RAI 840-6096**
 - ♦ **Open Item RAI 997-7033**
 - ♦ **Open Item RAI 719-5352**
- There were no staff action items from the October Subcommittee meeting related to the LTCC.

US-APWR Chapter 7

Instrumentation and Controls

- Chapter 7 addresses the reactor trip system, engineered safety feature systems, analyses of the plant's responses to postulated disturbances and postulated equipment failures or malfunctions.
- The open items discussed during the April Subcommittee meeting are as follows:
 - ♦ **Open Item RAI 568-4588** - Selection criteria for PAM variables should be refined (7.5)
 - ♦ **Open Item RAI 753-5742 & Follow-up RAI 988-7021** - Basis for the inputs and assumptions used in D3 Coping Analysis (7.8)
 - ♦ **Open Item RAI 992-6999** - Sufficient evidence to demonstrate that the use of O-VDUs enhance the performance of the safety system ITAAC that adequately verifies testing for normal and abnormal data transmission conditions for all non-safety to safety interfaces (7.9)

US-APWR Chapter 7

Instrumentation and Controls

- Open Items continued:
 - ♦ **Open Item RAI 995-7024** - Process to flow down the requirements for MELTAC platform hardware/software components (7.1)
 - ♦ **Open Item RAI 993-7027** - Process to ensure vendor's safety software development process (7.1)
 - ♦ **Open Item RAI 996-7040** - How the plant would be adequately protected from each PCMS failure, including single failures and design defects. (7.7)
- ACRS SC Meeting Actions
 - ♦ MHI submitted written responses in September to 14 Subcommittee questions after discussions with the NRC Staff.
 - ♦ Two additional items will require NRC staff to update the SE.