

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: RO A1a

TASK NUMBER: Conduct of Operations

TASK TITLE: 3-SR-2, Mode 3 Operator Rounds, Table 1.12 through 1.22

K/A NUMBER: 2.1.7 K/A RATING: RO 4.4

TASK STANDARD: Perform Operator logs in accordance with SR-2 Instrument Checks and Observations for log tables 1.13 through 1.22. Verify acceptance criteria are satisfied in accordance with notes and if not notification to Unit Supervisor is completed.

LOCATION OF PERFORMANCE: Simulator

REFERENCES/PROCEDURES NEEDED: 3-SR-2, Instrument Checks and Observations

VALIDATION TIME: 30 minutes

PERFORMANCE TIME:

COMMENTS: _____

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY ___ UNSATISFACTORY ___

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: You are a Unit Operator assigned to Unit 3, and it is Friday morning at 0800. 3-SR-2, Instrument Checks and Observations, is being performed.

The plant is in MODE 3.

INITIATING CUE: The Unit Supervisor directs you as the Unit Operator to complete a portion of 3-SR-2 day shift checks and observations Attachment 2 Surveillance Procedure Data Package Modes 1, 2, and 3 (pages 17 of 88 to 26 of 88) for Friday at 0800.

All readings that are already completed are correct and need not be checked by you.

Simulator

INITIAL CONDITIONS: You are a Unit Operator assigned to Unit 3, and it is Friday morning at 0800. 3-SR-2, Instrument Checks and Observations, is being performed.

The plant is in MODE 3.

INITIATING CUE: The Unit Supervisor directs you as the Unit Operator to complete a portion of 3-SR-2 day shift checks and observations Attachment 2 Surveillance Procedure Data Package Modes 1, 2, and 3 (pages 17 of 88 to 26 of 88) for Friday at 0800.

All readings that are already completed are correct and need not be checked by you.

START TIME _____

Performance Step 1:

Critical Not Critical

Attachment 2
(Page 18 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)				
Criteria Source: Technical Requirements Manual TSR-3.4.1.1				
LOCATION: Panel 3-9-4				Review Initials
	3-CR-43-11A/12A Ch 1 (μmho) Note 1	MAX (AC)	UO	Unit Supvr
Friday		1.0 μmho		
Saturday				
Sunday				
Monday				
Tuesday				
Wednesday				
Thursday				

- (1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify Chemistry to sample according to 3-SI-4.6.B.1-4.

Standard:

Records a Reactor Coolant Conductivity reading of .057 or .058 μmho . Initials under UO.

SAT__ UNSAT__ N/A__ COMMENTS: _____

Performance Step 2:

Critical X Not Critical

Attachment 2
(Page 19 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 3-9-3					Review Initials
	3-LI-64-54A (inches) Note 1	3-LI-64-66 (inches) Note 1	LIMITS (AC)	UO	Unit Supvr
Friday			≥-5.5 inches and ≤ -2.0 inches (Note 2)		
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 3-LI-64-54A and 3-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

Standard:

Records a Suppression Pool Level of (-) 2.75 inches; plus or minus 0.5 inches in both columns. Initials under UO.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 3:

Critical X Not Critical

Attachment 2
(Page 20 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times. (Refer to P&L Step 3.6A)						
Surveillance Requirements:		3.6.1.4.1						
LOCATION:		ICS Computer or 3-TI-82 or 3-TR-80-1					Review Initials	
	TIME	ICS Pt TEST2500 (°F) Note 1	3-TI-82 Value (°F) Note 1	3-TR-80-1(PT A08) (°F) (Note 1,2)	LIMITS (AC)	UO	Unit Supvr	
Friday	0800				≤ 150°F			
Saturday	0800							
Sunday	0800							
Monday	0800							
Tuesday	0800							
Wednesday	0800							
Thursday	0800							

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 OR 3-TI-82 OR 3-TR-80-1. Only one of the two methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 3-TR-80-1 to allow the point to be displayed.

Standard:

Records a Drywell Air Temperature from ICS of 104.1 °F; plus or minus 0.1 °F in the column under ICS Pt TEST2500. Initials under UO.

SAT__ UNSAT__ N/A__ COMMENTS: _____

Performance Step 4:

Critical Not Critical X

Attachment 2
(Page 21 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY:		Mode 1 (FROM 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.) Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements:		3.6.2.6.1		Technical Requirements Manual TSRs: 3.3.5.1			
LOCATION:		Panel 3-9-3				Review Initials	
	TIME	3-PDI-64-137 (psid) ≤ 1.33 psid (Note 1)	3-PDI-64-138 (psid) ≤ 1.33 psid (Note 1)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800			≥ 1.1 psid & ≤ 1.33 psid	0.10 psid		
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

(1) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

Standard:

Records a Drywell – Suppression Chamber Differential pressure of 1.1 to 1.2 psid in both columns. Initials under UO.

SAT__ UNSAT__ N/A __COMMENTS:_____

Performance Step 5:

Critical X Not Critical

Attachment 2
(Page 22 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE		DAY SHIFT		WEEK: _____ to _____				
APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)						
Surveillance Requirements:		3.6.2.1.1						
LOCATION:		Panel 3-9-3				Panel 3-25-32	Review Initials	
	3-TI-64-181 (°F) Notes 1,3, & 4 (AC)	3-TR-64-181 3-TM-64-181L (°F) Notes 1,3, & 4 (AC)	3-TI-64-182 (°F) Notes 1,3, & 4 (AC)	3-TR-64-182 3-TM-64-182L (°F) Notes 1,3, & 4 (AC)	MAX DELTA TEMP between instruments (Note 2)	3-TI-64-55B Notes 1,3, & 4 < 95°F	UO	Unit Supvr
Friday					CR Instruments within 5°F of each other and < 95°F			
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

(1) Limits:

- A. ≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed.
- B. ≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and
- C. ≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7

(2)

This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or if 3-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, Refer To site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 3-TI-64-55B affects LCO 3.3.3.2, "Backup Control System.

(3)

Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 3-SR-3.6.2.1.1.

(4)

If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

Standard:

Records Suppression Pool Water Temperature of 87.5 °F; plus or minus 2.5 °F in all 4 columns under Panel 9-3. Initials under UO.

SAT__ UNSAT__ N/A __COMMENTS:_____

Performance Step 6:

*Critical X Not Critical

Attachment 2
(Page 23 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 3-9-3							Review Initials	
	CS Loop I 3-PI-75-20 (psig)	RHR Loop I 3-PI-74-51 (psig)	RHR Loop II 3-PI-74-65 (psig)	CS Loop II 3-PI-75-48 (psig)	MIN (AC) Note 2	MAX Note 3	UO	Unit Supvr
Friday					For each OPERABLE subsystem:	For each OPERABLE subsystem: 100 psig		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

(1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.

(2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer To TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig

(3) MAX criteria is N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

Standard:

*Records a CS Loop I Fill Pressure of 50 psig (±) 5 psig and for *CS Loop II Discharge Fill Pressure of 50 psig (±) 5 psig. *Records a RHR Loop I Discharge Fill Pressure of 40 psig; (±) 5 psig. Records NA or 270 psig for RHR Loop II because it is in Shutdown Cooling. Initials under UO. *Informs Unit Supervisor that RHR Loop I discharge pressure is less than the minimum required discharge pressure of 48 psig.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 7:

Critical X Not Critical

**Attachment 2
(Page 24 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20 RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION PUMP OPERATION DAY SHIFT WEEK: _____ to _____

APPLICABILITY:		MODE 3, with reactor steam dome pressure less than the RHR low pressure permissive pressure. (Refer To P&L Step 3.6A) (Note 1) Readings are required at all times.									
Surveillance Requirements:		3.4.7.1									
LOCATION:		Panel 3-9-3 & Panel 3-9-4								Review Initials	
	TIME	Recirc Pump Note 2		RHR Shutdown Cooling Subsystem Note 2 & 3				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800							≥ One RHR Shutdown Cooling Subsystem OR ≥ One Recirc Pump In Service			
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHRSW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An “X” shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (3-XA-55-3D, Window 11) RESET.

Standard:

Places an X under RR Pump B for being in service and an X under RHR Shutdown Cooling Subsystem D for being in service. Records SAT in all data Column. Initials under UO.

SAT__ UNSAT__ N/A __COMMENTS:_____

Performance Step 8:

Critical X Not Critical

Attachment 2
(Page 25 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING		DAY SHIFT	WEEK: _____ to _____
APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)			
Surveillance Requirements: 3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)			
LOCATION: Panel 3-9-10			Review Initials
REACTOR ZONE EXHAUST RADIATION MONITOR			
3-RM-90-142		3-RM-90-143	
Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)
Friday			
Saturday			
Sunday			
Monday			
Tuesday			
Wednesday			
Thursday			
REFUEL ZONE EXHAUST RADIATION MONITOR			
3-RM-90-140		3-RM-90-141	
Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)
Friday			
Saturday			
Sunday			
Monday			
Tuesday			
Wednesday			
Thursday			

Standard:

Records Reactor Zone Exhaust Radiation Monitor readings of 1.0 mr/hr for both RM-90-142 and RM-90-143; plus or minus 0.5 mr/hr for Detector A and B. Records Refuel Zone Exhaust Radiation Monitor readings of 26.0 mr/hr for RM-90-140; plus or minus 1.0 mr/hr for Detector A and B. For RM-90-141 records reading of 50 mr/hr; plus or minus 1 mr/hr for Detector A and B. Initials under UO. Informs Unit Supervisor that Refuel Zone Exhaust Radiation Monitors are outside the MAX deviation of 20 mr/hr.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 9:

*Critical Not Critical

Attachment 2
(Page 26 of 88)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRSW RADIATION MONITORS		DAY SHIFT	WEEK: _____ to _____			
APPLICABILITY: During RHRSW Loop Operation Readings are required at all times. (Refer To P&L Step 3.6A)						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 3-9-2						
	3-RR-90-134		MAX (AC)	All Data SAT/UNSAT	Review Initials	
	3-RM-90-133 (channel 1) A & C HX (cpm)	3-RM-90-134 (channel 2) B & D HX (cpm)			UO	Unit Supvr
Friday			Note 1			
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

(1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRSW/RCW EFFLUENT RADIATION HIGH 3-RA-90-132 (Panel 3-9-3, 3-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

Standard:

Records NA for RM-90-133 or a reading of 300 cpm. *Records a reading for RM-90-134 of 300 cpm; plus or minus 10 cpm. *Records SAT in all data Column. *Initials under UO.

SAT__ UNSAT__ N/A__ COMMENTS: _____

END OF TASK

STOP TIME _____

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: RO A1a

TASK NUMBER: Conduct of Operations

TASK TITLE: 2-SR-2, Mode 3 Operator Rounds, Table 1.13 through 1.22

K/A NUMBER: 2.1.7 K/A RATING: RO 4.4

TASK STANDARD: Perform Operator logs in accordance with SR-2 Instrument Checks and Observations for log tables 1.13 through 1.22. Verify acceptance criteria are satisfied in accordance with notes and if not notification to Unit Supervisor is completed.

LOCATION OF PERFORMANCE: Simulator

REFERENCES/PROCEDURES NEEDED: 2-SR-2, Instrument Checks and Observations

VALIDATION TIME: 30 minutes

PERFORMANCE TIME:

COMMENTS: _____

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY ___ UNSATISFACTORY ___

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: You are a Unit Operator assigned to Unit 2, and it is Friday morning at 0800. 2-SR-2, Instrument Checks and Observations, is being performed.

The plant is in MODE 3.

INITIATING CUE: The Unit Supervisor directs you as the Unit Operator to complete a portion of 2-SR-2 day shift checks and observations Attachment 2 Surveillance Procedure Data Package Modes 1, 2, and 3 (pages 18 of 90 to 27 of 90) for Friday at 0800.

All readings that are already completed are correct and need not be checked by you.

Simulator

INITIAL CONDITIONS: You are a Unit Operator assigned to Unit 2, and it is Friday morning at 0800. 2-SR-2, Instrument Checks and Observations, is being performed.

The plant is in MODE 3.

INITIATING CUE: The Unit Supervisor directs you as the Unit Operator to complete a portion of 2-SR-2 day shift checks and observations Attachment 2 Surveillance Procedure Data Package Modes 1, 2, and 3 (pages 18 of 90 to 27 of 90) for Friday at 0800.

All readings that are already completed are correct and need not be checked by you.

START TIME _____

Performance Step 1:

Critical Not Critical

Attachment 2
(Page 18 of 90)
Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY		DAY SHIFT	WEEK: _____ to _____	
APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.				
Criteria Source: Technical Requirements Manual TSR-3.4.1.1				
LOCATION: Panel 2-9-4				Review Initials
	2-CR-43-11A/12A Ch 1 (µmho) (Note 1)	MAX (AC)	UO	Unit Supvr
Friday		1.0 µmho		
Saturday				
Sunday				
Monday				
Tuesday				
Wednesday				
Thursday				

- (1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify the Chemistry to sample according to 2-SI-4.6.B.1-4.

Standard:

Records a Reactor Coolant Conductivity reading of .057 or .058 µmho. Initials under UO.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 2:

Critical X Not Critical

Attachment 2
(Page 19 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 2-9-3					Review Initials
	2-LI-64-54A (inches) (Note 1)	2-LI-64-66 (inches) (Note 1)	LIMITS (AC)	UO	Unit Supvr
Friday			≥-5.5 inches and ≤ -2.0 inches (Note 2)		
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 2-LI-64-54A and 2-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

Standard:

Records a Suppression Pool Level of (-) 1 to (-) 2 inches in both columns.
Initials under UO.

SAT__ UNSAT__ N/A__ COMMENTS: _____

Performance Step 3:

Critical X Not Critical

Attachment 2
(Page 20 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.						
Surveillance Requirements: 3.6.1.4.1						
LOCATION: ICS Computer or 2-TI-82						Review Initials
	ICS Pt TEST2500 (°F) (Note 1)	2-TI-82 Value (°F) (Note 1)	2-TR-80-1 (FT A08) (°F) (Note 1, 2)	LIMITS (AC)	UO	Unit Supvr
Friday				≤ 150°F		
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 or 2-TR-80 or 2-TI-82 Value. Only one of the three methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 2-TR-80-1 to allow the point to be displayed.

Standard:

Records a Drywell Air Temperature from ICS of 102.4 °F or 102.5 °F in the column under ICS Pt TEST2500. Initials under UO.

SAT__ UNSAT__ N/A __COMMENTS: _____

Performance Step 4:

Critical Not Critical X

Attachment 2
(Page 21 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY:		Mode 1 Readings are required at all times.					
Surveillance Requirements:		3.6.2.6.1		Technical Requirements Manual 3.3.5.1			
LOCATION:						Review Initials	
Panel 2-9-3							
	TIME	2-PDI-84-137 (psid)	2-PDI-84-138 (psid)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800			≥ 1.1 psid & ≤ 1.33 psid (Note 1, 2)	0.10 psid (Note 1)		
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

- (1) Acceptance Criteria is not required to be met until 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.)
- (2) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

Standard:

Records a Drywell – Suppression Chamber Differential pressure of 1.15 to 1.2 psid in both columns. Initials under UO.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 5:

Critical X Not Critical

Attachment Z
(Page 22 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.								
Surveillance Requirements: 3.8.2.1.1								
LOCATION: Panel 2-9-3						Panel 2-25-32		Review Initials
	2-TI-64-161 (°F) (Notes 1, 3, & 4) (AC)	2-TR-64-161 2-TM-64-161L (°F) (Notes 1, 3, & 4) (AC)	2-TI-64-162 (°F) (Notes 1, 3, & 4) (AC)	2-TR-64-162 2-TM-64-162L (°F) (Notes 1, 3, & 4) (AC)	MAX DELTA TEMP between instruments	2-TI-64-55B (Notes 1, 3, & 4) < 95°F	UO	Unit Supvr
Friday					CR Instruments within 5°F of each other and < 95°F (Note 2)			
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

NOTES ARE ON THE FOLLOWING PAGE!

(1) Limits:

≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed;

≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and

≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7

- (2) This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or the 2-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain a valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, **REFER TO** site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 2-TI-64-55B affects LCO 3.3.3.2, "Backup Control System. Failure of an Analog (Pen), channel to track due to sticking or servo failure, contributing to the channel exceeding the Max Delta Limits or not, results in the channel being Inoperable.
- (3) Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 2-SR-3.6.2.1.1.
- (4) If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

Standard:

Records Suppression Pool Water Temperature of 87.5 °F; plus or minus 2 °F in all 4 columns under Panel 9-3. Initials under UO.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 6:

*Critical Not Critical

**Attachment 2
(Page 24 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: _____ to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 2-9-3							Review Initials	
	CS Loop I 2-PI-75-20 (psig)	RHR Loop I 2-PI-74-51 (psig)	RHR Loop II 2-PI-74-65 (psig)	CS Loop II 2-PI-75-48 (psig)	MIN (AC)	MAX	UO	Unit Supvr
Friday					For each OPERABLE subsystem: (Note 2)	For each OPERABLE subsystem: 100 psig (Note 3)		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.
- (2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer to TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig
- (3) MAX criteria are N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

Standard:

*Records a CS Loop I Fill Pressure of 50 psig (±) 5 psig and for *CS Loop II Discharge Fill Pressure of 45 psig (±) 5 psig. *Records a RHR Loop I Discharge Fill Pressure of 42.5 psig; plus 5 psig or minus 2.5 psig but less than 48 psig. Records NA or 270 psig for RHR Loop II because it is in Shutdown Cooling. Initials under UO. *Informs Unit Supervisor that RHR Loop I discharge pressure is less than the minimum required discharge pressure of 48 psig.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 7:

Critical X Not Critical

Attachment 2
(Page 25 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20 RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION PUMP OPERATION DAY SHIFT WEEK: _____ to _____

APPLICABILITY:		Mode 3 with the reactor steam dome pressure less than the RHR low pressure permissive pressure. Readings are required at all times.									
Surveillance Requirements:		3.4.7.1									
LOCATION:		Panel 2-9-3 & Panel 2-9-4								Review Initials	
	TIME	Recirc Pump (Note 2)		RHR Shutdown Cooling Subsystem (Note 2 & 3)				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800							≥ One RHR Shutdown Cooling Subsystem OR ≥ One Recirc Pump In Service			
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHRSW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An "X" shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (2-XA-55-3D, Window 11) is reset.

Standard:

Places an X under RR Pump B for being in service and an X under RHR Shutdown Cooling Subsystem D for being in service. Records SAT in all data Column. Initials under UO.

SAT__ UNSAT__ N/A__ COMMENTS: _____

Performance Step 8:

Critical X Not Critical

Attachment 2
(Page 26 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING		DAY SHIFT	WEEK: _____ to _____		
APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times.			
Surveillance Requirements:		3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)			
LOCATION:		Panel 2-9-10			Review Initials
REACTOR ZONE EXHAUST RADIATION MONITOR					
		2-RM-90-142		2-RM-90-143	
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)	MAX DEV (AC)
Friday					14 mr/hr
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					
REFUEL ZONE EXHAUST RADIATION MONITOR					
		2-RM-90-140		2-RM-90-141	
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)	MAX DEV (AC)
Friday					20 mr/hr
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					
					UO
					Unit Supvr

Standard:

Records Reactor Zone Exhaust Radiation Monitor readings of 1.0 mr/hr for both RM-90-142 and RM-90-143; plus or minus 0.5 mr/hr for Detector A and B. Records Refuel Zone Exhaust Radiation Monitor readings of 26.0 mr/hr for RM-90-140; plus or minus 1.0 mr/hr for Detector A and B. For RM-90-141 records reading of 50 mr/hr; plus or minus 1 mr/hr for Detector A and B. Initials under UO. Informs Unit Supervisor that Refuel Zone Exhaust Radiation Monitors are outside the MAX deviation of 20 mr/hr.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 9:

*Critical X Not Critical

Attachment 2
(Page 27 of 90)

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRWS RADIATION MONITORS		DAY SHIFT	WEEK: _____ to _____
APPLICABILITY: During RHRWS Loop Operation Readings are required at all times.			
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1			
LOCATION: Panel 2-9-2			Review Initials
	2-RR-90-134		
	2-RM-90-133 (Channel 1) A & C HX (cpm)	2-RM-90-134 (Channel 2) B & D HX (cpm)	MAX (AC)
Friday			All Data SAT/UNSAT
Saturday			UO
Sunday			Unit Supvr
Monday			
Tuesday			
Wednesday			
Thursday			

- (1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRWS/RCW EFFLUENT RADIATION HIGH 2-RA-90-132 (Panel 2-9-3, 2-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

Standard:

Records NA for RM-90-133 or a reading of 300 cpm. *Records a reading for RM-90-134 of 300 cpm; plus or minus 10 cpm. *Records SAT in all data Column. *Initials under UO.

SAT__ UNSAT__ N/A __ COMMENTS: _____

END OF TASK

STOP TIME ____

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 45 of 148
-----------------------	---	--

**Attachment 2
(Page 26 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRWS RADIATION MONITORS

DAY SHIFT

WEEK:

TODAY

to

APPLICABILITY: During RHRWS Loop Operation Readings are required at all times. (Refer To P&L Step 3.6A)						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 3-9-2					Review Initials	
	3-RR-90-134					
	3-RM-90-133 (channel 1) A & C HX (cpm)	3-RM-90-134 (channel 2) B & D HX (cpm)	MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday			Note 1			
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

TABLE 1.23 RCW RADIATION MONITOR

APPLICABILITY: During RCW releases (Refer To P&L Step 3.6A)						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 3-9-2					Review Initials	
	3-RR-90-134					
	3-RM-90-132 (channel 4) (cpm)		MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	NA		Note 1	NA	UO	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRWS/RCW EFFLUENT RADIATION HIGH 3-RA-90-132 (Panel 3-9-3, 3-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 44 of 148
-----------------------	---	--

**Attachment 2
(Page 25 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements:		3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)					
LOCATION:		Panel 3-9-10				Review Initials	
	REACTOR ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	UO	Unit Supvr
	3-RM-90-142		3-RM-90-143				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)			
Friday					14 mr/hr		
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							
	REFUEL ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	UO	Unit Supvr
	3-RM-90-140		3-RM-90-141				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)			
Friday					20 mr/hr		
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 43 of 148
-----------------------	---	--

**Attachment 2
(Page 24 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20 RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION PUMP OPERATION DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: MODE 3, with reactor steam dome pressure less than the RHR low pressure permissive pressure. (Refer To P&L Step 3.6A) (Note 1) Readings are required at all times.											
Surveillance Requirements: 3.4.7.1											
LOCATION: Panel 3-9-3 & Panel 3-9-4								Review Initials			
	TIME	Recirc Pump Note 2		RHR Shutdown Cooling Subsystem Note 2 & 3				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800							≥ One RHR Shutdown Cooling Subsystem OR ≥ One Recirc Pump In Service			
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHRSW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An "X" shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (3-XA-55-3D, Window 11) RESET.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 42 of 148
-----------------------	---	--

**Attachment 2
(Page 23 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 3-9-3							Review Initials	
	CS Loop I 3-PI-75-20 (psig)	RHR Loop I 3-PI-74-51 (psig)	RHR Loop II 3-PI-74-65 (psig)	CS Loop II 3-PI-75-48 (psig)	MIN (AC) Note 2	MAX Note 3	UO	Unit Supvr
Friday					For each OPERABLE subsystem:	For each OPERABLE subsystem: 100 psig		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.
- (2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer To TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig
- (3) MAX criteria is N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 41 of 148
-----------------------	---	--

**Attachment 2
(Page 22 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE

DAY SHIFT _____ WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)								
Surveillance Requirements: 3.6.2.1.1								
LOCATION: Panel 3-9-3						Panel 3-25-32		Review Initials
	3-TI-64-161 (°F) Notes 1,3, & 4 (AC)	3-TR-64-161 3-TM-64-161L (°F) Notes 1,3, & 4 (AC)	3-TI-64-162 (°F) Notes 1,3, & 4 (AC)	3-TR-64-162 3-TM-64-162L (°F) Notes 1,3, & 4 (AC)	MAX DELTA TEMP between instruments (Note 2)	3-TI-64-55B Notes 1,3, & 4 < 95°F	UO	Unit Supvr
Friday					CR Instruments within 5°F of each other and < 95°F	89		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Limits:
 - A. ≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed.
 - B. ≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and
 - C. ≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7
- (2) This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or if 3-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, Refer To site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 3-TI-64-55B affects LCO 3.3.3.2, "Backup Control System.
- (3) Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 3-SR-3.6.2.1.1.
- (4) If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 40 of 148
-----------------------	---	--

**Attachment 2
(Page 21 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Mode 1 (FROM 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.) Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements: 3.6.2.6.1			Technical Requirements Manual TSRs: 3.3.5.1				
LOCATION: Panel 3-9-3						Review Initials	
	TIME	3-PDI-64-137 (psid) ≤ 1.33 psid (Note 1)	3-PDI-64-138 (psid) ≤ 1.33 psid (Note 1)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800			≥ 1.1 psid & ≤ 1.33 psid	0.10 psid		
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

(1) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 39 of 148
-----------------------	---	--

**Attachment 2
(Page 20 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer to P&L Step 3.6A)							
Surveillance Requirements: 3.6.1.4.1							
LOCATION: ICS Computer or 3-TI-82 or 3-TR-80-1							Review Initials
	TIME	ICS Pt TEST2500 (°F) Note 1	3-TI-82 Value (°F) Note 1	3-TR-80-1(PT A08) (°F) (Note 1,2)	LIMITS (AC)	UO	Unit Supvr
Friday	0800				≤ 150°F		
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 OR 3-TI-82 OR 3-TR-80-1. Only one of the two methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 3-TR-80-1 to allow the point to be displayed.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 38 of 148
-----------------------	---	--

**Attachment 2
(Page 19 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 3-9-3					Review Initials
	3-LI-64-54A (inches) Note 1	3-LI-64-66 (inches) Note 1	LIMITS (AC)	UO	Unit Supvr
Friday			≥-5.5 inches and ≤ -2.0 inches (Note 2)		
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 3-LI-64-54A and 3-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 37 of 148
-----------------------	---	--

**Attachment 2
(Page 18 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Criteria Source: Technical Requirements Manual TSR-3.4.1.1					
LOCATION: Panel 3-9-4				Review Initials	
	3-CR-43-11A/12A Ch 1 (μ mho) Note 1		MAX (AC)	UO	Unit Supvr
Friday		1.0 μ mho			
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify Chemistry to sample according to 3-SI-4.6.B.1-4.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 49 of 154
-----------------------	---	--

**Attachment 2
(Page 27 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRSW RADIATION MONITORS

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: During RHRSW Loop Operation Readings are required at all times.						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 2-9-2					Review Initials	
	2-RR-90-134					
	2-RM-90-133 (Channel 1) A & C HX (cpm)	2-RM-90-134 (Channel 2) B & D HX (cpm)	MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday			Note 1			
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

TABLE 1.23 RCW RADIATION MONITOR

APPLICABILITY: During RCW releases Readings are required at all times.						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 2-9-2					Review Initials	
	2-RR-90-134					
	2-RM-90-132 (Channel 4) (cpm)		MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	NA		Note 1	NA	JO	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRSW/RCW EFFLUENT RADIATION HIGH 2-RA-90-132 (Panel 2-9-3, 2-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 48 of 154
-----------------------	---	--

**Attachment 2
(Page 26 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times.					
Surveillance Requirements:		3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)					
LOCATION:		Panel 2-9-10				Review Initials	
	REACTOR ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	UO	Unit Supvr
	2-RM-90-142		2-RM-90-143				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)			
Friday					14 mr/hr		
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							
	REFUEL ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	UO	Unit Supvr
	2-RM-90-140		2-RM-90-141				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)			
Friday					20 mr/hr		
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 47 of 154
-----------------------	---	--

**Attachment 2
(Page 25 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20

RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION
PUMP OPERATION

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Mode 3 with the reactor steam dome pressure less than the RHR low pressure permissive pressure. Readings are required at all times.											
Surveillance Requirements: 3.4.7.1											
LOCATION: Panel 2-9-3 & Panel 2-9-4										Review Initials	
	TIME	Recirc Pump (Note 2)		RHR Shutdown Cooling Subsystem (Note 2 & 3)				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800							≥ One RHR Shutdown Cooling Subsystem <u>OR</u> ≥ One Recirc Pump In Service			
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHRSW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An "X" shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (2-XA-55-3D, Window 11) is reset.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 46 of 154
-----------------------	---	--

**Attachment 2
(Page 24 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 2-9-3							Review Initials	
	CS Loop I 2-PI-75-20 (psig)	RHR Loop I 2-PI-74-51 (psig)	RHR Loop II 2-PI-74-65 (psig)	CS Loop II 2-PI-75-48 (psig)	MIN (AC)	MAX	UO	Unit Supvr
Friday					For each OPERABLE subsystem: (Note 2)	For each OPERABLE subsystem: 100 psig (Note 3)		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.
- (2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer to TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig
- (3) MAX criteria are N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 45 of 154
-----------------------	---	--

**Attachment 2
(Page 23 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

(1) Limits:

≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed;

≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and

≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7

- (2) This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or the 2-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain a valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, **REFER TO** site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 2-TI-64-55B affects LCO 3.3.3.2, "Backup Control System. Failure of an Analog (Pen), channel to track due to sticking or servo failure, contributing to the channel exceeding the Max Delta Limits or not, results in the channel being Inoperable.
- (3) Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 2-SR-3.6.2.1.1.
- (4) If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 44 of 154
-----------------------	---	--

**Attachment 2
(Page 22 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.								
Surveillance Requirements: 3.6.2.1.1								
LOCATION: Panel 2-9-3						Panel 2-25-32	Review Initials	
	2-TI-64-161 (°F) (Notes 1,3, & 4) (AC)	2-TR-64-161 2-TM-64-161L (°F) (Notes 1,3, & 4) (AC)	2-TI-64-162 (°F) (Notes 1,3, & 4) (AC)	2-TR-64-162 2-TM-64-162L (°F) (Notes 1,3, & 4) (AC)	MAX DELTA TEMP between instruments	2-TI-64-55B (Notes 1,3, & 4) < 95°F	UO	Unit Supvr
Friday					CR Instruments within 5°F of each other and < 95°F (Note 2)	90.4		
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

NOTES ARE ON THE FOLLOWING PAGE!

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 43 of 154
-----------------------	---	--

**Attachment 2
(Page 21 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Mode 1 Readings are required at all times.					
Surveillance Requirements: 3.6.2.6.1			Technical Requirements Manual 3.3.5.1				
LOCATION: Panel 2-9-3						Review Initials	
	TIME	2-PDI-64-137 (psid)	2-PDI-64-138 (psid)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800			≥ 1.1 psid & ≤ 1.33 psid (Note 1, 2)	0.10 psid (Note 1)		
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

- (1) Acceptance Criteria is not required to be met until 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.)
- (2) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 42 of 154
-----------------------	---	--

**Attachment 2
(Page 20 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.						
Surveillance Requirements: 3.6.1.4.1						
LOCATION: ICS Computer or 2-TI-82						Review Initials
	ICS Pt TEST2500 (°F) (Note 1)	2-TI-82 Value (°F) (Note 1)	2-TR-80-1 (PT A08) (°F) (Note 1, 2)	LIMITS (AC)	UO	Unit Supvr
Friday				≤ 150°F		
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 or 2-TR-80 or 2-TI-82 Value. Only one of the three methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 2-TR-80-1 to allow the point to be displayed.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 41 of 154
-----------------------	---	--

**Attachment 2
(Page 19 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 2-9-3					Review Initials
	2-LI-64-54A (inches) (Note 1)	2-LI-64-66 (inches) (Note 1)	LIMITS (AC)	UO	Unit Supvr
Friday			≥-5.5 inches and ≤ -2.0 inches (Note 2)		
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 2-LI-64-54A and 2-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 40 of 154
-----------------------	---	--

**Attachment 2
(Page 18 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.					
Criteria Source: Technical Requirements Manual TSR-3.4.1.1					
LOCATION: Panel 2-9-4				Review Initials	
	2-CR-43-11A/12A Ch 1 (μ mho) (Note 1)		MAX (AC)	UO	Unit Supvr
Friday		1.0 μ mho			
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify the Chemistry to sample according to 2-SI-4.6.B.1-4.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 45 of 148
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 26 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRSW RADIATION MONITORS

DAY SHIFT **WEEK:** TODAY to _____

APPLICABILITY: During RHRSW Loop Operation Readings are required at all times. (Refer To P&L Step 3.6A)						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 3-9-2					Review Initials	
	3-RR-90-134					
	3-RM-90-133 (channel 1) A & C HX (cpm)	3-RM-90-134 (channel 2) B & D HX (cpm)	MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	NA or 300	300	Note 1	SAT	UO	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

TABLE 1.23 RCW RADIATION MONITOR

APPLICABILITY: During RCW releases (Refer To P&L Step 3.6A)						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 3-9-2					Review Initials	
	3-RR-90-134					
	3-RM-90-132 (channel 4) (cpm)		MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	NA		Note 1	NA	UO	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRSW/RCW EFFLUENT RADIATION HIGH 3-RA-90-132 (Panel 3-9-3, 3-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 44 of 148
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 25 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)							
Surveillance Requirements: 3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)							
LOCATION: Panel 3-9-10					Review Initials		
	REACTOR ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)		
	3-RM-90-142		3-RM-90-143				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)		UO	Unit Supvr
Friday	<u>1.0 ± 0.5</u>	<u>1.0 ± 0.5</u>	<u>1.0 ± 0.5</u>	<u>1.0 ± 0.5</u>	14 mr/hr	<u>UD</u>	
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							
Friday							
	REFUEL ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)		
	3-RM-90-140		3-RM-90-141				
	Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)		UO	Unit Supvr
Friday	<u>26 ± 1.0</u>	<u>26 ± 1.0</u>	<u>50 ± 1.0</u>	<u>50 ± 1.0</u>	20 mr/hr	<u>US</u>	
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							
Friday							

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 43 of 148
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 24 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20 RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION PUMP OPERATION DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: MODE 3, with reactor steam dome pressure less than the RHR low pressure permissive pressure. (Refer To P&L Step 3.6A) (Note 1) Readings are required at all times.											
Surveillance Requirements: 3.4.7.1											
LOCATION: Panel 3-9-3 & Panel 3-9-4										Review Initials	
	TIME	Recirc Pump Note 2		RHR Shutdown Cooling Subsystem Note 2 & 3				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800		X				X	≥ One RHR Shutdown Cooling Subsystem OR ≥ One Recirc Pump In Service	SAT	JD	
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHR SW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An "X" shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (3-XA-55-3D, Window 11) RESET.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 42 of 148
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 23 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 3-9-3							Review Initials	
	CS Loop I 3-PI-75-20 (psig)	RHR Loop I 3-PI-74-51 (psig)	RHR Loop II 3-PI-74-65 (psig)	CS Loop II 3-PI-75-48 (psig)	MIN (AC) Note 2	MAX Note 3	UO	Unit Supvr
Friday	50 ± 5	40	N/A or 270	50 ± 5	For each OPERABLE subsystem:	For each OPERABLE subsystem: 100 psig	UO	
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.
- (2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer To TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig
- (3) MAX criteria is N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 41 of 148
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 22 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)								
Surveillance Requirements: 3.6.2.1.1								
LOCATION: Panel 3-9-3						Panel 3-25-32		Review Initials
	3-TI-64-161 (°F) Notes 1,3, & 4 (AC)	3-TR-64-161 3-TM-64-161L (°F) Notes 1,3, & 4 (AC)	3-TI-64-162 (°F) Notes 1,3, & 4 (AC)	3-TR-64-162 3-TM-64-162L (°F) Notes 1,3, & 4 (AC)	MAX DELTA TEMP between instruments (Note 2)	3-TI-64-55B Notes 1,3, & 4 < 95°F	UO	Unit Supvr
Friday	85	87	87.5	87	CR Instruments within 5°F of each other and < 95°F	89	UO	
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Limits:
 - A. ≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed.
 - B. ≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and
 - C. ≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7
- (2) This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or if 3-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, Refer To site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 3-TI-64-55B affects LCO 3.3.3.2, "Backup Control System.
- (3) Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 3-SR-3.6.2.1.1.
- (4) If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 40 of 148
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 21 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Mode 1 (FROM 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.) Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements: 3.6.2.6.1			Technical Requirements Manual TSRs: 3.3.5.1				
LOCATION: Panel 3-9-3						Review Initials	
	TIME	3-PDI-64-137 (psid) ≤ 1.33 psid (Note 1)	3-PDI-64-138 (psid) ≤ 1.33 psid (Note 1)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800	1.1 To 1.2	1.1 To 1.2	≥ 1.1 psid & ≤ 1.33 psid	0.10 psid	UD	
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

(1) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

** ANSWER KEY **

**Attachment 2
(Page 20 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer to P&L Step 3.6A)							
Surveillance Requirements: 3.6.1.4.1							
LOCATION: ICS Computer or 3-TI-82 or 3-TR-80-1						Review Initials	
	TIME	ICS Pt TEST2500 (°F) Note 1	3-TI-82 Value (°F) Note 1	3-TR-80-1(PT A08) (°F) (Note 1,2)	LIMITS (AC)	UO	Unit Supvr
Friday	0800	104.1 ± .1	—	—	≤ 150°F	JO	
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 OR 3-TI-82 OR 3-TR-80-1. Only one of the two methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 3-TR-80-1 to allow the point to be displayed.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 38 of 148
-----------------------	---	--

**Attachment 2
(Page 19 of 88)**

** ANSWER KEY **

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 3-9-3					Review Initials
	3-LI-64-54A (inches) Note 1	3-LI-64-66 (inches) Note 1	LIMITS (AC)	UO	Unit Supvr
Friday	<i>-2.75 ± 0.5</i>	<i>-2.75 ± 0.5</i>	≥-5.5 inches and ≤ -2.0 inches (Note 2)	<i>UO</i>	
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 3-LI-64-54A and 3-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

BFN Unit 3	Instrument Checks and Observations	3-SR-2 Rev. 0072 Page 37 of 148
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 18 of 88)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times. (Refer To P&L Step 3.6A)					
Criteria Source: Technical Requirements Manual TSR-3.4.1.1					
LOCATION: Panel 3-9-4				Review Initials	
	3-CR-43-11A/12A Ch 1 (μ mho) Note 1		MAX (AC)	UO	Unit Supvr
Friday	.057 or .058	1.0 μ mho		JO	
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify Chemistry to sample according to 3-SI-4.6.B.1-4.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 49 of 154
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 27 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.22 RHRWS RADIATION MONITORS		DAY SHIFT	WEEK: <u>TODAY</u>	to		
APPLICABILITY: During RHRWS Loop Operation Readings are required at all times.						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 2-9-2						Review Initials
	2-RR-90-134					
	2-RM-90-133 (Channel 1) A & C HX (cpm)	2-RM-90-134 (Channel 2) B & D HX (cpm)	MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	<u>NA or 300</u>	<u>300 ±10</u>	Note 1	<u>SAT</u>	<u>UO</u>	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

TABLE 1.23 RCW RADIATION MONITOR		DAY SHIFT	WEEK: <u>TODAY</u>	to		
APPLICABILITY: During RCW releases Readings are required at all times.						
Criteria Source: ODCM Section 1/2.1.1, Surveillance 2.1.1						
LOCATION: Panel 2-9-2						Review Initials
	2-RR-90-134					
	2-RM-90-132 (Channel 4) (cpm)		MAX (AC)	All Data SAT/UNSAT	UO	Unit Supvr
Friday	<u>NA</u>		Note 1	<u>SAT</u>	<u>UO</u>	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The instrument check will consist of observing that the instruments exhibit an expected reading for the given plant conditions. MAX will be the alarm (RHRWS/RCW EFFLUENT RADIATION HIGH 2-RA-90-132 (Panel 2-9-3, 2-XA-55-3A, Window 3)) setpoint for the respective monitor. Instrument Shop should be contacted for most current setpoints as required.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 48 of 154
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 26 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.21 REACTOR BUILDING VENTILATION RADIATION MONITORING DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Modes 1, 2 & 3 Readings are required at all times.					
Surveillance Requirements:		3.3.6.2.1(f3, 4) and 3.3.7.1.1(f3,4)					
LOCATION:		Panel 2-9-10				Review Initials	
		REACTOR ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	
		2-RM-90-142		2-RM-90-143			
		Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)	UO	Unit Supvr
Friday		1.0 ± 0.5	1.0 ± 0.5	1.0 ± 0.5	1.0 ± 0.5	UO	
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							
		REFUEL ZONE EXHAUST RADIATION MONITOR				MAX DEV (AC)	
		2-RM-90-140		2-RM-90-141			
		Detector A (mr / hr)	Detector B (mr / hr)	Detector A (mr / hr)	Detector B (mr / hr)	UO	Unit Supvr
Friday		26 ± 1	26 ± 1	50 ± 1	50 ± 1	UO	
Saturday							
Sunday							
Monday							
Tuesday							
Wednesday							
Thursday							

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 47 of 154
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 25 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.20

RHR SHUTDOWN COOLING SUBSYSTEM AND RECIRCULATION
PUMP OPERATION

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Mode 3 with the reactor steam dome pressure less than the RHR low pressure permissive pressure. Readings are required at all times.											
Surveillance Requirements: 3.4.7.1											
LOCATION: Panel 2-9-3 & Panel 2-9-4										Review Initials	
	TIME	Recirc Pump (Note 2)		RHR Shutdown Cooling Subsystem (Note 2 & 3)				LIMITS (AC)	All Data SAT/UNSAT	UO	Unit Supvr
		A I/S	B I/S	A I/S	B I/S	C I/S	D I/S				
Friday	0800		X				X	≥ One RHR Shutdown Cooling Subsystem OR ≥ One Recirc Pump In Service	SAT	JO	
Saturday	0800										
Sunday	0800										
Monday	0800										
Tuesday	0800										
Wednesday	0800										
Thursday	0800										

- (1) Technical Specification LCO 3.4.7 requires that two RHR Shutdown Cooling Subsystems be operable during this applicability. An operable Shutdown Cooling Subsystem consists of one RHR pump, associated heat exchanger, RHRSW pump capable of providing cooling water to its associated heat exchanger, associated piping and valves, all of which can be aligned in the Shutdown Cooling Mode for the removal of decay heat.
- (2) An "X" shall be placed in the associated Column for the In Service Pump or Subsystem.
- (3) To be considered as In Service, RHR System and its associated Shutdown Cooling Subsystems must be in the Shutdown Cooling Mode alignment with RHR SD CLG FLOW LOW annunciator (2-XA-55-3D, Window 11) is reset.

* ANSWER KEY *

**Attachment 2
(Page 24 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.19 RHR DISCHARGE FILL PRESSURE / CORE SPRAY DISCHARGE FILL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.								
Criteria Source: Technical Requirements Manual TSR 3.3.3.1.1 & 3.5.4.1								
LOCATION: Panel 2-9-3							Review Initials	
	CS Loop I 2-PI-75-20 (psig)	RHR Loop I 2-PI-74-51 (psig)	RHR Loop II 2-PI-74-65 (psig)	CS Loop II 2-PI-75-48 (psig)	MIN (AC)	MAX	UO	Unit Supvr
Friday	50 ± 5	42.5 ± 2.5	NA or 270	45 ± 5	For each OPERABLE subsystem: (Note 2)	For each OPERABLE subsystem: 100 psig (Note 3)	UO	
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

- (1) Each pressure indicator provides indication of the discharge pressure for one RHR or Core Spray Loop. The instrument check will consist of observing that the instrument exhibits an expected reading for the given plant conditions.
- (2) The Technical Requirements Manual requires a minimum discharge pressure for OPERABLE subsystems. Refer to TRM Section 3.5.4.

CS Loop I	PI-75-20	39 psig
CS Loop II	PI-75-48	39 psig
RHR Loop I	PI-74-51	48 psig
RHR Loop II	PI-74-65	35 psig
- (3) MAX criteria are N/A for RHR/Core Spray subsystems in service or if keep fill aligned to CS & S. When a RHR/Core Spray subsystem is in a standby readiness condition the maximum discharge pressure is 100 psig. High discharge pressures with pumps secured may be indication of primary valve leakage.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 45 of 154
-----------------------	---	--

**Attachment 2
(Page 23 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

(1) Limits:

≤ 95°F when any OPERABLE intermediate range monitor (IRM) channel is > 70 on Range 7 and no testing that adds heat to the suppression pool is being performed;

≤ 105°F when any OPERABLE IRM channel is > 70 on Range 7 and testing that adds heat to the suppression pool is being performed; and

≤ 110°F when all OPERABLE IRM channels are ≤ 70 on Range 7

- (2) This value is recorded to further validate the Suppression Pool Bulk Water Temperature indications when RHR Suppression Pool Cooling is not in service. If the Control Room Suppression Pool Bulk Water Temperature indications deviate more than 5°F from one another or the 2-TI-64-55B is greater than or equal to 95 deg F, RHR Suppression Pool Cooling may be required to be placed in service to obtain a valid Suppression Pool Bulk Water Temperature readings (may indicate a potential thermal stratification problem, **REFER TO** site response to GE SIL 106). Deviations in excess of 5°F for the MCR instruments is also an indication of a potential inoperable instrument; the Suppression Pool Bulk Water Temperature instruments affect LCO 3.3.3.1, "PAM Instruments" (CHANNEL CHECK surveillance requirement) and 2-TI-64-55B affects LCO 3.3.3.2, "Backup Control System. Failure of an Analog (Pen), channel to track due to sticking or servo failure, contributing to the channel exceeding the Max Delta Limits or not, results in the channel being Inoperable.
- (3) Suppression pool average temperature must be verified within the applicable limits and logged every 5 minutes when performing testing that adds heat to the suppression pool, accomplished by 2-SR-3.6.2.1.1.
- (4) If both the primary and secondary indication of any SRV tailpipe is inoperable, per Technical Requirements Manual 3.3.5, the Suppression Pool Water Temperature must be monitored at least once per shift to observe any unexplained temperature rise which might be indicative of an open SRV.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 44 of 154
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 22 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.18 SUPPRESSION POOL BULK WATER TEMPERATURE

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.								
Surveillance Requirements: 3.6.2.1.1								
LOCATION: Panel 2-9-3						Panel 2-25-32		Review Initials
	2-TI-64-161 (°F) (Notes 1,3, & 4) (AC)	2-TR-64-161 2-TM-64-161L (°F) (Notes 1,3, & 4) (AC)	2-TI-64-162 (°F) (Notes 1,3, & 4) (AC)	2-TR-64-162 2-TM-64-162L (°F) (Notes 1,3, & 4) (AC)	MAX DELTA TEMP between instruments CR Instruments within 5°F of each other and < 95°F (Note 2)	2-TI-64-55B (Notes 1,3, & 4) < 95°F	UO	Unit Supvr
Friday	87.5 ± 2	88.7 ± 2	87.5 ± 2	88.7 ± 2		90.4	UO	
Saturday								
Sunday								
Monday								
Tuesday								
Wednesday								
Thursday								

NOTES ARE ON THE FOLLOWING PAGE!

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 43 of 154
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 21 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.17 DRYWELL - SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY:		Mode 1 Readings are required at all times.					
Surveillance Requirements: 3.6.2.6.1			Technical Requirements Manual 3.3.5.1				
LOCATION: Panel 2-9-3						Review Initials	
	TIME	2-PDI-64-137 (psid)	2-PDI-64-138 (psid)	LIMITS (AC)	MAX DEV (AC)	UO	Unit Supvr
Friday	0800	1.15 TO 1.2 (1.15)	1.15 TO 1.2 (1.15)	≥ 1.1 psid & ≤ 1.33 psid (Note 1, 2)	0.10 psid (Note 1)	UD	
Saturday	0800						
Sunday	0800						
Monday	0800						
Tuesday	0800						
Wednesday	0800						
Thursday	0800						

- (1) Acceptance Criteria is not required to be met until 24 hours after THERMAL POWER is > 15% RTP following startup, TO 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.)
- (2) The Drywell-Suppression Chamber Differential Pressure should not exceed 1.33 psid.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 42 of 154
-----------------------	---	--

** ANSWER KEY **

**Attachment 2
(Page 20 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.15 BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.						
Surveillance Requirements: 3.6.1.4.1						
LOCATION: ICS Computer or 2-TI-82						Review Initials
	ICS Pt TEST2500 (°F) (Note 1)	2-TI-82 Value (°F) (Note 1)	2-TR-80-1 (PT A08) (°F) (Note 1, 2)	LIMITS (AC)	UO	Unit Supvr
Friday	102.4 or 102.5	—	—	≤ 150°F	J S	
Saturday						
Sunday						
Monday						
Tuesday						
Wednesday						
Thursday						

- (1) The required observation of Bulk Volumetric Average Drywell Air Temperature may be obtained from ICS Pt TEST2500 or 2-TR-80 or 2-TI-82 Value. Only one of the three methods is required to be logged and the other method may be N/A'd.
- (2) It may be necessary to have Instrument Maintenance turn on the "BULK VOLUMETRIC AVERAGE DRYWELL AIR TEMPERATURE" on 2-TR-80-1 to allow the point to be displayed.

BFN Unit 2	Instrument Checks and Observations	2-SR-2 Rev. 0077 Page 41 of 154
-----------------------	---	--

* ANSWER KEY *

**Attachment 2
(Page 19 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.14 SUPPRESSION POOL WATER LEVEL DAY SHIFT WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2 & 3 Readings are required at all times.					
Surveillance Requirements: 3.6.2.2.1					
LOCATION: Panel 2-9-3					Review Initials
	2-LI-64-54A (inches) (Note 1)	2-LI-64-66 (inches) (Note 1)	LIMITS (AC)	UO	Unit Supvr
Friday	-1.0 TO -2.0 (-1.25)	-1.0 TO -2.0 (-1.5)	≥-5.5 inches and ≤ -2.0 inches (Note 2)	UO	
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

- (1) The difference between readings of 2-LI-64-54A and 2-LI-64-66 should not exceed 2 inches. Deviations greater than 2 inches should be investigated.
- (2) The Technical Specification requirements for Suppression Pool Water Level are ≥-6.25" and ≤ -1.0" with DW to Torus DP established AND ≥ -7.25" and ≤ -1.0" without DW to Torus DP established.

** ANSWER KEY **

**Attachment 2
(Page 18 of 90)**

Surveillance Procedure Data Package - Modes 1, 2, & 3

TABLE 1.13 REACTOR COOLANT CONDUCTIVITY

DAY SHIFT

WEEK: TODAY to _____

APPLICABILITY: Modes 1, 2, & 3 Readings are required at all times.					
Criteria Source: Technical Requirements Manual TSR-3.4.1.1					
LOCATION: Panel 2-9-4				Review Initials	
	2-CR-43-11A/12A Ch 1 (μ mho) (Note 1)		MAX (AC)	UO	Unit Supvr
Friday	<i>.057 or .058</i>	1.0 μ mho		<i>JS</i>	
Saturday					
Sunday					
Monday					
Tuesday					
Wednesday					
Thursday					

(1) Whenever there is fuel in the reactor vessel and the continuous conductivity monitor is inoperable, periodic analysis of reactor coolant samples are required by the Technical Requirements Manual. If the reactor coolant continuous conductivity monitor becomes inoperable, notify the Chemistry to sample according to 2-SI-4.6.B.1-4.

OPERATOR: _____

RO ____ DATE: _____

JPM NUMBER: RO A1b

TASK NUMBER: U-078-AB-01

TASK TITLE: Calculate Time to Reach Temperature Targets for Loss of Fuel Pool Cooling

K/A NUMBER: 2.1.25 K/A RATING: RO 3.9

TASK STANDARD: Complete of SRM Operability surveillance and determine if core alterations may commence.

LOCATION OF PERFORMANCE: Simulator

REFERENCES/PROCEDURES NEEDED: 2-AOI-78-1, Fuel Pool Cleanup System Failure

VALIDATION TIME: 10 minutes

PERFORMANCE TIME:

COMMENTS: _____

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY ___ UNSATISFACTORY ___

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: You are a Reactor Operator on Unit 2. The RBCCW sectionalizing valve has failed closed. The Unit Supervisor has entered 2-AOI-70-1, Loss of Reactor Building Closed Cooling Water and 2-AOI-78-1, Fuel Pool Cleanup System Failure.

INITIATING CUES: The Unit Supervisor directs you to estimate the time for the fuel pool temperature to rise to 125 °F, 150 °F, and 200 °F in accordance with 2-AOI-78-1 step 3.7.

Simulator

INITIAL CONDITIONS: You are a Reactor Operator on Unit 2. The RBCCW sectionalizing valve has failed closed. The Unit Supervisor has entered 2-AOI-70-1, Loss of Reactor Building Closed Cooling Water and 2-AOI-78-1, Fuel Pool Cleanup System Failure.

INITIATING CUES: The Unit Supervisor directs you to estimate the time for the fuel pool temperature to rise to 125 °F, 150 °F, and 200 °F in accordance with 2-AOI-78-1 step 3.7.

START TIME _____

Performance Step 1: Critical Not Critical X

2-AOI-78-1 Fuel Pool Cleanup System Failure

[3.7] ESTIMATE the time for the fuel pool temperature to rise to 125°F, 150°F, and 200°F using the heat up rates as provided on Attachment 1, Table 1 at least once per shift UNTIL Fuel Pool cooling is restored:

Standard:

Proceeds to attachment 1 of 2-AOI-78-1

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 2: Critical X Not Critical

**Attachment 1
(Page 2 of 2)
Spent Fuel Pool Heat-up Rate at Normal Fuel Pool Level**

NOTE

Determine time to reach target temperatures of 125°F, 150°F and 200°F using the most conservative Heat-up Rate (the highest rate) for days that fall between the dates listed on Table 1.

Target Temperature 125 °F

Actual fuel pool temp(°F) – °F

Standard:

Records Actual Fuel Pool Temperature of 96.3 °F, can record 96 °F to 97 °F under each of the Target Temperatures (3 places).

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 3: Critical X Not Critical

Difference

Standard:

Calculates the difference 125 – actual temperature recorded; can record any of the following temperatures 28 °F to 29 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 4: Critical X Not Critical

Heat up rate from Table 1 ÷ °F/hr

Standard:

Records the Heat up rate from Table 1 of 1.37 °F under each of the Target Temperatures (3 places)

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 5: Critical X Not Critical

TIME (in hours) For FUEL POOL TO REACH Target Temperature = hrs

Standard:

Divides the difference by 0.99 and calculates a time to reach 125 °F of one of the following 20.4 hours to 21.2 hours.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 6:

Critical X Not Critical

Difference

Standard:

Calculates the difference 150 – actual temperature recorded; can record any of the following temperatures 53 °F to 54 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 7:

Critical X Not Critical

TIME (in hours) For FUEL POOL TO REACH Target Temperature = hrs

Standard:

Divides the difference by 1.37 and calculates a time to reach 150 °F of one of the following 38.7 hours to 39.4 hours.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 8:

Critical X Not Critical

Difference

Standard:

Calculates the difference 200 – actual temperature recorded; can record any of the following temperatures 103 °F to 104 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 9:

Critical X Not Critical

TIME (in hours) For FUEL POOL TO REACH Target Temperature = hrs

Standard:

Divides the difference by 1.37 and calculates a time to reach 200 °F of one of the following 75.2 hours to 75.9 hours.

SAT__ UNSAT__ N/A __COMMENTS:_____

END OF TASK

STOP TIME _____

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: RO A1b

TASK NUMBER: U-078-AB-01

TASK TITLE: Calculate Time to Reach Temperature Targets for Loss of Fuel Pool Cooling

K/A NUMBER: 2.1.25 K/A RATING: RO 3.9

TASK STANDARD: Complete of SRM Operability surveillance and determine if core alterations may commence.

LOCATION OF PERFORMANCE: Simulator

REFERENCES/PROCEDURES NEEDED: 3-AOI-78-1, Fuel Pool Cleanup System Failure

VALIDATION TIME: 10 minutes

PERFORMANCE TIME:

COMMENTS: _____

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY ___ UNSATISFACTORY ___

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: You are a Reactor Operator on Unit 3. The RBCCW sectionalizing valve has failed closed. The Unit Supervisor has entered 3-AOI-70-1, Loss of Reactor Building Closed Cooling Water and 3-AOI-78-1, Fuel Pool Cleanup System Failure.

INITIATING CUES: The Unit Supervisor directs you to estimate the time for the fuel pool temperature to rise to 125 °F, 150 °F, and 200 °F in accordance with 3-AOI-78-1 step 3.7.

Simulator

INITIAL CONDITIONS: You are a Reactor Operator on Unit 3. The RBCCW sectionalizing valve has failed closed. The Unit Supervisor has entered 3-AOI-70-1, Loss of Reactor Building Closed Cooling Water and 3-AOI-78-1, Fuel Pool Cleanup System Failure.

INITIATING CUES: The Unit Supervisor directs you to estimate the time for the fuel pool temperature to rise to 125 °F, 150 °F, and 200 °F in accordance with 3-AOI-78-1 step 3.7.

START TIME _____

Performance Step 1: Critical Not Critical X

3-AOI-78-1 Fuel Pool Cleanup System Failure

[3.7] ESTIMATE the time for the fuel pool temperature to rise to 125°F, 150°F, and 200°F using the heat up rates as provided on Attachment 1, Table 1 at least once per shift UNTIL Fuel Pool cooling is restored:

Standard:

Proceeds to attachment 1 of 3-AOI-78-1

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 2: Critical X Not Critical

**Attachment 1
(Page 2 of 2)
Spent Fuel Pool Heat-up Rate at Normal Fuel Pool Level**

NOTES

- 1) To determine time to reach target temperatures of 125°F, 150°F, and 200°F USE the following formulas.
- 2) Use the most conservative heat up rate (the highest rate) for days that fall between the dates listed on Table 1.

Target Temperature 125 °F

Actual fuel pool temp(°F) – °F

Standard:

Records Actual Fuel Pool Temperature of 97.7 °F, can record 97 °F to 98 °F under each of the Target Temperatures (3 places).

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 3:

Critical X Not Critical

Difference

Standard:

Calculates the difference 125 – actual temperature recorded; can record any of the following temperatures 28 °F to 29 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 4:

Critical X Not Critical

Heat up rate from Table 1 ÷ °F/hr

Standard:

Records the Heat up rate from Table 1 of 0.99 °F under each of the Target Temperatures (3 places).

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 5:

Critical X Not Critical

TIME (in hours) For FUEL POOL TO REACH Target Temperature = hrs

Standard:

Divides the difference by 0.99 and calculates a time to reach 125 °F of one of the following 27.2 hours to 28.3 hours.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 6:

Critical X Not Critical

Difference

Standard:

Calculates the difference 150 – actual temperature recorded; can record any of the following temperatures 52 °F to 53 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 7:

Critical X Not Critical

TIME (in hours) For FUEL POOL TO REACH Target Temperature = hrs

Standard:

Divides the difference by 0.99 and calculates a time to reach 150 °F of one of the following 52.5 hours to 53.5 hours.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 8:

Critical X Not Critical

Difference

Standard:

Calculates the difference 200 – actual temperature recorded; can record any of the following temperatures 102 °F to 103 °F.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 9:

Critical Not Critical

TIME (in hours) For FUEL POOL TO
REACH Target Temperature = hrs

Standard:

Divides the difference by 0.99 and calculates a time to reach 200 °F of one of the following
103 hours to 104 hours.

SAT__ UNSAT__ N/A __COMMENTS:_____

END OF TASK

STOP TIME _____

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: A2 Equipment Control

TASK NUMBER: S-000-AD-55

TASK TITLE: PSC Head Tank Pump 2B Clearance Boundary

K/A NUMBER: 2.2.13 K/A RATING: RO 4.1

TASK STANDARD: Determine the clearance boundary for PSC Head Tank Pump 2B

LOCATION OF PERFORMANCE: Class Room / Unit 2 Simulator

REFERENCES/PROCEDURES NEEDED: 2-47E814-1, 2-45E779-19, 2-47E610-75-1, 2-45E2750-4, and 2-45E751-3 and 5, NPG-SPP 10.2

VALIDATION TIME: 30 minutes

PERFORMANCE TIME:

COMMENTS:

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY _____ UNSATISFACTORY _____

SIGNATURE: _____ DATE: _____
EXAMINER

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: A2 Equipment Control

TASK NUMBER: S-000-AD-55

TASK TITLE: PSC Head Tank Pump 2B Clearance Boundary

K/A NUMBER: 2.2.13 K/A RATING: RO 4.1

TASK STANDARD: Determine the clearance boundary for PSC Head Tank Pump 2B

LOCATION OF PERFORMANCE: Class Room / Unit 2 Simulator

REFERENCES/PROCEDURES NEEDED: 2-47E814-1, 2-45E779-19, 2-47E610-75-1, 2-45E2750-4, and 2-45E751-3 and 5, NPG-SPP 10.2

VALIDATION TIME: 30 minutes

PERFORMANCE TIME:

COMMENTS:

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY _____ UNSATISFACTORY _____

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: Preventative maintenance is scheduled for the PSC Head Tank Pump 2B Motor.

Given:

- NPG Request for Clearance
- Page one of Completing Clearance form, NPG-SPG 10.2, Clearance Procedure to Safely Control Energy, Appendix B

INITIATING CUES: The Unit Supervisor directs you as a Reactor Operator to write a clearance to allow uncoupling the PSC Head Tank Pump 2B in support of preventative maintenance on the motor.

ESOMs is not currently working, use the Completing Clearance, Appendix B (page 8 of 11). On Appendix B (page 8 of 11) complete columns 18, 20, 21, and 22 for each identified component.

Class Room

INITIAL CONDITIONS: Preventative maintenance is scheduled for the PSC Head Tank Pump 2B Motor.

Given:

- NPG Request for Clearance
- Page one of Completing Clearance form, NPG-SPG 10.2, Clearance Procedure to Safely Control Energy, Appendix B

INITIATING CUES: The Unit Supervisor directs you as a Reactor Operator to write a clearance to allow uncoupling the PSC Head Tank Pump 2B in support of preventative maintenance on the motor.

ESOMs is not currently working, use the Completing Clearance, Appendix B (page 8 of 11). On Appendix B (page 8 of 11) complete columns 18, 20, 21, and 22 for each identified component.

START TIME _____

Performance Step 1: Critical Not Critical

Review prints to determine required isolation boundary: 2-47E814-1, 2-45E779-19, 2-47E610-75-1, 2-45E2750-4, and 2-45E751-3 and 5.

Standard:

Locates and reviews prints for PSC Head Tank Pump 2B.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 2: *Critical Not Critical

Determines Isolation boundary.

Standard:

*Determines at least one of the following components will need to be tagged to prevent pump rotation:

2-75-SHV-603 Pump Discharge Valve, Closed, Danger Tag.

AND/OR

2-75-SHV-599 Pump Suction Valve, Closed, Danger Tag.

Tag placement sequence will generally be after the electrical tag placement. NOT critical.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 3:

*Critical Not Critical

Determines Isolation boundary.

Standard:

*2-HS-75-76A Control Room Handswitch, Danger Tag, Pull to Lock.

Tag placement sequence will generally be one or two. NOT critical.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 4:

*Critical Not Critical

Determines Isolation boundary.

Standard:

*2B Pump Power Supply, 480 Volt RMOV Board 2B, Breaker 11D, Danger Tag, Off.

Tag placement sequence will generally be one or two. NOT critical.

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 5:

Critical__ Not Critical X

Determines Isolation Boundary.

Standard:

The following circuits may be identified but are not critical for personnel protection:

2-FU-075-076B Control Circuit

2-FU-075-076A Indicating Light

SAT__ UNSAT__ N/A __COMMENTS:_____

END OF TASK

STOP TIME ____

**Appendix A
(Page 3 of 3)**

NPG Request for Clearance

NPG Request for Clearance

<p>Date of Request: <u>TODAY</u></p> <p>Requester's name and phone number: <u>MAINTENANCE-5555</u></p> <p>Date and time work to begin: <u>NEXT WEEK</u></p> <p>Date and time work to be complete: _____</p> <p>Duration: _____</p> <p>Equipment can be returned to service in emergency: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Time required to return to service: _____</p> <p>Equipment/System to be cleared: <u>PSC HEAD TANK PUMP 2B</u></p>	<p>Work Order No.: <u>NRC EXAM</u></p> <p>Requester's Org.: _____</p> <p>Outage Work: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Planned Outage: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Forced Outage: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Grounds Required: <input type="checkbox"/> Yes <input type="checkbox"/> No</p>
<p>Detailed description/scope of work to be performed:</p> <p align="center"><u>UNCOUPLE THE PSC HEAD TANK PUMP 2B IN SUPPORT OF PREVENTATIVE MAINTENANCE ON THE MOTOR.</u></p>	
<p>Attached drawings/DCAs, marked up to show recommended clearance boundary: _____</p>	
<p>Potential adverse affects: _____</p> <p>Other systems affected: _____</p> <p>Reference drawings: _____</p> <p>Barricade Permit Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Scaffold Permit Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	
<p>Operations Review:</p> <p align="center"><u>N/A</u></p> <p>_____ Signature</p> <p>_____ Date</p>	
<p>Management approval for GSA or Grounding Plan (if required):</p> <p>_____ Signature</p> <p>_____ Date</p>	
<p>Clearance Number Issued: _____ Assigned by: _____</p> <p>Generating Sensitive Activity (GSA) Required: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Clearance Temporary Lift Required: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Other clearances required to be held for this work: _____</p>	
<p>Special instructions or notes associated with this clearance:</p> <p>_____</p>	

NPG Standard Programs and Processes	Clearance Procedure to Safely Control Energy	NPG-SPP-10.2 Rev. 0005 Page 48 of 80
-------------------------------------	--	--

**Appendix B
(Page 7 of 11)
Completing Clearance**

**Tennessee Valley Authority
Clearance Coversheet**

Clearance Sheet	Clearance No. (1)	Page ___ of ___ (2)
Component To Be Worked: (3) PSC HEAD TANK PUMP 2B MOTOR		Plant: (4) BEN UNIT 2
Requested By: (5) MAINTENANCE		
Ground Discs Issued? (6)		<input type="checkbox"/> Yes
Remarks: (7) UNCOUPLE THE PSC HEAD TANK PUMP 2B IN SUPPORT OF PREVENTATIVE MAINTENANCE ON THE MOTOR.		
Placement Instructions: (8) NONE		
Caution Tag Information: (9) N/A		
Release Instructions: (10) NONE		
Prepared By: (11)	Date:	Time:
Placement Review: (12)	Date:	Time:
Placement Approved: (13)	Date:	Time:
Issued Status: (14)	Date:	Time:
Release Modified: (15)	Date:	Time:
Release Reviewed & Approved: (16)	Date:	Time:
Released: (17)	Date:	Time:

NPG Standard Programs and Processes	Clearance Procedure to Safely Control Energy	NPG-SPP-10.2 Rev. 0005 Page 49 of 80
-------------------------------------	--	--

Appendix B
(Page 8 of 11)

Completing Clearance

Tennessee Valley Authority
Clearance Tag List and Operational Steps

Clearance Sheet

Clearance No. (1)

Page ____ of ____ (2)

Apparatus: (3)												
Equipment ID Equipment Description Equipment Location	Tag Serial No.	Tag Type	Place. Seq.	Place. Config.	Place. 1st Verifier	Place. 2nd Verifier	Rest. Seq.	Restore Config.	As left Config.	Restore 1st Verifier	Restore 2nd Verifier	Tag Notes
(18)	(19)	(20)	(21)	(22)	(23)	(24)	(25)	(26)	(27)	(28)	(29)	(30)
2-HS-75-76A, PSC PUMP 2B	-	DANGER	1 or 2	PULL TO LOCK								
480V RMV BD 2B-DISCONNECT 11D	-	DANGER	1 or 2	OFF								
2-75-SHV-599, PSC PUMP 2B, SUCTION VALVE	-	DANGER	3 or 4	CLOSED								
2-75-SHV-603, PSC PUMP 2B, DISCHARGE VALVE	-	DANGER	3 or 4	CLOSED								

OPERATOR: _____

RO ____ SRO ____ DATE: _____

JPM NUMBER: 548

TASK NUMBER: Radiation Control

TASK TITLE: Locked High Radiation Entry

K/A NUMBER: 2.3.12 K/A RATING: RO 3.2

TASK STANDARD: Determine dress out requirements and estimate dose to verify within RWP and quarterly limits. Determines exceeds quarterly administrative dose limit of 1000 mRem and determines that the MG dose alarm will sound for a dose of greater than 200 mRem.

LOCATION OF PERFORMANCE: Class Room

REFERENCES/PROCEDURES NEEDED: Handout RWP and Survey Map, NPG-SPP 5.1

VALIDATION TIME: 15 minutes

PERFORMANCE TIME:

COMMENTS: _____

Additional comment sheets attached? YES ____ NO ____

RESULTS: SATISFACTORY ____ UNSATISFACTORY ____

SIGNATURE: _____ DATE: _____
EXAMINER

INITIAL CONDITIONS: You are a Browns Ferry employee who has obtained an accumulative yearly dose of 750 mrem.

The job will require you to vent the RWCU Regenerative Hx and to manually close the 3-FCV-69-2 valve and place a mechanical restraining device on the valve. The RWCU Regenerative Hx will be vented from the scaffold at the south end of the Hx's (a scaffold has been erected to be used for venting - cannot leave scaffold while venting is in progress), and will require 35 minutes for venting. Then proceed to 3-FCV-69-2 valve to manually close and install the mechanical restraining device, it should require 25 minutes to close the valve and another 25 minutes to install the mechanical restraining device. Assume the 30cm reading will be the whole body dose received at each location. Assume a total travel dose of 25 mrem will be received.

INITIATING CUES: Given the survey map and RWP, determine the following:

- Dress-out requirements for entry to perform your assigned task
- Whether you can complete the assigned task in the area without exceeding your TVA administrative dose limit
- Whether you can complete the assigned task in the area without exceeding the RWP dose entry limits both rate and total dose, i.e. will you receive an MG alarm (Electronic Dosimeter).

Class Room

INITIAL CONDITIONS: You are a Browns Ferry employee who has obtained an accumulative yearly dose of 750 mrem.

The job will require you to vent the RWCU Regenerative Hx and to manually close the 3-FCV-69-2 valve and place a mechanical restraining device on the valve. The RWCU Regenerative Hx will be vented from the scaffold at the south end of the Hx's (a scaffold has been erected to be used for venting - cannot leave scaffold while venting is in progress), and will require 35 minutes for venting. Then proceed to 3-FCV-69-2 valve to manually close and install the mechanical restraining device, it should require 25 minutes to close the valve and another 25 minutes to install the mechanical restraining device. Assume the 30cm reading will be the whole body dose received at each location. Assume a total travel dose of 25 mrem will be received.

INITIATING CUES: Given the survey map and RWP, determine the following:

- Dress-out requirements for entry to perform your assigned task
- Whether you can complete the assigned task in the area without exceeding your TVA administrative dose limit
- Whether you can complete the assigned task in the area without exceeding the RWP dose entry limits both rate and total dose, i.e. will you receive an MG alarm (Electronic Dosimeter).

START TIME _____

Performance Step 1: Critical Not Critical

Determines Dress Out requirements

Standard:

Shoe covers - one pair, Coveralls - one pair, Face Shield, Gloves – rubber - two pair, cloth inserts, Booties – plastic - 2 pair, Rain suit, and Hood

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 2: Critical Not Critical

Calculates RWCU HX venting dose.

Standard:

35 minutes in a 250 mrem/hr area = 145 to 146 mrem

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 3: Critical Not Critical

Calculates 69-2 valve work dose

Standard:

50 minutes in a 100 mrem/hr area = 83 to 84 mrem

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 4:

Critical Not Critical

Calculates total dose received

Standard:

25 mrem travel + 146 mrem venting + 83 mrem 69-2 = 254 mrem

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 5:

Critical Not Critical

Calculates total dose for quarter

Standard:

750 mrem + 254 mrem = 1004 mrem

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 6:

* Critical Not Critical

Verifies RWP MG Setpoints

Standard:

MG setpoints: for Dose Rate alarm of 500 mrem/hr will **not** be exceeded and ***Dose alarm of 200 mrem will be exceeded.**

SAT__ UNSAT__ N/A __ COMMENTS: _____

Performance Step 7:

Critical Not Critical

Verifies dose limits for quarter and RWP

Standard:

Verifies will have a total dose of greater than 1000 mrem which is above the TVA administrative limit.

SAT__ UNSAT__ N/A __ COMMENTS: _____


END OF TASK

STOP TIME ____

Browns Ferry Radiological Survey

M0044.tif - M0044 Unit 3 RXB 593' RWCU Heat Exchanger Room Survey # 021407-2

Date/Time: 2/14/2007 03:01



Postings	Contamination Results:																											
M0044 RX-3 593 RWCU HTX Room OPS venting heat exchangers. ND Beta HWC 9.6 scfm power @81%	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 5%;">1)</td> <td style="width: 40%;">20000 DPM/100 cm²</td> <td style="width: 55%;"></td> </tr> <tr> <td>2)</td> <td>40000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>3)</td> <td>300000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>4)</td> <td>1300000 mrad/hr/100 cm²</td> <td></td> </tr> <tr> <td>5)</td> <td>200000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>6)</td> <td>250000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>7)</td> <td>400000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>8)</td> <td>80000 DPM/100 cm²</td> <td></td> </tr> <tr> <td>9)</td> <td>200000 DPM/100 cm²</td> <td></td> </tr> </table>	1)	20000 DPM/100 cm ²		2)	40000 DPM/100 cm ²		3)	300000 DPM/100 cm ²		4)	1300000 mrad/hr/100 cm ²		5)	200000 DPM/100 cm ²		6)	250000 DPM/100 cm ²		7)	400000 DPM/100 cm ²		8)	80000 DPM/100 cm ²		9)	200000 DPM/100 cm ²	
1)	20000 DPM/100 cm ²																											
2)	40000 DPM/100 cm ²																											
3)	300000 DPM/100 cm ²																											
4)	1300000 mrad/hr/100 cm ²																											
5)	200000 DPM/100 cm ²																											
6)	250000 DPM/100 cm ²																											
7)	400000 DPM/100 cm ²																											
8)	80000 DPM/100 cm ²																											
9)	200000 DPM/100 cm ²																											
Surveyed by: Rose, Edward D. Instrument Nos.: 534105,448,562898																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33%;">Date</th> <th style="width: 33%;">Survey #</th> <th style="width: 33%;">Surveyed By:</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	Date	Survey #	Surveyed By:																									
Date	Survey #	Surveyed By:																										

RADIOLOGICAL WORK PERMIT
BRIEFING REQUIRED EVERY ENTRY**GENERAL DESCRIPTION**

Status: Active	Start Date: 01-Jan-This year	End Date: 01-Jan-Next year
Type: SPECIFIC	MAP ID:	Outage: Y
Task: ROUTINE PLANT MAINTENANCE		Name:
HP	CONTINUOUS	PSE: N
ALARA Review Number: 0A-0010	Authorization Type: INDIVIDUAL	Primary Work Doc:
Person-mrem Estimate: 1904	Person-Hrs Estimate: 1082	Dose Rate Alarm: 500
Dose Alarm: 200		
DAC-Hrs Tracked: N		
Work Area Description: RWCU HX Room Unit 3		

DESCRIPTION OF WORK TO BE PERFORMED

Unit 3 Maintenance on RWCU (69) Systems	(LHRA VARIOUS DRESS) 200 / 500
---	--------------------------------

ANTI-CONTAMINATION CLOTHING REQUIREMENTS

1	LAB COAT	1,2	BOOTIES, CLOTH, ONE PAIR
1,2	GLOVES, RUBBER, ONE PAIR	1,2,3	CLOTH INSERTS
1,2,3	SHOE COVERS, ONE PAIR	1,2,3	MODESTY CLOTHING
1,2,3	NO PERSONAL OUTER CLOTHING	1,2,3	SURGEON'S CAP
2,3	COVERALLS, ONE PAIR	3	BOOTIES, PLASTIC, TWO PAIR
3	FACE SHIELD	3	RAIN SUIT
3	GLOVES, RUBBER, TWO PAIR	3,4	HOOD

DOSIMETRY REQUIREMENTS

ELECTRONIC DOSIMETER	TLD
----------------------	-----

BRIEFING REQUIREMENTS

PRE-JOB BRIEFING	
------------------	--

WORK STEPS

1	MANAGEMENT / WO WALKDOWN
2	3-CI-412
3	OPS VALVE LINEUP - 3-OI-69 & HX VENTING
4	07-712928-000
5	06-722560-000
6	06-727133-000
7	06-722556-000
8	06-722559-000
9	06-718308-002
10	06-722558-000

RADIOLOGICAL WORK PERMIT
BRIEFING REQUIRED EVERY ENTRY

WORKER INSTRUCTIONS

1 DRESSOUT CODE APPLICATIONS 1) FLOOR LEVEL INSP, LOW TO MODERATE CONTAMINATION. 2) MINOR MAINTENANCE, NO PRIMARY SYSTEM BREACH. 3) PRIMARY SYSTEM BREACH, HEAT EXCHANGER VENTING. 4) ANY WORK ABOVE FLOOR LEVEL REQUIRES SAFETY BELT W/ LIFELINE. 5) REQUIRED TO WEAR HEADGEAR OTHER THAN PERSONAL HARDHAT.
2 MONITOR YOUR ED (DAD) FREQUENTLY, EXIT THE AREA PRIOR TO REACHING THE DOSE ALARM SET POINT OR UPON RECEIVING ANY UNEXPECTED ALARMS.
3 DO NOT EXCEED 200 mrem PER ENTRY OR DOSE MARGIN (RAD-REMAINING ALLOWABLE DOSE).
4 REMOTE MONITORING , PEA , OR SIMILAR DEVICE REQUIRED.
5 ED (DAD) TO BE BAGGED (WRAPPED) AND WORN OUTSIDE OF C-ZONE CLOTHING.
6 REVIEW PLANNED WORK OR INSPECTIONS WITH RAD PROTECTION PRIOR TO ENTRY.
7 UTILIZE TIME, DISTANCE, AND SHIELDING ALARA PRINCIPLES.
8 REVIEW APPROPRIATE SURVEY DATA PRIOR TO ENTRY. NOTE AND AVOID POSTED HOT SPOTS. LOCATE AND UTILIZE LOW DOSE WAITING AREAS.
9 RADWORKER SHALL ADHERE TO ANY SPECIAL INSTRUCTIONS (APR, ETC) ON WHICH HE/SHE HAS BEEN BRIEFED BY RAD PROTECTION.
10 NOTIFY RADCON PRIOR TO ANY SYSTEM BREACH.
11 RAD PROTECTION COVERAGE MAY BE PROVIDED FROM OUTSIDE THE C-ZONE.
12 SECURE ALL HOSES, ELECTRICAL CORDS, WELDING LEADS AND OTHER SERVICES ENTERING THE C-ZONE AT THE C-ZONE BOUNDRY AND NOTIFY RAD PROTECTION.
13 NOTIFY RAD PROTECTION OF ANY UNUSUAL RADIOLOGICAL CONDITIONS (FOR EXAMPLE: WATER, LEAKS, RADIATION MONITOR ALARMS).
14 RAD PROTECTION PERMISSION REQUIRED PRIOR TO WELDING, GRINDING, BUFFING OR OTHER SURFACE DISTURBING ACTIVITIES.

APPROVAL

Prepared by: TJFRANK
Approved by: MJHAZEL
Final Approval: JWSMITH3

End of RWP

OPERATOR: _____

RO _____ DATE: _____

JPM NUMBER: A2 Equipment Control

TASK NUMBER: S-000-AD-55

TASK TITLE: PSC Head Tank Pump 2B Clearance Boundary

K/A NUMBER: 2.2.13 K/A RATING: RO 4.1

TASK STANDARD: Determine the clearance boundary for PSC Head Tank Pump 2B

LOCATION OF PERFORMANCE: Class Room / Unit 2 Simulator

REFERENCES/PROCEDURES NEEDED: 2-47E814-1, 2-45E779-19, 2-47E610-75-1, 2-45E2750-4, and 2-45E751-3 and 5, NPG-SPP 10.2

VALIDATION TIME: 30 minutes

PERFORMANCE TIME:

COMMENTS:

Additional comment sheets attached? YES ___ NO ___

RESULTS: SATISFACTORY _____ UNSATISFACTORY _____

SIGNATURE: _____ DATE: _____
EXAMINER