



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

February 11, 2014

10 CFR 50.55a

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Units 1, 2, and 3
Renewed Facility Operating License Nos. DPR-33, DPR-52, and DPR-68
NRC Docket Nos. 50-259, 50-260, and 50-296

Subject: **American Society of Mechanical Engineers, Section XI Code, Inservice Inspection Program for the Unit 1 Second Ten-Year Inspection Interval, Unit 2 Fourth Ten-Year Inspection Interval, and Unit 3 Third Ten-Year Inspection Interval, Request for Relief ISI-44**

Reference: 1. Letter from NRC to TVA, "Browns Ferry Nuclear Plant - NRC Supplemental 95003 Inspection Report 05000259/2013011, 05000260/2013011, and 05000296/2013011," dated August 22, 2013 [ML13234A539]

In accordance with Title 10 of the U.S. Code of Federal Regulations (CFR) Part 50, Section 55a Specification (g)(5)(iii), the Tennessee Valley Authority (TVA) is requesting relief from the weld examination coverage criterion associated with American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, for 27 full penetration welds included in the intergranular stress corrosion cracking (IGSCC) Augmented Inspection Program for the Browns Ferry Nuclear Plant (BFN). The reduction in obtained weld examination coverage is due to access limitations caused by design, geometry, or materials of construction of the components. Although these are non-Code examinations, TVA has determined a request for relief in accordance with 10 CFR 50.55a(g)(5)(iii) is the most appropriate method to resolve the issue raised during an NRC inspection, as discussed below. Therefore, relief is requested for the BFN Units 1, 2, and 3 Ten-Year Inspection Intervals, which began June 2, 2008, May 25, 2011, and November 19, 2005, respectively.

On August 22, 2013, the NRC issued an Inspection Report (Reference 1) that identified a non-cited violation (NCV) associated with the examination of one of the welds (i.e., DRHR-2-12) for which relief is being requested. The NCV was associated with TVA's failure to perform a 10 CFR 50.59 evaluation for a departure from the IGSCC inspection methodology on an ASME Code Class 1 piping weld. This weld, and the others

A047
NRR

U.S. Nuclear Regulatory Commission
Page 2
February 11, 2014

included in this request for relief, is inspected as part of the BFN Non-Code Augmented Inspection Program.

The ASME Section XI Code of record for the BFN Units 1, 2, and 3 for the current ten-year Inservice Inspection intervals are the 2001 Edition with the 2003 Addenda, the 2004 Edition, and the 2001 Edition with the 2003 Addenda, respectively, as amended by 10 CFR 50.55a(b)(2)(xv)(A)(2).

Specifically, this request for relief addresses 27 welds included in the BFN Augmented Inspection Program associated with Generic Letter 88-01, "NRC Position on IGSCC in BWR Austenitic Stainless Steel Piping," and BWRVIP-75P-A, "BWR Vessel and Internals Project Technical Basis for Revisions to Generic Letter 88-01 Inspection Schedules." Ultrasonic examinations were performed on the accessible areas of these welds to the maximum extent practical given the design configuration or materials of the weld.

The enclosure to this letter contains the BFN Units 1, 2, and 3, Request for Relief ISI-44 for NRC review and approval. Table 1 of the enclosure contains specific information associated with each weld for which TVA is requesting exam coverage relief. Attachment A provided the associated Inservice Inspection Drawings and Attachment B provides excerpts from the weld examination reports.

TVA requests approval of this request for relief within one year from the date of this letter.

There are no new regulatory commitments contained in this letter. If you have any questions, please contact Mr. Jamie L. Paul at (256) 729-2636.

Respectfully,



K. J. Polson
Site Vice President

Enclosure:

Browns Ferry Nuclear Plant, Units 1, 2, and 3 American Society of
Mechanical Engineers, Section XI Code Inservice Inspection Program,
Request for Relief ISI-44

cc (w/Enclosure):

NRC Regional Administrator - Region II
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant

A047
1/18

Enclosure

**Tennessee Valley Authority
Browns Ferry Nuclear Plant
Units 1, 2, and 3**

Augmented Inservice Inspection Program

Request for Relief ISI-44

Enclosure

TENNESSEE VALLEY AUTHORITY Browns Ferry Nuclear Plant, Units 1, 2, and 3 Request for Relief ISI-44

Executive Summary:

In accordance with 10 CFR 50.55a(g)(5)(iii), the Tennessee Valley Authority (TVA) is requesting relief from augmented weld examination coverage requirements for 27 full penetration austenitic stainless piping welds due to access limitations caused by design, geometry, or materials of construction of the components. Ultrasonic examinations (UT) were performed on the subject welds to the maximum extent practical due to the configuration and design using the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the Performance Demonstration Initiative (PDI) Program in accordance with 10 CFR 50.55a(g)(4) and 10 CFR 50.55a(g)(6)(ii)(C). Table 1 of this Enclosure describes the limitations preventing achieving acceptable coverage for the weld examinations. Relief is requested for the Browns Ferry Nuclear Plant (BFN) Units 1, 2, and 3, Ten-Year Inspection Interval, as listed below.

Unit: Browns Ferry Nuclear Plant, Units 1, 2, and 3

Systems:

- Residual Heat Removal (RHR) System
- Control Rod Drive (CRD) System
- Reactor Water Recirculation (RECIRC) System
- Reactor Water Cleanup (RWCU) System

Components Affected: 27 Full Penetration Piping Welds

- (10) RHR System full penetration piping welds,
- (6) CRD System full penetration piping welds,
- (5) RECIRC System full penetration piping welds, and
- (6) RWCU System full penetration piping welds,

IGSCC Category:

IGSCC Category for each weld is listed in Table 1

Enclosure

TENNESSEE VALLEY AUTHORITY Browns Ferry Nuclear Plant, Units 1, 2, and 3 Request for Relief ISI-44

Section XI Edition:

Unit 1 2001 Edition with the 2003 Addenda

Unit 2 2004 Edition

Unit 3 2001 Edition with the 2003 Addenda

Code Requirement:

Code Case N-460

Code Requirements from Which Relief Is Requested:

Code Case N-460 When the entire examination volume or area cannot be examined due to interference by another component or part geometry, a reduction in examination coverage may be accepted provided the reduction in coverage for that weld is less than 10%.

List of Components Associated with this Request for Relief:

See Table 1

Welds RCRD-2-49 and RCRD-2-50 have been removed under Design Change Notice (DCN) 71086A. Although these welds have been removed, TVA is requesting relief for these weld inspections that were performed prior to their removal.

Reason for Request:

The design configurations of the listed welds preclude a UT examination of essentially 100 percent of the required volume. It is not possible to perform the volumetric UT from both sides of each weld due to the configuration of these components.

10 CFR 50.55a(b)(2)(xv)(A)(2) states, "Where examination from both sides is not possible on austenitic welds or dissimilar metal welds, full coverage credit from a single side may be claimed only after completing a successful single-sided Appendix VIII demonstration using flaws on the opposite side of the weld." The component design configuration limits UT examination coverage of the welds to the percentages shown in Table 1 based on limitations discussed in Table 1. Only the stated coverage ranging from 12% to 88% can be claimed for these welds.

Proposed Alternative and Basis for Use:

No alternative method of examination is proposed. In lieu of the ASME Section XI Code required essentially 100 percent volumetric ultrasonic examination, TVA proposes credit for ultrasonic examination of accessible areas to the maximum extent practical for the component design configuration of the piping welds.

Enclosure

TENNESSEE VALLEY AUTHORITY Browns Ferry Nuclear Plant, Units 1, 2, and 3 Request for Relief ISI-44

Justification for Granting Relief:

The welds were examined with the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the PDI Program, in accordance with the requirements of the 2001 Edition, 2003 Addenda (Units 1 and 3), and the 2004 Edition (Unit 2), as amended by 10 CFR 50.55a(b)(2)(xv)(A) and 10 CFR 50.55a(b)(2)(xxiv), of ASME Section XI, Division 1, Appendix VIII as mandated by 10 CFR 50.55a(g)(4). These examinations were of the accessible areas to the maximum extent practical due to the design configuration of the weld joints.

10 CFR 50.55a(b)(2)(xv)(A)(2) states, "Where examination from both sides is not possible on austenitic welds or dissimilar metal welds, full coverage credit from a single side may be claimed only after completing a successful single-sided Appendix VIII demonstration using flaws on the opposite side of the weld." The "Comments" column of Table 1 describes coverage limitations due to the inability to examine welds from both sides, when applicable.

Credit for the one-sided only ultrasonic examination provides coverage ranging from 12% to 88%. These welds are part of a larger population of welds examined in which examination coverage is not reduced for which the required coverage is attained. When considered in aggregate with the entire sample population, an adequate level of inspection occurs to provide reasonable assurance that a pattern of IGSCC degradation that, if present, could affect the overall integrity of the components would be detected. These examinations provide an acceptable level of quality and safety, to the extent practical.

Therefore, pursuant to 10 CFR 50.55a(g)(5)(iii), TVA requests that relief be granted for the BFN Units 1, 2, and 3 for the second, fourth, and third Ten-Year ISI inspection intervals, respectively.

Implementation Schedule:

This request for relief is applicable to the following Ten-Year ISI inspection intervals for BFN:

- Unit 1, Second Ten-Year Interval which began on June 2, 2008, and will end on June 1, 2017;
- Unit 2, Fourth Ten-Year Interval which began on May 25, 2011, and will end on May 24, 2021, and;
- Unit 3, Third Ten-Year Interval which began on November 19, 2005, and will end on November 18, 2015.

The welds described above are listed in Table 1 of this enclosure. The welds associated with Unit 1 were examined during the first period (Cycle 7 - Fall 2008), the second period

Enclosure

TENNESSEE VALLEY AUTHORITY Browns Ferry Nuclear Plant, Units 1, 2, and 3 Request for Relief ISI-44

(Cycle 8 - Fall 2010), and the third period (Cycle 9 - Fall 2012) of the second Ten-Year inspection interval. The welds associated with Unit 2 were examined during the first period (Cycle 17 – Spring 2013) of the fourth Ten-Year inspection interval. The welds associated with Unit 3 were examined during the second period (Cycle 13 - Spring 2008), the third period (Cycle 14 - Spring 2010), and the fourth period (Cycle 15 - Spring 2012) of the third Ten-Year inspection interval.

Precedent:

This request for relief is similar to the following BFN requests for relief:

- 2-ISI-29, NRC approved by letter dated May 31, 2013 [ML13148A308]
- 3-ISI-25, NRC approved by letter dated January 20, 2012 [ML12003A081]
- 2-ISI-18R1, NRC approved by letter dated June 16, 2009 [ML091200040]
- 3-ISI-22, NRC approved by letter dated May 20, 2008 [ML080080524]
- 2-ISI-18, NRC approved by letter dated April 12, 2004 [ML041040375]
- 2-ISI-15, NRC approved by letter dated April 3, 2003 [ML030970815]

Attachments:

Attachment A - Inservice Inspection Drawings:

- 1-CHM-1081-C-1
- 1-CHM-1081-C-2
- 1-CHM-1088-C-1
- 1-CHM-1098-C-1
- 1-CHM-1098-C-2
- 1-ISI-0362-C-8
- 2-ISI-0221-C-1
- 2-ISI-0270-C-2
- 2-ISI-0272-C-1
- 3-ISI-0328-C-2
- 3-ISI-0330-C-1
- 3-ISI-0332-C-1

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Attachment B - Examination Reports:

- R024
- R078
- R098
- R237
- R253
- R254
- R257
- UT-10-024
- UT-10-026
- UT-10-028
- UT-10-030
- UT-12-027
- UT-12-031
- UT-12-039
- UT-12-054
- UT-12-055
- UT-12-058
- UT-12-060
- UT-13-004
- UT-13-013
- UT-13-024
- UT-13-044
- UT-13-072
- UT-13-076
- UT-13-079
- UT-13-080
- UT-13-086

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1

Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
DRHR-1-2 (RHR System)	D	24"	1-ISI-0362-C-8 (R237)	50%	1/7	ASTM A351, CF8M Casting Stainless Steel Valve to ASTM A106 GR. B Carbon Steel Pipe	ER309 stainless steel ¹ .	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. However, far side coverage for one sided examinations can only be credited if the far side of the weld is of wrought material. Because the far side of the weld is of cast material and although techniques were applied that are intended to interrogate the far side of the weld, no examination credit was applied since the far side of the weld is cast material. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
RCRD-1-50 (CRD System)	C	4"	1-CHM-1098-C-2 (R253)	81%	1/7	Carbon steel Elbow to forged stainless steel (A182 F316) Valve (dissimilar metal weld).	ER309 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 81% coverage can be claimed.
RCRD-1-52 (CRD System)	C	4"	1-CHM-1098-C-2 (R254)	88%	1/7	Carbon steel Pipe to forged stainless steel (A182 F316) Valve (dissimilar metal weld).	ER309 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 88% coverage can be claimed.
RCRD-1-49 (CRD System)	C	4"	1-CHM-1098-C-2 (R257)	81%	1/7	Carbon steel Elbow to forged stainless steel (A182 F316) Valve (dissimilar metal weld).	ER309 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 81% coverage can be claimed.

¹ TVA is unable to locate the Weld Data sheet for this weld. However based on the best available information of the process and procedures used for this configuration TVA concluded that the weld material is ER309.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1(continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
RWR-1-001-003 (RECIRC System)	A	28"	1-CHM-1081-C-1 (UT-10-024)	50%	1/8	SA376 TP316NG Pipe to A351 CF8 Cast Valve.	IN/ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
RWR-1-002-012 (RECIRC System)	A	28"	1-CHM-1081-C-2 (UT-10-026)	50%	1/8	SA376 TP316NG Pipe to A351 CF8 Cast Valve.	IN/ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
RWR-1-001-S023A (RECIRC System)	A	4"	1-CHM-1081-C-1 (UT-10-028)	50%	1/8	SA403 WP316NG Branch to SA376 TP316NG Pipe.	316 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought piping branch connection that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1(continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
RWCU-1-001-019 (RWCU System)	A	6"	1-CHM-1098-C-1 (UT-10-030)	50%	1/8	SA376 TP316NG Pipe to SA351 CF8M Cast Valve.	IN/ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
DRHR-1-3 (RHR System)	D	24"	1-CHM-1088-C-1 (UT-12-055)	13%	1/9	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel. ²	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 13% coverage can be claimed.
DRHR-1-12 (RHR System)	D	24"	1-CHM-1088-C-1 (UT-12-054)	12%	1/9	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel. ³	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 12% coverage can be claimed.

² TVA is unable to locate the Weld Data sheet for this weld. However based on the best available information of the process and procedures used for this configuration TVA concluded that the weld material is ER308.

³ TVA is unable to locate the Weld Data sheet for this weld. However based on the best available information of the process and procedures used for this configuration TVA concluded that the weld material is ER308.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1(continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
RWCU-1-005-006 (RWCU System)	D	4"	1-CHM-1098-C-2 (UT-12-058)	23%	1/9	A182 F316 Valve (Forged) to A351 CF8M Cast Valve .	IN/ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to the side of the valve that was wrought and then only for detection of axially oriented flaws. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The ultrasonic examination was conducted to the maximum extent practical. Only 23% coverage can be claimed.
RWR-1-002-053 (RECIRC System)	A	28"	1-CHM-1081-C-2 (UT-12-060)	50%	1/9	SA376 TP316NG Pipe to A351 CF8 Cast Valve.	IN/ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
RCRD-2-49 (CRD System)	D	4"	2-ISI-0272-C-1 (UT-13-013)	63%	2/17	Carbon steel Elbow to forged stainless steel (A182 F316) Valve (dissimilar metal weld).	ER309 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 63% coverage can be claimed. The stainless steel valve was removed and replaced by a carbon steel spool piece. Weld RCRD-2-49 was replaced by weld CRD-2-005-006, Carbon Steel Pipe to Pipe. RCRD-2-49 is no longer in the IGSCC Program.
RCRD-2-50 (CRD System)	D	4"	2-ISI-0272-C-1 (UT-13-086)	56%	2/17	Carbon steel Elbow to forged stainless steel (A182 F316) Valve (dissimilar metal weld).	ER309 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 56% coverage can be claimed. The stainless steel valve was removed and replaced by a carbon steel spool piece. Weld RCRD-2-50 was replaced by weld CRD-2-005-007, Carbon Steel Pipe to Pipe. RCRD-2-50 is no longer in the IGSCC Program.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1 (continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
KR-2-25 (RECIRC System)	C	28"	2-ISI-0270-C-2 (UT-13-072)	50%	2/17	A358 TP 304 stainless steel Pipe to A403 WP 304 stainless steel Tee.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought piping "T" fitting that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50 percent coverage can be claimed.
DRHR-2-03 (RHR System)	D	24"	2-ISI-0221-C-1 (UT-13-044)	50%	2/17	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
DRHR-2-09 (RHR System)	E	24"	2-ISI-0221-C-1 (UT-13-079)	50%	2/17	A358 GR304 stainless steel Pipe to A403 WP304 stainless steel Tee.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought piping "T" fitting that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1 (continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
DRHR-2-12 (RHR System)	D	24"	2-ISI-0221-C-1 (UT-13-004)	50%	2/17	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
DRHR-2-22 (RHR System)	E	20"	2-ISI-0221-C-1 (UT-13-080)	50%	2/17	A358 GR 304 stainless steel Pipe to A351 CF8M Cast Valve.	E/ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
CRD-2-005-003 (CRD System)	D	4"	2-ISI-0272-C-1 (UT-13-024)	71%	2/17	A333 GR1 carbon steel Pipe to A182 F316 stainless steel Valve (dissimilar metal weld).	ER309L stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-10, for dissimilar metal welds. The procedure is qualified for far side of the weld examination credit when the examination is restricted to one side of the weld. The ultrasonic examination was conducted to the maximum extent practical. Only 71% coverage can be claimed.
RWCU-2-003-070 (RWCU System)	D	6"	2-ISI-0272-C-1 (UT-13-076)	74%	2/17	A403 WP304 stainless steel Sweep-o-let to SA376 TP316 stainless steel Pipe.	ER316/316L stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought pipe to a branch connection configuration that partially restricts the ultrasonic examination. This configuration partially limited the circumferential scan surface for detection of axially oriented flaws on the branch connection side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI phased array procedure, EPRI-PIPE-MPA-1, for similar metal piping welds. The ultrasonic examination was conducted to the maximum extent practical. Only 74% coverage can be claimed.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Table 1 (continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
RWCU-3-001-070 (RWCU System)	A	6"	3-ISI-0332-C-1 (R098)	31%	3/13	A403 WP304 stainless steel Sweep-o-let to A351 CF8M Cast Valve.	ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought piping branch connection to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the branch connection side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 31% coverage can be claimed.
RWCU-3-001-071 (RWCU System)	A	6"	3-ISI-0332-C-1 (R078)	50%	3/13	SA376 TP316NG stainless steel Pipe to A351 CF8M Cast Valve.	ER308L stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
DRHR-3-03 (RHR System)	D	24"	3-ISI-0330-C-1 (UT-12-039)	30%	3/15	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 30% coverage can be claimed.

Enclosure

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**


Table 1(continued)								
Weld Number (System)	IGSCC Category	Nominal Pipe Size (NPS)	ISI Drawing Number (Weld Report)	Examination Coverage Percent (Nearest %)	Unit / Cycle Inspection Performed	Joint Configuration	Weld Material	Comments
DRHR-3-12 (RHR System)	D	24"	3-ISI-0330-C-1 (UT-12-031)	30%	3/15	A182 F304 Flued Head to A351 CF8M Cast Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a wrought fluted head penetration to a cast valve configuration that restricts the ultrasonic examination on both sides of the weld. This configuration limited the scan surface to only a portion of the fluted head side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 30% coverage can be claimed.
DRHR-3-21 (RHR System)	C	20"	3-ISI-0330-C-1 (R024)	50%	3/14	A403 WP304 stainless steel Elbow to A351 CF8M Cast Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.
GR-3-63 (RECIRC System)	E	28"	3-ISI-0328-C-2 (UT-12-027)	50%	3/15	A358 TP 304 stainless steel Pipe to A351 CF8 Cast steel Valve.	ER308 stainless steel.	Examination coverage limitations are due to the physical configuration of a cast valve that restricts the ultrasonic examination to one side of the weld. Examinations were conducted in accordance with an ASME Section XI, Appendix VIII qualified generic PDI procedure, PDI-UT-2, for austenitic metal welds. The qualified procedure requires examination techniques be applied that are intended to interrogate the far side of the weld. However, the generic ultrasonic procedure (or any other existing procedure) is not qualified for detection of flaws on the far side of the weld in austenitic material. Therefore, no examination credit was applied for the far side of the weld that was inaccessible. The ultrasonic examination was conducted to the maximum extent practical. Only 50% coverage can be claimed.

**BFN Units 1, 2, and 3
Request for Relief ISI-44**

**Enclosure
Attachment A**

Inservice Inspection Drawings

**1-CHM-1081-C-1
1-CHM-1081-C-2
1-CHM-1088-C-1
1-CHM-1098-C-1
1-CHM-1098-C-2
1-ISI-0362-C-8
2-ISI-0221-C-1
2-ISI-0270-C-2
2-ISI-0272-C-1
3-ISI-0328-C-2
3-ISI-0330-C-1
3-ISI-0332-C-1**




REFERENCE DRAWINGS:
1-47E408-5
DCN 51045

MATERIAL SPECIFICATIONS:
2" PIPE SA-376 TP316NG
2" FITTING-SA-182 F316NG
4" FITTING-SA-182 F316L (CAP & FLANGE)
4" WELDOLET-SA403 WP 316NG
12" PIPE SA376 TP316NG
22" PIPE SA403 WP 316NG
28" PIPE SA376 TP316NG
28" FITTING-SA403 WP 316NG
VALVES SS CASTINGS A351 CF8
PUMP CASING SS CASTING A351 CF8M

ASME CC-1 (EQUIVALENT)

—|— SHOP WELD
—||— FIELD WELD

NOTE:
RECIRC NOZZLES (INNER RADIUS)
N1A-IR
N2F-IR
N2G-IR
N2H-IR
N2J-IR
N2K-IR



DETAIL "A"

4" DECONTAMINATION LINE
RWR-1-001-012

(SEE DETAIL "A")
RWR-1-001-S013A

K = KELLOGG SHOP WELD
G = GE FIELD WELD
XR-N-N WELD NO.
SYSTEM UNIT NO.

SYSTEM NO.
068

003	ADMIN	K KING	B Campbell	DP Walker	7-30-12
REVISED PER RIMS MEMO R14 120119 105 (REF: BPER 443133) AND R14 090821 101					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE

TENNESSEE VALLEY AUTHORITY


BROWNS FERRY NUCLEAR PLANT
UNIT 1
RECIRCULATION SYSTEM
WELD LOCATIONS

DRAWN:	SUBMITTED	APPROVED	SCALE NTS
DATE:	DATE:	DATE:	SHEET 1 OF 2 SHEET(S)
CHECKED:			DRAWING NO.
DATE:			1-CHM-1081-C 003

ALL A/D HISTORY RESEARCHED AT ROOD

CAD MAINTAINED DRAWING

CCD



REFERENCE DRAWINGS:

1-47E403-6
DCN 51045

MATERIAL SPECIFICATIONS:

- 2" PIPE SA376 TP316NG
- 2" FITTING, SA182 F316NG
- 4" FITTING SA182 F316L (CAP & FLANGE)
- 4" WELDOLET-SA-403 WP316NG
- 12" PIPE-SA376 TP316NG
- 22" PIPE SA-403 WP 316NG
- 28" PIPE SA-376 TP316NG
- 28" FITTING-SA403 WP316NG


VALVES SS CASTINGS A351 CF8
PUMP CASING SS CASTING A351 CF8M

ASME CC-1 (EQUIVALENT)

- SHOP WELD
- FIELD WELD

NOTE:

RECIRC NOZZLES (INNER RADIUS)
N1B-IR
N2A-IR
N2B-IR
N2C-IR
N2D-IR
N2E-IR



DETAIL "A"

002	ADMIN	K KING	Campbell	DP W/ker	7-30-12
REVISED PER RIMS MEMO R14 120119 105 (REF: BPER 443133) AND R14 090821 101					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE


TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT
UNIT 1
RECIRCULATION SYSTEM
WELD LOCATIONS

DRAWN: TWT	SUBMITTED	APPROVED	SCALE NTS
DATE:	DATE:	DATE:	SHEET 2 OF 2 SHEET(S)
CHECKED:			DRAWING NO.
DATE:			REV.

1-CHM-1081-C 002
CAD MAINTAINED DRAWING
CCD

ALL A/D HISTORY RESEARCHED AT ROOD



REFERENCE DRAWINGS

RWCU-1-001 (TVA WELD MAP)
 DCN 51046
 1-47E406-7, -8
 1-47BM406-60

MATERIAL SPECIFICATIONS

FITTINGS 6" SA403 WP316NG SCH 80
 PIPING 6" SA376 TP316NG SCH 80
 BENT PIPING 6" SA403 WP316NG SCH 80
 VALVE 6" SA-351 CF8M

ASME CC-1 (EQUIVALENT)

—/— SHOP WELDS
 -/ - FIELD WELDS

000	ADMIN	W. TRIVETT	<i>[Signature]</i>	14-11-05
ISSUED TO CREATE CCD PER RIMS MEMO #78 030216 006; SUPERSEDES AS DESIGNED CHM-1098-C-1 RB (ADMINISTRATIVE REVISION)				
REV	CHANGE REF	PREPARER	CHECKER	APPROVED DATE

SYSTEM NO. 069
TENNESSEE VALLEY AUTHORITY
 BROWNS FERRY NUCLEAR PLANT
 UNIT 1
 REACTOR WATER CLEAN UP, RCIC, AND CRD
 WELD IDENTIFICATION

DRAWN: TWI	DATE:	SCALE: NTS	CADAM/ISICMP
CHECKED:	APPROVED:	SHEET 01 OF 02	REV
SUBMITTED:		1-CHM-1098-C	000

CCD

ALL A/D HISTORY RESEARCHED AT ROOD

CAD MAINTAINED DRAWING




REFERENCE DRAWINGS
 TVA 47W335-14
 TVA 47W335-17
 DRAVO E-2460-IC-4

NOTE:
 THIS DRAWING SUPERSEDES CHM-1097-C

MATERIAL SPECIFICATIONS
 4" X 0.337" NOM. WALL - CS
 SCH. 80 A-333, GR1 (SEAMLESS)
 6" X 0.562 NOM. WALL - CS, SCH. 120
 8" X 0.593 NOM. WALL - CS, SCH. 100
 CRD CAP 4" X 0.674" NOM. WALL SS
 4" VALVE 69-629 SA-216 WCB

VALVE SHV-69-580, SS CASTING A351 CF8M
 VALVES CKV-69-579, 85-576, & 85-577
 SS FORGINGS A182 F316

NOTE: ALL FIELD WELDS WERE MADE BY TVA
 ASME CC-1 (EQUIVALENT)



ADMIN

003	ADMIN	K KING	Campbell	DP #6/ker	7-30-12
REVISED PER RIMS MEMO R14 120119 105, (REF: BPER 443133)					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 1 REACTOR WATER CLEAN UP, RCIC, AND CRD WELD IDENTIFICATION					
DRAWN: PHB	DATE: 1-4-93	SCALE: NTS	CADAM/ISIGMP		
CHECKED: RPG	APPROVED:	SHEET 02 OF 02		REV	
SUBMITTED: JES	GLB	1-CHM-1098-C		003	

ALL A/D HISTORY RESEARCHED AT ROOD

CAD MAINTAINED DRAWING

CCD

NOTE:

1. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-1D (DOWNSTREAM)
- (BASE WELD NO.)-LS-2D (DOWNSTREAM)
- (BASE WELD NO.)-LS-1U (UPSTREAM)
- (BASE WELD NO.)-LS-2U (UPSTREAM)

THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHEST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)

2. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-D (DOWNSTREAM)
- (BASE WELD NO.)-LS-U (UPSTREAM)

REFERENCE DRAWINGS:


- 47N1568
- 47W335-4 & 6
- 47W452 SERIES
- DRAVO E-2458-IC-31, 32, & 33
- 2-ISI-0276-C SH1
- NOTE: THIS DRAWING SUPERCEDES CHM-2070-C ALL SHEETS.

MATERIAL SPECIFICATION:

- STAINLESS PIPE A-358, GR 304, CL. 1
- STAINLESS FITTINGS A-403WP304
- 24" X 1.219" NOM. WALL THK. SCH. 80 SS
- 20" X 1.031" NOM. WALL THK. SCH. 80 SS
- 20" X 1.031" NOM. WALL THK. SCH. 80 CS
- 6" X 0.432" NOM. WALL THK. SCH. 80S SS

FLUED HD SS FORGING A182 F304 VALVES WITH THE EXCEPTION OF FCV-74-47 ARE SS CASTINGS A351 CF8M.

ASME CC-1 (EQUIVALENT)



ADMIN

☐ RISK INFORMED WELD

003 ADMIN M.L. POOLE B Campbell DP Walker 7-27-12

REVISED PER RIMS MEMO R14 120119 105 (REF: BPPER 443133)

REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE

TENNESSEE VALLEY AUTHORITY


**BROWNS FERRY NUCLEAR PLANT
UNIT 2
RESIDUAL HEAT REMOVAL SYSTEM
WELD LOCATIONS**

DRAWN: RPG	DATE: 6-20-88	SCALE: NTS	CADAM/ISTCMP
CHECKED: JES	APPROVED: GLB	SHEET 01 OF 02	REV
SUBMITTED: EDC		2-ISI-0221-C	003

CAD MAINTAINED DRAWING

CCD

ALL A/D HISTORY RESEARCHED AT ROOD



REFERENCE DRAWINGS:

- 2-47W2408-8,9 (S.E. REPLACEMENT)
- GE 769E963 (S.E. REPLACEMENT)
- TVA 47K1544-2
- GE 2-153F754
- KELLOGG BF 2-180
- NOTE: THIS DRAWING SUPERSEDES CHM-2068-C ALL SHEETS

MATERIAL SPECIFICATIONS:

- A358, TP 304
- 4" X 0.337" NOM WALL THK. (SS)
- 12" X 0.569" NOM. WALL THK. (SS)
- 22" X 1.030" NOM. WALL THK. (SS)
- 28" X 1.138" NOM. WALL THK. (SS) SUCTION
- 28" X 1.322" NOM. WALL THK. (SS) DISCHARGE

- 2" SCH. 80, A376, TP304
- 2" FITTINGS A182, F304

- SAFE END REPLACEMENT
- 12" X 0.688 NOM. WALL THK. (SS)
- SA 403 WP 316 N.G.

- VALVES SS CASTINGS A351 CF8
- PUMP CASING SS CASTING A351 CF8M

ASME CC-1 (EQUIVALENT)

NOTES:

1. ALL 2" WELDS ARE SOCKET WELDED EXCEPT WHERE NOTED.
2. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:
 - (BASE WELD NO.)-LS-1D (DOWNSTREAM)
 - (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 - (BASE WELD NO.)-LS-1U (UPSTREAM)
 - (BASE WELD NO.)-LS-2U (UPSTREAM)

THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHERMOST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)

3. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS
 - (BASE WELD NO.)-LS-D (DOWNSTREAM)
 - (BASE WELD NO.)-LS-U (UPSTREAM)

 RISK INFORMED WELDS

006	ADMIN	M.L. POOLE	B. Campbell	DP Walker	7-30-12
REVISED PER RIMS MEMO R14 120119 105 (REF: BPER 443133)					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2 RECIRCULATION SYSTEM WELD LOCATIONS					
DRAWN: PHB	SUBMITTED	APPROVED	SCALE NTS		
DATE: 3-28-89	DATE 5-8-89	DATE 5-12-89	SHEET 2 OF 2 SHEET(S)		
CHECKED: JES	EDC	GLB	DRAWING NO.	REV.	
DATE: 5-3-89			2-ISI-0270-0006		

K = KELLOGG SHOP WELD
G = GE FIELD WELD

XR-N-N WELD NO.
UNIT NO.

2RXN WELD NO.
UNIT NO. RISER LETTER

ALL A/D HISTORY RESEARCHED AT ROOD

CAD MAINTAINED DRAWING

CCD

REFERENCE DRAWINGS

CRD-2-005
 RCIC-2-004
 RWC-2-001
 47W335-14, -17

NOTE:
 THIS DRAWING SUPERSEDES CHM-2075-C
 AND CHM-2072-C (ALL SHEETS)

MATERIAL SPECIFICATIONS

STAINLESS STEEL
 FITTINGS
 6" SA403 WP316NG SCH. 80 SS
 PIPING
 6" SA376 TP316NG SCH. 80 SS
 6" A376GR TP304 SCH. 80 SS
 6" A312GR TP304 SCH. 80 SS

CARBON STEEL

4" SCH. 80 A-333, GR1 (SEAMLESS) CS
 6" X 0.562" NOM WALL SCH. 120 CS
 8" X 0.593" NOM WALL SCH. 100 CS


VALVES

2-69-630 SA351 CF8M SS
 2-69-580 A351 CF8M SS
 2-FCV-69-01 A351 CF8M SS
 2-FCV-69-02 A351 CF8M SS
 2-85-577 A182 F316 SS
 2-85-576 A182 F316 SS
 2-69-579 A182 F316 SS


CRD CAP
 4" X 0.674" NOM WALL SS

ASME CC-1 (EQUIVALENT)

 RISK INFORMED WELD




REGION OF THERMAL FATIGUE
 EXAMINATION PER NUREG-0619
 THERMAL TEE
 (UPSTREAM OF VALVE
 2-FCV-69-630)



R14 120119 105

R14 070503 101



010	ADMIN	B CAMPBELL	J. McFarland	DP Walker	05/22/12
REVISED PER RIMS MEMOS R14 070503 101 AND R14 120119 105 (REF: BFPER 443133)					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE

TENNESSEE VALLEY AUTHORITY
 BROWNS FERRY NUCLEAR PLANT
 UNIT 2
 REACTOR WATER CLEAN UP, RCIC,
 AND CRD WELD IDENTIFICATION

DRAWN: PHB	DATE: 6-9-88	SCALE: NTS	CADAM/ISICMP
CHECKED: JES	APPROVED: GLB	SHEET 01 OF 03 REV	
SUBMITTED: EDC		2-ISI-0272-C p10	

ALL A/D HISTORY RESEARCHED AT ROOQ

CAD MAINTAINED DRAWING

CCD

NOTE:


- PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:

(BASE WELD NO.)-LS-1D (DOWNSTREAM)
 (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 (BASE WELD NO.)-LS-1U (UPSTREAM)
 (BASE WELD NO.)-LS-2U (UPSTREAM)


THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHERMOST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)

- PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS


(BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)



ADMIN

SYMBOL:
 RISK-INFORMED WELD

DO2	ADMIN	M.L. POOLE	Campbell	DP Miller	7-30-12
REVISED PER RIMS MEMO R14 120119 105 (REF: BFER 443133)					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT					
UNIT 3					
RESIDUAL HEAT REMOVAL SYSTEM					
WELD LOCATIONS					
DRAWN:	PHB	DATE:	5-17-89	SCALE:	NTS
CHECKED:	JES	APPROVED:	GLB	CADAM/ISICMP	
SUBMITTED:	EDC			SHEET	01 OF 01
				REV	
				3-ISI-0330-C	002
CAD MAINTAINED DRAWING				CCD	



REFERENCE DRAWINGS
 RWCU-3-001 (TVA WELD MAP)
 NOTE:
 THIS DRAWING SUPERSEDES A PORTION
 OF CHM-2144-C

MATERIAL SPECIFICATIONS
 FITTINGS
 6" SA403 WP316NG SCH. 80
 PIPING
 6" SA376 TP316NG SCH. 80
 VALVES SS CASTINGS A351 CF8M

ADMIN ASME CC-1 (EQUIVALENT)

002	ADMIN	M. L. POOLE	B. Campbell	DP Walker	7-30-12
REVISED PER RIMS MEMO R14 120119 105 (REF: BPPER 443133)					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 3 REACTOR WATER CLEAN UP, RCIC, AND CRD WELD IDENTIFICATION					
DRAWN:	PHB	DATE:	5-17-89	SCALE:	NTS
CHECKED:	JES	APPROVED:	GLB	CADAM/ISICMP	
SUBMITTED:	EDC			SHEET	01 OF 02
				REV	002
3-ISI-0332-C					

CCD

ALL A/D HISTORY RESEARCHED AT ROOD

CAD MAINTAINED DRAWING

**BFN Units 1, 2, and 3
Request for Relief ISI-44**

**Enclosure
Attachment B**

Weld Examination Reports

**R024
R078
R098
R237
R253
R254
R257
UT-10-024
UT-10-026
UT-10-028
UT-10-030
UT-12-027
UT-12-031
UT-12-039
UT-12-054
UT-12-055
UT-12-058
UT-12-060
UT-13-004
UT-13-013
UT-13-024
UT-13-044
UT-13-072
UT-13-076
UT-13-079
UT-13-080
UT-13-086**

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R024

(2 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R024</i>	
PROJECT: BFN		UNIT: 3	CYCLE: 14	COMPONENT ID: DRHR-3-21	
EXAMINATION METHOD				SYSTEM: RHR	ISI DWG. NO. 3-ISI-0330-C-01
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: 1	CATEGORY: R-A
PROCEDURE: N-UT-64		REV: 11	TC: N/A	CONFIG.: Elbow	TO Valve
EXAMINER: Tommy Brown		EXAMINER: Kristen Davis		EXAMINER: N/A	EXAMINER: N/A
LEVEL: III		LEVEL: Trn		LEVEL:	LEVEL:
<p>This report contains the data associated with the manual ultrasonic examination weld DRHR3-21. The exam was performed to meet the requirements of NU0313, EXREQ B02-02 Category C and ASME Section XI 2001 Edition 2003 Addenda, Category R-A, Item R1.16C.</p> <p>This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.</p> <p>This exam was performed using TVA Nuclear Procedure N-UT-64 Rev. 11 which incorporates PDI-UT 2 Rev C Addenda No. 1, 2, and 3, for UT examination Austenitic Welds. .</p> <p>The component was a single sided stainless steel piping weld, 20 inch diameter schedule 80 1.031" nominal Elbow to Valve weld, which limited the upstream scan due to configuration.</p> <p>A 45° Shear and a 60° RL was used for the axial scans and a 45° Shear for circ scans.</p> <p><i>RJ 2/5/14</i> ~53.75 Coverage Achieved. 50%.</p>					
RESOLUTION BY: Tommy Brown <i>Tommy Brown</i>		REVIEWED BY: Matt Welch <i>Matt Welch</i>		ANI: <i>Lawrence Howard</i>	
LEVEL: III		LEVEL: III		DATE: 3/16/10	PG. 1 OF 6
DATE: 03/04/2010		DATE: 3/9/10			


TVA **WALL THICKNESS PROFILE SHEET** **REPORT NO: R024**

PROJECT: BEFP
 UNIT: 3 CYCLE 14

WELD NO: DRHR-3-21
 SYSTEM: RHR

Record Thickness Measurements As Indicated, including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	1.23			
2	1.19	N		
3	1.20			
4	NA			A
5	NA			




CROWN HEIGHT: FLUSH DIAMETER: 2.0"
 CROWN WIDTH: 1.5" WELD LENGTH: 60.45"

Scan 3 .4 x 1.0 x 60.45 = 24.18
 Scan 4 0 x 0 x 0 = 0
 Scan 5 .4 x 1.65 x 60.45 = 39.9
 Scan 6 .4 x 1.65 x 60.45 = 39.9
 Achieved volume $\frac{103.98}{48.36 \times 4} = 53.75\%$
 required volume $48.36 \times 4 = 193.44$

Cast VALVE
 limits EXAM
 to 50%.

25/14
 = 53.75% 50%.

R Seal III
25/14



= Ax Scan - No coverage

THICKNESS & CONTIDUP DATA TAKEN FROM PREVIOUS DATA.

EXAMINER: <u>Jerry D Brea</u>	REVIEWED BY: <u>Walter Weller</u>	ANL: <u>[Signature]</u>
LEVEL: <u>III</u>	LEVEL: <u>III</u>	DATE: <u>3/26/10</u>
DATE: <u>3/4/10</u>	DATE: <u>3/9/10</u>	PAGE <u>5</u> OF <u>6</u>

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R078

(2 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: 7078	
PROJECT: BFN UNIT: 3		CYCLE: 13		COMPONENT ID: RWCU-3-001-071	
EXAMINATION METHOD				SYSTEM: <i>RWCWS</i> ISI DWG. NO. 3-ISI-0328-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: 1	CATEGORY: B-J
PROCEDURE: N-UT-64		REV: 11	TC: NA	COFIG.: Valve	TO Pipe
EXAMINER: <i>TOMMY BROWN</i>		EXAMINER: <i>ALEX ZIPPERER</i>		EXAMINER:	EXAMINER:
LEVEL: <i>II</i>		LEVEL: <i>II</i>		LEVEL:	LEVEL:

The package contains the ultrasonic examination data for RWCU-3-001-071.

This exam meets the requirements of NU0313, cat. A, EXREQ 96E-02. and ASME Section XI, cat. B-J, item B9.11, EXREQ P03-03. ✓

The examination was performed using ASME Section XI, Appendix VII and Appendix VIII personnel, equipment and techniques as amended by the 10CFR50.55a Final Rule ✓

This exam is a ASME Section XI Pre-Service exam. w-4/10/08

The joint configuration is a cast S/S pipe to pipe full pen butt weld. ✓

The examination was performed using TVA Procedure N-UT-64 which implements PDI Procedure PDI-UT-2 for Austenitic pipe welds ✓

The weld was examined using 1.5 MHz., 45 and 60 degree shear waves and a 70 degree 2.25 MHz shear wave. ✓

No recordable indications, in w-4/10/08

Access for the exam was limited to a single side due to joint geometry. ✓

Root geometry was recorded at acceptable levels. w-4/10/08

The achieved examination volume was ~~69%~~ *50%* ✓

2/5/14

RESOLUTION BY: <i>Sony D. Brown</i>	REVIEWED BY: <i>Walter White</i>	ANI: <i>[Signature]</i>
LEVEL: <i>II</i> DATE: <i>4/9/08</i>	LEVEL: <i>III</i> DATE: <i>4/10/08</i>	DATE: <i>4/23/08</i>
		PG. <i>1</i> OF <i>7</i>


<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: <h3>R078</h3>
--------------	---------------------------------------	-----------------------------

PROJECT: BFN
UNIT: 3


WELD NO: RWCU-3-001-071
SYSTEM: RWCU

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	.609			
3	.594			
4	.450			
5	.572			



CROWN HEIGHT: Flush DIAMETER: 6.0
CROWN WIDTH: .85 WELD LENGTH: 20.8



REQUIRED ASME EXAM VOLUME

$$(.2 \times .143) \div 2 \times 1.9 = .326$$

$$.326 \times 20.8 = 6.78 \text{ in}^3$$

ACHIEVED ASME EXAM VOLUME

SCAN 3 CRV OBTAINED = 18%

$$(.45 \times .143) \times 20.8 = .66$$

$$.66 \times 20.8 = 1.248 \quad 1.248 / 6.78 = 18\%$$

SCAN 4 OBTAINED 100%

SCAN 5 + 6 OBSTRUCTED

$$(.5 \times .2) \times 20.8 \div 6.78 = 31\%$$

SCAN 5 + 6 CRV OBTAINED

$$100\% - 31\% = 69\%$$

FLOW →

CAST value limits exam to 50% ✓ R Seal III 2/5/14

EXAMINER: Tommy D. B...
LEVEL: II
DATE: 4/9/08

REVIEWED BY: Walter White
LEVEL: III DATE: 4/10/08

ANII: [Signature]
DATE: 4/23/08
PAGE 4 OF 7

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R098

(5 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: <i>R098</i>	
PROJECT: BFN UNIT: 3		CYCLE: 13		COMPONENT ID: RWCU-3-001-070	
EXAMINATION METHOD				SYSTEM: RWCU <input checked="" type="checkbox"/> ISI DWG. NO. 3-ISI-0332-C SHT 1 <input checked="" type="checkbox"/>	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: I	CATEGORY: B-J <input checked="" type="checkbox"/>
PROCEDURE: N-UT-64		REV: 11 <input checked="" type="checkbox"/>	TC: N/A	CONFIG.: Sweep-O-let	TO Valve
EXAMINER: Patrick Mahoney <i>Patrick Mahoney</i>		EXAMINER: Alex Zipperer <i>Alex Zipperer</i>		EXAMINER: N/A	EXAMINER: N/A
LEVEL: II		LEVEL: III TRN <i>4/18/08</i>		LEVEL: N/A	LEVEL: N/A

This report contains the manual ultrasonic data associated with the examination of
Weld RWCU-3-001-070 /

The component examined was a S/S Sweep-O-Let to Valve Weld, 6" Diameter, Schedule 80,
with single sided access.

A 1.5Mhz. 45° Shear Wave, 60° Shear Wave, 1/2 Vee Path were used during the exam.
A 60° RL was used for the examination.
Maintained a 5%-20% ID Roll.

This examination satisfies the requirements of ASME Section XI, Category B-J,
item number B9.11, EXREQ P03-03, and BWRVIP-75A, Cat A, EXREQ, B02-02.

This is an ASME Section XI Pressure Exam. see 4/19/08

This exam was performed with equipment, procedures, and personnel qualified
in accordance with ASME Section XI, Appendix VIII as amended by the final rule.

There were limitations on the exam. Refer to attached drawings for calculations.

Scan 3 coverage = 51.75%
Scan 4 coverage = 0
Scan 5 coverage = 35.15%
Scan 6 coverage = 35.15%

Total Code Coverage obtained = 30.5%

Ref WO# 07-714055-000

The indications are associated with joint geometry and are acceptable. see 4/19/08


RESOLUTION BY: <i>Patrick Mahoney</i>	Patrick Mahoney	REVIEWED BY: <i>Alan Welch</i>	Alan Welch	ANI: <i>Santhosh</i>	Santhosh
LEVEL: II	DATE: 4/18/08	LEVEL: III	DATE: 4/19/08	PG. 1	OF 13

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R098
------------	---	---------------------------

PROJECT: <u>BFN</u>	WELD NO: <u>RWCU-3-001-070</u>
UNIT: <u>3 CYCLE 13</u>	SYSTEM: <u>RWCU</u>


Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	NA			
2				
3				
4				
5				



CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>6.625"</u>
CROWN WIDTH: <u>1.0" 1.6</u>	WELD LENGTH: <u>21 1/4</u>

PLOT SHEET




EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	DATE: <u>4/19/08</u>	DATE: <u>4/24/08</u>
DATE: <u>4/18/08</u>	PAGE: <u>3</u> OF <u>13</u>	

TVA
Office of Nuclear Power


PROJECT: BFN SYSTEM: RWCU
Unit: 3 CYCLE 13 WELD NO.: RWCU-3-001-070

REPORT NO.:
R098

TOP VIEW



SIDE VIEW



BY: [Signature] LEVEL: II DATE: 4/18/08 PAGE 4 OF 13


<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: R098
--------------	---------------------------------------	---------------------------

PROJECT: BFN
 UNIT: 3 CYCLE 13

WELD NO: RWCU-3-001-070
 SYSTEM: RWCU

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°


Position	0°	90°	180°	270°
1				
2				
3				
4				
5				



CROWN HEIGHT: FLUSH DIAMETER: 6.625"
 CROWN WIDTH: 1.6" WELD LENGTH: 21 1/4"

REQUIRED EXAM VOLUME: 8.9³ in
 $a = .35 \times .2 = .07$ $b = .25 \times .36 = .09$ $c = (.11 \times .25) \div 2 = .01375$ / $a+b+c = .17375 \times 21.25 = 3.69$
 ACHIEVED VOLUME SCAN 3: 52.2% ①

$(.35 \times .2) + (.35 \times .2) + ((.11 \times .25) \div 2) = .07 + .07 + .01375 = .15375$
 $.15375 \times 21.25 = 3.27$
 $3.27 \div 3.69 = .886 \times 100 = 88.6\%$



ACHIEVED VOLUME CIRC SCANS 5 & 6: 31.6% ①
 $a = .35 \times .2 = .07$ $b = .25 \times .2 = .05$ $c = (.11 \times .25) \div 2 = .01375$ / $a+b+c = .13375 \times 21.25 = 2.84$
 $2.84 \div 8.9 = .319 \times 100 = 31.9\%$


EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/24/08</u>
DATE: <u>4/13/08</u>	DATE: <u>4/19/08</u>	PAGE <u>6</u> OF <u>13</u>

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: R098
--------------	---------------------------------------	---------------------------

PROJECT: <u>BFN</u>	WELD NO: <u>RWCU-3-001-070</u>
UNIT: <u>3 CYCLE 13</u>	SYSTEM: <u>RWCU</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°


Position	0°	90°	180°	270°
1	/	/	/	/
2	/	/	/	/
3	/	/	/	/
4	/	/	/	/
5	/	/	/	/



CROWN HEIGHT: FLUSH DIAMETER: 6.625"
 CROWN WIDTH: 1.6" WELD LENGTH: 21 1/4"

REQUIRED EXAM VOLUME: 8.53 in
 $a = .2 \times 1.15 = .23$ $b = .2 \times .85 = .17$ $.23 + .17 = .4 \text{ in} \times 21.25 = 8.5 \text{ in}$ 90°

ACHIEVED VOLUME AXIAL SCAN 3 = 51.3% ①
 $A = (.35 \times .27) + ((.15 \times .2) \div 2) = .085$ $B = (.45 \times .2) + ((.2 \times .5) \div 2) = .12$
 $(.085 + .12) \times 21.25 = 4.56 \div 8.5 = .53 \times 100 = 51.3\% ①$



ACHIEVED VOLUME CIRC SCANS 5 = 38.7% ①
 $a = .65 \times .2 = .13$ $b = (.25 \times .2) \div 2 = .025$ $.13 + .025 = .155 \times 21.25 = 3.29$
 $3.29 \div 8.5 = .387 \times 100 = 38.7\%$

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANI: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/12/08</u>
DATE: <u>4/13/08</u>	DATE: <u>4/19/08</u>	PAGE: <u>7</u> OF <u>13</u>

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R237

(2 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R237	
PROJECT: <i>BFN</i> UNIT: <i>1</i> CYCLE <i>07</i>			COMPONENT ID: <i>DRHR-1-2</i>		
EXAMINATION METHOD			SYSTEM: <i>RHR</i>		ISI DWG NO: <i>ISI-0362-C-08</i>
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	
PROCEDURE: <i>N-UT-82</i>		REV <i>3</i>	TC: <i>N/A</i>	<i>P TO VLV</i>	
EXAMINER:		EXAMINER:	EXAMINER:	EXAMINER: <i>11/17/08</i>	
<i>Patrick Mahoney</i>		<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	
LEVEL: <i>II</i>		LEVEL:	LEVEL:	LEVEL:	
<p>Total coverage calculated to be approximately * 50% <i>100%</i></p> <p><i>A Manual UT Exam was performed on DRHR-1-2 (A 4/8 PIPE TO 5/8 CAST Valve)</i></p> <p><i>This exam was performed to meet the requirements of ASME SECTION XI 2001 ED, 2003 ADDENDA, Cat R-A, item RI.16'D, and NU D313, item D.</i></p> <p><i>TVAN Procedure N-UT-82 Rev 3 which incorporates the current EPRI Diss. Metal Procedure PDI-UT-10 Rev C, was used for examination</i></p> <p><i>A 45° RL, 60° RL & 45° Shear were used for Axial Scans</i></p> <p><i>A 45° Shear & 40° RL ^{PR 11-14-07} were used for circ. scans.</i></p> <p><i>No Scans from the Valve side due to configuration</i></p> <p>* CODE REQUIRED COVERAGE = 48.2% <i>50%</i></p> <p>* PROCEDURE REQUIRED COVERAGE 82.2% <i>50%</i></p> <p>* Refer to coverage sheet for calculations</p>					
RESOLUTION BY: <i>Patrick Mahoney</i>		REVIEWED BY: <i>Alan Wilch</i>		ANIL:	
LEVEL: <i>II</i> DATE: <i>11-14-08</i>		LEVEL: <i>III</i> DATE: <i>11/17/08</i>		DATE: <i>11/21/08</i>	
				Page: <i>1</i> OF <i>9</i>	

TVA
Office of Nuclear Power


PROJECT: BFN SYSTEM: RHR
Unit: 1 CYCLE 7 WELD NO.: DRHR 1-2

REPORT NO.:
R237

(a) .57 (43.3)
(b) .40 (30)
.97 (73.7)

REQ.
CODE: $1.81 (3.3 \times .55) \times 76 = 137.56$
PROC: $5.445 ((3.3 \times (1.55 + 1.75/2))) \times 76 = 413.82$

ACHIEVED.
CODE: $137.56 - 30 = 107.56 / 137.56 = .782 = 78.2\%$ 50% ~~80~~
PROC: $413.82 - 73.7 = 340.12 / 413.82 = .822 = 82.2\%$ 50% 2/5/14



CAST VALUE limits exam to MAXIMUM 50%
Coverage RSL L.V. III 2/5/14

BY: P. Mahoney P. Mahoney LEVEL: II DATE: 11/14/08 PAGE 9 OF 9

000003

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R253

(2 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R253</i>	
PROJECT: BFN UNIT: 1		CYCLE: 07		COMPONENT ID: RCRD-1-50	
EXAMINATION METHOD				SYSTEM: CRD ISI DWG. NO. 1-CHM-1098-C-2	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: N/A	CATEGORY: NU0313
PROCEDURE: N-UT-82		REV: 3	TC: N/A	CONFIG.: Valve	TO Elbow
EXAMINER: <i>Tommy Brown</i>		EXAMINER: N/A		EXAMINER: N/A	
<i>Joy D Brown</i>					
LEVEL: III		LEVEL:		LEVEL:	

A Manual Ultrasonic Examination was performed on weld RCRD-1-50. A carbon steel elbow to a stainless steel valve.

The exam was performed to meet the requirements of NU0313, category C EXREQ B02-02

This exam was performed using TVA Nuclear Procedure N-UT-82 Rev. 3, which incorporates PDI-UT 10 Rev C Addenda No. 1, the EPRI Procedure for doing UT on Dissimilar Metal Welds.

A 60° Shear, 60° RL and 70°RL was used for the axial scans. A 42° RL and 45° Shear was used for the circ scans.

No scan on the Down Stream side of the weld due to Elbow to Valve configuration.

80.6% Procedure coverage was obtained.

RESOLUTION BY: <i>Tommy Brown</i>		REVIEWED BY:		ANII: <i>N/A</i>	
<i>Joy D Brown</i>		<i>Mark Walker</i>		DATE: <i>11/20/08</i>	
LEVEL: III DATE: 11/7/08		LEVEL: <i>III</i> DATE: <i>11/20/08</i>		PG. <i>1</i> OF <i>11</i>	


000406

TVA WALL THICKNESS PROFILE SHEET REPORT NO: **R253**


PROJECT: REN WELD NO: FCRD-1-50
 UNIT: 1 SYSTEM: CRD

Record Thickness Measurement As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	.59			
2	.31			
3	.32			
4	N/A			
5	N/A			



CROWN HEIGHT: Flush DIAMETER: 4"
 CROWN WIDTH: .45" WELD LENGTH: 14.5



$$\begin{aligned}
 .31 \times .9 &= .279 \times 14.5 = 4.046 \\
 4.046 + .03 \times 14.5 &= 4.481 \\
 4.481 - .06 \times 14.5 &= 3.611 \\
 3.611 \div 4.481 &= .806 \times 100 = 80.6\%
 \end{aligned}$$

EXAMINED: [Signature] REVIEWED BY: [Signature] ANI: N/A

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R254

(2 pages)

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R254</i>	
PROJECT: BFN UNIT: 1		CYCLE: 07		COMPONENT ID: RCRD-1-52	
EXAMINATION METHOD				SYSTEM: CRD ISI DWG. NO. 1-CHM-1098-C-2	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: N/A	CATEGORY: NU0313 <i>NU0313</i>
PROCEDURE: N-UT-82		REV: 3	TC: N/A	CONFIG.:	Pipe TO Valve
EXAMINER: <i>Tommy Brown</i>		EXAMINER: N/A		EXAMINER: N/A	EXAMINER: N/A
LEVEL: III		LEVEL:		LEVEL:	LEVEL:

A Manual Ultrasonic Examination was performed on weld RCRD-1-52. A carbon steel pipe to a stainless steel valve.

The exam was performed to meet the requirements of NU0313, category C EXREQ B02-02

This exam was performed using TVA Nuclear Procedure N-UT-82 Rev. 3, which incorporates PDI-UT 10 Rev C Addenda No. 1, the EPRI Procedure for doing UT on Dissimilar Metal Welds.

A 60° RL, 70°RL, and a 60° Shear was used for the axial scans. A 42°RL and 45° Shear was used for the circ scans

No scan on the Down Stream side of the weld due to Pipe to Valve configuration.

88% Procedure coverage was obtained.

...


RESOLUTION BY: <i>Tommy Brown</i> <i>Tommy Brown</i>	REVIEWED BY: <i>Walter Willet</i>	ANII: <i>N/A</i>
LEVEL: III DATE: 10/31/08	LEVEL: <i>III</i> DATE: <i>11/20/08</i>	DATE: <i>N/A</i>
		PG. <i>1</i> OF <i>11</i>

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: R254
--------------	---------------------------------------	---------------------------


PROJECT: <u>BFIV</u>	WELD NO: <u>RCRD-1-52</u>
UNIT: <u>1</u>	SYSTEM: <u>CRD</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	39		N	
3	41			R
4	45			
5	53			



CROWN HEIGHT: <u>Flush</u>	DIAMETER: <u>4"</u>
CROWN WIDTH: <u>0.45</u>	WELD LENGTH: <u>14.5</u>



Exam volume = $1.0 \times (.55 + .4) \div 2 = .475 \times 14.5 = 6.89 \text{ in.}^3$

Not Examined = $((.25 \times .45) \div 2) \times 14.5 = .816 \text{ in.}^3$

Achieved $(6.89 - .816) \div 6.89 = .88 \times 100 = 88\%$

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>N/A</u>
LEVEL: <u>III</u>	DATE: <u>11/20/88</u>	DATE: _____
DATE: <u>10/21/08</u>		PAGE <u>12</u> OF <u>11</u>

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

R257

(2 pages)

000439 ✓

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R257</i>	
PROJECT: BFN UNIT: 1		CYCLE: 07		COMPONENT ID: RCRD-1-49	
EXAMINATION METHOD				SYSTEM: CRD ISI DWG. NO. 1-CHM-1098-C-2	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: N/A CATEGORY: NU0313	
PROCEDURE: N-UT-82		REV: 3	TC: N/A	CONFIG.:	Valve TO Elbow
EXAMINER: Tommy Brown <i>Joy D Brown</i>		EXAMINER: N/A		EXAMINER: N/A	
LEVEL: III		LEVEL:		LEVEL:	

A Manual Ultrasonic Examination was performed on weld RCRD-1-49. A stainless steel valve to a carbon steel elbow.

The exam was performed to meet the requirements of NU0313, category C EXREQ B02-02

This exam was performed using TVA Nuclear Procedure N-UT-82 Rev. 3, which incorporates PDI-UT 10 Rev C Addenda No. 1, the EPRI Procedure for doing UT on Dissimilar Metal Welds.

A 45° RL, 60° RL, and 70°RL was used for the axial scans. A 42° RL, 40° RL, and 45° Shear was used for the circ scans.

No scan on the Up Stream side of the weld from 3.5" to 12.5" due to Valve to Elbow configuration. Scans from 0" to 3.5" and from 12.5" were in weld repair area.

80.6% Procedure coverage was obtained.

RESOLUTION BY: Tommy Brown <i>Joy D Brown</i>		REVIEWED BY: <i>Mark Welch</i>	ANII: <i>N/A</i>
LEVEL: III DATE: 11/7/08		LEVEL: <i>III</i> DATE: <i>11/20/08</i>	DATE:
		PG. <i>1</i> OF <i>18</i>	


000455

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: <i>R257</i>
--------------	---------------------------------------	---------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>PCRD-1-49</u>
UNIT: <u>1</u>	SYSTEM: <u>CRD</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	.57			
3	.58			
4	.34			
5	N/A			



CROWN HEIGHT: Flush DIAMETER: 4"
 CROWN WIDTH: 2" (270° to 90°) 4" (90° to 270°) WELD LENGTH: 15.0"



EXAMINER: <u>Jerry D Brown</u>	REVIEWED BY: <u>Walter White</u>	ANII: <u>N/A</u>
LEVEL: <u>III</u>	LEVEL: <u>III</u>	DATE: <u>11/20/08</u>
DATE: <u>10/31/08</u>		PAGE <u>17</u> OF <u>18</u>

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-10-024

(2 pages)



Ultrasonic Examination

000201 ✓

Site/Unit: BFN / 1 Procedure: N-UT-84 Outage No.: U1R08
 Summary No.: 03122-ISI-BFN1 Procedure Rev.: 0 Report No.: UT-10-024
 Workscope: ISI Work Order No.: 1-SI-4.6.G Page: 1 of 7

Code: Section XI 2001 Ed/2003 Add Cat./Item: B-J/B9.11 Location: Drywell
 Drawing No.: 1-CHM-1081-C-1 Description: EL - VLV
 System ID: 068 - REACTOR WATER RECIRCULATING SYSTEM
 Component ID: RWR-1-001-003 Size/Length: N/A Thickness/Diameter: 1.088" / 28"
 Limitations: Single Side Austenitic Exam

Comments:

See attached supplemental sheets for examination data consisting of:

- Phased Array Calibration Data Sheet (Shear)
- Phased Array Calibration Data Sheet (Longitudinal)
- Piping Examination Data Sheet
- Coverage Plot
- Indication Plot
- Wall Thickness Profile Sheet

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: No

Reviewed Previous Data: Yes

Examiner	Level	II-PDI	Signature	Date	Reviewer	Signature	Date
Nissen, Jason P.				10/28/2010	Matt Welch, LIII		11/1/10
Examiner	Level	N/A	Signature	Date	Site Review	Signature	Date
N/A					N/A		
Other	Level	TRN	Signature	Date	ANII Review	Signature	Date
Clairday, Joey, E.				10/28/2010	Sam Flood		11/8/10

Vendor Examination For UT



Supplemental Report

Report No.: UT-10-024

Page: 5 of 7

Summary No.: 03122-ISI-BFN1

Examiner: Nissen, Jason P. *Jason Nissen*

Level: II-PDI

Reviewer: Matt Welch, LIII *Matt Welch*

Date: 11/1/10

Examiner: N/A

Level: N/A

Site Review: N/A

Date: _____

Other: Clairday, Joey, E. *Joey Clairday*


Level: TRN

ANII Review: Sam Flood *Sam Flood*

Date: 11/8/10

Comments: RWR-1-001-003 Coverage Plot

Sketch or Photo: O:\Ideal_Server\Ideal_BFM\Documentation\U1R8 Scanned Data\RWR-1-001-003 Coverage Plot.jpg



000205

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-10-026

(1 page)



Supplemental Report

Report No.: UT-10-026

Page: 5 of 7

Summary No.: 03155-ISI-BFN1

Examiner: Nissen, Jason P. *Jason P. Nissen*

Level: II-PDI

Reviewer: Matt Welch, LIII *Matt Welch*

Date: 11/1/10

Examiner: N/A

Level: N/A

Site Review: N/A

Date:

Other: PARKER, FREDDIE, J. *Freddie Parker*


Level: TRN

ANII Review: Sam Flood *Sam Flood*
B. Somers *B. Somers*
11/8/10

Date: 11/8/10

Comments: RWR-1-002-012 Coverage Plot

Sketch or Photo: O:\Ideal_Server\Ideal_BFN\Documentation\U1R8 Scanned Data\RWR-1-002-012 Coverage Plot.jpg



000213

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-10-028

(1 page)



Supplemental Report

Report No.: UT-10-028

Page: 5 of 6

Summary No.: 03252-ISI-BFN1

Examiner: Nissen, Jason P. *J. Nissen*

Level: II-PDI

Reviewer: Matt Welch, LIII *Matt Welch*

Date: 11/11/10

Examiner: N/A

Level: N/A

Site Review: N/A

Date: _____

Other: Clairday, Joey, E. *J. Clairday*


Level: TRN

ANII Review: Gam Flood *N/A* B. Ewing *B. Ewing*
11/18/10

Date: 11/11/10

Comments: RWR-1-001-S023A Coverage Plot

Sketch or Photo: O:\Ideaal_Server\Ideaal_BFN\Documentation\UI1R8 Scanned Data\RWR-1-001-S023A Coverage Plot.jpg



000221

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-10-030

(1 page)



Supplemental Report

Report No.: UT-10-030

Page: 3 of 4

Summary No.: 03110-ISI-BFN1

Examiner: Newgard, Jerry W. *Jerry W. Newgard*

Level: III(N)

Reviewer: Matt Welch, LIII *Matt Welch*

Date: 11/3/10

Examiner: N/A

Level: N/A

Site Review: N/A

Date: _____

Other: Walker, Scott *Scott Walker*


Level: TRN

ANII Review: Sam Flood *Sam Flood*
11/8/10

Date: 11/8/10

Comments: None

Sketch or Photo: O:\Ideaal_Server\Ideaal_BFMDocumentation\U1R8 Scanned Data\RWCU-1-001-019 Coverage Plot.jpg



**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-12-027

(1 page)



Supplemental Report

Report No.: UT-12-027

Page: 3 of 4


Summary No.: 05109-ISI-BFN3

Sketch or Photo: O:\Ideal_Server\Ideal_BFN\Documentation\U3R18 Scanned Data\GR-3-63 TC.jpg

THICKNESS AND CONTOUR

Position	0	90	180	270
1	N/A			
2"	1.26			
3	1.31			
4"	1.22			
5	1.20			

* Weld edge



Examiner:	Reviewer:	ANII:
Print name: <u>ED FISH</u>	Print name:	Print name:
Date:	Date:	Date:
COMPONENT ID: <u>GR-3-63</u>		
CROWN WIDTH: <u>1.25</u>	WELD LENGTH: <u>89.0"</u>	
CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>28"</u>	

Required exam volume:
 $.45 \times 1.77 \times 89 = 70.9 \text{ IN}^3$

Obtained exam volume:
 $70.9 - (.45 \times .89 \times 89) = 35.6 \text{ IN}^3 / 70.9 = 50.2 \times 100 = 50.2\%$

CAST S/S VALVE

45° bevel 45°

1.77 .45

= NO COVERAGE

Contour from previous data USC12.

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-12-031

(1 page)



Supplemental Report

Report No.: UT-12-031

Page: 5 of 7


Summary No.: 05100-ISI-BFN3

Sketch or Photo: O:\Ideas_Server\Ideas_BFN\Documentation\U3R18 Scanned Data\DRHR-3-12.jpg

THICKNESS AND CONTOUR

Position	0	90	180	270
1	1.4			
2	1.4			
3	1.4			
4	1.4			
5	1.4			

* Weld edge



Examiner: <i>ED FISH</i> 4/14/12	Reviewer: <i>MATT WELCH</i> 4/17/12	ANII: <i>B. EAMIGH</i> 4/18/12
Print name: ED FISH	Date:	Print name: MATT WELCH
Print name: BRUCE EAMIGH	Date:	Date:
COMPONENT ID: DRHR-3-12		
CROWN WIDTH: 1.6"	WELD LENGTH: 75.4 75.4"	
CROWN HEIGHT: FLUSH	DIAMETER: 2.66" OD	

Required diam volume:
 $(2.05 \times .5) \times 75.4 = 77.285 \text{ in}^3$
 Obtained diam volume:
 axial - $17.5 / 77.285 = .226$
 circ - $28.9 / 77.285 = .374$
 $((.374 + .226) \div 2) \times 100 = 30\%$

= OBSTRUCTED VOLUME = CAST SS

DET axial seam access

CAST SS

$A = .25 \times .5 = .125$ (45°)
 $B = .2 \times .5 = .1$ (60°)
 $C = (.15 \times .1) \div 2 = .0075$ (70°)
 $(A+B+C) \times 75.4 = 17.5 \text{ in}^3$ ACHIEVED AXIAL

$(77.285 / 2) - ((5 \times .26) \times 75.4) = 28.9 \text{ in}^3$ ACHIEVED CIRC

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-12-039

(1 page)



Supplemental Report

Report No.: UT-12-039

Page: 5 of 17


Summary No.: 01518-ISI-BFN3

Sketch or Photo: O:\Ideal_Server\Ideal_BFN\Documentation\U3R18 Scanned Data\DRHR-3-03 TC.jpg

THICKNESS AND CONTOUR

Position	0	90	180	270
1	N/A			
2*	1.4			
3	1.35			
4*	1.1			
5	N/A			

* Weld edge



Examiner: <u>ED FISH</u>	Date: <u>4-18-12</u>	Reviewer: <u>Matt Welch</u>	Date: <u>3/24/12</u>	ANII: <u>N/A</u>
Print name: <u>ED FISH</u>	Date: <u>4-18-12</u>	Print name: <u>MATT WELCH</u>	Date: <u>3/24/12</u>	Print name: <u>N/A</u>
COMPONENT ID: <u>DRHR-3-03</u>		WELD LENGTH: <u>75.4</u>		
CROWN WIDTH: <u>1.55</u>		DIAMETER: <u>2.76</u>		
CROWN HEIGHT: <u>FLUSH</u>				

Required Exam Volume:
 $(2.0 \times 0.5) \times 75.4 = 75.4 \text{ IN}^3$

Obtained Exam Volume:
 $(37.5 + 22.5) \div 2 = 30\%$

CAST SS

CAST SS

$A = .25 \times .5 = .125 (49)$
 $B = .2 \times .5 = .1 (40)$
 $70^\circ \text{ DID NOT IMPINGE ON EXAM VOLUME}$
 $(A+B) \times 75.4 = 16.92 \text{ IN}^3 \text{ ACHIEVED AXIAL}$
 $16.92 / 75.4 = .225 = 22.5\% \text{ OBTAINED BY}$

$(75.4 \div 2) - ((.5 \times .25) \times 75.4) = 28.275$
 $28.275 \div 75.4 = .375 = 37.5\% \text{ OBTAINED CIRC}$

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts


UT-12-054

(1 page)

THICKN. AND CONTOUR


Position	0	90	180	270
1	1.35	1.59	1.54	1.70
2*	1.30	1.37	1.35	1.40
3	1.33	1.38	1.32	1.29
4*	1.28	1.41	1.43	1.33
5	1.69	1.72	1.74	1.74

* Weld edge



12-054
Pg 3/4
UT-12-054

Examiner: <i>[Signature]</i>	Reviewer: <i>[Signature]</i> 10/31/12	ANII: <i>[Signature]</i>
Print name: Kenneth Fish Date: 9/25	Print name: MATT WELCH Date:	Print name: Samuel Flood 11/9/12 Date:
COMPONENT ID: DRHR-1-12		
CROWN WIDTH: 1.20"	WELD LENGTH: 75.625"	
CROWN HEIGHT: 0.10"	DIAMETER: 24.0"	



**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-12-055


(1 page)

THICKN. AND CONTOUR

LT 10SS
 PG 3/4
 UT-12-055

Position	0	90	180	270
1	1.49	1.54	1.42	1.38
2*	1.37	1.50	1.39	1.33
3	1.30	1.41	1.32	1.37
4*	1.42	1.47	1.44	1.44
5	1.66	1.64	1.58	1.66

* Weld edge



Examiner: <i>Kenneth Fish</i>	Reviewer: <i>Matt Welch</i> 10/31/12	ANII: <i>Samuel Flood</i>
Print name: <i>Kenneth Fish</i> Date: 10/21	Print name: <i>MATT WELCH</i> Date:	Print name: <i>Samuel Flood</i> 11/9/12 Date:
COMPONENT ID: <i>DRHR-1-3</i>		
CROWN WIDTH: <i>1.2"</i>	WELD LENGTH: <i>76.5</i>	
CROWN HEIGHT: <i>0.1"</i>	DIAMETER: <i>24.0"</i>	

SCAN 3 - 0%
 SCAN 4 - 50%
 SCAN 5 - 0%
 SCAN 6 - 0%

VALVE HEAD

REV = [(1.5" x 2.4") (76.5")] = 91.8
 OEV = [(1.5" x 1.2") (76.5")] = 45.9 (SCAN 4)
 12.5% OEV ACHIEVED

000045

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts


UT-12-058

(1 page)

THICKNESS AND CONTOUR

Position	0	90	180	270
1	*.57	*.52	*.57	*.55
2*	.54	.52	.51	.50
3	.60	.55	.53	.58
4*	.61	.51	*	.55
5	*	*	*	*

* Weld edge



UT-12-058
pg 3/5
4 10/3/12

Examiner: <i>E. Fish</i>	Reviewer: <i>Matt Welch</i> 10/3/12	ANII: <i>[Signature]</i>
Print name: EDWARD FISH Date: 10/3/12	Print name: MATT WELCH Date:	Print name: Samuel Floyd 11/10/12 Date:
COMPONENT ID: RWCU-1-005-006		
CROWN WIDTH: 0.6	WELD LENGTH: 15.0	
CROWN HEIGHT: FLUSH/AS WELDED	DIAMETER: 4.0 NOM	

VAIVE (SHV-06A-0580)

REV = [(0.2)(1.1)(15.0)] = 3.3³ in

OBST Volume = 3.3 - 1.52 = 1.78³ in

• SKEWED 25° to achieve Root/HAZ

0°

45°

CW/CCW

0.2

0.5

1.1

VAIVE (CKV-06A-0579)

S3 = 0%

S4 = 0%

S5 = 46%

S6 = 46%

Total Coverage = 23%

THICKNESS AND CONTOUR TAKEN FROM PREVIOUS DATA, REPORT # R-1066/URFO96R

** THICKNESS READINGS TAKEN APPROXIMATELY .5 INCHES FROM TOE WELD. 10/3/12

* NO THICKNESS READING TAKEN DUE TO COMPONENT CONFIGURATION.

000056

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-12-060


(1 page)

COVERAGE PLOT

Component ID: RWR-1-002-053

UT-12-060 P23/3

Examiner: <i>[Signature]</i>	Reviewer: <i>[Signature]</i>	ANII: N/A
Print name: Richard C. May	Print name: MATT WELCH	Print name: N/A
Date: 10-31-12	Date: 11/3/12	Date: N/A



$$REV = L \times H \times W = 88.75" \times .393" \times 1.7" = 59.29^3 \text{ in}$$
 OEV = 50% Single Sided Exam

* Not to scale - Obtained from previous data - UIRFlb - Report R-832

000063

**Enclosure
Attachment B**


**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-004

(1 page)

Examiner: <i>D.R. [Signature]</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: DAVID KLEINTAN	Print name: MATT WELCH	Print name:
Date: 22 MAR 2013	Date: 3/26/13	Date:



▨ OBSTRUCTED VOLUME
 REQUIRED EXAM VOLUME:
 $2.0625 \times .5 \times 90 = 92.8125 \text{ in}^3$
 OBSTRUCTED / LIMITED VOLUME:
 $1.03125 \times .5 \times 90 = 46.40625 \text{ in}^3$
 OBTAINED EXAM VOLUME:
 $92.8125 - 46.40625 = 46.40625$
 $46.40625 / 92.8125 \times 100 = 50\%$

00000

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-013

(6 pages)

22/1/13

UT-13-013

PROJECT:	BFN	UNIT:	2	CYCLE:	17
SYSTEM:	Rector Water Cleanup System			Component:	RCRD-2-49
Examiner:				Reviewer:	
Print Name:	David Kleinman			Print Name:	Matt Welch
Date:	29-Mar-13			Date:	4/18/13

Items #

1	RL Axial Full Required Exam Volume $15.125 \times 1.018 \times ((0.669 + 0.491) / 2) =$	8.9304
2	RL Axial Lower One Third Required Exam Volume $15.125 \times 1.018 \times ((0.223 + 0.163) / 2) =$	2.9717
3	Shear Axial Full Required Exam Volume $15.125 \times 1.018 \times ((0.669 + 0.491) / 2) =$	8.9304
4	Shear Axial Lower One Third Required Exam Volume $15.125 \times 1.018 \times ((0.223 + 0.163) / 2) =$	2.9717
5	RL Full Clockwise and CounterClockwise Scanning Required exam Volume $15.125 \times 1.018 \times ((0.669 + 0.491) / 2) =$	8.9304
6	RL Lower One Third Clockwise and CounterClockwise Scanning Required exam Volume $15.125 \times 1.018 \times ((0.223 + 0.163) / 2) =$	2.9717
7	Shear Full Clockwise and CounterClockwise Scanning Required exam Volume $15.125 \times 1.018 \times ((0.669 + 0.491) / 2) =$	8.9304
8	Shear Lower One Third Clockwise and CounterClockwise Scanning Required exam Volume $15.125 \times 1.018 \times ((0.223 + 0.163) / 2) =$	2.9717
9	RL Axial Full Volume Obstructed Exam from the Elbow side $(1.081 / 2) \times 5.135 \times 0.491 =$	1.3628
10	RL Axial Full Volume Obstructed Exam from the Valve side $(1.081 / 2) \times (2.7948 \times 3) \times 0.669 =$	3.0318
11	RL Axial Lower One Third Volume Obstructed Exam from the Elbow side $(1.081 / 2) \times 5.135 \times 0.163 =$	0.4524
12	RL Axial Lower One Third Volume Obstructed Exam from the Valve side $(1.081 / 2) \times (2.7948 \times 3) \times 0.223 =$	1.0106
13	Shear Axial Full Volume Obstructed Exam plus the area that is not qualified by this procedure from the Elbow side $15.125 \times ((0.492 \times 0.607) / 2) / 2 =$	2.2585
14	Shear Axial Full Volume Obstructed Exam plus the area that is not qualified by this procedure from the Valve side $(15.125 \times ((0.492 \times 0.607) / 2) / 2) + ((1.081 / 2) \times (1.9781 \times 3) \times 0.669) =$	2.1458
15	Shear Axial Lower One Third Volume Obstructed Exam plus the area of exam that is not qualified by this procedure from the Elbow side $15.125 \times ((0.206 \times 0.171) / 2) / 2 =$	0.1332
16	Shear Axial Lower One Third Volume Obstructed Exam plus the area of exam that is not qualified by this procedure from the Valve side $(15.125 \times ((0.206 \times 0.171) / 2) / 2) + ((1.081 / 2) \times (1.9781 \times 3) \times 0.223) =$	0.8485
17	RL Full Clockwise and CounterClockwise Scanning Obstructed exam Volume $15.125 \times ((.669 \times .255) + (.491 \times .251)) =$	4.4443
18	RL Lower One Third Volume Clockwise and CounterClockwise Scanning Obstructed exam Volume $15.125 \times ((.223 \times .255) + (.163 \times .251)) =$	1.4789
19	Shear Full Clockwise and CounterClockwise Scanning Obstructed exam Volume plus the area of exam that is not qualified by this procedure $15.125 \times ((0.492 \times 0.607) / 2) =$	2.2585

22/1/88

01-13-013

20	Shear Lower One Third Clockwise and CounterClockwise Scanning Obstructed exam Volume plus the area of exam that is not qualified by this procedure $15.125 * ((.171 * .206) / 2) =$	0.2664
21	RL Axial Full Obtained Exam Volume from Elbow side $((\text{Item } 1) / 2) - \text{Item } 9 =$	3.1024
22	RL Axial Full Obtained Exam Volume from Valve side $((\text{Item } 1) / 2) - \text{Item } 10 =$	1.4334
23	RL Axial Lower One Third Obtained Exam Volume from the Elbow side $((\text{Item } 2) / 2) - \text{Item } 11 =$	1.0334
24	RL Axial Lower One Third Obtained Exam Volume from the Valve side $((\text{Item } 2) / 2) - \text{Item } 12 =$	0.4753
25	Shear Axial Full Obtained Exam Volume from Elbow side $((\text{Item } 3) / 2) - \text{Item } 13 =$	2.2067
26	Shear Axial Full Obtained Exam Volume from Valve side $((\text{Item } 3) / 2) - \text{Item } 14 =$	2.3194
27	Shear Axial Lower One Third Obtained Exam Volume from the Elbow side $((\text{Item } 4) / 2) - \text{Item } 15 =$	1.3526
28	Shear Axial Lower One Third Obtained Exam Volume from the Valve side $((\text{Item } 4) / 2) - \text{Item } 16 =$	0.6374
29	RL Full Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 5 - Item 17 =	4.4861
30	RL Lower One Third Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 6 - Item 18 =	1.4928
31	Shear Full Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 7 - Item 19 =	6.6719
32	Shear Lower One Third Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 8 - Item 20 =	2.7053
33	RL Axial Full Exam Volume Percentage from Elbow side $(\text{Item } 21 / ((\text{Item } 1) / 2)) * 100 = \%$	69.48%
34	RL Axial Full Exam Volume Percentage from Valve side $(\text{Item } 22 / ((\text{Item } 1) / 2)) * 100 = \%$	32.10%
35	RL Axial Lower One Third Exam Volume Percentage from Elbow side $(\text{Item } 23 / ((\text{Item } 2) / 2)) * 100 = \%$	69.55%
36	RL Axial Lower One Third Exam Volume Percentage from Valve side $(\text{Item } 24 / ((\text{Item } 2) / 2)) * 100 = \%$	31.99%
37	Shear Axial Full Exam Volume Percentage from Elbow side $(\text{Item } 25 / ((\text{Item } 3) / 2)) * 100 = \%$	49.42%
38	Shear Axial Full Exam Volume Percentage from Valve side $(\text{Item } 26 / ((\text{Item } 3) / 2)) * 100 = \%$	51.94%
39	Shear Axial Lower One Third Exam Volume Percentage from Elbow side $(\text{Item } 27 / ((\text{Item } 4) / 2)) * 100 = \%$	91.04%
40	Shear Axial Lower One Third Exam Volume Percentage from Valve side $(\text{Item } 28 / ((\text{Item } 4) / 2)) * 100 = \%$	42.90%
41	RL Clockwise and CounterClockwise Full Exam Volume Percentage $(\text{Item } 29 / \text{Item } 5) * 100 = \%$	50.23%
42	RL Clockwise and CounterClockwise Lower One Third Exam Volume Percentage $(\text{Item } 30 / \text{Item } 6) * 100 = \%$	50.23%
43	Shear Clockwise and CounterClockwise Full Exam Volume Percentage $(\text{Item } 31 / \text{Item } 7) * 100 = \%$	74.71%
44	Shear Clockwise and CounterClockwise Lower One Third Exam Volume Percentage $(\text{Item } 32 / \text{Item } 8) * 100 = \%$	91.04%

11/13/22

11.13



45	Full Exam Volume Percentage combining Shear and RL in the Axial, Clockwise, and CounterClockwise Directions (Item 33 + Item 34 + Item 37 + Item 38 + Item 41 + Item 43)/6 =% 54.65%
46	Lower One Third Exam Volume Percentage combining Shear and RL in the Axial, Clockwise, and CounterClockwise Directions (Item 35 + Item 36 + Item 39 + Item 40 + Item 42 + Item 44)/6 =% 62.79%

COVERAGE PLOT

Component ID: RCRD-2-49

LT-13-013

Examiner: <i>S. R. [Signature]</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 29 MAR 2013	Date: <i>4/18/13</i>	Date:




COVERAGE PLOT

Component ID: RCRD-2-49

UT-13-013

Examiner: <i>J. R. [Signature]</i>	Reviewer: <i>[Signature]</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 29 MAR 2013	Date: <i>4/18/13</i>	Date:



000119


PS/22

COVERAGE PLOT

Component ID: RCRD-2-49

UT-13-013

Examiner: <i>D.R. B...</i>	Reviewer: <i>Matt Welch</i>	ANII: N/A
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 29 MAR 2013	Date: 4/18/13	Date:



000120

4/16/22

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts


UT-13-024

(2 pages)

Examiner: <i>J.R. [Signature]</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: <i>DAVID KLEINLIAN</i>	Print name: <i>MATT WELCH</i>	Print name:
Date: <i>29 APR 2013</i>	Date: <i>4/4/13</i>	Date:

VALVE

PIPE



▨ OBSTRUCTED VOLUME AXIAL CUT

REQUIRED EXAM VOLUME:

$$0.27 \times 1.15 \times 14.875 = 4.6186875 \text{ m}^3$$

OBSTRUCTED LIMITED VOLUME

$$(0.27 \times 0.55) \times 14.875 = 1.10446875 \text{ m}^3$$

OBTAINED EXAM VOLUME:


$$4.6186875 - 1.10446875 = 3.51421875$$

$$3.51421875 \div 4.6186875 \times 100 = 76.09\%$$

$$\text{COMBINED COVERAGE} = 76.09 + 65.15 = 141.24\% \div 2 = 70.62\%$$

pg 10/13

Examiner: <i>D. E. Kleinman</i>	Reviewer: <i>Matt Welch</i>	ANII: N/A
Print name: DAVID KLEINMAN	Print name: MATT WELCH	Print name:
Date: 29 MAR 2013	Date: 4/4/13	Date:



**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-044

(2 pages)



Ultrasonic Examination

000351

Site/Unit: BFN / 2 Procedure: N-UT-84 Outage No.: U2RF17
 Summary No.: 05507-ISI-BFN2 Procedure Rev.: 1 Report No.: UT-13-044
 Workscope: ISI Work Order No.: 2-SI-4.6.G Page: 1 of 29 ^{9/8/13}

Code: ASME Section XI 2004 Edition Cat./Item: R-A/R1.16D Location: Reactor Building
 Drawing No.: 2-ISI-0221-C-01 Description: VLV - FH
 System ID: 074 - Residual Heat Removal System
 Component ID: DRHR-2-03 Size/Length: N/A Thickness/Diameter: 1.219 / 24"
 Limitations: Single Sided Exam

Comments:

This examination was performed using TVA ISO procedure N-UT-84, revision 1, titled "Procedure for the Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This procedure implements the processes and requirements of EPRI Report 1016650 which contains the procedure EPRI-PIPE-MPA-1, revision 0, titled "Procedure for Manual Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This examination was performed on a 24" diameter SS weld consisting of a Flued Head penetration to a cast stainless steel valve. The cast material limited the exam to single side access

The exam was performed to satisfy the requirements of Risk informed Category R-A, Item R1.16D and Category D, item NU0313.

51.4% coverage of the examination volume was achieved.

50%.

RT
2/5/14


Results: Accept Reject Info
Percent Of Coverage Obtained > 90%: 51.4

reference PER# 443133 ^{4/10/13} *July*
Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Gatica, James A.	II	<i>[Signature]</i>	3/31/2013	Matt Welch, LIII	<i>[Signature]</i>	4/8/13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			Samuel Flood	<i>[Signature]</i>	4/17/13

Examiner: <i>J. H. O.</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>Samuel Flum</i>
Print name: JAMES CATICA	Print name: MATT WELCH	Print name: Samuel Flum
Date: 3/31/13	Date: 4/8/13	Date: 4/17/13

DRHR-2-03



VALVE
 ▨ OBSTRUCTED VOLUME
 Required Exam Volume:
 $1.75 \times .45 \times 75 = 59.0625$
 LIMITED VOLUME:
 $.85 \times .45 \times 75 = 28.6875$

OBTAINED EXAM VOLUME
 $59.0625 - 28.6875 = 30.375$
 $30.375 / 59.0625 = .514 = 51.4\% \text{ } 50\% \text{ } 2/5/14$

Cast valve limits coverage to 50%. RA Seab III 2/5/14 pg 8/9

000361

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-072

(2 pages)



Ultrasonic Examination

Site/Unit: BFN / 2 Procedure: N-UT-84 84 ^{4/14/13} Outage No.: U2RF17
 Summary No.: 05499-ISI-BFN2 Procedure Rev.: 1.0 Report No.: UT-13-072
 Workscope: ISI Work Order No.: 2-SI-4.6.G Page: 1 of 10

Code: Section XI 2004 Edition Cat./Item: R-A/R1.16C Location: Reactor Building - Drywell
 Drawing No.: 2-ISI-0270-C-02 Description: P - TEE
 System ID: 066 - Reactor Water Recirculating System
 Component ID: KR-2-25 Size/Length: 28 / Thickness/Diameter: 1.322 / 28
 Limitations: See Report

Comments:

This examination was performed using TVA ISO procedure N-UT-84, revision 1, titled "Procedure for the Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This procedure implements the processes and requirements of EPRI Report 1016650 which contains the procedure EPRI-PIPE-MPA-1, revision 0, titled "Procedure for Manual Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This examination was performed on a 28" diameter SS Pipe to Tee weld to satisfy the requirements of Risk Informed Category R-A, Item R1.16C and Category C, Item NU0313.

50% coverage of the examination volume was achieved.

No rejectable indications

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: 50


Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Kleinjan, Michael W.	III	<i>[Signature]</i>	4/8/2013	Matt Welch, LII	<i>[Signature]</i>	4/9/13
Examiner	Level	Signature	Date	Site Review	Signature	Date
Gatica, James A.	II	<i>[Signature]</i>	4/6/2013	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MAT LOVELL	<i>[Signature]</i>	4/16/13

THICKNESS AND CONTOUR

Position	0	90	180	270
1	1.4			
2*	1.41			
3	1.43			
4*	N/A			
5	N/A			

* Weld edge



UT-13-072

Examiner: <i>M. K. [Signature]</i> 4/1/13	Reviewer: <i>[Signature]</i> 4/1/13	ANII: <i>[Signature]</i> 4/16/13
Print name: <i>M. K. [Signature]</i> Date:	Print name: <i>MATT WELCH [Signature]</i> Date:	Print name: <i>MAT LOVELL</i> Date:
COMPONENT ID: KA-2-25		
CROWN WIDTH: 2.0	WELD LENGTH: 88	
CROWN HEIGHT: Flush	DIAMETER: 28	

Shear Scan
3-5-6
RL Scan
3

Unscanned Area

Exam Limited Due To Tee Configuration

Required Exam Volume
 $H = .146 \times W = 2.0 \times L = 88 = 80.96$
 Obtained Exam Volume = 50%

Single side Access No Circ Scan on Tee side, No Axial Scan on Tee side

000450

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-076

(4 pages)



Ultrasonic Examination

Site/Unit: BFN / 2 Procedure: N-UT-84 54 Outage No.: U2RF17
 Summary No.: 01859-ISI-BFN2 Procedure Rev.: 1 Report No.: UT-13-076
 Workscope: ISI Work Order No.: 2-SI-4.6.G Page: 1 of 10

Code: Section XI 2004 Edition Cat./Item: R-A/R1.16D Location: Reactor Building - Drywell
 Drawing No.: 2-SI-0272-C-01 Description: P - P
 System ID: 069 - Reactor Water Cleanup System
 Component ID: RWCU-2-003-070 Size/Length: 6 / Thickness/Diameter: 0.432 / 6
 Limitations: See Report

Comments:

This examination was performed using TVA ISO procedure N-UT-84, revision 1, titled "Procedure for the Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This procedure implements the processes and requirements of EPRI Report 1016650 which contains the procedure EPRI-PIPE-MPA-1, revision 0, titled "Procedure for Manual Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This examination was performed on a 6" diameter SS pipe to weld-o-let butt weld to satisfy the requirements of Risk Informed Category R-A, Item R1.16D and Category D, Item NU0313.

73.725%
 73.8% coverage of the examination volume was achieved.

4/19/13
 No rejectable indications.

Results: Accept Reject Info


Percent Of Coverage Obtained > 90%: 73.725%

Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Gatica, James A.	II		4/4/2013	Matt Welch, LII		4/9/13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MATT LOVELL		4/19/13

Examiner: <i>JH</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>Matt Welch</i>
Print name: JAMES GATICA	Print name: MATT WELCH III	Print name: MATT WELCH
Date: 4/4/13	Date: 4/9/13	Date: 4/19/13

LIMITATION DUE TO NON PARALLEL SURFACES ON TEE SIDE



CIRC SCAN LIMITATION:

$$[((0.25 + 0.15) / 2) \times 1.35] \times 4.9 = 4.023 \text{ } 5.616$$

20.0
4/4/13 4/19/13

CIRC OBTAINED VOLUME:

$$8.07 - 4.023 = 4.047 / 8.07 = .5014 = 50.1\% \text{ } 4/19/13$$

$$11.27 - 5.616 = 5.654 / 11.27 = .5017 = 50.2\%$$


SCANS:

- 3) 94.4% 73.705%
- 4) 100% = 73.6% Coverage
- 5) 50% 4/19/13
- 6) 50%

COVE. GE PLOT

Component ID: RWCU-2-003-070
 UT-13-076

Examiner: <i>[Signature]</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>[Signature]</i>
Print name: James Garcia	Print name: MATT WELCH III	Print name: MATT LOVELL
Date: 4/4/13	Date: 4/9/13	Date: 4/19/13



LIMITATION

$$[((.25 + .15) / 2) \times .15] \times 14.9 = .447 \cdot 624$$

20.8
u-4/19/13 *u-4/19/13*

REQUIRED EXAM VOLUME

$$[(.25 + .15) / 2 \times 2.71] \times 14.9 = 8.07 \cdot 11.27^3 \text{ IN}$$

20.8 *u-4/19/13*
u-4/19/13

SHEAR OBTAINED VOLUME = 94.4%

$$8.07 - .447 = 7.6 / 8.07 = .944 \text{ u-4/19/13}$$

$$11.27 - .627 = 10.65 / 11.27 = .9446 = 94.5\%$$

pg 9/10


000456

COVERED PIPE PLOT

Component ID: RWCU-2-003-070 LT-13-076

Examiner: <i>J. H. Gatica</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>Matt Lovell</i>
Print name: JAMES GATICA	Print name: MATT WELCH III	Print name: MATT LOVELL
Date: 4/4/13	Date: 4/9/13	Date: 4/19/13

RWCU-2-003-070



SINGLE SIDED COVERAGE pg 10/10

UJ04S7

**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-079

(3 pages)



Ultrasonic Examination



Site/Unit: BFN / 2 Procedure: N-UT-84 Outage No.: U2RF17
 Summary No.: 01507-ISI-BFN2 Procedure Rev.: 1 Report No.: UT-13-079
 Workscope: AUG Work Order No.: 2-SI-4.6.G Page: 1 of 11 *4/11/13*

Code: Section XI 2004 Edition Cat./Item: B-J/B9.11 Location: Reactor Building - Drywell
 Drawing No.: 2-ISI-0221-C-01 Description: P - P
 System ID: 074 - Residual Heat Removal System
 Component ID: DRHR-2-09 Size/Length: 24 / Thickness/Diameter: 1.219 / 24
 Limitations: See Attached Report

Comments:

This examination was performed using TVA ISO procedure N-UT-84, revision 1, titled "Procedure for the Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This procedure implements the processes and requirements of EPRI Report 1016650 which contains the procedure EPRI-PIPE-MPA-1, revision 0, titled "Procedure for Manual Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This examination was performed on a 24" diameter SS Pipe to Tee weld to satisfy the requirements of Category E, item NU0313.

This weld contains two previously recorded IGSCC flaws. Refer to UT sizing report UT-13-032 for additional data.

50% coverage of the examination volume was achieved.

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: 50

Reviewed Previous Data: Yes


Examiner	Level	Signature	Date	Reviewer	Signature	Date
KLEINJAN, DAVID R	III*	<i>[Signature]</i>	4/10/2013	Matt Welch, LIII	<i>[Signature]</i>	4/12/13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			N/A		



THICKNESS AND CONTOUR

Position	0	90	180	270
1	1.24			
2*	1.19			
3	1.32			
4*	1.3			
5	2			

* Weld edge



LT-13-079

Examiner: <i>D.R. [Signature]</i> APRIL 10, 13	Reviewer: <i>[Signature]</i> 4/12/13	ANII: N/A
Print name: DAVID Klemm	Date:	Print name: MATT WELLS Date:
COMPONENT ID: DRHR-2-09		
CROWN WIDTH: 1.5	WELD LENGTH: 76	
CROWN HEIGHT: 1/8	DIAMETER: 24	

PIPE

TEE

REQUIRED EXAM VOLUME
 $H = .63 \times W = 2" \times L = 76' = 95.8$
 Same limitation as R/I coverage. Discontinuity 50% coverage
 EXAM LIMITED DUE TO TEE CONFIGURATION


SINGLE SIDE ACCESS. NO CIRC SCAN ON TEE SIDE, NO AXIAL SCAN ON TEE SIDE

8/11

THICKNESS AND CONTOUR


Position	0	90	180	270
1	1.24			
2*	1.19			
3	1.32			
4*	1.3			
5	2.0			

* Weld edge



LIT-13-079

Examiner: <i>D. K. Klemjan</i> APRIL 10, 13	Reviewer: <i>Matt Welch</i> 4/12/13	ANII: <i>N/A</i>
Print name: <i>DAVID KLEMJAN</i> Date:	Print name: <i>MATT WELCH</i> Date:	Print name: Date:
COMPONENT ID: <i>DRHR-2-09</i>		
CROWN WIDTH: <i>1.5</i>	WELD LENGTH: <i>76"</i>	
CROWN HEIGHT: <i>1/8</i>	DIAMETER: <i>24</i>	



**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-080

(3 pages)



Ultrasonic Examination

✓

Site/Unit: BFN / 2 Procedure: N-UT-84 Outage No.: U2RF17
 Summary No.: 01518-ISI-BFN2 Procedure Rev.: 1 Report No.: UT-13-080
 Workscope: AUG Work Order No.: 2-SI-4.6.G Page: 1 of 11
 Code: Section XI 2004 Edition Cat./Item: B-J/B9.11 Location: Reactor Building - Drywell
 Drawing No.: 2-ISI-0221-C-01 Description: VLV - P
 System ID: 074 - Residual Heat Removal System
 Component ID: DRHR-2-22 Size/Length: 20 / Thickness/Diameter: 1.031 / 20
 Limitations: See Attached Report

Comments:

This examination was performed using TVA ISO procedure N-UT-84, revision 1, titled "Procedure for the Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This procedure implements the processes and requirements of EPRI Report 1016650 which contains the procedure EPRI-PIPE-MPA-1, revision 0, titled "Procedure for Manual Phased Array Ultrasonic Examination of Austenitic and Ferritic Pipe Welds".

This examination was performed on a 24" diameter SS Pipe to Tee weld to satisfy the requirements of Category E, item NU0313.

This weld contains one previously recorded IGSCC flaws. Refer to UT sizing report UT-13-033 for additional data.

50% coverage of the examination volume was achieved.

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90% 50 Reviewed Previous Data: Yes


Examiner	Level	Signature	Date	Reviewer	Signature	Date
KLEINJAN, DAVID R	III*	<i>[Signature]</i>	4/9/2013	Matt Welch, LIII	<i>[Signature]</i>	4/12/13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			N/A		



COVERAGE PLOT

Component ID: DRHR-2-22
LT-13-080

Examiner: <i>D. R. Kye</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: <i>DAVID KLEINJAN</i>	Print name: <i>MATT WELCH</i>	Print name:
Date: <i>09 APR 2013</i>	Date: <i>4/12/13</i>	Date:



REQUIRED EXAM VOLUME

$$H = .15 \times W = 1.7 \times L = 62.8 = 53.38$$

SINGLE SIDE ACCESS DUE TO VALVE CONFIGURATION

$$\text{LIMITATION} = 53.38 - (.85 \times .5) \times 62.8 = 27.1 / 53.38 = .507 \text{ COVERAGE OBTAINED SHEAR} = 50\%$$


SCAN	
# 3	0
# 4	100
# 5	50
# 6	50%
	200 ÷ 4

pg 8/11

COVERAGE PLOT

Component ID: DRHR-2-22
 LT-13-080

Examiner: <i>J.R. [Signature]</i>	Reviewer: <i>[Signature]</i>	ANII: <i>N/A</i>
Print name: Mike Kleinjan	Print name: MATT WELCH	Print name:
Date: APR 10 2013	Date: 4/12/13	Date:



**Enclosure
Attachment B**

**TENNESSEE VALLEY AUTHORITY
Browns Ferry Nuclear Plant, Units 1, 2, and 3
Request for Relief ISI-44**

Weld Inspection Report Excerpts

UT-13-086

(7 pages)

LF-13-086

6/16/13

PROJECT:	BFN	UNIT:	2	CYCLE:	17
SYSTEM:	Rector Water Cleanup System			Component:	RCRD-2-50
Examiner:	<i>D.R. Higgins</i>			Reviewer:	<i>Matt Weich</i>
Print Name:	David Kleinjan			Print Name:	Matt Weich
Date:	05-Apr-13			Date:	4/19/13

Items #

1	RL Axial Full Required Exam Volume $14.75 \times 1.09 \times ((0.332 + 0.828) / 2) =$	9.3250
2	RL Axial Lower One Third Required Exam Volume $14.75 \times 1.09 \times ((0.113 + 0.277) / 2) =$	3.1351
3	Shear Axial Full Required Exam Volume $14.75 \times 1.09 \times ((0.332 + 0.828) / 2) =$	9.3250
4	Shear Axial Lower One Third Required Exam Volume $14.75 \times 1.09 \times ((0.113 + 0.277) / 2) =$	3.1351
5	RL Full Clockwise and CounterClockwise Scanning Required exam Volume $14.75 \times 1.09 \times ((0.332 + 0.828) / 2) =$	9.3250
6	RL Lower One Third Clockwise and CounterClockwise Scanning Required exam Volume $14.75 \times 1.09 \times ((0.113 + 0.277) / 2) =$	3.1351
7	Shear Full Clockwise and CounterClockwise Scanning Required exam Volume $14.75 \times 1.09 \times ((0.332 + 0.828) / 2) =$	9.3250
8	Shear Lower One Third Clockwise and CounterClockwise Scanning Required exam Volume $14.75 \times 1.09 \times ((0.113 + 0.277) / 2) =$	3.1351
9	RL Axial Full Volume Obstructed Exam from the Elbow side $(1.09 / 2) \times 5.0125 \times ((0.332 + 0.561) / 2) =$	1.2198
10	RL Axial Full Volume Obstructed Exam from the Valve side $(1.090 / 2) \times (2.7948 \times 3) \times ((0.561 + 0.828) / 2) =$	3.1735
11	RL Axial Lower One Third Volume Obstructed Exam from the Elbow side $(1.090 / 2) \times 5.0 \times ((0.277 + 0.113) / 2) =$	0.5314
12	RL Axial Lower One Third Volume Obstructed Exam from the Valve side $(1.090 / 2) \times (2.7948 \times 3) \times 0.277 =$	1.2658
13	Shear Axial Full Volume Obstructed Exam plus the area that is not qualified by this procedure from the Elbow side $14.75 \times ((0.563 \times 0.561) / 2) / 2 =$	1.1647
14	Shear Axial Full Volume Obstructed Exam plus the area that is not qualified by this procedure from the Valve side $(14.75 \times (((0.563 \times 0.561) / 2) / 2)) + ((1.090 / 2) \times (1.9781 \times 3) \times 0.277) - (((0.149 \times 0.300) / 2) \times (1.9781 \times 3)) =$	1.9279
15	Shear Axial Lower One Third Volume Obstructed Exam plus the area of exam that is not qualified by this procedure from the Elbow side $14.75 \times (((0.298 \times 0.300) / 2) / 2) =$	0.3297
16	Shear Axial Lower One Third Volume Obstructed Exam plus the area of exam that is not qualified by this procedure from the Valve side $14.75 \times (((0.298 \times 0.300) / 2) / 2) + ((1.090 / 2) \times (1.9781 \times 3) \times 0.277) =$	0.8485
17	RL Full Clockwise and CounterClockwise Scanning Obstructed exam Volume $14.75 \times 0.388 \times ((0.828 + 0.561) / 2) =$	3.9746
18	RL Lower One Third Volume Clockwise and CounterClockwise Scanning Obstructed exam Volume $14.75 \times 0.388 \times 0.277 =$	1.5853
19	Shear Full Clockwise and CounterClockwise Scanning Obstructed exam Volume plus the area of exam that is not qualified by this procedure $14.75 \times ((0.563 \times 0.561) / 2) =$	2.3293

6/10/19
PS

UT-13. 2

20	Shear Lower One Third Clockwise and CounterClockwise Scanning Obstructed exam Volume plus the area of exam that is not qualified by this procedure $14.75 * ((0.298 * 0.300) / 2) =$	0.6593
21	RL Axial Full Obtained Exam Volume from Elbow side $((\text{Item } 1) / 2) - \text{Item } 9 =$	3.4427
22	RL Axial Full Obtained Exam Volume from Valve side $((\text{Item } 1) / 2) - \text{Item } 10 =$	1.4890
23	RL Axial Lower One Third Obtained Exam Volume from the Elbow side $((\text{Item } 2) / 2) - \text{Item } 11 =$	1.0362
24	RL Axial Lower One Third Obtained Exam Volume from the Valve side $((\text{Item } 2) / 2) - \text{Item } 12 =$	0.9018
25	Shear Axial Full Obtained Exam Volume from Elbow side $((\text{Item } 3) / 2) - \text{Item } 13 =$	3.4978
26	Shear Axial Full Obtained Exam Volume from Valve side $((\text{Item } 3) / 2) - \text{Item } 14 =$	2.7346
27	Shear Axial Lower One Third Obtained Exam Volume from the Elbow side $((\text{Item } 4) / 2) - \text{Item } 15 =$	1.2379
28	Shear Axial Lower One Third Obtained Exam Volume from the Valve side $((\text{Item } 4) / 2) - \text{Item } 16 =$	0.7191
29	RL Full Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 5 - Item 17 =	5.3503
30	RL Lower One Third Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 6 - Item 18 =	1.5498
31	Shear Full Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 7 - Item 19 =	6.9956
32	Shear Lower One Third Clockwise and CounterClockwise Scanning Obtained Exam Volume Item 8 - Item 20 =	2.4758
33	RL Axial Full Exam Volume Percentage from Elbow side $(\text{Item } 21 / ((\text{Item } 1) / 2)) * 100 = \%$	73.84%
34	RL Axial Full Exam Volume Percentage from Valve side $(\text{Item } 22 / ((\text{Item } 1) / 2)) * 100 = \%$	31.93%
35	RL Axial Lower One Third Exam Volume Percentage from Elbow side $(\text{Item } 23 / ((\text{Item } 2) / 2)) * 100 = \%$	66.10%
36	RL Axial Lower One Third Exam Volume Percentage from Valve side $(\text{Item } 24 / ((\text{Item } 2) / 2)) * 100 = \%$	19.25%
37	Shear Axial Full Exam Volume Percentage from Elbow side $(\text{Item } 25 / ((\text{Item } 3) / 2)) * 100 = \%$	75.02%
38	Shear Axial Full Exam Volume Percentage from Valve side $(\text{Item } 26 / ((\text{Item } 3) / 2)) * 100 = \%$	58.65%
39	Shear Axial Lower One Third Exam Volume Percentage from Elbow side $(\text{Item } 27 / ((\text{Item } 4) / 2)) * 100 = \%$	78.97%
40	Shear Axial Lower One Third Exam Volume Percentage from Valve side $(\text{Item } 28 / ((\text{Item } 4) / 2)) * 100 = \%$	45.87%
41	RL Clockwise and CounterClockwise Full Exam Volume Percentage $(\text{Item } 29 / \text{Item } 5) * 100 = \%$	57.38%
42	RL Clockwise and CounterClockwise Lower One Third Exam Volume Percentage $(\text{Item } 30 / \text{Item } 6) * 100 = \%$	49.43%
43	Shear Clockwise and CounterClockwise Full Exam Volume Percentage $(\text{Item } 31 / \text{Item } 7) * 100 = \%$	75.02%
44	Shear Clockwise and CounterClockwise Lower One Third Exam Volume Percentage $(\text{Item } 32 / \text{Item } 8) * 100 = \%$	78.97%

86
87.

45	Full Exam Volume Percentage combining Shear and RL in the Axial, Clockwise, and CounterClockwise Dircetions (Item 33 + Item 34 + Item 37 + Item 38 + Item 41 + Item 43)/6 =% 61.97%
46	Lower One Third Exam Volume Percentage combining Shear and RL in the Axial, Clockwise, and CounterClockwise Dircetions (Item 35 + Item 36 + Item 39 + Item 40 + Item 42 + Item 44)/6 =% 56.43%

PS 1/19

COVERAGE PLOT

Component ID: RCRD-2-50

LT-13-086

Examiner: <i>D. Kleinjan</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 05 APR 2013	Date: <i>4/19/13</i>	Date:

Elbow

Flow 

Valve


Shear Axial Scanning

Full Required Exam Volume:

$$14.75 \times 1.090 \times ((.332 + .828) / 2) = 9.3250 \text{in}^3$$

Lower One Third Required Exam Volume:

$$14.75 \times 1.090 \times ((.113 + .277) / 2) = 3.1351 \text{in}^3$$





RL Axial Scanning

Full Required Exam Volume:

$$14.75 \times 1.090 \times ((.332 + .828) / 2) = 9.3250 \text{in}^3$$

Lower One Third Required Exam Volume:

$$14.75 \times 1.090 \times ((.113 + .277) / 2) = 3.1351 \text{in}^3$$



000573


ps 12/19

COVERAGE PLOT

Component ID: RCRD-2-50

LT-13-0586

Examiner: <i>D.P. Klein</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 05 APR 2013	Date: <i>4/19/13</i>	Date:



000571


ps 13/19

COVERAGE PLOT

Component ID: RCRD-2-50

LIT-13-086

Examiner: <i>D. Kleinjan</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 05 APR 2013	Date: <i>4/19/13</i>	Date:



000575

PS 14/19

INDICATION PLOT

Component ID: RCRD-2-50

UT-13-086

Examiner: <i>D.R. Blay</i>	Reviewer: <i>Matt Welch</i>	ANII: <i>N/A</i>
Print name: David Kleinjan	Print name: Matt Welch	Print name:
Date: 05 APR 2013	Date: <i>4/19/13</i>	Date:

