


APR1400 Design Certification Application Pre-submittal Update



KEPCO/KHNP
October 29, 2014

18th Pre-application Meeting

Contents

- **Purposes**
- **Introduction**
- **APR1400 Design Certification Status**
- **NRC Comments**
- **Resolutions**
- **Additional Efforts**
- **Conclusions**


Purposes

- **Present the status of the APR1400 submittal readiness**
- **Receive the NRC feedback**


Introduction

- The APR1400 Design Concept and Features

- ✓ Major design concept is identical to System 80+



System80+



APR1400

Introduction

● The APR1400 Design Concept and Features

✓ Additional safety features incorporated in the APR1400

Thermal Power

- System80+ : 3,931 MWt
- APR1400 : 4,000 MWt

RCS Depressurization Equipment


- System80+ : 3 spring loaded PSV + 2 SDS
- APR1400 : 4 POSRVs

RV Upper Structure

- System80+ : Conventional
- APR1400 : IHA

Safety Injection System

- System80+ : 4 train ECCS + DVI
- APR1400 : 4 train ECCS + DVI + Fluidic Device



Introduction

- **Shin-Kori Units 3 and 4**

- ✓ **The reference plant for the DC application**
- ✓ **Expected commercial operations: 2015 and 2016**

- **Future Projects**

- ✓ **Shin-Hanul Units 1 and 2: Start-up 2017, 2018**
- ✓ **Shin-Kori Units 5 and 6: Start-up 2021, 2022**
- ✓ **Overseas Projects**

Introduction

- **APR1400 DC Application**

- ✓ **Retain the reference plant design (Shin-Kori Units 3 and 4)**
 - **Some minor differences (e.g., turbine generator design to be selected by COL applicants, ultimate heat sink)**
 - **Address U.S. industry standards and expectations**
- ✓ **Meet NRC expectations**
 - **Address December 2013 comments**
 - **Improve clarity**
 - **Include other changes resulting from NRC interactions this year**

APR1400 Design Certification Status

- **The letter of intent on the DC application submitted in March 2009.**
- **Numerous pre-application meetings held between 2010 ~ 2014.**
- **The initial APR1400 Design Certification Application submitted in September 2013.**
- **A summary of NRC review transmitted to KHNP in December 2013 (ML13351A417):**
 - ✓ **Twelve issues identified**
 - ✓ **Non-acceptance for docketing**

Twelve Issues

NRC Comments

ML13351A417

“...the application’s deficiencies in the areas of instrumentation and controls (I&C), human factors engineering, probabilistic risk assessment, and in the environmental report. The two key I&C issues for which the application did not provide sufficient information are the software common cause failures of non-safety related control systems that can lead to spurious actuations of redundant safety and non-safety components; and the critical characteristics, such as deterministic performance and the software development process of the safety I&C system platform. Additionally, the NRC staff determined that the application did not provide a sufficient level of detail related to reactor coolant pump design; leak-before-break evaluation; effects of irradiation-assisted stress corrosion cracking on core supports and reactor internals; turbine missile probability; welds for reactor vessel integrity evaluations; radioactive waste management; and radiation protection. The NRC staff also notes that you have not yet submitted technical reports in the following areas: vibration assessment of reactor internals; flywheel integrity; fuel seismic response evaluation; and new and spent fuel criticality analysis.”

NRC Comments

- **The deficiencies in the areas of:**
 - ✓ **instrumentation and controls (I&C);**
 - ✓ **human factors engineering;**
 - ✓ **probabilistic risk assessment; and**
 - ✓ **environmental report**

NRC Comments

- **Insufficient level of detail related to:**
 - ✓ reactor coolant pump design;
 - ✓ leak-before-break evaluation;
 - ✓ effects of irradiation-assisted stress corrosion cracking on core supports and reactor internals;
 - ✓ turbine missile probability;
 - ✓ welds for reactor vessel integrity evaluations;
 - ✓ radioactive waste management; and
 - ✓ radiation protection

NRC Comments

- **Technical reports needed in the following areas:**
 - ✓ **vibration assessment of reactor internals;**
 - ✓ **flywheel integrity;**
 - ✓ **fuel seismic response evaluation; and**
 - ✓ **new and spent fuel criticality analysis**

Resolutions

● Instrumentation & Control (I&C)

✓ Issues

- **Insufficient information on the software Common Cause Failures (CCFs) of non-safety related control systems**
- **Lack of critical characteristics of the safety I&C platform**

✓ Resolutions

- **Evaluated safety of the system under software common cause failures of non-safety related control systems.**
- **Adopted Westinghouse Common Q as the safety I&C platform. The critical characteristics of the platform are provided as a technical report.**

Resolutions

● Human Factor Engineering (HFE)

✓ Issues

- Lack of clarity, conciseness and technical detail
- HFE design approaches:
 - Detailed implementation plans (IPs) with supporting ITAAC or
 - General IPs with associated results summary reports

✓ Resolutions

- Improved document quality and supplemented technical details in Design Control Document (DCD) and the technical reports.
- Will submit 9 detailed IPs and 3 Technical Reports.

Resolutions

● Probabilistic Risk Assessment (PRA)

✓ Issues

- Lack of quantitative development of the Low-Power Shutdown (LPSD) internal fire/flooding PRAs, and the LPSD level 2 PRAs
- Lack of detailed risk insights

✓ Resolutions

- Performed quantitative assessments of LPSD PRAs
- Updated the risk insights

● Environmental Report (ER)

✓ Issues

- Lack of design-specific Severe Accident Mitigation Design Alternative (SAMDA) list
- Lack of detailed documentation

✓ Resolutions

- Clarified the design-specific SAMDA list
- Prepared a technical report with the detailed information

Resolutions

● Reactor Coolant Pump (RCP)

✓ Issues

- Insufficient level of details
- Proposed Design Acceptance Criteria (DAC) for the RCP design
- RCP flywheel integrity was lacking

✓ Resolutions

- DCD enhanced with additional technical details
- DAC will not be used for the RCP design, the Tier 1 revised
- RCP flywheel integrity technical report will be submitted

Resolutions

● Leak-Before-Break (LBB)

✓ Issues

- Not addressed pre-service inspection for all welds in LBB-applied piping (i.e., surge line, SI/SC piping)

✓ Resolutions

- Will apply 100% pre-service inspection for the LBB applied piping welds.
- A technical report will be submitted.

● Irradiation-Assisted Stress-Corrosion Cracking (IASCC)

✓ Issues

- No evaluation on the effects of IASCC and void swelling

✓ Resolutions

- Performed the evaluation for susceptibility to IASCC and void swelling.
- The results are incorporated into the DCD.

Resolutions

● Turbine Missile Probability

✓ Issue

- Lack of turbine missile probability analysis

✓ Resolution

- Revised DCD to incorporate the Combined License (COL) action items and Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) with the detailed turbine missile probability analysis plan for the COL applicant.

● Reactor Vessel (RV) Weld Integrity

✓ Issue

- Not included RV integrity related evaluations for the RV welds

✓ Resolutions

- Performed RV integrity for RV weld and incorporated into DCD.
- Revised the technical report.

Resolutions

● Radwaste Management (RW)

✓ Issues

- **Compliance of Liquid Waste Management System (LWMS) and Gas Waste Management System (GWMS) with 10CFR20, App. B and 10CFR50, App. I**
- **Initial loading and type of subsystem demineralizers and filters**
- **Automatic isolation of effluent release**

✓ Resolutions

- **Added detailed description for processing the liquid/gaseous waste prior to release.**
- **Added an ITAAC specifying the Decontamination Factor (DF) requirements and filter efficiency.**
- **Added an ITAAC to confirm the automatic isolation of effluent release.**

Resolutions

● Radiation Protection (RP)

✓ Issues

- Stay times in vital areas outside Main Control Room (MCR) and Technical Support Center (TSC) are not specified
- Occupational Radiation Exposure (ORE) data consistency with RG 8.19
- Justification of Environmental Qualification (EQ) total integrated dose (TID) margin
- Radiation zones for Turbine Building and component cooling water (CCW) heat exchanger building

✓ Resolutions

- Vital area mission dose analyses have been completed with consideration of actual expected time and locations where the emergency operator actions are required.
- Number of workers expected to be working on a given task and exposure time have been specified to be consistent with RG 8.19.
- EQ margin justification and updates of the radiation zones drawings will be incorporated into the DCD.

Resolutions

● Technical Reports

✓ Issues

- **Four Technical Reports needed:**
 - **vibration assessment of reactor internals;**
 - **flywheel integrity;**
 - **fuel seismic response evaluation; and**
 - **new and spent fuel criticality analysis**

✓ Resolution

- **The four technical reports are prepared and will be submitted with the DCD.**

Additional Efforts

- **Four topical reports submitted are under review by the NRC.**
- **Over 50 technical reports are to be submitted with the DCD.**
- **The KHNP Quality Assurance Program Description (QAPD) for the APR1400 DC has been approved by the NRC in 2013.**
- **The Safeguards Information (SGI) order has been received, and the program approval is in process.**

Conclusions

- **All issues identified by the NRC staff have been addressed, and the staff's feedback received during several pre-application meetings were incorporated.**
- **The APR1400 DC application is being finalized, and the supporting technical reports will be submitted together with the DC application.**
- **KEPCO/KHNP plans to submit the APR1400 DC application in December 2014.**

Conclusions

- **The KEPCO/KHNP management is in full support of the DCD submittal.**
- **The financial and technical resources are available to support the NRC staff's review of the DCD.**
- **KEPCO/KHNP looks forward to interact with NRC during the APR1400 DC application reviews, after its acceptance.**

Thank You!

Acronyms (1/2)

APR	– Advanced Power Reactor	HVAC	– Heating, Ventilation, Air Conditioning
CCF	– Common Cause Failure	I&C	– Instrumentation & Control
CCW	– Component Cooling Water	IASCC	– Irradiation-Assisted Stress-Corrosion Cracking
COL	– Combined License	IHA	– Integrated Head Assembly
DAC	– Design Acceptance Criteria	IP	– Implementation Plan
DC	– Design Certification	IRWST	– In-containment Refueling Water Storage Tank
DCD	– Design Control Document	ITAAC	– Inspections, Tests, Analyses, and Acceptance Criteria
DF	– Decontamination Factor	KEPCO	– Korea Electric Power Corporation
DVI	– Direct Vessel Injection	KHNP	– Korea Hydro & Nuclear Power Co. Ltd
ECCS	– Emergency Core Cooling System	LBB	– Leak-Before-Break
ER	– Environmental Report	LPSD	– Low-Power and Shutdown
EQ	– Environmental Qualification	LWMS	– Liquid Waste Management System
ESF	– Engineering Safety Feature	MCR	– Main Control Room
GWMS	– Gaseous Waste Management System		
HFE	– Human Factors Engineering		

Acronyms (2/2)

NRC – Nuclear Regulatory Commission

ORE – Occupational Radiation Exposure

POSRV – Pilot Operated Safety Relief Valve

PRA – Probabilistic Risk Assessment

PSV – Pressurizer Safety Valve

QAPD – Quality Assurance Program

Description

PRA – Probabilistic Risk Assessment

RCP – Reactor Coolant Pump

RCS – Reactor Coolant System

RG – Regulatory Guide

RV – Reactor Vessel

RW – Radwaste Management

SAMDA – Severe Accident Mitigation Design

Alternative

SDS – Safety Depressurization System

SGI – Safeguards Information

SI/SC – Safety Injection/Shutdown Cooling

TID – Total Integrated Dose

TSC – Technical Support Center