

A large, decorative blue wave graphic that starts as a light blue shape on the left and transitions into a solid blue shape on the right, arching across the top of the slide.

St. Lucie Unit 2 Fuel Transition Project

November 3, 2014

AGENDA

- **Introduction and Purpose**
- **Proposed Technical Specifications Changes**
- **Fuel Mechanical Design**
- **Nuclear Design**
- **Thermal Hydraulic Design**
- **Accident and Transient Analyses**
- **Impact on Other Analyses**
- **License Amendment Request Contents**
- **Summary and Schedule**
- **Public Questions**

Introduction and Purpose

- **Purpose:** Discuss the planned License Amendment Request for the transition to the AREVA High Thermal Performance (HTP) fuel design at St. Lucie Unit 2.
- St. Lucie Unit 2 has experienced some grid-to-rod fretting fuel failures in the current fuel design.
- The AREVA HTP fuel has operated successfully in St. Lucie Unit 1 for 8 complete cycles without fuel failures.
- The transition to AREVA HTP fuel design is planned for Cycle 23 – Current operating cycle is Cycle 21.

St. Lucie Unit 2 Description

- St. Lucie 2 is a Combustion Engineering 2x4 plant with a 16x16 fuel lattice array.
- Except for fuel array, Units 1 and 2 are very similar
 - 217 fuel assemblies in core
 - 4 guide tubes, 1 center instrument tube
 - 8.18 inch bundle pitch
 - 136.7 inch fuel column
 - 3,020 MW(th) core power

Proposed Technical Specifications Changes

- **Technical Specifications changes:**
 - TS 4.2.1.3 (Surveillance Requirements for LINEAR HEAT RATE)
 - Delete bullets d – f.
 - Deletion of F_q surveillance with $W(z)$, when monitoring on excore detector system, is consistent with AREVA methods & similar to St. Lucie Unit 1.
 - TS 5.3.1 (Fuel Assemblies)
 - Add M5 as a fuel rod cladding material.
 - Change “Zircaloy or ZIRLO” to “Zircaloy, ZIRLO or M5”
 - TS 6.9.1.11 (CORE OPERATING LIMITS REPORT)
 - Revise to include AREVA NRC approved methods for Neutronics, Fuel Mechanical, Thermal-Hydraulics, and Safety Analyses.

Proposed Technical Specifications Changes (Contd.)

-- Neutronics Methods

- EMF-96-029(P)(A), Volumes 1 & 2
- XN-NF-78-44 (NP)(A)
- XN-75-27(A), and Supplements 1 through 5

-- Fuel Mechanical Design Methods

- XN-NF-82-06 (P)(A), Rev 1 and Supplements 2, 4 and 5
- XN-NF-85-92(P)(A)
- ANF-88-133(P)(A) and Supplement 1
- EMF-92-116(P)(A), Rev 0
- BAW-10240(P)(A), Rev 0

Proposed Technical Specifications Changes (Contd.)

-- Thermal Hydraulics Methods

- XN-NF-82-21(P)(A), Revision 1
- EMF-92-153(P)(A), Revision 1
- EMF-1961(P)(A), Revision 0
- EMF-2310(P)(A), Revision 1
- XN-75-32(P)(A), Supplements 1, 2, 3 and 4

-- Safety Analyses Methods

- EMF-2310(P)(A), Revision 1 (S-RELAP5 Non-LOCA)
- BAW-10231P-A, Revision 1 (COPERNIC)
- EMF-2103(P)(A) Revision 0 (RLBLOCA)
- EMF-2328(P)(A) Revision 0 (SBLOCA)

Proposed Technical Specifications Changes (Contd.)

- **Other Affected Technical Specifications**
 - TS Condition 3.K (ZIRLO Requirements)
 - This TS is applicable to ZIRLO cladding. Since ZIRLO clad fuel will remain in the core during transition cycles, this TS is retained.

 - TS Condition 3.N (FATES3B Safety Analyses)
 - Current more restrictive requirements retained for Westinghouse fuel.
 - Requirement for re-analyses for thermal conductivity degradation effects for Westinghouse fuel are deleted due to transition to AREVA fuel.

Proposed Technical Specifications Changes (Contd.)

- TS Figure 2.1-1 (Thermal Margin Safety Limit Lines)
 - Remains unchanged
 - Figure verified to be applicable for the fuel design change.
- **COLR Changes**
 - Delete Fq surveillance $W(z)$ requirements and Table 3.2-3, consistent with the change to TS 4.2.1.3.
 - Revise Figure 3.2-1 to change peak linear heat rate limit from 12.5 kW/ft to 13 kW/ft.
 - Revise the list of methodology consistent with the changes to TS 6.9.1.11.
- **TS Bases Changes**
 - Revise TS Bases consistent with the above TS changes.

Fuel Mechanical Design

- AREVA HTP Fuel Design
 - Overall assembly geometrical dimensions similar to AREVA HTP design in St. Lucie-1
 - HTP design robust and grid-to-rod fretting resistant
 - MONOBLOC guide tube
 - M5 fuel rod cladding
 - FUELGUARD debris filter
- Operating Experience
 - Significant successful operating history of base HTP design in B&W 15x15 plants, Westinghouse 15x15 and 17x17 plants, and CE 14x14, 15x15, and 16x16 plants in the US, as well as worldwide experience.

Fuel Mechanical Design (Contd.)

- Bundle and Component Testing
 - Performed extensive component and fuel assembly mechanical testing.
 - Performed hydraulic testing on AREVA HTP and co-resident fuel design.
 - Testing in the same flow loop ensures comparable results.
 - Supports thermal-hydraulic compatibility in transition cores.

Fuel Mechanical Design (Contd.)

- Mechanical Compatibility
 - Fuel determined to be compatible with reactor components and co-resident fuel.
- Mechanical Design Evaluations
 - Acceptable results for fuel rod analysis and structural analysis.
 - Analysis meets all NRC-approved mechanical criteria established per EMF-92-116(P)-A, BAW-10240(P)-A, and BAW-10133(P)-A, Rev. 1, and Addendums 1 and 2.
 - Requirements of the Standard Review Plan 4.2. (NUREG-0800) are satisfied.
 - Issues identified in IN-2012-09, Irradiation Effects on Fuel Assembly Spacer Grid Crush Strength, are addressed.

Fuel Mechanical Design (Contd.)

- TCD impacts have been incorporated.
 - Performed full seismic/LOCA evaluation for BOL and EOL conditions using BAW-10133P-A.
 - Seismic models include a full core of AREVA HTP fuel as well as a series of mixed-core configurations with the co-resident design.
- **Conclusions**
 - The mechanical and structural design requirements are demonstrated to be met through mechanical testing and analyses.
 - All fuel rod and fuel assembly criteria are met.
 - Structural integrity is acceptable under seismic (OBE and SSE), and combined SSE+LOCA loading conditions.
 - The coolable geometry and control rod insertability requirements are satisfied.

Nuclear Design

- Core/Neutronics Design
 - The reload methodology unchanged from the current methodology used for St. Lucie-2 (ANC). AREVA PRISM code will be used for selected analyses.
 - BEACON core monitoring system will continue to be used.
 - FPL's ANC-based physics methodology will continue to be used with AREVA safety analysis codes – same as current St. Lucie-1 methodology.
 - AREVA PRISM code used for transition analyses.
 - Benchmarked to St. Lucie-2 Cycles 14-20.
 - showed acceptable results.
 - Developed representative transition cycle designs.
 - Generated power histories, axial shapes, and other safety inputs
 - Parameters similar to current designs and within the current cycle-to-cycle variations.

Thermal Hydraulic Design

- Mixed core evaluations
 - Pressure drop testing of HTP and co-resident fuel
 - Hydraulic Compatibility
 - Core Pressure Drop, RCS Loop Flow, and Bypass Flow
 - Calculated change in pressure drop and core flow due to transition.
 - Crossflow Velocities
 - Assured satisfactory mechanical performance during transition.
 - DNB Performance
 - Determined relative DNB performance during transition.
 - Guide Tube Heating
 - Verified no boiling.

Thermal Hydraulic Design (Contd.)

- Mixed core evaluations
 - Hydraulic Compatibility (contd.)
 - Control Rod Drop Time
 - Validated no change to Tech Spec drop time.
 - Hydrodynamic instability
 - Evaluated susceptibility to thermo-hydrodynamic instabilities.
- Setpoint analysis verified no changes to setpoints.
- Analysis met the acceptance criteria of EMF-92-116(P)-A.
- Results and Conclusions
 - Thermal-hydraulic compatibility between AREVA fuel and co-resident fuel was confirmed.
 - DNB and FCM analyses meet requirements.
 - Setpoint verifications maintain positive margin.

Accident and Transient Analyses

- Methodology used for St. Lucie Unit 2 transition work (LOCA and non-LOCA Safety Analyses) is the same as recently approved for St. Lucie Unit 1 EPU.
- **Non-LOCA Analyses**
 - EMF-2310 Revision 1 methodology as modified and approved for St. Lucie-1, applied to events affected by fuel design change
 - S-RELAP5 non-LOCA analyses provide boundary conditions for MDNBR and peak LHR calculations
 - S-RELAP5 calculates peak fuel centerline temperature for “fast” events

Accident and Transient Analyses (Contd.)

- **Non-LOCA Analyses (contd.)**
 - Analysis Codes Used
 - S-RELAP5
 - RODEX2
 - COPERNIC
 - X-COBRA-IIIC
 - PRISM
 - Disposition of events
 - Identified events not affected by fuel design change
 - Identified events affected by fuel design change but bounded by other analyses
 - Identified affected events for re-analysis with AREVA methodology

Accident and Transient Analyses (Contd.)

- Analysis of affected events
 - Analyzed for SAFDLs
 - Feedwater system malfunctions
 - Increase in steam flow
 - Pre-trip steamline break
 - Post-trip steamline break
 - Loss of condenser vacuum
 - Loss of forced reactor coolant flow
 - Reactor coolant pump shaft seizure
 - Uncontrolled CEA withdrawal
 - Dropped CEA
 - Inadvertent opening of a PORV
 - CEA Ejection (also analyzed for energy deposition)
 - CVCS malfunction (boron dilution) - analyzed for sub-criticality
 - Loss of coolant accidents

Accident and Transient Analyses (Contd.)

- Events unaffected by fuel design change
 - Loss of condenser vacuum (overpressurization)
 - Loss of AC Power (overpressurization)
 - Loss of normal feedwater
 - Feedwater system pipe break
 - Reactor coolant pump shaft seizure (overpressurization)
 - Uncontrolled CEA withdrawal (overpressurization)
 - CVCS malfunction (increase in RCS inventory)
 - Steam generator tube rupture
- Events bounded by other events
 - Inadvertent opening of a MSSV or ADV
 - Loss of AC power (SAFDL)

Accident and Transient Analyses (Contd.)

- **SBLOCA Analysis**
 - SBLOCA EMF-2328 Rev. 0 methodology with modifications (same method as approved for St. Lucie-1)
 - Conservative analysis inputs
 - peak LHR of 13 kW/ft
 - Fr of 1.65
 - SG tube plugging of 20%
 - S-RELAP5 break spectrum and SI line break analyses
 - PCT and Oxidation confirmed to meet limits
 - SI Line Break not limiting

Accident and Transient Analyses (Contd.)

- **RLBLOCA Analysis**
 - RLBLOCA EMF-2103 Rev. 0 methodology with Transition Package and changes (same method as approved for St. Lucie-1)
 - Conservative analysis inputs
 - peak LHR of 13 kW/ft
 - Fr of 1.65
 - SG tube plugging of 20%
 - S-RELAP5 best-estimate uncertainty analysis
 - Included LOOP and no-LOOP
 - PCT and Oxidation confirmed to meet limits

Impact on Other Analyses

- **Radiological Consequences Analysis**
 - No change in power level
 - No change to the applicable peaking limits
 - No change to plant systems
 - Accident analysis results within the fuel failure assumptions used in the dose analysis
 - UFSAR analyses continue to remain applicable

Impact on Other Analyses (Contd.)

- **Spent Fuel Pool Criticality Analysis**
 - Criticality analysis remains bounding
 - Power level remains unchanged.
 - No change in fuel parameters input to criticality analysis.
 - Spent fuel pool configuration and poison remain unchanged.
- **Post-LOCA Long Term Cooling**
 - Boron precipitation analysis unaffected by the fuel design change.
 - Post-LOCA criticality analyzed/evaluated every cycle based on cycle specific core design.

Contents of License Amendment Request

- **Proposed Technical Specifications Changes**
 - Description/Justification of changes
 - COLR/TS/Bases changes
 - Regulatory Analysis
 - Regulatory requirements/Criteria
 - No Significant Hazard Consideration Determination
 - Environmental Evaluation
- **Evaluation of TS and Fuel Design Changes**
 - Technical Report
 - Non-LOCA Summary Report
 - SBLOCA Summary Report
 - RLBLOCA Summary Report

Contents of License Amendment Request (Contd.)

- Other analysis
 - Radiological consequences analysis
 - Post-LOCA long-term cooling analysis
 - SFP criticality analysis
- **Technical Report**
 - Description of fuel design
 - Fuel mechanical design/analysis description
 - mixed core effects, including impact on co-resident fuel
 - Neutronics design / methodology
 - T&H analysis / fuel compatibility
 - Non-LOCA analysis results
 - SBLOCA analysis results
 - RLBLOCA analysis results

Contents of License Amendment Request (Contd.)

- **Non-LOCA summary report**
 - Details of non-LOCA analyses
- **SBLOCA summary report**
 - Details of SBLOCA analysis
- **RLBLOCA summary report**
 - Details of RLBLOCA analysis
- M5 Cladding 10 CFR 50.46 and 10 CFR 50 Appendix K Exemption Request (recently approved for St. Lucie Unit 1)

Summary

- **Summary**

- Improved fuel design
 - operating parameters unchanged
 - Benefits in fuel reliability – resistance to grid-to-rod fretting
- Analyses confirm that acceptance criteria using approved Topical Reports are met for all analyses.
- No change in FPL Neutronics methodology.
- Safety analysis methodology - previously approved and currently used for St. Lucie Unit 1.
- Lessons learned from recent AREVA fuel transitions and St. Lucie Unit 1 EPU incorporated in the transition work.
- M5 Exemption - previously approved by NRC for other licensees and St. Lucie Unit 1.

Schedule

<u>Key Milestones</u>	
Pre-Submittal Meeting	November 3, 2014
License Amendment Request, M5 Cladding Exemption Request	December 2014
Post-Submittal Meeting (as necessary)	TBD
SER request date	1Q 2016
Initial AREVA Fuel delivery	1Q 2017
Implementation	Cycle 23