

## NRR-PMDAPEm Resource

---

**From:** Thadani, Mohan  
**Sent:** Tuesday, October 28, 2014 4:37 PM  
**To:** Wanda D Craft (Generation - 6) (wanda.d.craft@dom.com)  
**Cc:** Huynh, Alan  
**Subject:** RE: MILLSTONE 3 - STEAM GENERATORS END OF CYCLE INSPECTIONS CALL (MF5037)

Wanda:

The NRC staff has requested that the license clarify what we discussed in the phone call. Please provide a breakdown of the indications for each degradation mechanism (e.g. TSP wear indications versus AVB wear indications) when the licensee is done with its inspections in SG "A":

- The number of indications found
- The number of new and old indications
- The maximum indication found for new versus old indications

Thank you for your support,

*Mohan E Thadani*

Senior Project Manager  
Millstone, Ginna, and Constellation Fleet Plants  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
(301) 415-1476 [Mohan.Thadani@nrc.gov](mailto:Mohan.Thadani@nrc.gov)

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 1671

**Mail Envelope Properties** (Mohan.Thadani@nrc.gov20141028163600)

**Subject:** RE: MILLSTONE 3 - STEAM GENERATORS END OF CYCLE INSPECTIONS  
CALL (MF5037)  
**Sent Date:** 10/28/2014 4:36:53 PM  
**Received Date:** 10/28/2014 4:36:00 PM  
**From:** Thadani, Mohan

**Created By:** Mohan.Thadani@nrc.gov

**Recipients:**

"Huynh, Alan" <Alan.Huynh@nrc.gov>

Tracking Status: None

"Wanda D Craft (Generation - 6) (wanda.d.craft@dom.com)" <wanda.d.craft@dom.com>

Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	788	10/28/2014 4:36:00 PM

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**