

NRR-PMDAPEm Resource

From: CLARK, ROBERT W [RCLARK@entergy.com]
Sent: Friday, October 31, 2014 4:15 PM
To: George, Andrea
Cc: JAMES, DALE E; PYLE, STEPHENIE L
Subject: Complete Signed Submittal
Attachments: 2CAN101403.PDF

Importance: High

Attached is the complete submittal as one and this version has the signature.

Hearing Identifier: NRR_PMDA
Email Number: 1675

Mail Envelope Properties (CF6D15BAF745124991C3CFB735BDD2C349E837A2)

Subject: Complete Signed Submittal
Sent Date: 10/31/2014 4:15:18 PM
Received Date: 10/31/2014 4:15:41 PM
From: CLARK, ROBERT W

Created By: RCLARK@entergy.com

Recipients:

"JAMES, DALE E" <DJAMES@entergy.com>
Tracking Status: None
"PYLE, STEPHENIE L" <SPYLE@entergy.com>
Tracking Status: None
"George, Andrea" <Andrea.George@nrc.gov>
Tracking Status: None

Post Office: JDCXMETSP002.etrsotherp.entergy.com

Files	Size	Date & Time
MESSAGE	79	10/31/2014 4:15:41 PM
2CAN101403.PDF	916369	

Options

Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:



Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel/479-858-4704

Stephenie L. Pyle
Manager, Regulatory Assurance
Arkansas Nuclear One

2CCAN101403

October 31, 2014

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Emergency Request Alternative to Utilize ASME Code Case N-513-4,
"Evaluation Criteria for Temporary Acceptance of Flaws in Moderate
Energy Class 2 or 3 Piping Section XI, Division 1"
Relief Request ANO2-ISI-017
Arkansas Nuclear One – Unit 2
Docket No. 50-368
License No. NPF-6

Dear Sir or Madam:

In accordance with 10 CFR 50.55a(a)(3)(ii), Entergy Operations, Inc. (Entergy) is requesting emergency NRC approval of a proposed alternative to the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI for Arkansas Nuclear One, Unit 2 (ANO-2). The alternative is for the current fourth 10-year inservice inspection interval. This interval began on March 26, 2010.

Specifically, Entergy is requesting to apply the evaluation methods of ASME endorsed Code Case N-513-4, "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping Section XI, Division 1," to Class 2 and 3 moderate energy piping including elbows, bent pipe, reducers, expanders, and branch tees. The NRC has not generically endorsed this Code Case.

This methodology is to be used to evaluate a through-wall flaw that was identified in a 6-inch branch connection from the Service Water (SW) supply header to the suction of the "B" Emergency Feedwater Pump. This line was determined to be inoperable and the unit entered a Technical Specification 72-hour allowable outage time (AOT) in accordance with Limited Condition of Operation (LCO) 3.7.3.1 on October 30, 2014, at 2118. Immediate repair or replacement of the pipe is not feasible during this LCO. Without approval of this relief, ANO-2 will be required to shutdown following expiration of the AOT and result in a hardship or unusual difficulty without a compensating increase in the level of quality and safety.

It has been determined that the root cause of the flaw is microbiological induced corrosion (MIC). The majority of leaks in ANO-2 SW piping in the past have been MIC-induced. The associated piping system continues to be capable of performing its required safety function and is not susceptible to sudden or catastrophic failure.

The attached request maintains the quality and safety considerations of structures, systems, and components required for safe operation of ANO-2.

Entergy requests the use of Code Case N-513-4 until a Section XI compliant repair / replacement can be completed prior to startup from the next refueling outage (fall of 2015) or exceeding the temporary acceptance criteria of Code Case N-513-4 and this relief request, whichever comes first.

Attachment 1 contains the request for alternative. The stress analysis is provided in Attachment 2 with the NDE Data Sheet provided in Attachment 3.

Entergy requests approval of this relief prior to the expiration of the LCO AOT which will end at 2118 on November 2, 2014.

Should you have any questions regarding this submittal, please contact me.

Sincerely,



SLP/rwc

Attachments:

1. Relief Request ANO2-ISI-017
2. Structural Integrity Associates Calculation 1401289.301
3. UT Thickness Examination - Report 2-BOP-UT-14-040

cc: Mr. Marc L. Dapas

Regional Administrator
U. S. Nuclear Regulatory Commission, Region IV
1600 East Lamar Boulevard
Arlington, TX 76011-4511

NRC Senior Resident Inspector
Arkansas Nuclear One
P. O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Ms. Andrea E. George
MS O-8B1
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

ATTACHMENT 1 TO

2CAN101403

RELIEF REQUEST ANO2-ISI-017

RELIEF REQUEST
ANO2-ISI-017

Component / Number: 2HCC-2003 (elbow) and 2HBC-33 (sweep-o-let)

Code Class: American Society of Mechanical Engineers (ASME Section III) Class 3

References: ASME Code, Section XI, 2001 Edition with the 2003 Addenda Code Case N-513-4

Description: Service Water (SW) to 2P-7B, Emergency Feed Water (EFW) Pump Suction

Unit / Inspection Interval Arkansas Nuclear One, Unit 2 (ANO-2) / Fourth (4th) 10-year

Applicability: interval, 2R24 Refueling Outage

I. CODE REQUIREMENTS

The applicable ASME Section XI Code Edition and Addenda for ANO-2 is the ASME Code, Section XI, 2001 Edition with the 2003 Addenda. Articles IWC-3120 and IWC-3130 require that flaws exceeding the defined acceptance criteria be corrected by repair / replacement activities or be evaluated and accepted by analytical evaluation. ASME Code, Section XI, IWD-3120(b) requires that components exceeding the acceptance standards of IWD-3400 be subject to supplemental examination, or to a repair / replacement activity:

II. PROPOSED ALTERNATIVE

Background

On October 20, 2014, Operations personnel identified leakage at the toe of the dissimilar weld between the stainless steel elbow and the carbon steel sweep-o-let on the SW piping to the suction of the "B" EFW pump. This leak is located in the Arkansas Nuclear One, Unit 2 (ANO-2) Auxiliary Building. The insulation around the subject line was wet; however, the leak rate at the time of discovery was 1 to 2 drops per hour. Upon buffing of the weld for enhanced ultrasonic testing (UT), the leak progressed to 12 drops per hour, or one drop every 5 minutes. The piping in question forms a branch connection, via a sweep-o-let, with the main SW header.

To evaluate the piping in the region of the leak, a detailed UT mapping was conducted immediately around the leak. This thickness mapping provided the means of characterizing the flaw at the leak location and verification that the flaw could be treated as a single flaw with respect to the proximity of other thinned regions. The UT report noted that the flaw could be characterized as a nonplanar flaw. The report from this mapping is provided in Attachment 3. Based on the results of the report, the remaining

pipings beyond the flaw is sufficient to maintain a pressure-retaining boundary and postulated leakage does not exceed operability margins. The nonplanar indication is the result of microbiological induced corrosion (MIC). Such corrosion indications are historically limited to localized areas on ANO-2 SW piping and piping components and do not manifest in general thinning, cracking, or other prompt structural failure precursors. This isolated corrosion area can be reliably monitored to ensure flow and structural integrity are maintained.

ASME Code Case N-513-3 is conditionally acceptable to the NRC (per Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1," Revision 17). It does not allow evaluation of flaws located away from attaching circumferential piping welds that are in elbows, bent pipe, reducers, expanders, and branch tees. ASME Code Case N-513-4 provides guidance for evaluation of flaws in these locations. This code case was recently endorsed by ASME on May 7, 2014. This code case has not been generically approved by the NRC.

SW System Description

Briefly, the SW system for ANO-2 consists of two independent full capacity 100 percent redundant loops. Each SW loop is capable of supplying cooling water to the required components during normal and emergency conditions. This redundancy allows continued plant operation when a single component failure occurs. System crossite valves provide additional redundancy by allowing one of the three SW pumps to be removed from service for maintenance. The remaining two pumps provide total system flow for both SW loops.

In the event of an emergency, the SW system can be the supply source for the EFW system (ANO-2 Technical Specification (TS) 3.7.1.3).

The design pressure for the ANO-2 SW system is 150 psig and the design temperature is 130°F.

ANO-2 TS 3.7.3 requires that two SW loops shall be operable and powered from independent essential buses to provide redundant and independent flow paths in Modes 1, 2, 3, and 4. ANO-2 TS 3.7.4 requires the Emergency Cooling Pond (ECP) to be operable in Modes 1, 2, 3, and 4. Two EFW pumps and associated flow paths are to remain operable in Modes 1, 2, and 3 (ANO-2 TS 3.7.1.2).

On October 30, 2014, at 2118, Loop 1 of SW and 2P-7B, Emergency Feedwater pump were declared inoperable and the appropriate Technical Specification actions entered. It was determined that conducting a code qualified repair during power operation is not feasible with the time clock of the TS. The inoperable loop is required to be restored within 72 hours or the unit must be placed in Hot Shutdown within 6 hours and Cold Shutdown within the following 30 hours per ANO-2 TS 3.7.3. Based on the insignificance of the flaw, it appears inappropriate to challenge the operation of the plant.

Due to the fact that the original flaw is MIC-induced, and ANO-2 has extensive experience with similar flaws in this system and it is well understood by ANO-2 staff, consideration of flaw growth is not a significant concern. Therefore, it has been

concluded that the overall condition and the continued operation of the associated SW loop until the next ANO-2 refueling outage is acceptable.

Proposed Alternative

The NRC issued Generic Letter 90-05, "Guidance for Performing Temporary Non-Code Repair of ASME Code Class 1, 2, and 3 Piping (Generic Letter 90-05)," to address the acceptability of limited degradation in moderate energy piping. The generic letter defines conditions that would be acceptable to utilize temporary non-code repairs with NRC approval. The ASME recognized that relatively small flaws could remain in service without risk to the structural integrity of a piping system and developed Code Case N-513. NRC approval of Code Case N-513 versions in Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1," allows acceptance of partial through-wall or through-wall leaks for an operating cycle provided all conditions of the Code Case and NRC conditions are met. The Code Case also requires the Owner to demonstrate system operability due to leakage and any implied / potential spray.

ASME recognized that the limitations in Code Case N-513-3 were preventing needed use in piping components such as elbows, bent pipe, reducers, expanders, and branch tees. Code Case N-513-4 was recently approved by the ASME to expand use on these locations and to revise several other areas of the Code Case. It should be noted that Code Case N-513-4 is not listed in the latest revision of Regulatory Guide 1.147 (Revision 17, August 2014).

Code Case N-513-4 utilizes technical evaluation approaches that are based on principals that are accepted in other Code documents already accepted by the NRC.

As required, ANO-2 will perform the augmented examinations as described in Section 5 of Code Case N-513-4.

III. **BASIS FOR ALTERNATIVE**

A structural evaluation, using Code Case N-513-4, was performed for the affected piping components. The basis for the evaluation includes Structural Integrity Associates (SIA) calculation number 1401289.301 (Attachment 2).

In addition to the structural evaluations discussed above, the proposed alternative was evaluated for:

- Flooding / Spray Concerns
- Reduction in flow to SW supplied components
- Emergency cooling pond inventory concerns

The results of these evaluations are presented below.

Flooding / Spray Concerns

The leakage at present is insignificant and does not present a flooding concern. No equipment susceptible to water damage is under or adjacent to the leakage site. The magnitude of the water loss can easily be accommodated by the room drainage system and does not pose a flooding concern. The leak is located in a well-lighted area (ANO-2 Auxiliary Building) that is frequented by Operations personnel on rounds. Thus if the leak rate experienced a rapid increase it would be quickly identified and addressed. A floor drain is located approximately 3 feet from the leak and is sized to remove normal leakage from this area of the plant. However, based on the structural assessment and engineering experience with respect to flaw growth, no significant leak rate increase is expected to occur.

Reduction in Flow to SW Supplied Components

Due to the small leak magnitude there is no appreciable impact on flow to other components in the ANO-2 SW System. The flow margin above that required for the minimum margin component is bounded, assuming all leakage in this condition were taken from that component, per the latest SW flow test.

ECP Inventory Concerns

The current leak is essentially imperceptible relative to ECP inventory and thus has no impact on ECP inventory.

IV. DURATION OF PROPOSED ALTERNATIVE

The proposed alternative is for use of Code Case N-513-4 in the evaluation of the flaw identified in ANO-2 SW piping components. A Section XI compliant repair / replacement can be completed prior to startup from the next refueling outage (fall of 2015) or exceeding the temporary acceptance criteria of Code Case N-513-4 and this relief request, whichever comes first.

V. PRECEDENT

By letter dated March 5, 2014 (ML 14073A059), as supplemented by letter dated March 25, 2014 (ML 14091A407), Entergy Nuclear Operations, requested authorization of a proposed alternative to certain requirements of the ASME Code, Section XI, Article IWD-3000 for the Pilgrim Station. Specifically, it was proposed to use alternate analytical evaluation criteria for acceptance of through-wall flaws. The alternate analytical evaluation criteria were based on the draft Code Case N-513-4. The NRC granted verbal authorization of the proposed alternative on March 26, 2014. The safety evaluation associated with the authorization was provided via letter dated September 30, 2014 (ML 14240A603).

ATTACHMENT 2 TO

2CAN101403

STRUCTURAL INTEGRITY ASSOCIATES CALCULATION 1401289.301



Structural Integrity Associates, Inc.®

File No.: 1401289.301

Project No.: 1401289

Quality Program: Nuclear Commercial

CALCULATION PACKAGE

PROJECT NAME:

ANO Leaking Flaw Evaluation

CONTRACT NO.:

10423246, Change Request No. 00109841

CLIENT:

Entergy Arkansas, Inc.

PLANT:

Arkansas Nuclear One, Unit 2

CALCULATION TITLE:

Evaluation of a Through-Wall Leak in a Service Water Tee (Dwg 2HCC-2003-1)




Document Revision	Affected Pages	Revision Description	Project Manager Approval Signature & Date	Preparer(s) & Checker(s) Signatures & Date
0	1 - 12	Initial Issue	 Eric J. Houston 10/31/2014	<p>Preparer:</p>  Adam C. Roukema 10/31/2014
			<p>Checker:</p>  Brad P. Dawson 10/31/2014	



Table of Contents

1.0	INTRODUCTION	3
2.0	TECHNICAL APPROACH	3
3.0	DESIGN INPUTS AND ASSUMPTIONS	3
4.0	CALCULATIONS.....	4
4.1	Minimum Required Wall Thickness.....	5
4.2	Applied Loads.....	5
4.2.1	<i>Hoop Stress</i>	5
4.2.2	<i>Axial Stresses</i>	5
4.3	Stress Intensity Factor Calculations.....	6
4.4	Critical Fracture Toughness Determination.....	7
5.0	RESULTS	8
6.0	CONCLUSIONS	8
7.0	REFERENCES	9

List of Tables

Table 1:	Applied Moment Loading for Bounding Moments.....	10
Table 2:	J _{IC} Values for A106 Gr. B Carbon Steel from NRC's Pipe Fracture Database [9]..	11
Table 3:	Axial and Circumferential Structural Factors [2].....	12
Table 4:	Load Combinations for Circumferential Flaw Analyses.....	12
Table 5:	Pressure Blowout Check.....	12

1.0 INTRODUCTION

Arkansas Nuclear One has identified a pinhole leak in a 6-inch branch connection (Sweep-o-let) in the service water system. The system is safety related, and therefore requires an evaluation to demonstrate operability. The objective of this calculation is to determine the allowable through-wall flaw lengths in accordance with ASME Code Case N-513-4 [1].

2.0 TECHNICAL APPROACH

The flaw evaluation herein is based on the criteria prescribed in ASME Code Case N-513-4, allowing for the temporary acceptance of through-wall flaws in moderate energy Class 2 or Class 3 piping. N-513-4 allows non-planar, through-wall flaws to be characterized and evaluated as planar (i.e., crack-like), through-wall flaws in the axial and circumferential directions.

In addition to straight pipe, N-513-4 evaluation criteria includes rules for the evaluation of piping components such as elbows, branch tees and reducers. Flaws in these components may be evaluated as if in straight pipe provided the stresses used in the evaluation are adjusted to account for geometric differences. Details are provided in N-513-4 for determining these adjusted stresses. The leaking flaw is in the carbon steel sweep-o-let, near the dissimilar metal weld at the adjoining stainless steel elbow. Therefore, the evaluation approach for branch connections in N-513-4 is appropriate. Although the attached elbow material has significantly higher toughness than the carbon steel (which if used would result in a much larger allowable through-wall flaw) the influence of the higher toughness on the allowable through-wall flaw is ignored and the system is evaluated as only carbon steel.

N-513-4 has been approved and published by ASME. It is recognized in ASME committee that the technical approach is very conservative. Simple treatment of piping component flaw evaluation using hand calculations was an important objective in the development of the approach recognizing the trade-off being conservative results. N-513-4 allows for alternative methods to calculate the stresses used in the analysis to reduce conservatism. N-513-4 has not been generically reviewed by the NRC.

Code Case N-513-4 evaluation criteria rely on the methods given in ASME Section XI, Appendix C [2]. Linear Elastic Fracture Mechanics (LEFM) criteria are conservatively employed as described in Article C-7000. Equations for through-wall stress intensity factor parameters F_m , F_b and F are given in the Code Case, Appendix I. Allowable flaw lengths are determined through iteration comparing calculated stress intensity factors to a critical fracture toughness defined in C-7200 of Section XI, Appendix C.

3.0 DESIGN INPUTS AND ASSUMPTIONS

The piping design Code of Construction is ASME Section III - 1971 with Addenda through Summer 1971 [3] except for the items listed below:

- A) Use ASME Section III – 1971 Winter 1972 Addenda, NC-3611.1(b)(4)(c) and NC-3650 with Code Case 1606-1, for the following:
 - a. Moments
 - b. Design Loading Combinations

- c. Section Modulus
- d. Stress Limits
- B) Use ASME Section III – 1974 [4], NC-3673.2 for the following:
 - a. Flexibility Factors
 - b. Stress Intensification Factors

The sweep-o-let material is ASME A105 Gr II carbon steel and the run piping is A106 Gr. B [5] carbon steel. For the analysis, A106 Gr. B carbon properties are conservatively used. In addition, the fracture toughness of the two materials are assumed to be comparable.

The following design inputs are used in this calculation:

1. Outside diameter = 6.625 inches [5, Line Item 14]
2. Nominal wall thickness = 0.280 inch (based on standard pipe size) [5, Line Item 14]
3. Design temperature = 130°F [6, Page 114]
4. Design pressure = 150 psig [6, Page 114]
5. Material stress allowable = 15 ksi [7, PDF Page 19]
6. Young's modulus = 27,900 ksi [7, PDF Page 19]
7. NDE inspection results [8]

The moment loadings applied to the piping are obtained from the piping stress report [7] for the element located between nodes 25 and 225. The bounding moments are shown in Table 1.

Determination of the fracture toughness, J_{IC} , used in the evaluation is based on Section XI, Appendix C, C-8320 [2], which specifies that 'reasonable lower bound fracture toughness data' may be used to determine the allowable stress intensity factor, K_{Ic} . The NRC's Pipe Fracture Encyclopedia [9] contains numerous CVN test results for A106 Gr. B carbon steel at low temperature, which are reproduced in Table 2. The minimum reported value of 293 in-lb/in² is used in the analysis.

The following assumptions are used in this calculation:

1. Poisson's ratio is assumed to be 0.3.
2. The impact of weld residual stress on the structural stability of the observed flaw is assumed negligible. Weld residual stresses are secondary (i.e., self-limiting) and do not contribute significantly to gross structural failure in ductile materials in the presence of a through-wall flaw. In addition, the contribution, if any, to flaw growth due to secondary weld residual stresses is not required as the Code Case specifies a frequent re-inspection interval.
3. A corrosion allowance is not considered (the ongoing inspection requirements in Code Case N-513-4 address the possibility of flaw growth during the temporary acceptance period).

4.0 CALCULATIONS

The applied stresses and resulting stress intensity factors are conservatively calculated using an evaluated wall thickness, t_{eval} , 0.175 inches.

4.1 Minimum Required Wall Thickness

An evaluation of ASME Section III, NC-3650 equations 3, 8, 9B, 9D, and 10 has been conducted using inputs discussed in Section 3.0. Based on these equations the minimum required wall thickness is 0.115 inch.

4.2 Applied Loads

Axial and circumferential (i.e., hoop) stresses are calculated from the moment loads in Table 1 and the design pressure. The evaluated wall thickness, t_{eval} , is used to determine the section properties. The nominal wall thickness, t_{nom} , is used to calculate the flexibility characteristic 'h' in accordance with the guidance of N-513-4.

4.2.1 Hoop Stress

For the allowable axial flaw length on a branch tee, the hoop stress, σ_h , may be determined from Equation 13 of N-513-4:

$$\sigma_h = \frac{pD_o}{2t} \quad (1)$$

where:

p = internal design pressure, psig

D_o = outside diameter, in

t = evaluated wall thickness = t_{eval} , in

4.2.2 Axial Stresses

For the allowable circumferential flaw length, the axial stress due to pressure, deadweight and seismic loading is presented below. For axial membrane stress due to pressure, σ_m , Equation 14 of N-513-4 is used. Note that there is a typo in the published version of this equation; the correct form is:

$$\sigma_m = B_1 \frac{pD_o}{2t} \quad (2)$$

B_1 is the primary stress index for pressure loading. As allowed by the Code Case, the primary stress indices B_1 and B_2 are taken from a more recent edition of the ASME Code [10, Table NB-3681(a)-1]. For branch connections, B_1 is 0.5.

For axial bending stress, σ_b , due to deadweight and seismic moments, Equation 15 of N-513-4 may be used:

$$\sigma_b = B_2 \frac{D_o M_b}{2I} \quad (3)$$

where:

M_b = resultant primary bending moment, in-lbs.

I = moment of inertia based on evaluated wall thickness, in⁴

The coefficient B_2 for branch connections is $0.5 * C_2$ (but not < 1.0) and [10, NB-3683.8]:

$$C_2 = 1.5 \left(\frac{R_m}{r_r} \right)^{2/3} \left(\frac{r'_{1m}}{R_m} \right)^{1/2} \left(\frac{r'_{1b}}{r_r} \right) \left(\frac{r'_{1m}}{r_p} \right) \quad (4)$$

where:

R_m = mean nominal radius of run pipe, in

r_r = nominal wall thickness of run pipe, in

r'_{1m} = mean nominal radius of branch pipe, in

r'_{1b} = nominal wall of branch pipe, in

r_p = outside nominal radius of branch pipe, in

For axial bending stress, σ_e , due to thermal expansion, Equation 16 of N-513-4 may be used:

$$\sigma_e = i \frac{D_o M_e}{2I} \quad (5)$$

where:

i = stress intensification factor

M_e = resultant thermal expansion moment, in-lbs.

The stress intensification factor is calculated based on a welding tee as [4, Figure NC-3673.2(b)-1]:

$$i = \frac{0.9}{h^{2/3}} \quad \text{and} \quad h = \frac{4.4 t_n}{r} \quad (6, 7)$$

where:

h = flexibility characteristic

t_n = nominal wall thickness of run piping, in

r = mean radius of run piping, in

4.3 Stress Intensification Factor Calculations

For LEFM analysis, the stress intensity factor, K_I , for an axial flaw is taken from Article C-7000 [2] as prescribed by N-513-4 and is given below:

$$K_I = K_{Im} + K_r$$

where:

$$K_{Im} = (SF_m) F_{\sigma h} (\pi a / Q)^{0.5}$$

SF_m = structural factor for membrane stress (see Table 3)

F = through-wall stress intensification factor parameter for an axial flaw under hoop stress (given in Appendix I of N-513-4)

σ_H = hoop stress, ksi
a = flaw depth (taken as half flaw length for through-wall flaw per Appendix I of N-513-4), in
Q = flaw shape parameter (unity per Appendix I of N-513-4)
 K_{Ir} = K_I from residual stresses at flaw location (assumed negligible)

Only the hoop stress influences the allowable axial flaw length, which is a function of pressure.

For LEFM analysis, the stress intensity factor, K_{Ic} , for a circumferential flaw is taken from Article C-7000 [2] as prescribed by N-513-4 and is given below:

$$K_I = K_{Im} + K_{Ib} + K_{Ir}$$

where:

$$K_{Im} = (SF_m)F_m\sigma_m(\pi a)^{0.5}$$

F_m = through-wall stress intensity factor parameter for a circumferential flaw under membrane stress (given in Appendix I of N-513-4)

σ_m = membrane stress, ksi

$$K_{Ib} = [(SF_b)\sigma_b + \sigma_e]F_b(\pi a)^{0.5}$$

SF_b = structural factor for bending stress (see Table 3)

σ_b = bending stress, ksi

σ_e = thermal stress, ksi

F_b = through-wall stress intensity factor parameter for a circumferential flaw under bending stress (given in Appendix I of N-513-4)

K_{Ir} = K_I from residual stresses at flaw location (assumed negligible)

Note that the through-wall flaw stress intensity factor parameters are a function of flaw length.

Table 4 shows the specific load combinations considered herein for the allowable circumferential flaw calculations.

4.4 Critical Fracture Toughness Determination

For LEFM analysis, the static fracture toughness for crack initiation under plane strain conditions, K_{Ic} , is taken from Article C-7000 [2] as prescribed by N-513-4 and is given below:

$$K_{Ic} = \sqrt{\frac{J_{Ic} E'}{1000}}$$

where:

J_{Ic} = material toughness, in-lb/in²

E' = $E/(1-\nu^2)$

E = Young's modulus, ksi

ν = Poisson's ratio

Based on the design input listed above, $K_{Ic} = 94.7 \text{ ksi-in}^{0.5}$. The allowable flaw lengths are determined iteratively by increasing flaw length until the stress intensity factor is equal to the static fracture toughness.

5.0 RESULTS

Based on inputs in Section 3.0, moments in Table 1 and using equations from Section 4.0, the allowable through-wall flaw in the circumferential direction is 2.7 inches and the allowable through-wall flaw in the axial direction is 5.8 inches. The allowable through-wall flaw lengths are based on an evaluated wall thickness of 0.175 inch. Based on the inspection data given in Reference [8], the analyzed thickness and flaw lengths easily bound the observed thinning. Thus, the acceptance criteria of Code Case N-513-4 are met.

Code Case N-513-4, Paragraph 3.2(c) requires that the remaining ligament average thickness over the degraded area be sufficient to resist pressure blowout [1, Equation 8]. Table 5 shows the required average thickness, $t_{c,avg}$, as a function of the equivalent diameter of the circular region, d_{adj} , for which the wall thickness is less than t_{adj} . Based on the inspection data given in Reference [8], the values in Table 5 easily bound the observed thinning. Thus, the Code Case requirement is met.

6.0 CONCLUSIONS

Arkansas Nuclear One has identified a pinhole leak in a 6-inch branch connection (Sweep-o-let) in the service water system. Allowable through-wall flaw lengths have been calculated in accordance with ASME Code Case N-513-4. Because N-513-4 has not been generically reviewed by the NRC, justification for continued operation without repair or replacement until the next scheduled outage requires NRC review and approval.

The allowable through-wall flaw in the circumferential and axial directions is 2.7 inches and 5.8 inches, respectively. The allowable through-wall flaw lengths are based on an evaluated wall thickness of 0.175 inch. Table 5 shows the requirements to meet the Code Case pressure blowout limits.

The observed pinhole leak is easily bounded by the results of the analysis; thus, the acceptance criteria of Code Case N-513-4 are met. The system should be considered operable but degraded.



7.0 REFERENCES

1. ASME Code Case N-513-4, "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping Section XI, Division 1," Cases of ASME Boiler and Pressure Vessel Code, May 7, 2014.
2. ASME Boiler and Pressure Vessel Code, Section XI, Appendix C, 2001 Edition with 2003 Addenda.
3. ASME Boiler and Pressure Vessel Code, Section III, 1971 Edition with Addenda through Summer 1971.
4. ASME Boiler and Pressure Vessel Code, Section III, 1974 Edition.
5. Entergy Drawing No. 2HBC-33-2, Sheet 1, Revision 16, "Large Pipe Isometric Service Water Supply Header #1," SI File No. 1401289.201.
6. Entergy Calculation No. 88-E-0200-15, Revision 3, "P-T Calculation for Unit 2 Service Water System," SI File No. 1401289.201.
7. Entergy Calculation No. 90-D-2003-08, Revision 3, "Supply Piping Analysis for Piping in DCP 90-2003," SI File No 1401289.201.
8. Entergy UT Thickness Examination Report No. 2-BOP-UT-14-040, SI File No. 1401289.201.
9. Pipe Fracture Encyclopedia, US Nuclear Regulatory Commission, Volume 1, 1997.
10. ASME Boiler and Pressure Vessel Code, Section III, 2004 Edition.

Table 1: Applied Moment Loading for Bounding Moments

Deadweight (in-lbs)	OBE (in-lbs)	DBE (in-lbs)	Thermal (in-lbs)
6902	21471	30657	5408

Notes:

1. Square Root Sum of the Squares (SRSS) is used to calculate moments from Reference [7].
2. Moments are from the bounding location, which is at node 225.

Table 2: J_{IC} Values for A106 Gr. B Carbon Steel from NRC's Pipe Fracture Database [9]

A106 Grade B							
Database Reference	Temperature (°C)	Temperature (°F)	J _{IC} (kJ/m ²)	J _{IC} (lb-in/in ²)	K _{IC} (ksi-in ^{3/2})		
2	24	75	97	552	133		
2	24	75	336	1919	249		
16	25	77	81	464	122		
16	25	77	418	2386	277		
16	25	77	270	1542	223		
16	25	77	193	1104	189		
22	24	75	224	1278	203		
22	20	68	112	641	144		
22	20	68	117	668	147		
22	23	73	214	1223	199		
22	20	68	167	954	175		
22	20	68	223	1271	202		
22	20	68	108	617	141		
23	52	126	116	663	146		
23	23	73	103	590	136		
23	23	73	105	600	139		
23	23	73	93	528	131		
24	23	73	76	431	118		
24	23	73	82	469	123		
24	57	135	51	293	97		
25	23	73	77	439	119		
25	23	73	70	400	114		
25	57	135	62	356	107		
90	20	68	235	1342	208		
90	20	68	219	1251	201		
90	20	68	255	1456	217		
90	20	68	281	1605	228		
90	20	68	281	1605	228		
90	20	68	335	1913	248		
90	20	68	421	2404	279		
90	20	68	385	2198	266		
90	20	68	175	999	160		
90	20	68	172	982	178		
90	20	68	178	1016	181		
90	20	68	214	1222	199		
90	20	68	275	1570	225		
90	20	68	133	759	157		
90	20	68	140	799	161		
90	20	68	174	994	179		
90	20	68	111	634	143		
90	20	68	190	1085	187		
90	20	68	71	405	114		
90	20	68	110	628	142		
90	20	68	104	594	138		
90	20	68	104	594	138		
90	20	68	97	554	134		
90	20	68	89	508	128		
90	20	68	88	502	127		
90	20	68	267	1525	222		



Table 3: Axial and Circumferential Structural Factors [2]

Service Level	Membrane Stress, SF _m	Bending Stress, SF _b
A	2.7	2.3
B	2.4	2.0
C	1.8	1.6
D	1.3	1.4

Table 4: Load Combinations for Circumferential Flaw Analyses

Load Combination	Service Level
P+DW+TH	A
P+DW+TH+OBE	B
P+DW+TH+DBE	D

Table 5: Pressure Blowout Check

d _{adj}	t _{avg}
0.25	0.01
0.75	0.03
1.25	0.04
1.75	0.06
2.25	0.08
2.75	0.10
3.25	0.11
3.75	0.13
4.25	0.15
4.75	0.17
5.25	0.19

ATTACHMENT 3 TO

2CAN101403

UT THICKNESS EXAMINATION

REPORT 2-BOP-UT-14-040



Entergy

Supplemental Report

Report No.: 2-BOP-UT-14-040

Page: 2 of 4


Summary No.: FW-1 2HCC-2003-1

Examiner:	<u>Taylor, Michael W.</u>	Level:	<u>II</u>	Reviewer:	<u>N/A</u>	Date:	_____
Examiner:	<u>N/A</u>	Level:	<u>N/A</u>	Site Review:	<u>Panther, Ken</u>	Date:	<u>10/22/2014</u>
Other:	<u>Jackson, Rickey</u>	Level:	<u>N/A</u>	ANII Review:	<u>N/A</u>	Date:	_____

Comments: The leak was located at the toe of weld on the Sweep-o-let side of weld. UT readings taken in a Star pattern around leak location to establish a wear area. Each row is incremented every 45° with each reading taken every .25" away from leak. This flaw is considered Non-Planar.

Sketch or Photo: Widenseis001MIDDEAL\liddleal_Ver 8\liddleal_Server\liddleal_ANO\Documents\ANO BOP 2014\MIC\2HCC Star.jpg

TDC





Entergy

Supplemental Report

Report No.: 2-BOP-UT-14-040

Summary No.: FW-1 2HCC-2003-1

Page: 3 of 4

Examiner: Taylor, Michael W. *MT* Level: II Reviewer: N/A Date: _____
 Examiner: N/A Level: N/A Site Review: Panther, Ken *KPanther* Date: 10/22/2014
 Other: Jackson, Rickey *RJ* Level: N/A ANII Review: N/A Date: _____

Comments: UT readings taken 360° around pipe at the plane of the leak for circumferential thicknesses. 01 reading was taken at TDC. Also scanned 100% circumferentially around pipe looking for other low readings and none were found. *02 reading is north of 01 reading. MT 10/22/14*

Sketch or Photo: \\\dcrs\sp001\NDEAL\liddleal_Ver 8\liddleal_Server\liddleal_ANOD\Documents\ANO BOP 2014\MIC\2HCC_Grd.jpg

	A	B	C
0	0.650	0.313	0.277
1	0.577	0.319	0.282
2	0.544	0.309	0.285
3	0.477	0.302	0.285
4	0.533	0.399	0.279
5	0.592	0.416	0.285
6	0.436	0.411	0.286
7	0.595	0.415	0.281
8	0.512	0.448	0.290
9	0.490	0.357	0.282
10	0.434	0.431	0.276
11	0.445	0.440	0.296
12	0.388	0.393	0.309
13	0.437	0.379	0.293
14	0.447	0.225	0.289
15	0.367	0.409	0.265
16	0.321	0.350	0.286
17	0.316	0.379	0.286
18	0.283	0.245	0.300
19	0.235	0.250	0.275
20	0.258	0.235	0.264
21	0.289	0.252	0.282
22	0.351	0.263	0.281
23	0.388	0.301	0.272
24	0.456	0.240	0.276
25	0.406	0.254	0.258
26	0.465	0.287	0.265
27	0.442	0.398	0.265
28	0.460	0.403	0.281
29	0.490	0.392	0.269
30	0.430	0.416	0.274
31	0.494	0.459	0.279

Supplemental Report

Report No.: 2-BOP-UT-14-040Page: 4 of 4Summary No.: FW-1 2HCC-2003-1Examiner: Taylor, Michael W. *MT*Level: IIReviewer: N/A

Date: _____

Examiner: N/ALevel: N/ASite Review: Panther, Ken *Panther*Date: 10/22/2014Other: Jackson, Rickey *RJ*Level: N/AANII Review: N/A

Date: _____

Comments: Pictures before and after grinding weld flat. Picture on left shows weld still painted with stain appearing on SS elbow. Picture on the right is after grinding weld flat showing the leak to be at the toe of the weld on the Sweep-o-let side. *LEAK IS IN LOWER South quadrant OF FW-1. *MT* 10/29/14*

Sketch or Photo: \\jdcnsetsp001\IDDEAL\Ideall Ver 8\Ideall_Server\Ideall_ANO\Documents\ANO BOP 2014\Photos\WO396448 U2 SW leak\IDSCF2747.JPG

\\jdcnsetsp001\IDDEAL\Ideall Ver 8\Ideall_Server\Ideall_ANO\Documents\ANO BOP 2014\Photos\WO396448 U2 SW leak\IDSCF2597.JPG

