

Indian Point Admin JPM Comments

SRO Admin 1a-

Add in 'The following plant conditions exist' prior to cue conditions
Edit applicant cue sheet to match front page cue sheet

SRO Admin 1b-

Discrepancies in calculated QPTR data on front page cue, page 6, and applicant cue sheet.
Appears correct number for erroneously calculated QPTR should be 1.0638 with a required power reduction <80.7%

SRO Admin 3-

Typo page 4, 'Fire Protection Systems'
Requires more detailed answer key for examiner, delineating each piece of equipment affected, required entry, and associated time clocks

SRO Admin 4-

Typo for procedure number on page 3, '2-SOP-%.1.5'

SRO Admin 5-

No comment