

Dominion Resources Services, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard, 2SE, Glen Allen, VA 23060



October 27, 2014

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No. 14-212A  
NL&OS/GDM: R0  
Docket No. 50-281  
License No. DPR-37

**VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)**  
**SURRY POWER STATION UNIT 2**  
**CORE OPERATING LIMITS REPORT**  
**SURRY 2 CYCLE 26 PATTERN EBA REVISION 0**  
**REQUEST FOR CLARIFICATION**

By letter dated April 23, 2014 (Serial No. 14-212), Dominion submitted the Core Operating Limits Report (COLR) for Surry Unit 2 Cycle 26, Pattern EBA, Revision 0, as required by Surry Technical Specification (TS) 6.2.C, "CORE OPERATING LIMITS REPORT." Subsequent to the submittal, the NRC requested clarification regarding the methodology used to determine TS 2.1. The specific NRC question and the Dominion response are provided below.

**NRC Question**

The COLR report provided contains a list of references. Each reference contains a list of technical specifications for which that methodology is used. TS 2.1, "Safety Limit, Reactor Core," is not listed under any of the references. Please clarify which methodology(ies) is (are) used to determine TS 2.1, "Safety Limit, Reactor Core."

**Response**

The Dominion methodology used to determine TS 2.1 is VEP-FRD-42, Rev. 2.1-A, "Reload Nuclear Design Methodology," dated August 2003. TS 2.1 was inadvertently omitted from the list of TS sections associated with this methodology reference in Section 2.1 of the COLR. TS 2.1 will be appropriately referenced in future Surry COLR submittals.

If you have any questions or require additional information, please contact Mr. Gary Miller at (804) 273-2771.

Sincerely,

T. R. Huber, Director  
Nuclear Licensing and Operations Support  
Dominion Resources Services, Inc. for  
Virginia Electric and Power Company

A001  
NRR

Commitment Summary: There are no new commitments contained in this letter.

cc: U.S. Nuclear Regulatory Commission  
Region II  
Marquis One Tower  
245 Peachtree Center Avenue, NE  
Suite 1200  
Atlanta, Georgia 30303-1257

Ms. K. Cotton-Gross  
NRC Project Manager - Surry  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

Dr. V. Sreenivas  
NRC Project Manager – North Anna  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

NRC Senior Resident Inspector  
Surry Power Station