

FORD 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306300126 DOC.DATE: 93/05/12 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH.NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards public version of rev 93-02, vol A to "Oconee Nuclear Site Emergency Plan" & rev 93-08, vol C to "Oconee Nuclear Site EPIP." W/930628 release memo.

DISTRIBUTION CODE: DF01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5+24
 TITLE: Direct Flow Distribution: 50 Docket (PDR Avail)

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL
INTERNAL:	NUDOCS-	ABSTRACT	1	1	<u>REG FILE</u>	01	1	1
EXTERNAL:	NRC	PDR	1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK. ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 4 ENCL 4

R
I
D
S
/
F
O
R
D
2
D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

May 12, 1993

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Emergency Plan
Volume A, Revision 93-02
Volume C, Revision 93-08

Please find attached for your use and review copies of the revisions to the Oconee Nuclear Station Emergency Plan:


Volume A	Revision 93-02	May 7, 1993
Volume C	Revision 93-08	May 7, 1993

These revisions are being submitted in accordance with 10 CFR 50-54(q) and do not decrease the effectiveness of the Emergency Plan or the Emergency Plan Implementing Procedures.

Please delete privacy material in the form of personal telephone numbers prior to placing in the Public Document Room.

By copy of this letter, two copies of this revision are being provided to the NRC, Region II, Atlanta, Georgia.

Very truly yours,


J. W. Hampton
VP, Oconee Nuclear Site

xc: (w/2 copies of attachments)
Mr. Stewart D. Ebnetter,
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

(w/o Attachments, Oconee Nuclear Station)
NRC Resident Inspector
C. C. Jennings, Manager, Emergency Planning

270000
9306300126 930512
PDR ADDCK 05000269
PDR

May 3, 1993

**MEMORANDUM TO FILE
OCONEE NUCLEAR SITE**

**SUBJECT: Revision 93-2, Volume A
Oconee Emergency Plan**

The following changes were made to Section D, Volume A, Oconee Nuclear Site Emergency Plan:

Record of Changes - Shows effective date of emergency plan revision 93-2.

SECTION A

Page A-4 - Added Memorandum of Understanding (Joint Information Center). Memorandum was in the plan but was not listed on this page with all other agreements.

SECTION B

Figure B-4 - Removed Technical Briefers from under the jurisdiction of the Engineering Manager. Technical briefers are civil engineers but in an emergency situation where the JIC is activated, these people will respond to the News Director. See News Group organization chart.

SECTION D -

Page D-27 - Number 10 - Site Area Emergency. Major Damage to Spent Fuel in Containment or Fuel Handling Building.

Fuel Handling Building

New radiation monitors have been installed at Oconee. It was not fully understood how the monitors would actually work for a very high radiological release. It was assumed that RIA 45 would go offscale high and RIA 46 would come on scale. After the simulator model was completed to duplicate the new Radiation monitors, it was determined that RIA 45 would drop to 0 when it went offscale high. The EALS are being revised to reflect this.

Reference to RIA 45 has been deleted from the emergency action level.

Page D-28 - Number 13 - Site Area Emergency. Accidental Release of Gases.

New radiation monitors have been installed at Oconee. It was not fully understood how the monitors would actually work for a very high radiological release. It was assumed that RIA 45 would go offscale high and RIA 46 would come on scale. After the simulator model was completed to duplicate the new Radiation monitors, it was determined that RIA 45 would drop to 0 when it went offscale high. The EALS are being revised to reflect this.

Reference to RIA 45 has been deleted from the emergency action level.

Page D-31 - Number 1. General Emergency. Accidental Release of Gases.

New radiation monitors have been installed at Oconee. It was not fully understood how the monitors would actually work for a very high radiological release. It was assumed that RIA 45 would go offscale high and RIA 46 would come on scale. After the simulator model was completed to duplicate the new Radiation monitors, it was determined that RIA 45 would drop to 0 when it went offscale high. The EALS are being revised to reflect this.

Reference to RIA 45 has been deleted from the emergency action level.

Page D-32 - Number 2. General Emergency. Loss of 2 of 3 Fission Product Barriers with a Potential Loss of 3rd Barrier.

A typographical error was made in the EAL and the basis portion of the condition. The correct hydrogen concentration is 9% and not 8%. See RP/0/B/1000/01, page 3 of 12.

APPENDIX 5 - New letters of agreement.

APPENDIX 6 - Pages 1, 4, 6

The above changes do not reflect a decrease in the effectiveness of the Oconee Emergency Plan.


Coleman C. Jennings
Manager, Emergency Planning

May 12, 1993

SUBJECT: Oconee Nuclear Site Emergency Plan
Volume A, Revision 93-02

Please make the following changes to the Emergency Plan, Volume A by following these directions:

REMOVE

Title Page, Rev. 93-01
Record of Changes, Page 3
Section A, Page A-4
Section B, Page B-10
Section D, Pages D 27-28
Section D, Pages D 31-32
Appendix 5, Letters of Agreement
for:
Oconee County Sheriff's Dept.
Pickens County Sheriff's Dept.
S. C. Highway Patrol
S. C. Law Enforcement Division
Oconee Memorial Hospital
Dr. Don Richardson
Dr. J. R. Pruitt
Dewitt Mize/Rural Fire Assoc.
Pickens County EP Agency
Oconee County EP Agency
Oconee County School District
Appendix 6, Pages 1,4,6

ADD

Title Page, Rev. 93-02
Record of Changes, Page 3
Section A, Page A-4
Section B, Page B-10
Section D, Pages D 27-28
Section D, Pages D 31-32
Appendix 5, Letters of Agreement
for:
Oconee County Sheriff's Dept.
Pickens County Sheriff's Dept.
S. C. Highway Patrol
S. C. Law Enforcement Division
Oconee Memorial Hospital
Dr. Don Richardson
Dr. J. R. Pruitt
Dewitt Mize/Rural Fire Assoc.
Pickens County EP Agency
Oconee County EP Agency
Oconee County School District
Appendix 6, Pages 1,4,6



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 28, 1993

Docket 50-269, 50-270, 50-287
Oconee Nuclear Station

MEMORANDUM FOR: Chief, Document Control Branch, IRM

FROM: Director, Division of Freedom of Information
and Publications Services, ADM

SUBJECT: REVIEW OF UTILITY EMERGENCY PLAN DOCUMENTATION

The Division of Freedom of Information and Publications Services has reviewed the attached document and has determined that it may now be made publicly available.

A handwritten signature in cursive script, reading "Donnie H. Grimsley" with a small mark to the right.

Donnie H. Grimsley, Director
Division of Freedom of Information
and Publications Services
Office of Administration

290052