



**Entergy**<sup>®</sup>

Entergy Operations, Inc.  
River Bend Station  
5485 U.S. Highway 61N  
St. Francisville, LA 70775  
Tel 225-381-4177

Joseph A. Clark  
Manager-Licensing

RBG-47656  
RBF1-16-0026

February 25, 2016

Mr. Greg Warnick  
U.S. Nuclear Regulatory Commission  
Region IV  
1600 E. Lamar Blvd.  
Arlington, TX 76011-4511

Reference: NRC letter to Entergy, dated February 16, 2016, NRC Inspection Report  
05000458/2015010; Preliminary White Finding

Subject: Response to Preliminary White Finding  
River Bend Station – Unit 1  
Docket No. 50-458  
License No. NPF-47

Dear Mr. Warnick:

As requested in NRC Special Inspection Report 05000458/2015010, this letter is to inform the NRC of our intentions regarding the Preliminary White Finding for failure to adequately assess the risk of operating the control building chilled water system (HVK) chillers in various single-failure vulnerable configurations. River Bend Station has chosen the option to attend a Regulatory Conference to present the station's perspective on the facts and assumptions used to arrive at the finding and assessment of its significance.

Should you have any questions regarding this matter, please contact me at (225) 381-4177.

Sincerely,

JAC/KRH

IED1  
NRR

Response to Preliminary White Finding  
RBG-47656  
Page 2 of 2

cc: U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

NRC Resident Inspector  
PO Box 1050  
St. Francisville, LA 70775

Ms. Tracie Lowrey  
Public Utility Commission of Texas  
1701 N. Congress Ave.  
Austin, TX 78711-3326

Mr. Stephen Koenick, Project Manager  
U.S. Nuclear Regulatory Commission  
MS 8 B1A  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852