

TVA

WALL THICKNESS
PROFILE SHEET

REPORT NO:

R-P0152

PROJECT: WBN


SYSTEM WELD NO: RCS

UNIT: 2

weld no: RCF-G1-4
DATE: 3-2-09

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	3.16	3.06	2.66	3.37
2	3.23	3.37	3.23	3.13
3	3.30	3.36	3.30	3.39
4	3.95	3.89	3.81	3.69
5	N/A	N/A	N/A	N/A




CROWN HEIGHT: Flush

DIAMETER: 31.0

CROWN WIDTH: 3"

WELD LENGTH: 119.5"



EXAMINER: Jose Alejandro [Signature]
LEVEL: II
DATE: 02-17-09

REVIEWED BY: [Signature]
LEVEL: III DATE: 2-24-09

ANII: [Signature]
DATE: 3/9/09
PAGE 4 OF 5

TVA
Office of Nuclear Power

PROJECT: WBN


SYSTEM: RCS

REPORT NO.:

UNIT: 2

WELD NO: RCF-G1-4

R. POISA



BY: Jose Alejandro Jose Alejandro LEVEL: JH DATE: 2-17-09 PAGE 5 OF 5