

TVA

**WALL THICKNESS
PROFILE SHEET**

REPORT NO:


R. P. Jones

PROJECT: WBN
UNIT: 2


WELD NO: RCF-D145-05
SYSTEM: RCS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

| Position | 0° | 90° | 180° | 270° |
|----------|------|------|------|------|
| 1 | .554 | .601 | .648 | .562 |
| 2 | .521 | .541 | .549 | .545 |
| 3 | .562 | .542 | .560 | .557 |
| 4 | .580 | .532 | .574 | .709 |
| 5 | .710 | * | .677 | * |



CROWN HEIGHT: FLUSH DIAMETER: 4.0
CROWN WIDTH: .75 WELD LENGTH: 14.5



** unable to take thickness reading due to expander configuration.*

EXAMINER: Jose Alejandro Jimenez
LEVEL: II
DATE: 03-05-09

REVIEWED BY: [Signature]
LEVEL: III DATE: 3-11-09

ANII: [Signature]
DATE: 3/16/09
PAGE 5 OF 10

TVA

Office of Nuclear Power

PROJECT: WBN SYSTEM: RCS

UNIT: 2 WELD NO: RCF-D145-05


REPORT NO.:

R-PO228

← FLOW →

Expander

Tee



Profile at 90° and 270°
Scan 3 limitations,
due to Tee geometry.

BY: Jose Alejandro Quevedo LEVEL: II DATE: 03-05-09 PAGE 6 OF 6

| | | |
|---|--|--|
| NPG Nondestructive Examination Procedure | CALCULATION OF ASME CODE COVERAGE FOR SECTION XI, APPENDIX VIII ULTRASONIC EXAMINATIONS | N-GP-31 Rev. 0002 Page 15 of 24 |
|---|--|--|


Attachment 3
(Page 1 of 1)

AUSTENITIC PIPING WELDS DUAL SIDE ACCESS - SUPPLEMENT 2

Required and obtained examination volume coverage work sheet

Below is a typical example of examination coverage plots although are not to be considered inclusive of all situations.

Typical example of a dual sided examination, generally the examination volume is the lower 1/3T of the weld metal and 1/4 inch of the adjacent base material.



Weld # RCF-D145-05 W=1.3 H=.2 L=14.5 ✓

| Item | Description | Value |
|------------------------------------|---|--------------|
| REQUIRED EXAMINATION VOLUME | | |
| 1 | Required examination volume in sq in. (width x height) for single scan stroke | .25 |
| 2 | Number of scan directions (normally 4; i.e. upst,dnst, cw, & ccw) | 4 |
| 3 | Total scan volume in sq inches (Item 1 * Item 2) | 1.04 |
| 4 | Total length of weld | 14.5 |
| 5 | Total required examination volume in cubic inches (Item 3 * Item 4) | 15.08 |
| OBTAINED EXAMINATION VOLUME | | |
| 6 | Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. upst) multiplied by the length of weld examined | 2.25 |
| 7 | Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. dnst) multiplied by the length of weld examined | 3.77 |
| 8 | Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. cw) multiplied by the length of weld examined | 3.77 |
| 9 | Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. ccw) multiplied by the length of weld examined | 3.77 |
| 10 | Determine the achieved examination volume by adding Items 6, 7, 8, and 9 | 13.56 |
| 11 | Examination volume percentage [(Item 10 / item 5) X 100] | (.899) = 90% |

JA

INFORMATION ONLY