#### NOTE:

The following slides were presented by representatives of Pacific Gas & Electric (PG&E) /Diablo Canyon Power Plant during a Regulatory Conference (a Category 1 Public Meeting) conducted in the NRC Region IV Office on November 15, 2016.

The purpose of the Regulatory Conference was to discuss an apparent violation related to inadequate procedures associated with the installation of external limit switches on motor operated valves as documented in NRC Inspection Report 05000275/2016010 and 05000323/2016010, issued on October 3, 2016.

Slide 19 of the presentation includes an embedded video file which is available to be viewed in this downloaded Adobe Acrobat PDF file. The video was presented at the Regulatory Conference to demonstrate the timeline and actions PG&E staff would have used to prepare and open a chamber in the auxiliary building in attempting to recover valve SI-8982 under certain accident conditions.

The events in the video were notional (i.e., were conducted as a drill) and the emergency events leading to the demonstrated actions did not actually occur at the Diablo Canyon Power Plant.

PUBLIC MEETING CONTACT:	Jeremy Groom, Chief
	Reactor Project Branch A, Division of Reactor Projects, Region IV
	Phone: (817) 200-1148

ML16335A439

# Diablo Canyon Power Plant NRC Regulatory Conference

# Limit Switch Finding Significance

November 15, 2016





### **Opening Remarks**



## Jim Welsch Vice President Nuclear Generation

### Introduction

### **PG&E Representatives**

### **Diablo Canyon Power Plant**

#### **Participants**

**PGS**F

- Jim Welsch Vice President Nuclear Generation
- Jan Nimick Senior Director Nuclear Services
- John Whetsler Operations Shift Manager
- Bob Waltos Assistant Director Engineering Services
- Nathan Barber Senior PRA Analyst



Торіс	Presenter
Preliminary Finding	Jan Nimick
ECCS Operational Overview	John Whetsler
Plant Design	Bob Waltos
Condition Description	Bob Waltos
ECCS Operation with the Condition	John Whetsler
Capability to Recover Local Manual Remote Electrical Interlock Jumper	John Whetsler John Whetsler Bob Waltos
SPAR Risk Significance	Nathan Barber
Summary and Conclusion	Jan Nimick



### Why are we here today?

Performance deficiency: Failure to provide instructions for limiting the travel of external limit switches installed on safety related motor operated valves.

#### Violation: of Technical Specification(TS) 5.4.1.a, "Procedures"

- Resulted in failure of an external closed limit switch for the Residual Heat Removal (RHR) Pump (PP) 2-2 Suction valve, RHR-2-8700B. This blocked control logic to open RHR PP 2-2 Containment Recirculation Sump Suction Valve SI-2-8982B.
- PG&E agrees with the performance deficiency
- PG&E has identified new information that results in a change to Core Damage Frequency when entered into the plant-specific SPAR Model.



### What will you be hearing from PG&E?

#### New Information not considered in the NRC's Significance Determination Program Evaluation




Three primary areas of new information affecting the safety significance:

- Contribution of medium break Loss of Coolant Accidents
- Operational strategies improving time to recover
- Robust and reliable recovery methods

### **Emergency Core Cooling System (ECCS) Operational Overview**

PG<mark>&</mark>E

### **ECCS Operation and Switchover to Recirculation**





### **Plant Design**

### RHR Pump Suction Valve from Containment Recirculation Sump (SI-8982)




- Located within the Recirc Chamber beneath the RHR Containment Sump
- Unobstructed access to valve via 36" manway opening
- Chamber is opened every refueling outage
- Valve is operated from the Control Room to initiate Cold Leg Recirculation




### Plant Design

### **RHR Pump 2-2 Suction Valve from the Refueling Water Storage Tank (RHR-2-8700B)**



- NEW
- Valve is located in an easily accessible uncontaminated area in the Auxiliary Building
  - External position switch performs an interlock function with SI-2-8982B



### **ECCS Operation with the Condition**

### **ECCS Operation and Switchover to Recirculation**

If BOTH Recirculation Sump Suction Valves (SI-2-8982A & B) fail to open, Operators transition to the "Loss of Emergency Coolant Recirculation," procedure and:

Initiate continuous actions to restore ECCS recirculation from the sump



Initiate makeup water to the RWST to add inventory




Minimize SIP/CCP injection to match the decay heat load and further preserve inventory



Depressurize the Steam Generators to cool down and depressurize the RCS

### **ECCS Operation with the Condition**

### **Condition Timeline (MAAP 3.5" LOCA)**




### **Plant Specific SPAR Model**

#### Medium LOCA (MLOCA) Modeling

- NRC analysis distributed the total MLOCA initiating event frequency linearly based on break size range.
- NUREG-1829 shows that the relationship between frequency and break size is logarithmic.

NEW


Use of NUREG-1829 data results in a break frequency for 3.5" to 6" of ~8E-06 per year, lower than the NRC estimate of ~1E-04.



### **ECCS Operation with the Condition**

### Frequency and Break Size Interpolation

PGSE



 Use of NUREG-1829 data results in a break frequency for 3.5" to 6" of ~8E-06 per year, lower than the NRC estimate of ~1E-04.

### **ECCS Operation with the Condition**

### Effect on $\Delta CDF$

PG<mark>&</mark>E

#### **LOCA Frequencies**

Initiator	Break Diameter Range	NRC IR Freq. (/yr)	NUREG-1829 Freq. (/yr)	% of total (NRC IR)	% of total (NUREG - 1829)
Small MLOCA	2"-3.5"	5.6E-05	1.28E-04	37.5%	94%
Large MLOCA	3.5"-6"	9.4E-05	8.09E-06	62.5%	6%

#### **Plant-Specific SPAR Model**

	Model Input	Decrease in ∆CDF	Internal ∆CDF
• NF	RC Baseline Internal △CDF		7.10E-06
EN ML	LOCA Modeling	2.17E-06	4.93E-06



### **Plant Specific SPAR Model**

#### **Common Cause Factor (CCF)**

 Current NRC SPAR model for DCPP uses alpha factors from the 2010 parameter update




- Updated alpha factors from 2013 are lower (alpha2 is 1.77E-02 vs. 1.92E-02)
- Replaced 2010 MOV alpha factors with 2013 values
- Reduction in CDF is most pronounced for large MLOCA

# ECCS Operation with the Condition

### Effect on ΔCDF

#### Plant Specific SPAR Model

	Model Input	Decrease in ∆CDF	Internal ∆CDF
	<ul> <li>NRC Baseline Internal CDF</li> </ul>		7.10E-06
EN	<ul> <li>MLOCA Modeling</li> </ul>	2.17E-06	4.93E-06
NUN	<ul> <li>CCF Alpha Factor Update</li> </ul>	1.08E-07	4.82E-06
NE.			



# The condition would be revealed during implementation of EOP's when transferring to cold leg recirculation

- The control room would contact the TSC to request assistance in opening valve SI-2-8982B
- Three independent recoveries would be available:
  - a) Manually open the SI-2-8982B valve using the handwheel
  - b) Electrically open the SI-2-8982B valve at the switchgear
- New c) Make-up the failed interlock on valve RHR-2-8700B using a jumper

### Local Manual Operation of the Recirculation Sump Suction Valve (SI-2-8982)

 8982 chamber is an uncongested area accessed every refueling outage.



EN

NEW

PG<mark>s</mark>e

- Expected post accident ambient temperatures would be ≈ 83 F.
- Operating experience substantiates that the chamber will not be contaminated or require a respirator.
- Chamber access instructions are readily available to personnel in the Operations Support Center.



Time to start of valve opening was 50 min from start of pre-job brief.



### Video - Opening SI-8982 Chamber



### Plant Specific SPAR Model

#### **Local Manual Recovery**

The Human Error Probability (HEP) for local manual recovery using SPAR-H was updated based on new information:





- Increase in time available for action. Time Available Extra
  - Time required for action reduced based on actual hatch operation timing test.



 Based on new information, ergonomics reassessed. No need for respirator or ladder, and the space is expansive.
 Ergonomics - Nominal

Operators are trained on manual operation of similar MOVs.
 Experience/Training – Nominal

A change in these PSFs results in a significant reduction in the human error probability for manual valve operation.



### Effect on $\Delta CDF$

### **Plant Specific SPAR Model**


Model Input	Decrease in ∆CDF	Internal ∆CDF
<ul> <li>NRC Baseline Internal CDF</li> </ul>		7.10E-06
<ul> <li>MLOCA Modeling</li> </ul>	2.17E-06	4.93E-06
<ul> <li>CCF Alpha Factor Update</li> </ul>	1.08E-07	4.82E-06
• Open 8982 Manually	4.28E-06	5.42E-07
<ul> <li>NEN</li> <li>CCF Alpha Factor Update</li> <li>NEN</li> <li>Open 8982 Manually</li> </ul>	4.28E-06	5.42E-07

#### **Opening 8982 MOV at Switchgear**

#### **Remote Electrical Operation**

PG<mark>&</mark>E

- Procedure OP O-22, training, and Task Performance Evaluation ensure operators are familiar with requirements to open or close MOVs by actuating the motor contactor at the 480V breaker.
- OP O-22 instructions ensure timely identification and correction of wrong contactor use.
- Motor curve predicts no damage from Locked Rotor Amps, up to 10 seconds



### **Plant Specific SPAR Model**

#### **Remote Electrical Recovery**

The HEP for remote electrical recovery was updated:

NEW

IEN

- Increase in time available for diagnosis. Time Available –
   Expansive
- A change in the action PSF for procedures is warranted based on the availability of procedures (OP O-22).
  - OP O-22 contains a diagram of a typical layout. Procedure – Available, but Poor




Diagram provided for 52-2G-24 (SI-2-8835). Layout is typical for most vital 480V MOVs

OP O-22 Diagram



### Effect on $\Delta CDF$

#### Plant Specific SPAR Model


	Model Input	Decrease in ∆CDF	Internal <b>ACDF</b>
	<ul> <li>NRC Baseline Internal CDF</li> </ul>		7.10E-06
	MLOCA Modeling	2.17E-06	4.93E-06
NEW	CCF Alpha Factor Update	1.08E-07	4.82E-06
NEW	<ul> <li>Open 8982 Manually</li> </ul>	4.28E-06	5.42E-07
NEW	<ul> <li>Open 8982 from Switchgear</li> </ul>	5.64E-08	4.86E-07
NE		· · · · · · · · · · · · · · · · · · ·	



PG<mark>s</mark>e

### Install Interlock Jumper on 8700B Actuator to allow Opening 8982B from the Control Room

- Maintenance Procedure would be used to jumper the position switch contacts on 8700B.
- Installation would be at the valve actuator, removing the actuator housing and jumpering across the switch contacts on the actuator rotors.



Unobstructed Access to RWST Suction Valve (8700B) and Actuator



### **Plant Specific SPAR Model**



#### Install Interlock Jumper on 8700 MOV and Open 8982 From the Control Room

- MP E-53.10A has instructions on jumpering 8982B interlocks including wire IDs. Procedure provides specific instructions for landing jumper.
   Procedure – Available but Poor
- Jumpers would be installed at 8700B valve is easily accessible.
   Ergonomics Nominal
- Electrical technicians are trained on how to install jumpers.
   Experience – Nominal
- Very low ambiguity in execution.
   Complexity Moderately Complex
- Action time available.
   Time Available Nominal



Typical MOV Limit Switch finger base with Jumper

### **Plant Specific SPAR Model**


Recovery of common cause valve SI-2-8982A failure to open

 Dominant scenarios include common cause failure of 8982A

PGSE

NEW

- A failure of 8982A due to the same procedure deficiency would allow the same recovery actions to be applied
- Given the large amount of time available for recovery, sufficient time is available to attempt recovery of A train following failure of B train actions.



### **Plant Specific SPAR Model**

#### **Calculation of Internal and External CDF**

PG&E used the current NRC SPAR model to assess  $\Delta \text{CDF}$  given the previously discussed new inputs

- Internal  $\triangle CDF = 4.86E-07$ .
- Reduction in Large MLOCA frequency reduces contribution from breaks >3.5".
- △CDF for Small LOCAs and Small MLOCAs (≤3.5") is reduced due to changes in SPAR-H PSFs.
- Additional recovery actions are appropriate given substantial increase in the time available.



External ∆CDF values were calculated by applying the updated recovery actions to the ∆CDF from the inspection report. After crediting recovery, external ∆CDF was reduced to 4.56E-08.



### Effect on $\Delta CDF$

**Plant Specific SPAR Model** 



Model Input	NRC ∆CDF	PG&E ∆CDF
Total Internal ∆CDF	7.10E-06	4.86E-07
Total External ∆CDF	5.40E-07	4.56E-08
Total ∆CDF	7.64E-06	5.32E-07

### **SPAR Risk Significance**

#### Plant Specific SPAR Model PRA Conservative Inputs NOT Modeled



- LOCA must be >4.5" to actuate containment spray. No recovery from breaks >3.5" and <4.5" was credited.</li>
- Recovery time for all SLOCAs used the shorter 3.5" LOCA time. No credit for very long recovery times provided by small LOCAs.
- Recovery of Train A recirculation sump suction valve common cause failure was not credited.
- Credible procedural operator actions in timeline not taken:
  - Refilling RWST from Liquid Holdup Tanks
  - Normal charging from the Volume Control Tank and Boric Acid Blender makeup after RWST reaches 4% level.
  - Action to refill the Spent Fuel Pool.

The inputs listed above are currently being evaluated to determine their significance.

Note that different combinations of input values may change their individual contribution to Core Damage Frequency which would warrant inclusion of the above inputs into the final assessment and require further analysis.



### **SPAR Risk Significance**

### Effect on $\Delta CDF$

#### **Plant Specific SPAR Model Sensitivities**

#### **MLOCA Frequency Sensitivities**

Sensitivity	Large MLOCA ∆ CDF
Use of 4.5" LOCA category from NUREG-1829. Large MLOCA = 2.88E-06 /Small MLOCA = 1.34E-04	1.20E-07
Use of 3" LOCA category from NUREG-1829. Large MLOCA = 1.36E-05 /Small MLOCA = 1.23E-04	6.67E-07

#### **Recovery Action Sensitivities**

Sensitivity	Internal ∆ CDF
Electrical and Manual Recovery (1.30E-03)	4.86E-07
Jumper and Electrical Recovery (2.12E-02)	8.50E-07
Manual with Poor Ergonomics plus Electrical (1.82E-03)	4.95E-07
Manual with Poor Ergonomics (1.29E-02)	6.97E-07

### **Summary and Conclusions**

### **SUMMARY**

PG<mark>s</mark>e

- The preliminary significance documented in IR 2016-010 is a conservative and bounding assessment of condition significance.
- The new information presented by PG&E today, using the NRC's SPAR model, provides a robust revision of the assessment of condition significance.

### CONCLUSION

A robust revision of the assessment of this condition demonstrates a total ΔCDF of 5.32E-07/yr.





### **Closing Remarks**



# Jim Welsch Vice President Nuclear Generation