



FIRE AREA KEY PLAN  
 Hatched area = BUFFER ZONE

C  
 (SEE DUG. E-200767)

B  
 (SEE DUG. E-200766)

A  
 (SEE DUG. E-200765)

D  
 (SEE DUG. E-200768)

NOTES  
 1) PROTECTED SAFE SHUTDOWN PATH (I.E. DIVISION II) IS DEFINED AS THOSE SAFE SHUTDOWN CABLES AND COMPONENTS WHICH MUST BE PROTECTED FROM FIRE DAMAGE WITHIN THE DESIGNATED FIRE ZONE. WHERE BOTH DIVISIONS ARE SHOWN, BOTH DIVISIONS MUST BE PROTECTED.

DEVIATION REQUEST NO. 14  
 FIRE ZONES WITHOUT FIRE DETECTION

FLOOR PLAN @ EL. 799'-1"

**LEGEND**

- FIRE ZONES
- DIVISION I PROTECTED SAFE SHUTDOWN PATH
- DIVISION II PROTECTED SAFE SHUTDOWN PATH
- 3 HR. FIRE-RATED WALLS
- FIRE DOOR NUMBER
- FIRE ZONE BOUNDARY
- FIRE DAMPER
- FIRE RATING
- 1 1/2 = 1 1/2 HR. RATING
- 3 = 3 HR. RATING
- 3P = 3 HR. RATING PNEUMATIC OPER. TYPE.

R-1B	E-184302, SHT. 6				
C-1858	E-105004, SHT. 6				
C-1739	E-213488				
C-1738	E-205968				
C-1737	E-205967				
C-1736	E-205966				
RE DRAWING NO.	PPAL DRAWING NO.				
REFERENCE DRAWINGS					
3	ADDED SECTION G-G	REV. DATE	BY	CHK	DATE
2	ADDED FIRE AREAS	REV. DATE	BY	CHK	DATE
1	PER ENGINEERING INFO.	REV. DATE	BY	CHK	DATE
0	INITIAL ISSUE	REV. DATE	BY	CHK	DATE
REV.	DESCRIPTION	DR. CH.	APPROVED DATE		
NON-QUALITY RELATED					
SUSQUEHANNA S.E.S.					
UNIT 1					
REACTOR BUILDING					
FIRE ZONE PLAN OF					
ELEVATION 799'-1"					
AREA 25-27, 28, 29 ELEV. 799'-1" SCALE 1/8"=1'-0"					
PENNSYLVANIA POWER & LIGHT COMPANY					
PPAL DRAWING NO.	SHEET NO.	REV. NO.			
E-205955	1	3			
RE DRAWING NO.	SHEET NO.				
C-1726	1				
SAVED AS A/D DRAWING NAME ST003					

30X I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE NORMAL AND REGULAR COURSE OF BUSINESS, ON THE DATE STATED BELOW, AND THAT IT IS AN ACCURATE REPRODUCTION OF THE DOCUMENT SUBMITTED TO SRS FOR CORRESPONDENCE AND DRAWING FILES.  
 DATE: 10/22/88

SI APERTURE CARD

8812200302