



FIRE AREA KEY PLAN  
 ■ BUFFER ZONE

NOTES  
 1) PROTECTED SAFE SHUTDOWN PATH (I.E. DIVISION) IS DEFINED AS THOSE SAFE SHUTDOWN CABLES AND COMPONENTS WHICH MUST BE PROTECTED FROM FIRE DAMAGE WITHIN THE DESIGNATED FIRE ZONE. WHERE BOTH DIVISIONS ARE SHOWN, BOTH DIVISIONS MUST BE PROTECTED.

DEVIATION REQUEST NO. 14  
 FIRE ZONES WITHOUT FIRE DETECTION

FLOOR PLAN @ EL. 779'-1"

LEGEND	
	FIRE ZONES
	DIVISION I PROTECTED SAFE SHUTDOWN PATH
	DIVISION II PROTECTED SAFE SHUTDOWN PATH
	3 HR. FIRE-RATED WALLS
	1 1/2 HR. FIRE-RATED WALLS
	FIRE-RATED FLOORS
	FIRE ZONE BOUNDARY
	FIRE DOOR NUMBER
	INSERTED CONTAINMENT BOUNDARY
	FIRE DAMPER
	FIRE RATING
	FIRE RATING 1 1/2 = 1 1/2 HR. RATING 3 = 3 HR. RATING 3P = 3 HR. RATING PNEUMATIC OPER. TYPE.

REV.	DESCRIPTION	REV. NO.	DATE	APPROVED
4	ADDED SECTION H-H	BOB	12/28/88	JAS
3	INCRP. DCN 11 (87-4684) & ADDED FIRE AREAS.	BOB	08/28/88	JAS
2	PER ENGINEERING INFO. AND DCN 87-0744.	BOB	08/28/88	JAS
1	PER ENGINEERING INFO. AND DCN 87-0744.	BOB	08/28/88	JAS
0	INITIAL ISSUE	BOB	08/28/88	JAS

NON-QUALITY RELATED

AREA 20, 32, 33, 34	ELEV. 779'-1"	SCALE 1/8"=1'-0"
PPAL DRAWING NO.	E-205962	SHEET NO. 1
REV. DRAWING NO.	C-1733	SHEET NO. 1
REV. NO.		4

30X I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE NORMAL AND REGULAR COURSE OF BUSINESS, ON THE DATE STATED BELOW, AND THAT IT IS AN ACCURATE REPRODUCTION OF THE DOCUMENT SUBMITTED TO THIS CORRESPONDENCE AND DRAWING FILES.  
 DATE: 12/28/88  
 BY: [Signature]  
 FOR: [Signature]

SI APERTURE CARD

8812200368