



FLOOR PLAN @ EL. 818'-1"

NOTES  
 1) PROTECTED SAFE SHUTDOWN PATH (I.E. DIVISION) IS DEFINED AS THOSE SAFE SHUTDOWN CABLES AND COMPONENTS WHICH MUST BE PROTECTED FROM FIRE DAMAGE WITHIN THE DESIGNATED FIRE ZONE. WHERE BOTH DIVISIONS ARE SHOWN, BOTH DIVISIONS MUST BE PROTECTED.

DEVIATION REQUEST NO. 14  
 FIRE ZONES WITHOUT FIRE DETECTION

A-17	E-184302, SHT. 7
C-1739	E-105004, SHT. 7
C-1738	E-205968
C-1737	E-205967
C-1736	E-205966
C-1735	E-205965
AE DRAWING NO.	REF. DRAWING NO.

**LEGEND**

- FIRE ZONE BOUNDARY
- FIRE RATED WALLS
- FIRE DOOR NUMBER
- DIVISION I PROTECTED SAFE SHUTDOWN PATH
- DIVISION II PROTECTED SAFE SHUTDOWN PATH
- FIRE ZONES

SUSQUEHANNA S.E.S.	
UNIT 2	
REACTOR BUILDING	
FIRE ZONE PLAN OF	
ELEVATION 818'-1"	
AREA NO. 30.3	ELEV. 818'-1" SCALE 1/8" = 1'-0"
PENNSYLVANIA POWER & LIGHT COMPANY	ALLENTOWN PA.
PROJECT NO. E-205964	SHEET NO. 1
REVISION NO. C-1735	SHEET NO. 1

30X I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE NORMAL AND REGULAR COURSE OF BUSINESS ON THE DATE STATED BELOW AND THAT IT IS AN ACCURATE REPRODUCTION OF THE DOCUMENT SUBMITTED TO SEMS CORRESPONDENCE AND DRAWING FILES  
 DATE: 8/21/88

SI APERTURE CARD 8812200371 D