

JPM TITLE:	Review a RCS Leak	Rate Determination		
JPM NUMBER:	PBN JPM P119.2236	.SRO	REV. 0	
TASK NUMBER(S) / TASK TITLE(S):	PBN P119.223.SRO	/ Review completed	procedures	
K/A NUMBERS:	2.1.7	K/A VALUE: 4	.4 / 4.7	
Justification (FOR K/A	VALUES <3.0):			
TASK APPLICABILITY	: "A 🗌 Non-Lic 🗌 SF		R:	
APPLICABLE METHO	O OF TESTING: Sin	nulate/Walkthrough:	Perform:	\boxtimes
EVALUATION LOCATION	DN: In-Plant: [Contro	I Room:	
	Simulator: [Other:	\boxtimes	
	Lab: [
Time for Completion	: <u>15</u> Minut	es Time Critical:	🗌 Yes 🛛 No	
Alternate Path [NRC]: 🗌 Yes 🖂 No			
Alternate Path [INPC	0]: 🗌 Yes 🖂 No			
Developed by:	Instructor	/Developer		Date
Reviewed by:		Developer		Date
Kevieweu by.		uctional Review)		Date
Validated by:		nical Review)		Date
Approved by:	Training	Supervision		Date
Approved by:	-	-		Luie
	Training Pr	ogram Owner		Date



JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED PRIOR TO USE.

REV	IEW STATEMENTS	YES	NO	N/A
1.	Are all items on the signature page filled in correctly?	\boxtimes		
2.	Has the JPM been reviewed and validated by SMEs?	\boxtimes		
3.	Can the required conditions for the JPM be appropriately established in the simulator if required?			\boxtimes
4.	Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	\boxtimes		
5.	Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	\boxtimes		
6.	Has the completion time been established based on validation data or incumbent experience?	\boxtimes		
7.	If the task is time critical, is the time critical portion based upon actual task performance requirements?			\boxtimes
8.	Is the job level appropriate for the task being evaluated if required?	\boxtimes		
9.	Is the K/A appropriate to the task and to the licensee level if required?	\boxtimes		
10.	Is justification provided for tasks with K/A values less than 3.0?			\square
11.	Have the performance steps been identified and classified (Critical / Sequence / Time Critical) appropriately?	\boxtimes		
12.	Have all special tools and equipment needed to perform the task been identified and made available to the trainee?	\boxtimes		
13.	Are all references identified, current, accurate, and available to the trainee?	\square		
14.	Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	\boxtimes		
15.	Are all critical steps supported by procedural guidance? (e.g., if licensing, EP or other groups were needed to determine correct actions, then the answer should be NO.)	\boxtimes		
16.	If the JPM is to be administered to an LOIT student, has the required knowledge been taught to the individual prior to administering the JPM? TPE does not have to be completed, but the JPM evaluation may not be valid if they have not been taught the required knowledge.	\boxtimes		

All questions/statements must be answered "YES" or "N/A" or the JPM is not valid for use. If all questions/statements are answered "YES" or "N/A," then the JPM is considered valid and can be performed as written. The individual(s) performing the initial validation shall sign and date the cover sheet.

Protected Content: (CAPRs, corrective actions, licensing commitments, etc. associated with this material)

 $\{C001\}$



UPDATE LOG: Indicate in the following table any minor changes or major revisions (as defined in TR-AA-230-1003) made to the material after initial approval. Or use separate Update Log form TR-AA-230-1003-F16.					
#	DESCRIPTION OF CHANGE	REASON FOR CHANGE	AR/TWR#	PREPARER	DATE
#	DESCRIPTION OF CHANGE	REASON FOR CHANGE		REVIEWER	DATE
Rev. 0	Rev. 0 Developed for the 2017 NRC ILT Exam.				



SIMULATOR SET-UP: (Only required for simulator JPMs)

Simulator Setup Instructions:

1. 2.

SIMULATOR MALFUNCTIONS:

SIMULATOR OVERRIDES:

SIMULATOR REMOTE FUNCTIONS:

Required Materials:	 OI-55, Primary Leak Rate Calculation (Procedure marked up as completed through step 5.5.8 and Attachment A completed through step 5.0)
	2. Calculator
General References:	1. OI-55, Primary Leak Rate Calculation
	2. Technical Specifications
Task Standards:	Review and identify errors associated with OI 55 Primary Leak Rate
	Calculation and determine TSAC impact per OI-55.



I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- You are OS2.
- Unit 1 is operating at stable full reactor power with indications of a primary leak.
- The Letdown Gas Stripper (LDGS) is bypassed per OI 17, Letdown Gas Stripper Operation.
- AOP-1A Unit 1 Reactor Coolant Leak was entered and is currently in progress.
- The PAB AO has reported the following Charging Pumps seal leak rates:
 - 1P-2A = 20 cc/min
 - 1P-2B = 15 cc/min
 - 1P-2C = 25 cc/min
- Steam Generator Tube Leakage (SGTL) LR_{SGTL} = 0
- Reactor Component Leak Rate $LR_{RC} = 0$
- Non RCPB Leakage $LR_{P3} = 0$
 - The following plant parameters were observed at time 0400:
 - RCS Tavg 575.6 °F
 - RCS T(Terr) 0 °F
 - PZR Level 46.0 %
 - VCT Level 45.0 %
 - U1 PRT level 74.7%
 - U1 RCDT Level 52 %
 - The following plant parameters were observed at time 0420:
 - RCS Tavg 575.6 °F
 - RCS T(Terr) 0 °F
 - PZR Level 45.7%
 - VCT Level 43.8 %
 - U1 PRT level 74.7%
 - U1 RCDT Level 52.5 %
- No borations, dilutions or diverts to HUT took place.
- There is no Chemistry sampling in progress.
- C04 has completed OI 55 through Attachment A, Primary Leak Rate Worksheet, up to Step 6.0 and has presented it to you for your review.

INITIATING CUES (IF APPLICABLE):

- Review the Primary Leak Rate Worksheet
- Complete remaining steps of OI 55, Primary Leak Rate Calculation, starting at Step 5.6.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM PERFORMANCE INFORMATION

Start Time:

NOTE: When providing "Evaluator Cues" to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee's actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

NOTE: Critical steps are marked with a "Y" below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM.

Performance Step: 1 Critical N	Attachment A 2.0 RECORD the following data: RCS LEAK RATE DATA
Standard:	 The examinee checks data accurately entered from the initial conditions and calculates the results. Time change 20 minutes RC T_{error} (Terr) change is 0°F PZR Level change is 0.3 % = 19.47 gal. VCT Level change is 1.2 % = 15.168 gal.
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 2 Critical N	Attachment A 2.0 RECORD the following data: RMW AND BA ADDITIONS
Standard:	The examinee verifies that this step does not apply
Evaluator Note:	Per the initial conditions, no RMW or acid additions occurred.
Performance: Comments:	SATISFACTORY UNSATISFACTORY



Performance Step: 3 Critical N	Attachment A 2.0 RECORD the following data: DIVERT
Standard:	The examinee verifies that this step does not apply
Evaluator Note:	Per the initial conditions, no diverts occurred.
Performance: Comments:	SATISFACTORY UNSATISFACTORY

Performance Step: 4 Critical Y	Attachment A 3.0 Calculate RCS leak rate: CALCUALTED RCS LEAK RATE
Standard:	The examinee calculates RCS leak rate of 1.732 gpm (1.725 to 1.735 gpm) and determines that recorded RCS leak rate is in error.
Evaluator Note:	First error Time change of 30 min vice 20 min was used to calculate LR _{RCS} .
Performance: Comments:	SATISFACTORY UNSATISFACTORY



Performance Step: 5 Critical N	Attachment A 4.0 CALCULATE_RCS Unidentified Leak Rate as follows: 4.1 CALCULATE Identified RCS Leak Rate: IDENTIFIED RCS LEAK RATE DATA	
Standard:	 The examinee checks data accurately entered from the initial conditions and calculates the results. Time change 20 minutes PRT Level change 0 gpm The examinee calculates RCDT Level change of 0.088 gpm. SG Tube Leakage (LR_{SGTL}) 0 gpm Reactor Component Leak Rate (LR_{RC}) 0 gpm 	
Performance:	SATISFACTORY UNSATISFACTORY	
Comments:		

Performance Step: 6 Critical Y	Attachment A 4.0 CALCULATE_RCS Unidentified Leak Rate as follows: 4.2 CALCULATE Non Reactor Coolant Pressure Boundary : Non Reactor Coolant Pressure Boundary
Standard:	 The examinee calculates Charging Pump Seals (LR_{P2}) of 0.016 gpm and determines the recorded value is in error. Non RCPB Leakage (LR_{P3}) 0 gpm
Evaluator Note:	Second error Charging pump seal leakage was miscalculated by a factor of 10.
Performance: Comments:	SATISFACTORY UNSATISFACTORY



Performance Step: 7 Critical Y	Attachment A 4.0 CALCULATE RCS Unidentified Leak Rate as follows: 4.3 CALCULATE RCS Unidentified leakage: UNIDENTIFIED RCS LEAK RATE
Standard:	Based on corrected values, the examinee recalculates Unidentified Leak Rate (LR_{UD}) to be 1.628 gpm (1.625 to 1.635 gpm) rather than the original value of 0.909 gpm. (errors carried forward)
Performance: Comments:	SATISFACTORY UNSATISFACTORY

Performance Step: 8 Critical N	5.6 <u>IF</u> the Unit is in Mode 5, <u>THEN</u> perform Attachment B, Cold Shutdown Primary Leak Rate Worksheet as follows:
Standard:	The examinee verifies that this step is not applicable.
Performance: Comments:	SATISFACTORY UNSATISFACTORY

Performance Step: 9 Critical N	 5.7 IF the plant is in Mode 1 through 4, <u>AND</u> Pressure Boundary leakage is detected, <u>THEN</u> ENTER Technical Specification LCO 3.4.13 Action Condition B.
Standard:	The examinee verifies that the action condition entry is not required at this time.
Evaluator Cue:	Relief crew is preparing for a containment entry to inspect for pressure boundary leakage.
Performance: Comments:	SATISFACTORY UNSATISFACTORY
Comments.	



Performance Step: 10 Critical N	 5.8 IF RCS Unidentified Leakage shows a significantly increasing trend, <u>OR</u> reaches 0.15 gpm, <u>THEN</u> PERFORM the following actions: 5.8.1 INFORM the Shift Manager and Duty Station Manager. 5.8.2 CHECK the following at least once per hour: a. Containment particulate monitor (RE 211) high and low values. b. Containment radiogas monitor (RE 212) high and low values. c. Containment humidity. 5.8.3 PERFORM the RCS leakrate calculation of Section 5.5 or 5.6 as applicable at least once per shift. 5.8.4 OBTAIN a sump A sample and have Chemistry analyze to aid in determining the source of leakage. 5.8.5 DIRECT Chemistry to sample and analyze Containment atmosphere for hydrogen content and REPORT the results to the SM. 5.8.6 NOTIFY Engineering to review Containment Air Cooler performance and cleaning frequencies to determine if an adverse long term trend exists. 5.8.7 IF a containment inspection is warranted to localize the source of leakage, <u>THEN</u> the inspection should consist of the following: a. Evidence of steam in containment. b. Wetness on the floor. c. Boric Acid deposits. d. Abnormal packing or gasket leakage. Note: A thorough examination should be performed of the reactor vessel head using binoculars or other methods allowed by RP. e. Reactor vessel head locations as permitted by Health Physics.
Evaluator Cue:	Shift Manager will have OS2 address actions contained in step 5.8
Standard:	The examinee identifies actions required as listed by procedure
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



Performance Step: 11 Critical N	5.9 IF the RCS leak rate approaches 0.20 gpm and the cause is known, THEN the priority of the work order associated with the contributor SHALL be increased.
Standard:	The examinee verfies that this step is not applicable because the cause of the leakage is unknown.
Performance: Comments:	SATISFACTORY UNSATISFACTORY

Performance Step: 12 Critical Y	 5.10 <u>IF</u> the plant is in Mode 1 through 4, <u>AND</u> Unidentified Leakage exceeds one gpm, <u>THEN</u> ENTER Technical Specification LCO 3.4.13 Action Condition.
Standard:	The examinee identifies RCS unidentified leakage >1 gpm is in excess of limit for Technical Specifications LCO 3.4.13.
Performance: Comments:	SATISFACTORY UNSATISFACTORY

Performance Step: 13 Critical N	5.11 <u>IF</u> Unidentified Leakage is greater than 1.0 gpm <u>OR</u> Identified Leakage is greater than 10 gpm, <u>THEN</u> INITIATE AOP 1A, Reactor Coolant Leak.
Standard:	The examinee identifies that AOP 1A is already in effect, per initial conditions.
Performance: Comments:	SATISFACTORY UNSATISFACTORY



Performance Step: 14 Critical N	 5.12 IF the plant is in Mode 1 through 4, AND Identified Leakage exceeds 10 gpm, THEN ENTER Technical Specification LCO 3.4.13 Action Condition. 	
Standard:	The examinee identifies RCS identified leakage is less than 10 gpm.	
Performance: Comments:	SATISFACTORY UNSATISFACTORY	

Terminating Cues: JPM is complete.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.

Stop

Time:



Examinee:	Evaluator:
	on-Lic SRO CERT Date:
PERFORMANCE RESULTS:	SAT: UNSAT:
Remediation required:	
	nments shall be made for any steps graded
unsatisfactory).	

EXAMINER NOTE: ENSURE ALL EXAM MATERIAL IS COLLECTED AND PROCEDURES CLEANED, AS APPROPRIATE.

EVALUATOR'S SIGNATURE:

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.



TURNOVER SHEET

INITIAL CONDITIONS:

- You are OS2.
- Unit 1 is operating at stable full reactor power with indications of a primary leak.
- The Letdown Gas Stripper (LDGS) is bypassed per OI 17, Letdown Gas Stripper Operation.
- AOP-1A Unit 1 Reactor Coolant Leak was entered and is currently in progress.
- The PAB AO has reported the following Charging Pumps seal leak rates:
 - 1P-2A = 20 cc/min
 - 1P-2B = 15 cc/min
 - P 1P-2C = 25 cc/min
- Steam Generator Tube Leakage (SGTL) LR_{SGTL} = 0
- Reactor Component Leak Rate LR_{RC} = 0
- Non RCPB Leakage $LR_{P3} = 0$
 - The following plant parameters were observed at time 0400:
 - RCS Tavg 575.6 °F
 - RCS T(Terr) 0 °F
 - PZR Level 46.0 %
 - VCT Level 45.0 %
 - U1 PRT level 74.7%
 - U1 RCDT Level 52 %
 - The following plant parameters were observed at time 0420:
 - RCS Tavg 575.6 °F
 - RCS T(Terr) 0 °F
 - PZR Level 45.7%
 - VCT Level 43.8 %
 - U1 PRT level 74.7%
 - U1 RCDT Level 52.5 %
- No borations, dilutions or diverts to HUT took place.
- There is no Chemistry sampling in progress.
- C04 has completed OI 55 through Attachment A, Primary Leak Rate Worksheet up to Step 6.0 and has presented it to you for your review.

INITIATING CUES (IF APPLICABLE):

- Review the Primary Leak Rate Worksheet
- Complete remaining steps of OI 55, Primary Leak Rate Calculation, starting at Step 5.6.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM TITLE:	Complete a Calculation Review of TS 32		
JPM NUMBER:	PBN P119.203d.SRO REV. 1		
TASK NUMBER(S) / TASK TITLE(S):	P119.203.SRO Maintain Required Logs	and Records	
K/A NUMBERS:	2.2.23	K/A VALUE: 4.0	6
Justification (FOR K/A V	/ALUES <3.0): N/A		
TASK APPLICABILITY:	🗌 STA 🗌 Non-Lic] OTHER:
APPLICABLE METHOD	OF TESTING: Simul	ate/Walkthrough:	Perform: X
EVALUATION LOCATION	N: In-Plant:	Control Roor	m:
	Simulator: X	Other:	X
	Lab:		
Time for Completion:	20 Minutes	Time Critical:	NO
Alternate Path [NRC]			
Alternate Path [INPO]	j. <u>110</u>		
Developed by:			
	Instructor/D	eveloper	Date
Reviewed by:	Instructor (Instruc	tional Review)	Date
Validated by:			
Approved by:	SME (Technic	al Review)	Date
PP	Training Sup	pervision	Date
Approved by:			
	Training Progr	am Owner	Date



JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED PRIOR TO USE.

REV	IEW STATEMENTS	YES	NO	N/A
1.	Are all items on the signature page filled in correctly?	\square		
2.	Has the JPM been reviewed and validated by SMEs?	\square		
3.	Can the required conditions for the JPM be appropriately established in the			\boxtimes
	simulator if required?			
4.	Do the performance steps accurately reflect trainee's actions in accordance	\square		
	with plant procedures?			
5.	Is the standard for each performance item specific as to what controls,			
	indications and ranges are required to evaluate if the trainee properly	\boxtimes		
	performed the step?			
6.	Has the completion time been established based on validation data or	\square		
	incumbent experience?			
7.	If the task is time critical, is the time critical portion based upon actual task			\boxtimes
	performance requirements?			
8.	Is the job level appropriate for the task being evaluated if required?	\boxtimes		
9.	Is the K/A appropriate to the task and to the licensee level if required?	\boxtimes		
10.	Is justification provided for tasks with K/A values less than 3.0?			\square
11.	Have the performance steps been identified and classified (Critical /	\square		
	Sequence / Time Critical) appropriately?			
12.	Have all special tools and equipment needed to perform the task been			\boxtimes
	identified and made available to the trainee?			
13.	Are all references identified, current, accurate, and available to the trainee?	\square		
14.	Have all required cues (as anticipated) been identified for the evaluator to	\square		
	assist task completion?			
15.	Are all critical steps supported by procedural guidance? (e.g., if licensing,			
	EP or other groups were needed to determine correct actions, then the	\square		
	answer should be NO.)			
16.	If the JPM is to be administered to an LOIT student, has the required			
	knowledge been taught to the individual prior to administering the JPM?	\square		
	TPE does not have to be completed, but the JPM evaluation may not be			
	valid if they have not been taught the required knowledge.			

All questions/statements must be answered "YES" or "N/A" or the JPM is not valid for use. If all questions/statements are answered "YES" or "N/A," then the JPM is considered valid and can be performed as written. The individual(s) performing the initial validation shall sign and date the cover sheet.

<u>Protected Content:</u> (CAPRs, corrective actions, licensing commitments, etc. associated with this material) {C001}



PBN JPM P119.203d.SRO, Complete a Calculation Review of TS 32, Rev. 1

#	DESCRIPTION OF CHANGE	REASON FOR	AR/TWR	PREPARER	DATE
п	DECOMINENT OF CHANCE	CHANGE	#	SUPERVISOR	DATE
Rev. 0	New JPM				
Rev. 1	Updated for the 2017 NRC ILT Exam.				



SIMULATOR SET-UP: (Only required for simulator JPMs)

SIMULATOR SETUP INSTRUCTIONS:

SIMULATOR MALFUNCTIONS:

SIMULATOR OVERRIDES:

SIMULATOR REMOTE FUNCTIONS:

Required Materials:	TS 32, Miscellaneous Equipment Checks (Monthly) Unit 1 Calculator Steam Tables
General References:	TS 32, Miscellaneous Equipment Checks (Monthly) Unit 1
Task Standards:	Identify discrepancies (two) not properly noted by the Control Operator, and determine that test results for CET based subcooling margin are NOT within acceptance criteria.



I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- Both Units are at rated power.
- UNIT 1 PPCS Yellow Core Exit Thermocouple indications were acting erratically and have since been repaired.
- PPCS is available.
- CO3 just completed a partial TS 32, Miscellaneous Equipment Checks (Monthly) Unit 1, Attachment B, Calculations.
- CO3 has just requested that you conduct the SRO review for the completed TS 32, Attachment B.

INITIATING CUES:

• You are directed you to perform the SRO review of TS 32, Attachment B.

Evaluator Note: This JPM requires supplying a copy of TS 32 filled out up to the applicable steps of the procedure and Attachment A and B. Provide a calculator and steam tables if the JPM is not conducted in the simulator or control room.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM PERFORMANCE INFORMATION

Start Time:

- NOTE: When providing "Evaluator Cues" to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee's actions warrant receiving the information (i.e., the examinee looks or asks for the indication).
- NOTE: Critical steps are marked with a "Y" below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM.
- NOTE: Will need to provide the student with a copy of TS 32 completed through steps to conduct attachment A and B for the Yellow Subcooling channel on tan paper; and a calculator if one if not readily available.

Performance Step: 1	Reviews Procedure and Attachments		
Critical <u>N</u>			
Standard:	The examinee reviews TS 32 prior to beginning calculation verification		
Evaluator Note:	Provide a copy of TS 32 with required steps and Attachments A and B for Yellow Subcooling monitor being completed		
Performance:			
Comments:			



Performance Step: 2 Critical <u>N</u>	Reviews Attachment B calculations prior to signing that review is complete.
Standard:	Reviews Attachment B calculations and determines that errors exist
Evaluator Note:	The next three JPM steps list the errors that are in the attachment, it is not critical that the errors be discovered in the order listed in the JPM, but all three must be identified.
Performance:	
Comments:	

Performance Step: 3 Reviews procedure step: Critical Y 2.0 DETERMINE average Core Exit Thermocouple temperature for each channel: b. T/C Yellow Channel. b. T/C Yellow Channel. Standard: The examinee determines that "T/C Avg" was calculated incorrectly. The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCCOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY Comments:			
channel: b. T/C Yellow Channel. Standard: The examinee determines that "T/C Avg" was calculated incorrectly. The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY	Performance Step: 3	Reviews procedure step:	
b. T/C Yellow Channel. Standard: The examinee determines that "T/C Avg" was calculated incorrectly. The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY	Critical <u>Y</u>	2.0 DETERMINE average Core Exit Thermocouple temperature for each	
Standard: The examinee determines that "T/C Avg" was calculated incorrectly. The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY		channel:	
The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY		b. T/C Yellow Channel.	
The examinee calculates a correct value for "T/C Avg" of 604.4°F, and corrects the error carried forward to Steps 3.b. and 5.e. based on this result. Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY			
Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY	Standard:	The examinee determines that "T/C Avg" was calculated incorrectly.	
Evaluator Cue: If notified of error in calculation then acknowledge report and ask student to continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY []		The examinee calculates a correct value for "T/C Avg" of 604.4°F, and	
continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY		corrects the error carried forward to Steps 3.b. and 5.e. based on this result.	
continue with performance of the procedure. The error may not be reported until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY			
until review is completed. Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY	Evaluator Cue:	If notified of error in calculation then acknowledge report and ask student to	
Evaluator Note: For Step 2.b the acceptable range =603.7 to 604.8°F For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY []		continue with performance of the procedure. The error may not be reported	
For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY []		until review is completed.	
For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to 50.4°F) Performance: SATISFACTORY UNSATISFACTORY []			
50.4°F) Performance: SATISFACTORY UNSATISFACTORY	Evaluator Note:	For Step 2.b the acceptable range =603.7 to 604.8°F	
Performance: SATISFACTORY UNSATISFACTORY		For Step 3.b and 5.e: °F _{SUBCOOLED} = 49.7°F (Acceptable range = 49.3 to	
		50.4°F)	
Comments:	Performance:		
	Commonts:		
	Comments.		



Performance Step: 4	Review procedure step:
Critical <u>Y</u>	5.0 PERFORM a channel check for Core Exit Thermocouple based
_	subcooling margin:
Standard:	The examinee determines that at Step 5.g. the wrong value was entered,
	and enters the correct value of 40.9°F from Table 2.
Evaluator Cue:	If notified of error, then acknowledge report and ask student to continue with
	performance of the procedure. The error may not be reported until review is
	completed.
Evaluator Note:	The incorrect value of 47.8 was taken from "Subcooling Monitor (RTD)" vice
	"Subcooling Monitor(T/C)" on Table 2.
Performance:	SATISFACTORY 🗌 UNSATISFACTORY 🗌
Comments:	

Porformance Stony 5	Poviou procedure stop:		
Performance Step: 5	Review procedure step:		
Critical <u>Y</u>	5.0 PERFORM a channel check for Core Exit Thermocouple based		
	subcooling margin:		
	h. The difference between all three Yellow Channel values is less than		
	or equal to 7.9°F(CIRCLE one) SAT / UNSAT		
Standard:	The examinee determines that the difference between Yellow Channel		
	values is greater than 7.9°F, and that the step is "UNSAT."		
Evaluator Cue:	If notified of error in calculation then acknowledge report and ask student to		
	continue with performance of the procedure. The error may not be reported		
	until review is completed.		
Evaluator Note:	Once errors have been corrected for values at steps 5.e and 5.g, the		
	examinee should identify a difference of 8.8°F.		
Performance:			
Comments:			



Performance Step: 6	Reports errors in calculations and asks for CO to review data and does not
Critical <u>N</u>	sign for calculation verification
Standard:	The examinee does not sign calculation verification until deficiencies are resolved
Evaluator Cue:	Acknowledge report
Performance:	
Comments:	

Terminating Cues: That completes this JPM.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.

Stop Time:



Examinee:		Evaluator:	
	-Lic 🗌 SRO CERT	Date:	
LOIT RO LOIT SRO			
PERFORMANCE RESULTS:	SAT:		UNSAT:
Remediation required:	YES	NO	

COMMENTS/FEEDBACK:	(Comments shall be made for any steps graded unsatisfactory).

EXAMINER NOTE: ENSURE ALL EXAM MATERIAL IS COLLECTED AND PROCEDURES CLEANED, AS APPROPRIATE.

EVALUATOR'S SIGNATURE:

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.



TURNOVER SHEET

INITIAL CONDITIONS:

- Both Units are at rated power.
- UNIT 1 PPCS Yellow Core Exit Thermocouple indications were acting erratically and have since been repaired.
- PPCS is available.
- CO3 just completed a partial TS 32, Miscellaneous Equipment Checks (Monthly) Unit 1, Attachment B, Calculations.
- CO3 has just requested that you conduct the SRO review for the completed TS 32, Attachment B.

INITIATING CUES:

• You are directed you to perform the SRO review of TS 32, Attachment B.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM TITLE:	Review IT 90 TRAIN B, Atmospheric Steam Dump	Valve Train B Unit 1
JPM NUMBER:	PBN JPM P119.231.SRO	REV. 0
TASK NUMBER(S) / TASK TITLE(S):	PBN P119.231.SRO / Perform surveillances per th Program	e Plant Inspection
K/A NUMBERS:	2.2.12 K/A VALUE: 3.7/2	↓.1
Justification (FOR K/A V	ALUES <3.0):	
TASK APPLICABILITY:	□ Non-Lic □ SRO CERT □ OTHER:	
APPLICABLE METHOD	DF TESTING: Simulate/Walkthrough:	Perform: X
EVALUATION LOCATION	I: In-Plant: Control Ro	om:
	Simulator: Other:	X
	Lab:	
Time for Completion	n: <u>15</u> Minutes Time Critical: <u>No</u>	
Alternate Path [NR	C]: _{No}	
Alternate Path [INF	PO]: No	
Developed by:		
	Instructor/Developer	Date
Reviewed by:	Instructor (Instructional Daviau)	Deta
Validated by:	Instructor (Instructional Review)	Date
	SME (Technical Review)	Date
Approved by:	Training Supervision	Date
Approved by:		
	Training Program Owner	Date



JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED PRIOR TO USE.

REV	IEW STATEMENTS	YES	NO	N/A
1.	Are all items on the signature page filled in correctly?	\square		
2.	Has the JPM been reviewed and validated by SMEs?	\square		
3.	Can the required conditions for the JPM be appropriately established in the simulator if required?			\boxtimes
4.	Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	\boxtimes		
5.	Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	\boxtimes		
6.	Has the completion time been established based on validation data or incumbent experience?	\boxtimes		
7.	If the task is time critical, is the time critical portion based upon actual task performance requirements?			\boxtimes
8.	Is the job level appropriate for the task being evaluated if required?	\square		
9.	Is the K/A appropriate to the task and to the licensee level if required?	\square		
10.	Is justification provided for tasks with K/A values less than 3.0?			\square
11.	Have the performance steps been identified and classified (Critical / Sequence / Time Critical) appropriately?	\boxtimes		
12.	Have all special tools and equipment needed to perform the task been identified and made available to the trainee?			\boxtimes
13.	Are all references identified, current, accurate, and available to the trainee?	\square		
14.	Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	\boxtimes		
15.	Are all critical steps supported by procedural guidance? (e.g., if licensing, EP or other groups were needed to determine correct actions, then the answer should be NO.)	\boxtimes		
16.	If the JPM is to be administered to an LOIT student, has the required knowledge been taught to the individual prior to administering the JPM? TPE does not have to be completed, but the JPM evaluation may not be valid if they have not been taught the required knowledge.			

All questions/statements must be answered "YES" or "N/A" or the JPM is not valid for use. If all questions/statements are answered "YES" or "N/A," then the JPM is considered valid and can be performed as written. The individual(s) performing the initial validation shall sign and date the cover sheet.

Protected Content: (CAPRs, corrective actions, licensing commitments, etc. associated with this material)

{C001}



# Rev. 0	DESCRIPTION OF CHANGE	REASON FOR CHANGE	AR/TWR#	PREPARER	DATE
Rev. 0	Developed for the 2017 NRC ILT				DATE
Rev. 0	Developed for the 2017 NRC ILT			SUPERVISOR	DATE
		Exam.			



SIMULATOR SET-UP: (Only required for simulator JPMs) None

SIMULATOR SETUP INSTRUCTIONS: None

SIMULATOR MALFUNCTIONS: None

SIMULATOR OVERRIDES: None

SIMULATOR REMOTE FUNCTIONS: None

Required Materials:	Marked up copy (with errors) of IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1
General References:	IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1
Task Standards:	Identify the two inserted deficiencies during supervisory review of IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1. Assess test results to identify that the ADV is OPERABLE, but does not meet IST acceptance criteria, and initiate required actions.



I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- You are OS1.
- The third license just completed IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1 and has requested that you perform the supervisory review prior to exiting TSAC 3.7.4.A.1.

INITIATING CUES (IF APPLICABLE):

• Complete the supervisory review for IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM PERFORMANCE INFORMATION

Start Time:

- NOTE: When providing "Evaluator Cues" to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee's actions warrant receiving the information (i.e., the examinee looks or asks for the indication).
- NOTE: Critical steps are marked with a "Y" below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM.

Performance Step: 1 Critical N	 Review the cover page for accuracy and completeness: Verified Current Copy List pages used for Partial Performance Controlling Work Document Numbers 	
Standard:	 The examinee reviews the cover page and determines it is accurate and complete: Verified Current Copy List pages used for Partial Performance Controlling Work Document Numbers 	
Evaluator Note:	 Verified Current Copy (Signature / Date / Time correctly filled in) List pages used for Partial Performance (None) Controlling Work Document Numbers (as noted) 	
Performance:	SATISFACTORY UNSATISFACTORY	
Comments:		



Performance Step: 2 Critical N	 Review <u>Step 2.1</u> stopwatch data for accuracy and completeness: ID No. Calibration Due Date
Standard:	The examinee checks stopwatch data and notes that ID No. is filled in, and Calibration Due Date is NOT past due.
Evaluator Note:	No errors with this step.
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 3 Critical N	 Review <u>Step 4.0</u>, Initial Conditions for accuracy and completeness: 4.1 This test is being done to satisfy: IST Coordinator availability Permission to Perform Test
Standard:	 The examinee reviews <u>Step 4.0</u>, Initial Conditions and notes that it is complete and accurate. 4.1 This test is being done to satisfy: 4.2 IST Coordinator availability 4.3 Permission to Perform Test
Evaluator Note:	 No errors in this section. 4.1 This test is being done to satisfy: (Checked and includes Task Sheet No.) 4.2 IST Coordinator: N/A (not PMT) 4.3 Permission to Perform Test (Signature / Date / Time)
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



PBN JPM P119.231.SRO, Review Atmospheric Steam Dump Valve Train B Unit 1, Rev. 0

Performance Step: 4 Critical N	 Review Steps 5.1.1 through 5.1.6 for accuracy and completeness: Date / time Pressures Initials IV initial
Standard:	The examinee reviews Steps 5.1.1 through 5.1.6 and notes they are accurate and complete.
Evaluator Note:	 No errors this section. 5.1.1 Date / Time 5.1.3 Value should be 800 psig 5.1.4 b Value should be 1050 psig 5.1.5 i Should be marked N/A 5.1.5 j Should be marked N/A 5.1.6 b Value should be 800 psig 5.1.6 d Value should be 1050 psig 5.1.6 m Should be marked N/A
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 5 Critical N	 Review Step 5.1.7 through 5.1.9 for accuracy and completeness: Date / Time Initials IV initials
Standard:	The examinee reviews Step 5.1.7 through 5.1.9 and notes they are accurate and complete.
Evaluator Note:	5.1.9 Date / Time
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



Performance Step: 6 Critical N	 Review Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.5 b Control Room Time to OPEN Local Positon Indication Control Room Position Indication
Standard:	 The examinee reviews Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.5 b and determines it is accurate and complete. Control Room Time to OPEN Local Positon Indication Control Room Position Indication
Evaluator Note:	 Control Room Time to OPEN (11.77) Local Positon Indication (OPEN) Control Room Position Indication (ON / OFF)
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



PBN JPM P119.231.SRO, Review Atmospheric Steam Dump Valve Train B Unit 1, Rev. 0

Performance Step: 7 Critical N	 Review Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.5 e. Control Room Time to SHUT Local Positon Indication Control Room Position Indication
Standard:	 The examinee reviews Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.5 e and determines it is accurate and complete. Control Room Time to SHUT Local Positon Indication Control Room Position Indication
Evaluator Note:	 Control Room Time to SHUT (34.56) Local Positon Indication (SHUT) Control Room Position Indication (OFF / ON) The examinee may identify that "Time to SHUT" does not meet IST acceptance criteria. This will be critical for JPM Step 11.
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



PBN JPM P119.231.SRO, Review Atmospheric Steam Dump Valve Train B Unit 1, Rev. 0

Performance Step: 8 Critical Y	 Review Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.6 g Control Room Time to OPEN Local Positon Indication Control Room Position Indication
Standard:	The examinee identifies the Step 5.1.6 g transposition error (entered value of OFF / ON rather than the required value of ON / OFF).
Evaluator Note:	 Control Room Time to OPEN (11.78) Local Positon Indication (OPEN) Control Room Position Indication (OFF / ON), (First of two inserted errors.)
Evaluator Cue:	If the examinee questions the CO about the incorrect valve position indication, report that the actual indication was "Red Light ON and Green Light OFF."
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 9 Critical N	 Review Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.6 i Control Room Time to SHUT Local Positon Indication Control Room Position Indication
Standard:	 The examinee reviews Attachment A, 1MS-2015 Valve Stroke Verification data recorded in the table for Steps 5.1.6 i and determines it is accurate and complete. Control Room Time to SHUT Local Positon Indication Control Room Position Indication
Evaluator Note:	 No errors this section. Control Room Time to SHUT (34.48) Local Positon Indication (SHUT) Control Room Position Indication (OFF / ON)
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



Performance Step: 10 Critical Y	 Review Attachment A, 1MS-2015 Valve Stroke Verification data recorded after the table for: LVFST Satisfied for all tested valves in Attachment A: (SAT / UNSAT) IST Data Satisfied for all tested valves in Attachment A: (SAT / UNSAT) Performer, Date / Time Remarks
Standard:	The examinee identifies that SAT was circled in error for the 'IST Data Satisfied for all tested values in Attachment A.'
Evaluator Note:	 LVFST Satisfied for all tested valves in Attachment A: (SAT circled) IST Data Satisfied for all tested valves in Attachment A: (SAT circled) (Second of two inserted errors.) Performer, Date / Time (Signature / Date / Time) Remarks (Comment addressing IST out-of-spec for step 5.1.5 e)
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



Performance Step: 11 Critical Y	Completes Step 6.1: Operations Analysis
Standard:	 The examinee: Completes Step 6.1.1 – signature / date / time Step 6.1.2 – marks step as N/A Step 6.1.3 – marks step as N/A Completes Step 6.1.4 – actions request submittal and IST Engineer notification
Evaluator Cue:	When the step is addressed, notify the SRO that the CO has written an AR. AR # 1234567 When the step is addressed, notify the SRO that the IST Engineer has been informed of his required review.
Evaluator Note:	 The examinee should: Identify "Time to SHUT" does not meet IST acceptance criteria, requiring performance of Step 6.1.4. Give direction to generate an AR and Notify the IST Engineer.
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Terminating Cues: The JPM is complete.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.

Stop Time:



Examinee:		Evaluator:
	n-Lic 🗌 SRO CERT	Date:
LOIT RO LOIT SRO		
PERFORMANCE RESULTS:	SAT:	UNSAT:
Remediation required:	YES	NO
COMMENTS/FEEDBACK: (Comm	nents shall be made for	r any steps graded unsatisfactory).
_		

EXAMINER NOTE: ENSURE ALL EXAM MATERIAL IS COLLECTED AND PROCEDURES CLEANED, AS APPROPRIATE.

EVALUATOR'S SIGNATURE:

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.



TURNOVER SHEET

INITIAL CONDITIONS:

- You are OS1.
- The third license just completed IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1 and has requested that you perform the supervisory review prior to exiting TSAC 3.7.4.A.1.

INITIATING CUES (IF APPLICABLE):

• Complete the supervisory review for IT 90 Train B, Atmospheric Steam Dump Valve Train B Unit 1.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM TITLE:	Review a Discharge Calculat	ion (OI 140B)	
JPM NUMBER:	PBN JPM P119.223d.SRO	REV. 0	
TASK NUMBER(S) / TASK TITLE(S):	PBN P119.223.SRO / Review	v completed procedures	
K/A NUMBERS:	2.3.6	K/A VALUE: 3.9 / 4.2	
Justification (FOR K/A V	ALUES <3.0):		
TASK APPLICABILITY:	Non-Lic 🗌 SRO CERT		
APPLICABLE METHOD	DF TESTING: Simulate/	Walkthrough: Perform	: X
EVALUATION LOCATION	1: In-Plant:	Control Room:]
	Simulator:	Other: X]
	Lab:		
Time for Completion	on: <u>15</u> Minutes	Time Critical: No	
Alternate Path [NR	C]: _{No}		
Alternate Path [INF	PO]: N0		
Developed by:			
	Instructor/Devel	loper	Date
Reviewed by:	Instructor (Instruction		Date
Validated by:	Ϋ́,		Dale
	SME (Technical R	(eview)	Date
Approved by:	Training Superv	/ision	Date
Approved by:			-
,	Training Program	Owner	Date



JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED PRIOR TO USE.

REV	IEW STATEMENTS	YES	NO	N/A
1.	Are all items on the signature page filled in correctly?	\boxtimes		
2.	Has the JPM been reviewed and validated by SMEs?	\boxtimes		
3.	Can the required conditions for the JPM be appropriately established in the simulator if required?	\boxtimes		
4.	Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	\boxtimes		
5.	Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	\boxtimes		
6.	Has the completion time been established based on validation data or incumbent experience?	\boxtimes		
7.	If the task is time critical, is the time critical portion based upon actual task performance requirements?			\boxtimes
8.	Is the job level appropriate for the task being evaluated if required?	\boxtimes		
9.	Is the K/A appropriate to the task and to the licensee level if required?	\boxtimes		
10.	Is justification provided for tasks with K/A values less than 3.0?			\square
11.	Have the performance steps been identified and classified (Critical / Sequence / Time Critical) appropriately?	\boxtimes		
12.	Have all special tools and equipment needed to perform the task been identified and made available to the trainee?			
13.	Are all references identified, current, accurate, and available to the trainee?	\boxtimes		
14.	Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	\boxtimes		
15.	Are all critical steps supported by procedural guidance? (e.g., if licensing, EP or other groups were needed to determine correct actions, then the answer should be NO.)	\boxtimes		
16.	If the JPM is to be administered to an LOIT student, has the required knowledge been taught to the individual prior to administering the JPM? TPE does not have to be completed, but the JPM evaluation may not be valid if they have not been taught the required knowledge.	\boxtimes		

All questions/statements must be answered "YES" or "N/A" or the JPM is not valid for use. If all questions/statements are answered "YES" or "N/A," then the JPM is considered valid and can be performed as written. The individual(s) performing the initial validation shall sign and date the cover sheet.

Protected Content: (CAPRs, corrective actions, licensing commitments, etc. associated with this material)



PBN JPM P119.223d.SRO, Review a Discharge Calculation (OI 140C), Rev. 0

	the material after initial approval. Or use separate Update Log form TR-AA-230-1003-F16.				
#	DESCRIPTION OF CHANGE	REASON FOR CHANGE	AR/TWR#	SUPERVISOR	DATE
Rev. 0					



SIMULATOR SET-UP: (Only required for simulator JPMs)

SIMULATOR SETUP INSTRUCTIONS: None

SIMULATOR MALFUNCTIONS: None

SIMULATOR OVERRIDES: None

SIMULATOR REMOTE FUNCTIONS: None

Required Materials:	OI 140B, Standard Radioactive Batch Liquid Release – Waste Distillate Tanks PBNP Liquid Waste Discharge Permit for the "A" Waste Distillate Tank CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water OI-38, Circulating Water System Operation TLB 23, Waste Distillate Tank T-104 A/B
General References:	OI 140B, Standard Radioactive Batch Liquid Release – Waste Distillate Tanks PBNP Liquid Waste Discharge Permit for the "A" Waste Distillate Tank CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water
Task Standards:	Review and identify the three errors on CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water associated with the discharge of the "A" Waste Distillate Tank.



I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- You are the Shift Manager on mids
- A "A" Waste Distillate Tank discharge was recently completed on your shift and the paperwork was routed to you for review and approval.

INITIATING CUES (IF APPLICABLE):

Complete the "Permit review by Shift Manager" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the "A" Waste Distillate Tank prior to routing to the Chemistry Manager.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.



JPM PERFORMANCE INFORMATION

Start Time:

- NOTE: When providing "Evaluator Cues" to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee's actions warrant receiving the information (i.e., the examinee looks or asks for the indication).
- NOTE: Critical steps are marked with a "Y" below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM.

Performance Step: 1 Critical N	 Review "Completed Prior to Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Initials for actual dilution flow Initials for number of Circulating Water pumps operating (2) Initials and Date/Time for Shift Manager Review/Approval to Start Discharge
Standard:	 The examinee reviews the "Completed Prior to Discharge" section for accuracy and completeness: Initials for actual dilution flow Initials for number of Circulating Water pumps operating (2) Initials and Date/Time for Shift Manager Review/Approval to Start Discharge
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	



PBN JPM P119.223d.SRO, Review a Discharge Calculation (OI 140C), Rev. 0

Performance Step: 2 Critical N	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: The two Notes Ensure flow response option circled The initial flow calculation / data recorded in the box The final flow calculation / data recorded in the box.
Standard:	 The examinee reviews the "Completed During Discharge" section for accuracy and completeness for the following: The two Notes (circle / slashed) Ensure flow response option (circled) – LW-15
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 3 Critical N	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Discharge START Date/Time and initials
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Discharge START Date/Time and initials
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	

Performance Step: 4 Critical N	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Discharge START Level and initials 	
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Discharge START Levels and initials – 78% 	
Performance:	SATISFACTORY UNSATISFACTORY	
Comments:		



Performance Step: 5 Critical N	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Discharge STOP Date/Time and initials
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Discharge STOP Date/Time and initials
Performance:	SATISFACTORY UNSATISFACTORY
Comments:	
	Deview "Operandeted During Discharge" as then of OAMD 024. Date Object 4

Performance Step: 6 Critical N	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Discharge STOP Level and initials 		
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Discharge STOP Level and initials 		
Performance:	SATISFACTORY UNSATISFACTORY		
Comments:			



Performance Step: 7 Critical Y	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Actual Discharge Volume (gal) 		
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Actual Discharge Volume (gal) Determines that the recorded volume of 7410 gal is incorrect. The correct volume is 8610 gal. 		
Evaluator Note:	 The recorded volume of 7410 gal does not account for 1200 gal in the tank below the 0% level indication. See TLB 23 and OI-140B P&L 3.15. The actual volume discharged is 8610 gal. 		
Performance:	SATISFACTORY UNSATISFACTORY		
Comments:			

Performance Step: 8 Critical Y	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Actual Discharge Rate (gpm) 		
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Actual Discharge Rate (gpm) <u>AND</u> Determines that the discharge rate calculation is NOT accurate. 		
Evaluator Note:	The values used for both discharged volume and time are incorrect. Using the corrected value for volume discharged (JPM Step 7) and the correct time of 2 hr, 32 min (152 min) the Actual Discharge Rate is 56.6 gpm. [8610 gal / 152 min = 56.6 gpm]		
Performance:	SATISFACTORY UNSATISFACTORY		
Comments:			



PBN JPM P119.223d.SRO, Review a Discharge Calculation (OI 140C), Rev. 0

Performance Step: 9 Critical Y	 Review "Completed During Discharge" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the following: Actual Discharge Rate (gpm) 		
Standard:	 The examinee reviews the "Completed During Discharge" section for the following: Actual Discharge Rate (gpm) <u>AND</u> Determines that the corrected Actual Discharge Rate exceeds the Maximum Release Rate as specified on the Discharge Permit. 		
Evaluator Note:	The corrected value for "Actual Discharge Rate" is 56.6 gpm is greater than the Maximum Release Rate of 50 gpm as specified on the Discharge Permit.		
Performance:	SATISFACTORY UNSATISFACTORY		
Comments:			

Terminating Cues: The JPM is complete.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.

Stop Time:



Examinee:		Evaluator:			
🗌 RO 🗌 SRO 🗌 STA 🗌 Non	-Lic 🗌 SRO CERT	Date:			
PERFORMANCE RESULTS:	SAT:	UNSAT:			
Remediation required:	YES	NO			
COMMENTS/FEEDBACK: (Comments shall be made for any steps graded unsatisfactory).					

EXAMINER NOTE: ENSURE ALL EXAM MATERIAL IS COLLECTED AND PROCEDURES CLEANED, AS APPROPRIATE.

EVALUATOR'S SIGNATURE:

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.



TURNOVER SHEET

INITIAL CONDITIONS:

- You are the Shift Manager on mids
- A "A" Waste Distillate Tank discharge was recently completed on your shift and the paperwork was routed to you for review and approval.

INITIATING CUES (IF APPLICABLE):

Complete the "Permit review by Shift Manager" section of CAMP 031, Data Sheet 1 – Permits for Batch Discharge of Liquid Radioactive Water for the "A" Waste Distillate Tank prior to routing to the Chemistry Manager.

NOTE: Ensure the turnover sheet that was given to the examinee is returned to the evaluator.

SRO Admin JPM 5 (Emergency Plan)

PERFORM REQUIRED NOTIFICATIONS

(Facility JPM Number: PBN JPM P119.214c.SRO)

Exam material withheld from public disclosure due to proprietary content.