



**Commonwealth Edison**  
 Dresden Nuclear Power Station  
 R.R. #1  
 Morris, Illinois 60450  
 Telephone 815/942-2920

*WLB*

**REGULATORY DOCKET FILE COPY**

November 12, 1980

DJS Ltr. #80-240

James G. Keppler, Regional Director  
 Directorate of Regulatory Operations - Region III  
 U.S. Nuclear Regulatory Commission  
 799 Roosevelt Road  
 Glen Ellyn, IL 60137

1980 NOV 28 PM 1:59  
 RECEIVED DISTRIBUTION SERVICES UNIT  
 U.S. NRC SERVICES BRANCH  
 DISTRIBUTION SERVICES BRANCH

Reportable Occurrence Report #80-42/03L-0, Docket #050-237 being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(c), observed inadequacies in the implementation of administrative or procedural controls which threaten to cause reduction of degree of redundancy provided in reactor protection systems or engineered safety feature systems.

*Douglas J. Scott*

D. J. Scott  
 Station Superintendent  
 Dresden Nuclear Power Station

DJS/nh

Enclosure

cc/ Director of Inspection & Enforcement  
 Director of Management Information & Program Control  
 U.S. NRC, Document Management Branch  
 File/NRC

*A002  
 S  
 1/1*

NOV 24 1980



# DEVIATION REPORT

**Commonwealth Edison**

DVR NO. \_\_\_\_\_  
 STA UNIT YEAR NO.  
 0-12 - 2 - 80 - 69

**PART 1** TITLE OF DEVIATION: Ultrasonic Testing of the Scram Discharge Volume on Units 2 & 3 not completed  
 OCCURRED: 11/2/80 0530  
 DATE TIME

SYSTEM AFFECTED: 0300 CRD System  
 PLANT CONDITIONS: D2 Run 1359  
 MODE: D3 Run PWR(MWT): 1816.5 LOAD(MWE): 583.5  
 TESTING: YES  NO

DESCRIPTION OF EVENT: A review of the Unit 2 and 3 operator's logs and subsequent verification with Technical Staff personnel, indicated that UT of Unit 2 or Unit 3 scram discharge volumes had not been performed during 1500-2300 shift.

DESCRIPTION OF CAUSE: Unknown

OTHER APPLICABLE INFORMATION: Shift Engineer contacted the Tech. Staff and confirmed the above information.

EQUIPMENT FAILURE: YES  NO   
 DR NO.: NA WR NO.: NA  
 R. A. Mitzel 11/2/80  
 RESPONSIBLE SUPERVISOR DATE

**PART 2** OPERATING ENGINEERS COMMENTS: A level check of the Unit 2 and Unit 3 scram discharge volumes was immediately performed. No water was found to be present in either scram discharge volume.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21 <input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION		
80-42/03L-0		E. Budzichowski	11/3/80	10:25A
		TITLE	DATE	TIME
		TITLE	DATE	TIME

24-HOUR NRC NOTIFICATION (Courtesy)				PROMPT OFF-SITE NOTIFICATION		
<input checked="" type="checkbox"/> TPH <input type="checkbox"/> TGM	Tom Tongue	11/3/80	0915	F. Palmer	11/3/80	11:55
	REGION III	DATE	TIME	TITLE	DATE	TIME
	REGION III & DOL	DATE	TIME	TITLE	DATE	TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC: Michael Wright  
 REVIEW AND COMPLETED: OPERATING ENGINEER 11-3-80 DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED  
 DATE \_\_\_\_\_  
 RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

*Jack Brunner* 11/19/80  
*John W. Wiggins* 11/20/80  
*Douglas Scott* STATION SUPERINTENDENT 11/20/80 DATE