

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9704030004 DOC. DATE: 97/03/27 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 AUTH. NAME AUTHOR AFFILIATION
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 REYES, L.A. Region 2 (Post 820201)

SUBJECT: Submits results of inservice insp SG tube plugging.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	1 1
	CROTEAU, R	1 1		
INTERNAL:	AEOD/SPD/RAB	1 1	FILE CENTER 0	1 1
	NRR/DE/EMEB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS3	1 0	RES/DET/EIB	1 1
	RES/DET/EMEB	1 1		
EXTERNAL:	LITCO ANDERSON	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 13 ENCL 12 MA





MAR 27 1997

L-97-084
10 CFR 50.36

Luis A. Reyes
Regional Administrator
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Dear Mr. Reyes:


Re: Turkey Point Unit 3
Docket No. 50-250
Steam Generator Tube Plugging - 15 Day Special Report

In accordance with Turkey Point Technical Specification 4.4.5.5.a, the subject Special Report is submitted pursuant to Specification 6.9.2 for Turkey Point Unit 3 as a result of the End-of-Cycle 15 inservice inspection of steam generator tubes.

The Turkey Point Unit 3 steam generators were inspected from March 13, 1997, through March 19, 1997. There were 3 steam generator tubes plugged in steam generator 3A as a result of the inspection bringing the total tubes plugged in 3A to 20. There were 9 tubes plugged in steam generator 3B bringing the total tubes plugged in 3B to 27. There were 2 tubes plugged in steam generator 3C bringing the total tubes plugged in 3C to 35. The attachment to this letter provides additional Unit 3 steam generator tube plugging details.

Should there be any questions, please contact us.

Very truly yours,


R. J. Hovey
Vice President
Turkey Point Plant


MSD

cc: USNRC, Document Control Desk, Washington, D.C.
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point
Plant

9704030004 970327
PDR ADOCK 05000250
G PDR



A047/1



Attachment to
L-97-084

End-of-Cycle 15
Turkey Point Unit 3 Steam Generator Tube Plugging

(NOTE: Technical Specification represented as TS below)

<u>Steam Generator</u>	<u>Row</u>	<u>Column</u>	<u>Reason for Tube Plugging</u>
A	13	5	Defective per TS 4.4.5.4.a
	31	18	Defective per TS 4.4.5.4.a
	44	36	Defective per TS 4.4.5.4.a
B	37	20	Defective per TS 4.4.5.4.a
	42	38	Defective per TS 4.4.5.4.a
	39	39	Defective per TS 4.4.5.4.a
	44	40	Defective per TS 4.4.5.4.a
	23	41	Defective per TS 4.4.5.4.a
	44	41	Defective per TS 4.4.5.4.a
	41	44	Defective per TS 4.4.5.4.a
	45	41	Preventively Plugged*
	45	42	Preventively Plugged*
C	33	66	Defective per TS 4.4.5.4.a
	30	48	Preventively Plugged**

* Tubes adjacent to a foreign object were preventively plugged

** Tube was preventively plugged due to wear at the anti-vibration bar