

NIAGARA MOHAWK POWER CORPORATION
301 PLAIN FIELD ROAD
SM-3
SYRACUSE, NY 13212

TECHNICAL REPORT TR-6801-2

REVISION 1

MARK I TORUS SHELL AND VENT SYSTEM THICKNESS REQUIREMENTS
NINE MILE POINT UNIT 1 NUCLEAR STATION

JANUARY 29, 1988

TELEDYNE ENGINEERING SERVICES

130 SECOND AVENUE
WALTHAM, MASSACHUSETTS 02254
617-890-3350

8806060224 880527
PDR ADDCK 05000220
P DCD





LIST OF REVISIONS

- Revision 1 Revise cover and report to Revision 1.
- Revise Figures 9, 10, 14, 15, 16 and 17 to add clarity.
- Add Figure 18 vent sphere thicknesses.
- Revise text to simplify figure use.
- Add page D-3, Rev.: 1, VADR.
- Add Appendix E.



TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION	1
2.0 TORUS SHELL ANALYSIS	2
2.1 Minimum Torus Shell Thickness Requirements	3
2.2 Permissible Local Reduction in Torus Shell Thickness for an Indication	5
2.3 Certified Material Test Report Review for Torus Shell	7
3.0 VENT SYSTEM SHELL STRESS ANALYSIS	9
3.1 Minimum Vent System Shell Thickness Requirements	10
3.2 Permissible Local Reduction in Vent System Thickness for an Indication	10
4.0 REFERENCES	13
APPENDIX A - TORUS AND VENT SYSTEM REQUIRED SHELL THICKNESS CALCULATIONS	A- 1
A.1 TORUS SHELL THICKNESS CALCULATIONS	A- 2
A.2 VENT SYSTEM THICKNESS CALCULATIONS	A-14
APPENDIX B - PERMISSIBLE INDICATION SIZE CALCULATIONS	B- 1
B.1 TORUS SHELL RANGE OF INDICATION SIZES	B-14
B.2 VENT SYSTEM RANGE OF INDICATION SIZES	B-22
APPENDIX C - TORUS SHELL CERTIFIED MATERIAL REPORTS AND STATISTICAL ANALYSIS	C- 1
C.1 STATISTICAL ANALYSIS	C- 2
C.2 DATA EXTRACTION	C- 5
C.3 CERTIFIED MATERIAL REPORTS	C-19
APPENDIX D - QUALITY ASSURANCE INFORMATION	D- 1
APPENDIX E - SAMPLE TORUS SHELL CALCULATIONS FOR POSTULATED INDICATIONS	E- 1





LIST OF TABLES

	<u>PAGE</u>
TABLE 1. MINIMUM TORUS SHELL THICKNESS REQUIREMENTS, NINE MILE POINT UNIT 1 NUCLEAR STATION	15
TABLE 2. MINIMUM VENT SYSTEM THICKNESS REQUIREMENTS, NINE MILE POINT UNIT 1 NUCLEAR STATION	16



LIST OF FIGURES

	<u>PAGE</u>
FIGURE 1. STARDYNE ONE-FORTIETH FINITE-ELEMENT COMPUTER MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION	17
FIGURE 2. STARDYNE ONE-FORTIETH COMPUTER MODEL DIMENSIONS, NINE MILE POINT UNIT 1 NUCLEAR STATION	18
FIGURE 3. STARDYNE TORUS MODEL UPPER SHELL SECTION, NINE MILE POINT UNIT 1 NUCLEAR STATION	19
FIGURE 4. STARDYNE TORUS MODEL LOWER SHELL SECTION, NINE MILE POINT UNIT 1 NUCLEAR STATION	20
FIGURE 5. LOCAL TORUS SHELL STRESS REGIONS, NINE MILE POINT UNIT 1 NUCLEAR STATION	21
FIGURE 6. MARK I STRUCTURAL ACCEPTANCE CRITERIA EVENT COMBINATIONS	22
FIGURE 7. PERMISSIBLE CORRODED THICKNESS FOR THE TORUS CROSS-SECTION ADJACENT TO RING GIRDER (LOCAL SHELL REGION), NINE MILE POINT UNIT 1 NUCLEAR STATION	23
FIGURE 8. PERMISSIBLE CORRODED THICKNESS FOR THE TORUS CROSS-SECTION AT MIDBAY (FREE-SHELL REGION), NINE MILE POINT UNIT 1 NUCLEAR STATION	24
FIGURE 9. PERMISSIBLE SIZE RANGE FOR INDICATION, FREE-SHELL REGION OF THE TORUS, NINE MILE POINT UNIT 1 NUCLEAR STATION	25
FIGURE 10. PERMISSIBLE SIZE RANGE FOR INDICATION, RING GIRDER REGION OF THE TORUS, NINE MILE POINT UNIT 1 NUCLEAR STATION	26
FIGURE 11. VENT SYSTEM BEAM MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION	27
FIGURE 12. VENT HEADER/DOWNCOMER INTERSECTION MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION	28
FIGURE 13. FREE AND LOCAL SHELL REGIONS FOR THE VENT HEADER, NINE MILE POINT UNIT 1 NUCLEAR STATION	29
FIGURE 14. PERMISSIBLE SIZE RANGE FOR INDICATION, VENT PIPE, NINE MILE POINT UNIT 1 NUCLEAR STATION	30
FIGURE 15. PERMISSIBLE SIZE RANGE FOR INDICATION, VENT HEADER, NINE MILE POINT UNIT 1 NUCLEAR STATION	31



	<u>PAGE</u>
FIGURE 16. PERMISSIBLE SIZE RANGE FOR INDICATION, DOWNCOMER, NINE MILE POINT UNIT 1 NUCLEAR STATION	32
FIGURE 17. PERMISSIBLE SIZE RANGE FOR INDICATION, VENT SPHERE, NINE MILE POINT UNIT 1 NUCLEAR STATION	33
FIGURE 18. VENT SPHERE LOCAL THICKNESS REGIONS, NINE MILE POINT UNIT 1 NUCLEAR STATION	34





1.0 INTRODUCTION

Teledyne Engineering Services (TES) has been requested by Niagara Mohawk Power Corporation (NMPC) (Reference 1) to review the Mark I Torus Containment Program analysis of the torus and vent system to determine the shell thickness requirements for these vessel components.

The torus shell analysis of record will be reviewed herein using available information to:

1. Map the profile of the required minimum shell thickness for the symmetric torus bays.
2. Determine the permissible local reduction in shell thickness at midbay bottom dead center, the location of least margin, for a range of postulated indications.
3. Review the Nine Mile Point Nuclear Station Certified Material Test Reports (Reference 2) for the torus shell plate material to determine if an additional margin exists when compared to the appropriate design stress intensity values from the Code.

In addition, TES will review the existing vent system analysis to:

1. Determine the corrosion allowance used for the analysis, if any.
2. Review all critical vent system shell locations calculating the minimum required shell thickness based on the present Mark I event loading combinations.
3. Identify and report on analysis conservatisms which might significantly decrease the required minimum wall thickness with additional refinement, if any.



2.0 TORUS SHELL ANALYSIS

TES had previously determined that the Mark I Program analysis of record for the torus shell took advantage of the full as-built vessel thickness (Reference 3). In reviewing the documentation, it was determined that both the full thickness and the refinement by GE to the drywell vent system pressurization transient were required to comply with the Code (Reference 4) requirements for the torus shell stress at the midbay (free-shell) locations for the specified event combinations (Reference 5). These event combinations include both the original design loads and Mark I Program loads per the structural acceptance criteria (Reference 6).

It should be noted that along with the use of the full torus shell thickness in the analysis of record its availability had been appropriately verified by NMPC using ultrasonic thickness measurements (Reference 7).

During the review of this documentation TES determined that the torus shell analysis conservatisms had been previously considered and eliminated as a practical consideration for demonstrating compliance with the Code requirements during the original evaluation. Some of the important refinements which eliminated the analysis conservatism and reduced the number of modifications at the Nine Mile Point include:

- Use of a Y-quencher in place of the standard T-quencher for mitigation of SRV loading.
- Use of in-situ SRV testing to reduce the conservatism in the GE load definition.
- TES in-house development of the torus shell stress postprocessing program DISTRESS to handle the many computer analyses for the various loading conditions, to combine all data on a component stress level, and to produce final results for the 27 Mark I event combinations.



- Redefinition of the condensation oscillation loading function in the time domain to account for load phasing.
- Development of an improved methodology to enforce compatibility between the torus shell and the attached piping systems.

Therefore, it is our opinion that additional refinement of the Mark I torus shell analysis would not be practical to increase the margin on torus shell thickness.

2.1 Minimum Torus Shell Thickness Requirements

TES has reviewed the torus shell analysis package (Reference 8) and associated computer output from our one-fortieth Stardyne (Reference 9) finite-element computer model (Figures 1 and 2) to obtain event combination stress output at specific locations from our DISTRESS torus shell stress postprocessor (Reference 10). Because of the large volume of data available for postprocessing during the Mark I Program, only those elements at critical locations as determined by preliminary scoping analyses had been postprocessed during the final analysis phase. These elements, which are located at midbay (free-shell) and adjacent to the ring girder (local shell), are shaded in Figures 3 and 4. It is our opinion that this information is adequate to determine the minimum thickness requirements since the major loads (i.e., pressure, DBA condensation oscillation, poolswell) are relatively constant along the longitudinal axis of the torus bay.

The minimum thickness requirements at the midbay (free-shell) location of the torus shell are governed by the primary membrane stress (P_M) obtained from the one-fortieth Stardyne model considering the various Mark I event combinations. For the torus shell adjacent to the ring girder (local shell), a gross structural discontinuity, the minimum thickness requirements are governed by the primary local stress (P_L). The primary local stress region extends for a distance of a 8.6325 inches or one-square-root-of-mean-radius-times-thickness ($1.0 \sqrt{Rt}$) from the intersection of the ring girder longitudinally along the torus bay (Figure 5).



Code compliance for primary membrane and primary local stress intensity shall be determined based on comparison of the actual event stress intensity (i.e., from the finite-element analysis of the torus shell) to the Code allowable stress which is a function of the event service limit as defined by the structural acceptance criteria (Reference 5).

<u>Stress Intensity</u>	<u>Service Limit Allowable</u>	
	<u>A or B</u>	<u>C</u>
P_M	SMC	Larger of 1.2 SMC or 1.0 S_y
P_L	1.5 SMC	Larger of 1.8 SMC or 1.5 S_y

The Mark I program event combinations to be reviewed are those which were previously found to control the torus shell stress analysis as bounding cases (Reference 11). They are event combinations 2, 3, 14, 15, 18, 19, 20, 21 and 25 (Figure 6). However, some of these event combinations can be eliminated from further consideration without increasing the conservatism as follows:

- Event combinations 2 and 3 are bounded by event combinations 14 and 15.
- The difference between event combinations, pairs 14 and 15, 18 and 19, 20 and 21, is OBE versus SSE seismic loading. The SSE load is marginally larger (i.e., much less than 20%) than the OBE load in all cases. For these pairs, the higher event numbers (i.e., the SSE event) are Level C service limit events with a minimum 20% increase in allowable stress. Therefore, the Level B lower event numbers 14, 18, and 20 will control the analyses.

Therefore, the remaining event combinations to be reviewed are 14, 18, 20 and 25.



Calculation of the minimum thickness herein is based on the determination of an equivalent pressure (P_0) which will yield a hoop membrane stress equal to the event combination primary membrane or local stress intensity. Then, solving for the required minimum thickness based on compliance with the Code allowable stress intensity:

$$\begin{aligned} & (P_0)R/t \leq SMC \text{ for } P_M \\ \text{or} & (P_0)R/t \leq 1.5 SMC \text{ for } P_L \end{aligned}$$

where P_0 - equivalent pressure (psi)
 R - torus radius (162 inches)
 t - required thickness (i.e., ≤ 0.46)

Table 1 provides the minimum thickness requirements as calculated in Appendix A for the two torus shell locations adjacent to the ring girder (local shell region) and at midbay (free-shell region). Figures 7 and 8 represent this data plotted as the permissible corroded thickness on the torus cross sections. As previously suggested, the thickness requirements adjacent to the ring girder extend longitudinally 8.6325 inches along the torus shell. In addition, on the torus shell mitre side of the ring girder, the local region shall extend 8.6325 inches beyond the mitre away from the ring girder (Figure 5). The remainder of the torus shell is governed by the midbay thickness requirements.

2.2 Permissible Local Reduction in Torus Shell Thickness for an Indication

An indication, which may be found upon inspection of the torus shell (Figure 5), may be acceptable if it does not meet the screening criteria of 2.1, Table 1, for required shell thickness (Figures 7 and 8) provided that it meets the local stress criteria of the Code for the particular location of concern.

A generalized compatibility analysis to determine the effect of a cylindrical depression on a uniform stress distribution was performed (Appendix B) for a large circular plate of constant thickness.



Figure 9 for the free shell and Figure 10 for the local shell regions of the torus are based upon this analysis using the necessary Nine Mile Point torus parameters. Therefore, if an indication is found in these regions which does not meet the minimum wall thickness requirements of Table 1 or Figure 7 (the permissible corroded thickness of the local shell region adjacent to the ring girder) or Figure 8 (the permissible corroded thickness of the free-shell region), the following procedure may be performed using the appropriate Figure 9 or Figure 10.

The procedure for use of Figures 9 and 10 for an indication in its final-blended and as-examined state is as follows:

1. Circumscribe the area of the indication and measure the diameter (D).
2. Determine the maximum indication depth (d).
3. Assure that no additional indications are found local to the circumscribed area within 21.5 inches or two-and-one-half-square-roots-of-mean-radius-times-thickness (i.e., $2.5 \sqrt{Rt}$).
4. If the criterion of step 3 is violated, repeat the procedure starting with step 1 and include any indications which violate the criterion of step 3 in the circumscribed area.
5. Review Figure 7 or 8 to determine the arc region (S) of the torus shell which contains the circumscribed indications resulting from step 1.
6. If the measured indication depth (d) is less than the permissible corroded thickness from the appropriate Figure 7 or 8, the indication is acceptable and the remaining steps 7 through 9 may be skipped.
7. Determine the circumscribed diameter multiplier (F) from the table of Figure 9 or 10 based on the arc region (S) from





step 5. If the circumscribed indications extend into other arc regions, use the largest multiplier (F) in step 7.

8. Determine the equivalent diameter (D') which circumscribes the indications:

$$D' = D \times F$$

9. Using D' and the appropriate Figure 9 or 10 curve, determine the allowable indications depth d' and compare it to the measured depth d .

$$d \leq d'$$

Note that the allowable depth (d') shall be measured based on the uncorroded nominal shell thickness. See Appendix E for sample calculations.

2.3 Certified Material Test Report Review for Torus Shell

TES has reviewed the Torus Shell Certified Material Test Reports (A201 Gr B FBX), which are provided for clarity in Appendix C. A statistical analysis was performed using this (large) sample data to determine the .99 confidence interval estimate of the mean yield and ultimate strength of this material.

The Code requires that the minimum yield and minimum ultimate strength of the material be used to determine the allowable stress intensity (S_{MC}) as follows:

S_{MC} at 70°F is the lessor of

$$1.1 \left[\frac{5}{8} S_{Y_{min}} \right] \quad \text{or} \quad 1.1 \left[\frac{1}{4} S_{U_{min}} \right]$$



Therefore, TES has assumed that the minimum yield and ultimate strengths of the material are bounded by using two sample standard deviations from the statistically estimated minimum mean values.

Based on the Appendix C calculations using the above stated criteria, the Code allowable stress intensity would be estimated at:

$$SMC = 17600 \text{ at } 70^{\circ}\text{F}$$

Use of this estimated allowable stress intensity will provide an additional 1100 psi relief as compared to the present Code allowable of 16500 psi which was used during the Mark I analysis for the torus shell material for the full range of anticipated event temperatures from 70 to 350°F. In terms of relief on the shell thickness requirements, the increased allowable will provide just under 1/32 inches or 6% additional margin.



3.0 VENT SYSTEM SHELL STRESS ANALYSIS

TES has reviewed the calculation packages (References 12 through 16) associated with the drywell vent system and has determined that the shell thicknesses used for the vent system components during the Mark I Torus Requalification Program analyses of record were not reduced for corrosion. This philosophy was consistent with the decisions made for the torus shell as described in Section 2.0. The vent system components analyzed for shell stress are the vent pipe, vent header, vent sphere, and downcomers.

The Mark I Torus Program vent system analyses (References 13, 15 and 16) were completed using a combination of hand calculations and two Stardyne (Reference 3) models; a beam model (Figure 11) for general loading (Reference 12); and a detailed finite-element model (Figure 12) for the downcomer/vent header intersection (References 14 and 20). The less detailed beam model analysis was possible in this case for two reasons: first, because GE provided the BWR Owner's Group detailed stress intensification factors for each specific BWR vent pipe/vent header intersection (i.e., the vent sphere, Reference 13), and secondly, because the anticipated stress levels in the vent system based on the initial scoping analyses appeared to be well within Code allowables for all components with the exception of the vent header at the downcomer intersection. The vent header/downcomer intersection eventually required a modification to the downcomer pairs, tie bars, even with the use of significantly more refined analytical techniques.

Generally, as a result of low stress levels and in accordance with our five BWR clients' wishes, the final vent system analyses were completed using conservative bounding techniques to reduce costs and to provide timely results. Loads in most cases were combined absolutely for the two event combinations analyzed. These two event combinations (Reference 13), a poolswell event (event combination 19) and a vent system chugging event (event combination 21), were determined to conservatively bound the remaining twenty-five combinations listed in the structural acceptance criteria (Reference 5). The resultant stress intensities were also conservatively calculated without regard to location and were compared to Code allowables.



Based on our recent review of this work, it does appear that an additional margin exists for some of the vent system components with regard to minimum shell thickness requirements and the remaining shell thicknesses available for corrosion to be reported on in Sections 3.1 and 3.2. It should be noted that the aforementioned analysis conservatism could be reduced, through a moderate effort, using less conservative stress analysis techniques and the presently available loads.

3.1 Minimum Vent System Shell Thickness Requirements

TES has reviewed the vent system analysis packages (References 13 and 14) to determine the minimum shell thickness requirements for each of the major components: the vent pipe, vent sphere, vent header and downcomers. The calculation of the minimum thickness requirements herein (A.2) is based on the methodology presented in Section 2.1 for the torus shell.

As described in Section 3.0, because of the known available margins, much of the vent system stress analysis was completed in a conservative fashion by hand. In most instances the amount of data presently available without completing a more refined analysis for each of the major components is limited. Therefore, additional conservative assumptions were required to determine the minimum vent system shell thickness requirements and resulting shell thickness remaining for corrosion for the major component locations as provided in Table 2. The vent header thickness requirements are determined for the free shell and the local shell regions adjacent to the mitred joint, the downcomer and vent sphere as defined in Figure 13.

3.2 Permissible Local Reduction in Vent System Thickness for an Indication

An indication which may be found upon inspection of the vent system components - the vent pipe, vent sphere, vent header, and downcomers - may be acceptable if it does not meet the screening criteria of 3.1, Table 2, provided that it meets the local stress criteria of the Code for the particular location of concern.



The generalized compatibility analysis of Appendix B, as described in Section 2.2, was used to perform these analyses as provided in B.2 and Figures 13 through 17 herein.

The procedure for the use of Figures 14 through 17 for an indication in its final-blended and as-examined state is as follows:

1. Circumscribe the area of the indication and measure the diameter (D).
2. Determine the maximum indication depth (d).
3. Assure that no additional indications are found local to the circumscribed area within two-and-one-half-square-roots-of-mean-radius-times-thickness (i.e., $2.5 \sqrt{Rt}$) as listed below.

<u>Vent System Component</u>	<u>Thickness in</u>	<u>Radius in</u>	<u>$2.5 \sqrt{Rt}$ in</u>
Vent Pipe	.3125	40.94	8.94
Vent Sphere	.3125	66.00	11.35
	.6875		16.84
	.8125		18.31
Vent Header	.3125	29.36	7.57
Downcomer	.25	12.25	4.38

4. If the criterion of step 3 is violated, repeat the procedure starting with step 1 and include any indications which violate the criterion of step 3 in the circumscribed area.
5. If the measured indication depth (d) is less than the permissible corroded thickness (remaining thickness) of Table 2 for the appropriate location, the indication is acceptable and the remaining steps may be skipped.





6. Review Figures 14 through 17 to determine the appropriate curve for the region of the vent system that contains the circumscribed indications.

7. Using D' and the appropriate figure and curve, determine the allowable indications depth d' and compare it to the measured depth d .

$$d \leq d'$$

Note that the allowable depth (d') shall be measured based on the uncorroded nominal shell thickness. See Appendix E for sample calculations.





4.0 REFERENCES

1. NMPC P.O. Number 62144 and Change Order Numbers 1 (11/3/87) and 3 (11/25/87).
2. Nine Mile Point Nuclear Station Certified Mill Reports, Stone and Webster Engineering Corporation, File Number 3-N2-S22.4.
3. TES Technical Report Number TR-6801-1, August 6, 1987, Verification of the Analyzed Corrosion Allowance, Mark I Torus Requalification Program, Nine Mile Point Unit 1.
4. ASME Boiler and Pressure Vessel Code, Section III, Division 1, Subsection NE, Class MC Vessels, 1974 Edition through Summer 1977 Addenda.
5. Mark I Containment Program, Structural Acceptance Criteria, Plant Unique Analysis Application Guide, Document Number NEDO-24583-1, October 1979.
6. Mark I Containment Program Load Definition Report, Document Number NEDO-21888, Rev.. 2, November 1981.
7. NMPC Letter F. A. Hawksley to R. M. Pace, "Suppression Chamber Thickness Measurements at Nine Mile Point Unit #1 Nuclear Station", April 26, 1979.
8. TES Analysis Package 5320-20, Nine Mile Point Torus Shell Analysis, September 6, 1984.
9. Stardyne User Information Manual, January 1984.
10. TES Computer Code TG-8, DISTRESS Computer Program Check, October 13, 1982.



11. TES Technical Report TR-5320-1, Mark I Containment Program, Plant Unique Analysis Report of the Torus Suppression Chamber for Nine Mile Point Unit 1.
12. TES Calculation Package 5320-10, Nine Mile Vent System Beam Model Geometry.
13. TES Calculation Package 5320-3, Nine Mile Point Vent System, Vent Pipe/Vent Header Intersection Analysis.
14. TES Calculation Package 5320-2, Nine Mile Point Vent System, Vent Header/Downcomer Intersection Analysis.
15. TES Calculation Package 5320-16, Torus Vent System Acoustic Pressure Loads Evaluation.
16. TES Calculation Package 5320-22, Nine Mile Point Fatigue Analysis Vent System.
17. Applied Business Statistics, Second Edition, Fadil H. Zuwaylif, May 1984.
18. CB&I Contract No. 9-1370, Drawing 316, Rev 3.
19. TES Project Quality Assurance Program, Project 6801, Revision 1, November 20, 1987, Niagara Mohawk Corporation.
20. TES Calculation Package 5320-5, Nine Mile Point, Vent Header/Downcomer Intersection Analysis, Downcomer Chugging and Condensation Loading.



TABLE 1		
MINIMUM TORUS SHELL THICKNESS REQUIREMENTS NINE MILE POINT UNIT 1 NUCLEAR STATION		
Element No. (Midbay)	Required Thickness (inches)	Remaining Thickness (inches)
11	.304	.156
13	.362	.098
15	.418	.042
17	.446	.014
19	.447	.013
21	.425	.035
23	.382	.078
25	.320	.140
27	.287	.173
(Ring Girder)		
123	.172	.288
129	.191	.269
135	.168	.292
141	.173	.287
147	.125	.335
153	.139	.321
159	.198	.262
NOTE: Only lower shell elements are listed.		



.

.

.

.

.

.

.

.

2203

TABLE 2			
MINIMUM VENT SYSTEM THICKNESS REQUIREMENTS NINE MILE POINT UNIT 1 NUCLEAR STATION			
Component Location	Shell Thickness (in)	Required Thickness (in)	Remaining Thickness (in)
Vent Pipe	.3125	.201	.1115
Vent Header	.3125	.159	.1535
Downcomer	.250	.222	.028
Vent Pipe at Drywell	.3125	.134	.1785
Vent Header at Mitre Joint	.3125	.203	.1095
Vent Header at Downcomer	.3125	.248	.0645
Downcomer at Mitre Joint	.250	.148	.102
Vent Sphere at t_1	.3125	.290	.0225
Vent Sphere at t_2	.6875	.637	.0505
Vent Sphere at t_3	.8125	.753	.0595







FIGURE 1. STARDYNE ONE-FORTIETH FINITE-ELEMENT COMPUTER MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION






NINE MILE NUCLEAR PLANT UNIT 1

FIGURE 2. STARDYNE ONE FORTIETH COMPUTER MODEL DIMENSIONS, NINE MILE POINT UNIT 1 NUCLEAR STATION



TORUS ELEMENTS

**NOTE: all units in inches
unless otherwise
stated.**




NINE MILE POINT NUCLEAR PLANT

FIGURE 3. STARDYNE TORUS MODEL UPPER SHELL SECTION, NINE MILE POINT UNIT 1 NUCLEAR STATION



TORUS ELEMENTS

NOTE: all units in inches
 unless otherwise
 stated.



NINE MILE POINT NUCLEAR PLANT

FIGURE 4. STARDYNE TORUS MODEL LOWER SHELL SECTION, NINE MILE POINT UNIT 1 NUCLEAR STATION



11

LOCAL TORUS SHELL STRESS REGIONS NINE MILE POINT UNIT 1 NUCLEAR STATION




FIGURE 5


4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

THE UNIVERSITY OF CHICAGO





PERMISSIBLE CORRODED THICKNESS
FOR THE TORUS CROSS-SECTION
ADJACENT TO RING-GIRDER
(LOCAL SHELL REGION)
NINE MILE POINT UNIT 1 NUCLEAR STATION




NOTE: INTERMEDIATE
VALUES MAY BE
SCALED

FIGURE 7



PERMISSIBLE CORRODED THICKNESS
FOR THE TORUS CROSS-SECTION AT MID-BAY
(FREE SHELL REGION)
NINE MILE POINT UNIT 1 NUCLEAR STATION





NOTE: INTERMEDIATE
VALUES MAY BE
SCALED

FIGURE 8



PERMISSIBLE SIZE RANGE FOR INDICATION
FREE SHELL REGION OF THE TORUS
NINE MILE POINT UNIT 1 NUCLEAR STATION




ARC REGION	FACTOR "F"	GEN. CORR. t_c
S1	0.800	0.173
S2	0.851	0.140
S3	0.930	0.078
S4	0.974	0.035
S5	1.000	0.013
S6	1.000	0.014
S7	0.965	0.042
S8	0.904	0.098
S9	0.824	0.156


FIGURE 9



PERMISSIBLE SIZE RANGE FOR INDICATION
RING GIRDER REGION OF THE TORUS
NINE MILE POINT UNIT 1 NUCLEAR STATION



D X F = D' (in)



ARC REGION	FACTOR "F"	GEN. CORR. t_c
S1	1.000	0.262
S2	0.839	0.321
S3	0.796	0.335
S4	0.935	0.287
S5	0.925	0.292
S6	0.925	0.292
S7	0.978	0.269
S8	0.935	0.288

FIGURE 10






FIGURE 11. VENT SYSTEM BEAM MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION







FIGURE 12. VENT HEADER/DOWNCOMER INTERSECTION MODEL, NINE MILE POINT UNIT 1 NUCLEAR STATION



FREE AND LOCAL SHELL REGIONS
FOR THE VENT HEADER
NINE MILE POINT UNIT 1 NUCLEAR STATION



* LOCAL REGIONS ($1.0 \sqrt{RT} = 3.03"$)

FIGURE 13



PERMISSIBLE SIZE RANGE FOR INDICATION VENT PIPE NINE MILE POINT UNIT 1 NUCLEAR STATION





FIGURE 14



PERMISSIBLE SIZE RANGE FOR INDICATION VENT HEADER NINE MILE POINT UNIT 1 NUCLEAR STATION





FIGURE 15



PERMISSIBLE SIZE RANGE FOR INDICATION DOWNCOMER NINE MILE POINT UNIT 1 NUCLEAR STATION





FIGURE 16



PERMISSIBLE SIZE RANGE FOR INDICATION VENT SPHERE
 NINE MILE POINT UNIT 1 NUCLEAR STATION





FIGURE 17



VENT SPHERE LOCAL THICKNESS REGIONS NINE MILE POINT UNIT 1 NUCLEAR STATION




FIGURE 18



APPENDIX A

TORUS AND VENT SYSTEM REQUIRED SHELL THICKNESS CALCULATIONS

The calculations herein were performed using the Mark I Analysis of Record for Nine Mile Point Unit 1. The minimum thickness requirements are based on the analyzed state of stress for the postulated Mark I event combinations.



APPENDIX A.1

TORUS SHELL THICKNESS CALCULATIONS



BY RJE DATE 12-10-87
CHKD. BY IMP DATE 12-18-87

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 3 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

DETERMINATION OF MINIMUM SHELL THICKNESS REQUIRED

THE MINIMUM TORUS SHELL THICKNESS IS BASED ON THE EQUIVALENT HOOP PRESSURE STRESS WHICH WOULD BE EQUAL TO THE MARK I PROGRAM, EVENT COMBINATION PRIMARY MEMBRANE OR LOCAL MEMBRANE STRESS INTENSITY.

$$P_M = \frac{PR}{t} \leq S_{mc}$$

$$P_L = \frac{PR}{t} \leq 1.5 S_{mc}$$

THE PRIMARY LOCAL STRESS REGION EXTENDS FOR A LONGITUDINAL DISTANCE OF $1.0 \sqrt{Rt}$ FROM THE INTERSECTION OF THE SHELL AND RING GIRDER.

$$1.0 \sqrt{Rt} = 1.0 \sqrt{162'' (0.460'')} = 8.6325'' \text{ (REF. A)}$$

THE TORUS SHELL THICKNESS USED IN THE NINE MILE POINT UNIT 1 MARK I CONTAINMENT ANALYSIS IS 0.460 INCHES, (NO CORROSION ALLOWANCE WAS USED.). ALL MARK I LOADINGS (EXCLUDING DEADWEIGHT AND SEISMIC CASES) WERE INPUT AS INTERNAL PRESSURE LOADINGS. IT IS



 **TELEDYNE ENGINEERING SERVICES**

BY RAC DATE 12-10-87
CHKD. BY RMP DATE 12-18-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 4 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

DETERMINATION OF MINIMUM SHELL THICKNESS REQUIRED
(CONTINUED)

CONSERVATIVE TO CONSIDER THE TOTAL COMBINED
EVENT LOADING AS AN INTERNAL PRESSURE CASE.
THUS, THE MINIMUM WALL THICKNESS CAN BE
CALCULATED WITH THE FOLLOWING EQUATIONS:

MID-BAY


$$t_{min} = \frac{P_m (0.460^{in})}{S} \quad \{EQ. No 1\}$$

RING GIRDER

$$t_{min} = \frac{P_L (0.460^{in})}{1.5 S} \quad \{EQ. No. 2\}$$

<u>WHERE :</u>	<u>STRESS</u> <u>INTENSITY</u>	<u>SERVICE LIMIT ALLOWABLE (S)</u>		
		<u>A</u>	<u>B</u>	<u>C</u>
	P_m	S_{mc}	S_{mc}	LARGER OF $1.2 S_{mc}$ or $1.0 S_y$
	P_L	$1.5 S_{mc}$	$1.5 S_{mc}$	LARGER OF $1.8 S_{mc}$ or $1.5 S_y$

(REFERENCE 4)



TELEDYNE ENGINEERING SERVICES

BY KNS DATE 12-11-87
CHKD. BY RMP DATE 12-18-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 5 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
PRIMARY MEMBRANE STRESS t_{min}

<u>ELEMENT No.</u>	<u>EVENT 1A P_M (REF 8)</u>	<u>ALLOWABLE S_{MC} (REF 11)</u>	<u>t_{min} (USING EQ-1)</u>
11	10,568. Psi	16,500. Psi ↓ (1.5 S _{MC})	.295 ⁱⁿ
13	11,595.		.323
15	12,575.		.351
17	12,576.		.351
19	13,232.		.369
21	12,426.		.346
23	11,965.		.334
25	10,912.		.304
27	10,289.		.287
	<u>(P_L)</u>		
123	7,247. Psi	24,750. Psi	.135 ⁱⁿ
129	7,796.	↓	.145
135	9,040.		.168
141	9,325.		.173
147	6,712.		.125
153	7,459.		.139
159	8,282.		.154
165	8,824.		.164
171	8,361.		.155

(Level B)



TELEDYNE ENGINEERING SERVICES

BY RAS DATE 12-11-87
CHKD. BY EMP DATE 12-19-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 6 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL
PRIMARY MEMBRANE SHELL t_{MIN}

<u>ELEMENT NO.</u>	<u>EVENT 18 PM (REF 8)</u>	<u>ALLOWABLE S_{MC} (REF 11)</u>	<u>t_{MIN} (USING EQ-1)</u>
11	3,293. psi	↓	.092 ^{IN}
13	4,436.		.124
15	6,506.		.181
17	7,668.		.214
19	7,812.		.218
21	7,251.		.202
23	4,826.		.134
25	5,130.		.143
27	3,611.		.101
	<u>(P_L)</u>		<u>(1.5 S_{MC})</u>
123	9,260.	24,750.	.172
129	10,265.	↓	.191
135	6,944.		.129
141	4,752.		.088
147	4,423.		.082
153	5,652.		.105
159	10,078.		.187
165	13,187.		.245
171	12,225.		.227

(Level B)



TELEDYNE ENGINEERING SERVICES

BY KAS DATE 12-11-87
CHKD. BY LM DATE 12-19-91

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 7 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL
PRIMARY MEMBRANE STRESS t_{MIN}

<u>ELEMENT NO.</u>	<u>EVENT 2D P_M (REF 8)</u>	<u>ALLOWABLE S_{MC} (REF 11)</u>	<u>t_{MIN} (USING EQ-1)</u>
11	10,902. psi	16,500. psi ↓	.304
13	12,975.		.362
15	14,988.		.418
17	16,005.		.446
19	16,025.		.447
21	15,231.		.425
23	13,706.		.382
25	11,493.		.320
27	9,791.		.273
	<u>(P_L)</u>		<u>(1.5 S_{MC})</u>
123	9,033.	24,750.	.168
129	8,368.	↓	.156
135	7,398.		.137
141	6,037.		.112
147	6,742.		.125
153	7,003.		.130
159	10,644.		.198
165	10,033.		.186
171	10,464.		.194

(Level B)



TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-11-87
CHKD. BY RMP DATE 12-19-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 3 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL
PRIMARY MEMBRANE STRESS ϵ_{MIN}

<u>ELEMENT</u> <u>No.</u>	<u>EVENT 25</u> <u>P_M</u> <u>(REF 8)</u>	<u>ALLOWABLE</u> <u>S_y</u> <u>(REF 11)</u>	<u>ϵ_{MIN}</u> <u>(Using EQ-1)</u>
11	3,934.	32,000. psi ↓	.057
13	5,737.		.082
15	7,362.		.106
17	9,251.		.133
19	8,920.		.128
21	7,585.		.109
23	5,907.		.085
25	7,511.		.108
27	4,657.		.067
	<u>(P_L)</u>		<u>(15 S_y)</u>
123	13,612.	48,000.	.130
129	12,339.	↓	.118
135	10,678.		.102
141	8,480.		.081
147	5,931.		.057
153	8,554.		.082
159	13,687.		.131
165	18,738.		.180
171	14,747.		.141

(Level C)



BY RNE DATE 12-11-87
CHKD. BY JM DATE 12-18-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 1 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

MEMBRANE MINIMUM SHELL THICKNESS SUMMARY

ELEMENT NO.	EVENT				GOVERNING t_{min}
	14	18	20	25	
11	.295 ^{IN}	.092 ^{IN}	.304 ^{IN}	.057 ^{IN}	.304 ^{IN}
13	.323	.124	.362	.082	.362
15	.351	.181	.418	.106	.418
17	.351	.214	.446	.133	.446
19	.369	.218	.447	.128	.447
21	.346	.202	.425	.109	.425
23	.334	.134	.382	.085	.382
25	.304	.143	.320	.108	.320
27	.287	.101	.273	.067	.287
123	.135	.172	.168	.130	.172
129	.145	.191	.156	.118	.191
135	.168	.129	.137	.102	.168
141	.173	.088	.112	.081	.173
147	.125	.082	.125	.057	.125
153	.139	.105	.130	.082	.139
159	.154	.187	.198	.131	.198
165	.164	.245	.186	.180	.245
171	.155	.227	.194	.141	.227



 **TELEDYNE ENGINEERING SERVICES**

BY RSE DATE 12-16-87
CHKD. BY fwf DATE 12-18-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**


SHEET NO. 10 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

MINIMUM THICKNESS REQUIREMENTS

<u>ELEMENT NO.</u> <u>(MID - BAY)</u>	<u>REQUIRED</u> <u>THICKNESS</u>	<u>REMAINING</u> <u>THICKNESS</u>
11	.304 ^{IN}	.156 ^{IN}
13	.362	.098
15	.418	.042
17	.446	.014
19	.447	.013
21	.425	.035
23	.382	.078
25	.320	.140
27	.287	.173
<u>(RING GIRDER)</u>		
123	.172 ^{IN}	.288 ^{IN}
129	.191	.269
135	.168	.292
141	.173	.287
147	.125	.335
153	.139	.321
159	.198	.262

NOTE: ONLY LOWER SHELL ELEMENTS LISTED




TELEDYNE ENGINEERING SERVICES

BY RME DATE 12-18-87
CHKD. BY RMP DATE 12-21-87

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 11 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL
LONGITUDINAL LOCATION GUIDE FOR REMAINING THICKNESS






TELEDYNE ENGINEERING SERVICES

BY RVE DATE 12-18-87
CHKD. BY RMP DATE 12-21-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 17 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL
RING GIRDER/MITRE REMAINING THICKNESS



11
12
13




TELEDYNE ENGINEERING SERVICES

BY RME DATE 12-17-87
CHKD. BY IMP DATE 12-21-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
MID-BAY REMAINING THICKNESS



- S₁ = 254.5" /
- S₂ = 226.2" /
- S₃ = 169.6" /
- S₄ = 113.1" /
- S₅ = 56.5" /
- S₆ = 84.8" /
- S₇ = 141.4" /
- S₈ = 197.9" /
- S₉ = 254.5" /

(SCALE
1 to 30)

← REACTOR
(INSIDE)

(OUTSIDE)

⊕
BOTTOM



APPENDIX A.2

VENT SYSTEM THICKNESS CALCULATIONS

The vent system thickness calculations were performed using a similar methodology to that of the torus shell in A.1.

20

1

2000




TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-17-87
CHKD. BY RMF DATE 12-22-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
TYPICAL VENT SYSTEM CONFIGURATION
(REFERENCE 12)





TELEDYNE ENGINEERING SERVICES

BY KNE DATE 12-17-87
CHKD. BY PM DATE 12-22-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
PRIMARY MEMBRANE SHELL t_{MIN}

<u>COMPONENT</u> <u>LOCATION</u>	<u>SHELL</u> <u>THICKNESS</u> (REFERENCE 12)	<u>EVENT 19</u> <u>PM</u> (REFERENCE 13)	<u>ALLOWABLE</u> <u>S_{MC}</u>	<u>t_{MIN}</u> <u>(EQ-1)</u>
VENT PIPE	.3125 ^{IN}	10,194. Psi	16,500. Psi	.193 ^{IN}
VENT HEADER	.3125	7,081. *	↓	.134
DOWNCOMER	.250	9,729.		.147
		<u>EVENT 21</u> <u>PM</u>		
VENT PIPE	.3125 ^{IN}	10,628. Psi	16,500. Psi	.201 ^{IN}
VENT HEADER	.3125	8,380. *	↓	.159
DOWNCOMER	.250	14,673.		.222

* STRESSES UNINTENSIFIED ARE REPRESENTATIVE OF VENT HEADER PIPE, WHEN INTENSIFIED WITH "GE FACTORS" THEY REPRESENT THE INTERSECTION STRESSES AT THE SPHERE.



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-17-87
CHKD. BY AW DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
LOCAL MEMBRANE SHELL t_{MIN}

COMPONENT LOCATION	SHELL THICKNESS (REF 12)	EVENT 19 PL (REF 13 AND 14)	ALLOWABLE 1.5 S _{mc}	t_{MIN} (EQ-2)
VENT PIPE @ DRYWELL	.3125 ^{IN}	10,194. PSI	24,750. PSI	.129 ^{IN}
VENT HEADER @ MITRE JOINT	.3125	14,721.	↓	.186
VENT HEADER @ DOWNCOMER	.3125	10,421.		.105
DOWNCOMER @ MITRE JOINT	.250	9,729.		.698

EVENT 21
PL

VENT PIPE @ DRYWELL	.3125	10,628. PSI	24,750. PSI	.134 ^{IN}
VENT HEADER @ MITRE JOINT	.3125	16,063.	↓	.203
VENT HEADER @ DOWNCOMER	.3125	24,600.		.248
DOWNCOMER @ MITRE JOINT	.250	14,673.		.148

100
100
100



TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-18-87
CHKD. BY AWP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**


SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
LOCAL MEMBRANE SHELL t_{min} (CONT'D)

COMPONENT LOCATION	SHELL THICKNESS (REF 18)	EVENT 19 P_L (REF 13)	ALLOWABLE 1.5 S_{mc}	t_{min} (EQ-2)
VENT SPHERE @ t_1	.3125 ^{IN}	19,689. PSI	24,750. PSI	.248 ^{IN}
VENT SPHERE @ t_2	.6875	↓	↓	.547
VENT SPHERE @ t_3	.8125	↓	↓	.646

EVENT 21
 P_L

VENT SPHERE @ t_1	.3125 ^{IN}	22,936. PSI	24,750. PSI	.290 ^{IN}
VENT SPHERE @ t_2	.6875	↓	↓	.637
VENT SPHERE @ t_3	.8125	↓	↓	.753



 **TELEDYNE ENGINEERING SERVICES**

BY RKE DATE 12-18-87
CHKD. BY SLP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

MINIMUM THICKNESS REQUIREMENTS

<u>COMPONENT</u> <u>LOCATION</u>	<u>SHELL</u> <u>THICKNESS</u>	<u>REQUIRED</u> <u>THICKNESS</u>	<u>REMAINING</u> <u>THICKNESS</u>
VENT PIPE	.3125 ^{IN}	.201 ^{IN}	.1115 ^{IN}
VENT HEADER	.3125	.159	.1535
DOWNCOMER	.250	.222	.028
VENT PIPE @ DRYWELL	.3125	.134	.1785
VENT HEADER @ MITRE JOINT	.3125	.203	.1095
VENT HEADER @ DOWN COMER	.3125	.248	.0645
DOWNCOMER @ MITRE JOINT	.250	.148	.102
VENT SPHERE @ t ₁	.3125	.290	.0225
VENT SPHERE @ t ₂	.6875	.637	.0505
VENT SPHERE @ t ₃	.8125	.753	.0595



APPENDIX B

PERMISSIBLE INDICATION SIZE CALCULATIONS

The general calculations contained in this appendix consider the discontinuity effects resulting from a localized indication to determine the range of permissible indication sizes in the presence of general membrane stresses for Class MC pressure vessel.

B.1 and B.2 use the general results to specifically address the torus shell and vent system range of permissible indication sizes.




BY RME DATE 12-16-87
CHKD. BY RMP DATE 12-21-87


**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
PERMISSIBLE INDICATION SIZE CLASS MC VESSEL



(Scale 1 to 30)



- D = dia. of reduced thickness
- d = Maximum depth
- T_0 = Original thickness
- P_0 = Pressure Normal to Surface
- S = Allowable Membrane Stress



BY WLL DATE 7-9-74
CHKD. BY GM DATE 4-22-79


**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 1 OF
PROJ. NO. 6801

Consider a large circular plate of thickness T_0 subject to a uniform membrane stress σ_0 which may be less than or equal to the allowable general membrane stress S_m . Let the plate contain a cylindrical depression of diameter D and depth d . How may D and d be varied without exceeding the limits on local membrane stress intensity or on local membrane plus primary bending stress intensity, both of which are $1.5S_m$. In considering primary bending, the effects of a lateral pressure P_0 will have to be considered.

$$D = 2R$$

$$t = T_0 - d$$





BY MLB DATE 790424
CHKD. BY GM DATE 4-27-79

**NMP-1 SHELL THICKNESS
REQUIREMENTS. 6801-2**

SHEET NO. 2 OF
PROJ. NO. 6801

Primary bending stress in plug:

Maximum at center, tensile on top

$$S_p = \frac{3(3+\nu)R^2 P_0}{8 t^2} \quad \dots \text{(Timoshenko, Plates & Shells, Eq. (71))} \quad (1)$$

Plug deformation

$$S_{ot} = \frac{(1-\nu)R H_t}{E t} \quad (2)$$

$$\theta_{ot} = \frac{12(1-\nu)R M_t}{E t^3} + \frac{3(1-\nu)R^3 P_0}{2 E t^3} \quad \text{(Roark)} \quad (3)$$

Plate deformation

$$S_{CT} = R \epsilon_{\theta R}$$

$\epsilon_{\theta R}$ = hoop strain at radius R

$$= \frac{1}{E} [\sigma_{\theta} - \nu \sigma_r]$$

For an internal pressure p_i and an external pressure p_o ; and an internal radius a and external radius b ; and, evaluating at radius a

$$\sigma_{\theta} = - \frac{a^2 b^2 (p_o - p_i)}{b^2 - a^2} \left(\frac{1}{a}\right)^2 + \frac{p_i a^2 - p_o b^2}{b^2 - a^2} \quad \text{(Timoshenko, Th)} \\ \text{(Elw., Eq (45))}$$

divide by b^2 , let $b^2 \rightarrow \infty$

$$\sigma_{\theta} = - (p_o - p_i) - p_o = - 2p_o + p_i$$

so that

$$\sigma_{\theta} = 2 \sigma_0 - \frac{H_T}{T_0}$$

$$\sigma_r = \frac{H_T}{T_0}$$

and



BY W.H. DATE 7/04/79
CHKD. BY G.M. DATE 4-27-79

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 3 OF
PROJ. NO. 6801

$$\delta_{CT} = \frac{R}{E} \left[2\sigma_0 - \frac{H_T}{T_0} - \nu \frac{H_T}{T_0} \right]$$

or

$$\delta_{CT} = \frac{R}{E} \left[2\sigma_0 - (1+\nu) \frac{H_T}{T_0} \right] \quad (4)$$

The rotation of a circular plate of radius a containing a hole of radius b and subject to a moment M_1 around the hole is evaluated at $r = b$

$$\frac{dw}{dr} = \frac{a^2 b^2 M_1}{D(1-\nu)(a^2 - b^2)} \left[\frac{1}{b} + \frac{1-\nu}{1+\nu} \frac{b}{a^2} \right] \quad \left(\begin{array}{l} \text{Timoshenko} \\ \text{Eq. 7.2} \end{array} \right)$$

Dividing by a^2 , let $a \rightarrow \infty$

$$\frac{dw}{dr} = \frac{b M_1}{D(1-\nu)} = \frac{12 b M_1 (1-\nu^2)}{E t^3 (1-\nu)} = \frac{12 b M_1}{E t^3} (1+\nu)$$

whence

$$\theta_{CT} = - \frac{12 R M_T}{E T_0^3} (1+\nu) \quad (5)$$

The displacement and rotation at point O are related to those at point C as follows:


$$\theta_{OT} = \theta_{CT} \quad (6)$$

$$\delta_{OT} = \delta_{CT} = \frac{1}{2} (T_0 - t) \theta_{CT} \quad (7)$$

Therefore:

$$\theta_{OT} = - \frac{12 R M_T}{E T_0^3} (1+\nu) \quad (8)$$

and



BY ZM DATE 7/20/24
CHKD. BY GM DATE 4-27-79

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 4 OF _____
PROJ. NO. 6801

$$\delta_{OT} = \frac{R}{E} \left[2\sigma_0 - (1+\nu) \frac{H_T}{T_0} \right] - \frac{1}{2} (T_0 - t) \left(- \frac{12 R M_T}{E T_0^3} \right) (1+\nu)$$

$$\delta_{OT} = \frac{R}{E} \left[2\sigma_0 - (1+\nu) \frac{H_T}{T_0} + \frac{6 (T_0 - t) M_T}{T_0^3} (1+\nu) \right] \quad (9)$$

For equilibrium of internal forces and moments:

$$H_T = H_t \quad (10)$$

$$M_T = M_t - \frac{1}{2} (T_0 - t) H_t \quad (11)$$

Substituting (10) and (11) in (8) and (9)

$$\theta_{OT} = - \frac{12 R}{E T_0^3} \left[M_t - \frac{1}{2} (T_0 - t) H_t \right] (1+\nu) \quad (12)$$

$$\delta_{OT} = \frac{R}{E} \left\{ 2\sigma_0 - (1+\nu) \frac{H_t}{T_0} + \frac{6 (T_0 - t)}{T_0^3} \left[M_t - \frac{1}{2} (T_0 - t) H_t \right] (1+\nu) \right\}$$

$$= \frac{R}{E} \left\{ 2\sigma_0 + \frac{6 (1+\nu) (T_0 - t)}{T_0^3} M_t - (1+\nu) \left[\frac{1}{T_0} + \frac{3 (T_0 - t)^2}{T_0^3} \right] H_t \right\}$$

$$\delta_{OT} = \frac{R}{E} \left\{ 2\sigma_0 + \frac{6 (1+\nu) (T_0 - t) M_t}{T_0^3} - (1+\nu) \left[1 + \frac{3 (T_0 - t)^2}{T_0^2} \right] \frac{H_t}{T_0} \right\} \quad (13)$$

For compatibility:

$$\delta_{Ot} = \delta_{OT} \quad (14)$$

$$\theta_{Ot} = \theta_{OT} \quad (15)$$

Substituting (2) and (13) in (14)



BY RM DATE 2/20/79
CHKD. BY GM DATE 4-27-79

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 5 OF
PROJ. NO. 6801

$$\frac{(1-\nu)R H_t}{Et} = \frac{R}{E} \left\{ 2\sigma_0 + \frac{6(1+\nu)(T_0-t)M_t}{T_0^3} (1+\nu) \left[1 + 3\frac{(T_0-t)^2}{T_0^2} \right] \frac{H_t}{T_0} \right\}$$

$$\left[\frac{(1-\nu)}{t} + \frac{(1+\nu)}{T_0} + \frac{3(1+\nu)(T_0-t)^2}{T_0^3} \right] H_t - \frac{6(1+\nu)(T_0-t)}{T_0^3} M_t = 2\sigma_0$$

$$\left[(1-\nu) + (1+\nu)\left(\frac{t}{T_0}\right) + 3(1+\nu)\left(\frac{t}{T_0}\right)^2 \left(1 - \frac{t}{T_0}\right) \right] \frac{H_t}{t} - 6(1+\nu) \left(1 - \frac{t}{T_0}\right) \frac{M_t}{t} = 2\sigma_0$$

Let $\frac{t}{T_0} = \lambda$

$$\left[1 - \nu + \lambda + 3(1-\nu)\lambda^2 \right] \frac{H_t}{t} - 6(1-\nu)\lambda \frac{M_t}{t} = 2\sigma_0$$

$$\left[\frac{1+\nu}{1-\nu} + \lambda + 3\lambda^2 - 6\lambda^2 + 3\lambda^3 \right] \frac{H_t}{t} - 6\lambda^2 \frac{M_t}{t} = 2\sigma_0$$

$$\left[\frac{1+\nu}{1-\nu} + 4\lambda - 3\lambda^2 + 3\lambda^3 \right] \frac{H_t}{t} - 6\lambda^2 \frac{M_t}{t} = 2\sigma_0$$


From which

$$\frac{M_t}{t} = \frac{\left[\frac{1-\nu}{1+\nu} + 4\lambda - 3\lambda^2 + 3\lambda^3 \right] \frac{H_t}{t} - 2\sigma_0}{6\lambda^2}$$

(16)

(17)

(18)



BY FAC DATE 7-14-77
CHKD. BY GM DATE 4-27-79

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 6 OF
PROJ. NO. 6801

Subst (3) and (12) in (15)

$$\frac{12(1-\nu)RM_4 + 3(1-\nu)R^3P_0}{Et^3} = - \frac{12(1+\nu)R}{ET_0^3} \left[M_t - \frac{1}{2}(T_0-t)H_t \right]$$

$$- \frac{2(1+\nu)(T_0-t)}{T_0^3} H_t + 4 \left[\frac{(1-\nu)}{t^3} + \frac{(1+\nu)}{T_0^3} \right] M_t = - \frac{(1-\nu)R^2P_0}{2t^3}$$

$$2(1+\nu)\left(1-\frac{t}{T_0}\right) \frac{H_t}{T_0^2} - 4 \left[\frac{(1-\nu)}{t} + \frac{(1+\nu)t^2}{T_0^3} \right] M_t = + \frac{(1-\nu)}{2t^2} \left(\frac{R}{t}\right)^2 P_0$$

$$2(1+\nu)\left(1-\frac{t}{T_0}\right) \left(\frac{t}{T_0}\right)^2 \frac{H_t}{t} - 4 \left[(1-\nu) + (1+\nu)\left(\frac{t}{T_0}\right)^3 \right] \frac{M_t}{t^2} = \frac{(1-\nu)}{2} \left(\frac{R}{t}\right)^2 P_0$$

$$\text{Using (16)} \quad - (1+\nu)(1-2) \frac{2}{t} \frac{H_t}{t} - 2 \left[(1-\nu) + (1+\nu)t^3 \right] \frac{M_t}{t^2} = \frac{(1-\nu)}{4} \left(\frac{R}{t}\right)^2 P_0$$

$$(1-2) \frac{2}{t} \frac{H_t}{t} + 2 \left[\frac{1-\nu}{1+\nu} + 2 \right] \frac{M_t}{t^2} = \frac{(1-\nu)}{4(1+\nu)} \left(\frac{R}{t}\right)^2 P_0 \quad (19)$$

Subst. (18) in (15)

$$(1-2) \frac{2}{t} \frac{H_t}{t} + 2 \left[\frac{1-\nu}{1+\nu} + 2 \right] \frac{M_t}{t^2} = \frac{\left\{ \left[\frac{(1-\nu)}{1+\nu} + 2 \right] \left[\frac{H_t}{t} + 2h - 2g - 2h + 2g \right] \right\}}{2(2-1) \frac{2}{t}} = \frac{4(1+\nu)h}{4(1+\nu)} \left(\frac{R}{t}\right)^2 P_0$$



BY ML DATE 7/20/42
CHKD. BY GM DATE 4-27-79

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 7 OF
PROJ. NO. 6801

(20)

$$\left\{ 2 \left[\frac{1-2}{1+2} + 2^3 \right] \frac{\sigma_0}{(1+2)} \left[\frac{(1+2)}{4} \right] \frac{r}{H} \right\} \left\{ \sigma_0 \left(\frac{R}{E} \right) \frac{r}{H} P_0 \right\} = \\
 = \left[\frac{1-2}{1+2} \right] \frac{r}{H} \frac{r}{H} + \left[\frac{1-2}{1+2} \right] \left[\frac{1+2}{1+2} \right] \left[\frac{1+2}{1+2} \right] \frac{r}{H} \frac{r}{H} + \\
 - 3 \frac{r}{H} \frac{r}{H} + 6 \frac{r}{H} \frac{r}{H} - 3 \frac{r}{H} \frac{r}{H} + \\
 + 2 \frac{r}{H} \frac{r}{H} - 6 \frac{r}{H} \frac{r}{H} + 3 \frac{r}{H} \frac{r}{H} + \\
 + 2 \frac{r}{H} \frac{r}{H} + \left[\frac{1-2}{1+2} \right] \left[\frac{1+2}{1+2} \right] \left[\frac{1+2}{1+2} \right] \frac{r}{H} \frac{r}{H} = \\
 \left\{ 2 \left[\frac{1-2}{1+2} \right] \frac{r}{H} \frac{r}{H} - \frac{3}{4} (1-2) \frac{r}{H} \frac{r}{H} \right\} \left\{ \sigma_0 \left(\frac{R}{E} \right) \frac{r}{H} P_0 \right\} \\
 = \frac{r}{H} \frac{r}{H} \left[2 \left(\frac{1-2}{1+2} \right) + \frac{3}{4} (1-2) \right] \sigma_0 \left(\frac{R}{E} \right) \frac{r}{H} P_0$$



BY ZM DATE 7-20-75
CHKD. BY GM DATE 4-27-79

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 8 OF
PROJ. NO. 6801

$$\frac{H_t}{t} = \frac{2 \left[\frac{1}{1+\nu} + \frac{\tau^3}{1-\nu} \right] \sigma_0 - \frac{3}{4} (1-\tau) \tau^2 \left(\frac{R}{t} \right)^2 P_0}{\frac{1-\nu}{1+\nu} + 4\tau - 6\tau^2 + 4\tau^3 + \left(\frac{1+\nu}{1-\nu} \right) \tau^4} \quad (20)$$

$$\begin{aligned} \text{Let } [A] &= \frac{1-\nu}{1+\nu} + 4\tau - 6\tau^2 + 4\tau^3 + \left(\frac{1+\nu}{1-\nu} \right) \tau^4 \\ [B] &= 2 \left[\frac{1}{1+\nu} + \frac{\tau^3}{1-\nu} \right] / [A] \\ [C] &= \frac{3}{4} (1-\tau) \tau^2 / A \end{aligned} \quad (21)$$

$\nu = 0.3$

Then

$$\frac{H_t}{t} = [B] \sigma_0 - [C] \left(\frac{R}{t} \right)^2 P_0$$

For t/t_0

	[A]	[B]	[C]	t/t_0
1.0	4.396	1.0	0	1.0
0.9	3.413	1.061	0.0178	0.9
0.821		1.100		0.821
0.9	2.707	1.109	0.0355	0.9
0.7	2.216	1.136	0.0497	0.7
0.6	1.883	1.145	0.0574	0.6
0.5	1.655	1.146	0.0567	0.5
0.4	1.482	1.161	0.0486	0.4
0.3	1.3215	1.223	0.0358	0.3
0.2	1.133	1.378	0.0212	0.2
0.156	1.033	1.500		0.156
0.1	0.883	1.746	0.0076	0.1
0	0.538	2.857	0	0



BY RLB DATE 7904W
CHKD. BY GM DATE 6-5-79

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 9 OF _____
PROJ. NO. 6801

The total local membrane plus primary bending stress is

$$P_L + P_b = [B] \sigma_0 - [C] \left(\frac{R}{t}\right)^2 P_0 + \frac{3(3+\nu)}{E} \left(\frac{R}{t}\right)^2 P_0$$

$$= [B] \sigma_0 + \{1.2375 - [C]\} \left(\frac{R}{t}\right)^2 P_0 \quad (22)$$

Noting that $0 \leq [C] < 0.06$, it is conservative to neglect the effects of $[C]$.

Then

$$P_L + P_b \leq [B] \sigma_0 + 1.2375 \left(\frac{R}{t}\right)^2 P_0 \quad (23)$$

The Code allowable is

$$(P_L + P_b) \leq 1.5 S_m \quad (24)$$

For Class MC S_m should be taken as S .

Therefore it is required that

$$[B] \sigma_0 + 1.2375 \left(\frac{R}{t}\right)^2 P_0 \leq 1.5 S \quad (25)$$

If there is no excess thickness, so

that $\sigma_0 = S$

$$1.2375 \left(\frac{R}{t}\right)^2 \left(\frac{P_0}{S}\right) \leq 1.5 - [B]$$

$$\text{OR} \quad \left(\frac{R}{t}\right)^2 \left(\frac{P_0}{S}\right) \leq \frac{1.5 - [B]}{1.2375}$$

$$\text{Since } \frac{R}{t} = \frac{D/2}{T_0 - d} = \frac{D/T_0}{2(1 - \frac{d}{T_0})}$$

it is required that

$$\frac{D}{T_0} \leq 2 \left[1 - \frac{d}{T_0}\right] \sqrt{\left(\frac{1.5 - [B]}{1.2375}\right) \frac{S}{P_0}} \quad (26)$$

1950-1951



TELEDYNE ENGINEERING SERVICES

BY MM DATE 7-5-79
CHKD. BY GM DATE 6-5-79


**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 10 OF _____
PROJ. NO. 801

For

$$\frac{t}{T_0} = 1 - \frac{d}{T_0} \quad \{B\} \quad 1.5 \{B\} \frac{D_0}{T} \sqrt{\frac{P_0}{S}} \leq 2 \left[1 - \frac{d}{T_0} \right] \sqrt{\frac{1.5 - 0.7}{1.2375}}$$


1.0	1.0	0.5	1.271
0.9	1.061	0.439	1.072
0.8	1.109	0.391	0.899
0.7	1.136	0.364	0.759
0.6	1.145	0.355	0.643
0.5	1.146	0.354	0.535
0.4	1.161	0.339	0.419
0.3	1.223	0.277	0.284
0.2	1.378	0.122	0.126
0.156	1.500	0	0



BY ZM DATE 7/04/79
CHKD. BY GM DATE 6-5-79

Permissible Local
Reduction in Thickness

SHEET NO. 11 OF _____
PROJ. NO. 6801





APPENDIX B.1

TORUS SHELL RANGE OF INDICATION SIZES

Specific dimensional data, the analyzed state of stress and the Code allowable stress intensity for the torus are used to determine the range of permissible indication sizes for the torus shell.

The results are based on the primary membrane stress intensities of A.1 and the general calculations for Class MC vessels provided in this appendix.



TELEDYNE ENGINEERING SERVICES

BY SE DATE 12-15-87
CHKD. BY RWP DATE 12-19-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONTINUED)

<u>ELEMENT</u> <u>NO.</u>	<u>GOVERNING</u> <u>P_M</u> (APPENDIX A.1)	<u>EQUIVALENT</u> <u>PRESS. = P₀</u>
11	10,902. Psi	31.0 psi
13	12,975.	36.4
15	14,938	42.6
17	16,005.	45.4
19	16,025.	45.5
21	15,231.	43.3
23	13,706.	38.9
25	11,493.	32.9
27	10,289. *	29.2

* FROM EVENT 14, ALL OTHERS FROM EVENT 20.

$$P_0 = \frac{P_M t}{R} = \frac{P_M (0.460'')}{162.0''}$$



TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-15-87
CHKD. BY RMP DATE 12-18-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TERNIS SHELL

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONTINUED)

<u>ELEMENT NO.</u>	<u>EQUIVALENT PRESSURE, P₀</u>	<u>$\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$</u>	<u>NOMINALIZED $\frac{D}{T_0} \sqrt{\frac{P_0}{S}} = D(f)$</u>
11	31.0 Psi	.094 D	0.824 D
13	36.9	.103 D	0.904 D
15	42.6	.110 D	0.965 D
17	45.4	.114 D	1.000 D
19	45.5	.114 D	1.000 D
21	43.3	.111 D	0.974 D
23	38.9	.106 D	0.930 D
25	32.9	.097 D	0.851 D
27	29.2	.091 D	0.800 D

WHERE: T_0 = SHELL THICKNESS = 0.460" ^{MIN}

S = PM ALLOWABLE STRESS - S_{mc} = 16,500. PSI



TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-16-87
CHKD. BY RM DATE 12-21-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

① $\frac{d}{T_0}$	② $d' = \frac{d}{T_0} (0.460")$	③ $\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	④ $\frac{③}{0.114} = D'_{Fmax}$	⑤ $\frac{④}{0.800} = D'_{Fmin}$
0.0	0.000	1.271	11.15	13.94
0.1	0.046	1.072	9.40	11.75
0.2	0.092	0.899	7.88	9.85
0.3	0.138	0.759	6.66	8.32
0.4	0.184	0.643	5.64	7.05
0.5	0.230	0.535	4.69	5.86
0.6	0.276	0.419	3.68	4.60
0.7	0.322	0.284	2.49	3.11
0.8	0.368	0.126	1.11	1.39
0.844	0.388	0.000	0.00	0.00
0.9	0.414			
1.0	0.460			

4
2
1





BY RAE DATE 12-16-87
 CHKD. BY RMP DATE 12/4/97
 REV. BY RAE 1-26-88
 CHKD. BY RMP 1-26-88


**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
 PROJ. NO. 6801

NMP-1 TORUS SHELL

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)





BY KKE DATE 12-18-87
CHKD. BY RW DATE 12-22-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
PERMISSIBLE LOCAL REDUCTION IN THICKNESS FOR
LOCAL REGION ADJACENT TO RING GIRDELL

ELEMENT No.	GOVERNING P_L	EQUIV. PRESS. P_0	$\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	NOMINALIZED D(F)	
BOTTOM	123	9260. Psi *	26.3 Psi	.087 D	0.935 D
	124	10,265. *	29.1	.091 D	0.978 D
	135	9,040.	25.7	.086 D	0.925 D
	141	9,325.	26.5	.087 D	0.935 D
	147	6,712.	19.1	.074 D	0.796 D
	153	7,459.	21.2	.078 D	0.839 D
	159	10,644. **	30.2	.093 D	1.000 D
TOP	165	13,187. *	37.4	.104 D	—
	171	12,225. *	34.7	.100 D	—

$$P_0 = \frac{P_L t}{R} = \frac{P_L (.460)}{162''}$$

$t = T_0 =$ SHELL THICKNESS = 0.460"

$R =$ TORUS RADIUS = 162."

$S =$ PM ALLOWABLE STRESS = $S_{mc} = 16,500$. Psi

** P_L from EVENT 20

* P_L from EVENT 18

ALL OTHER P_L from EVENT 14

1. 1959

1961

BY RDE DATE 12-18-87
CHKD. BY RVP DATE 12-22-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL
PERMISSIBLE LOCAL REDUCTION IN THICKNESS FOR
LOCAL REGION ADJACENT TO RING GIRDER (CONT'D)

(NOMINALIZATION OF THICKNESS REDUCTION CURVES)

① $\frac{d}{T_0}$	② $d' = \frac{d}{T_0} (.460)$	③ $\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	④ $0.093 = D'_{Fmax}$	⑤ $0.796 = D'_{Fmin}$
0.0	0.000	1.271	13.67	17.16
0.1	0.046	1.072	11.53	14.48
0.2	0.092	0.894	9.67	12.13
0.3	0.138	0.754	8.16	10.25
0.4	0.184	0.643	6.91	8.68
0.5	0.230	0.535	5.75	7.22
0.6	0.276	0.419	4.51	5.66
0.7	0.322	0.284	3.05	3.83
0.8	0.368	0.126	1.35	1.70
0.844	0.388	0.000	0.00	0.00
0.9	0.414			
1.0	0.460			




BY RAE DATE 12-18-87
 CHKD. BY RWC DATE 12-22-87
 REV BY RAE 1-26-88
 CHKD BY RWC 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS - 6801-2**

SHEET NO. _____ OF _____
 PROJ. NO. 6801

NMP-1 TERNUS SHELL

PERMISSIBLE LOCAL REDUCTION IN THICKNESS FOR
LOCAL REGION ADJACENT TO RING GIRDER (CONT'D)





APPENDIX B.2

VENT SYSTEM RANGE OF INDICATION SIZES

The range of indication sizes for the vent system components - the vent pipe, vent header, and downcomers - were calculated using the A.2 primary membrane stress intensities as well as vent system specific dimensions by the same procedures utilized for the torus shell (B.1).

1

2



.....

.....

TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-18-87
CHKD. BY RMP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6501

NMP-1 VENT SYSTEM


PERMISSIBLE LOCAL REDUCTION IN THICKNESS

<u>COMPONENT LOCATION</u>	<u>GOVERNING STRESS (A.2)</u>	<u>SHELL THICKNESS (A.2)</u>	<u>SHELL RADIUS</u>	<u>EQUIVALENT PRESS. = P₀</u>
VENT PIPE	10,628. P _s	.3125 ^{IN}	40.94 ^{IN}	81.12 P _s
VENT HEADER	8,380.	.3125	29.36	89.19
DOWNCOMER	14,673.	.250	12.25	299.45
VENT PIPE @ DRYWELL	10,628.	.3125	40.94	81.12
VENT HEADER @ MITRE JOINT	16,063.	.3125	29.36	170.97
VENT HEADER @ DOWNCOMER	24,600.	.3125	29.36	261.83
DOWNCOMER @ MITRE JOINT	14,673.	.250	12.25	299.45
VENT SPHERE @ t ₁	22,936.	.3125	66.00	54.30
VENT SPHERE @ t ₂	22,936.	.6875	66.00	119.46
VENT SPHERE @ t ₃	22,936.	.8125	66.00	141.18



$$P_0 = \frac{\text{Stress}(t)}{\text{Radius}}$$

* for SPHERE, $P_0 = \frac{\text{Stress}(t)}{2(\text{Radius})}$



TELEDYNE ENGINEERING SERVICES

BY AKC DATE 12-18-87
CHKD. BY JMP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT. SYSTEM
PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

<u>COMPONENT LOCATION</u>	<u>EQUIV. PRESS. P₀</u>	<u>SHELL (t) t₀</u>	<u>$\frac{D}{t_0} \sqrt{\frac{P_0}{S}}$</u>	<u>NORMALIZED (DYF)</u>
VENT PIPE (GENERAL + LOCAL)	81.12 ^{psi}	.3125 ^{IN}	.224D	1.000D
DOWNCOMER (GENERAL + LOCAL)	299.45	.25D	.539D	1.000D
VENT HEADER	89.19	.3125	.235D	0.583D
VENT HEADER @ MITRE JOINT	170.97	.3125	.326D	0.809D
VENT HEADER @ DOWNCOMER	261.83	.3125	.403D	1.000D
VENT SPHERE @ t ₁	54.30	.3125	.184D	1.000D _{t₁}
VENT SPHERE @ t ₂	119.46	.6875	.124D	1.000D _{t₂}
VENT SPHERE @ t ₃	141.18	.8125	.114D	1.000D _{t₃}

WHERE : S = P_m ALLOWABLE STRESS = S_{mc} = 16,500. PSI

4
1
2




BY RME DATE 12-23-87
CHKD. BY ICM DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
VENT HEADER FREE AND LOCAL SHELL REGIONS



* LOCAL REGIONS (1.0 VRT = 3.03")

11-11-68



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-21-87
CHKD. BY RMV DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT PIPE GENERAL + LOCAL AREAS

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

①	②	③	④
$\frac{d}{T_0}$	$d' = \frac{d}{T_0} (.3125)$	$\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	$\frac{③}{0.224} = D'_{FMAX}$
0.0	0.0000 ⁱⁿ	1.271	5.67
0.1	0.0312	1.072	4.78
0.2	0.0625	0.899	4.01
0.3	0.0938	0.759	3.39
0.4	0.1250	0.643	2.87
0.5	0.1562	0.535	2.39
0.6	0.1875	0.419	1.87
0.7	0.2188	0.284	1.27
0.8	0.2500	0.126	0.56
0.844	0.2638	0.000	0.00
0.9	0.2812		
1.0	0.3125		



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-22-87

CHKD. BY RMP DATE 12-23-87

REV BY RJE 1-26-88

CHKD BY RWP 1-26-88

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2



SHEET NO. _____ OF _____

PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT PIPE GENERAL + LOCAL AREAS



1

1000000000

2

3

4

5

6

7



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-21-87
CHKD. BY WLP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

DOWNCOMER GENERAL + LOCAL AREAS

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

①	②	③	④
$\frac{d}{T_0}$	$d' = \frac{d}{T_0} (.250)$	$\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	$\frac{③}{0.539} = D'_{FMAX}$
0.0	0.000 ^{IN}	1.271	2.36
0.1	0.025	1.072	1.99
0.2	0.050	0.899	1.67
0.3	0.075	0.759	1.41
0.4	0.100	0.643	1.19
0.5	0.125	0.535	0.99
0.6	0.150	0.419	0.78
0.7	0.175	0.284	0.53
0.8	0.200	0.126	0.23
0.844	0.211	0.000	0.00
0.9	0.225		
1.0	0.250		

2
24



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-22-87
CHKD. BY RMP DATE 12-23-87
REV. BY RKE 1-26-88
CHKD. BY RMP 1-26-88



NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

DOWNCOMER GENERAL + LOCAL AREAS



1972

22



TELEDYNE ENGINEERING SERVICES

BY RAC DATE 12-21-87
CHKD. BY WV DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT HEADER, + @ MITRE JOINT, + @ DOWNCOMER JOINT

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

(1)	(2)	(3)	(4)	(5)	(6)
$\frac{d}{T_0}$	$d' = \frac{d}{T_0} (.3125)$	$\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	$\frac{(3)}{0.463} = D'_{FMAX DNCR.}$	$\frac{(4)}{0.809} = D'_{MITRE}$	$\frac{(4)}{0.583} = D'_{V. HDR GENERAL}$
0.0	0.0000	1.271	3.15	3.90	5.40
0.1	0.0312	1.072	2.66	3.29	4.56
0.2	0.0625	0.899	2.23	2.76	3.82
0.3	0.0938	0.759	1.88	2.33	3.22
0.4	0.1250	0.643	1.60	1.97	2.74
0.5	0.1562	0.535	1.33	1.64	2.22
0.6	0.1875	0.419	1.04	1.28	1.78
0.7	0.2188	0.284	0.70	0.87	1.22
0.8	0.2500	0.126	0.31	0.37	0.43
0.844	0.2638	0.000	0.00	0.00	0.00
0.9	0.2812				
1.0	0.3125				

100-100000-100000

100-100000-100000



TELEDYNE ENGINEERING SERVICES

BY RJE DATE 12-22-87
 CHKD. BY RWP DATE 12-23-87
 REV. BY RJE DATE 1-26-88
 CHKD BY RWP DATE 1-26-88

**NMP-1 SHELL THICKNESS
 REQUIREMENTS 6801.2**



SHEET NO. _____ OF _____
 PROJ. NO. 6801



NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT HEADER GENERAL, VENT HDR @ MITRE, VENT HDR @ DNCR



44

55
75

11
12



BY RAE DATE 12-21-87
CHKD. BY AMP DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT SPHERE @ $t_1 = 0.3125''$

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

① $\frac{d}{T_0}$	② $d' = \frac{d}{T_0} (.3125)$	③ $\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	④ $\frac{③}{0.184} = D'_{FMAX}$
0.0	0.0000	1.271	6.91
0.1	0.0312	1.072	5.83
0.2	0.0625	0.899	4.88
0.3	0.0938	0.759	4.12
0.4	0.1250	0.643	3.49
0.5	0.1562	0.535	2.91
0.6	0.1875	0.419	2.28
0.7	0.2188	0.284	1.54
0.8	0.2500	0.126	0.68
0.844	0.2638	0.000	0.00
0.9	0.2812		
1.0	0.3125		

10/10/10

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



BY RHE DATE 12-21-87
CHKD. BY W DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT SPHERE @ $t_2 = 0.6875''$

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

① $\frac{d}{T_0}$	② $d' = \frac{d}{T_0} (.6875)$	③ $\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	④ $\frac{③}{0.124} = D'_{FMAX}$
0.0	0.0000	1.271	10.25
0.1	0.0688	1.072	8.64
0.2	0.1375	0.899	7.25
0.3	0.2062	0.759	6.12
0.4	0.2750	0.643	5.18
0.5	0.3438	0.535	4.31
0.6	0.4125	0.419	3.38
0.7	0.4812	0.284	2.29
0.8	0.5500	0.126	1.02
0.844	0.5802	0.000	0.00
0.9	0.6188		
1.0	0.6875		

100

101

102

103

104

105



TELEDYNE ENGINEERING SERVICES

BY RAG DATE 12-21-87
CHKD. BY [Signature] DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. _____ OF _____
PROJ. NO. 6801


NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT. SPHERE @ $t_3 = 0.8125''$

(NOMINALIZATION OF THICKNESS REDUCTION CURVE)

① $\frac{d}{T_0}$	② $d' = \frac{d}{T_0} (.8125)$	③ $\frac{D}{T_0} \sqrt{\frac{P_0}{S}}$	④ $\frac{③}{0.114} = D'_{FMAX}$
0.0	0.0000	1.271	11.15
0.1	0.0812	1.072	9.40
0.2	0.1625	0.899	7.88
0.3	0.2437	0.759	6.66
0.4	0.3250	0.643	5.64
0.5	0.4062	0.535	4.69
0.6	0.4875	0.419	3.68
0.7	0.5688	0.284	2.49
0.8	0.6500	0.126	1.10
0.844	0.6858	0.000	0.00
0.9	0.7312		
1.0	0.8125		



TELEDYNE ENGINEERING SERVICES

BY RKE DATE 12-22-87
 CHKD. BY RMP DATE 12-23-87
 REV BY RKE 1-26-88
 CHKD BY RWP 1-26-89


**NMP-1 SHELL THICKNESS
 REQUIREMENTS 6801-2**


SHEET NO. _____ OF _____
 PROJ. NO. 6801

NMP-1 VENT SYSTEM

PERMISSIBLE LOCAL REDUCTION IN THICKNESS (CONT'D)

VENT SPHERE @ $t_1 = 0.3125"$, $t_2 = 0.6875"$, $t_3 = 0.8125"$








REV. BY RWE DATE 1-26-88
CHKD. BY RMP DATE 1-26-88

NMP-1 SHELL THICKNESS
REQUIREMENTS
6801-2

SHEET NO. _____ OF _____
PROJ. NO. 6801

NMP-1 VENT SYSTEM
VENT SPHERE LOCAL THICKNESS REGIONS



REF #18: CB&I CONTRACT 9-1375 DWG. 316 REV. 3

SHOP DETAILS OF VENT HEADER JUNCTION



APPENDIX C

TORUS SHELL CERTIFIED MATERIAL REPORTS AND STATISTICAL ANALYSIS


The certified material reports (Reference 2) are reviewed herein to determine the margin present on the Code (Reference 4) allowable stress intensity S_{MC} for the torus shell material A201, Gr B FBX.



APPENDIX C.1

STATISTICAL ANALYSIS

The sample data extracted from the material certifications, which are presented in C.2, is evaluated herein to determine the minimum expected mean values of yield and ultimate strength at 70°F. This data was then used to approximate the minimum yield and ultimate strength of the torus shell material (A201, Gr B FBX).



TELEDYNE ENGINEERING SERVICES

BY RMP DATE 12/18/87
CHKD. BY MQR DATE 12/23/87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801.2**

SHEET NO. _____ OF _____
PROJ. NO. 6801

SAMPLE STATISTICS - TORUS. SHELL *
(BASED ON CERTIFIED MATERIAL TEST REPORTS)
A 201 61-T GR B FBX

MATERIAL	SAMPLE	STANDARD	STANDARD	Number
<u>ALLOWABLE (PST)</u>	<u>MEAN (\bar{x})</u>	<u>DEVIATION (S)</u>	<u>ERROR ($\frac{s}{\sqrt{n}}$)</u>	<u>OF SAMPLES (n)</u>
SY	47407	1287	105	150
SULB	67076	1220	100	150
SULT	67096	1421	116	149

DETERMINE THE POPULATION MEAN (μ) BASED ON A .99 CONFIDENCE INTERVAL ESTIMATE FROM THE SAMPLE DATA (LARGE SAMPLE $n > 30$).

WHERE $\mu = \bar{x} \pm 2.58 (\frac{s}{\sqrt{n}})$

	<u>μ_{min}</u>	<u>μ_{max}</u>
SY	47136	47678
SULB	66818	67334
SULT	6679.6	67396 ← CONTROLS

* TABULARIZED DATA IS FROM SUMMARIES IN C.2



 TELEDYNE ENGINEERING SERVICES

BY RMP DATE 12/19/87
CHKD. BY MGR DATE 12/23/87

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801.2

SHEET NO. _____ OF _____
PROJ. NO. 6801

BASED ON ARTICLES III - 1000 AND 3000 SMC
THE ALLOWABLE TORUS SHELL STRESS INTENSITY
IS THE LESSER OF THE FOLLOWING:

$$1.1 \left[\frac{5}{8} S_{Y \min} \right]$$

$$1.1 \left[\frac{1}{4} S_{U \min} \right]$$

AT 70°F

ASSUME THAT THE MINIMUM VALUES OF S_Y AND
 S_U WILL OCCUR TWO STANDARD DEVIATIONS
AWAY FROM THE MINIMUM ESTIMATED POPULATION
MEAN (μ_{\min}).

$$S_{Y \min} = 47136 - 2(1287) = 44562 \text{ PSI}$$

$$S_{U \min} = 66796 - 2(1421) = 63954 \text{ PSI}$$

NOW FIND SMC:

$$1.1 \left[\frac{5}{8} (44562) \right] = 30.6 \text{ KSI}$$

$$1.1 \left[\frac{1}{4} (63954) \right] = 17.6 \text{ KSI}$$

$S_{MC} \sim 17.6 \text{ KSI}$ AT 70°F



APPENDIX C.2

DATA EXTRACTION

The C.3 certified material reports were reviewed for the yield and ultimate strengths of the torus shell material (A201, Gr B FBX) with a shell thickness of 0.46 inches. This data was extracted and re-digitized herein.



Technical Report
TR-6801-2

C-6

REPORT DATE
12/22/87 15:25

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154

PAGE 1

BY mcg DATE 12/23/87

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

CHKD BY Rmp DATE 12/23/87

HEAT NUMBER -----	PIECE NUMBER -----	SY (PSI) -----	SU-LB (PSI) -----	SU-LT (PSI) -----
72P781	284907A	47950	63900	68650
72P781	284907B	47950	68900	62650
72P781	284908A	45850	67310	68150
72P731	284908B	47950	67310	69150
72P781	284911B	47750	65830	64110
72P781	284912A	47060	68360	68080
72P781	284912B	47060	69380	68080
72P781	284916A	46900	66010	66240
72P781	284916B	46900	66010	66240
72P781	284917A	48750	66390	66540
72P781	284920A	46350	65460	65250
72P781	284925A	45380	65560	67000
72P731	284925B	45380	66560	67000
72P731	284953B	47960	67560	67330
72P781	284954A	46180	67230	69210
72P781	284954B	46180	67230	68210
72P731	284958A	47930	67520	68740
72P781	284969B	45920	69180	66870
72P781	284970A	47850	67340	66900
72P731	284970B	47850	67340	66900
73P635	289911A	46220	65960	67240
73P685	289911B	46220	66950	67240
73P685	289912B	46990	66730	67160
73P635	289915B	47260	65200	67190
73P685	289916B	49070	66770	67290
73P635	289917A	46030	65560	64360
73P685	289917B	46030	65560	64360
73P685	289919A	46170	67000	67020
73P635	289920A	46210	66080	66070
73P685	289920B	46210	66080	66070
72P781	284953A	47960	67560	67330
72P781	284965A	47720	66720	67570
73P695	289912A	46990	66780	67160
73P635	289913A	49030	67160	66960
73P685	289913B	49030	67160	66960
73P685	289919B	46170	67000	67020
72P781	284914A	46360	67310	69290



Technical Report
TR-6801-2

C-7

REPORT DATE
12/22/87 15:25

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154

PAGE 2
BY MGR DATE 12/23/87

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

CHKD BY RMP DATE 12/23/87

HEAT NUMBER -----	PIECE NUMBER -----	SY (PSI) -----	SU-LB (PSI) -----	SU-LT (PSI) -----
72P731	2849148	46380	67310	68290
72P781	284918A	46600	67610	67720
72P781	294918B	46600	67610	67720
72P781	284926A	47090	65000	65550
72P781	294911A	47750	65830	64110
72P781	234913A	47760	66660	66200
72P781	284913B	47760	66660	66200
72P781	284915A	46900	65870	66010
72P781	284915B	46900	65870	66010
72P781	284919A	47160	65860	65900
72P781	284920B	46350	65460	65250
72P781	284921A	47070	66600	64970
72P781	284921B	47070	66600	64870
72P781	284923A	47220	63130	65640
72P731	284924B	46650	65140	66390
72P781	284926B	47080	65000	65550
72P781	284919B	47160	65860	65900
72P781	284923B	47720	65150	65640
72P781	284944A	43420	68010	67440
72P781	284944B	49420	68010	67440
72P781	284945A	46560	67160	67270
72P781	284945A1	46560	67160	67270
72P781	284948A	47440	66820	65360
72P781	284948B	47440	66820	65360
72P731	284949A	48530	67550	67080
72P781	284949B	48530	67550	67080
72P781	284956B	47840	66750	66780
72P781	284962B	47030	65000	65550
72P781	284965B	47720	66720	67570
72P781	284966A	48520	67050	68250
72P781	284966B	48530	67050	68250
72P781	284968A	49300	66640	66840
72P781	284969A	45920	63180	66870
72P781	287473A	47390	67810	66850
72P781	284947B	46370	66940	67450
72P781	284955A	48600	69190	68260
72P781	284955B	48600	68190	68260



Technical Report
TR-6801-2

C-8

REPORT DATE
12/22/87 15:25

TELEOYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154


PAGE 3

BY MAC DATE 12/23/87

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

CHKD BY RMP DATE 12/23/87

HEAT NUMBER -----	PIECE NUMBER -----	SY (PSI) -----	SU-LB (PSI) -----	SU-LT (PSI) -----
72P781	284959A	48430	67930	68130
72P781	284959B	48430	67930	68130
72P781	284963A	46390	67600	66900
72P781	284963B	46390	67600	66900
72P781	284967A	47610	67780	67030
72P781	284967B	47610	67780	67030
72P781	284971B	43310	67710	68240
72P781	284975B	46480	67240	67200
73P685	289914A	46380	67310	67070
73P685	289914B	46380	67310	67070
72P781	284960B	47690	66760	65140
72P781	284909A	47610	68800	68340
72P781	284946A	47570	68300	68570
72P781	284950A	45870	67820	68100
72P781	284950B	46870	67820	68100
72P781	284952B	48370	66760	68510
72P781	284957A	46450	67250	67600
72P781	284957B	46450	67250	67600
72P781	284958B	47930	67570	66740
72P781	284961A	43270	65300	66600
72P781	284961B	43270	66300	66600
72P781	284973B	47390	67810	66850
73P685	289915A	47260	66200	67190
68P772	282303A	48030	68550	68670
68P772	282303B	48030	68550	68670
68P772	282304A	48830	68900	68380
68P772	282304A1	48830	68900	68380
72P781	284910B	46360	67620	66960
72P781	284922A	47020	66890	66170
72P781	284922B	47080	66880	66170
72P781	284975A	46480	67240	67200
72P781	284909B	47610	68300	68340
72P781	284971B	48750	66390	66540
72P781	284960A	47690	66730	65140
73P685	289916A	49060	66770	67290
73P685	290049B	45750	63400	64470
73P685	290050A	47160	64400	64340



Technical Report
TR-6801-2

C-9

REPORT DATE
12/22/87 15:25

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154

PAGE 4

BY MCR DATE 12/23/87

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

CHKD BY RLW DATE 12/23/87

HEAT NUMBER -----	PIECE NUMBER -----	SY (PSI) -----	SU-LB (PSI) -----	SU-LT (PSI) -----
73P685	2900508	47160	64400	64340
72P781	284910A	46360	67620	65950
71P952	341708A	47030	67300	0
71P952	341709B	48910	63490	69360
71P952	343000B	49330	69320	70140
71P952	343001A	51300	60470	69730
71P952	343001B	51300	63470	69730
73P685	289918A	45680	67540	66320
73P685	289918B	45680	67540	66220
73P685	289921A	45370	64950	64440
73P685	289921A1	45370	64950	64440
73P693	301657A	47210	65540	65960
73P693	301657B	47210	66540	65860
73P685	290055A	46490	65280	64430
73P685	290055B	46490	65280	64430
71P952	343000A	49330	60320	70140
73P693	301659A	47420	65350	66500
73P685	290052A	48020	65140	65960
73P685	290052B	48020	65140	65960
73P685	290054A	46300	64230	65400
73P685	290054B	46300	64230	65400
71P952	341695A	49650	68850	69500
71P952	341695B	49650	68850	69500
73P685	289922A	45580	67160	67300
73P685	289922A1	46590	67160	67300
71P952	341686A	50670	69520	70310
71P952	341686B	50670	69520	70310
71P952	341694A	50050	68660	68470
71P952	341694B	50050	68660	68470
71P952	341709A	48910	68430	69360
71P952	341710A	48160	68420	68520
71P952	341710B	48160	68420	68520
71P952	341711B	48150	67460	69220
71P952	003998	43340	67880	68020
71P952	341695A	47860	67760	68340
71P952	341695B	47860	67760	68340
71P952	341708B	47090	67300	69520



Technical Report
TR-6801-2

C-10

REPORT DATE
12/22/87 15:25

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154

PAGE 3

BY MGR DATE 12/23/87

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

CHKD BY RMP DATE 12/23/87

HEAT NUMBER -----	PIECE NUMBER -----	SY (PSI) -----	SU-LB (PSI) -----	SU-LT (PSI) -----
73P693	291571	45920	63950	65200
72P781	284946A	47570	63300	62570



STATISTICS SUMMARY FOR VARIABLE SY

	SY
MEAN	47407
STD DEV	1286.76
STD ERR	105.06
MINIMUM	43270
MAXIMUM	51300
RANGE	8030

NMP.1 SHELL THICKNESS
REQUIREMENTS 68U..-

BY MCR DATE 12/23/87
CHKD BY RM DATE 12/23/87



STATISTICS SUMMARY FOR VARIABLE SU-LR

	SU-LR
MEAN	67076
STD DEV	1220.46
STD ERR	99.65
MINIMUM	63400
MAXIMUM	69520
RANGE	6120

NMP-1 SHELL THICKNESS
REQUIREMENTS__ 680+-2

BY MCR DATE 12/23/87

CHKD BY RMP DATE 12/23/87



STATISTICS SUMMARY FOR VARIABLE SU-LT

	SU.LT
MEAN	67096
STD DEV	1420.80
STD ERR	116.40
MINIMUM	64110
MAXIMUM	70310
RANGE	6200

NMP-1 SHELL THICKNESS
REQUIREMENTS . 680±2

BY MAE DATE 12/23/87

CHKD BY RM DATE 12/23/87

10-10-1964



 **TELEDYNE ENGINEERING SERVICES**

BY Rmp DATE 12/23/87
CHKD. BY AE DATE 12-23-87

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801.2**

SHEET NO. _____ OF _____
PROJ. NO. _____

THE FOLLOWING REPRESENTS A CHECK
OF THE PROGRAM USED TO GENERATE THE
MEAN, STANDARD DEVIATION AND STANDARD
ERROR ASSOCIATED WITH THE SAMPLE DATA.



74

75

76

77



78

79

80

81



Technical Report
TR-6801-2

C-15

REPORT DATE
12/22/87 16:58

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASS. 02154

PAGE 1

SUBJECT: NINE MILE POINT NUCLEAR STATION
MILL REPORTS
FILE 3-N2-S22.4

BY MCR DATE 12/23/87

CHKD BY RMP DATE 12/23/87

HEAT NUMBER	PIECE NUMBER	SY (PSI)	SU-LB (PSI)	SU-LT (PSI)
73P685	2900498	45750	63400	64470
73P635	290050A	47160	64400	64340
73P685	290050E	47160	64400	64340
73P685	290055A	46490	65280	64430
73P685	290055B	46490	65280	64430
73P685	290052A	48020	66140	65960
73P685	290052B	48020	66140	65960
73P685	290054A	46300	64830	65400
73P635	290054B	46300	64830	65400

$\Sigma =$ 421,690 584,700 584,730

$\bar{X} =$ 46,854 64,967 64,970

↑
FULL TEST CASE



STATISTICS SUMMARY FOR VARIABLE SY

NMP-1 SHELL THICKNESS
REQUIREMENTS 680.-2

MEAN
STD DEV
STD ERR
MINIMUM
MAXIMUM
RANGE

SY
46854 ✓
790.89 ✓
263.63 ✓
45750 ✓
48020 ✓
2270 ✓

BY MCZ DATE 12/23/87

CHKD BY RMP DATE 12/23/87

SY	$(SY - \bar{X}_{SY})$	$(SY - \bar{X}_{SY})^2$
45750	-1104	1,218,816
47160	306	93,636
47160	306	93,636
46490	-364	132,496
46490	-364	132,496
48020	1166	1,359,556
48020	1166	1,359,556
46300	-554	306,916
46300	-554	306,916

$$\Sigma = 5,004,024$$

$$\text{STD DEV} = \sqrt{\frac{\Sigma (SY - \bar{X}_{SY})^2}{n-1}} = \sqrt{\frac{5,004,024}{8}} = 790.89$$

$$\text{STD ERR} = \frac{\text{STD DEV}}{\sqrt{n}} = \frac{790.89}{3} = 263.63$$



52



STATISTICS SUMMARY FOR VARIABLE SU-LR

MEAN	SU.LR
STD DEV	64966 ✓
STD ERR	872.05
MINIMUM	290.68
MAXIMUM	63400
RANGE	66140
	2740

NMP-1 SHELL THICKNESS
REQUIREMENTS 680.-2

BY MCP DATE 12/23/87

CHKD BY RMY DATE 12/23/87



STATISTICS SUMMARY FOR VARIABLE SU-LT

MEAN	SU.LT.
STD DEV	64970 ✓
STD ERR	703.30
MINIMUM	234.43
MAXIMUM	64340
RANGE	65960
	1620

NMP.1 SHELL THICKNESS
REQUIREMENTS 680.2

BY MAC DATE 12/23/87
CHKD BY RMP DATE 12/23/87



APPENDIX C.3

CERTIFIED MATERIAL REPORTS

The Reference 2 certified material reports were reviewed for the torus shell data (i.e., A201, Gr B FBX, $t=0.46$ inches). The information specific to the torus shell is provided herein.



NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

BUFFALO, NEW YORK 14203

December 13, 1965

Stone & Webster Engineering Corporation
P. O. Box #64
Lycoming, New York - 13903

Attention: Mr. C. E. Goodman

Subject: Nine Mile Point Nuclear Station
Mill Reports
File 3-N2-S22.4

Gentlemen:

We are enclosing copies of a complete set of certified mill reports for the CB&I contract work.

Yours very truly,

NIAGARA MOHAWK POWER CORPORATION


G. E. Sanford

GES:RC


Enc.

cc: M. W. Morris

NOTED

DEC 15 1965

D. R. WARREN





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
 WORKS DUPLICATE DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-42345
 RESOURCES 9-1370 SHEET 1 10/9/64
 DRAWING NO. EJCE006701 SHIPPER NO. & DATE 56051 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 10th DAY OF Dec. 1964
 J. M. FAWCETT, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 My Commission Expires
 May 25, 1965

CHICAGO BRIDGE & IRON CO
 P. O. BOX 610
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DESPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.
 SIGNATURE J. L. GIOVE, CH. MGT.
 DATE 12/09/64

ASTM A 201 81T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 T ULS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F
 03986
 MILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-81T GRADE U
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS
 0706

ITEM NO	HEAT NO	PIECE IDENTIFY NO	MATERIAL DESCRIPTION					YIELD ST. PSI	TENSILE STR. PSI	ELONGATION %		% RED OF AREA	REMARKS
			NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			IN 8"	IN 2"		
1	72P781	284907A	1	.46000	120	255	3/8	4080	47950	68900	32.0		BH
1	72P781	284907B	1	.46000	120	255	3/8	4070	47950	68900	32.0		BH
1	72P781	284908A	1	.46000	120	255	3/8	4100	45850	67310	32.0		BH
1	72P781	284908B	1	.46000	120	255	3/8	4090	47950	67310	32.0		BH
1	72P781	284911B	1	.46000	120	255	3/8	4080	47750	65430	32.0		BH
1	72P781	284912A	1	.46000	120	255	3/8	4100	47060	68380	29.5		BH
1	72P781	284912B	1	.46000	120	255	3/8	4110	47060	68380	29.5		BH
1	72P781	284916A	1	.46000	120	255	3/8	4170	46900	66010	31.0		BH
1	72P781	284916B	1	.46000	120	255	3/8	4170	46900	66010	31.0		BH
1	72P781	284917A	1	.46000	120	255	3/8	4100	48750	66390	28.0		BH
1	72P781	284920A	1	.46000	120	255	3/8	4150	46350	65460	31.0		BH

ALL TESTS MADE ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE. See sheet #3 for Impact Values

HEAT NO	C	Mn	P	S	S	Cu	Ni	Cr	Mo	Si	Al	N	V	B	I	Cs	Cs
72P781	14	112	012	022	29						050						

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000





PRODUCTION DEPARTMENT - METALLURGICAL



PRODUCTION DEPARTMENT - METALLURGICAL

United States Steel Corporation

Sheet #2

TEST REPORT OF PLATES
HUNSTEAD DISTRICT U.S.S. ORDER NO. HP03405 INVOICE NO. 164-0-42345
 CUSTOMER ORDER NO. 9-1370 SHEET 1 10/9/64
 CAR TRUCK NO. EJGE006701 SHIPPER NO. & DATE 56051 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 10th DAY OF Dec. 1964
 J. L. GIOVE, Notary Public
 Allegheny, Allegheny Co., Penna.
 My Commission Expires May 28, 1965.

CHICAGO BRIDGE & IRON CO
 211 BOX 810
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

ASTM A 201-61T GR B FIREBOX FIRE GRAIN NORMALIZE & FLATTEN TO STD
 T OLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

WILL SHOW FA ALSO ASTM A-201-61T GRADE U
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

SIGNATURE J. L. GIOVE, CH. PET.

0706

DATE 12/09/64

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO PCS	THICKNESS OR SECTION	MATERIAL DESCRIPTION			WEIGHT	YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	BH
					WIDTH, DIA OR FT. WT	LENGTH					IN 8"	IN 2"		
1	72P781	284929A	1	.46000	120	255	3/8	4150	45380	66560	31.0		BH	
1	72P781	284929B	1	.46000	120	255	3/8	4140	45360	66560	31.0		BH	
1	72P781	284953B	1	.46000	120	255	3/8	4100	47960	67560	34.5		BH	
1	72P781	284954A	1	.46000	120	255	3/8	4110	46180	67250	32.5		BH	
1	72P781	284954B	1	.46000	120	255	3/8	4140	46180	67250	32.5		BH	
1	72P781	284958A	1	.46000	120	255	3/8	4240	47930	67520	32.5		BH	
1	72P781	284969B	1	.46000	120	255	3/8	4170	45920	68180	30.0		BH	
1	72P781	284970A	1	.46000	120	255	3/8	4170	47850	67360	30.5		BH	
1	72P781	284970B	1	.46000	120	255	3/8	4180	47850	67360	30.5		BH	
1	73P685	289911A	1	.46000	120	255	3/8	4150	46220	66960	33.0		BH	
1	73P685	289911B	1	.46000	120	255	3/8	4100	46220	66960	33.0		BH	

NOTE: WE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

See Sheet #3 for Impact Values

HEAT NO.	C	Mn	P	S	S	Cu	Pb	Cr	Ni	Mo	Sn	Al	N	V	Se	Si	Cu	Ce
72P781	0.04	0.12	0.012	0.022	0.29							0.50						
73P685	0.13	0.13	0.009	0.024	0.27													

100-100000-100000

100-100000-100000



PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #3

U.S. REPORT OF PLATES
 WORKS HONOLULU DISTRICT U.S. ORDER NO. HP33405 INVOICE NO. 164-0-42345
 CUSTOMER ORDER NO. 9-1370 SHEET 1 10/9/64
 CARTRUCK NO. EJ6E006701 SHIPPER NO. & DATE 56051 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 10th DAY OF Dec. 1964
 J. L. GIOVE, Notary Public
 Allegheny Co., Penna.
 My Commission Expires
 May 28, 1965

CHICAGO BRIDGE & IRON CO
 P O BOX 510
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS
 OF THE COMPANY.

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 TUBS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F
 03986
 MILL G SEP SW TR SHOW FA ALSO ASTM A-201-61T GRADE B
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

SIGNATURE J. L. GIOVE, CH. MET.
 DATE 12/6/64

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO. PCS.	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
				THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT	LENGTH	WEIGHT			N 8"	IN 2"		
1	73P685	2899128	1	.46000	120	255 3/8	4140	46990	68730	28.0			
1	73P685	2899158	1	.46000	120	255 3/8	4080	47260	67160	32.0			
1	73P685	2899168	1	.46000	120	255 3/8	4180	49070	67190	29.5			
1	73P685	289917A	1	.46000	120	255 3/8	4260	46030	68170	31.0			
1	73P685	289917B	1	.46000	120	255 3/8	4270	46030	67240	31.0			
1	73P685	289919A	1	.46000	120	255 3/8	4270	46170	65560	33.0			
1	73P685	289920A	1	.46000	120	255 3/8	4180	46210	64360	33.0			
1	73P685	289920B	1	.46000	120	255 3/8	4180	46210	67020	33.0			
		284925		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made				at Minus 50	Fof-73-73-72 Ft. Lbs.				
		284953		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made				at Minus 50	Fof-111-82-77 Ft. lbs.				
		284954		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made				at Minus 50	Fof-83-80-111 Ft. Lbs.				
		284958		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made				at Minus 50	Fof-76-133-160 Ft. Lbs.				

WHEN SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

See Sheet #4

HEAT NO.	TYPE	C	Mn	P	S	S ₂	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Co	Co
73P685	1	13	113	009	024	27												

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #4

TEST REPORT OF PLATES

WORKS PITTSBURGH DISTRICT U.S.S. ORDER NO. HP 83405 INVOICE NO. 164-0-42345

CUSTOMER'S ORDER NO. 9-1370 10/9/64

SHIP TO ORDER NO. 612 006701 SHIPPER P.C. & DATE 56051 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 10th DAY OF Dec. 1964

J.L. Glove
 J. L. GLOVE, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 My Commission Expires
 Dec. 25, 1965

SHIP TO

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING TO LAW; DEPOSES AND SAYS THAT THE CHEMICAL ANALYSES AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS OBTAINED IN THE RECORDS OF THE COMPANY;

SIGNATURE J.L. GLOVE, CH. MET.
 DATE 12/9/64

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	SH. EN. MIN. CO.
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH			WEIGHT	IN 2'		
721751		284969	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-66-71-71	Ft. Lbs.				
		284970	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-105-91-110	Ft. Lbs.				
731685		289911	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-65-72-81	Ft. Lbs.				
		289912	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-93-91-81	Ft. Lbs.				
		289913	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-73-67-76	Ft. Lbs.				
		289916	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-119-97-66	Ft. Lbs.				
		289917	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-105-109-111	Ft. Lbs.				
		289919	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-136-91-87	Ft. Lbs.				
		289920	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-87-102-93	Ft. Lbs.				
		284907	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-86-51-86	Ft. Lbs.				
		284908	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-98-67-93	Ft. Lbs.				
		284911	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-120-181-187	Ft. Lbs.				
721751		284912	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-56-65-59	Ft. Lbs.				
		284916	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-105-142-152	Ft. Lbs.				
		284917	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-122-81-72	Ft. Lbs.				
		284920	1	Longitudinal V Notch Charpy	Impact Tests 10 x 10 MM Made	at Minus	500F-77-87-76	Ft. Lbs.				

INVENTIVE TESTS ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION USED AND IS

Plates Normalized

HEAT NO.	C	Mn	P	S	Si	Ca	Mg	Cu	Va	Sn	Al	N	V	Z	Cl	Co
721751	14	1.12	0.12	0.02	0.29			Grain	Size	#8						
731685	13	1.15	0.09	0.02	0.27			Grain	Size	#8						

100-100000-100000

100-100000-100000

100-100000-100000





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
 WORKS HONESTEAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-42953
 CUSTOMER ORDER NO. 9-1370 SHEET 1 10/9/64
 CASE NO. NYC 500769 SHIPPER NO. & DATE 56117 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 J. L. GIVVE, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 Commission Expires
 Dec. 25, 1965

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DESPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

ASTM A-201-61T-GR-B FIREBOX FINE GRAIN-NORMALIZE & FLATTEN TO STD
 T U.S. ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

HILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-61T-GRADE-B
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

SIGNATURE J. L. GIVVE, CH. MET.
 DATE 12/11/64

0706

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WT.		LENGTH	WEIGHT	YIELD ST. PSI	TENSILE STR. PSI	ELONGATION %		% RED. OF AREA	BY SEC. NO.
											IN 8"	IN 2"		
1	72P781	284953A	1	.46000	120		255 3/8	4060	47960	67560 67330	34.5			BB
1	72P781	284965A	1	.46000	120		255 3/8	4160	47720	66720 67370	29.0			BB
1	73P685	289912A	1	.46000	120		255 3/8	4160	46990	66780 67160	28.0			BB
1	73P685	289913A	1	.46000	120		255 3/8	4160	49030	67160 68960	32.0			BB
1	73P685	289913B	1	.46000	120		255 3/8	4190	49030	67160 68960	32.0			BB
1	73P685	289919B	1	.46000	120		255 3/8	4260	46170	67000 67020	33.0			BB
2	72P781	284914A	1	.46000	111 1/4		255 3/8	3830	46380	67310 68290	31.0			BB
2	72P781	284914B	1	.46000	111 1/4		255 3/8	3830	46380	67310 68290	31.0			BB
2	72P781	284918A	1	.46000	111 1/4		255 3/8	3810	46600	67610 67720	32.0			BB
2	72P781	284918B	1	.46000	111 1/4		255 3/8	3850	46600	67610 67720	32.0			BB
2	72P781	284926A	1	.46000	111 1/4		255 3/8	3890	47080	65000 65550	30.0			BB

ALL METALS TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

See Sheet #3 for Impact Values

72P781	73P685	14	112	012	022	29	Co	Mn	Ce	20	Se	050	N	V	B	Si	Co
1	1	13	115	009	024	27											

10/10/10

10/10/10

10/10/10

10/10/10





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #2

TEST REPORT OF PLATES

WORKS HOMESTEAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-42953

ORDER NO. 9-1370 SHEET 1 10/9/64

NYC 500769 SHIPPER NO & DATE 56117 160

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
THIS 11th DAY OF December 1964
Doris M. Rickett, Notary Public
Pittsburgh, Pa. Notary Co., Pa. No. 12645
Commission Expires May 23, 1966

[Signature]

CHICAGO BRIDGE & IRON CO
P O BOX 610
GREENVILLE PA

CHICAGO BRIDGE & IRON CO
GREENVILLE PA

SHIP TO

ASTM A-201-61T-GR-B-FIREBOX-FINE-GRAIN-NORMALIZE-&-FLATTEN-TO-STD
T ULS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

MILL-6-SEP-SM-TR-SHOW-FA-ALSO-ASTM-A-201-61T-GRADE-B
FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

0706

BEING DULY SWORN ACCORDING TO LAW, DEPOSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

SIGNATURE J.L. GIOVE, CH. MET.

DATE 12/11/64

ITEM NO	SAC NO.	PIECE IDENTITY NO.	NO. PCS	THICKNESS OR SECTION	MATERIAL DESCRIPTION			WEIGHT	YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	3M EC
					WIDTH, DIA. OR FI. WI.	LENGTH					IN 8"	IN 2"		
1	72P781	284911A	1	.46000	120	255	3/8	4050	47750	65830	32.0			EH
1	72P781	284913A	1	.46000	120	255	3/8	4200	47160	66660	28.0			EH
1	72P781	284913B	1	.46000	120	255	3/8	4240	47760	66200	28.0			EH
1	72P781	284915A	1	.46000	120	255	3/8	4310	46900	66200	31.0			EH
1	72P781	284915B	1	.46000	120	255	3/8	4280	46900	65870	31.0			EH
1	72P781	284919A	1	.46000	120	255	3/8	4080	47160	66010	34.0			EH
1	72P781	284920B	1	.46000	120	255	3/8	4180	46350	65860	31.0			EH
1	72P781	284921A	1	.46000	120	255	3/8	4090	47070	65900	30.0			EH
1	72P781	284921B	1	.46000	120	255	3/8	4080	47070	66000	30.0			EH
1	72P781	284923A	1	.46000	120	255	3/8	4060	47220	64870	31.0			EH
1	72P781	284924B	1	.46000	120	255	3/8	4090	46650	65180	31.5			EH

ANALYSIS MADE ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

See Sheet #3 for Impact Values

72P781	1	14	112	012	022	29	Cu	Ni	Cr	Mn	Sn	Al	050	N	V	B	Si	Ca	Co
--------	---	----	-----	-----	-----	----	----	----	----	----	----	----	-----	---	---	---	----	----	----



PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #3

TEST REPORT OF PLATES
 WORKS HIGHESTAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-42953
 CONSUMER ORDER NO. 9-1370 SHEET 1 10/9/64
 CAR ORDER NO. NYC 500769 SHIPPER NO. & DATE 56117 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SHORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 JAMES M. FAWCETT, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 My Commission Expires May 25, 1965

CHICAGO BRIDGE & IRON CO
 P O BOX 810
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SHORN ACCORDING TO LAW; DESPOSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

ASTM A-201-61T-GR-B-FIREBOX-FINE-GRAIN-NORMALIZE-&-FLATTEN-TO-STD
 TOLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

MILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-61T-GRADE-B
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

0706

SIGNATURE J.L. GIOVE, CH. MET.
 DATE 12/11/64

QA NO	HEAT NO.	PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA
			NO. PCS.	THICKNESS OR SECTION	WIDTH Dia OR FT. WT.	LENGTH	WEIGHT			IN 8"	IN 2"	
2	72P781	2849268 LT Longitudinal	1	.46000	111 1/4	255 3/8	3920	47080	65000 65550	30.0		
	72P781	284953 Longitudinal										
	73P685	284965 Longitudinal										
		289912 Longitudinal										
		289913 Longitudinal										
		289919 Longitudinal										
	72P781	284914 Longitudinal										
		284918 Longitudinal										
		284926 Longitudinal										
		284911 Longitudinal										
		284913 Longitudinal										
		284915 Longitudinal										

CHARPY SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	PIECE NO.	TEST NO.	TEST TYPE	TEST RESULT	TEST DATE	TESTER	TEST LOCATION	TEST EQUIPMENT	TEST STATUS
72P781	1	14	112-012-022-29					050	



PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #4

TEST REPORT OF PLATES
 WORKS ALLEGHENY DISTRICT U.S.S. ORDER NO. HP-83405 INVOICE NO. 164-0-42953
 CUSTOMER ORDER NO. 9-1370 10/9/64
 REF. OR PLAC. NO. HTO 500769 SHIPPER NO. & DATE 56117 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 J. L. GLOVE, CH. CLERK
 1115 N. FAWCETT, Notary Public
 Allegheny Co., Penna.
 My Commission Expires
 May 25, 1965

SHIP TO
 CHICAGO BRIDGE & IRON CO
 10 BOX C10
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECCROS OF)
 THE COMPANY.
 SIGNATURE J. L. GLOVE, CH. CLERK.
 DATE 12/11/64

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	BY NO. OF DC
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH			IN 8"	IN 2"		
72P781		284919				10 x 10 MM Made	at Minus	500F-100-100-103	Ft.	Lbs.		
		284920										500F-77-87-76
		284921										500F-100-44-106
		284923										500F-104-92-118
		284924										500F-71-93-93
Grain Size #8 Plates Normalized												

OVER SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

HEAT NO.	C	Mn	P	S	S	Cu	Ni	Cr	Mo	Sn	Al	V	Z	B	Fe	Co
72P781	14.1	1.2	0.012	0.022	29											

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000





PRODUCED IN DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
 DISTRICT U.S.S. ORDER NO. HP 83405 INVOICE NO. 164-0-42522
 CUSTOMER ORDER NO. 9-1370 DATE 10/9/64
 ORDER NO. 090819 SHIPPER NO. & DATE 56059 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 J. M. PATRICEY, Notary Public
 Allegheny Co., Penna.
 My Commission Expires
 May 25, 1968

CHICAGO BRIDGE & IRON CO
 PO BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD TOLB ASTM A 300
 CHARPY IMPACT LONG TEST AT MINUS 50oF

MILL 6 SEP SW TR SHOW PA ALSO ASTM A 201-61T GRADE B FIREBOX ALSO ASTM A-300

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

SIGNATURE J.L. GLOVE, CH. MET.
 DATE 12/10/64

QA NO	HEAT NO	PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	2IN FT. TO 2IN DIA
			NO PCS	THICKNESS OR SECTION	WDM, DA OR FL. WT	LENGTH	WEIGHT			IN 2"	IN 4"		
1	72F781	284919B LB LT	1	.46000	120	255 3/8	4100	47160	65860 65900	34.0			D.
1	72F781	284923B LB LT	1	.46000	120	255 3/8	4150	47720	65140 65640	31.0			E.
1	72F781	284944A LB LT	1	.46000	120	255 3/8	4120	49420	68010 67440	30.0			D.
1	72F781	284944B LB LT	1	.46000	120	255 3/8	4150	See Above	67160 67270	30.5			DH
1	72F781	284945A LB LT	1	.46000	120	255 3/8	8510	See Above					
1	72F781	284945A1 LB LT	1	.46000	120	255 3/8	8510	See Above					

ALL TESTS PERFORMED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATIONS LISTED ABOVE.

HEAT NO	SIZE	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sp	Al	N	V	E	Ti	Ch	Ce
72F781		14	1.12	0.12	0.022	29												

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #2

TEST REPORT OF PLATES
 PLANT LANCASTER DISTRICT U.S. ORDER NO. HP 83405 INVOICE NO. 164-0-42522
 CUSTOMER ORDER NO. 9-1370 DATE 10/9/64
 ORDER NO. RI 090848 SHIPPER NO. & DATE 56959 106

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME, H. Y. WISSETT, Notary Public,
 this 11th DAY OF Dec. 1964. My Commission Expires May 25, 1965.

[Handwritten Signature]
[Handwritten Signature]

CHICAGO BRIDGE & IRON CO
 PO BOX 610
 GREENVILLE PA

SHIP TO

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GRADE B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD TOLS ASTM A 300
 CHARPY IMPACT LONG TEST AT MINUS 50oF

HILL 6 SEP SW TR SHOW FA ALSO ASTM A 201 61T GRADE B FIREBOX ALSO ASTM A-300

BEING DULY SWORN ACCORDING TO LAW, DEPOSES AND SAYS THAT THE CHEMICAL ANALYSES AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

SIGNATURE J. L. GLOVE, CH. MGR.

DATE 12/10/64

ITEM NO	HEAT NO.	PECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
			NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			N 8"	IN 2"		
1	72P731	284948A LB LT	1	.46000	120	255 3/8	4230	47440	66820 65360	31.0			BH
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											
1	72P731	284948B	1	.46000	120	255 3/8	4210	See above					
1	72P731	284949A LB LT	1	.46000	120	255 3/8	4200	48530	67550 67080	29.0			E..
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											
1	72P731	284949B	1	.46000	120	255 3/8	4200	See Above					
1	72P731	284956B LB LT	1	.46000	120	255 3/8	4150	47840	66750 66730	32.0			BH
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											
1	72P731	284962B LB LT	1	.46000	120	255 3/8	4120	47030	65000 65550	30.0			BH
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											
1	72P731	284965B LB LT	1	.46000	120	255 3/8	4120	47720	66720 67570	29.0			BH
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-											

TESTS WERE PERFORMED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

123-102-104 Ft. Lbs.

ITEM NO	TYPE	C	Mn	P	S	Si	Cr	Ni	Gr	Mo	Sn	Al	N	V	B	I	Cu	Ce
72P731		14	1.12	0.12	0.022	29												

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951

1950-1951





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #3

TEST REPORT OF PLATES
 MADE AT ROSENTHAL DISTRICT U.S.S. ORDER NO. HP 84305 INVOICE NO. 164-0-42522
 QUANTITY 9-1370 10/9/64
 ORDER NO. 81 020448 SHIPPER NO. & DATE 56059 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 J. L. GLOVE, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 My Commission Expires
 May 25, 1965

CHICAGO BRIDGE & IRON CO
 50 BOX 610
 GREENVILLE PA

SHIP TO

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GRADE B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD TOL3 ASTM A 300
 CHARPY IMPACT LOXO TEST AT MINUS 500F

ROLL 6 SEP SM TR SHOW PA ALSO ASTM A 201 61T GRADE B FIREBOX ALSO ASTM A300

SIGNATURE J. L. GLOVE, CH. MPT.

DATE 12/10/64

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

ITEM NO.	HEAT NO.	PECE IDENTIFY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	PH. EQ. NUM. DO.
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WT.	LENGTH	WEIGHT			IN 8"	IN 2"		
1	72P781	284965A LB LT	1	.46000	120	255 3/8	4150	48530	67050 63250	32.0			EH
1	72P781	284966B	1	.46000	120	255 3/8	4140	48530	67050 63250	32.0			EH
1	72P781	284968A LB LT	1	.46000	120	255 3/8	4070	48300	66640 66640	33.0			EH
1	72P781	284969A LB LT	1	.46000	120	255 3/8	4130	45920	65120 66370	30.0			EH
1	72P781	284973A LB LT	1	.46000	120	255 3/8	4170	47390	67410 66350	27.5			EH
2	72P781	284947B LB LT	1	.46000	111 1/4	255 3/8	3880	46370	65940 67450	30.0			BH
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-							63-20-30 Ft. Lbs.				
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-							174-159-133 Ft. Lbs.				
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-							66-74-71 Ft. Lbs.				
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-							36-78-62 Ft. Lbs.				
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-							139-134-122 Ft. Lbs.				

PHYSICAL SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Co	Co
72P781	14	1.12	0.02	0.02	29												

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100





PRODUCTION DEPARTMENT - METALLURGICAL

United States Steel Corporation

Sheet #4

TEST REPORT OF PLATES

WORKS HEMPSTEAD DISTRICT USS ORDER NO. HP 84305 INVOICE NO. 164-0-42522

CUSTOMER ORDER NO. 9-1370 10/9/64

SHIP OR PLACE NO. HI. 090348 SHIPPER NO. & DATE 56059 160

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
THIS 11th DAY OF Dec. 1964.

J. L. GLOVE
J. L. GLOVE, Notary Public
Fittsburgh, Allegheny Co., Penna.
By Commission Expires
May 25, 1965

CHICAGO BRIDGE & IRON CO
PO BOX 610
GREENVILLE PA

SHIP TO

CHICAGO BRIDGE & IRON CO
GREENVILLE PA

ASTM A 201 61T GRADE B FIREBOX FINE GRAIN NORMALIZE & FLATEN TO STD TOLS ASTM A 300
CHARVY IMPACT LONG TEST AT MINUS 50oF

HILL 6 SEP 54 TR SHOW PA ALSO ASTM A 201 61T GRADE B FIREBOX ALSO ASTM A 300

BEING DULY SWORN ACCORDING
TO LAW, DEPOSES AND SAYS
THAT THE CHEMICAL ANALYSES
AND/OR TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CON-
TAINED IN THE RECORDS OF
THE COMPANY.

SIGNATURE J. L. GLOVE, CH. MEY.

DATE 12/10/64

ITEM NO.	ITEM NO.	PIECE IDENTIFY NO.	NO. PCS	THICKNESS OF SECTION	MATERIAL DESCRIPTION			YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	SH. EC. NO. CO
					WIDTH, DIA. OR FT. WI.	LENGTH	WEIGHT			IN 8"	IN 2"		
2	72F781	284955A LB LT	1	.46000	111 1/4	255 3/8	3840	48600	69190 68260	30.0			BU
		Longitudinal R Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-						143-103-143					
2	72F781	284955B	1	.46000	111 1/4	255 3/8	3850	See Above					
2	72F781	284959A LB LT	1	.46000	111 1/4	255 3/8	3840	48450	67930 68130	32.5			BU
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-						134-103-128					
2	72F781	284959B	1	.46000	111 1/4	255 3/8	3860	See Above					
2	72F781	284963A LB LT	1	.46000	111 1/4	255 3/8	3830	46300	67600 66900	32.5			BU
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-						105-110-98					
2	72F781	284963B	1	.46000	111 1/4	255 3/8	3830	See Above					
2	72F781	284967A LB LT	1	.46000	111 1/4	255 3/8	3870	47610	67730 67030	31.0			BU
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-						150-165-153					
2	72F781	284967B	1	.46000	111 1/4	255 3/8	3870	See Above					

QUANTITIES LISTED ACCORDING TO COMPANY RECORDS CONFORM TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

ITEM NO.	SIZE	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Al	N	V	B	I	Co	Co
72F781		14	1.12	0.12	0.022	.29											

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Sheet 53

PLATES
 DISTRICT _____ U.S.S. ORDER NO. HP 84305 INVOICE NO. 164-0-42522
9-1370 10/9/64
RI 090348 SHIPPED IN C & DATE 56059 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 11th DAY OF Dec. 1964
 J. L. GLOVE, Notary Public
 Pittsburgh, Allegheny Co., Penna.
 My Commission Expires
 May 25, 1965


CHICAGO BRIDGE & IRON CO
 GREENVILLE PA
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA
 ASTM A 201 61T GRADE B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD TOLS ASTM A 300
 IMPACT LONG. TEST AT MINUS 500F
 ALL 6 SHEETS TR SHOW FAALSO ASTM A 201 61T GRADE B FIREBOX ALSO ASTM A300

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.
 SIGNATURE J. L. GLOVE, CH. MET.
 DATE 12/10/64

QTY	HEAT NO.	PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE ST. PSI.	TOLERANCE %		% RED. OF AREA	BIN NO.
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WL.	LENGTH	WEIGHT			N"	IN"		
2	721781	284971B LB LT	1	.46000	111 1/4	255 3/8	3840	48310	67710 68240	31.0			D11
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-						120-135-121 Ft. Lbs.					
2	721781	284975B LB LT	1	.46000	111 1/4	255 3/8	3870	46480	67240 67200	30.5			B11
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-						132-143-64 Ft. Lbs.					
2	721685	289914A LB LT	1	.46000	111 1/4	255 3/8	3870	46380	67510 67070	31.0			D11
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-						100-87-109 Ft. Lbs.					
2	721685	289914B	1	.46000	111 1/4	255 3/8	3950	See Above					
		Plates Normalized											

ANALYSIS LISTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	Si	Ca	Ni	Co	Mo	Cu	Al	N	Zn	As	Sb	Cb	Co
721781	14	1.12	.012	.022	.29		Grain Size #8										
721685	13	1.15	.009	.024	.27		Grain Size #8										





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

EST REPORT OF _____ PLATES
 WORKS HOMESTEAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-46150
 QUANTITY 9-1370 SHEET 1 10/9/64
 ORDER NO. PELE000702 SHIPPER NO & DATE 56550 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 23rd DAY OF Dec 1964
 I, JAMES K. GLOVE, Notary Public
 Pittsburgh, Allegheny Co., Pa.
 My Commission Expires
 12/23, 1964

CHICAGO BRIDGE & IRON CO
 P O BOX 810
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

James K. Glove
 BEING DULY SWORN ACCORDING
 TO LAW, DESPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

ASTM A 201 61T GR B FIREBOX FINE GRAIN NGRMALIZE & FLATTEN TO STD
 T DLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

HILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-61T GRADE B
 FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

SIGNATURE J. L. GIOVE, CH. MET.

DATE 12/18/64

0706

ITEM NO.	ITEM NO.	PIECE IDENTIFY NO.	NO. PCS.	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	BH CO. NO.
				THICKNESS OR SECTION	WIDTH, DIA. OR FI. WT.	LENGTH	WEIGHT			IN 8"	IN 2"		
1	72P781	284960B	LT	1	.46000	111 1/4	255 3/8	4120	65140				
1	72P781	284909A	LT	1	.46000	120	255 3/8	4090	47690	66760	33.0		BH
1	72P781	284946A	LT	1	.46000	120	255 3/8	4100	47610	68340	31.0		BH
1	72P781	284950A	LT	1	.46000	120	255 3/8	4210	47570	68570	31.0		BH
1	72P781	284950B	LT	1	.46000	120	255 3/8	4230	46870	68300	27.5		BH
1	72P781	284952B	LT	1	.46000	120	255 3/8	4150	46570	68100	27.5		BH
1	72P781	284957A	LT	1	.46000	120	255 3/8	4090	48370	67400	32.5		BH
1	72P781	284957B	LT	1	.46000	120	255 3/8	4060	46450	67250	30.0		BH
1	72P781	284958B	LT	1	.46000	120	255 3/8	4230	46450	67250	30.0		BH
1	72P781	284961A	LT	1	.46000	120	255 3/8	4030	47930	67520	32.5		BH
1	72P781	284961B	LT	1	.46000	120	255 3/8	4070	43270	66300	30.0		BH
									43270	66300	30.0		BH

ONE OF THESE TESTS ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

ITEM NO.	C	Mn	P	S	S	Cr	Mo	Ni	Al	N	V	B	Si	Ca
72P781	14	1.12	0.12	0.022	0.29				0.050					
See Sheet # 3 for Charpy Tests														

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000





PRODUCTS DEPARTMENT - METALLURGICAL
United States Steel Corporation

EST REPORT OF PLATES
 ORDER NO. HONESLEAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-46150
 QUANTITY 9-1370 SHEET 1 10/9/64
 ORDER NO. PGLE000702 SHIPPER NO. & DATE 56550 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 22nd DAY OF Dec 1964
 J. L. GIOVE, CH. MET.

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING TO LAW, DEPOSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 Y DLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F
 03986

WILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-61T GRADE B FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS
 0706

SIGNATURE J. L. GIOVE, CH. MET.
 DATE 12/18/64

QTY	HEAT NO.	PIECE IDENTIFY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	BH OR NM DR
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			N 3"	IN 2"		
1	72P781	2849738 LB	1	.46000	120	255 3/8	4130	47370	67810	27.5			
1	73P685	289915A B LB	1	.46000	120	255 3/8	4110	47260	66850	32.0			BH
2	68P772	282303A B LB	1	.46000	111 1/4	255 3/8	3820	48030	67190	29.5			BH
2	68P772	282303B B LB	1	.46000	111 1/4	255 3/8	3870	48030	68670	29.5			BH
2	68P772	282304A LB	1	.46000	111 1/4	255 3/8		48830	68900	32.0			BH
2	68P772	282304A1 LB	1	.46000	111 1/4	255 3/8	7610	48830	68900	32.0			BH
2	72P781	284910B LB	1	.46000	111 1/4	255 3/8	3900	46360	66960	30.0			BH
2	72P781	284922A LB	1	.46000	111 1/4	255 3/8	3930	47020	66170	30.0			BH
2	72P781	284922B LB	1	.46000	111 1/4	255 3/8	3920	47020	66170	30.0			BH
2	72P781	284975A LB	1	.46000	111 1/4	255 3/8	3870	46480	67200	30.5			BH

See Sheet # 3 for Charpy Tests

When We Tested According to Company Records Conforms to the Requirements of the Specification Listed Above.

HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	Fe	V	B	Ti	CL	Co
72P781	.14	1.12	.012	.022	.29						.050						
73P685	.13	1.15	.009	.024	.27												
68P772	.17	1.08	.007	.020	.23												

10-10-1964

10-10-1964

10-10-1964

10-10-1964

10-10-1964

10-10-1964

10-10-1964





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation



PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet # 3

TEST REPORT OF Plates
 MADE AT Homestead District U.S.S. ORDER NO HF83405 INVOICE NO 164-0-46150
 ORDER NO 9-1370 Sheet-1-10/9/64
 SHIPPER NO & DATE _____

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SHOWN TO BEFORE ME
 THIS 23rd DAY OF December, 1964
Notary Public for Allegheny County, Pa. My Comm. Expires July 18, 1968

Chicago Bridge & Iron Co
 P O Box 610
 Greasville, Pa

SHIP TO
 Chicago Bridge & Iron Co
 Greasville Pa

John Kline
 BEING FULLY SHOWN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.
 SIGNATURE J. L. GLOVE, CH. MET.
 DATE 12/23/64

HEAT NO.	PIECE IDENTIF NO.	NO PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WT.	MATERIAL DESCRIPTION	LENGTH	WEIGHT	YIELD FL. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	BIN NO. DO
										IN 8"	IN 2"		
72P781	284960	-	Longitudinal V Notch	Charpy Impact	Tests 7.5 x 10 MM Made at Minus 50°F.	93-141-92	Ft. Lbs.						
72P781	284909	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	81-100	Ft. Lbs.						
72P781	284946	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	72-102-90	Ft. Lbs.						
72P781	284950	-	Longitudinal V Notch	Charpy Impact	Tests 7.5 x 10 MM Made at Minus 50°F.	102-102-102	Ft. Lbs.						
72P781	284952	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	72-117-110	Ft. Lbs.						
72P781	284957	-	Longitudinal V Notch	Charpy Impact	Tests 7.5 x 10 MM Made at Minus 50°F.	72-139-113	Ft. Lbs.						
72P781	284958	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	76-138-101	Ft. Lbs.						
72P781	284961	-	Longitudinal V Notch	Charpy Impact	Tests 7.5 x 10 MM Made at Minus 50°F.	76-124-120	Ft. Lbs.						
72P781	284973	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	76-78-62	Ft. Lbs.						
73P683	289915	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	73-92-75	Ft. Lbs.						
63P772	282303	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	91-122-124	Ft. Lbs.						
63P772	282304	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	71-74-65	Ft. Lbs.						
72P781	284910	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	70-92-64	Ft. Lbs.						
72P781	284922	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	97-79-70	Ft. Lbs.						
72P781	284975	-	Longitudinal V Notch	Charpy Impact	Tests 10 x 10 MM Made at Minus 50°F.	72-143-64	Ft. Lbs.						

Grain Size all heats A-8 Plates and tests normalized.

TESTS PERFORMED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

C	Mn	P	S	Si	Cu	Ni	Cr	Mg	Sn	Al	N	V	B	Ti	Co	Co

2000-0000-0000

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1000000





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
 WORKS LORESTEAD DISTRICT U.S.S. ORDER NO. HP83405 INVOICE NO. 164-0-50528
 CUSTOMER ORDER NO. 9-137G SHEET 1 10/9/64
 CASE OR FILE NO. PELECC0742 SHIPPER NO. & DATE 57146 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO
 THIS 4th. DAY OF Jan. 1964

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING TO LAW, DESPSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 TOLS ASTM A 309 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

FIRE BOX SW IR SHGW FA ALSO ASTM A-201-61T GRADE B
 FIRE BOX ALSO ASTM A-302-58 & CHARPY IMPACT TEST RESULTS

SIGNATURE J.L. GIOVE, CH. MET.

0756

12/31/64

QTY	ITEM NO	PLATE IDENTIFYING NO	PLATE THICKNESS	PLATE WIDTH	PLATE LENGTH	PLATE WEIGHT	NET WT	GROSS WT	TENSILE STRENGTH	YIELD STRENGTH	ELONGATION	REDUCED AREA	TEST RESULTS
1	72P781	2849C93	LT	1	.46000	120	255 3/8	4150	*47610	68850	31.0		
1	72P781	2849173	LT	1	.46000	120	255 3/8	4100	*48750	68340	28.0		
1	72P781	284965A	LT	1	.46000	120	255 3/8	3940	*47650	68510	31.0		
1	73P685	289916A	LB	1	.46000	120	255 3/8	4200	*49060	66770	29.5		BH
1	73P685	290049B	LT	1	.46000	120	255 3/8	4260	*45750	63400	34.0		BH
1	73P685	29005CA	LT	1	.46000	120	255 3/8	4170	*47160	64470	28.0		BH
1	73P685	290050B	LT	1	.46000	120	255 3/8	4190	*47160	64340	28.0		BH
2	72P781	284910A	LT	1	.46000	111 1/4	255 3/8	3910	*46360	67620	30.0		BH

See Sheet #2 for Impact Values

YILD PT AT .5% FAT

ITEM NO	TYPE	C	MA	P	S	S	Co	Ni	Cr	AS	Sn	Al	Mn	P	B	Si	Cb	Co
72P781	1	114	112	G12	022	129						650						
73P685	1	113	115	OC9	027	127												

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #2

TEST REPORT OF PLATES
 WORKS EVANSTON DISTRICT U.S. ORDER NO. HP 83405 INVOICE NO. 161-0-50528
 CUSTOMER ORDER NO. 9-1370 10/9/64
 CASE RECORD NO. PLS C00742 SHIPPER NO. & DATE 57146 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 4th DAY OF Jan. 1965

John W. Caldwell
 J. W. CALDWELL, Notary Public
 Pittsburgh, Allegheny Co., Pa.
 My Commission Expires
 May 23, 1965

CHICAGO BRIDGE & IRON CO
 PO BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY:

SIGNATURE J. L. GLOVE, CH. MET.

DATE 12/31/64

TEST NO.	PLATE NO.	TEST TYPE	SIZE	TEMP.	RESULT	REMARKS	CF
73731	284909	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-92-21-100 Ft. Lbs.		
	284917	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-122-21-72 Ft. Lbs.		
	284929	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-92-111-96 Ft. Lbs.		
	284930	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-92-111-96 Ft. Lbs.		
73735	289916	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-117-27-60 Ft. Lbs.		
	290049	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-86-87-35 Ft. Lbs.		
	290050	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-77-32-74 Ft. Lbs.		
73781	284910	Longitudinal V Notch Charpy	Impact Tests 10 x 10	M4 Made at Minus	500F-110-22-64 Ft. Lbs.		
Grain Sizes #8 Plates Normalized							

OVER ONE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

TEST NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	II	Cb	Co

SECRET

SECRET

SECRET



RECEIVED

EST REPORT OF PLATES
 WORKS HGNESTEAD DISTRICT U.S.S. ORDER NO. HP 90240 INVOICE NO. 164-0-18842
 CUSTOMER ORDER NO. 9-1370 10/20/64
 CAR OR TRUCK NO. PRR 469685 SHIPPER NO. & DATE 41401 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 GREENVILLE
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 28th DAY OF Jan. 1965
John M. Fawcett
 JOHN M. FAWCETT, Notary Public
 Pittsburgh, Allegheny Co., Pa.
 My Commission Expires
 May-25-1966

CHICAGO BRIDGE & IRON CO
 PO BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

John De Cello
 BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

ASTM A201-61T GR B FIREBOX QUAL FINE GRAIN NORMALIZE & FLATTEN ASTM A-300
 CHARPY IMPACT LONG TEST AT MINUS 50oF

MILL 6 SW TR

SIGNATURE J.L. GLOVE, CH. MET.

DATE 1/27/65

HEAT NO.	HEAT NO.	PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
			NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WI.	LENGTH	WEIGHT			IN 8"	IN 2"		
3	71F952	341708A LB LT	1	.46000	124	346 1/8	5800	47080	67300	27.5			
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF						-104-91-85					
3	71F952	341709B LB LT	1	.46000	124	346 1/8	5730	48910	68490	26.0			
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF						-85-126-139					
4	71F952	343000B LB LT	1	.46000	112	255 1/4	3980	49330	69320	30.0			
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF						-47-82-92					
4	71F952	343001A LB LT	1	.46000	112	255 1/4	3830	51300	69470	31.0			
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF						-90-74-84					
4	71F952	343001B	1	.46000	112	255 1/4	3860	See Above					
		Grain Size #7 Plates Normalized											

NOTE: SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	TYPE	C	Mn	P	S	S ₂	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Cb	Co
71F952		15	116	010	024	27												

1000

1000

1000

1000





IRON DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
JUNIESTEAD DISTRICT U.S.S. ORDER NO. EP83405 INVOICE NO. 164-C-23612
 CUSTOMER ORDER NO. 9-1270 SHEET 1 10/9/64
 DRAWING OR TRUCK NO. RI CSIC65 SHIPPER NO & DATE 42027 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO before me
 THIS 9th. DAY OF Feb, 1965
 J. L. GIVRE, Notary Public
 Allegheny Co., Penna.
 My Commission Expires
 May 25, 1965

(Signature)
 BEING FULLY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

SIGNATURE J. L. GIVRE, CH. MET.
 DATE 02/09/65

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 T GLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

0706

WILL 7 SEP SH TR SHCN FA ALSO ASTM A-201-61T GRADE B
 FIREBOX ALSO ASTM A-300-56 & CHARPY IMPACT TEST RESULTS

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO. PCS	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
				THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			IN 8"	IN 2"		
2	73P685	289918A LB LT	1	.46000 V-NOTCH 10	111 1/4 x 10 MM	255 3/8	3880	45680	67540 66820	35.0			BT
				LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50°F 104 093 092 000 FT. LBS									
2	73P685	289918B	1	.46000	111 1/4	255 3/8	3890	See Above					
				CHARPY IMPACT TESTS MADE AT MINUS									
				Grain Size #8									
				Plates Normalized									

CHEMICAL TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S	Cu	Ni	Cr	Mo	Si	Al	N	V	B	Ti	Cb	Co
73P685	13	115	009	024	27												

SECRET

SECRET

SECRET

SECRET





IRON DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF _____ PLATES
 HEADS _____ P-C HEAD DISTRICT USS ORDER NO. EP2405 INVOICE NO. 164-C-23617
 CUSTOMER ORDER NO. S-127C SHEET 1 10/9/64
 ORDER NO. HILW65C48E SHIPPER NO. & DATE 42029 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SHOWN TO BECARE ME
 THIS 9th DAY OF Feb. 1965
 JAMES M. FAYCETT, Notary Public in Allegheny Co., Pa.
 My Comm. Exp. Expires _____

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 T CLS ASTM A 200 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

MILL'S SEP SW TR SFCH FA ALSO ASTM A-201-61T GRADE B
 FIREBOX ALSO ASTM A-200-58 & CHARPY IMPACT TEST RESULTS

[Signature]
 BEING FULLY SHOWN ACCORDING
 TO LAW; CESPCSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

SIGNATURE J.L. GIOVE, CH. MET.
 DATE 02/09/65

QTY	HEAT NO.	PIECE IDENTITY NO.	NO. PCS.	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
				THICKNESS OR SECTION	WIDTH, DIA. OR FI. WT.	LENGTH	WEIGHT			IN 8"	IN 2"		
1	73P685	289921A LB LT	1	.46000 V NOTCH 10	120 X 10 MM	255 3/8	4155	45370	64950 64440	31.0			U
		LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50F				092 080 062	600 FT.	LBS					
1	73P685	289921A1 CHARPY IMPACT	1	.46000	120	255 3/8	4155	See Above					
		TESTS MADE AT MINUS					FT.	LBS					
1	73P693	2C1657A LB LT	1	.46000 V NOTCH 10	120 X 10 MM	255 3/8	4110	47210	66540 65860	34.0			Bi
		LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50F				C71 C65 C56	600 FT.	LBS					
1	73P693	2C1657B	1	.46000	120	255 3/8	4120	See Above					

Grain Size #8
 Plates Normalized

ANAL. SIZE LISTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S	Co	Fe	Cr	Ni	Cu	Al	N	V	B	Ti	Ce	Co
73P685	13	115	CC9	C24	127												
73P693	15	155	C10	C26	125												

2000

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38





IRON DEPARTMENT - METALLURGICAL

United States Steel Corporation

TEST REPORT OF: PLATES

WORKS: GREENVILLE DISTRICT U.S.S. ORDER NO. HP-90240 INVOICE NO. 164-0-23287

DATE OF ORDER: 9-1370 10/20/64

SHIP ORDER NO. HP-002625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

SUBSCRIBED AND SHOWN TO BEFORE ME
THIS 9th DAY OF Feb. 1965
J. L. GLOVE, Notary Public
Greenville, Allegheny Co., Penna.
My Commission Expires
Oct 25, 1965

CHICAGO BRIDGES & IRON CO
PO BOX 610
GREENVILLE PA

SHIP TO

CHICAGO BRIDGES & IRON CO
GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZER & FLATTEN
ASTM A 200 CHARPY IMPACT LONG TEST AT MINUS 50o

MILL 6 SW TR ALSO ASTM A 201-61T GR B FIREBOX QUAL & A-300-58

BEING DULY SHOWN ACCORDING
TO LAW, DEPOSES AND SAYS
THAT THE CHEMICAL ANALYSES
AND/OR TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CON-
TAINED IN THE RECORDS OF
THE COMPANY;

SIGNATURE J. L. GLOVE, CH. MET.

DATE

2/7/65

QTY NO	MATERIAL NO.	PIECE IDENTIFY NO	MATERIAL DESCRIPTION					YIELD ST. PSI	TENSILE ST. PSI	ELONGATION %		% RED. OF AREA	PH NO. DO
			NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			" 8"	" 2"		
4	73F685	290055A LB LT	1	.46000	112	255 1/4	3860	46490	65230 64130	32.5			REI
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-82-84-82 Ft. Lbs.											
4	73F685	290055B	1	.46000	112	255 1/4	3820	See Above					
4	71F552	343000A LB LT	1	.46000	112	255 1/4	3910	49330	69380 70170	30.0			REI
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-47-82-92 Ft. Lbs.											
4	73F693	301659A LB LT	1	.46000	112	255 1/4	3830	47420	55350 66500	33.0			REI
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 50oF-80-102-71 Ft. Lbs.											

FORMERLY TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

TEST NO	DATE	C	MA	P	S	S	C	NO	C	%C	Sn	Al	N	V	B	%	Ce	Ce
73F685		13	115	009	024	27				Grain Size #8								
71F552		15	116	010	024	27				Grain Size #7								
73F693		15	95	010	026	29				Grain Size #8								

1952 10 10

10 10 1952

10 10

10 10 1952

10 10





PRODUCED IN DEPARTMENT - METALLURGICAL

United States Steel Corporation

Sheet #2

TEST REPORT OF PLATES
 OFFICE BRIDGE DISTRICT U.S.S. ORDER NO. HP-90240 INVOICE NO. 164-0-22287
 CUSTOMER ORDER NO. 9-1370 10/20/64
 SALES ORDER NO. HP-002625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 9th DAY OF Feb. 1965
 J. L. GLOVE, Notary P.
 Philadelphia, Allegheny Co., Pa.
 My Commission Expires
 May 25, 1965

CHICAGO BRIDGE & IRON CO
 10 BOX CLO
 GREENVILLE PA

TO
 FROM

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSES
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

SIGNATURE J. L. GLOVE, CH. MET.

DATE 2/7/65

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN ASTM A 300 CHARPY IMPACT
 LONG TEST AT MINUS 500

MILL G SW TR ALSO ASTM A-201-61T GR B FIREBOX QUAL & A-300-58

ITEM NO.	HEAT NO.	PIECE IDENTIFY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED OF AREA	B. NO. OF DO.
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			IN 2"	IN 4"		
4	73F685	290052A LB LT	1	.46000	112	255 1/4	3880	46020	66100 65900	32.5			E.
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-						57-55-40 ft. lbs.					
4	73F683	290052B	1	.46000	112	255 1/4	3960	See Above					
4	73F685	290054A LB LT	1	.46000	112	255 1/4	3890	46300	64800 65400	31.0			E.
		Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 500F-						39-60-46 ft. lbs.					
4	73F685	290054B	1	.46000	112	255 1/4	3950	See Above					

CHEMICAL ANALYSES ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S	Co	Ni	Cr	Mo	V	B	Fe	Co	Co
73F685	13	1.15	0.09	0.024	27	Grain Size #3								

10

11

12

13

14

15

SECRET

16

17

18

19

20

21

22





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #3

TEST REPORT OF PLATES
 WORKS LOVESTEAD DISTRICT U.S.S. ORDER NO. HP90240 INVOICE NO. 164-C-23287
 CUSTOMER ORDER NO. S-137C SHEET NO 2 1C/2C/64
 CAR OR TRUCK NO. NRP CC2625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 9th. DAY OF Feb. 1965

J. L. GIVRE, Notary Public
 Allegheny Co.
 My Commission Expires
 May 23, 1965

J. L. Givre
 BEING DULY SWORN ACCORDING TO LAW, DESPOSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

CHICAGO BRIDGE & IRON CO
 P O BOX 61C
 GREENVILLE PA

SHIP TO

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 6IT GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 T ULS ASTM A 30C CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

MILL 6 SW TR SHOW FA ALSO ASTM A-201-6IT GRADE B FIREBOX
 QUALITY AND A-300-5E

SIGNATURE J. L. GIVRE, CH. MET.

DATE C2/C7/65

0706

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO. PCS	MATERIAL DESCRIPTION				YIELD FL. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED OF AREA	SH. FOR N.S. DO
				THICKNESS OR SECTION	WIDTH, DIA. OR FI. WT.	LENGTH	WEIGHT			.8"	IN 2"		
4	71P952	341695A LB LT	1	.46000 V NOTCH 10	112 x 10 MM	255 1/4	3800	49650	68850 65500	34.0			Bit
		LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50F				075 046 071	000 FT.	LBS					
4	71P952	341695B CHARPY IMPACT	1	.46000	112	255 1/4	3900	See Above					
		LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS					FT.	LBS					
4	73P685	289922A LB LT	1	.46000 V NOTCH 10	112 x 10 MM	255 1/4		46580	67160 67300	23.0			Bit
		LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50F				073 074 075	000 FT.	LBS					
4	73P685	289922A1	1	.46000	112	255 1/4	7800	See Above					

SMALL SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S ₂	Cu	Ni	Cr	Mo	Sn	Al	Si	V	B	Ti	Co	Co
71P952	115	116	010	024	127												
73P685	113	115	CC9	024	127												
								Grain Size #7									
								Grain Size #8									

10

11

12

13

14

15

16

17

18

19

20

21



PRODUCTS DEPARTMENT - METALLURGICAL

United States Steel Corporation

Sheet #4

TEST REPORT OF PLATES

WORKS HEMPSTEAD DISTRICT U.S. ORDER NO. HP9C24G INVOICE NO. 164-0-23287

CUSTOMER ORDER NO. S-137G SHEET NO 2 1C/20/64

TANK OR TRUCK NO. NKP G02625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
THIS 9th DAY OF Feb. 1965

J. L. GLOVE
Notary Public
Commission Expires
May 25, 1965

CHICAGO BRIDGE & IRON CO
P O BOX 61C
GREENVILLE PA

CHICAGO BRIDGE & IRON CO
GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
T ULS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

WILL 6" SW TR SHOW FA ALSO ASTM A-201-61T GRADE B FIREBOX
QUALITY AND A-300-58

0706

SIGNATURE J. L. GLOVE, CH. MET.
DATE 02/07/65

J. L. Glove
BEING DULY SWORN ACCORDING
TO LAW, DEPOSES AND SAYS
THAT THE CHEMICAL ANALYSIS
AND/OR TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CON-
TAINED IN THE RECORDS OF
THE COMPANY.

ITEM NO.	HEAT NO.	PIECE IDENTITY NO.	NO. PCS	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WT.	LENGTH	WEIGHT	YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED OF AREA	SH. EC. NO. DO
										IN 8"	IN 2"		
4	71P952	341686A LB LT	1	.4600C V NOTCH 10 x 10 MM	112	255 1/4	3970	50670	69520 70310	31.0			BI
LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 050F 024 025 022 600 FT. LBS													
4	71P952	341686B CHARPY IMPACT	1	.4600C	112	255 1/4	3960	See Above					BI
TESTS MADE AT MINUS													
4	71P952	341694A LB LT	1	.4600C V NOTCH 10 x 10 MM	112	255 1/4	3870	50050	68660 68470	33.0			BI
LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 050F 071 062 049 600 FT. LBS													
4	71P952	341694B	1	.4600C	112	255 1/4	3940	See Above					

PIECE SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	TIME	C	MA	P	S	S	Cu	Ni	Co	Mo	Al	N	V	B	Si	Ca	Cn
71P952	1	15	116	010	024	27											
Grain Size #7																	

1944

1944

1944





PRODUCTS DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #5

EST REPORT OF PLATES
HOVESTRAD DISTRICT U.S.S. ORDER NO. HP9C240 INVOICE NO. 164-0-23287
9-1370 SHEET NO 2 1C/20/64
HP CC2625 SHIPPER NO & DATE 41959 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 9th DAY OF Feb. 1965

J. L. Givve
 J. L. GIVVE, Notary Public
 Allegheny Co., Penn.
 My Commission Expires
 May 25, 1965

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 301 61T GR B FIREBOX FINE GRAIN NICKELIZE & FLATTEN TO STD
 T OLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

039E6

WILL 6 SW TR SEOW FA ALSO ASTM A-201-61T GRADE B FIREBOX
 QUALITY AND A-300-58

07C6

SIGNATURE J. L. GIVVE, CH. MET.

DATE 02/07/65.

ITEM NO	HEAT NO	PIECE IDENTITY NO.	NO. PCS	MATERIAL DESCRIPTION				YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	EM. CO. NO. DO
				THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			N 8"	IN 2"		
3	71P952	341709A LB LT	1	.46000 V NOTCH 10	124 x 10 MM	346 1/8	5770	48910	68490 69260	26.0			BH
LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 050F 085 126 139 000 FT. LBS													
3	71P952	341710A LB LT	1	.46000 V NOTCH 10	124 x 10 MM	346 1/8	5740	48160	68420 68520	30.0			BH
LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 050F 054 081 139 000 FT. LBS													
3	71P952	341710B CHARPY IMPACT	1	.46000	124	346 1/8	5860	See Above FT. LBS					
3	71P952	341711B LB LT	1	.46000	124	346 1/8	5660	48150	67460 69220	24.5			BH
LONGITUDINAL V NOTCH CHARPY IMPACT TESTS 10 x 10 MM MADE AT MINUS 50oF - 87-109-101 FT. LBS.													

WHEN THE TESTED SPECIMENS TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO	AN	P	S	Si	Cu	Mn	Cr	Ni	V	B	Ti	Co	Co
71P952	115	116	010	024	27		Grain Size #7						

SECRET

SECRET



PRODUCTION DEPARTMENT - METALLURGICAL

United States Steel Corporation

Sheet #5

TEST REPORT OF PLATES
 PLACES LEWISTOWN DISTRICT U.S.S. ORDER NO. HP90240 INVOICE NO. 164-0-23287
 QUANTITY 9-137C SHEET NO 2 1C/2C/64
 ORDER NO. MRP 002625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME, Notary Public,
 THIS 9th. DAY OF Feb. 1965, at Lehigh Valley Co., Penn.
 My Commission Expires May 25, 1965

[Handwritten Signature]
[Handwritten Name]

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 TPLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

02986

MILL 6 SW TR SHGW FA ALSO ASTM A-201-61T GRADE B FIREBOX
 QUALITY AND A-300-58

SIGNATURE J.L. SIGVE, CH. MET.

0706

DATE 02/07/65

ITEM NO	ITEM NO	PIECE IDENTIFY NO	NO PCS	THICKNESS OR SECTION	MATERIAL DESCRIPTION			WEIGHT	YIELD ST. PSI.	TENSILE ST. PSI.	ELONGATION %		% RED. OF AREA	BIL. NO. DO
					WIDTH, DIA. OR FL. WL.	LENGTH					IN 8"	IN 2"		
3	71P952	C03958 LB LT	1	.46000 10 x 10 MM	124	346 1/8	5870	48240	67880 68920	31.0			Bi	
LONGITUDINAL V NOTCH CHARPY IMPACT TESTS MADE AT MINUS 50oF - 150-122-105 FT. LBS														
3	71P952	341685A LB LT	1	.46000 10 x 10 MM	124	346 1/8	5910	47860	67760 68340	31.0			Bi	
LONGITUDINAL CHARPY IMPACT TESTS MADE AT MINUS 50oF 067 062 063 000 FT. LBS														
3	71P952	341685B LB LT	1	.46000	124	346 1/8	5960	See Above					Bi	
CHARPY IMPACT TESTS MADE AT MINUS														
3	71P952	3417C8B LB LT	1	.46000	124	346 1/8	5820	47080	67300 68520	27.5			Bi	
LONGITUDINAL V NOTCH CHARPY IMPACT TESTS 10 x 10 MM MADE AT MINUS 50oF-104-91-85 FT. LBS.														

QUALITY AND A-300-58

QUALITY AND A-300-58

QUALITY AND A-300-58

ITEM NO	C	Mn	P	S	S	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Bi	Cb	Co
71P952	1	0.15	0.16	0.010	0.024	0.27		Grain Size #7									

SECRET

10
11
12
13
14
15





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

Sheet #6

TEST REPORT OF PLATES
HONESILED DISTRICT U.S. ORDER NO. HP90240 INVOICE NO. 164-0-23287
 QUANTITY 9-1370 SHEET NO 2 1C/2C/64
 ORDER NO. HRP 002625 SHIPPER NO. & DATE 41959 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 9th DAY OF Feb. 1965
 JOHN W. FAWCETT, Notary
 Pittsburgh, Allegheny Co.
 My Comm. No. 2501
 Exp. 03-31-65
J.L. Gicve
 BEING FULLY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.
 SIGNATURE J.L. GICVE, CH. MET.
 DATE 02/07/65

CHICAGO BRIDGE & IRON CO
 P. O. BOX 610
 GREENVILLE PA

TO SHIP

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

ASTM A 201-61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD
 1 CLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F

03986

PLATE 6 SW TR SLOW FA ALSO ASTM A-201-61T GRADE B FIREBOX
 QUALITY AND A-300-58

0706

TEST NO.	HEAT NO.	PIECE IDENTITY NO.		NO. PCS.	MATERIAL DESCRIPTION				YIELD ST. PS.	TENSILE STR. PS.	ELONGATION %		% RED. OF AREA	REMARKS	
					THICKNESS OR SECTION	WIDTH, DIA OR FT. W.	LENGTH	WEIGHT			IN 8"	IN 2"			
5	73P693	291571	LB LT	1	46000 V NOTCH 10	112 x 10 MM	267 1/4	4060	45290	6355C 6520C	22.0			B1	
					TESTS MADE AT MINUS 050 F				600 FT. LBS						
					Plates Normalized										

CHEM. ANAL. TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

HEAT NO.	C	Mn	P	S	S	Co	PH	Grain	Sl%o	#8	Sn	Al	N	V	B	II	Cu	Co
73P693	15	55	010	026	25													





PRODUCTION DEPARTMENT - METALLURGICAL
United States Steel Corporation

TEST REPORT OF PLATES
 MADE AT FORESTEAD DISTRICT U.S.S. ORDER NO. HP03405 INVOICE NO. 163-0-34666
 NUMBER OF SHEETS 9-1370-SHEET-1-10/9/64
 ORDER NO. NYC-496189 SHIPPER NO & DATE 43098 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME, Notary Public,
 THIS 4th DAY OF March 1965 at Pittsburgh, Allegheny Co., Pa.
 My Commission Expires May 29, 1965

CHICAGO BRIDGE & IRON CO
 P O BOX 610
 GREENVILLE PA

CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

BEING FULLY SWORN ACCORDING TO LAW, DEPOSES AND SAYS THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.
 SIGNATURE J.L. GIOVE, CH. MET.
 DATE 03/12/65

ASTM A 201 61T GR B FIREBOX FINE GRAIN NORMALIZE & FLATTEN TO STD TOLS ASTM A 300 CHARPY IMPACT LONG TEST AT MINUS 50 DEG F
 03986
 WILL 6 SEP SW TR SHOW FA ALSO ASTM A-201-61T GRADE B FIREBOX ALSO ASTM A-300-58 & CHARPY IMPACT TEST RESULTS

ITEM NO	PLATE NO	PIECE IDENTIFY NO.	NO. PCS	THICKNESS OR SECTION	MATERIAL DESCRIPTION			WEIGHT	YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA	REMARKS
					W.DTH, DIA OR FI. WT.	LENGTH					IN 8"	IN 2"		
1	72P781	284946A-19	1	.46000	120	255 3/8	4100	47570	68570	31.0				
				CHARPY IMPACT TESTS MADE AT MINUS 50°F. -72-102-90										
				Plates Normalized Grain Size # 8										

ANALYSIS MADE ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

PLATE NO	ITEM NO	C	Mn	P	S	S ₂	Co	Ni	Cr	Mo	Cu	Al	N	V	B	Fe	Ch	Co
72P781	1	14	1.12	0.12	0.22	.29						0.50						



APPENDIX D

QUALITY ASSURANCE INFORMATION

The completed "Verification and Document Release" form contained herein is indication of the compliance of this technical report with the Teledyne Engineering Services Quality Assurance Program (Reference 19).

[Faint, illegible text scattered across the page, possibly bleed-through from the reverse side.]



VERIFICATION AND DOCUMENT RELEASE

PROJECT NO. 6801 DATE January 7, 1988
DOCUMENT ID NO. TR-6801-2 REV NO 0
TYPE OF DOCUMENT Technical Report NUMBER OF PAGES 144

TITLE
Mark I Torus Shell and Vent System Thickness Requirement
Nine Mile Point Unit 1 Nuclear Station

REV DESCRIPTION
None

THE FOLLOWING COMPUTER RUNS APPLY TO THIS DOCUMENT:

Unique ID	Date	Prog. Name/ Version	Software Error Check	Unique ID	Date	Prog. Name/ Version	Software Error Check
1. <u>None</u>				7.			
2.				8.			
3.				9.			
4.				10.			
5.				11.			
6.				12.			

If more space required, attach additional pages.

ORIGINATOR [Signature] DATE 1/6/88
CHECKER [Signature] DATE 1-6-88

THIS DOCUMENT HAS BEEN VERIFIED AND IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE TES QUALITY ASSURANCE PROGRAM.

VERIFIER [Signature] DATE 1-6-88

APPROVED FOR RELEASE
PROJECT MANAGER [Signature] DATE 1/6/88
QAE [Signature] DATE 1-6-88

08
07
06

05
04
03

02
01

00

99
98

97
96

0000000000
0000000000



VERIFICATION AND DOCUMENT RELEASE

PROJECT NO. 6801 DATE January 29, 1988
DOCUMENT ID NO. TR-6801-2 REV NO 1
TYPE OF DOCUMENT Technical Report NUMBER OF PAGES 163

TITLE

Mark I Torus Shell and Vent System Thickness Requirements
Nine Mile Point Unit 1 Nuclear Station

REV DESCRIPTION

E.C.O. No. 8582

THE FOLLOWING COMPUTER RUNS APPLY TO THIS DOCUMENT:

Unique ID	Date	Prog. Name/ Version	Software Error Check	Unique ID	Date	Prog. Name/ Version	Software Error Check
1. <u>None</u>				7.			
2.				8.			
3.				9.			
4.				10.			
5.				11.			
6.				12.			

If more space required, attach additional pages.

ORIGINATOR *[Signature]* DATE 1-29-88
CHECKER *[Signature]* DATE 1-29-88

THIS DOCUMENT HAS BEEN VERIFIED AND IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE TES QUALITY ASSURANCE PROGRAM.

VERIFIER *[Signature]* DATE 1-29-88


APPROVED FOR RELEASE

PROJECT MANAGER *[Signature]* DATE 1-21-88
QAE *[Signature]* DATE 1-29-88



APPENDIX E

SAMPLE TORUS SHELL CALCULATIONS FOR POSTULATED INDICATIONS



TELEDYNE ENGINEERING SERVICES



BY RFE DATE 1-26-88
 CHKD. BY YMP DATE 1-26-88

**NMP-1 SHELL THICKNESS
 REQUIREMENTS 6801-2**

SHEET NO. 1 OF
 PROJ. NO. 6801

NMP-1 TORUS SHELL


TORUS SHELL INDICATION SAMPLE CALCULATION #1




(OUTSIDE)

$$l_1 = 71.258 \text{ IN}$$

$$l_2 = 87.320 \text{ IN}$$





 **TELEDYNE ENGINEERING SERVICES**

BY RJE DATE 1-26-88
CHKD. BY kmf DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 2 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION # 1

STEP 1 CIRCUMSCRIBED DIAMETER OF INDICATION AREA.

$D = 16.062''$

STEP 2 MAXIMUM DEPTH OF INDICATION $d = 0.0325''$

STEP 3 CONFIRM THAT NO ADDITIONAL INDICATIONS
ARE FOUND WITHIN A 21.5" RADIUS

✓ CONFIRMED

STEP 4 IF STEP 3 IS VIOLATED, RE-CIRCUMSCRIBE
THE AREA AND RE-DETERMINE "D" AND "d"

STEP 5 DETERMINE ARC REGION (S) FROM APPROPRIATE
FIGURE 7 OR 8

 LOCAL SHELL REGION, FIGURE 7.

✓ FREE SHELL REGION, FIGURE 8.

$l_1 = 71.258''$ LIES IN ARC REGION S4

$l_2 = 87.320''$ LIES IN ARC REGION S4

S4 PERMISSIBLE CORRODED THICKNESS = $0.035''$

S4 PERMISSIBLE CORRODED THICKNESS = $0.035''$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

TABLE 1



 TELEDYNE ENGINEERING SERVICES

BY RNE DATE 1-26-88
CHKD. BY IMP DATE 1-26-88

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 3 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #1

STEP 6 CHECK IF MEASURED INDICATION DEPTH
IS LESS THAN THE PERMISSIBLE CORRODED
THICKNESS (t_c)

PERMISSIBLE CORRODED THICKNESS = $t_c = 0.035$ "
INDICATION DEPTH = $d = 0.0325$ "

✓, $d \leq t_c$, THEN INDICATION IS ACCEPTABLE,
STOP, SKIP REMAINING STEPS

___, $d > t_c$, THEN CONTINUE

STEP 7 DETERMINE CIRCUMSCRIBED DIAMETER MULTIPLIER
(F) FROM THE TABLE OF FIGURE 9 OR 10.


___ FREE SHELL REGION, FIGURE 9

___ RING GIRDER (LOCAL) SHELL REGION, FIGURE 10

S___, FACTOR "F" = _____

S___, FACTOR "F" = _____

LARGEST MULTIPLIER FACTOR "F" = _____





BY RVE DATE 1-26-88
 CHKD. BY IMP DATE 1-26-99

**NMP-1 SHELL THICKNESS
 REQUIREMENTS 6801.2**

SHEET NO. 4 OF
 PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #



1944-1945, 1946-1947

1948

1949

1950

1951

1952

1953

1954

1955



 **TELEDYNE ENGINEERING SERVICES**

BY RNE DATE 1-26-88
CHKD. BY RLP DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 5 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #2

STEP 1 CIRCUMSCRIBED DIAMETER OF INDICATION AREA.
D = 4.285" IN

STEP 2 MAXIMUM DEPTH OF INDICATION d = 0.211" IN

STEP 3 CONFIRM THAT NO ADDITIONAL INDICATIONS
ARE FOUND WITHIN A 21.5" RADIUS
✓ CONFIRMED

STEP 4 IF STEP 3 IS VIOLATED, RE-CIRCUMSCRIBE
THE AREA AND RE-DETERMINE "D" AND "d"

STEP 5 DETERMINE ARC REGION (S) FROM APPROPRIATE
FIGURE 7 OR 8

 LOCAL SHELL REGION, FIGURE 7.

✓ FREE SHELL REGION, FIGURE 8.

L₁ = 136.122" IN LIES IN ARC REGION S₃

L₂ = N/A LIES IN ARC REGION S

S₃ PERMISSIBLE CORRODED THICKNESS = 0.078 / 0.140

S PERMISSIBLE CORRODED THICKNESS =

Page 1 of 1

 **TELEDYNE ENGINEERING SERVICES**

BY RKE DATE 1-26-88
CHKD. BY PWP DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 6 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #2

STEP 6 CHECK IF MEASURED INDICATION DEPTH
IS LESS THAN THE PERMISSIBLE CORRODED
THICKNESS (t_c)

NOTE IF d WAS IN THE RANGE OF t_c
ACTUAL t_c COULD BE INTERPOLATED

PERMISSIBLE CORRODED THICKNESS = $t_c = \frac{0.078 \text{ IN}}{0.190 \text{ IN}}$
INDICATION DEPTH = $d = \underline{0.211 \text{ IN}}$

 , $d < t_c$, THEN INDICATION IS ACCEPTABLE,
STOP., SKIP REMAINING STEPS

✓, $d > t_c$, THEN CONTINUE

STEP 7 DETERMINE CIRCUMSCRIBED DIAMETER MULTIPLIER
(F) FROM THE TABLE OF FIGURE 9 OR 10.

✓ FREE SHELL REGION, FIGURE 9

 RING GIRDER (LOCAL) SHELL REGION, FIGURE 10

S3, FACTOR "F" = 0.930

S , FACTOR "F" =

LARGEST MULTIPLIER FACTOR "F" = 0.930

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200



BY RJE DATE 1-26-88
CHKD. BY RMP DATE 1-26-88

NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2

SHEET NO. 7 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #

STEP 8 DETERMINE EQUIVALENT DIAMETER (D')
WHICH CIRCUMSCRIBES THE INDICATIONS.

$$D' = D \times F$$

$$D' = \underline{4.285}^{\text{IN}} \times \underline{0.930} = \underline{3.985}^{\text{IN}}$$

STEP 9 USING D' AND APPROPRIATE FIGURE 9 OR 10,
DETERMINE THE ALLOWABLE INDICATION
DEPTH (d')

FREE SHELL, FIGURE 9

LOCAL SHELL, FIGURE 10

$$\text{ALLOWABLE DEPTH, } d' = \underline{0.265}^{\text{IN}}$$

* ADJUST ALLOWABLE DEPTH (d') TO ACCOUNT FOR
REDUCED WALL THICKNESS MEASURED.

$$\text{ORIGINAL WALL THICKNESS, } T_0 = 0.460^{\text{IN}}$$

$$\text{MEASURED WALL THICKNESS, } t = \underline{0.458}^{\text{IN}}$$

$$\text{ADJUSTED } d' = d' - (T_0 - t) = \underline{0.263}^{\text{IN}}$$

$$\text{INDICATION DEPTH, } d = \underline{0.211}^{\text{IN}}$$

, $d \leq d'$, INDICATION IS ACCEPTABLE

, $d > d'$, WELD REPAIR REQUIRED

of the ...

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



TELEDYNE ENGINEERING SERVICES



BY RXE DATE 1-26-88
 CHKD. BY WV DATE 1-26-88

**NMP-1 SHELL THICKNESS
 REQUIREMENTS 6801-2**

SHEET NO. 8 OF
 PROJ. NO. 6801

NMP-1 TORUS SHELL


TORUS SHELL INDICATION SAMPLE CALCULATION #3



(OUTSIDE)

$$l_1 = 38.125 \text{ IN}$$

$$l_2 = 43.253 \text{ IN}$$



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

THE UNIVERSITY OF CHICAGO



 **TELEDYNE ENGINEERING SERVICES**

BY RNE DATE 1-26-88
CHKD. BY RMP DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 4 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #3

STEP 1 CIRCUMSCRIBED DIAMETER OF INDICATION AREA.

$D = 6.312''$

STEP 2 MAXIMUM DEPTH OF INDICATION $d = 0.277''$

STEP 3 CONFIRM THAT NO ADDITIONAL INDICATIONS
ARE FOUND WITHIN A 21.5'' RADIUS

✓ CONFIRMED.

STEP 4 IF STEP 3 IS VIOLATED, RE-CIRCUMSCRIBE
THE AREA AND RE-DETERMINE "D" AND "d"

STEP 5 DETERMINE ARC REGION (S) FROM APPROPRIATE
FIGURE 7 OR 8

✓ LOCAL SHELL REGION, FIGURE 7.

 FREE SHELL REGION, FIGURE 8.

$l_1 = \underline{38.125''}$ LIES IN ARC REGION S5

$l_2 = \underline{43.253''}$ LIES IN ARC REGION S5

S5 PERMISSIBLE CORRODED THICKNESS = $0.292''$

S5 PERMISSIBLE CORRODED THICKNESS = $0.292''$

 **TELEDYNE ENGINEERING SERVICES**

BY RKE DATE 1-26-88
CHKD. BY PWP DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 10 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION # 3

STEP 6 CHECK IF MEASURED INDICATION DEPTH
IS LESS THAN THE PERMISSIBLE CORRODED
THICKNESS (t_c)

PERMISSIBLE CORRODED THICKNESS = $t_c = \underline{0.292}''$

INDICATION DEPTH = $d = \underline{0.277}''$

✓, $d \leq t_c$, THEN INDICATION IS ACCEPTABLE,
STOP, SKIP REMAINING STEPS

_____, $d > t_c$, THEN CONTINUE

STEP 7 DETERMINE CIRCUMSCRIBED DIAMETER MULTIPLIER
(F) FROM THE TABLE OF FIGURE 9 OR 10.


____ FREE SHELL REGION, FIGURE 9

____ RING GIRDER (LOCAL) SHELL REGION, FIGURE 10

S____, FACTOR "F" = _____

S____, FACTOR "F" = _____

LARGEST MULTIPLIER FACTOR "F" = _____



TELEDYNE ENGINEERING SERVICES



BY RAE DATE 1-26-88
CHKD. BY RWP DATE 1-26-99

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**


SHEET NO. 11 OF
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #4



(OUTSIDE)
 $l_1 = 46.513''$
 $l_2 = 48.336''$



100-100000

100-100000



 **TELEDYNE ENGINEERING SERVICES**

BY R.H. DATE 1-26-88
CHKD. BY JMP DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 12 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #4

STEP 1 CIRCUMSCRIBED DIAMETER OF INDICATION AREA.

$D = 2.261$ IN

STEP 2 MAXIMUM DEPTH OF INDICATION $d = 0.338$ IN

STEP 3 CONFIRM THAT NO ADDITIONAL INDICATIONS
ARE FOUND WITHIN A 21.5" RADIUS

✓ CONFIRMED

STEP 4 IF STEP 3 IS VIOLATED, RE-CIRCUMSCRIBE
THE AREA AND RE-DETERMINE "D" AND "d"

STEP 5 DETERMINE ARC REGION (S) FROM APPROPRIATE
FIGURE 7 OR 8

✓ LOCAL SHELL REGION, FIGURE 7.

 FREE SHELL REGION, FIGURE 8.

$L_1 = 16.513$ IN LIES IN ARC REGION S5

$L_2 = 48.336$ IN LIES IN ARC REGION S4

S5 PERMISSIBLE CORRODED THICKNESS = 0.292 IN

S4 PERMISSIBLE CORRODED THICKNESS = 0.287 IN

THE UNIVERSITY OF CHICAGO

1952

1953

1954

1955

1956

1957

1958

1959

1960

1961

1962

1963

1964

1965

1966

1967

1968

1969



 **TELEDYNE ENGINEERING SERVICES**

BY RKS DATE 1-26-88
CHKD. BY lm DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 13 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #4

STEP 6 CHECK IF MEASURED INDICATION DEPTH
IS LESS THAN THE PERMISSIBLE CORRODED
THICKNESS (t_c).

PERMISSIBLE CORRODED THICKNESS = $t_c = \underline{0.287}^{\text{IN}}$

INDICATION DEPTH = $d = \underline{0.338}^{\text{IN}}$

____, $d < t_c$, THEN INDICATION IS ACCEPTABLE,
STOP, SKIP REMAINING STEPS.

✓, $d > t_c$, THEN CONTINUE

STEP 7 DETERMINE CIRCUMSCRIBED DIAMETER MULTIPLIER
(F) FROM THE TABLE OF FIGURE 9 OR 10.

____ FREE SHELL REGION, FIGURE 9

✓ RING GIRDER (LOCAL) SHELL REGION, FIGURE 10

S5, FACTOR "F" = 0.925

S4, FACTOR "F" = 0.935

LARGEST MULTIPLIER FACTOR "F" = 0.935

1000

1000



 **TELEDYNE ENGINEERING SERVICES**

BY RJE DATE 1-26-88
CHKD. BY RM DATE 1-26-88

**NMP-1 SHELL THICKNESS
REQUIREMENTS 6801-2**

SHEET NO. 14 OF _____
PROJ. NO. 6801

NMP-1 TORUS SHELL

TORUS SHELL INDICATION SAMPLE CALCULATION #4

STEP 8 DETERMINE EQUIVALENT DIAMETER (D')
WHICH CIRCUMSCRIBES THE INDICATIONS.

$$D' = D \times F$$

$$D' = \underline{2.261}^{\text{IN}} \times \underline{0.935} = \underline{2.114}^{\text{IN}}$$

STEP 9 USING D' AND APPROPRIATE FIGURE 9 OR 10,
DETERMINE THE ALLOWABLE INDICATION
DEPTH (d')

 FREE SHELL, FIGURE 9

 ✓ LOCAL SHELL, FIGURE 10

$$\text{ALLOWABLE DEPTH, } d' = \underline{0.347}^{\text{IN}}$$

* ADJUST ALLOWABLE DEPTH (d') TO ACCOUNT FOR
REDUCED WALL THICKNESS MEASURED.

$$\text{ORIGINAL WALL THICKNESS, } T_0 = 0.460^{\text{IN}}$$

$$\text{MEASURED WALL THICKNESS, } t = \underline{0.453}^{\text{IN}}$$

$$\text{ADJUSTED } d' = d' - (T_0 - t) = \underline{0.340}^{\text{IN}}$$

$$\text{INDICATION DEPTH, } d = \underline{0.338}^{\text{IN}}$$

 ✓ , $d \leq d'$, INDICATION IS ACCEPTABLE
 , $d > d'$, WELD REPAIR REQUIRED

1
2
3



ATTACHMENT D

Niagara Mohawk Calculation S22-4-WW198-STAT01

Torus Wall Thinning
Trending Analysis

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100

100



NUCLEAR ENGINEERING &
LICENSING

DISCIPLINE: STRUCTURAL

PAGE 1

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1 CALC. NO. S22-4-WW198-STAT 1

SUBJECT: TORUS WALL THINNING, TRENDING ANALYSIS

BUILDING: REACTOR FLOOR ELEV.: 198'

INDEX NO.: 3-N2.1-S22-4

ORIGINATOR(S): A-Habis (CSL) D. Westcott

TOTAL SHT'S. 119

CHECKER(S): [Signature]

LAST SHT. NO.: 115

RECORD OF ISSUES

REV.	DESCRIPTION	M.O.#	BY	DATE	CHKD.	DATE	APPD.	DATE	DATE FILMED
0	INITIAL ISSUE	-	AH/DP	5/29/88	RF	5/29	RF	5/24/88	

COMPUTER OUTPUT YES NO

SAFETY RELATED YES NO

DRAWINGS REFERENCED: NONE

REFERENCES:

DWG. NO. INDEX SHT. REV.

- (1) ISJ TORUS WALL THICKNESS MEASUREMENTS (APPENDIX A)
- (2) SOFTWARE PACKAGES SYMPHONY^(1.2) & CHART MASTER (VER. 6.2)

KEYWORDS: NMP1, STRUCTURAL, TORUS WALL,

CROSS REF.:



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522-4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT I

CALC. NO. -STAT #1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING - ANALYSIS


ORIG. AT/DRW DATE: 5/20/88

INDEX: 3-N2.1-522-4

CHK'D. FIF DATE: 5/23

TABLE OF CONTENTS

	<u>PAGE NO.</u>
SCOPE	3
DISCUSSION	3
ANALYSIS OF 1975, 1977, 1979, 1981 AND 1984 ISI DATA	6
ANALYSIS OF 1986 DATA	11
ANALYSIS OF 1988 DATA	14
ANALYSIS OF 1988 BOTTOM RADIAL DATA	17
ANALYSIS OF 1988 NRC DATA	20
REGION 1 TRENDING CHART	23
REGION 1 TRENDING CHART (W/O 1984 DATA)	24
REGION.. 2 TRENDING CHART	24A
REGION 3 TRENDING CHART	24B
REGION 4 TRENDING CHART	24C
REGION 5 TRENDING CHART	24D
APPENDIX 'A' — ISI MEASUREMENTS FOR TORUS SHELL THICKNESS FOR YEAR 1975, 1977, 1979, 1981, 1986, 1988 (AREAS 1 THRU 5)	25
— RADIAL MEASUREMENTS 1988 UT EXAM - STEAM EROSION	
— 1988 NRC DATA	



522.4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT I

CALC. NO. - STAT #1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS

ORIG. AH/DRW DATE: 5/20/88

INDEX: 3-N2.1-522.4

CHK'D. FTE DATE: 5/23/88

SCOPE

TO GENERATE TRENDING CHARTS FOR TORUS SHELL THICKNESS BASED ON MEASUREMENTS CONDUCTED BY THE ISI GROUP AT NINE MILE POINT.

THESE CHARTS HAVE BEEN PRESENTED TO RESOLVE NRC CONCERN REGARDING TORUS WALL THINNING:

DISCUSSION

THE ISI GROUP AT NINE MILE POINT HAS CONDUCTED THE MEASUREMENTS OF TORUS SHELL THICKNESS SINCE 1975 USING UT METHODS. THIS DATA IS CONTAINED IN APPENDIX 'A' OF THESE CALCULATIONS. 'SYMPHONY' WAS USED TO ANALYZE THIS DATA TO CALCULATE:

- (i) MEAN VALUE
 - (ii) STANDARD DEVIATION
 - & (iii) (MEAN VALUE) - (STANDARD DEVIATION)
- FOLLOWING 'SYMPHONY' FILES WERE GENERATED.

<u>FILE NAME</u>	<u>DESCRIPTION</u>
DAN. WR1	ANALYSIS OF 1975, 1977, 1979, 1981 AND 1984 ISI DATA. ALSO INCLUDES SUMMARY OF RESULTS.
DAN. WR2	ANALYSIS OF 1986 DATA
DAN. WR3	ANALYSIS OF 1988 DATA
DAN. WR4	ANALYSIS OF 1988 BOTTOM RADIAL DATA
DAN. WR5	ANALYSIS OF 1988 NRC DATA



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522-4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. -STAT ϕ 1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING . ANALYSIS

ORIG. ATH/DRW DATE: 5/20/88

INDEX: 3-N2.1-522-4

CHK'D. EIF DATE: 5/23/88

THE 'SYMPHONY' FILES WERE USED AS INPUT TO 'CHART MASTER' TO GENERATE TRENDING CHARTS FOR DIFFERENT REGIONS.

FOLLOWING 'CHART MASTER' FILES WERE GENERATED

<u>FILE NAME</u>	<u>DESCRIPTION</u>
DAN 1. CHT	REGION 1 TRENDING CHART
DAN 1A. CHT	REGION 1 TRENDING CHART (W/O 1984 DATA)
DAN 2. CHT	REGION 2 TRENDING CHART
DAN 3. CHT	REGION 3 TRENDING CHART
DAN 4. CHT	REGION 4 TRENDING CHART
DAN 5. CHT	REGION 5 TRENDING CHART

REGION 1 THRU 5 ARE SHOWN ON THE SKETCH ON PAGE 5

THE SPREADSHEETS FOR SYMPHONY FILES DAN,WR1 THRU DAN,WR5 ARE STRUCTURED IN TWO BLOCKS OF FIVE COLUMNS. THE SECOND SET OF COLUMNS INVOLVE INSTRUMENT ERROR CALCULATIONS THAT WERE NOT USED IN THIS ANALYSIS.

THE ERROR MESSAGES AT THE BOTTOM OF COLUMNS FOUR & FIVE IN DAN,WR5 ARE IRRELEVANT BECAUSE THESE COLUMNS WERE NOT USED IN THE CALCULATIONS.

A TYPICAL EX1

70 11

12
13
14

15


16



PROJECT: NINE MILE POINT NUC. STA.-UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDDING ANALYSIS
 INDEX: 3-N2.1-522-4

522-4-WW198
 CALC. NO. -STAT 01 REV. 0
 ORIG. AH/DRW DATE: 5/29/88
 CHK'D. FHF DATE: 5/31/88

LOCATION OF NINE MILE PT UNIT #1 SUPPRESSION CHAMBER THICKNESS MEASUREMENT "STATIONS"




NIAGARA MOHAWK POWER CORP.

4-26-79

SE CORNER

- NOTES:
- 1 SCALE 1/8" = 1' 10"
 - 2 2 6" CORE SPRAY BYPASS
 - 3 12" CORE SPRAY



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1

S22-4-WW198
CALC. NO. -STAT Φ1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS

ORIG. AH/DRW DATE: 5/20/88

INDEX: 3-N2.1-522.4

CHK'D. FMP DATE: 5/23

DAN. WR 1

POINT	1	2	3	4	5	1	2	3	4	5
A1	0.485	0.475	0.485	0.490	0.485	0.48015	0.47025	0.48015	0.4851	0.48015
A2	0.495	0.480	0.490	0.485	0.490	0.49005	0.4752	0.4851	0.48015	0.4851
A3	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
A4	0.500	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
A5	0.490	0.480	0.495	0.490	0.485	0.4851	0.4752	0.4851	0.49005	0.4851
B1	0.485	0.480	0.490	0.490	0.485	0.48015	0.4752	0.4851	0.49005	0.4851
B2	0.495	0.480	0.490	0.490	0.485	0.4851	0.4752	0.4851	0.49005	0.4851
B3	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
B4	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
B5	0.495	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
C1	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
C2	0.495	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
C3	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
C4	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
D1	0.495	0.480	0.495	0.490	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
D2	0.495	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
D3	0.495	0.480	0.495	0.490	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
D4	0.485	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
D5	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
E1	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
E2	0.480	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
E3	0.485	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
E4	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
E5	0.485	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
F1	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
F2	0.485	0.480	0.490	0.495	0.485	0.4851	0.4752	0.4851	0.49005	0.4851
F3	0.490	0.480	0.490	0.495	0.485	0.4851	0.4752	0.4851	0.49005	0.4851
F4	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
F5	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
G1	0.495	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
G2	0.475	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
G3	0.495	0.480	0.495	0.490	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
G4	0.500	0.480	0.495	0.490	0.485	0.4851	0.47025	0.4851	0.49005	0.4851
G5	0.490	0.475	0.490	0.495	0.485	0.4851	0.47025	0.4851	0.49005	0.4851

0.490714 0.476285 0.490285 0.492142 0.485285
 0.004333 0.002185 0.001645 0.003440 0.004452
 0.486381 0.474100 0.488619 0.488702 0.480822

TYPICAL FOR PAGES 7, 8, 9, 10, 13, 16, 19 & 21
 MEAN VALUE
 STANDARD DEVIATION
 (MEAN VALUE) MINUS
 (STANDARD DEVIATION)

100

100



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522-4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT I

CALC. NO. - STAT #1 REV. 0

SUBJECT: TORUS WALL THINNING TRENDING . ANALYSIS

ORIG. AH/DRW DATE: 5/29/88

INDEX: 3-N2.1-522.4

CHK'D. TJF DATE: 5/23

Outage Year	1	2	3	4	5
A1	0.470	0.470	0.470	0.470	0.470
A2	0.470	0.465	0.470	0.470	0.470
A3	0.455	0.470	0.470	0.470	0.470
A4	0.470	0.470	0.470	0.470	0.470
A5	0.470	0.470	0.470	0.470	0.470
B1	0.470	0.468	0.470	0.470	0.470
B2	0.470	0.458	0.470	0.470	0.470
B3	0.475	0.470	0.470	0.470	0.470
B4	0.470	0.470	0.470	0.470	0.470
B5	0.470	0.470	0.470	0.470	0.470
C1	0.468	0.470	0.470	0.470	0.470
C2	0.470	0.465	0.470	0.470	0.470
C3	0.468	0.465	0.470	0.470	0.470
C4	0.470	0.465	0.470	0.470	0.470
C5	0.470	0.470	0.470	0.470	0.470
D1	0.470	0.470	0.470	0.470	0.470
D2	0.470	0.470	0.470	0.470	0.470
D3	0.470	0.470	0.470	0.470	0.470
D4	0.470	0.470	0.470	0.470	0.470
D5	0.470	0.470	0.470	0.470	0.470
E1	0.470	0.460	0.470	0.470	0.470
E2	0.478	0.470	0.470	0.470	0.470
E3	0.470	0.470	0.470	0.470	0.470
E4	0.475	0.470	0.470	0.470	0.470
E5	0.460	0.470	0.470	0.470	0.470
F1	0.470	0.470	0.470	0.470	0.470
F2	0.465	0.470	0.470	0.470	0.470
F3	0.465	0.470	0.470	0.470	0.470
F4	0.470	0.470	0.470	0.470	0.470
F5	0.470	0.470	0.470	0.470	0.470
G1	0.470	0.470	0.470	0.470	0.470
G2					
G3					
G4					
G5					

0.469633 0.468866 0.47 0.47 0.47 0.47
 0.003124 0.002376 0.000000 0.000000 0.000000 0.000000
 0.466508 0.465489 0.469999 0.469999 0.469999 0.469999

(SEE PAGE 6)



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT Nuc. STA.-UNIT I

SUBJECT: TORUS WALL THINNING TRENDDING ANALYSIS

INDEX: 3-N2.1-522.4


S22.4-WW198
CALC. NO. -STAT Φ1 REV. 0

ORIG. AH/DRW DATE: 5/20/88

CHK'D. VHF DATE: 5/23/88

Outage Year	1979	AREA				
Instr. Error		1	2	3	4	5
A1	0.491	0.478	0.495	0.483	0.485	
A2	0.491	0.478	0.495	0.483	0.487	
A3	0.487	0.483	0.495	0.483	0.483	
A4	0.482	0.483	0.480	0.498	0.483	
A5	0.488	0.485	0.486	0.487	0.497	
A6	0.484	0.483	0.485	0.490	0.498	
B1	0.482	0.481	0.485	0.489	0.498	
B2	0.486	0.488	0.489	0.490	0.488	
B3	0.480	0.483	0.482	0.496	0.493	
B4	0.482	0.486	0.484	0.490	0.490	
B5	0.479	0.481	0.500	0.492	0.480	
B6	0.485	0.486	0.494	0.488	0.487	
C1	0.483	0.484	0.492	0.490	0.485	
C2	0.483	0.483	0.491	0.485	0.489	
C3	0.484	0.478	0.483	0.485	0.490	
C4	0.487	0.483	0.483	0.489	0.489	
C5	0.479	0.480	0.488	0.482	0.489	
C6	0.485	0.484	0.490	0.485	0.488	
D1	0.480	0.480	0.495	0.487	0.490	
D2	0.487	0.482	0.487	0.478	0.489	
D3	0.481	0.484	0.498	0.480	0.488	
D4	0.486	0.482	0.490	0.480	0.482	
D5	0.482	0.477	0.486	0.486	0.485	
D6	0.483	0.490	0.493	0.486	0.489	
E1	0.487	0.487	0.487	0.488	0.493	
E2	0.482	0.493	0.480	0.487	0.489	
E3	0.460	0.482	0.483	0.484	0.483	
E4	0.485	0.481	0.487	0.488	0.492	
E5	0.488	0.485	0.480	0.487	0.490	
E6	0.482	0.485	0.489	0.480	0.490	
F1	0.484	0.475	0.490	0.486	0.486	
F2	0.485	0.484	0.487	0.485	0.491	
F3	0.488	0.492	0.480	0.487	0.485	
F4	0.479	0.480	0.486	0.483	0.485	
F5	0.475	0.480	0.483	0.488	0.488	
F6	0.483	0.476	0.484	0.480	0.485	
G1						
G2						
G3						
G4						
G5						

0.48325 0.482944 0.487722 0.487222 0.488277
 0.005203 0.003929 0.005236 0.004333 0.004127
 0.478046 0.479014 0.482485 0.482868 0.484150
 (SEE PAGE 6)



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522-4-WW198

PROJECT: NINE MILE POINT MUC. STA.-UNIT I

CALC. NO. -STAT Φ I REV. 0

SUBJECT: TORUS WALL THINNING TRENDING ANALYSIS


ORIG. AH/DRW DATE: 5/20/88

INDEX: 3-N2.1-522-4

CHK'D. TJF DATE: 5/23

Outage Year	1981	1982	1983	1984	1985
POINT	1	2	3	4	5
A1	0.481	0.466	0.479	0.482	0.490
A2	0.480	0.472	0.481	0.483	0.488
A3	0.482	0.468	0.478	0.487	0.485
A4	0.481	0.468	0.483	0.487	0.488
A5	0.470	0.470	0.481	0.489	0.486
A6	0.471	0.485	0.482	0.489	0.485
B1	0.479	0.469	0.478	0.485	0.485
B2	0.481	0.470	0.477	0.481	0.486
B3	0.488	0.468	0.479	0.485	0.483
B4	0.484	0.470	0.480	0.486	0.483
B5	0.467	0.469	0.487	0.482	0.486
B6	0.471	0.480	0.478	0.488	0.490
C1	0.483	0.473	0.481	0.479	0.486
C2	0.487	0.468	0.482	0.480	0.484
C3	0.486	0.473	0.479	0.481	0.488
C4	0.479	0.471	0.482	0.475	0.482
C5	0.474	0.469	0.485	0.482	0.483
C6	0.467	0.480	0.488	0.477	0.479
D1	0.487	0.471	0.484	0.479	0.485
D2	0.489	0.474	0.481	0.481	0.483
D3	0.479	0.478	0.483	0.479	0.486
D4	0.480	0.469	0.483	0.479	0.482
D5	0.474	0.475	0.482	0.479	0.482
D6	0.476	0.480	0.478	0.483	0.480
E1	0.483	0.471	0.485	0.480	0.484
E2	0.482	0.474	0.484	0.483	0.482
E3	0.486	0.470	0.485	0.473	0.483
E4	0.482	0.475	0.484	0.477	0.470
E5	0.491	0.475	0.480	0.477	0.479
E6	0.468	0.482	0.483	0.481	0.479
F1	0.488	0.473	0.493	0.475	0.485
F2	0.482	0.476	0.490	0.483	0.483
F3	0.486	0.478	0.489	0.475	0.483
F4	0.482	0.475	0.482	0.475	0.484
F5	0.472	0.476	0.478	0.475	0.472
F6	0.467	0.481	0.478	0.479	0.479
G1					
G2					
G3					
G4					
G5					

0.479611 0.473388 0.482277 0.480833 0.4835
 0.002791 0.004650 0.003708 0.003954 0.004106
 0.472919 0.468738 0.478568 0.476878 0.479393
 (SEE PAGE 6)



NUCLEAR ENGINEERING & LICENCING


DISCIPLINE STRUCTURAL

PROJECT: NBIE MILE POINT NUC. STA.-UNIT I
 SUBJECT: TORUS WALL THINNING TRENDDING. ANALYSIS
 INDEX: 3-N2.1-S22-4

522-4-WW198
 CALC. NO. -STAT Φ1 REV. 0
 ORIG. AH/DRAW DATE: 5/20/88
 CHK'D. FHF DATE: 5/23/88

Outage Year	1984	AREA				
POINT	1	2	3	4	5	
A1	0.48	0.50	0.51	0.49	0.51	0.4752
A2	0.49	0.50	0.49	0.48	0.51	0.4851
A3	0.50	0.50	0.50	0.49	0.50	0.495
A4	0.49	0.49	0.50	0.49	0.51	0.4851
A5	0.47	0.50	0.51	0.48	0.51	0.4653
A6	0.49	0.50	0.50	0.49	0.49	0.4851
B1	0.49	0.53	0.51	0.49	0.49	0.4851
B2	0.48	0.50	0.51	0.49	0.52	0.4752
B3	0.50	0.49	0.52	0.49	0.51	0.495
B4	0.48	0.49	0.50	0.49	0.50	0.4851
B5	0.49	0.50	0.50	0.49	0.50	0.4851
B6	0.49	0.50	0.49	0.48	0.49	0.4851
C1	0.50	0.50	0.50	0.49	0.50	0.495
C2	0.49	0.50	0.51	0.49	0.50	0.4851
C3	0.48	0.49	0.50	0.48	0.50	0.4752
C4	0.48	0.50	0.52	0.48	0.51	0.4851
C5	0.49	0.50	0.50	0.48	0.51	0.495
C6	0.49	0.50	0.49	0.48	0.50	0.4851
D1	0.51	0.50	0.52	0.48	0.50	0.5049
D2	0.49	0.51	0.50	0.48	0.49	0.4851
D3	0.49	0.50	0.50	0.48	0.49	0.4851
D4	0.48	0.50	0.51	0.49	0.49	0.4752
D5	0.49	0.50	0.50	0.48	0.49	0.4851
D6	0.48	0.50	0.49	0.48	0.48	0.4752
E1	0.50	0.50	0.53	0.48	0.49	0.495
E2	0.49	0.49	0.50	0.48	0.51	0.4851
E3	0.49	0.49	0.52	0.48	0.50	0.4851
E4	0.48	0.50	0.50	0.48	0.50	0.4752
E5	0.49	0.50	0.50	0.48	0.50	0.4851
E6	0.49	0.50	0.48	0.48	0.51	0.4752
F1	0.51	0.50	0.50	0.48	0.49	0.5049
F2	0.48	0.50	0.50	0.48	0.51	0.4752
F3	0.49	0.49	0.51	0.46	0.51	0.5049
F4	0.50	0.50	0.50	0.48	0.50	0.495
F5	0.50	0.50	0.50	0.49	0.49	0.4851
F6	0.49	0.50	0.48	0.48	0.49	0.4752
G1						
G2						
G3						
G4						
G5						

... 1722 0.49944 0.50277 0.48361 0.50027
 0.00255 0.00643 0.01070 0.00480 0.00897
 0.43106 0.49280 0.49207 0.47887 0.491306
 (SEE PAGE 6)



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT MUC. STA. - UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDDING. ANALYSIS
 INDEX: 3-N2.1-522.4


522.4-WW198
 CALC. NO. -STAT #1 REV. 0
 ORIG. ACT/DRW DATE: 5/20/88
 CHK'D. FHP DATE: 5/23


DAN. WR 2

Dna's Analysis #2

YEAR 1986

POINT	1	2	3	4	5	1	2	3	4	5
A1	0.46	0.46	0.44	0.48	0.46	0.4554	0.4554	0.4356	0.4752	0.4554
A2	0.46	0.46	0.44	0.48	0.46	0.4554	0.4554	0.4356	0.4752	0.4554
A3	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A4	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A5	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A6	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A7	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A8	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A9	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A10	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A11	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
A2	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B1	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B2	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B3	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B4	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B5	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B6	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B7	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B8	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B9	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B10	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B11	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
B12	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C1	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C2	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C3	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C4	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C5	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C6	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C7	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C8	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C9	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C10	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C11	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
C12	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D1	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D2	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D3	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D4	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D5	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D6	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D7	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D8	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D9	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D10	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D11	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
D12	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
E1	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
E2	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
E3	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
E4	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554
E5	0.46	0.46	0.46	0.48	0.46	0.4554	0.4554	0.4554	0.4752	0.4554





1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

S22-4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. -STAT #1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING. ANALYSIS

ORIG. Alt/DRW DATE: 5/20/88

INDEX: 3-N2.1-S22-4

CHK'D. TUF DATE: 4/23

DAN.WR3

Dan's Analysis #3

YEAR 1988

INSIG-ERRGR

POINT	1	2	3	4	5	AREA	1	2	3	4	5	AREA	
A1	0.452	0.455	0.456	0.460	0.462	0.45192	0.450192	0.45318	0.454176	0.45816	0.460152	0.45816	0.460152
A2	0.458	0.459	0.460	0.463	0.462	0.456168	0.456168	0.457164	0.45816	0.45816	0.461148	0.45816	0.461148
A3	0.459	0.459	0.460	0.455	0.462	0.457164	0.457164	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A4	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A5	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A6	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A7	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A8	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A9	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A10	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A11	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
A12	0.460	0.459	0.460	0.455	0.462	0.45816	0.45816	0.457164	0.45816	0.45816	0.460152	0.45816	0.460152
B1	0.461	0.458	0.459	0.456	0.459	0.459156	0.459156	0.456168	0.457164	0.457164	0.460152	0.457164	0.460152
B2	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B3	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B4	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B5	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B6	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B7	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B8	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B9	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B10	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B11	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
B12	0.459	0.458	0.459	0.456	0.459	0.457164	0.457164	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C1	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C2	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C3	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C4	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C5	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C6	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C7	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C8	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C9	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C10	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C11	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
C12	0.458	0.458	0.459	0.456	0.459	0.456168	0.456168	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
D1	0.454	0.454	0.460	0.458	0.451	0.452184	0.452184	0.456168	0.457164	0.457164	0.457164	0.457164	0.457164
D2	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D3	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D4	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D5	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D6	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D7	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D8	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D9	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D10	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D11	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
D12	0.454	0.454	0.460	0.458	0.452	0.452184	0.452184	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
E1	0.456	0.458	0.460	0.453	0.452	0.454176	0.454176	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
E2	0.459	0.458	0.460	0.453	0.452	0.454176	0.454176	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
E3	0.459	0.458	0.460	0.453	0.452	0.454176	0.454176	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
E4	0.459	0.458	0.460	0.453	0.452	0.454176	0.454176	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816
E5	0.459	0.458	0.460	0.453	0.452	0.454176	0.454176	0.456168	0.45816	0.45816	0.45816	0.45816	0.45816

1000

1000

1000

NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA.-UNIT I

522-4-WW198
CALC. NO. - STAT 01 REV. 0


SUBJECT: TORUS WALL THINNING TRENDING ANALYSIS

ORIG. AH/DRW DATE: 5/20/88

INDEX: 3-N2.1-522-4

CHK'D. PHF DATE: 5/23

E6	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E7	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E8	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E9	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E10	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E11	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
E12	0.459	0.458	0.460	0.455	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F1	0.459	0.460	0.464	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F2	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F3	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F4	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F5	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F6	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F7	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F8	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F9	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F10	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F11	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
F12	0.459	0.460	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G1	0.458	0.459	0.460	0.454	0.449	0.457164	0.456168	0.45816	0.45318	0.450192
G2	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G3	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G4	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G5	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G6	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G7	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G8	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G9	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G10	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G11	0.458	0.459	0.460	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
G12	0.458	0.459	0.461	0.452	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
H1	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H2	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H3	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H4	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H5	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H6	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H7	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H8	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H9	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H10	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H11	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
H12	0.458	0.459	0.461	0.452	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
I1	0.455	0.458	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I2	0.457	0.458	0.462	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I3	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I4	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I5	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I6	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I7	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I8	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I9	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I10	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I11	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
I12	0.459	0.458	0.461	0.454	0.452	0.457164	0.456168	0.45816	0.45318	0.450192
J1	0.452	0.458	0.461	0.454	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
J2	0.452	0.458	0.461	0.454	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
J3	0.452	0.458	0.461	0.454	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
J4	0.452	0.458	0.461	0.454	0.455	0.457164	0.456168	0.45816	0.45318	0.450192
J5	0.452	0.458	0.461	0.454	0.455	0.457164	0.456168	0.45816	0.45318	0.450192



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL


PROJECT: NINE MILE POINT NUC. STA.-UNIT I
 SUBJECT: TORUS WALL THINNING TRENDDING. ANALYSIS
 INDEX: 3-N2.1-S22.4

S22-4-WW198
 CALC. NO. -STAT #1 REV. 0
 ORIG. AH/DRW DATE: 5/20/88
 CHK'D. FF DATE: 6/23

J6	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
U	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
J9	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
J10	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
J11	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
J12	0.452	0.454	0.455	0.450192	0.456168	0.459156	0.452184	0.45318
K1	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K2	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K3	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K4	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K5	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K6	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K7	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K8	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K9	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K10	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K11	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
K12	0.458	0.458	0.452	0.456168	0.456168	0.45816	0.456168	0.450192
L1	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L2	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L3	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L4	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L5	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L6	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L7	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L8	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L9	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L10	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L11	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192
L12	0.457	0.458	0.452	0.457164	0.457176	0.45816	0.452184	0.450192

0.457479 0.458486 0.46025 0.453333 0.453854
 0.002263 0.000841 0.000953 0.002303 0.003197
 0.455215 0.457644 0.459296 0.453029 0.450657
 0.456448 0.456448 0.458408 0.456448 0.456448
 0.456448 0.456448 0.458408 0.456448 0.456448

(SEE PAGE 6)



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT Nuc. STA. - UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDS: ANALYSIS
 INDEX: 3-N2.1-S22-4

S22-4-WW198
 CALC. NO. - STAT #1 REV. 0
 ORIG. Att/DRW DATE: 5/20/88
 CHK'D. FIFE DATE: 5/73


DAN.WR.4

Dan's Analysis #4

1988 BOTTOM

YEAR
 LISC. EGOR

POINT	0 DEG	90 DEG	180 DEG	270 DEG	AREA
A1	0.465	0.456	0.463	0.464	0.46314
A2	0.464	0.455	0.465	0.455	0.462144
A3	0.465	0.454	0.466	0.455	0.461148
A4	0.466	0.453	0.467	0.456	0.460152
A5	0.467	0.452	0.468	0.457	0.459156
A6	0.468	0.451	0.469	0.458	0.458160
A7	0.469	0.450	0.470	0.459	0.457164
A8	0.470	0.449	0.471	0.460	0.456168
A9	0.471	0.448	0.472	0.461	0.455172
A10	0.472	0.447	0.473	0.462	0.454176
A11	0.473	0.446	0.474	0.463	0.453180
A12	0.474	0.445	0.475	0.464	0.452184
A13	0.475	0.444	0.476	0.465	0.451188
A14	0.476	0.443	0.477	0.466	0.450192
A15	0.477	0.442	0.478	0.467	0.449196
A16	0.478	0.441	0.479	0.468	0.448200
A17	0.479	0.440	0.480	0.469	0.447204
A18	0.480	0.439	0.481	0.470	0.446208
A19	0.481	0.438	0.482	0.471	0.445212
A20	0.482	0.437	0.483	0.472	0.444216
A21	0.483	0.436	0.484	0.473	0.443220
A22	0.484	0.435	0.485	0.474	0.442224
A23	0.485	0.434	0.486	0.475	0.441228
A24	0.486	0.433	0.487	0.476	0.440232
A25	0.487	0.432	0.488	0.477	0.439236
A26	0.488	0.431	0.489	0.478	0.438240
A27	0.489	0.430	0.490	0.479	0.437244
A28	0.490	0.429	0.491	0.480	0.436248
A29	0.491	0.428	0.492	0.481	0.435252
A30	0.492	0.427	0.493	0.482	0.434256
A31	0.493	0.426	0.494	0.483	0.433260
A32	0.494	0.425	0.495	0.484	0.432264
A33	0.495	0.424	0.496	0.485	0.431268
A34	0.496	0.423	0.497	0.486	0.430272
A35	0.497	0.422	0.498	0.487	0.429276
A36	0.498	0.421	0.499	0.488	0.428280
A37	0.499	0.420	0.500	0.489	0.427284
A38	0.500	0.419	0.501	0.490	0.426288
A39	0.501	0.418	0.502	0.491	0.425292
A40	0.502	0.417	0.503	0.492	0.424296
A41	0.503	0.416	0.504	0.493	0.423300
A42	0.504	0.415	0.505	0.494	0.422304
A43	0.505	0.414	0.506	0.495	0.421308
A44	0.506	0.413	0.507	0.496	0.420312
A45	0.507	0.412	0.508	0.497	0.419316
A46	0.508	0.411	0.509	0.498	0.418320
A47	0.509	0.410	0.510	0.499	0.417324
A48	0.510	0.409	0.511	0.500	0.416328
A49	0.511	0.408	0.512	0.501	0.415332
A50	0.512	0.407	0.513	0.502	0.414336
A51	0.513	0.406	0.514	0.503	0.413340
A52	0.514	0.405	0.515	0.504	0.412344
A53	0.515	0.404	0.516	0.505	0.411348
A54	0.516	0.403	0.517	0.506	0.410352
A55	0.517	0.402	0.518	0.507	0.409356
A56	0.518	0.401	0.519	0.508	0.408360
A57	0.519	0.400	0.520	0.509	0.407364
A58	0.520	0.399	0.521	0.510	0.406368
A59	0.521	0.398	0.522	0.511	0.405372
A60	0.522	0.397	0.523	0.512	0.404376
A61	0.523	0.396	0.524	0.513	0.403380
A62	0.524	0.395	0.525	0.514	0.402384
A63	0.525	0.394	0.526	0.515	0.401388
A64	0.526	0.393	0.527	0.516	0.400392
A65	0.527	0.392	0.528	0.517	0.399396
A66	0.528	0.391	0.529	0.518	0.398400
A67	0.529	0.390	0.530	0.519	0.397404
A68	0.530	0.389	0.531	0.520	0.396408
A69	0.531	0.388	0.532	0.521	0.395412
A70	0.532	0.387	0.533	0.522	0.394416
A71	0.533	0.386	0.534	0.523	0.393420
A72	0.534	0.385	0.535	0.524	0.392424
A73	0.535	0.384	0.536	0.525	0.391428
A74	0.536	0.383	0.537	0.526	0.390432
A75	0.537	0.382	0.538	0.527	0.389436
A76	0.538	0.381	0.539	0.528	0.388440
A77	0.539	0.380	0.540	0.529	0.387444
A78	0.540	0.379	0.541	0.530	0.386448
A79	0.541	0.378	0.542	0.531	0.385452
A80	0.542	0.377	0.543	0.532	0.384456
A81	0.543	0.376	0.544	0.533	0.383460
A82	0.544	0.375	0.545	0.534	0.382464
A83	0.545	0.374	0.546	0.535	0.381468
A84	0.546	0.373	0.547	0.536	0.380472
A85	0.547	0.372	0.548	0.537	0.379476
A86	0.548	0.371	0.549	0.538	0.378480
A87	0.549	0.370	0.550	0.539	0.377484
A88	0.550	0.369	0.551	0.540	0.376488
A89	0.551	0.368	0.552	0.541	0.375492
A90	0.552	0.367	0.553	0.542	0.374496
A91	0.553	0.366	0.554	0.543	0.373500
A92	0.554	0.365	0.555	0.544	0.372504
A93	0.555	0.364	0.556	0.545	0.371508
A94	0.556	0.363	0.557	0.546	0.370512
A95	0.557	0.362	0.558	0.547	0.369516
A96	0.558	0.361	0.559	0.548	0.368520
A97	0.559	0.360	0.560	0.549	0.367524
A98	0.560	0.359	0.561	0.550	0.366528
A99	0.561	0.358	0.562	0.551	0.365532
A100	0.562	0.357	0.563	0.552	0.364536



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1

PROJECT: S22-4-WW198
CALC. NO. - STAT #1 REV. 0


SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS

ORIG. AH/DRW DATE: 5/20/88

INDEX: 3-N2.1-S22.4

CHK'D. FJC DATE: 5/23

E6	0.466	0.456	0.465	0.45	0.454176	0.454176	0.46314	0.4482
E7	0.465	0.453	0.468	0.46	0.46314	0.451188	0.466128	0.45816
E8	0.462	0.453	0.469	0.458	0.460152	0.451188	0.467124	0.456168
E9	0.463	0.455	0.466	0.455	0.461148	0.45318	0.464136	0.44322
E10	0.464	0.455	0.467	0.455	0.462144	0.45318	0.465132	0.45318
E11	0.462	0.458	0.466	0.451	0.460152	0.456168	0.464136	0.449196
E12	0.462	0.458	0.457	0.466	0.460152	0.456168	0.455172	0.45816
F2	0.465	0.46	0.465	0.465	0.460152	0.45318	0.45816	0.464136
F3	0.462	0.459	0.468	0.465	0.46314	0.45816	0.46314	0.46314
F4	0.463	0.453	0.469	0.464	0.460152	0.457164	0.466128	0.464136
F5	0.464	0.456	0.469	0.464	0.462144	0.454176	0.467124	0.462144
F6	0.469	0.46	0.466	0.463	0.461148	0.45816	0.464136	0.461148
F7	0.466	0.462	0.467	0.467	0.464136	0.460152	0.465132	0.465132
F8	0.462	0.448	0.48	0.463	0.460152	0.446208	0.47808	0.461148
F9	0.466	0.462	0.465	0.465	0.464136	0.460152	0.46314	0.46314
F10	0.466	0.458	0.466	0.46	0.464136	0.456168	0.45816	0.45816
F11	0.467	0.46	0.463	0.464	0.46314	0.45816	0.46314	0.46314
F12	0.462	0.462	0.459	0.463	0.460152	0.45816	0.46314	0.462144
G1	0.453	0.462	0.454	0.468	0.451188	0.460152	0.457164	0.461148
G2	0.463	0.459	0.462	0.478	0.461148	0.457164	0.460152	0.467128
G3	0.454	0.465	0.463	0.478	0.452184	0.464136	0.461148	0.46988
G4	0.458	0.465	0.467	0.48	0.456168	0.46314	0.465132	0.47808
G5	0.458	0.462	0.469	0.48	0.456168	0.460152	0.467124	0.47808
G6	0.46	0.466	0.466	0.477	0.45816	0.464136	0.464136	0.475092
G7	0.46	0.466	0.466	0.48	0.45816	0.464136	0.46318	0.47808
G8	0.462	0.466	0.463	0.48	0.460152	0.464136	0.461148	0.47808
G9	0.466	0.465	0.456	0.474	0.464136	0.46314	0.461148	0.472104
G10	0.459	0.462	0.46	0.473	0.457164	0.460152	0.45916	0.471108
G11	0.459	0.461	0.457	0.474	0.456168	0.459156	0.459172	0.472104
G12	0.459	0.461	0.455	0.475	0.457164	0.459156	0.45318	0.4731
H1	0.461	0.465	0.462	0.459	0.459156	0.46314	0.460152	0.457164
H2	0.462	0.46	0.459	0.464	0.460152	0.45816	0.457124	0.462144
H3	0.464	0.461	0.459	0.465	0.462144	0.459156	0.457164	0.46314
H4	0.463	0.464	0.457	0.465	0.461148	0.462144	0.455172	0.46314
H5	0.465	0.463	0.462	0.469	0.46314	0.461148	0.460152	0.467124
H6	0.462	0.463	0.462	0.467	0.460152	0.461148	0.460152	0.465132
H7	0.463	0.462	0.458	0.468	0.461148	0.460152	0.456168	0.466128
H8	0.465	0.465	0.458	0.468	0.46314	0.46714	0.456168	0.466128
H9	0.465	0.464	0.454	0.465	0.46314	0.46714	0.45318	0.46314
H10	0.465	0.462	0.457	0.465	0.46314	0.460152	0.455172	0.46448
H11	0.462	0.465	0.456	0.462	0.460152	0.46314	0.454176	0.460152
H12	0.463	0.462	0.454	0.464	0.461148	0.45816	0.452184	0.462144
I1	0.463	0.46	0.454	0.468	0.461148	0.45816	0.452184	0.462144
I2	0.463	0.462	0.455	0.468	0.461148	0.460152	0.45318	0.466128
I3	0.463	0.462	0.456	0.464	0.461148	0.460152	0.45318	0.466128
I4	0.462	0.461	0.456	0.466	0.460152	0.459156	0.454176	0.454176
I5	0.464	0.46	0.453	0.467	0.462144	0.459156	0.45318	0.465132
I6	0.462	0.461	0.458	0.467	0.460152	0.459156	0.456168	0.465132
I7	0.463	0.462	0.457	0.467	0.461148	0.460152	0.455172	0.465132
I8	0.465	0.462	0.462	0.465	0.46314	0.460152	0.460152	0.46318
I9	0.464	0.461	0.461	0.465	0.462144	0.459156	0.459156	0.46314
I10	0.462	0.461	0.46	0.467	0.460152	0.459156	0.456168	0.465132
I11	0.463	0.462	0.457	0.464	0.461148	0.460152	0.45318	0.462144
I12	0.466	0.46	0.461	0.466	0.461148	0.460152	0.459156	0.464136
J1	0.462	0.46	0.459	0.466	0.460152	0.45816	0.459156	0.464136
J2	0.464	0.462	0.462	0.467	0.462144	0.460152	0.460152	0.465132
J3	0.466	0.462	0.462	0.467	0.464136	0.460152	0.460152	0.465132
J4	0.465	0.462	0.465	0.462	0.46314	0.460152	0.464136	0.460152
J5	0.455	0.462	0.465	0.467	0.46314	0.460152	0.464136	0.465132



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522-4-WW198

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1

CALC. NO. - STAT #1 REV. 0

SUBJECT: TORUS WALL THINNING
TRENDING. ANALYSIS

ORIG. NH/DRW DATE: 5/20/88


INDEX: 3-N2.1-522.4

CHK'D. FJF DATE: 6/23

J6	0.462	0.462	0.463	0.467	0.460152	0.461148	0.465132
J7	0.463	0.46	0.461	0.467	0.461148	0.45816	0.459156
J8	0.462	0.462	0.463	0.466	0.460152	0.461148	0.464136
J9	0.462	0.463	0.46	0.465	0.460152	0.461148	0.46314
J10	0.462	0.46	0.459	0.464	0.460152	0.45816	0.462144
J11	0.463	0.462	0.459	0.458	0.461148	0.460152	0.457164
J12	0.463	0.462	0.462	0.461	0.46314	0.460152	0.459156
K1	0.464	0.462	0.459	0.467	0.462144	0.460152	0.465132
K2	0.463	0.461	0.454	0.468	0.461148	0.459156	0.466132
K3	0.462	0.462	0.454	0.466	0.460152	0.452184	0.466132
K4	0.464	0.462	0.456	0.464	0.462144	0.460152	0.464136
K5	0.466	0.467	0.462	0.468	0.464136	0.463132	0.460152
K6	0.463	0.467	0.459	0.466	0.461148	0.463132	0.466132
K7	0.464	0.46	0.458	0.467	0.462144	0.45816	0.457164
K8	0.463	0.463	0.455	0.467	0.461148	0.45318	0.465132
K9	0.465	0.461	0.456	0.465	0.46314	0.459156	0.46176
K10	0.465	0.46	0.458	0.462	0.46314	0.45816	0.46314
K11	0.463	0.462	0.458	0.461	0.461148	0.460152	0.460152
K12	0.463	0.462	0.453	0.461	0.461148	0.460152	0.451188
L1	0.463	0.462	0.463	0.465	0.461148	0.460152	0.461148
L2	0.464	0.464	0.454	0.467	0.462144	0.462144	0.465132
L3	0.462	0.464	0.457	0.468	0.460152	0.462144	0.455172
L4	0.463	0.462	0.454	0.464	0.461148	0.452184	0.462144
L5	0.462	0.463	0.455	0.465	0.460152	0.461148	0.46314
L6	0.466	0.463	0.455	0.467	0.46417	0.461148	0.45318
L7	0.462	0.461	0.458	0.467	0.460152	0.459156	0.465132
L8	0.462	0.461	0.454	0.465	0.460152	0.459156	0.465132
L9	0.463	0.461	0.454	0.465	0.461148	0.459156	0.46314
L10	0.462	0.465	0.455	0.464	0.460152	0.46314	0.45318
L11	0.463	0.467	0.452	0.462	0.461148	0.465132	0.450192
L12	0.461	0.461	0.455	0.459	0.459156	0.459156	0.45318
	0.463263	0.459104	0.462125	0.462138	0.003081	0.00408	0.00084
	0.002111	0.004013	0.005060	0.006592	0.00084	0.00084	0.00188
	0.461152	0.455090	0.457064	0.452545			
	0.461657						

SEE PAGE 6

AVERAGE OF
MEAN VALUES
PLOTTED AS
'RADIAL' GN
PAGE 23 & 24



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT Nuc. STA. - UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDDNG. ANALYSIS
 INDEX: 3-N2.1-522.4

522.4-WW198
 CALC. NO. -STAT Φ1 REV. 0
 ORIG. Att/DRW DATE: 5/20/88
 CHK'D. FVF DATE: 5/23

DAN. WR 5

Dan's Analysis #5
 YEAR 1988 NRC DATA
 1988-05-05 0.001

POINT	1	2	3	4	5	AREA	1	2	3	4	5
A1	0.453	0.483	0.448			ERR	0.451188	0.481068			
A3	0.451	0.452	0.45			ERR	0.449196	0.450192			
A5	0.45	0.459	0.446			ERR	0.4482	0.457164			
A7	0.449	0.456	0.451			ERR	0.447204	0.454176			
A9	0.448	0.457	0.448			ERR	0.446208	0.455172			
A11	0.447	0.456	0.45			ERR	0.445212	0.454176			
B3	0.449	0.456	0.453			ERR	0.444204	0.454176			
B5	0.451	0.452	0.449			ERR	0.443204	0.450192			
B7	0.449	0.451	0.449			ERR	0.442204	0.449196			
B9	0.449	0.454	0.448			ERR	0.441204	0.452184			
B11	0.45	0.465	0.449			ERR	0.440204	0.46314			
C1	0.449	0.459	0.453			ERR	0.439204	0.457164			
C3	0.45	0.453	0.452			ERR	0.438204	0.451188			
C5	0.45	0.458	0.453			ERR	0.437204	0.451188			
C7	0.449	0.458	0.452			ERR	0.436208	0.456168			
C9	0.451	0.455	0.452			ERR	0.435208	0.45318			
C11	0.451	0.454	0.452			ERR	0.434208	0.456168			
D1	0.45	0.453	0.453			ERR	0.43318	0.45318			
D3	0.45	0.453	0.45			ERR	0.432184	0.452184			
D5	0.451	0.458	0.45			ERR	0.431188	0.451188			
D7	0.451	0.454	0.452			ERR	0.430192	0.456168			
D9	0.448	0.451	0.452			ERR	0.429196	0.452184			
D11	0.449	0.458	0.456			ERR	0.428208	0.45318			
E1	0.448	0.462	0.454			ERR	0.427204	0.456168			
E3	0.451	0.448	0.447			ERR	0.426208	0.460152			
E5	0.451	0.456	0.45			ERR	0.425196	0.446208			
E7	0.451	0.457	0.452			ERR	0.424176	0.454176			
E9	0.45	0.455	0.454			ERR	0.423172	0.455172			
E11	0.451	0.454	0.451			ERR	0.422184	0.45318			
F1	0.449	0.454	0.454			ERR	0.421188	0.452184			
F3	0.453	0.457	0.45			ERR	0.420204	0.452184			
F5	0.45	0.458	0.454			ERR	0.419196	0.455172			
F7	0.449	0.456	0.453			ERR	0.418204	0.456168			
F9	0.451	0.457	0.453			ERR	0.417204	0.454176			
F11	0.45	0.456	0.452			ERR	0.416208	0.457164			
G1	0.45	0.441	0.452			ERR	0.4152184	0.457164			
G3	0.451	0.459	0.452			ERR	0.414204	0.452184			
G5	0.449	0.459	0.45			ERR	0.413204	0.455172			
G7	0.45	0.454	0.455			ERR	0.412204	0.452184			
G9	0.449	0.458	0.454			ERR	0.411204	0.456168			
G11	0.449	0.457	0.451			ERR	0.410204	0.456168			
H1	0.45	0.458	0.452			ERR	0.409204	0.455172			
H3	0.455	0.452	0.448			ERR	0.408204	0.455168			
H5	0.449	0.461	0.457			ERR	0.407204	0.450192			
H7	0.45	0.454	0.453			ERR	0.406204	0.452184			
H9	0.449	0.458	0.454			ERR	0.405204	0.459156			
H11	0.45	0.457	0.454			ERR	0.404204	0.45168			
I1	0.445	0.456	0.449			ERR	0.403204	0.455172			
I3	0.457	0.455	0.452			ERR	0.402208	0.45318			
I5	0.448	0.455	0.452			ERR	0.401208	0.454176			
I7	0.449	0.461	0.454			ERR	0.400204	0.459156			
I9	0.448	0.453	0.451			ERR	0.399208	0.456158			



100



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDDING. ANALYSIS
 INDEX: 3-N2.1-522-4

S22-4-WW198
 CALC. NO. -STATΦ1 REV. 0
 ORIG. A4/DRW DATE: 5/20/88
 CHK'D. FJP DATE: 5/23

111	0.455	0.457	0.449	0.451	0.4482	0.455172	ERR	0	0	0
J1	0.447	0.453	0.449	0.451	0.447204	0.451188	ERR	0	0	0
J3	0.452	0.459	0.45	0.452	0.4482	0.457164	ERR	0	0	0
J5	0.452	0.461	0.449	0.456	0.447204	0.459156	ERR	0	0	0
J7	0.452	0.456	0.449	0.456	0.447204	0.454176	ERR	0	0	0
J9	0.453	0.455	0.45	0.453	0.4482	0.454176	ERR	0	0	0
J11	0.454	0.461	0.449	0.454	0.447204	0.459156	ERR	0	0	0
K1	0.452	0.459	0.449	0.452	0.447204	0.457164	ERR	0	0	0
K3	0.453	0.463	0.45	0.453	0.4482	0.461148	ERR	0	0	0
K5	0.453	0.454	0.45	0.453	0.4482	0.452184	ERR	0	0	0
K7	0.453	0.456	0.448	0.453	0.446208	0.454176	ERR	0	0	0
K9	0.452	0.456	0.451	0.452	0.449196	0.454176	ERR	0	0	0
K11	0.452	0.453	0.45	0.452	0.4482	0.451168	ERR	0	0	0
L1	0.454	0.459	0.45	0.454	0.4482	0.487164	ERR	0	0	0
L3	0.456	0.461	0.45	0.456	0.4482	0.459156	ERR	0	0	0
L5	0.451	0.46	0.451	0.451	0.449196	0.45816	ERR	0	0	0
L7	0.449	0.462	0.449	0.453	0.447204	0.460152	ERR	0	0	0
L9	0.45	0.458	0.45	0.454	0.4482	0.456168	ERR	0	0	0
L11	0.452	0.46	0.452	0.456	0.450192	0.45816	ERR	0	0	0

(SEE PAGE 6)
 { 0.449888 0.456763 0.452125 ERR
 0.001629 0.004724 0.002426 ERR
 0.448259 0.452039 0.449698 ERR

0.452925
~~0.004299~~

SEE COMMENTS ON PAGE 4
 AVERAGE OF MEAN VALUE PLOTTED AS 'NRC' ON PAGE 23 & 24

11

11

11

11



1
2
3
4





NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1 522-4-WW198
 SUBJECT: TORUS WALL THINNING TRENDING ANALYSIS CALC. NO. -STAT 01 REV. 0
 INDEX: 3-N2.1-522.4 ORIG. ALL/DRW DATE: 5/20/88
 CHK'D. FHF DATE: 5/23

NINE MILE POINT UNIT 1
 MINIMUM TORUS WALL THICKNESS
 AREA NUMBER ONE :






NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT Nuc. STA.-UNIT 1
 SUBJECT: TORUS WALL THINNING TRENDING ANALYSIS
 INDEX: 3-N2.1-522-4

522-4-WW198
 CALC. NO. -STATØ1 REV. 0
 ORIG. AH/DRW DATE: 5/20/88
 CHK'D. FJF DATE: 5/23

NINE MILE POINT UNIT 1
 MINIMUM TORUS WALL THICKNESS
 AREA NUMBER ONE:
 (WITHOUT 1984 DATA)



CONTINUED ON 24A

1
2
3
4
5



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

S22.4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. -STAT 01 REV. 0


SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS

ORIG. AA/DRW DATE: 5/23/88

INDEX: 3-N2.1-S22.4

CHK'D. FWF DATE: 5/23

NINE MILE POINT UNIT 1
MINIMUM TORUS WALL THICKNESS
AREA NUMBER TWO



1
2
3
4

1994




NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1 CALC. NO. 522-4-WW/198 REV. 0
 SUBJECT: TORUS WALL THINNING TRENDING ANALYSIS ORIG. AH/DRW DATE: 5/23/88
 INDEX: 3-N2.1-522-4 CHK'D. PH DATE: 5/23

NINE MILE POINT UNIT 1
 MINIMUM TORUS WALL THICKNESS
 AREA NUMBER THREE



1
2

Journal of the Board of Directors

3

4

5

6

7



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522.4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. -STAT ϕ 1 REV. 0


SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS


ORIG. AH / DRW DATE: 5/23/88

INDEX: 3-N2.1-522.4

CHK'D. FLF DATE: 5/23

NINE MILE POINT UNIT 1
MINIMUM TORUS WALL THICKNESS
AREA NUMBER FOUR :





NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

522.4-WW198

PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. -STAT #1 REV. 0


SUBJECT: TORUS WALL THINNING
TRENDING ANALYSIS


ORIG. AGT/DPW DATE: 5/23/88

INDEX: 3-N2.1-522.4

CHK'D. FHF DATE: 5/23

NINE MILE POINT UNIT 1
MINIMUM TORUS WALL THICKNESS
AREA NUMBER FIVE





NUCLEAR ENGINEERING & LICENCING

DISCIPLINE STRUCTURAL

PROJECT: <u>NINE MILE POINT NUC. STA.-UNIT I</u>	522-4-WW198
SUBJECT: <u>TORUS WALL THINNING</u> <u>TRENDING ANALYSIS</u>	CALC. NO. <u>-STAT 01</u> REV. <u>0</u>
INDEX: <u>3-N2.1-522-4</u>	ORIG. <u>Alt/DRW</u> DATE: <u>5/20/88</u>
	CHK'D. <u>FIVE</u> DATE: <u>5/23</u>

APPENDIX 'A'

1950年10月

第100号

第100号

第100号



TORUS DATA SHEET

Vessel NINE MILE POINT Calibration Block No. 121

Procedure No. ISE-QAI-48 Rev. 0 WITH SUPP Calib. Sheet No. # 13

Date 10-15-75

Examiner LINDEMAN ASNT Level II

Data Taker Muir ASNT Level II

Equipment Data: Instrument Model No. KRAUTKRAMER Shoe No. N/A

Instrument Serial No. 508305 Cable No. N/A

Transducer Size 1/2" Frequency N/A MHz


Transducer Serial No. KMS 4 Beam Angle 0° IIIV-2

EXAM AREA # 1

	1	2	3	4	5
A	.485	.495	.490	.500	.490
B	.485	.495	.490	.490	.495
C	.490	.495	.490	.490	.495
D	.490	.495	.490	.485	.490
E	.490	.480	.485	.490	.485
F	.490	.485	.490	.490	.490
G	.495	.495	.495	.500	.490

	1	2	3	4	5
A					
B					
C					
D					
E					
F					
G					

Torus



* ALL READINGS WERE TAKEN AT INTERSECTION

1

2

3

4

5

6

7

8

9

10

11

12

13

14



TORUS DATASHEET

Vessel NINE MILE POINT Calibration Block No. # 121

Procedure No. ISE-RAI-43 Rev. 0 with Supp. Calib. Sheet No. # 13

Date 10-15-75

Examiner LINDEMAN ASNT Level: II

Data Taker MURTZ ASNT Level II

Equipment Data: Instrument Model No. KZUTERAMEK Shoe No. N/A

Instrument Serial No. 508305 Cable No. N/A

Transducer Size 1/2" Frequency N/A MHz


Transducer Serial No. KMS-4 Beam Angle 0° III-2

EXAM AREA # 2

	1	2	3	4	5
	.475	.480	.475	.475	.480
	.480	.480	.475	.475	.475
	.475	.475	.475	.475	.480
	.475	.475	.480	.475	.475
	.475	.475	.475	.475	.475
	.475	.480	.480	.475	.475
	.475	.475	.480	.475	.475

	1	2	3	4	5
A					
B					
C					
D					
E					
F					
G					

2us



* ALL READINGS WERE TAKEN AT INTERSECTION

10
11
12
13



TORUS DATA SHEET

Vessel NINE MILE POINT Calibration Block No. # 121

Procedure No. ISE:QAI-48 Rev. 0 WITH SUPP. Calib. Sheet No. # 13

Date 10-13-75

Examiner LINDEMAN ASNT Level: II

Data Taker MUIZ ASNT Level: II

Equipment Data: Instrument Model No. KRAUTZRAMER Shoe No. N/A

Instrument Serial No. 508 305 Cable No. N/A

Transducer Size 1/2" Frequency N/A MHz


Transducer Serial No. KMS-4 Beam Angle 0° IIW-2

EXAM AREA # 3

	1	2	3	4	5
A	.485	.490	.490	.490	.495
B	.490	.490	.490	.490	.490
C	.490	.490	.490	.490	.490
D	.495	.490	.490	.490	.490
E	.490	.490	.490	.490	.490
F	.490	.490	.490	.490	.490
G	.490	.490	.495	.490	.490

	1	2	3	4	5
A					
B					
C					
D					
E					
F					
G					

TORUS



* ALL READINGS WERE TAKEN AT INTERSECTION

TORUS DATA SHEET

Vessel NINE MILE POINT Calibration Block No. # 121

Procedure No. ISE:QAI-48 Rev. 0 with Supp. Calib. Sheet No. # 13

Date 10-15-75

Examiner LINDERMAN ASNT Level: II

Data Taker MUIR ASNT Level: II

Equipment Data: Instrument Model No. KRAUT KRAMER Shoe No. N/A

Instrument Serial No. 508 305 Cable No. N/A


Transducer Size 1/2" Frequency N/A MHz

Transducer Serial No. KMS-4 Beam Angle 0° IIV-2

EXAM AREA # 4

	1	2	3	4	5
A	.490	.485	.495	.495	.495
B	.490	.490	.495	.495	.495
C	.485	.490	.495	.495	.490
D	.490	.495	.495	.495	.490
E	.490	.495	.495	.495	.495
F	.485	.495	.495	.495	.490
G	.485	.495	.490	.490	.490

	1	2	3	4	5
A					
B					
C					
D					
E					
F					
G					



* ALL READINGS WERE TAKEN AT INTERSECTION

100-100000

100-100000

100-100000



TORUS DATA SHEET

Vessel NINE MILE POINT Calibration Block No. # 121

Procedure No. KE-QAI-48 Rev. 0 WITH: SUP Calib. Sheet No. # 13

Date 10-15-75

Examiner LINDSMAN ASNT Level: II

Data Taker MUIR ASNT Level II

Equipment Data: Instrument Model No. KRAUTKRAMER Shoe No. N/A

Instrument Serial No. 508305 Cable No. N/A

Transducer Size 1/2" Frequency N/A MHz


Transducer Serial No. KMS-4 Beam Angle 0 III-V-2

EXAM AREA #5

	1	2	3	4	5
A	.485	.490	.490	.485	.435
B	.485	.485	.485	.485	.485
C	.490	.490	.485	.435	.435
D	.485	.435	.435	.435	.485
E	.490	.485	.485	.435	.430
F	.490	.485	.490	.485	.470
G	.490	.490	.485	.485	.470

	1	2	3	4	5
A					
B					
C					
D					
E					
F					
G					

Torus




* ALL READINGS WERE TAKEN AT INTERSECTIONS

1. 1980-1981

2. 1982-1983

3. 1984-1985



472890
 ME



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT #1
 PROCEDURE NO. IST-02 NISCU
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, B-5
 CAL. BLOCK NO. PIF TORUS 1012 2612
 EXAM METHOD U.T.
 GRID AREA EXAMINED AREA #1

	1	2	3	4	5	6
A	470"	470"	465"	470"	470"	
B	470"	470"	475"	470"	470"	
C	468"	470"	468"	470"	470"	
D	470"	470"	470"	470"	470"	
E	470"	478"	470"	475"	460"	
F	470"	465"	465"	470"	470"	

EXAMINER(S) SIGNATURE(S) REQD.

Rodney B. Bomer SNT-TC-1A
LEVEL II

Arthur Puzsik SNT-TC-1A
LEVEL II

DATE 4-15-77 TIME 1230

REVIEWED _____

12
14
16
18
20

22
24

26
28
30
32

34

36



ULTRASONIC
THICKNESS
MEASUREMENT

33

SITE LOCATION NINE MILE POINT UNIT #1
 PROCEDURE NO. ISI-02 Nisco
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, B-5
 CAL. BLOCK NO. PIF Torus 10/2 26/2
 EXAM METHOD UT
 GRID AREA EXAMINED AREA #2

	1	2	3	4	5	6
A	.470"	.465"	.470"	.470"	.470"	
B	.468"	.468"	.470"	.470"	.470"	
C	.470"	.465"	.465"	.465"	.470"	
D	.470"	.470"	.470"	.470"	.470"	
E	.460"	.470"	.470"	.470"	.470"	
F	.470"	.470"	.470"	.470"	.470"	

EXAMINER(S) SIGNATURE(S) REQD.

Rodney B. Barne SNT-TC-1A
LEVEL II
Arthur Piszniak SNT-TC-1A
LEVEL I

DATE 4.15.77 TIME 1230

REVIEWED _____

11
12
13
14
15

16

17
18
19
20



ULTRASONIC
THICKNESS
MEASUREMENT

34

SITE LOCATION NINE MILE POINT UNIT
 PROCEDURE NO. ISI-02 NISCO
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, B-5
 CAL. BLOCK NO. PIE TORUS 10/2 20/2
 EXAM METHOD H.T.
 GRID AREA EXAMINED AREA #3

	1	2	3	4	5	6
A	.470"	.470"	.470"	.470"		
B	.470"	.470"	.470"	.470"		
C	.470"	.470"	.470"	.470"		
D	.470"	.470"	.470"	.470"		
E	.470"	.470"	.470"	.470"		
F	.470"	.470"	.470"	.470"		

EXAMINER(S) SIGNATURE(S) REQD.

Robinson, S. Ramo SNT-TC-1A
LEVEL II

Nathan Pinski SNT-TC-1A
LEVEL I

DATE 4-15-77 TIME 12:30

REVIEWED _____

1
2
3
4
5

6
7
8



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1

PROCEDURE NO. ISL-02 NUSCO

AREA OF EXAM. TORUS WALL

DRAWING NO. B-4, B-5

CAL. BLOCK NO. PIF TORUS 10/2 26/2

EXAM METHOD UT

GRID AREA EXAMINED AREA #4

	1	2	3	4	5	6
A	470"	470"	470"	470"		
B	470"	470"	470"	470"		
C	470"	470"	470"	470"		
D	470"	470"	470"	470"		
E	470"	470"	470"	470"		
F	470"	470"	470"	470"		

EXAMINER(S) SIGNATURE(S) REQD.

Rodney S Barner SNT-TC-1A
LEVEL II

Arthur Piszak SNT-TC-1A
LEVEL I

DATE 4-15-77 TIME 12:30

REVIEWED _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

SECRET



ULTRASONIC
THICKNESS
MEASUREMENT

36

SITE LOCATION NINE MILE POINT UNIT #1
 PROCEDURE NO. E.I. - 02 NISCO
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, B-5
 CAL. BLOCK NO. PIF TORUS 10/2 20/2
 EXAM METHOD UT

GRID AREA EXAMINED AREA #5

	1	2	3	4	5	6
A	470"	470"	470"	470"	470"	
B	470"	470"	470"	470"	470"	
C	470"	470"	470"	470"	470"	
D	470"	470"	470"	470"	470"	
E	470"	470"	470"	470"	470"	
F	470"	470"	470"	470"	470"	

EXAMINER(S) SIGNATURE(S) REQD.

Rodney S. Bames SNT-TC-1A
LEVEL II


Arthur Pinnak SNT-TC-1A
LEVEL I

DATE 4-15-77 TIME 1:30

REVIEWED _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100





NOTES:

- 1 SCALE 1/16" = 1' 00"
- 2 ● = 6" CORE SPERM BARRIS
- = 12" CORE SPERM

JANUARY FEBRUARY MARCH APRIL MAY JUNE JULY AUGUST SEPTEMBER OCTOBER NOVEMBER DECEMBER



10
11
12
13
14



15
16
17
18
19



20
21

2434-1

ULTRASONIC
THICKNESS
MEASUREMENT

F.A. HAWKSLEY
INFO
ONLY

38

SITE LOCATION NINE MILE POINT UNIT 1

PROCEDURE NO. 90A2434

AREA OF EXAM. TOWNS WALL

DRAWING NO. B-4, B-5

CAL. BLOCK NO. PIF -1--5 NMPG

EXAM METHOD U-T.

GRID AREA EXAMINED AREA #1

	1	2	3	4	5	6
A	-491	-491	-487	-482	-488	-484
B	-482	-486	-480	-482	-479	-485
C	-485	-483	-484	-487	-479	-485
D	-480	-487	-481	-486	-482	-483
E	-487	-482	-460	-485	-488	-482
F	-484	-485	-488	-479	-475	-483

EXAMINER(S) SIGNATURE(S) REQD.

Rodney D. Bomer

SNT-TC-1A
LEVEL II

Keith A. Dew

SNT-TC-1A
LEVEL I

DATE 4-9-79 TIME 1715

REVIEWED _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. 60A2434
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, R-5
 CAL. BLOCK NO. PIF -4-5 NMPC
 EXAM METHOD U-T.
 GRID AREA EXAMINED AREA #2

	1	2	3	4	5	6
A	-483	-476	-482	-483	-485	-483
B	-481	-488	-483	-486	-481	-486
C	-484	-483	-478	-483	-480	-484
D	-480	-482	-484	-482	-477	-490
E	-487	-493	-482	-481	-485	-485
F	-475	-484	-492	-480	-480	-476

EXAMINER(S) SIGNATURE(S) REQD.

Rodney J. Bomer

SNT-TC-1A
LEVEL II

Keith S. Dew

SNT-TC-1A
LEVEL I

DATE 4-9-79 TIME 1715

REVIEWED _____

知 道 是 什 么

知 道 是 什 么



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. 60A2434
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4; B-5
 CAL. BLOCK NO. PIF -1- -5 NMPL
 EXAM METHOD UT
 GRID AREA EXAMINED AREA #3

	1	2	3	4	5	6
A	-495	-495	-495	-480	-486	-485
B	-485	-489	-482	-484	-500	-494
C	-492	-487	-483	-483	-488	-490
D	-495	-487	-498	-490	-486	-493
E	-487	-480	-483	-487	-480	-489
F	-490	-487	-480	-486	-483	-484

EXAMINER(S) SIGNATURE(S) REQD.

Rodney S. Barnes

SNT-TC-1A
LEVEL II

Kathy A. Dew

SNT-TC-1A
LEVEL I

DATE 4-9-79 TIME 1715

REVIEWED _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102

103

104

105

106

107

108

109

110

111



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. 80A2434
 AREA OF EXAM. TOBUS WALL
 DRAWING NO. A-4; A-5
 CAL. BLOCK NO. PIF -1-5 NMPC
 EXAM METHOD U-T-

GRID AREA EXAMINED AREA #4

	1	2	3	4	5	6
A	-491	-483	-495	-498	-487	-490
B	-489	-490	-496	-490	-492	-488
C	-490	-491	-485	-489	-482	-485
D	-487	-478	-480	-489	-486	-486
E	-488	-487	-484	-488	-487	-480
F	-486	-485	-487	-483	-488	-480

EXAMINER(S) SIGNATURE(S) REQD.

Rodney J. Boner

SNT-TC-1A
LEVEL II

Keith A. Dew

SNT-TC-1A
LEVEL I

DATE 4-9-79 TIME 1715

REVIEWED _____

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. 60A2434
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B-4, B-5
 CAL. BLOCK NO. PIF -1--5 NMPC
 EXAM METHOD U-T

GRID AREA EXAMINED AREA #5

	1	2	3	4	5	6
A	-485	-487	-483	-483	-497	-498
B	-494	-488	-493	-490	-480	-487
C	-485	-489	-490	-486	-489	-488
D	-490	-489	-488	-482	-485	-489
E	-493	-489	-483	-492	-490	-490
F	-486	-491	-485	-485	-488	-485

EXAMINER(S) SIGNATURE(S) REQD.

Rodney D. Barnes SNT-TC-1A
LEVEL II

Keith A. Dew SNT-TC-1A
LEVEL I

DATE 4-9-79 TIME 1715

REVIEWED _____

ULTRASONIC
THICKNESS
MEASUREMENT

43

SITE LOCATION NINE MILE POINT UNIT 1
PROCEDURE NO. 80A 2434
AREA OF EXAM. TORUS WALL
DRAWING NO. B4, B5
CAL. BLOCK NO. PIF-1-5 NmPC
EXAM METHOD UT

GRID AREA EXAMINED AREA 1

	1	2	3	4	5	6
A	481	480	482	481	470	471
B	479	481	488	484	467	471
C	483	487	486	479	474	467
D	487	489	479	480	474	476
E	483	482	486	482	491	468
F	488	483	486	482	472	467

EXAMINER(S) SIGNATURE(S) REQD..

Arthur Pennawen SNT-TC-1A
LEVEL II

Edmund R. Downer SNT-TC-1A
LEVEL I

DATE 3-19-81 TIME 1800

REVIEWED _____

ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1

PROCEDURE NO. 80A 2434

AREA OF EXAM. TOBUS WALL

DRAWING NO. B4, B5

CAL. BLOCK NO. PIF-1-5 NMP

EXAM METHOD UT

GRID AREA EXAMINED Area 2

	1	2	3	4	5	6
A	466	472	468	468	470	485
B	469	470	468	470	469	480
C	473	468	473	471	469	480
D	471	474	478	469	475	480
E	471	474	470	475	475	482
F	473	476	478	475	476	481

EXAMINER(S) SIGNATURE(S) REQD..

Arthur Pennawew SNT-TC-1A
LEVEL II

Edward R. Downum SNT-TC-1A
LEVEL I

DATE 3-19-81 TIME 1700

REVIEWED _____

104

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119

120

ULTRASONIC
THICKNESS
MEASUREMENT

45

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. BOA 2434
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B4, B5
 CAL. BLOCK NO. P1F-1-5 Nm Pc
 EXAM METHOD UT
 GRID AREA EXAMINED Area 3

	1	2	3	4	5	6
A	479	481	478	483	481	482
B	478	477	479	480	487	478
C	481	482	479	482	485	488
D	484	481	483	483	482	478
E	485	484	485	484	480	483
F	483	490	489	482	478	478

EXAMINER(S) SIGNATURE(S) REQD..

Arthur Pennawel SNT-TC-1A
 LEVEL II

Edward R. D... .. SNT-TC-1A
 LEVEL I

DATE 3-19-81 TIME 1715

REVIEWED _____

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24



ULTRASONIC
THICKNESS
MEASUREMENT

SITE LOCATION NINE MILE POINT UNIT 1

PROCEDURE NO. BOA 2434

AREA OF EXAM. TORUS WALL

DRAWING NO. B4, B5

CAL. BLOCK NO. PIF-1-5 Nm Pc

EXAM METHOD UT

GRID AREA EXAMINED Area 4

	1	2	3	4	5	6
A	482	483	487	483	489	489
B	483	481	485	486	482	488
C	479	480	481	475	482	477
D	479	481	479	480	479	483
E	480	483	473	477	477	481
F	475	483	475	475	479	479

EXAMINER(S) SIGNATURE(S) REQD..

Arthur Pennanen SNT-TC-1A
LEVEL II

Edward R. Danner SNT-TC-1A
LEVEL I

DATE 3-19-81 TIME 1730

REVIEWED _____

101

102

103

104

105

106

107

108

109

110



ULTRASONIC
THICKNESS
MEASUREMENT

47

SITE LOCATION NINE MILE POINT UNIT 1
 PROCEDURE NO. BOA 2434
 AREA OF EXAM. TORUS WALL
 DRAWING NO. B4, B5
 CAL. BLOCK NO. PIF-1-5 NMPC
 EXAM METHOD UT

GRID AREA EXAMINED AREA 5

	1	2	3	4	5	6
A	490	488	486	487	488	483
B	485	486	483	483	486	490
C	486	484	488	482	483	479
D	485	483	486	482	487	480
E	484	482	483	482	470	479
F	485	483	483	484	472	479

EXAMINER(S) SIGNATURE(S) REQD..

Arthur Pennanen ARTHUR PENNANEN SNT-TC-1A
LEVEL II

Edmund R. Aronson SNT-TC-1A
LEVEL I

DATE 3-19-81 TIME 1745

REVIEWED _____

Vertical text on the left side of the page, possibly a page number or header.



Information Only

Plant/Unit NMP #1
 Comp/System ...
 ISO N/A Loop N/A

CALIBRATION DATA SHEET

Page 1 of 2
 Data Sheet No. 2433-8
 Procedure No. 9022473
 Subject: STEAM GENERATOR
 Rev/Change No. 3
 Calibration
 Block No. 1120-C-9003613
 Fabrication No. 17-700411
 Surface 00
 Block Temp TEMP 123/129
 Comp. Temp TEMP 123/71
 Thickness STEP WEDGE
 CRT Calibrated in 10 DIVISIONS
OF METAL PATH
 Each Maj. Screen Div = 0.10"

INSTRUMENT SETTINGS

Mfg/Model No.: KRUSL 32
 Serial No.: 211954
 Sweep Length: 9.0
 Sweep Delay: 7.0
 Pulse Length/Damping: N/A
 Freq.: 5.0 Rep. Rate: N/A
 Filter: N/A Video: N/A Jack: TRK
 DEC/Gate Switch: OFF Range: 5
 Mode Select: DUAL Quiacr: OFF
 Gain (coarse): N/A (fine): N/A
 Scan Sensitivity: ...


SEARCH UNIT

Scan Angle: 0° Mode: LUMI
 Fixturing (if any): NONE
 Style or Type No.: GAMMA
 Size & Shape: 3/8" DIA. ALU
 Frequency: 5.0 MHz
 Serial No./Brand: KIS 10093
 Measured Angle: N/A
 Cable Type & Length: ...
 Couplant Brand: ULTRACAL II
 Couplant Batch: 8439

INSTR. LINEARITY CAL.

	Amplitude			
	High	Low	High	Low
1	100	52	60	30
2	90	46	50	26
3	80	40	40	20
4	70	36	30	15

20 10



SCAN AREA

0° WRV	N/A
0° Max'l	X
= To Weld	N/A
⊥ To Weld	N/A
Calibration	
Axial	N/A
Circ	N/A

AMPL. CONTROL LINEARITY

Initial	dB	Result
80	-6	39
80	-12	20
40	+6	91
20	+12	82

EXAMINATION WELD/AREA	Recordable Indications			COMMENTS/REASON FOR INCOMPLETED SCAN (S)									
	Yes	No	Geom										
See Screen	N/A	N/A	N/A	THRU AREA # 2 AND 3									
<table border="1" style="width: 100%;"> <thead> <tr> <th>NIAGARA NO</th> <th>DATE</th> <th>OPERATION</th> </tr> </thead> <tbody> <tr> <td>N/A</td> <td>REVISION</td> <td>N/A</td> </tr> <tr> <td>YES</td> <td>Chittam</td> <td>4/15/84</td> </tr> </tbody> </table>					NIAGARA NO	DATE	OPERATION	N/A	REVISION	N/A	YES	Chittam	4/15/84
NIAGARA NO	DATE	OPERATION											
N/A	REVISION	N/A											
YES	Chittam	4/15/84											

CALIBRATION CHECKS TIME

Initial Cal.	1020
Intermediate	
Intermediate	
Intermediate	
Final Cal.	1140

ADDITIONAL SHEETS Yes No

Office Use Only - Leave Blank
 ANII REVIEW

SIGNATURE [Signature]
 DATE: 6/15/84

EXAMINERS 1 [Signature] Date 5-23-84 Level II
 2 [Signature] Date 5-23-84 Level I
 REVIEWERS 1 [Signature] Date 5-23-84
 2 _____ Date _____
 3 _____ Date _____



SECRET

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

SECRET

SECRET



19-0910 (R 2/70) 101 10 Squares to the inch • MADE IN U.S.A.

PAGE 2 of 2
DENTAL SURCH 2433-7

	2	3	4	5	6
A	48	49	50	49	47
B	49	50	51	49	47
C	50	51	52	49	47
D	51	49	49	49	48
E	50	49	49	49	47
F	51	49	50	50	49
G	2	3	4	5	6

UTERINE CERVIX - CLAM
ON TORUS CERVIX
AREA F 1, 2, AND 3

A	51	50	50	50	50
B	52	50	50	50	50
C	50	50	50	50	50
D	50	50	50	50	50
E	50	50	50	50	50
F	50	50	50	50	50
G	2	3	4	5	6

ANIL REVIEW
SIGNATURE *[Signature]*
DATE 5/10/84

A	50	50	50	50	50
B	50	50	50	50	50
C	50	50	50	50	50
D	50	50	50	50	50
E	50	50	50	50	50
F	50	50	50	50	50
G	2	3	4	5	6

DATE 5-23-84

A	50	49	50	50	50
B	50	50	50	50	49
C	50	50	50	50	49
D	50	50	50	50	49
E	50	50	50	50	49
F	50	50	50	50	49
G	2	3	4	5	6

DATE 5-23-84

A	50	50	50	50	49
B	50	50	50	50	49
C	50	50	50	50	49
D	50	50	50	50	49
E	50	50	50	50	49
F	50	50	50	50	49
G	2	3	4	5	6

FOR INFORMATION ONLY

INVESTIGATION NO. 101-10
FVA REVIEW REQUESTED YES
SIGNATURE & DATE *[Signature]* 5/10/84

NO 19 0910 (R 2/70) 101 10 Squares to the inch • MADE IN U.S.A.

VERNON McMILLAN, INC. ELIZABETH, N.J. 07208

48

SECRET

SECRET

SECRET

SECRET

SECRET

Information ONLY

Plant/Unit NMD-1
 Comp/System Torus
 ISO #/A Loop #/A


CALIBRATION DATA SHEET

Page 1 of 2
 Data Sheet No. 2432-17
 Procedure No. 80A2433
 Subject: Steam Erosion Disinfection
 Rev/Change No. 3
 Calibration
 Block No. 1020 CS 80C363
 Fabrication No. 17-760411
 Surface 00
 Block Temp m23 69 °F
 Comp. Temp m23 71 °F
 Thickness Step Wedge
 CRT Calibrated in 1" of
metal path
 Each Maj. Screen Div = .1"

INSTRUMENT SETTINGS	
Fig/Model No.:	KAI 45L 32
Serial No.:	21964
Sweep Length:	1.77
Sweep Delay:	7.76
Pulse Length/Damping:	F. x 20
Freq.:	5 Rep. Rate: N/A
Filter:	N/A Video: N/A Jack: T/E
DEC/Gate Switch:	Range: S
Mode Select:	Dual Range: min
Gain (coarse):	N/A (fine): N/A
Scan Sensitivity:	22

SEARCH UNIT	
Scan Angle:	0 Mode: LCR
Fixturing (if any):	N/A
Style or Type No.:	Gamma D Sp
Size & Shape:	3/8" Round Dual
Frequency:	5 mHz
Serial No/Brand:	ARTECH KR10090
Measured Angle:	N/A
Cable Type & Length:	2 1/2' 115' cord
Couplant Brand:	Ultracool II
Couplant Batch:	3439

INSTR. LINEARITY CAL.					
	Amplitude				
	High	Low	High	Low	
1.	100	51	5	60	30
2	90	45	6	50	25
3	80	40	7	40	19
4	70	35	8	30	15



SCAN AREA	
0° WRV	N/A
0° Mar'1	X
= To Weld	N/A
⊥ To Weld	N/A
Calibration	
Axial	N/A
Circ	N/A

AMPL. CONTROL LINEARITY		
Initial	dB	Result
80	-6	40
80	-12	19
40	+6	82
20	+12	84

EXAMINATION WELD/AREA	Recordable Indications			COMMENTS/REASON FOR INCOMPLETED SCAN (S)
	Yes	No	Geom	
See SEARCH	N/A	N/A	N/A	TORUS AREA - N/A
FOR INFORMATION				
				NIAGARA MOBILE SERVICE CORPORATION N/A YES NO Signature & Date: 6/15/84

CALIBRATION CHECKS TIME	
Initial Cal.	1015
Intermediate	—
Intermediate	—
Intermediate	—
Final Cal.	1145

ADDITIONAL SHEETS Yes No

EXAMINERS 1 Alan L. (Hand) Date 5/23/84 Level III
 2 Paul Smith Date 5/23/84 Level I
 REVIEWERS 1 P. L. Kock 4/12 Date 5-23-84
 2 _____ Date _____
 3 _____ Date _____

Office Use Only- Leave Blank
 ANII REVIEW

SIGNATURE [Signature]
 DATE: 6/15/84



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100



100

DATE 5-23-84
DATA SHEET 2933

4

1 2 3 4 5 6

A	.49"	.48"	.49"	.49"	.48"	.49"
B	.49"	.49"	.49"	.49"	.49"	.48"
C	.49"	.49"	.48"	.48"	.48"	.48"
D	.48"	.48"	.48"	.49"	.48"	.48"
E	.48"	.48"	.48"	.48"	.48"	.48"
F	.48"	.48"	.48"	.48"	.49"	.48"

STEAM EROSION EXAM OF
TORUS WALL
AREAS 4 + 5

5

1 2 3 4 5 6

A	.51"	.51"	.50"	.51"	.51"	.50"
B	.49"	.52"	.51"	.50"	.50"	.49"
C	.50"	.50"	.50"	.51"	.51"	.50"
D	.50"	.49"	.49"	.49"	.49"	.48"
E	.49"	.51"	.50"	.50"	.50"	.51"
F	.49"	.51"	.51"	.50"	.49"	.49"

Allen C. David 4 FT

F. L. Keck 4 FT 5-23-84

DO NOT WRITE IN THESE SPACES
ENCLOSURE

NO. 19 0910M 2176 10-10 Squares 1/4 in. x 1/4 in. Made in U.S.A.

VERHOEFFMILLER INC. (E244) BY RJG 07208

Vertical text on the left side of the page.

Vertical text on the left side of the page.

Vertical text on the left side of the page.

Vertical text on the left side of the page.

Vertical text on the left side of the page.

Vertical text on the left side of the page.



PLANT/UNIT NMP1
COMP/SYSTEM TORUS
NA LOOP NA

1986 OUTAGE
CALIBRATION DATA SHEET
YEAR 10

PAGE 1 OF 22
DATA SHEET NO. 2434-1
PROCEDURE NO. 80A2434
SUBJECT UT THICKNESS
REV./CHANGE NO. 3/NA

INSTRUMENT SETTING

MFG/MODEL NO.: KBI-USK-7
 SERIAL NO.: 27276-807
 SWEEP LENGTH: 8.34
 SWEEP DELAY: 7.60
 PULSE LENGTH/DAMPING: BEST
 FREQ.: F350 REP RATE: F350
 FILTER: NA VIDEO: NA
 JACK: R DEC/GATE: OFF
 RANGE: .5 MODE SELECT: SINGLE
 REJECT: MIN
 GAIN(COARSE): 0 (FINE): 14
 SCAN SENSITIVITY: NAENTASNO
80% BACK REFLECTION

SEARCH UNIT

SCAN ANGLE: 0° MODE: LONG
 FIXTURING (if any): NA
 STYLE or TYPE NO.: GAMMA
 SIZE and SHAPE: .5" ROUND
 FREQUENCY: 2.25 MHz
 SERIAL NO/BRAND: C26146/KEROTECH
 MEASURED ANGLE: NA
 CABLE TYPE & LENGTH: DHC6BNC 1x6'
 COUPLANT BRAND: ULTRAGEL II
 COUPLANT BATCH: 8557

CALIBRATION BLOCK


BLOCK NO.: 80C3613
 FAB. NO.: NA
 SURFACE: OD
 BLOCK TEMP.: A85-11 68° F
 COMPONENT TEMP.: A85-11 62° F
 BLK. THICKNESS: .105" to 1.006"
 COMPONENT THICKNESS: .48"

CRT CALIBRATED IN 2.0"
OF DEPTH
EACH MAJOR SCREEN DIV. = .20"

INSTRUMENT LINEARITY CAL.

AMPLITUDE

	HIGH	LOW	HIGH	LOW
1	100	50	5	60 30
2	90	45	6	50 25
	80	40	7	40 20
	70	35	8	30 15
			9	20 8



SCAN AREA

0 WRY	<u>NA</u>
0 Mat 7	<u>NA</u>
II to WELD	<u>NA</u>
I to WELD	<u>NA</u>
CALIBRATION	
AXIAL	<u>NA</u>
CIRC	<u>NA</u>

AMPLITUDE CONTROL LINEARITY

INITIAL	dB	RESULT
80	-6	42
80	-12	21
40	+6	78
20	+12	78

EXAMINATION YELD AREA	RECORDABLE INDICATIONS		COMMENTS/REASON FOR INCOMPLETED SCANS						
	YES	NO GEOM							
TORUS	<u>NA</u>	<u>NA</u>	THICKNESS MEASUREMENTS SEE PG 22 OF 22 FOR SKETCH						
			<table border="1"> <tr><td>QUALITY CONTROL</td><td><u>NA</u></td></tr> <tr><td>REVIEW ACCEPTED</td><td><u>NA</u></td></tr> <tr><td>SIGNATURE & DATE</td><td><u>5/2/86</u></td></tr> </table>	QUALITY CONTROL	<u>NA</u>	REVIEW ACCEPTED	<u>NA</u>	SIGNATURE & DATE	<u>5/2/86</u>
QUALITY CONTROL	<u>NA</u>								
REVIEW ACCEPTED	<u>NA</u>								
SIGNATURE & DATE	<u>5/2/86</u>								

CALIBRATION CHECKS

CHECKS	TIME
INITIAL CALIBRATION	<u>0948</u>
INTERMEDIATE	<u>NA</u>
INTERMEDIATE	<u>NA</u>
INTERMEDIATE	<u>NA</u>
FINAL CALIBRATION	<u>1300</u>

ADDITIONAL SHEETS

CONTINUATION	<u>NA</u>	BEAM PLOT	<u>NA</u>
SUPPLEMENTS	<u>X</u>	NONE	<u>NA</u>

YELDS ACCEPTABLE YES NA NO NA

EXAMINER 1: [Signature] LEVEL II DATE 4-16-86
 EXAMINER 2: [Signature] LEVEL II DATE 4-16-86
 REVIEWER 1: [Signature] LEVEL II DATE 4-30-86
 REVIEWER 2: _____ LEVEL _____ DATE _____
 REVIEWER 3: _____ LEVEL _____ DATE _____

DISPOSITION
 REQUIRED YES NA NO NA
 ANII REVIEW
 SIGNATURE [Signature]

100

100

100

100

100

100

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 2 OF 22

SITE LOCATION NMPI
 PROCEDURE NO. 80A2434
 AREA OF EXAM See Attached Sketch
 DRAWING NO. N/A
 CAL. BLOCK NO. STEPWEDGE #800.3613
 EXAM METHOD UT
 GRID AREA EXAMINED #1

NANTAKA MOHAWK POWER CORPORATION

<input checked="" type="checkbox"/>	QUALITY CONTROL	<input type="checkbox"/>
YES	REVIEW ACCEPTED	NO
<i>Chambers 5/2/86</i> SIGNATURE & DATE UT-III		

	1	2	3	4	5	6
A	MAX= .58" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
B	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
C	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
D	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
E	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
F	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"

EXAMINER *[Signature]* LEVEL II DATE 4-16-86
 EXAMINER *[Signature]* LEVEL II DATE 4-16-86
 REVIEWER *[Signature]* LEVEL II DATE 4-30-86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE *[Signature]*
DATE _____

[Signature]

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 3 OF 22

SITE LOCATION NMPI
 PROCEDURE NO. 80A2434
 AREA OF EXAM SEE ATTACHED SKETCH
 DRAWING NO. N/A
 CAL. BLOCK NO. STEPWEDGE #80C3613
 EXAM METHOD UT
 GRID AREA EXAMINED #1

NIAGARA MOHAWK POWER CORPORATION
 YES NO
 QUALITY CONTROL REVIEW ACCEPTED
Chas. Mass 5/2/86
 SIGNATURE & DATE UT-III

	7	8	9	10	11	12
A	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
B	MAX= .48" MIN= .46"	MAX= .48" MIN= .48"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .48"
C	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
D	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .44"	MAX= .48" MIN= .44"	MAX= .48" MIN= .44"	MAX= .48" MIN= .44"
E	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
F	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"

EXAMINER *[Signature]* LEVEL II DATE 4-16-86
 EXAMINER *[Signature]* LEVEL III DATE 4-16-86
 REVIEWER *Edmund R. Donovan* LEVEL II DATE 4-30-86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
 SIGNATURE *[Signature]*

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 4 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP WEDGE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #1

INDIANA MICHIGAN POWER CORPORATION
 QUALITY CONTROL REVIEW ACCEPTED
YES NO
[Signature] 5/2/86
SIGNATURE & DATE UT-II

	1	2	3	4	5	6
G	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
H	MAX= .48" MIN= .44"	MAX= .48" MIN= .44"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
I	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .46" MIN= .46"
J	MAX= .46" MIN= .44"	MAX= .46" MIN= .44"	MAX= .46" MIN= .44"	MAX= .46" MIN= .44"	MAX= .46" MIN= .44"	MAX= .46" MIN= .44"
K	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
L	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

AMH REVIEW
SIGNATURE [Signature]
DATE 5-2-87

[Handwritten mark]

100

100

100

100



**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 5 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEPUP EDGE #8003613
EXAM METHOD UT
GRID AREA EXAMINED #1

INDIANA EDWARDS PROJECT CORPORATION
 QUALITY CONTROL
YES REVIEW ACCEPTED N/A
NO
Cliff M... 5/2/86
SIGNATURE & DATE UT-III

	7	8	9	10	11	12
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.46" MIN=.44"	MAX=.46" MIN=.44"	MAX=.46" MIN=.44"	MAX=.46" MIN=.44"	MAX=.46" MIN=.44"	MAX=.46" MIN=.44"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANTI REVIEW
SIGNATURE [Signature]
DATE _____

(in)

Vertical text on the left side of the page, possibly a page number or header.

Horizontal text in the center of the page, possibly a title or subtitle.



**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 6 OF 22

SITE LOCATION UMP1
 PROCEDURE NO. 80A2434
 AREA OF EXAM SEE ATTACHED SKETCH
 DRAWING NO. N/A
 CAL. BLOCK NO. STEPWEDGE # 80C3613
 EXAM METHOD UT
 GRID AREA EXAMINED #2

QUALITY CONTROL YES NO
 REVIEW ACCEPTED YES NO
Cliff Mass 5/2/86
 SIGNATURE & DATE UT-III

	1	2	3	4	5	6
A	MAX= .48" MIN= .46"	MAX= .46" MIN= .46"	MAX= .48" MIN= .48"	MAX= .46" MIN= .46"	MAX= .47" MIN= .47"	MAX= .46" MIN= .46"
B	MAX= .46" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"	MAX= .48" MIN= .46"
C	MAX= .48" MIN= .46"	MAX= .47" MIN= .46"	MAX= .48" MIN= .46"	MAX= .47" MIN= .46"	MAX= .48" MIN= .46"	MAX= .47" MIN= .46"
D	MAX= .48" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"
E	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"
F	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"	MAX= .47" MIN= .46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
 EXAMINER [Signature] LEVEL II DATE 4-16-86
 REVIEWER [Signature] LEVEL II DATE 4-30-86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
 SIGNATURE [Signature]

SECRET

CONFIDENTIAL

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 2 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEPWEDGE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #2

NIA SAKA BAHAWA POWER CORPORATION
 YES
 NO
QUALITY CONTROL REVIEW ACCEPTED
Cliff M... 5/2/86
SIGNATURE & DATE UT

	7	8	9	10	11	12
A	MAX=.46" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
B	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
C	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
D	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
E	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
F	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

1992-1993

1992-1993

1992-1993

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 8 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM See Attached Sketch
DRAWING NO. 4/A
CAL. BLOCK NO. STEPWEDGE #8003613
EXAM METHOD UT
GRID AREA EXAMINED #2

NIAGARA MOHAWK POWER CORPORATION

YES **QUALITY CONTROL REVIEW ACCEPTED** N/A I.O.

Champs 5/2/86

SIGNATURE & DATE UT-III

	1	2	3	4	5	6
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86

EXAMINER [Signature] LEVEL II DATE 4-16-86

REVIEWER [Signature] LEVEL II DATE 4-30-86

REVIEWER _____ LEVEL _____ DATE _____

REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 1 OF 22

SITE LOCATION NMPI
 PROCEDURE NO. 80A2434
 AREA OF EXAM SEE ATTACHED SKETCH
 DRAWING NO. N/A
 CAL. BLOCK NO. STEPPED WEDGE #80C3613
 EXAM METHOD UT
 GRID AREA EXAMINED #2

QUALITY CONTROL REVIEW ACCEPTED


YES NO

SIGNATURE & DATE UT-III

	7	8	9	10	11	12
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4.16.86
 EXAMINER [Signature] LEVEL II DATE 4.16.86
 REVIEWER [Signature] LEVEL II DATE 4.30.86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]



**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 10 OF 22


SITE LOCATION NMP1
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP 1 & 2 OF #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #3

INDIANIA MECHANICAL SCHOOL CERTIFICATION
 QUALITY CONTROL REVIEW ACCEPTED
YES NO
[Signature] 5/2/86
SIGNATURE & DATE UT-III

	1	2	3	4	5	6
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.48"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
VIEWER [Signature] LEVEL I DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 11 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM See Attached Sketch
DRAWING NO. N/A
CAL. BLOCK NO. Stepwedge # 80C3613
EXAM METHOD UT
GRID AREA EXAMINED F3

QUALITY CONTROL
 YES REVIEW ACCEPTED NO
Cliff M... 5/18/86
SIGNATURE & DATE UT-III

	7	8	9	10	11	12
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4.16.86
EXAMINER [Signature] LEVEL II DATE 4.16.86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 12 OF 22

SITE LOCATION NMPI
 PROCEDURE NO. 80A2434
 AREA OF EXAM SEE ATTACHED SKETCH
 DRAWING NO. N/A
 CAL. BLOCK NO. Step 5.0 Cal # 8003613
 EXAM METHOD UT
 GRID AREA EXAMINED # 3

NIAGARA MOHAWK PUBLIC CORPORATION
 QUALITY CONTROL REVIEW ACCEPTED
 YES NO
Chaffin 5/1/86
 SIGNATURE & DATE UT-III

	1	2	3	4	5	6
A	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.48"	MAX=.48" MIN=.46"
B	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
C	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
D	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
E	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
F	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER *Robert J. Fiden* LEVEL II DATE 4.16.86
 EXAMINER *Robert J. Fiden* LEVEL II DATE 4.16.86
 REVIEWER *Edmund R. D'Arcangelo* LEVEL II DATE 4-30-86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
 SIGNATURE *W. O. Kelly*

100

101

102

103

104

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 13 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP WEDGE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #3

NIAGARA MOHAWK PIPING CORPORATION
 YES QUALITY CONTROL REVIEW ACCEPTED N/A NO
[Signature] 5/1/88
SIGNATURE & DATE UT-III

	7	8	9	10	11	12
A	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
B	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
C	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
D	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
E	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
F	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER Edward R. Donovan LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

100

100

100



**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 14 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP BY STEP #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #4

NIAGARA MOHAWK POWER CORPORATION
 QUALITY CONTROL REVIEW ACCEPTED
YES NO
Cliff M... 5/2/86
SIGNATURE & DATE UT-III

	1	2	3	4	5	6
A	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48
B	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48
C	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48
D	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48
E	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48
F	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48	MAX= .48 MIN= .48

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER Edmund R. Donovan LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANTI REVIEW
SIGNATURE [Signature]
DATE: 5-7-87

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 15 OF 22

SITE LOCATION UMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEPWEXE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #4

QUALITY CONTROL CORPORATION
 YES REVIEW ACCEPTED
Chris M... 5/2/86
SIGNATURE & DATE KT-III

	7	8	9	10	11	12
A	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"
B	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"
C	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"
D	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"
E	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"
F	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"	MAX= .48" MIN= .48"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER Edmund R. Donovan LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 16 OF 22

SITE LOCATION NMP1
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP WEDGE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED = 4

QUALITY CONTROL YES NO
REVIEW ACCEPTED YES NO
SIGNATURE: Cliff Mass DATE: 5/1/86
WT-III

	1	2	3	4	5	6
G	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
H	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
I	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
J	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]
DATE _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

... ..



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 17 OF 22

SITE LOCATION NMP1
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. SEQUENCE # 8003613
EXAM METHOD UT
GRID AREA EXAMINED. #4

NIAGARA MOHAWK POWER CORPORATION
 QUALITY CONTROL REVIEW ACCEPTED
YES NO
5/2/86
UT-III

	7	8	9	10	11	12
G	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
H	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
I	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
J	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"	MAX=.48" MIN=.48"
K	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
L	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4.16.86
EXAMINER [Signature] LEVEL II DATE 4.16.86
REVIEWER Edmund R. Donovan LEVEL II DATE 4-30-86
VIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]
DATE: 5-7-87

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2734-1
PAGE 18 OF 22

SITE LOCATION KUMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEPWEDGE #80C3613
EXAM METHOD UT
GRID AREA EXAMINED #5

NIAGARA MOHAWK POWER CORPORATION
 YES NO
QUALITY CONTROL REVIEW ACCEPTED
Chris Mass 5/2/86
SIGNATURE & DATE UT-III

	1	2	3	4	5	6
A	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
B	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
C	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
D	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
E	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
F	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER Edward R. Donovan LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 19 OF 22

SITE LOCATION WMP1
PROCEDURE NO. QA2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEP EDGE # RC3613
EXAM METHOD UT
GRID AREA EXAMINED #5

MALAYSIA ATOMIAK PUBLIC CORPORATION
 QUALITY CONTROL
YES REVIEW ACCEPTED NO
Chaf MRS 5/2/86
SIGNATURE & DATE 47-III

	7	8	9	10	11	12
A	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
B	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
C	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
D	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
E	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
F	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]

1000

1000

1000

1000

1000

1000
1000
1000
1000

1000

1000

1000

1000

1000

1000

1000

1000

**TORUS
ULTRASONIC
THICKNESS
MEASUREMENT**

DATA SHEET 2434-1
PAGE 20 OF 22


SITE LOCATION NMPI
 PROCEDURE NO. 80A2434
 AREA OF EXAM SEE ATTACHED SKETCH
 DRAWING NO. N/A
 CAL. BLOCK NO. STEPWEDGE #80C3613
 EXAM METHOD UT
 GRID AREA EXAMINED # 5

QUALITY CONTROL **N/A**
 YES REVIEW ACCEPTED NO
Chas M... 5/2/86
 SIGNATURE & DATE UT-III

	1	2	3	4	5	6
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"
L	MAX=.48" MIN=.44"	MAX=.48" MIN=.46"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"

EXAMINER [Signature] LEVEL II DATE 4.16.86
 EXAMINER [Signature] LEVEL II DATE 4.16.86
 REVIEWER [Signature] LEVEL II DATE 4-30-86
 REVIEWER _____ LEVEL _____ DATE _____
 REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]



TORUS
ULTRASONIC
THICKNESS
MEASUREMENT

DATA SHEET 2434-1
PAGE 21 OF 22

SITE LOCATION NMPI
PROCEDURE NO. 80A2434
AREA OF EXAM SEE ATTACHED SKETCH
DRAWING NO. N/A
CAL. BLOCK NO. STEPWEDGE # 8003613
EXAM METHOD UT
GRID AREA EXAMINED # 5

NIAGARA MOHAWK POWER CORPORATION
 YES
 NO
QUALITY CONTROL
REVIEW ACCEPTED
Cliff M... 5/2/86
SIGNATURE & DATE UT-III

	7	8	9	10	11	12
G	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
H	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
I	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
J	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"	MAX=.48" MIN=.46"
K	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"
L	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"	MAX=.48" MIN=.44"

EXAMINER [Signature] LEVEL II DATE 4-16-86
EXAMINER [Signature] LEVEL II DATE 4-16-86
REVIEWER [Signature] LEVEL II DATE 4-30-86
REVIEWER _____ LEVEL _____ DATE _____
REVIEWER _____ LEVEL _____ DATE _____

ANII REVIEW
SIGNATURE [Signature]
DATE _____



Area #1
New York

73

NIAGARA MOHAWK POWER CORPORATION

TELECOPIER COVER LETTER

PLEASE DELIVER THE FOLLOWING PAGES TO:

NAME ~~Ray [unclear]~~ & Larry McNeer
COMPANY NMPC - Salina Meadows

FROM:

NAME Dick Shelton
COMPANY NMPC - Nine Mile Point Nuclear Station # 1

NUMBER OF PAGES 4 (INCLUDING COVER SHEET)

DATE 4-22-88 TIME 9:45 A.M.
P.M.

IF YOU DO NOT RECEIVE ALL THE PAGES OR THERE IS A PROBLEM WITH THE TRANSMISSION, PLEASE CALL RECEPTIONIST, (315) 349-2833 or 2855.

RAPICOM 210 - AUTOMATIC RAPICOM NUMBER (315) 349-2371
OR
BACKUP

RAPICOM 210 - AUTOMATIC RADIATION RECORDS DEPARTMENT
RAPICOM NUMBER (315) 349-2832

PLEASE - COPY & DELIVER
A COPY TO EACH.
THANKS!

THE UNIVERSITY OF CHICAGO

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

THE UNIVERSITY OF CHICAGO

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED
 Comp./Sys.: TIGUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET

Date Pkg.: 2433-88A-73
 Page 1 of 3
 Exam Item: GRID AREA #1
 Procedure: 80A2433
 Rev./F.C.: 3 / FC.1
 Title: LIT EXAM - STEAM EROSION


INSTRUMENT SETTINGS	
Serial #	213220.4
MFG./Model #	KKB-USL-48
Sweep Length	6.77
Sweep Delay	8.02
Pulse Length/Comp.	FIXED
Freq.	5.0 Range 5°
DEC/Gate	<input checked="" type="checkbox"/> Reject MIN
Jacks	T&R
Mode Select	DUAL
Coarse Gain	40 Fine 24
Scan Sens.	80%

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	25° ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X5' SELF CONT
Couplant Batch	8764
Couplant Brand	ULTRAGE II

Calibration - Block	NMP-1SW-1020-CS
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	SEE REACHED
Block Temperature	72 °F
Comp. Temperature	80 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Callb.	2325
Intermediate	0100
Intermediate	N/A
Intermediate	N/A
Final Callb.	0216
Calibration Date	4/22/88

INSTRUMENT LINEARITY				
1	100	50	6	50 25
2	80	45	7	40 20
3	80	40	8	30 15
4	70	35	9	20 10
5	60	30		



AMPLITUDE LINEARITY			
80 + 6 =	42	80 + 12 =	22
40 + 6 =	74	20 + 12 =	76

DAC		
Reflector	%FSH	Position
1	2"	80% 2.0
2	4"	70% 4.0
3	5"	50% 5.0
4	8"	40% 8.0
5	10"	30% 10
6	N/A	N/A N/A

CRT Calibrated in
 1" OF DEPTH
 Each Major Screen Div. = 10°

Scan Angle	0 DEGREES
Meas. Angle	N/A
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item GRID AREA #1

Comments/Reasons for Incomplete Exams
TORUS CALIBRATION FOR THICKNESS READINGS
ONLY. SEE ATTACHED FOR THICKNESS
READINGS AND GRID EXAM

Remarks
CLEANED OFF COUPLANT RESIDUE
WITH DEMIN WATER AND TSP

Examiner 1: Gordon Forster Level: II Date: 4-22-88
 GORDON FORSTER LEVEL II

Examiner 2: ANDREW BULLOCK Level: LEVEL I Date: 4-22-88
 ANDREW BULLOCK LEVEL I

WR#
 NCR#
 TRAVELER

NES REVIEWER: _____ LEVEL: _____ DATE: _____

QA/QC	ANII
-------	------

WELD ACCEPTABLE?
 YES NO

NMPC ENG.
 DISP. REQ.
 YES NO

www.ck12.org



Plant/Unit: NIAGARA POINT UNIT, CV-2
ISO: N/A
Comp. Sys.: TARUS
Loop: N/A

Date Pkg.: 2753-88A-73
Page 2 of 3
Exam Item: GRID AREA #1
Procedure: 80A2433
Rev. I.F.C.: 317C-1
Title: UT EXAM - STEAM EROSION

	1	2	3	4	5	6	7	8	9	10	11	12
A	.460"	.461"	.453"	.455"	.456"	.465"	.459"	.458"	.457"	.457"	.450"	.450"
B	.456"	.458"	.451"	.451"	.452"	.450"	.456"	.454"	.453"	.455"	.449"	.449"
C	.454"	.455"	.453"	.455"	.457"	.458"	.458"	.467"	.461"	.453"	.450"	.453"
D	.453"	.453"	.452"	.452"	.454"	.456"	.456"	.462"	.458"	.452"	.449"	.450"
E	.455"	.455"	.452"	.456"	.451"	.451"	.455"	.457"	.453"	.455"	.460"	.454"
F	.452"	.453"	.452"	.453"	.450"	.448"	.448"	.457"	.450"	.453"	.458"	.452"
G	.450"	.454"	.454"	.452"	.454"	.455"	.456"	.457"	.450"	.452"	.454"	.453"
H	.448"	.452"	.452"	.450"	.452"	.453"	.452"	.454"	.448"	.450"	.452"	.450"
I	.456"	.454"	.454"	.455"	.456"	.458"	.455"	.464"	.456"	.453"	.452"	.455"
J	.454"	.452"	.453"	.454"	.455"	.455"	.454"	.457"	.454"	.451"	.450"	.451"
K	.455"	.454"	.456"	.458"	.458"	.466"	.462"	.457"	.457"	.458"	.467"	.461"
L	.453"	.452"	.453"	.453"	.455"	.464"	.460"	.454"	.453"	.454"	.463"	.457"
M	.456"	.454"	.463"	.454"	.454"	.457"	.472"	.452"	.453"	.453"	.461"	.457"
N	.454"	.452"	.459"	.451"	.451"	.454"	.466"	.451"	.451"	.451"	.464"	.453"
O	.457"	.455"	.455"	.457"	.456"	.457"	.461"	.457"	.465"	.458"	.457"	.456"
P	.456"	.452"	.452"	.455"	.451"	.455"	.459"	.457"	.461"	.455"	.452"	.451"
Q	.457"	.455"	.453"	.461"	.463"	.460"	.458"	.459"	.456"	.461"	.459"	.456"
R	.455"	.450"	.450"	.456"	.457"	.457"	.453"	.455"	.453"	.456"	.454"	.452"
S	.458"	.455"	.452"	.456"	.456"	.463"	.458"	.456"	.456"	.455"	.456"	.456"
T	.453"	.454"	.450"	.455"	.455"	.458"	.454"	.454"	.454"	.454"	.453"	.453"
U	.452"	.455"	.457"	.462"	.461"	.453"	.455"	.454"	.462"	.456"	.458"	.462"
V	.453"	.452"	.456"	.459"	.459"	.450"	.453"	.450"	.457"	.452"	.454"	.458"
W	.454"	.462"	.457"	.455"	.464"	.458"	.454"	.456"	.458"	.454"	.462"	.455"
X	.451"	.457"	.455"	.453"	.458"	.455"	.453"	.453"	.454"	.451"	.456"	.452"

Examiner 1: Barlow Foster Level: II Date: 4-22-88

Examiner 2: **INFORMATION ONLY** Level: I Date: 4-22-88

NES REVIEWER: _____ LEVEL: _____ DATE: _____

QA/OC	ANII
-------	------




SO: N/A
 Comp. 15y: TMS
 002: N/A

SKETCH
 SH
 NOT SCALE

Date: Pkg.: 243 88A-73
 Page 3 of 2
 Exam Item: NAV 9 AREA #1
 Procedure: 80A 7433
 Rev. IF C.: 3 / FC-1
 Title: UT EADM STREAM EROSION

TRANSVERSE MEASUREMENT STATIONS



SOUTH EAST CORNER WATCH

Examiner 1: Gordon Forster Level: II Date: 4-22-88

Examiner 2: INFORMATION ONLY Date:

YES REVIEWER: LEVEL: DATE:

APL 22 1988 05:58 9 MILE UNIT #1

76

5871-

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: NA
 Comp./Sys.: TORUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET


Data Pkg.: 2434-88A-131
 Page 1 of 22
 Exam Item: TORUS
 Procedure: 80A2434
 Rev./F.C.: 3/FC-182
 Title: UT EXAM - THICKNESS

INSTRUMENT SETTINGS	
Model	KB2051-10
Sweep Length	6.24
Sweep Delay	5.00
Pulse Length/Damp.	FXD
Freq	5.0 Range 50°
DEC/Gate	OFF Select MIN
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40 Fine 20
Scan Sens.	SEE REMARKS

SEARCH UNIT	
Brand	KB AEROTECH
Frequency	5.0 MHz
Size/Shape	25° ROUND
Style/Type	GAMMA DUFF
Fixture	N/A
Cable	2X6' SELF-CONT
Couplant Batch	8554
Couplant Brand	ULTRAGEL II

Calibration Block	
Block	NMP-1SW-1020-C8
Comp. Temp	75 °F
Thermometer	KB114
Surface	CD

Calibration Checks :Time	
Initial Calib.	1430
Intermediate	N/A
Intermediate	N/A
Intermediate	N/A
Final Calib.	1600
Calibration Date	2-19-88



DAC		
Reflector	%FSH	Position
1	30"	80 3.0
2	60"	80 6.0
3	N/A	N/A N/A
4	N/A	N/A N/A
5	N/A	N/A N/A
6	N/A	N/A N/A

INSTRUMENT LINEARITY				
1	100	50	8	50 25
2	90	45	7	40 20
3	80	40	8	30 15
4	70	35	9	20 10
5	60	30		

AMPLITUDE LINEARITY			
80 - 6 = 40	80 - 12 = 20		
40 + 6 = 80	20 + 12 = 80		

CRT Calibrated in
 INCHES OF DEPTH
 Each Major Screen Div. = 1.0"

Scan Angle	0°
Meas. Angle	N/A
Mode	LONG
Calibration	THICKNESS
Scan Area	GRD

Exam Item | TORUS

Comments/Reasons for Incomplete Exams
TORUS THICKNESS AREAS 1 THRU 5
SCANNED GRID AREAS 1 THRU 5
REFER TO ATTACHED MAP AND GRIDS FOR THICKNESS READINGS

Remarks
MAINTAINED 80% BACK
REFLECTION

Examiner 1: H. M. Hawkins Level: II Date: 2-19-88 WR# N/A
HARRY HAWKINS UT LEVEL II NCR# N/A
 Examiner 2: Gary Jude Level: II Date: 2-19-88 TRAVELER RXBM-88-001
GARY JUDE UT LEVEL II

NES REVIEWER: Art Purnan LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------

YIELD ACCEPTABLE?
 YES NO
 NMPG. ENG.
 DIS. REQ.
 YES NO

1880

1880

1880

1880

1880

1880

1880




LOCATION OF
NINE MILE PT
UNIT # 1
SUPPRESSION CHAMBER
THICKNESS MEASUREMENT
STATIONS

"SECTION"
LOOKING
SOUTH WEST

CIRC SEAM
AT
135°

LOOKING NORTH WEST

S.C.



NOTES:

1. SCALE 1/4" = 1'-0"
2. 6" CORE SPRAY BYPASS
3. 12" CORE SPRAY

NIAGARA MOHAWK
POWER CORP.

4-26-78

SE corner

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30



Plant/Unit: NMP # I
ISO: 7A
Comp./Sys: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2454-SSA-131
Page 3 of 22
Exam Item: Torus Grid #1
Procedure: 80A2434
Rev./F.C.: 3 / FC-1.2
Title: UT Exam Thickness

	1	2	3	4	5	6
A	MAX-.465 MIN-.452	MAX-.469 MIN-.458	MAX-.465 MIN-.459	MAX-.469 MIN-.460	MAX-.469 MIN-.460	MAX-.469 MIN-.460
B	MAX-.468 MIN-.461	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459
C	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458
D	MAX-.465 MIN-.454	MAX-.465 MIN-.454	MAX-.465 MIN-.454	MAX-.465 MIN-.454	MAX-.465 MIN-.454	MAX-.465 MIN-.454
E	MAX-.467 MIN-.456	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459
F	MAX-.469 MIN-.459	MAX-.469 MIN-.459	MAX-.469 MIN-.459	MAX-.469 MIN-.459	MAX-.469 MIN-.459	MAX-.469 MIN-.459

Examiner 1: H.M. Harris Level: II Date: 2-19-88

Examiner 2: Perry Spade Level: I Date: 2-19-88

RES REVIEWER: Pat R... LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------

SECRET

SECRET

SECRET

SECRET

SECRET

SECRET

SECRET



Plant/Unit: NINE MILE POINT I
ISO: HA
Comp./Sys.: TORUS
Loop: NA

TORUS THICKNESS

Date Pkg.: 2434-KYA-131
Page 4 of 22
Exam Item: TORUS Grid #1
Procedure: 80A2434
Rev./F.C.: Rev. 3 / F.C.: 1, 2
Title: UT: EXAM Thickness

Calibration Block: STEP WEDGE 805013
Grid Area: 1.255

	7	8	9	10	11	12
A	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460
B	MAX= .468 MIN= .459	MAX= .468 MIN= .459	MAX= .468 MIN= .459	MAX= .468 MIN= .459	MAX= .468 MIN= .459	MAX= .468 MIN= .459
C	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458
D	MAX= .465 MIN= .454	MAX= .465 MIN= .454	MAX= .465 MIN= .454	MAX= .465 MIN= .454	MAX= .465 MIN= .454	MAX= .465 MIN= .454
E	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459
F	MAX= .469 MIN= .459	MAX= .469 MIN= .459	MAX= .469 MIN= .459	MAX= .469 MIN= .459	MAX= .469 MIN= .459	MAX= .469 MIN= .459

Examiner 1: H. M. Hainline Level: II Date: 2-19-88

Examiner 2: Amy J. [unclear] Level: II Date: 2-19-88

QA/QC REVIEWER: [Signature] LEVEL: II DATE: 2-19-88

QA/QC	ANII
-------	------

SECRET

SECRET

SECRET

SECRET

SECRET



Plant/Unit: NINE MILE POINT #1
ISO: NA
Comp./Sys.: TORUS
LOOO: NA

TORUS THICKNESS

Date Pkg.: 2/17-88A-131
Page 5 of 22
Exam Item: Torus Grid #1
Procedure: 80A2434
Rev. J.F.C.: 3 / FC-1.2
Title: UT EXAM THICKNESS

	1	2	3	4	5	6
G	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458
H	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458
I	MAX-.466 MIN-.455	MAX-.465 MIN-.457	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459
J	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452
K	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458
L	MAX-.465 MIN-.457	MAX-.466 MIN-.459	MAX-.465 MIN-.457	MAX-.465 MIN-.457	MAX-.465 MIN-.457	MAX-.465 MIN-.457

Examiner 1: A.M. Hankin Level: II Date: 2-19-88

Examiner 2: Avery Jide Level: IT Date: 2-19-88

QA/QC REVIEWER: Pat. P... LEVEL: II DATE: 2-20-88

QA/QC	AXII
-------	------

100

100

100

100

100

100

100



Plant/Unit: NMP #1
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88A-131
Page 6 of 22
Exam Item: Torus Grid #1
Procedure: 80A2434
Rev./F.C.: 3 / FC-1,2
Title: UT Exam Thickness

Grid Area: 162.5

	7	8	9	10	11	12
G	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458
H	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458
I	MAX=.465 MIN=.459	MAX=.465 MIN=.459	MAX=.465 MIN=.459	MAX=.465 MIN=.459	MAX=.465 MIN=.459	MAX=.465 MIN=.459
J	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452
K	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.458	MAX=.465 MIN=.459	MAX=.465 MIN=.458
L	MAX=.465 MIN=.457	MAX=.465 MIN=.457	MAX=.465 MIN=.457	MAX=.465 MIN=.457	MAX=.465 MIN=.457	MAX=.465 MIN=.457

Examiner 1: N.M. Hamlin Level: II Date: 2-19-88

Examiner 2: Arny Jude Level: ET Date: 2-19-88

REVIEWER: Art P... LEVEL: III DATE: 2-20-88

QA/QC	AMII
-------	------



Plant/Unit: NMP #1
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88A-131
Page 7 of 22
Exam Item: Torus Grid #2
Procedure: 80A2434
Rev./F.C.: 3 / F.C.-1, 2
Title: UT Exam Thickness

Ins. Block: 2-045V

	1	2	3	4	5	6
A	MAX-.470 MIN-.455	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459	MAX-.466 MIN-.459
B	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458
C	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458
D	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458
E	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458	MAX-.464 MIN-.458
F	MAX-.467 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460

Examiner 1: N.M. Hankin Level: II Date: 2-19-88

Examiner 2: Arny Jada Level: IT Date: 2-19-88

TEST REVIEWER: At P... LEVEL: II DATE: 2-20-88

QA/QC	ANII
-------	------

SECRET

SECRET

SECRET

SECRET

SECRET

SECRET



Plant/Unit: NMP #1
190: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-58A-181
Page 8 of 22
Exam Item: Torus Grid #2
Procedure: 80A2434
Rev./F.C.: 3 / F.C. -1, 2
Title: UT Exam Thickness

Block: Step Wedge 80C 361
Area: 2 of 5

	7	8	9	10	11	12
A	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459	MAX= .466 MIN= .459
B	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458
C	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458
D	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458
E	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458	MAX= .464 MIN= .458
F	MAX= .468 MIN= .460	MAX= .468 MIN= .460	MAX= .468 MIN= .460	MAX= .468 MIN= .460	MAX= .468 MIN= .460	MAX= .468 MIN= .460

Examiner 1: H. M. Hankin Level: II Date: 2-19-88

Examiner 2: Andy Judd Level: IT Date: 2-19-88

DES REVIEWER: Art P... LEVEL: II DATE: 2-20-88

QA/CC	AMII
-------	------

1

2

3

4

5

6

7

8

9

10

11

12

13



14

Plant/Unit: NMP#1
ISO: N/A
Comp./Sys.: Torus
Load: N/A

TORUS THICKNESS

Data Pkg.: 2134-88A-131
Page: 9 of 22
Exam Item: Torus Grid #2
Procedure: 80A2434
Rev./F.C.: 3 / F.C. - 1, 2
Title: UT Exam Thickness

Spec. No. 2095 J

	1	2	3	4	5	6
G	MAX-.463 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459
H	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459
I	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458	MAX-.465 MIN-.458
J	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458
K	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458	MAX-.468 MIN-.458
L	MAX-.466 MIN-.460	MAX-.466 MIN-.456	MAX-.466 MIN-.456	MAX-.466 MIN-.458	MAX-.469 MIN-.460	MAX-.469 MIN-.460

Examiner 1: A. M. Hankin Level: II Date: 2-19-88

Examiner 2: Greg Jacobs Level: ET Date: 2-19-88

REVIEWER: Det. P. ... LEVEL: ... DATE: ...

GA/GC	ANII
-------	------

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail.

2. The second part of the document outlines the various methods used to collect and analyze data. It describes how different types of information are gathered and how they are processed to identify trends and anomalies. This section also covers the use of statistical techniques to interpret the data.

3. The third part of the document focuses on the results of the analysis. It presents a detailed breakdown of the findings, including a comparison of actual performance against the budget. It also discusses the implications of these results for the organization's overall financial health and for future planning.

4. The final part of the document provides a summary of the key points and offers recommendations for improving the financial reporting process. It suggests ways to enhance the accuracy and timeliness of the data and to ensure that the information is presented in a clear and concise manner.

5. In conclusion, the document highlights the significance of a robust financial reporting system. It stresses that such a system is essential for making informed decisions and for ensuring the long-term success of the organization.

Plant/Unit: NMP#1
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Data Pkg.: 2434-SPA-151
Page 10 of 22
Exam Item: Torus Grid #2
Procedure: 80A2434
Rev./F.C.: 3 / F.C. 1, 2
Title: UT Exam Thickness

Wedge: 2075

	7	8	9	10	11	12
G	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459
H	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459	MAX= .465 MIN= .459
I	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458	MAX= .465 MIN= .458
J	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458
K	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458	MAX= .468 MIN= .458
L	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460	MAX= .469 MIN= .460

Examiner 1: [Signature] Level: II Date: 2-19-88

Examiner 2: [Signature] Level: II Date: 2-19-88

QA/QC REVIEWER: [Signature] LEVEL: II DATE: 2-20-88

QA/QC	ANII
-------	------



Handwritten text, possibly a signature or date, located in the center of the page.

Plant/Unit: NMP#1
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Data Pkg.: 2434-88A-131
Page 11 of 22
Exam Item: Torus Grid #3
Procedure: 80A2434
Rev./F.C.: 3 / F.C.-1,2
Title: UT Exam Thickness

	1	2	3	4	5	6
A	MAX-.465 MIN-.456	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460
B	MAX-.465 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459
C	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459
D	MAX-.469 MIN-.460	MAX-.465 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460
E	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460
F	MAX-.469 MIN-.464	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462

Examiner 1: H. P. Hankin Level: II Date: 2-19-88

Examiner 2: Arny J. [Signature] Level: II Date: 2-19-88

RES REVIEWER: Act. P. [Signature] LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------

100

100

100

100

100

100

100

100

100



Plant/Unit: NMP # I
ISO: NA
Comp./Sys.: Torus
Leap: N/A

TORUS THICKNESS

Date Pkg.: 2451-SFA-131
Page 12 of 22
Exam Item: Torus Grid # 3
Procedure: 80A2434
Rev./F.C.: 3 / FC-1,2
Title: UT Exam Thickness

Calibration Block: Step Wedge 80C3613
Grid Area: 3 of 5


	7	8	9	10	11	12
A	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460	MAX-.465 MIN-.460
B	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459	MAX-.468 MIN-.459
C	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459	MAX-.465 MIN-.459
D	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460	MAX-.467 MIN-.460
E	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460	MAX-.468 MIN-.460
F	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462	MAX-.469 MIN-.462

Examiner 1: H.M. Nash Level: II Date: 2-19-88

Examiner 2: Greg Judd Level: II Date: 2-19-88

QA/QC REVIEWER: GP LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------



Plant/Unit: NMP# I
ISO: 7A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2454-88A-131
Page 13 of 22
Exam Item: Torus Grid #3
Procedure: 80A2434
Rev./F.C.: 3 / F.C. - 1, 2
Title: UT Exam Thickness

Calibration Dia: 3.68
Grid Area: 3.68


	1	2	3	4	5	6
G	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460
H	MAX-.470 MIN-.461	MAX-.471 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461
I	MAX-.471 MIN-.462	MAX-.471 MIN-.461	MAX-.471 MIN-.461	MAX-.471 MIN-.461	MAX-.471 MIN-.461	MAX-.471 MIN-.461
J	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461	MAX-.470 MIN-.461
K	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460
L	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460	MAX-.470 MIN-.460

Examiner 1: N.M. Namb Level: II Date: 2-19-88

Examiner 2: George Level: II Date: 2-19-88

RES REVIEWER: Pat LEVEL: II DATE: 2-20-88

QA/QC	ANII
-------	------



Plant/Unit: NMP# I
ISO: 7/2
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-28A-131
Page 14 of 22
Exam Item: Torus Grid #3
Procedure: 80A2434
Rev./F.C.: 3 / F.C. - 1,2
Title: UT Exam Thickness

	7	8	9	10	11	12
G	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,461
H	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461
I	MAX=,471 MIN=,461	MAX=,471 MIN=,461	MAX=,471 MIN=,461	MAX=,471 MIN=,461	MAX=,471 MIN=,461	MAX=,471 MIN=,461
J	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461	MAX=,470 MIN=,461
K	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460
L	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460	MAX=,470 MIN=,460

Examiner 1: N.M. Hawk Level: II Date: 2-19-88

Examiner 2: A. J. [unclear] Level: ET Date: 2-19-88

RES. REVIEWER: Art Penn LEVEL: III DATE: 2-20-88

I/QC:	ANIT:
-------	-------

1945

1945

1945

1945

1945

1945

1945

Plant/Unit: NMP # I
 ISO: N/A
 Comp./Sys.: Torus
 Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88d-131
 Page 15 of
 Exam Item: Torus Grid # 4
 Procedure: 80A2434
 Rev./F.C.: 3 / FC-1, 2
 Title: UT Exam Thickness

Grid Area: 107.5

	1	2	3	4	5	6
A	MAX- 469 MIN- 460	MAX- 468 MIN- 463	MAX- 465 MIN- 455	MAX- 465 MIN- 455	MAX- 465 MIN- 455	MAX- 465 MIN- 455
B	MAX- 469 MIN- 456	MAX- 469 MIN- 456	MAX- 469 MIN- 456	MAX- 469 MIN- 456	MAX- 469 MIN- 456	MAX- 469 MIN- 456
C	MAX- 467 MIN- 460	MAX- 466 MIN- 456	MAX- 466 MIN- 456	MAX- 466 MIN- 456	MAX- 466 MIN- 456	MAX- 466 MIN- 456
D	MAX- 466 MIN- 458	MAX- 466 MIN- 458	MAX- 466 MIN- 458	MAX- 466 MIN- 458	MAX- 466 MIN- 458	MAX- 466 MIN- 458
E	MAX- 465 MIN- 453	MAX- 461 MIN- 455	MAX- 464 MIN- 455	MAX- 464 MIN- 455	MAX- 464 MIN- 455	MAX- 464 MIN- 455
F	MAX- 466 MIN- 455	MAX- 465 MIN- 458	MAX- 465 MIN- 458	MAX- 465 MIN- 458	MAX- 465 MIN- 458	MAX- 465 MIN- 458

Examiner 1: H.M. Hawkins Level: II Date: 2-19-88

Examiner 2: Arny Judd Level: II Date: 2-19-88

RES. REVIEWER: Pat Purnan LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------

100

100

100

100



Plant/Unit: NMP # I
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Data Pkg.: 2434-88A-131
Page 16 of 22
Exam Item: Torus Grid #4
Procedure: 80A2434
Rev./F.C.: 3 / F.C. - 1, 2
Title: UT Exam Thickness

Calibration Block: Step Wedge No. 36.5
Grid Area: 4.075


	7	8	9	10	11	12
A	MAX=.465 MIN=.455	MAX=.465 MIN=.455	MAX=.465 MIN=.455	MAX=.465 MIN=.455	MAX=.465 MIN=.455	MAX=.465 MIN=.455
B	MAX=.469 MIN=.456	MAX=.469 MIN=.456	MAX=.469 MIN=.456	MAX=.469 MIN=.456	MAX=.469 MIN=.456	MAX=.469 MIN=.456
C	MAX=.466 MIN=.456	MAX=.466 MIN=.456	MAX=.466 MIN=.456	MAX=.466 MIN=.456	MAX=.466 MIN=.456	MAX=.466 MIN=.456
D	MAX=.466 MIN=.458	MAX=.466 MIN=.458	MAX=.466 MIN=.458	MAX=.466 MIN=.458	MAX=.466 MIN=.458	MAX=.466 MIN=.458
E	MAX=.464 MIN=.455	MAX=.464 MIN=.455	MAX=.464 MIN=.455	MAX=.464 MIN=.455	MAX=.464 MIN=.455	MAX=.464 MIN=.455
F	MAX=.465 MIN=.458	MAX=.465 MIN=.460	MAX=.465 MIN=.460	MAX=.465 MIN=.460	MAX=.465 MIN=.460	MAX=.465 MIN=.460

Examiner 1: H. M. Namb Level: II Date: 2-19-88

Examiner 2: Greg J. [unclear] Level: ET Date: 2-19-88

RES REVIEWER: [Signature] LEVEL: II DATE: 2-20-88

QA/QC	ANII
-------	------



Plant/Unit: NMP # I
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88A-131
Page 17 of 32
Exam Item: Torus Grid #4
Procedure: 80A2434
Rev./F.C.: 3 / FC-1,2
Title: UT Exam Thickness

	1	2	3	4	5	6
G	MAX- .466 MIN- .454	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452
H	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452	MAX- .465 MIN- .452
I	MAX- .466 MIN- .454	MAX- .466 MIN- .454	MAX- .466 MIN- .454	MAX- .466 MIN- .454	MAX- .466 MIN- .454	MAX- .466 MIN- .454
J	MAX- .463 MIN- .454	MAX- .463 MIN- .454	MAX- .463 MIN- .454	MAX- .463 MIN- .454	MAX- .463 MIN- .454	MAX- .463 MIN- .454
K	MAX- .463 MIN- .458	MAX- .463 MIN- .458	MAX- .463 MIN- .458	MAX- .463 MIN- .458	MAX- .463 MIN- .458	MAX- .463 MIN- .458
L	MAX- .462 MIN- .454	MAX- .462 MIN- .454	MAX- .462 MIN- .454	MAX- .462 MIN- .454	MAX- .462 MIN- .454	MAX- .462 MIN- .454

Examiner 1: H. M. Hankin Level: II Date: 2-19-88

Examiner 2: Sary J. J. J. Level: II Date: 2-19-88

NES REVIEWER: Pat. P. P. LEVEL: III DATE: 2-20-88

WQC	AMII
-----	------

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

Plant/Unit: NMP #I
ISO: NA
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-PXA-131
Page: 28 of 22
Exam Item: Torus Grid #4
Procedure: 80A 2434
Rev./F.C.: 3 / FC-1,2
Title: UT Exant Thickness

UT Area: 4645

	7	8	9	10	11	12
G	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452
H	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452
I	MAX=.466 MIN=.454	MAX=.466 MIN=.454	MAX=.466 MIN=.454	MAX=.466 MIN=.454	MAX=.466 MIN=.454	MAX=.466 MIN=.454
J	MAX=.463 MIN=.454	MAX=.463 MIN=.454	MAX=.463 MIN=.454	MAX=.463 MIN=.454	MAX=.463 MIN=.454	MAX=.463 MIN=.454
K	MAX=.463 MIN=.458	MAX=.463 MIN=.458	MAX=.463 MIN=.458	MAX=.463 MIN=.458	MAX=.463 MIN=.458	MAX=.463 MIN=.458
L	MAX=.462 MIN=.454	MAX=.462 MIN=.454	MAX=.462 MIN=.454	MAX=.462 MIN=.454	MAX=.462 MIN=.454	MAX=.462 MIN=.454

Examiner 1: H.M. Hawks Level: II Date: 2-19-88

Examiner 2: George Jude Level: ET Date: 2-19-88

YES REVIEWER: Art Pearson LEVEL: III DATE: 2-20-88

QA/CC	AMII
-------	------



Plant/Unit: NMP # I
ISO: 7A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88A-131
Page 19 of 22
Exam Item: Torus Grid # 5
Procedure: 80A 2434
Rev./F.C.: 3 / FC-1,2
Title: UT Exam Thickness

Calibration: Step 1 of 5
Grid Area: 5 of 5

	1	2	3	4	5	6
A	MAX=.465 MIN=.462	MAX=.465 MIN=.462	MAX=.465 MIN=.462	MAX=.465 MIN=.462	MAX=.465 MIN=.462	MAX=.465 MIN=.462
B	MAX=.462 MIN=.459	MAX=.462 MIN=.459	MAX=.462 MIN=.459	MAX=.462 MIN=.452	MAX=.462 MIN=.452	MAX=.462 MIN=.452
C	MAX=.464 MIN=.453	MAX=.462 MIN=.459	MAX=.465 MIN=.459	MAX=.465 MIN=.456	MAX=.465 MIN=.456	MAX=.465 MIN=.456
D	MAX=.459 MIN=.451	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452
E	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452
F	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452	MAX=.465 MIN=.452

Examiner 1: H.M. Hark Level: II Date: 2-19-88

Examiner 2: Arny Jude Level: II Date: 2-19-88

TEST REVIEWER: Carl P... LEVEL: III DATE: 2-20-88

A/QC	ANII
------	------

100-100000

2

3

4

5

6

7

100-100000

100-100000

100-100000

100-100000



Plant/Unit: NMP # I
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS
THICKNESS

Date Pkg.: 2424-88A-131
Page 20 of 22
Exam Item: Torus Grid # 5
Procedure: 80A2434
Rev./F.C.: 3 / F.C.-1, 2
Title: UT Exam Thickness

Grid Area: 5 of 5

	7	8	9	10	11	12
A	MAX= .465 MIN= .462	MAX= .465 MIN= .462	MAX= .465 MIN= .462	MAX= .465 MIN= .462	MAX= .465 MIN= .462	MAX= .465 MIN= .462
B	MAX= .462 MIN= .452	MAX= .462 MIN= .452	MAX= .462 MIN= .452	MAX= .462 MIN= .452	MAX= .462 MIN= .452	MAX= .462 MIN= .452
C	MAX= .464 MIN= .456	MAX= .465 MIN= .456	MAX= .465 MIN= .456	MAX= .465 MIN= .456	MAX= .465 MIN= .456	MAX= .465 MIN= .456
D	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452
E	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452
F	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452

Examiner 1: H.M. Hawker Level: II Date: 2-19-88

Examiner 2: Arny Judd Level: ET Date: 2-19-88

TEST REVIEWER: Ch. P... LEVEL: III DATE: 2-20-88

IA/QC	ANII
-------	------

100

100

100



Plant/Unit: NMP # I
ISO: NA
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434-88A-131
Page 21 of 22
Exam Item: Torus Grid # 5
Procedure: 80A2434
Rev./F.C.: 3 / F.C. - 1,2
Title: UT Exam Thickness

Def Area: 505

	1	2	3	4	5	6
G	MAX-.461 MIN-.449	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452
H	MAX-.459 MIN-.455	MAX-.459 MIN-.455	MAX-.459 MIN-.455	MAX-.459 MIN-.455	MAX-.459 MIN-.455	MAX-.459 MIN-.455
I	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452
J	MAX-.478 MIN-.465	MAX-.465 MIN-.452	MAX-.465 MIN-.455	MAX-.465 MIN-.455	MAX-.465 MIN-.455	MAX-.465 MIN-.455
K	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452
L	MAX-.464 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452	MAX-.465 MIN-.452

Examiner 1: H.M. Hawks Level: II Date: 2-19-88

Examiner 2: Andy Jude Level: IT Date: 2-19-88

RES REVIEWER: Art Purnan LEVEL: III DATE: 2-20-88

QA/QC	ANII
-------	------

100

100

100

100

100

100



Plant/Unit: NMP# I
ISO: N/A
Comp./Sys.: Torus
Loop: N/A

TORUS THICKNESS

Date Pkg.: 2434 80A-131
Page 22 of 22
Exam Item: Torus Grid # 5
Procedure: 80A 2434
Rev./F.C.: 3/ F.C.-1, 2
Title: UT Exam Thickness


	7	8	9	10	11	12
G	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452
H	MAX= .459 MIN= .455	MAX= .459 MIN= .455	MAX= .459 MIN= .455	MAX= .459 MIN= .455	MAX= .459 MIN= .455	MAX= .459 MIN= .455
I	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452
J	MAX= .465 MIN= .455	MAX= .465 MIN= .455	MAX= .465 MIN= .455	MAX= .465 MIN= .455	MAX= .465 MIN= .455	MAX= .465 MIN= .455
K	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452
L	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452	MAX= .465 MIN= .452

Examiner 1: H. McLaughlin Level: II Date: 2-19-88

Examiner 2: Angela Level: IT Date: 2-19-88

WES REVIEWER: Cutler LEVEL: II DATE: 2-20-88

QA/OC	ANII
-------	------



Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS
 Comp./Sys.: TOBUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET


Data Pkg.: 2433-88A-85
 Page 1 of 2
 Exam Item: GRID 0 DEGREE TOP
 Procedure: 80A2433
 Rev./F.C.: 3 / FC 1
 Title: LIT EXAM - STEAM EROSION

INSTRUMENT SETTINGS			
Serial #	213220-4		
MFG./Model #	KKB-USL-48		
Sweep Length	6.50		
Sweep Delay	6.00		
Pulse Length/Damp.	OFF		
Freq.	5	Range	.5"
DEC/Gate	OFF	Reject	OFF
Jacks	R&T		
Mode Select	DUAL		
Coarse Gain	40	Fine	18
Scan Sens.	80% BR		

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL II

Calibration Block	
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1 2"	80%	2	
2 4"	65%	4	
3 6"	55%	6	
4 8"	40%	8	
5 1"	30%	10	
6 N/A	N/A	N/A	

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item GRID 0 DEGREE TOP

Comments/Reasons for Incomplete Exams
GRIDS 0 DEGREE TOP

Remarks
 CLEANED WITH DEMIN WATER & TSP.
 GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I.
 SEE ATTACHED SHEETS.

Examiner 1: H. M. Hawkins
 HARRY M. HAWKINS LEVEL II

Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELER 2x6m-88-002

Examiner 2: N/A

Level: Date:

NES REVIEWER: Prinos

LEVEL: III DATE: 4/21/88

FOR NMPC INFO.
JB 4/21/88
 WELD ACCEPTABLE?
 YES NO

QA/QC	ANII
	ANII INITIAL REVIEW: SIGNATURE _____ DATE _____ ANII FINAL ACCEPTANCE: <u>R. Prinos</u> <u>4/21/88</u> SIGNATURE _____ DATE _____

NMPC ENG. DISP. REQ.
 YES NO

0° Top

	1	2	3	4	5	6	7	8	9	10	11	12
A	.469	.467	.465	.465	.468	.472	.470	.470	.471	.470	.470	.483
B	.455	.454	.461	.454	.457	.455	.456	.458	.456	.455	.461	.460
C	.468	.466	.467	.467	.470	.470	.466	.468	.468	.471	.466	.465
D	.457	.453	.452	.452	.455	.453	.455	.455	.461	.455	.459	.452
E	.465	.465	.465	.465	.464	.465	.467	.470	.472	.470	.465	.465
F	.455	.452	.458	.453	.450	.452	.455	.449	.452	.462	.460	.449
G	.464	.462	.465	.463	.468	.466	.466	.465	.465	.467	.465	.462
H	.452	.449	.450	.460	.455	.459	.439	.444	.453	.457	.456	.457
I	.468	.463	.466	.462	.465	.465	.462	.465	.462	.466	.462	.465
J	.452	.450	.455	.452	.461	.457	.453	.463	.459	.449	.457	.454
K	.466	.466	.462	.466	.467	.467	.464	.469	.465	.463	.470	.470
L	.455	.452	.454	.458	.452	.452	.452	.453	.460	.456	.449	.456
M	.464	.462	.463	.464	.466	.462	.462	.463	.463	.463	.461	.470
N	.457	.449	.455	.452	.468	.454	.452	.459	.456	.456	.458	.454
O	.469	.465	.465	.462	.463	.462	.463	.466	.462	.463	.462	.465
P	.457	.455	.452	.455	.460	.455	.454	.455	.459	.460	.458	.455
Q	.465	.464	.465	.463	.463	.463	.462	.463	.463	.462	.462	.463
R	.453	.453	.453	.461	.453	.452	.452	.456	.456	.457	.454	.451
S	.461	.467	.467	.462	.461	.468	.461	.460	.470	.470	.467	.472
T	.453	.458	.457	.455	.458	.446	.452	.457	.457	.458	.455	.457
U	.464	.463	.462	.463	.462	.463	.461	.460	.460	.465	.463	.465
V	.453	.461	.459	.456	.449	.448	.454	.456	.454	.461	.456	.455
W	.462	.462	.466	.465	.463	.465	.465	.465	.464	.464	.470	.471
X	.457	.453	.456	.445	.456	.453	.459	.457	.462	.462	.462	.460

Record min/max thicknesses three decimal places.
 W. M. Hankins III 4-20-88

ANII INITIAL REVIEW:	
SIGNATURE _____	DATE _____
ANII FINAL ACCEPTANCE:	
<i>W. M. Hankins III</i>	4/21/88
SIGNATURE	DATE

W. M. Hankins III 4/21/88

02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100



Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS.
 Comp./Sys.: TOBUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET


Data Pkg.: 2433-88A-66
 Page 1 of 2
 Exam Item: GRID 0 DEGREE- BOTTOM
 Procedure: 80A2433
 Rev./F.C.: 3 / EC 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5 Range .5"
DEC/Gate	OFF Reject OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40 Fine 18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL

Calibration Block	
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1	2"	80%	2
2	4"	65%	4
3	6"	55%	6
4	8"	40%	8
5	1"	30%	10
6	N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated-In-
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item GRID 0 DEGREE- BOTTOM

Comments/Reasons for Incomplete Exams
GRIDS 0 DEGREE BOTTOM-

Remarks
 CLEANED WITH DEMIN WATER & TSP
 GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.T.
 SEE ATTACHED SHEETS

Examiner 1: H.M. Hawkins
 HARRY M. HAWKINS LEVEL II

Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELER# 8m-28-002

Examiner 2: N/A

Level: Date:

NES REVIEWER: Prinos

LEVEL: III DATE: 4/21/88

B 4/21/88
 FOR NMPC INFO.
 WELD ACCEPTABLE?
 YES NO N/A
 NMPC ENG. DISP. REQ.
 YES NO

QA/QC


ANII
 ANII INITIAL REVIEW:
 SIGNATURE _____ DATE _____
 ANII FINAL ACCEPTANCE:
H. B. ... 4/21/88
 SIGNATURE _____ DATE _____

1125



CALC # M79-81-M001 Rev 0 Page 6

NINE MILE POINT UNIT 1 MINIMUM TORUS WALL THICKNESS AREA NUMBER ONE





... ..

...

0° BOTTOM

	1	2	3	4	5	6	7	8	9	10	11	12
A	.469 .465	.470 .464	.470 .465	.471 .466	.469 .463	.474 .466	.470 .464	.470 .465	.473 .465	.470 .464	.472 .464	.472 .464
B	.470 .465	.472 .465	.475 .463	.470 .462	.470 .460	.469 .464	.470 .464	.470 .463	.471 .462	.472 .463	.473 .464	.471 .463
C	.469 .465	.472 .464	.474 .463	.472 .463	.472 .463	.470 .464	.470 .464	.471 .462	.470 .463	.470 .463	.470 .462	.472 .464
D	.472 .466	.470 .466	.472 .464	.472 .465	.470 .465	.471 .465	.471 .463	.472 .463	.472 .466	.472 .464	.472 .462	.471 .463
E	.470 .462	.473 .462	.472 .465	.474 .464	.474 .464	.475 .466	.474 .465	.473 .462	.472 .463	.472 .464	.469 .462	.470 .462
W D J T A U	.531 .462	.565 .465	.545 .462	.543 .463	.550 .464	.530 .469	.545 .466	.537 .462	.556 .466	.521 .466	.531 .467	.523 .462
	.531 (.453)	.565 .463	.545 .454	.543 .458	.550 .458	.530 .460	.545 .460	.537 .462	.556 .466	.521 .459	.531 .458	.523 .459
I H U	.470 .461	.472 .462	.469 .464	.471 .463	.473 .465	.472 .462	.469 .463	.469 .465	.468 .465	.470 .465	.470 .462	.470 .464
	.475 .463	.472 .463	.472 .463	.473 .462	.470 .464	.470 .462	.470 .463	.469 .465	.469 .464	.469 .462	.470 .463	.473 .466
K L	.470 .462	.469 .464	.468 .466	.470 .465	.472 .465	.470 .462	.469 .463	.469 .462	.470 .462	.469 .462	.472 .463	.472 .465
	.470 .464	.473 .463	.472 .462	.472 .464	.470 .466	.472 .463	.471 .464	.472 .463	.469 .465	.471 .465	.472 .463	.470 .463
T C	.470 .463	.473 .464	.472 .462	.471 .463	.474 .462	.469 .466	.475 .462	.473 .462	.472 .463	.474 .462	.473 .463	.472 .461

Record min/max thicknesses three decimal places.

H. M. Haski II 4-20-88

Diavano III 4/21/88

ANII INITIAL REVIEW:	
SIGNATURE _____	DATE _____
ANII FINAL ACCEPTANCE:	
R. B. [Signature] _____	4/21/88
SIGNATURE	DATE

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS
 Comp./Sys.: TOBUS
 Loop: N/A

**ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET**


Data Pkg.: 2433-88A-67
 Page 1 of 2
 Exam Item: GRID 90 DEGREE TOP
 Procedure: 80A2433
 Rev./F.C.: 3 / FC 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5
Range	.5"
DEC/Gate	OFF
Reject	OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40
Fine	18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELE CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL IS

Calibration Block	
Block Thickness	NMP-1SW-1020-CS
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	OD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1	2"	80%	2
2	4"	65%	4
3	6"	55%	6
4	8"	40%	8
5	1"	30%	10
6	N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item GRID 90 DEGREE TOP.

Comments/Reasons for Incomplete Exams
GRIDS 90 DEGREE TOP

Remarks
 CLEANED WITH DEMIN WATER & TSP
 GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I. SEE ATTACHED SHEETS.

Examiner 1: H. M. Hawkins
 HARRY M. HAWKINS LEVEL II

Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELER 2433-88-002

Examiner 2: N/A

Level: Date:

NES REVIEWER: Prisco

LEVEL: III DATE: 4/21/88

4/21/88
 FOR NMPC HFO.
 WELD ACCEPTABLE?
 YES NO

QA/QC

ANII
 ANII INITIAL REVIEW:
 SIGNATURE _____ DATE _____
 ANII FINAL ACCEPTANCE:
R. Blitman 4/21/88
 SIGNATURE _____ DATE _____

NMPC ENG.
 DISP. REQ.
 YES NO



24

25

26

27



28

29

30

31

32

33

34

35

36

37



90° TOP

	1	2	3	4	5	6	7	8	9	10	11	12
A	.461	.462	.464	.471	.465	.463	.466	.463	.464	.465	.466	.469
	.457	.460	.462	.458	.460	.455	.453	.454	.462	.450	.452	.456
B	.464	.475	.465	.462	.465	.467	.466	.471	.469	.467	.465	.469
	.462	.461	.450	.454	.456	.451	.461	.458	.453	.456	.464	.460
C	.463	.465	.471	.470	.465	.465	.465	.469	.465	.464	.462	.471
	.454	.456	.454	.456	.450	.453	.461	.457	.455	.462	.456	.466
D	.462	.465	.464	.462	.465	.463	.460	.475	.466	.466	.462	.469
	.456	.462	.462	.455	.461	.460	.457	.458	.454	.460	.457	.459
E	.466	.469	.470	.475	.466	.466	.469	.470	.468	.469	.470	.468
	.457	.464	.455	.457	.458	.451	.462	.461	.459	.462	.465	.457
F	.465	.465	.469	.465	.467	.468	.463	.462	.464	.470	.468	.470
	.459	.451	.464	.461	.465	.467	.457	.457	.458	.456	.455	.458
G	.470	.471	.465	.469	.468	.470	.472	.467	.463	.463	.465	.462
	.455	.457	.457	.458	.453	.461	.452	.450	.450	.457	.455	.451
H	.469	.462	.462	.462	.468	.467	.468	.469	.468	.465	.465	.468
	.451	.454	.457	.453	.461	.460	.453	.449	.453	.450	.459	.452
I	.465	.462	.462	.461	.462	.464	.463	.464	.466	.463	.461	.461
	.455	.450	.451	.452	.457	.455	.449	.448	.455	.450	.451	.451
J	.461	.462	.460	.462	.465	.465	.466	.469	.469	.466	.461	.467
	.458	.451	.450	.449	.450	.453	.446	.458	.452	.448	.448	.450
K	.465	.463	.463	.465	.462	.461	.465	.465	.465	.462	.466	.461
	.445	.448	.448	.449	.449	.456	.450	.463	.446	.454	.451	.447
L	.465	.466	.463	.463	.466	.469	.467	.462	.461	.461	.463	.462
	.449	.451	.446	.457	.454	.443	.446	.452	.451	.457	.457	.456

Record min/max thicknesses three decimal places.

G. M. Hauli II 4-20-88

Brian III 4/21/88

ANII INITIAL REVIEW:	
SIGNATURE	DATE
ANII FINAL ACCEPTANCE:	
G. M. Hauli II	4/21/88
SIGNATURE	DATE

Handwritten text, possibly a date or reference number, located on the right side of the page.



Small handwritten mark or signature located in the lower-left quadrant of the page.

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS.
 Comp./Sys.: TORUS
 Loop: N/A

**ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET**


Data Pkg.: 2433-88A-68
 Page 1 of 2
 Exam Item: GRID 90 DEGREE BOTTOM
 Procedure: 80A2433
 Rev./F.C.: 3 / EC 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5 Range .5"
DEC/Gate	OFF Reject OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40 Fine 18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL II

Calibration Block	NMP-1SW-1020-GS
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1 2"	80%	2	
2 4"	65%	4	
3 6"	55%	6	
4 8"	40%	8	
5 1"	30%	10	
6 N/A	N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item | GRID 90 DEGREE BOTTOM

Comments/Reasons for Incomplete Exams
GRIDS 90 DEGREE BOTTOM

Remarks
 CLEANED WITH DEMIN WATER & TSP.
 GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I. SEE ATTACHED SHEETS.

Examiner 1: H. M. Hawkins Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELERx801-88 CDZ

Examiner 2: N/A Level: Date:

NES REVIEWER: Armano LEVEL: III DATE: 4/21/88

B 4/21/88
 FOR NXP INFO.
 WELD ACCEPTABLE?
 YES NO

QA/QC	ANII
	ANII INITIAL REVIEW: SIGNATURE _____ DATE _____ ANII FINAL ACCEPTANCE: <u>G. R. [Signature]</u> 4/21/88 SIGNATURE _____ DATE _____

NMPC ENG.
 DISP. REQ.
 YES NO



10/20/2011


90° BOTTOM

	1	2	3	4	5	6	7	8	9	10	11	12
A	.464	.470	.464	.467	.469	.462	.469	.462	.462	.469	.462	.465
B	.456	.455	.454	.454	.454	.453	.455	.455	.456	.455	.454	.456
C	.462	.462	.465	.465	.462	.468	.471	.470	.468	.465	.467	.469
D	.455	.455	.455	.456	.455	.454	.459	.456	.454	.455	.456	.456
E	.470	.469	.465	.465	.465	.463	.463	.465	.465	.465	.463	.465
F	.453	.454	.454	.455	.455	.459	.452	.455	.456	.457	.457	.455
G	.465	.462	.462	.462	.468	.465	.465	.466	.462	.466	.462	.465
H	.455	.454	.454	.456	.466	.457	.454	.454	.454	.455	.457	.455
I	.468	.465	.462	.465	.468	.462	.464	.464	.462	.466	.463	.460
J	.457	.455	.455	.456	.454	.456	.453	.453	.455	.455	.458	.458
K	.577	.560	.582	.587	.556	.574	.557	.563	.536	.583	.526	.587
L	.455	.460	.459	.453	.456	.460	.462	.448	.462	.458	.460	.462
M	.577	.560	.582	.587	.556	.574	.557	.563	.536	.583	.526	.587
N	.462	.459	.466	.465	.462	.466	.466	.466	.465	.462	.461	.461
O	.470	.468	.470	.470	.470	.471	.471	.479	.472	.469	.470	.472
P	.465	.460	.461	.464	.463	.463	.462	.465	.464	.462	.465	.462
Q	.469	.469	.470	.472	.472	.468	.470	.470	.471	.471	.468	.468
R	.460	.462	.462	.461	.460	.461	.462	.462	.461	.461	.462	.460
S	.471	.469	.470	.470	.470	.470	.468	.471	.468	.468	.468	.470
T	.460	.462	.462	.462	.462	.462	.460	.462	.463	.460	.462	.462
U	.468	.469	.468	.468	.468	.469	.469	.470	.469	.468	.471	.469
V	.462	.461	.462	.462	.467	.467	.460	.463	.461	.460	.462	.462
W	.471	.470	.469	.469	.471	.471	.471	.470	.468	.468	.470	.469
X	.462	.464	.464	.462	.463	.463	.461	.461	.461	.465	.467	.461

Record min/max thicknesses three decimal places.
H.M. Hank II 4-20-88

ANII INITIAL REVIEW:	
SIGNATURE _____	DATE _____
ANII FINAL ACCEPTANCE:	
<i>R. B. [Signature]</i>	4/21/88
SIGNATURE _____	DATE _____

Brian IV 4/21/88



Plant/Unit: NINE MILE POINT UNIT ONE
ISO: SEE ATTACHED SHEETS & DRWGS
Comp./Sys.: TOBUS
Loop: N/A

ULTRASONIC
EXAMINATION
CALIBRATION
SHEET


Data Pkg.: 2433-88A-72
Page 1 of 2
Exam Item: GRID 180 DEGREE TOP
Procedure: 80A2433
Rev./F.C.: 3 / FC 1
Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5
Range	.5"
DEC/Gate	OFF
Reject	OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40
Fine	18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL I

Calibration Block	
Block Thickness	NMP-1SW-1020-GS
Comp. Thickness	.10-1.0"/1.1-2.0"
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1	2"	80%	2
2	4"	65%	4
3	6"	55%	6
4	8"	40%	8
5	1"	30%	10
6	N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated In
DEPTH OF METAL
Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item | GRID 180 DEGREE TOP

Comments/Reasons for Incomplete Exams
GRIDS 180 DEGREE TOP

Remarks
CLEANED WITH DEMIN WATER & TSP
GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I.
SEE ATTACHED SHEETS

Examiner 1: H.M. Hawkins
HARRY M. HAWKINS LEVEL II

Level: II Date: 4-20-88

WR# N/A
NCR# N/A
TRAVELER# 421-88-002

Examiner 2: N/A

Level: Date:

NES REVIEWER: Briano

LEVEL: III DATE: 4/21/88

FOR NMPC INFO
4/21/88
WELD ACCEPTABLE?
YES NO

QA/QC

ANII

ANII INITIAL REVIEW:	
SIGNATURE	DATE
ANII FINAL ACCEPTANCE:	
<u>R. R. [Signature]</u>	<u>4/21/88</u>
SIGNATURE	DATE

NMPC ENG. DISP. REQ.
YES NO

SECRET



SECRET

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS.
 Comp./Sys.: TORUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET


Data Pkg.: 2433-88A-71 109
 Page 1 of 2
 Exam Item: GRID 180 DEGREE BOTTOM
 Procedure: 80A2433
 Rev./F.C.: 3 / FC 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5
Range	.5"
DEC/Gate	OFF
Reject	OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40
Fine	18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAFLEX II

Calibration Block	
Block Thickness	NMP-1SW-1020-QS
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC			
Reflector	%FSH	Position	
1	2"	80%	2
2	4"	65%	4
3	6"	55%	6
4	8"	40%	8
5	10"	30%	10
6	N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

GRT Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item: GRID 180 DEGREE BOTTOM

Comments/Reasons for Incomplete Exams
GRIDS 180 DEGREE BOTTOM

Remarks
CLEANED WITH DEMIN WATER & TSP
GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I.
SEE ATTACHED SHEETS.

Examiner 1: H. M. Hawkins Level: II Date: 4-20-88
 HARRY M. HAWKINS LEVEL II

WR# N/A
 NCR# N/A
 TRAVELER K&BM-33-002


Examiner 2: N/A Level: Date:

NES REVIEWER: Prisano LEVEL: III DATE: 4/21/88

4/21/88
 FOR NMPC INFO.
 WELD ACCEPTABLE?
 YES NO
 NMPC ENG. DISP. REQ.
 YES NO

QA/QC	ANII ANII INITIAL REVIEW: SIGNATURE _____ DATE _____ ANII FINAL ACCEPTANCE: <u>R. Blaylock</u> <u>4/21/88</u> SIGNATURE _____ DATE _____
-------	---





INSTRUMENT SETTINGS: SEARCH UNIT: Calibration block: 1020-69
180° BOTTOM

	1	2	3	4	5	6	7	8	9	10	11	12
A	.478	.472	.469	.478	.472	.472	.474	.469	.471	.474	.472	.477
B	.465	.465	.466	.467	.465	.468	.467	.467	.467	.467	.465	.468
C	.474	.469	.474	.474	.475	.469	.480	.468	.480	.470	.481	.479
D	.468	.465	.467	.465	.469	.466	.470	.462	.469	.466	.465	.466
E	.468	.470	.469	.471	.473	.472	.469	.470	.474	.467	.467	.472
F	.465	.466	.466	.469	.469	.466	.467	.465	.468	.463	.463	.463
G	.473	.469	.468	.469	.470	.470	.468	.470	.467	.471	.467	.465
H	.466	.465	.467	.466	.465	.465	.464	.465	.468	.467	.465	.464
I	.472	.480	.467	.470	.486	.479	.472	.477	.468	.468	.469	.465
J	.466	.465	.464	.469	.466	.465	.468	.469	.466	.467	.465	.465
K	.530	.555	.567	.585	.578	.588	.539	.577	.554	.554	.555	.556
L	.460	.465	.468	.469	.469	.466	.467	.486	.465	.466	.465	.459
M	.530	.555	.567	.585	.578	.588	.539	.517	.554	.554	.555	.556
N	.454	.462	.463	.464	.469	.466	.455	.463	.462	.462	.462	.465
O	.464	.465	.462	.465	.465	.464	.462	.463	.462	.462	.462	.465
P	.462	.459	.459	.457	.462	.462	.458	.458	.454	.454	.454	.454
Q	.460	.460	.460	.465	.464	.461	.461	.465	.466	.466	.466	.461
R	.454	.455	.456	.456	.455	.458	.457	.462	.466	.466	.466	.466
S	.461	.465	.465	.472	.475	.474	.475	.469	.463	.466	.462	.466
T	.459	.462	.462	.466	.466	.463	.461	.463	.460	.459	.459	.462
U	.467	.464	.457	.462	.466	.466	.467	.465	.462	.462	.460	.462
V	.459	.454	.454	.456	.462	.459	.458	.455	.456	.458	.458	.453
W	.465	.459	.460	.462	.464	.465	.465	.465	.465	.466	.466	.464
X	.463	.454	.457	.454	.455	.455	.458	.454	.454	.455	.452	.455

Record min/max thicknesses three decimal places.
H. M. Newlin II 4-20-88

ANII INITIAL REVIEW:
SIGNATURE: _____ DATE: _____
ANII FINAL ACCEPTANCE:
SIGNATURE: *H. M. Newlin II* DATE: *4/21/88*

H. M. Newlin II



Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS
 Comp./Sys.: TORUS
 Loop: N/A

ULTRASONIC
 EXAMINATION
 CALIBRATION
 SHEET


Data Pkg.: 2433-88A-69 111
 Page 1 of 2
 Exam Item: GRID 270 DEGREE TOP
 Procedure: 80A2433
 Rev./F.C.: 3 / FC 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5 Range .5"
DEC/Gate	OFF Reject OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40 Fine 18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Brand	KB-AEROTECH
Frequency	5.0 mHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONT.
Couplant Batch	8764
Couplant Brand	ULTRAGEL II

Calibration Block	
Block Thickness	NMP-1SW-1020-GS
Block Thickness	.10-1.0"/1.1-2.0"
Comp. Thickness	N/A
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC		
Reflector	%FSH	Position
1 2"	80%	2
2 4"	65%	4
3 6"	55%	6
4 8"	40%	8
5 1"	30%	10
6 N/A	N/A	N/A

INSTRUMENT LINEARITY					
1	100	50	6	50	25
2	90	45	7	40	20
3	80	40	8	30	15
4	70	35	9	20	10
5	60	30			

AMPLITUDE LINEARITY			
80 - 6 =	40	80 - 12 =	20
40 + 6 =	80	20 + 12 =	80

CRT Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Meas. Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item | GRID 270 DEGREE TOP

Comments/Reasons for Incomplete Exams

GRIDS 270 DEGREE TOP

Remarks

CLEANED WITH DEMIN WATER & TSP

GRID SHEET PER CW GRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY C.B.I. SEE ATTACHED SHEETS.

Examiner 1: H. M. Hawkins
 HARRY M. HAWKINS LEVEL II

Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELER Exm-88-002

Examiner 2: N/A

Level: Date:

NES REVIEWER: Prisco

LEVEL: III DATE: 4/21/88

B 4/21/88
 FOR UMPC INFO.
 WELD ACCEPTABLE?
 YES NO

QA/QC

ANII

ANII INITIAL REVIEW:
 SIGNATURE _____ DATE _____

ANII FINAL ACCEPTANCE:
R. B. [Signature] 4/21/88
 SIGNATURE _____ DATE _____

NMPC ENG.
 DISP. REQ.
 YES NO

1105



11

12

13

14



15

16



1020

1020

270° TOP

	1	2	3	4	5	6	7	8	9	10	11	12
A	489	480	470	470	465	470	472	472	474	472	472	477
B	463	459	456	456	462	468	458	468	459	458	469	471
C	473	476	474	474	473	472	471	470	473	474	479	471
D	459	456	464	456	470	457	460	467	453	460	469	462
E	470	471	479	475	473	472	471	476	480	477	470	472
F	457	460	465	466	466	460	453	456	453	452	459	465
G	473	474	473	475	478	472	470	470	475	477	477	472
H	455	462	458	462	460	460	457	456	461	450	464	457
I	470	471	472	471	470	475	472	475	473	472	470	470
J	467	462	458	469	460	468	465	466	468	462	462	461
K	473	470	473	472	477	472	475	475	472	473	478	478
L	455	462	467	450	455	463	466	460	468	461	468	459
M	476	470	474	470	471	475	474	477	473	474	473	472
N	461	458	457	462	459	465	460	462	460	461	462	456
O	470	470	470	474	471	471	471	471	471	472	470	472
P	457	455	461	461	460	457	464	458	460	467	462	456
Q	471	471	471	469	470	474	470	470	472	470	471	471
R	457	458	450	457	467	458	462	456	462	453	455	452
S	470	471	476	474	470	470	470	472	470	475	470	470
T	469	460	461	457	458	458	457	459	451	455	458	457
U	470	471	472	470	472	470	470	472	472	477	470	470
V	457	460	452	457	453	463	454	459	457	452	454	460
W	470	471	472	472	471	470	470	471	470	473	471	471
X	458	458	460	460	458	458	460	460	453	454	460	463

Record min/max thicknesses three decimal places.

H. McHaulin II 4-20-88

Prinos III 4/21/88

ANII INITIAL REVIEW:	
SIGNATURE	DATE
ANII FINAL ACCEPTANCE:	
R. Blatchley	4/21/88
SIGNATURE	DATE

124

124

124

124

Plant/Unit: NINE MILE POINT UNIT ONE
 ISO: SEE ATTACHED SHEETS & DRWGS
 Comp./Sys.: TORUS
 Loop: N/A

ULTRASONIC
 EXAMINATIONS
 CALIBRATION
 SHEET


Data Pkg.: 2433-88A-70 113
 Page 1 of 7
 Exam Item: GRID 270 DEGREE BOTTOM
 Procedure: 80A2433
 Rev./F.C.: 3/EO 1
 Title: UT EXAM - STEAM EROSION

INSTRUMENT SETTINGS	
Serial #	1213220-4
MFG./Model #	KKB-USL-48
Sweep Length	6.50
Sweep Delay	6.00
Pulse Length/Damp.	OFF
Freq.	5 Range .5"
DEC/Gate	OFF Reject OFF
Jacks	R&T
Mode Select	DUAL
Coarse Gain	40 Fine 18
Scan Sens.	80% BR

SEARCH UNIT	
Serial #	A31357
Stand	KB-AEROTECH
Frequency	5.0 MHz
Size/Shape	.25" ROUND
Style/Type	GAMMA
Fixture	N/A
Cable	2X6' SELF CONF.
Couplant Batch	8764
Couplant Brand	ULTRAGEL II

Calibration Block	
Block Thickness	NMP-TSW-1020-03
Comp. Thickness	10-1.0"/1.1-2.0"
Block Temperature	63 °F
Comp. Temperature	62 °F
Thermometer	KB108
Surface	CD

Calibration Checks :Time	
Initial Calib.	1300
Intermediate	1600
Intermediate	1800
Intermediate	N/A
Final Calib.	2000
Calibration Date	4/20/88



DAC		
Reflector	%FSH	Position
1 2"	80%	2
2 4"	65%	4
3 6"	55%	6
4 8"	40%	8
5 1"	30%	10
6 N/A	N/A	N/A

INSTRUMENT LINEARITY			
1	100	50	6
2	90	45	7
3	80	40	8
4	70	35	9
5	60	30	

AMPLITUDE LINEARITY			
80 - 8 =	40	80 - 12 =	20
40 + 8 =	80	20 + 12 =	80

ORJ Calibrated In
 DEPTH OF METAL
 Each Major Screen Div. = 10"

Scan Angle	0 DEGREES
Mean Angle	0 DEGREES
Mode	LONG
Calibration	DEPTH
Scan Area	GRID

Exam Item: GRID 270 DEGREE BOTTOM

Comments/Reasons for Incomplete Exams
GRIDS 270 DEGREE BOTTOM

Remarks
CLEANED WITH DEION WATER & TSP
GRID SHEET PEROW CRANT NOT LIKE ACTUAL GRID THAT IS CONSTRUCTED BY ORJ
SEE ATTACHED SHEETS

Examiner 1: H.M. Hawkins Level: II Date: 4-20-88

WR# N/A
 NCR# N/A
 TRAVELER 213 m-88-002

Examiner 2: N/A Level: Date:

NES REVIEWER: Priano LEVEL: III DATE: 4/21/88

FOR NMPC INFO.
18 4/21/88
 WELD ACCEPTABLE?
 YES NO

QA/QC	ANII
	ANII INITIAL REVIEW: SIGNATURE _____ DATE _____ ANII FINAL ACCEPTANCE: <u>P. B. [Signature]</u> <u>4/21/88</u> SIGNATURE _____ DATE _____

1125

RU *

111
111

1111111111

11

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111

1111111111



INSTRUMENT SETTINGS	SEARCH UNIT	Calibration Block
Model: 320-4	Serial #: A01357	Block Thickness
	Brand: HOITECH	Comp. Lot #
	270 Bottom	Temp. Compensation

	1	2	3	4	5	6	7	8	9	10	11	12
A	.470	.472	.475	.476	.470	.473	.469	.469	.476	.471	.470	.471
B	.464	.455	.455	.457	.458	.457	.460	.457	.456	.452	.457	.455
C	.471	.473	.474	.471	.476	.472	.473	.472	.471	.476	.471	.473
D	.453	.457	.455	.457	.458	.458	.459	.458	.458	.458	.456	.458
E	.470	.470	.472	.472	.471	.473	.474	.471	.471	.470	.470	.470
F	.458	.458	.454	.458	.458	.458	.457	.457	.458	.458	.457	.456
G	.472	.472	.470	.472	.463	.470	.471	.470	.472	.472	.471	.470
H	.472	.470	.470	.470	.470	.470	.470	.470	.470	.470	.470	.470
I	.459	.458	.450	.451	.451	.450	.460	.458	.455	.455	.455	.460
J	.599	.573	.528	.539	.528	.551	.548	.579	.588	.595	.599	.599
K	.466	.465	.466	.464	.469	.466	.467	.463	.463	.460	.463	.463
L	.599	.573	.528	.539	.528	.551	.548	.579	.587	.592	.609	.599
M	.480	.470	.470	.480	.477	.480	.480	.480	.480	.480	.480	.480
N	.484	.483	.478	.485	.477	.486	.478	.473	.477	.477	.477	.477
O	.480	.482	.482	.484	.484	.484	.483	.482	.482	.482	.482	.482
P	.468	.468	.454	.456	.467	.467	.467	.455	.465	.465	.467	.466
Q	.476	.479	.472	.476	.477	.478	.477	.479	.474	.472	.478	.472
R	.466	.467	.467	.462	.467	.467	.467	.466	.465	.464	.458	.461
S	.476	.473	.471	.477	.480	.476	.474	.472	.471	.470	.478	.480
T	.467	.468	.466	.464	.468	.466	.467	.467	.465	.462	.461	.461
U	.473	.476	.480	.474	.477	.476	.475	.474	.472	.477	.472	.470
V	.465	.467	.468	.464	.465	.467	.467	.465	.465	.464	.462	.459

Record min/max thicknesses three decimal places.
 H.M. Naukin II 4-20-88

ANII INITIAL REVIEW:	
SIGNATURE	DATE
ANII FINAL ACCEPTANCE:	
R. B. [Signature]	4/21/88
SIGNATURE	DATE

[Signature] 4/21/88



1942



1942



Actual Measurements
for TORUS THICKNESS

SYSTEM: DUPRESTON CHAMBER
PROCEDURE: DOA 34

	A	B	C	D	E	F	G	H	I	J	K	L
GRID 1 OF 5												
1	.453	.447	.449	.450	.448	.449	.450	.458	.445	.449	.449	.450
3	.451	.449	.450	.450	.451	.453	.451	.455	.457	.450	.450	.450
5	.450	.451	.450	.451	.451	.450	.449	.449	.448	.449	.450	.451
7	.449	.450	.449	.451	.451	.449	.450	.450	.449	.449	.448	.449
9	.448	.449	.451	.448	.450	.451	.449	.449	.448	.450	.451	.450
11	.448	.450	.451	.449	.451	.450	.449	.450	.450	.449	.450	.452
GRID 2 OF 5												
1	.483	.456	.459	.453	.462	.454	.441	.458	.456	.453	.459	.459
3	.452	.456	.453	.453	.448	.457	.458	.452	.455	.459	.456	.461
5	.459	.452	.453	.458	.456	.458	.459	.461	.456	.461	.454	.460
7	.456	.451	.458	.454	.457	.456	.454	.454	.461	.456	.456	.462
9	.457	.454	.455	.455	.455	.457	.458	.458	.458	.456	.456	.458
11	.458	.465	.454	.458	.454	.454	.457	.457	.457	.461	.453	.460
GRID 3 OF 5												
2	.448	.450	.453	.453	.454	.454	.452	.452	.449	.447	.452	.454
4	.450	.453	.452	.450	.447	.450	.452	.448	.452	.452	.453	.456
6	.446	.452	.453	.450	.450	.454	.450	.457	.452	.452	.453	.451
8	.451	.449	.452	.452	.452	.453	.455	.453	.454	.452	.453	.453
10	.448	.448	.458	.454	.454	.453	.454	.454	.454	.453	.452	.454
12	.449	.449	.452	.456	.451	.456	.451	.454	.455	.454	.452	.456
INDEPENDANT MEASURMENT TAKEN 3" FROM PENETRATION XS-344												
READINGS TAKEN THROUGH PAINT												
	1	2	3	4	5	6	7	8	9			
A	.471	.469	.465	.469	.470	.473	.470	.464	.469			
B	.453	.469	.472	.473	.473	.467	.466	.466	.470			
	.467	.460	.464	.468	.469	.465	.466	.466	.461			



ATTACHMENT E

Niagara Mohawk Calculation M79-81-M001

Core Spray Pumps -
Effects Of Torus Sludge On



NUCLEAR ENGINEERING & LICENSING

DISCIPLINE: NUCLEAR PROJECTS

PROJECT: NINE MILE POINT NUC. STA. - UNIT 1 CALC. NO. M79-81-17001
 SUBJECT: CORE SPRAY PUMPS - EFFECT OF TORUS SLUDGE ON SYSTEM #91
 BUILDING: REACTOR FLOOR ELEV.: 198'-0" INDEX NO.: 3-N2.1-1774
 ORIGINATOR(S): L. M. McNEER TOTAL SHT'S. 6
 CHECKER(S): P. P. ADAMINI, A. SMITH LAST SHT. NO.: 6

RECORD OF ISSUES

REV	DESCRIPTION	M.O.#	BY	DATE	CHKD.	DATE	APPD.	DATE	DATE FILMED
0	INITIAL ISSUE	1023	LMM	5/17/80	PB	5/20/80	C. J. K.	5/22/80	

COMPUTER OUTPUT YES NO

SAFETY RELATED YES NO

DRAWINGS REFERENCED:

DWG. NO.	INDEX	SHT.	REV.
C-18364-C	3-N2-S14	—	16
C4237R2 (ANDALE Co.)	—	—	2

REFERENCES:

1. WATER QUALITY AND CORROSION CONTROL OF THE SUPPRESSION POOL AT NINE MILE POINT-1 3/20/80; RCT-8001
2. NINE MILE POINT-1 SUPPRESSION POOL PILOT-SCALE CLEAN-UP TESTS 4/81; OCT-8111

KEYWORDS: NMP 1

DISCIPLINE: NUCLEAR PROJECTS
 SAFETY CLASS: NON-SAFETY
 PURPOSE: TORUS SLUDGE CORE SPRAY

CROSS REF.:



PROJECT: NINE MILE POINT NUC. STA.-UNIT 1

CALC. NO. M79-87-M001 REV. 0

SUBJECT: CORE SPRAY PUMPS-EFFECT OF TORUS SLUDGE ON

ORIG. J.M.M. KERN DATE: 5/19/88

INDEX: 3-N2.1-M79

System #81

CHK'D. P. BARTOLINI DATE: 5/20/88

THIS CALC. ADDRESSES AN NRC CONCERN REGARDING THE EFFECT OF THE IRON OXIDE (SLUDGE), IN THE TORUS, ON ECCS PUMPS IF STIRRED UP BY A LOCA.

ASSUMPTIONS:

1. 100% OF THE SLUDGE BECOMES ^{UNIFORMLY STIRRED OR} SUSPENDED UPON A LOCA AND AVAILABLE FOR SECTION INTO THE CORE SPRAY LINES AND PUMPS.
2. THE SLUDGE IS THAT PROJECTED TO BE PRODUCED AS A RESULT OF OXIDATION OF ALL UNDER WATER SURFACES (20,000 ft²*) SINCE 1979 (LAST DEDUING OF TORUS) TO 1990, OR 11 YRS. (1), (2).
3. CORROSION/ OXIDATION RATE OF UNDER WATER SURFACES IS 2 MILS (0.002") PER YR. - SEE ATTACHED GRAPH
4. ALL SLUDGE IS Fe₂O₃
5. THE TOTAL VOLUME OF WATER IN THE TORUS IS 500,000 GAL. (1).
6. THERE WILL BE NO CHUNKS OR PIECES LARGE ENOUGH TO PLUG THE STRAINERS OR NOZZLES (1)(2).
- THIS WAS VERIFIED THRU TELECON WITH ROGER ASSAY, RCT - ALSO SEE ATTACHED DRGS.

* ASSUMES TORUS IS HALF FILLED WITH WATER



PROJECT: NINE MILE POINT NUC. STA. - UNIT 1

CALC. NO. N70-81-Med1 REV. 0

SUBJECT: COKE SPRAY PUMPS - EFFECT OF TROSS SIZES

ORIG. L.M. McVey DATE: 5/19/88

INDEX: 3-N2.1-M77

SYSTEM #81

CHK'D. P. BARTOLINI DATE: 5/20/88

CALC. OF TOTAL AMOUNT OF IRON (FE) IN SLUDGE:

$$\frac{20,000 \text{ ft}^2 \times 0.002 \text{ in/yr.} \times 11 \text{ yr.} \times 0.26 \text{ lb/in}^3 \times 1728 \text{ in}^3/\text{ft}^3}{12 \text{ in/ft.}} = 16,474 \text{ lb.}$$

CALC. OF TOTAL AMOUNT OF SLUDGE (FE₂O₃):

$$\frac{2(58^*) + 3(18^{**})}{2(58^*)} = 1.465$$

$$1.465 \times 16,474 \text{ lb. FE} = 24,143 \text{ lb. FE}_2\text{O}_3 \text{ (SLUDGE)}$$

CALC. OF SP. GR. OF SLURRY (SLUDGE + H₂O)

$$\frac{500,000 \text{ gal.} \times 8.347 \text{ lb/gal.} + 24,143 \text{ lb. FE}_2\text{O}_3}{500,000 \text{ gal.} \times 8.347 \text{ lb/gal.}} = \boxed{1.0058}$$

* ATOMIC WT. OF FE = 58

** ATOMIC WT. OF O = 18



NUCLEAR ENGINEERING & LICENCING

DISCIPLINE MECH


PROJECT: NINE MILE POINT NUC. STA. - UNIT 1 CALC. NO. M79-81-MOD REV. 0
 SUBJECT: EFFECT OF TORUS SLUDGE ON CORE SPRAY PUMPS ORIG. P. BARTOLINI DATE: 5/20/88
 INDEX: 3-N2.1-M79 SYSTEM # 81 CHK'D. G.K. Smith DATE: 5/23/88

Purpose: THE PURPOSE OF THIS SECTION IS TO DETERMINE HOW THE CORE SPRAY PUMPS & TOPPING PUMPS WILL RESPOND TO THE INCREASE IN TORUS WATER SPECIFIC GRAVITY.

GIVEN: BOTH THE CORE SPRAYS PUMPS & THE CORE SPRAY TOPPING PUMPS ARE CENTRIFUGAL TYPE PUMPS. THE CORE SPRAY PUMPS ARE RATED FOR 3400 GPM @ 422 FEET, THE CORE SPRAY TOPPING PUMPS ARE RATED FOR 3600 GPM @ 275 FEET. THE COMBINED PUMP PERFORMANCE FOR ONE SET OF CORE SPRAY PUMPS WITH TOPPING PUMPS IS 3400 GPM @ 697 FEET

ANALYSIS: THE HEAD (IN FEET) DEVELOPED BY A CENTRIFUGAL PUMP IS INDEPENDENT OF SPECIFIC GRAVITY. PUMP CAPACITY (FLOW) IS ALSO INDEPENDENT OF SPECIFIC GRAVITY. THEREFORE HEAD & CAPACITY MAY BE READ DIRECTLY FROM THE PUMP CURVE WITHOUT CORRECTION AS LONG AS THE VISCOSITY IS APPROXIMATELY CONSTANT (THE SLUDGE IN THE TORUS WATER WILL NOT IMPACT TORUS WATER VISCOSITY).

THE WORK PERFORMED IN MOVING A LIQUID DEPENDS ON THE WEIGHT OF THE LIQUID BEING HANDLED, AS DOES THE DISCHARGE PRESSURE FROM THE PUMP.



PROJECT: NINE MILE POINT NUC. STA. - UNIT 1

CALC. NO. MT9-81-M00REV. 6

SUBJECT: EFFECT OF TORUS SLUDGE ON CORE SPRAY PUMPS

ORIG. P. BARTOLINI DATE 5/20/88

INDEX: 3-N2.1-MT9 SYSTEM #81

CHK'D. G. K. ... DATE 5/23/88

ANALYSIS (CONT'D)

BASED ON A TORUS WATER SPECIFIC GRAVITY OF 1.0058 THE PUMP DISCHARGE PRESSURE WILL BE:

CORE SPRAY PUMP

$$\text{Pressure in psi} = \frac{(422 \text{ ft}) (1.0058)}{2.31 \text{ ft/psi}} = 183.74 \text{ psi}$$

THIS REPRESENTS AN INCREASE OF 1.06 psi

CORE SPRAY TOPPING PUMP

$$\text{Pressure in psi} = \frac{(275) (1.0058)}{2.31} = 119.74 \text{ psi}$$

THIS REPRESENTS AN INCREASE OF 0.7 psi

∴ TOTAL INCREASE IN DISCHARGE PRESSURE = 1.76 psi WHICH IS NEGLECTIBLE

THE INCREASE IN TORUS WATER SPECIFIC GRAVITY WILL ALSO AFFECT THE WATER HORSEPOWER ON EACH PUMP. THE INCREASE IN WHP IS DIRECT. THEREFORE THE INCREASE IN EACH PUMP WILL BE 0.58% WHICH AGAIN IS NEGLECTIBLE.

BASED ON THE ABOVE THE CHANGE IN TORUS WATER SPECIFIC GRAVITY WILL HAVE LITTLE TO NO AFFECT ON CORE SPRAY OPERATION.



1/2

