

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8910060064 DOC. DATE: 89/09/29 NOTARIZED: NO DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220  
 AUTH. NAME AUTHORITY AFFILIATION  
 TERRY, C.D. Niagara Mohawk Power Corp. *566 RJD*  
 RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards addl info re simulator certification for facility,  
 per 890803 request.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 150  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-1 LA		1	<del>10</del>	PD1-1 PD		1	1	
	SLOSSON, M		5	<del>51</del>					
INTERNAL:	ACRS		6	<del>61</del>	NRR/DEST/ADS 7E		1	1	
	NRR/DEST/ESB 8D		1	1	NRR/DEST/ICSB		1	1	
	NRR/DEST/MTB 9H		1	1	NRR/DEST/RSB 8E		1	1	
	NRR/DOEA/TSB 11		1	1	NUDOCS-ABSTRACT		1	1	
	OC/LFMB		1	0	OGC/HDS1		1	0	
	<u>REG FILE 01</u>		1	1	RES/DSIR/EIB		1	1	
EXTERNAL:	LPDR		1	1	NRC PDR		1	1	
	NSIC		1	1					

LIMITED DISTRIBUTION OF ENCLOSURES DUE TO SIZE

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25

14

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

1954

1954

September 29, 1989  
NMP1L 0440

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555


Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Gentlemen:

This letter is in reply to your letter dated August 3, 1989 regarding Simulator Certification for Nine Mile Point Unit 1. Enclosure A includes answers to your questions and additional documents that you requested. On September 6, 1989, Ms. M.M. Slosson of your staff verbally granted a schedule extension until September 30, 1989.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

  
C. D. Terry  
Vice President  
Nuclear Engineering and Licensing

MS/mjd  
7830G

xc: Regional Administrator, Region I  
Mr. R. A. Capra, Director  
Ms. M. M. Slosson, Project Manager  
Mr. W. A. Cook, Resident Inspector  
Records Management

8910060064 890929  
PDR ADOCK 05000220  
P PIC

*Food*

ENCLOSURE A

Simulator Certification - Unit 1  
Response to Questions  
September 1989

.8910060064

NIAGARA MOHAWK POWER CORPORATION  
Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63



1944

NIAGARA MOHAWK POWER CORPORATION  
RESPONSE TO NRC QUESTIONS ON UNIT 1  
SIMULATOR CERTIFICATION

Question 1:

On Form 474 you indicate that "Simulation Facility Performance Test Abstracts (are) attached." However, Attachment 1, "Performance Testing", is only a list of tests performed. Please provide the abstracts for these tests. These abstracts should include the following:

1. Date test was conducted.
2. Name and description of test (including relationship to Section 3.1.2, "Plant Malfunctions", of the Standard, if applicable).
3. Available options (e.g., range of rates or severity of which the simulation facility is capable).
4. Tested options (i.e., what was actually tested for certification).
5. Initial conditions (for each tested option).
6. Final conditions (for each tested option).
7. Descriptions of baseline data used to determine fidelity to the reference plant.
8. Deficiencies found as a result of the test, corrective action planned and dates by which corrections will be made.
9. Exceptions taken to ANSI/ANS-3.5-1985 as a result of the test, with justification.

If the baseline data used was the judgment of a panel of experts, then documentation of their review, sufficient for a third party to evaluate the adequacy of the test(s) and results, should be included. This documentation may include such items as the make-up and qualifications of the panel and any differing professional opinions as to the outcome of the test(s).

Response 1:

Enclosed are copies of the ANSI/ANS 3.5 Annual Reports for 1986 (initial), 1987 and 1988. The baseline data did not involve the judgement of a panel of experts. Also enclosed is the 1989 ANSI/ANS 3.5 Test Procedures (Test Methodology and Performance Tests). The detailed response is as follows:

- 1.1 Factory acceptance test - March 1984 to May 1984.  
On-site final acceptance test - August 1984 to September 1984.  
Initial ANSI 3.5 1986 test - March 1986.  
ANSI 3.5 1987 test - May 1987.  
ANSI 3.5 1988 test - May 1988.

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second section of faint, illegible text in the middle of the page.

Third section of faint, illegible text, appearing to be a list or series of entries.

1.2 Tests are described in the following sections:

ANSI 3.5 1986, 1987, and 1988 Annual Reports, Section III.  
ANSI 3.5 1986 Attachment 3 (lists the malfunction names).

1.3 The available options/malfunctions are listed in ANSI 3.5 1986 Annual Report, Attachment 3. Each malfunction has a specific cause and effect (refer to sample malfunction cause and effect ED09 enclosed). A complete copy of the malfunction cause and effect book will be supplied upon request.

1.4 Tested options are described in the ANSI 3.5 1986 Annual Report. All options/malfunctions (listed in Attachment 3) and other tests (listed in Section III) were tested for certification.

1.5 Each tested option/malfunction has a specific test procedure similar to the test procedure for malfunction ED09 enclosed. The complete malfunction test procedures occupies three books (two inch binders) which are available for your review on-site.

1.6 This response is the same as 1.5.

1.7 The baseline data was the simulator design data base which contained the following:

- a. Reference plant controlled drawings (PID, Electrical, etc.).
- b. Reference plant FSAR.
- c. Selected GEK's.
- d. Reference plant panel photographs.
- e. Referent plant BOP logs.
- f. Reference plant P-1 edits and other OD printouts.
- g. Reference plant Operating Procedures.

1.8 All deficiencies identified during the applicable tests were recorded and corrected. No Discrepancy Reports remain open from the original 474 submittal test procedures.

1.9 Exceptions are described in the following sections:

- a. ANSI 3.5 1986 Annual Report, Section I.B.
- b. ANSI 3.5 1987 Annual Report, Section I.B.
- c. ANSI 3.5 1988 Annual Report, Section I.B.





Question 2:

You have also indicated on Form 474 that a Simulation Facility Performance Testing Schedule (is) attached. However, Attachment 2, "Malfunction Testing", appears to be only a list of 4-character malfunction designators, which are intended to indicate which malfunctions will be tested in each year. Please provide a schedule which more fully describes these tests.

Response 2:

ANSI/ANS 3.5 1986 Annual Report, Attachment 3, provides a word description for each malfunction. They are tested using the original factory acceptance test and the malfunction cause and effect for that malfunction. A sample copy of malfunction ED09 (AC Power Board Electrical Fault - PB13, Section A) factory acceptance test and malfunction cause and effect is enclosed. Additional malfunction test procedures will be supplied upon request. All malfunctions have been tested during the past four year period. Malfunction CU05 was missed in 1987 and subsequently tested in 1989.

Question 3:

In Attachment 1, Item III indicates that an initial ANSI 3.5 test report was prepared. It would be helpful if you could provide this report as it may provide some of the information requested in Item 1 of this enclosure.

Response 3:

Enclosed please find the ANSI 3.5 Annual Reports for 1986 (initial), 1987, and 1988. Included, also, is the 1989 ANSI 3.5 Test Procedures.

Question 4:

Items III.3 and III.4 of Attachment 1 state that simulator performance was compared against the FSAR. ANSI/ANS-3.5-1985 states in Appendix A, Section A.3.3(2) that FSAR transients may be inappropriate for real-time dynamic simulation comparisons. Please provide justification for making such comparisons.

Response 4:

The use of Nine Mile Point Unit 1 FSAR for transient response was the only transient data available to the testers, during initial construction. This issue was recognized by Niagara Mohawk in January 1989. The 1989 ANSI transient test results are being compared to General Electric transient data NED024708A Rev. 1 (December 1980). The 1989 ANSI Test Report will include the results of this analysis. Preliminary results indicate that the simulator response complies with ANSI 3.5 requirements.



Question 5:

ANSI/ANS 3.5-1985, Section 5.4.1, "Simulator Performance Testing", requires testing within the requirements of Section 4 (Performance Criteria). One of the criteria in Section 4 is that "administrative controls or other means shall be provided to alert the instructor when certain parameters approach values indicative of events beyond the implemented model or known plant behavior." It appears that no testing was performed to ensure that this criterion was met. Performance test abstracts for such testing, or justification for exception to this requirement, should be provided.

Response 5:


Review of the Factory acceptance, on-site final acceptance, and annual ANSI 3.5 testing shows no evidence of such testing. The simulator does have a light indication to warn the instructor when the operating limits are exceeded in accordance with ANSI/ANS 3.5 Section 4.3. A special test procedure is being written, will be conducted, and the resulting data included with the 1989 ANSI 3.5 test data, which is presently scheduled for December 1989.



UNIT 1 SIMULATOR  
1989 ANSI/ANS 3.5 TEST PROCEDURES

Submitted  8/29/89  
Gary E. Corbin  
Supervisor Simulator Technology Date

Reviewed  8/29/89  
R. T. Seifried  
Assistant Superintendent Training Date

Approved  8/29/89  
A. D. Rivers  
Superintendent Training - Nuclear Date



## UNIT - 1 SIMULATOR ANSI 3.5 TEST METHODOLOGY

### I. Assemble Test Package Sections:

A. Computer Real Time Test

B. Appendix "B" Steady State Tests:

1. 25% Steady State
2. 50% Steady State
3. 75% Steady State
4. 100% Steady State
5. 100% Steady State 60 minute run

NOTE: The following data is required for each test run (critical data)

- a. Neutron flux
- b. Core thermal power
- c. Individual Recirculation loop flows
- d. Total core flow
- e. Reactor dome pressure
- f. Reactor water level (narrow range)
- g. Total steam flow
- h. Total feedwater flow
- i. Feedwater temperature (after last stage of feedwater heaters)
- j. Control Rod Drive System
  - 1) flow
  - 2) temperature
- k. Reactor Water Cleanup System
  - 1) inlet flow
  - 2) return flow
  - 3) return temperature
- l. Main Generator gross electrical watts
- m. Drywell
  - 1) temperature
  - 2) pressure





n. Secondary plant heat balance data

NOTE: Performance Criteria -

- a. Simulator instrument error shall be NO greater than that of the related instrument in the Reference plant
- b. Principal mass and energy balances shall be satisfied:
  - 1) Net NSSS thermal power to generated electrical power
  - 2) Feedwater flow to reactor thermal power
- c. Simulator computed values for steady state, full power reference plant configuration operation, shall be stable and not vary more than  $\pm 2\%$  of the initial values over a 60 minute period
- d. Simulator computed values of critical parameters shall agree within  $\pm 2\%$  of the reference plant parameter at the specified power level

C. Appendix "B" Transient tests:

(Section B1.2.1)

1. Manual scram
2. Simultaneous trip of all feedwater pumps
3. Simultaneous closure of all Main Steam Isolation Valves
4. Main turbine trip (from max power WITHOUT immediate Rx. Scram)
5. Maximum rate power ramp (100% - 75% - 100%)

NOTE: Recirc Flow Control in Master Manual

Test parameters recorded vs. time with a resolution  $\leq 0.5$  seconds

- a. Reactor power (% neutron flux)
- b. Total steam flow
- c. Total feedwater flow
- d. Wide range reactor pressure
- e. Narrow range reactor pressure
- f. Wide range reactor water level
- g. Narrow range reactor water level (feedwater control)
- h. Generator gross electrical power
- i. Turbine steam flow
- j. Total core flow (total recirc flow)



6. Simultaneous trip of all recirculation pumps
7. Single recirculation pump trip

Test parameters recorded vs. time with a resolution  $\leq 0.5$  seconds

- a. Reactor power (% neutron flux)
  - b. Total steam flow
  - c. Total feedwater flow
  - d. Narrow range reactor pressure
  - e. Narrow range reactor water level (feedwater control)
  - f. Total core flow (no accurate indication with less than 5 loops)
  - g. Individual recirculation loop flows
8. Maximum size reactor coolant system rupture combined with loss of all offsite power
  9. Maximum size unisolable main steam line rupture
  10. Simultaneous closure of all Main Steam Isolation Valves combined with single stuck open safety/relief valve

Test parameters recorded vs. time with a resolution  $\leq 0.5$  seconds

- a. Reactor power (% neutron flux)
- b. Wide range pressure
- c. Wide range water level
- d. Fuel zone water level
- e. Total steam flow
- f. total feedwater flow/high pressure coolant injection flow
- g. Torus water temperature
- h. Torus air temperature
- i. Torus pressure
- j. Drywell temperature
- k. Drywell pressure
- l. Total low pressure core spray flow

NOTE: Transient test Performance Criteria:

- 1) Be the same as reference plant startup test criteria where applicable.



- 2) The observable change in the monitored parameters correspond in direction to those expected from a best estimate analysis for the simulated transient and do not violate the physical laws of nature. Reference Document NEDO24708A Rev. 1 8/79 for transient data.
- 3) Not fail to cause an alarm or automatic action if the reference plant would have and not cause an alarm or automatic action if the reference plant would not have.

D. Malfunction Tests

(meets requirements of ANSI A3.5 and Regulatory Guide 1.149)

1. ADO4 Relief Valve Leaks
2. CS01 Core Spray Pump Trip
3. CT02 Containment Spray RAW Water Pump Trip
4. CU03 RWCU Reject FCV Fails Open
5. CU07 RWCU Low Pressure Control Valve Fails Open
6. CU11 Coolant Leak Outside Primary Containment
7. CW04 RBCLC Pump Trip
8. CW08 Circulating Water Intake Structure Icing
9. DGO2 Diesel Generator Trip
10. ECO4 Emergency Cooling System Return Valve Fails Open
11. ED01 Loss of Offsite 115KV Power
12. ED05 PB12 Electrical Fault
13. ED09 PB13 Section "A" Electrical Fault
14. ED13 PB14 Section "B" Electrical Fault
15. ED17 PB15 Section "C" Electrical Fault
16. ED21 PB17 Section "B" Electrical Fault
17. ED25 Loss of Power to Instrument Control Bus 130 Normal and Alt
18. EG04 Main Generator Core Internal Heating
19. EG08 Generator Hydrogen Emergency Seal Oil Pump Failure
20. EG12 Power Grid Network Load Transient - Decrease
21. FP02 Electric Fire Pump Failure
22. FP06 Control Room Fire Detection - Various Panels
23. FP10 Reactor Building Fire Detection
24. FW04 Shaft Driven Feedwater Pump 13 Failure
25. FW08 Feedwater Control Valve 11 Controller Fails - Low
26. FW12 Feedwater Control Valve 13 Controller Fails - Low



D. Malfunction Tests (Cont'd)

27. FW16 Feedwater Master Controller Fails as is
28. FW20 Condensate Recirc Valve (FCV 50-24) Fails Closed
29. FW24 Feedwater Control Valve Fails Closed (13A/13B)
30. FW28 HPCI Mode Failure to Initiate
31. IA01 Loss of Instrument Air
32. MC03 Hotwell Level Controllers in Auto Fail - High
33. MS01 Steam Line Rupture Outside Primary Containment
34. MS05 Turbine Steam Seal Regulator Fails Closed
35. MS09 Second State Reheater 112 Drain Tk Level Control Fail Low
36. NM02 SRM Channel Failure - Downscale
37. NM10 IRM Channel Failure - Upscale
38. NM18 IRM Channel Detector Stuck
39. NM25 LPRM Failure - Upscale
40. NM36 Recirc Flow Converter Channel Failure - Upscale
41. NM40 Recirc Flow Converter Failure - Comparator
42. OG04 Off Gas Discharge to Stack Isolation Valve Fails Closed
43. PP01 Failure of Plant Process Computer
44. RD04 Control Rod Failure - Stuck
45. RD08 Control Rod Failure - RPIS
46. RD36 CRD Flow Control Valve Failure - Closed
47. RD40 Reactor Manual Control System Timer Malfunction - Settle
48. RM03 Area Radiation Monitor Drawer Upscale
49. RP04 Reactor Protection System Failure to Scram - Automatic
50. RP08 Anticipated Transient Without Scram (ATWS)
51. RR04 Recirculation Pump 11 Control Signal Failure
52. RR08 Recirculation Pump 12 Seizure
53. RR12 Recirc Pump 13 Field Breaker Trip
54. RR15 Recirc pump 14 Drive Breaker Trip
55. RR20 Recirc Pump 14 Incomplete Start Sequence
56. RR24 Recirc Pump 15 Control Signal Failure
57. RR27 Master Recirc Flow Controller Failure - Low
58. RR31 Reactor Vessel Pressure Recorder Failure - Low
59. RR35 Reactor Vessel Pressure Indicator Failure - Upscale
60. RR39 Reactor Vessel Level Recorder Failure - Downscale





61. RR43 Rx Vessel Level Indication (Control Sys) Fail - as is
62. RR47 Recirc Pump Discharge Valve Stem Separates From Gate
63. RR51 Rx Vessel Level Transmitter (RPS Input) Fails - High
64. RR55 Rx Vessel Level Transmitter (Control Input) Fails - Low
65. RR59 Rx Vessel Pressure Transmitter (RPS Input) Fails as is
66. RR63 Reactor Recirc Pump 12 Inner Seal Failure
67. RR67 Reactor Recirc Pump 15 Tachometer Fails - Oscillates
68. RR71 Reactor Safety Valve Inadvertently Opens
69. RX02 Increased Rod Worth
70. TC02 Turbine Governor Fails - High
71. TC06 Electrical Pressure Regulator Fails - Oscillates
72. TC10 First Bypass Valve Sticks Open
73. TU01 Exhaust Hood Spray Valve Fails Closed
74. TU05 Main Turbine Bearing High Temperature

NOTE: Performance Criteria -

- a. Be the same as reference plant startup test criteria where applicable
  - b. The observable change in the monitored parameters correspond in direction to those expected from a best estimate analysis for the simulated transient and do not violate the physical laws of nature.
  - c. Not fail to cause an alarm or automatic action if the reference plant would have and not cause an alarm or automatic action if the reference plant would not have.
  - d. Respond in accordance with the malfunction cause and effect
- E. Appendix "A" Section A3.2 Steady State and Normal Operations

NOTE: Using controlled operating procedures conduct all evolutions listed in ANSI 3.5 Section 3.1.1.

1. Plant start-up to Hot Standby, Operation at Hot Standby, and Start-up from Hot Standby to Rated Power including Turbine and Generator Start-up and Load Changes [meets requirements of Section 3.1.1 (1), (2), (3), (5) and (6)]
  - a. Master Start-up Checkoff Form III
  - b. Master Systems Pre-Start-up Checkoff List Form IV
  - c. Plant Start-up N1-OP-43 Sections "E" and "H.2.1"



2. Plant Shutdown to Hot Standby, and cooldown to Cold Shutdown Conditions (meets requirements of Section 3.1.1 (8)
    - a. Plant Shutdown N1-OP-43, Section "G"
    - b. Reactor Hot Standby N1-OP-43, Section "H.2.2.2"
  3. Reactor trip followed by three (3) Recirc Loop Reactor startup to 90% power, Start-up of idle Recirc Loops, continuation to Rated Power, Shutdown of Recirc Pump at power, and Shutdown and Cooldown to Cold Shutdown Condition (meets requirements of 3.1.1 (4), and (7)
    - a. Special Operating Procedure No. 1 "Reactor Scram"
    - b. Short Pre-Start-up Check-Off-Systems Form I
    - c. Plant Start-up N1-OP-43, Section "E"
    - d. Plant Shutdown N1-OP-43, Section "G"
    - e. Nuclear Steam Supply System N1-OP-1, Section "H.1, H.2 and H.3"
  4. Surveillance test procedures (using Control Room installed instrumentation) [meets requirements of Section 3.1.1 (9) and (10)]. As designated by the Simulator Configuration Control Board"
- F. Appendix "A" Section A3.3 Transients
1. LER's with reference plant data, as selected by the Simulator Configuration Control Board



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: ANSI 3.5 Appendix "A" Section A3.2 Steady State and Normal  
Operation Test

I. Initial conditions: As specified in each individual test section

II. Data Collection:

A. Method:

1. Data for the 100% steady state 60 minute run will be gathered on the critical parameters using a Simulator program called "ANSI SS60"
  - a. Data is gathered at 30 second intervals, and collected for the 60 minute period
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Data for the Normal operating and 25%, 50%, 75% 100% steady state operation tests will be gathered on the critical parameters using the Process Plant Computer (PPC) on demand BOP log, P-1 and OD-3 edits and procedure checkoff forms as specified.

B. Critical Parameters:

Computer Point

- |   |      |
|---|------|
| 1. Neutron Flux (%)   | H441 |
| 2. Core Thermal Power   | C875 |
| 3. Total Core Flow (Total Recirc Flow)                              | A445 |
| 4. Reactor Dome Pressure  | D372 |
| 5. Reactor Water Level (Narrow Range)                               | D377 |
| 6. Total Steam Flow   | D376 |
| 7. Total Feedwater Flow   | A391 |
| 8. Feedwater temperature<br>(after last stage of feedwater heaters) | A390 |
| 9. Control Rod Drive System   |      |
| a. Flow   | C328 |
| b. Temperature  | D417 |

ANSI 3.5 A3.2 NORMAL OP TEST -1



- 10. Reactor Water Cleanup System
  - a. Inlet Flow F361
  - b. Return Flow
  - c. Return Temperature F360
- 11. Main Generator Gross Electrical Watts F414
- 12. Drywell
  - a. Temperature D322
  - b. Pressure D320
- 13. Secondary Plant Heat Balance Data (OD-3 and BOP Log)

C. Supplemental Data:

- 1. None

III. Prerequisites

- A. All participants read applicable test sections and fill out section VIII.a (performed by)

IV. Procedure: (individual test sections)

- A. Plant start-up to Hot Standby, Operation at Hot Standby, and Start-up from Hot Standby to Rate Power including Turbine and Generator Start-up and Load Changes

Using controlled procedures attached perform the following and initial procedures where applicable

- 1. Initial conditions - Cold Shutdown with normal reference plant equipment lineup
- 2. Complete Master Start-up Checkoff Form III
- 3. Complete Master Systems per-start-up Checkoff List Form IV
- 4. Perform a Plant Start-up to Hot Standby and maintain Hot Standby conditions in accordance with (IAW) NI-OP-43 Sections "E" and "H.2.1"
- 5. Continue Start-up to rated power IAW NI-OP-43, Section "E"
  - a. Hold power steady at 25%, 50%, 75% and 100%; gather critical data IAW Section II.A.2

NOTE: Verify AGAF's within technical specification limits





6. Test Section Acceptance

a. The simulator plant start-up accomplished IAW reference plant controlled operating procedures, any procedure exceptions documented IAW NTI-4.5.3

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

b. The simulator steady state parameters meet performance criteria of Section V.A, V.B, and V.C

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. Plant Shutdown to Hot Standby, and Cooldown to Cold S/D Conditions

Using controlled procedures attached perform the following and initial procedures where applicable.

1. Initial conditions - rated power steady state with normal reference plant equipment lineup

2. Perform a plant shutdown to Hot Standby IAW NI-OP-43, Section "G" and "H.2.2.2"

3. Continue plant cooldown to cold shutdown IAW NI-OP-43, Section "G"

4. Test section acceptance

a. The simulator plant shutdown accomplished in accordance with (IAW) reference plant controlled operating procedures, any procedure exceptions documented IAW NTI-4.5.3.

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date



C. Reactor trip followed by recover to rated power; Startup, Shutdown and power operation with less than full reactor coolant flow -

Using controlled procedures attached perform the following and initial procedures where applicable

1. Initial conditions - Rated power steady state with normal reference plant equipment lineup
2. Manually scram the Reactor and perform Special Operating Procedure No. 1 "Reactor Scram"
3. Perform Short Pre-Start-up Check-Off-Systems Form I
4. Shutdown Recirc Pumps 12 and 14 IAW N1-OP-1, leaving 3 recirc loops in operation for Reactor startup
5. Perform a Reactor start-up to maximum attainable with 3 loop configuration IAW N1-OP-43, Section "E"
6. Startup idle Recirc Loops IAW N1-OP-1, Section "H.1.0"
7. Continue power ascension to rated
9. Reduce power to the maximum attainable in 3 loop configuration (Step IV.C.5) and shutdown recirc Pumps 11 and 15 IAW N1-OP-1, Section "H.2.0"
11. Perform a Reactor shutdown to all control rods inserted to position 00 IAW N1-OP-43, Section "G"
12. Test section acceptance
  - a. All manipulations in test Section "III.C" accomplished in accordance with (IAW) reference plant controlled operating procedures, any procedure exceptions documented IAW NTI-4.5.3

_____/_____	Satisfactory	_____/_____	Unsatisfactory
Initial/Date		Initial/Date	

D. 100% steady state 60 minute run performance test

1. Initial conditions: Full power steady state, Equilibrium Xenon at 100% ± 1%, Middle of cycle, with normal reference plant equipment lineup

NOTE: Use fast time  $X_e$  and snap shot a test IC if necessary to establish initial conditions



2. Reset to test condition IC, DO NOT TAKE OUT OF FREEZE
3. Activate data gathering program ANSI DATA COLLECTION option - 4
4. Un-freeze the Simulator and allow it to run
5. At problem time 61:00 minutes freeze the simulator
6. Download the collected data to a PC and graph the information
7. Evaluate the critical parameter graphs or raw data for acceptance in accordance with performance criteria section V.D.

\_\_\_\_\_ / \_\_\_\_\_ Satisfactory \_\_\_\_\_ / \_\_\_\_\_ Unsatisfactory  
 Initial/Date Initial/Date

E. Surveillance Tests -

Using controlled procedures attached perform the following listed surveillance tests. Initial and sign test procedures where applicable.

NOTE: Use only installed Control Room indications

1. N1-ST-C2, Manual Opening of Solenoid Actuated Pressure Relief Valves and Flow Verification
2. N1-ST-C1, Auto Startup of High Press Cool Injec Sys
3. N1-ST-C5, Secondary Containment and Reactor Building Emergency Ventilation System Operability
4. N1-ST-C7, Automatic Securing and Isolation of the Mechanical Vacuum Pumps
5. N1-ST-C8, Automatic Initiation of Off-Gas Isolation Valve
6. N1-ST-C14, Alternate Control Rod Insertion/Back-up Scram Valve/Scram
7. N1-ST-D0, Daily Checks
8. N1-ST-IC1, Liq POI Pump Inoper Comp Oper Test
9. N1-ST-IC2, Emer Cool Surv With an Inoper Sys Test
10. N1-ST-IC3, Core Spr Redundant Comp or Sys Oper Test
11. N1-ST-IC4, Control Rod Dr Pump Surv W/Inoper Comp Test
12. N1-ST-IC5, High Pressure Coolant Injection Surveillance with Inoperable Component Test
13. N1-ST-IC7, Emer Vent Sys Surv with an Inoper Branch
14. N1-ST-IC9, Emer Diesel Gen Inoper Comp Oper Test



15. N1-ST-M1, Liquid Poison System Pump & Valve Operability Test
16. N1-ST-M2, Emers Cool Sys Makeup Tanks Lvl Control Vlvs Exer
17. N1-ST-M3, Supp Pool Drywell Relief Vlvs Exer
18. N1-ST-M4, Emergency Diesel Generators Manual Start & 1 Hr Rated Load Test Power Board 102 & 103 Undervoltage Relay Test
19. N1-ST-M6, Core Spray Keep Fill System
20. N1-ST-M8, Emer Vent Sys Oper Test
21. N1-ST-M10, Scram Discharge Volume Vent & Drain Valve Position Verification
22. N1-ST-Q1, Core Spray Pumps Valves Operability Test
23. N1-ST-Q2, Control Rod Drive Pumps Flow Rate Test
24. N1-ST-Q3, High Press Cool Injec Pump and Valve Oper Test
25. N1-ST-Q4, Reactor Coolant System Isolation Valves Operability Test
26. N1-ST-Q5, Primary Cont Iso Vlvs Exercising
27. N1-ST-Q6, Containment Spray System Quarterly Operability Test
28. N1-ST-Q7, Manual Scram Instrument Channel Test
29. N1-ST-Q8, Liquid Poison Pump and Check Valve Operability Test
30. N1-ST-Q13, Emerg Service Water Pump & Check Valve Operability Test
31. N1-ST-Q15, Condensate Transfer System Operability Test
32. N1-ST-Q16, Emergency Diesel Generator Quarterly Test
33. N1-ST-Q17, N2 Supply Systems Valves Operability Test
34. N1-ST-Q21, Instrument Air Valves
35. N1-ST-Q24, Drywell/Torus and Torus/Reactor Building Vacuum Breakers Test
36. N1-ST-R1, Control Rod Scram Insertion Time Test
37. N1-ST-R8, Hi Cool & Prim Cont Iso Vlvs Timing
38. N1-ST-R16, Emergency Service Water Pump Header Test
39. N1-ST-V3, Rod Worth Minimizer Operability Test
40. N1-ST-V4, Feedwater & Main Steam Line Power Operatied Iso Vlvs Ex





- 41. N1-ST-V5, Suppression Temperature Monitoring During Relief Valve Operation
- 42. N1-ST-V7, Reactor Building Closed Loop Cooling System Pump & Valve Operability Test
- 43. N1-ST-V8, Main Steam Iso Vlv Full Closure Test
- 44. N1-ST-W1, Control Rod Exercising
- 45. N1-ST-W4, Main Steamline High Radiation Instrument Channel Test Section Acceptance
  - a. All manipulations in test Section "III.D" accomplished in accordance with (IAW) reference plant controlled operating procedures, any procedure exceptions documented IAW NTI-4.5.3

<u>          </u> / <u>          </u>	Satisfactory	<u>          </u> / <u>          </u>	Unsatisfactory
Initial/Date		Initial/Date	

V. Performance Criteria


- A. Simulator instrument error shall be NO greater than that of the related instrument in the reference plant
- B. Principal mass and energy balances shall be satisfied
  - 1. Net NSSS thermal power to generated electrical power
  - 2. Feedwater flow to reactor thermal power
- C. Simulator computed values of critical parameters shall agree within  $\pm 2\%$  of the reference plant parameter at the specified power level
- D. Simulator computed values for steady state, full power reference plant configuration operation, shall be stable and not vary more than  $\pm 2\%$  of the initial values over a 60 minute period



VI. Remarks:

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
B. Approved by SCCB	_____		_____
	Signature		Date




# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI 3.5 A3.4 Plant Malfunctions Tests

- I. Initial conditions: In accordance with the Malfunction applicable Acceptance Test Procedure (ATP) Section
- II. Data Collection:
  - A. Method: Manual as specified by the applicable ATP section
  - B. Parameters: In accordance with the applicable ATP section
- III. Prerequisites
  - A. All participants read test procedure and fill out section VII.A (performed by)
- IV. Procedure
  - A. Perform each of the following listed Malfunction tests in accordance with the applicable ATP section and Malfunction Cause and Effect
    1. AD04 Relief Valve Leaks
    2. CS01 Core Spray Pump Trip
    3. CT02 Containment Spray RAW Water Pump Trip
    4. CU03 RWCU Reject FCV Fails Open
    5. CU07 RWCU Low Pressure Control Valve Fails Open
    6. CU11 Coolant Leak Outside Primary Containment
    7. CW04 RBCLC Pump Trip
    8. CW08 Circulating Water Intake Structure Icing
    9. DG02 Diesel Generator Trip
    10. EC04 Emergency Cooling System Return Valve Fails Open
    11. ED01 Loss of Offsite 115 KV Power
    12. ED05 PB12 Electrical Fault
    13. ED09 PB13 Section "A" Electrical Fault
    14. ED13 PB14 Section "B" Electrical Fault
    15. ED17 PB15 Section "C" Electrical Fault
    16. ED21 PB17 Section "B" Electrical Fault

ANSI 3.5 A3.4 MALFUNCTION TESTS -1



17. ED25 Loss of Power to Instrument Control Bus 130 Normal and Alt
18. EG04 Main Generator Core Internal Heating
19. EG08 Generator Hydrogen Emergency Seal Oil Pump Failure
20. EG12 Power Grid Network Load Transient - Decrease
21. FP02 Electric Fire Pump Failure
22. FP06 Control Room Fire Detection - Various Panels
23. FP10 Reactor Building Fire Detection
24. FW04 Shaft Driven Feedwater Pump 13 Failure
25. FW08 Feedwater Control Valve 11 Controller Fails - Low
26. FW12 Feedwater Control Valve 13 13 Controller Fails - Low
27. FW16 Feedwater Master Controller Fails as is
28. FW20 Condensate Recirc Valve (FCV 50-24) Fails Closed
29. FW24 Feedwater Control Valve Fails Closed (13A/13B)
30. FW28 HPCI Mode Failure to Initiate
31. IA01 Loss of Instrument Air
32. MC03 Hotwell Level Controllers in Auto Fail - High
33. MS01 Steam Line Rupture Outside Primary Containment
34. MS05 Turbine Steam Seal Regulator Fails Closed
35. MS09 Second Stage Reheater 112 Drain Tk Level Control Fail Low
36. NM02 SRM Channel Failure - Downscale
37. NM10 IRM Channel Failure - Upscale
38. NM18 IRM Channel Detector Stuck
39. NM25 LPRM Failure - Upscale
40. NM36 Recirc Flow Converter Channel Failure - Upscale
41. NM40 Recirc Flow Converter Failure - Comparator
42. OG04 Off Gas Discharge to Stack Isolation Valve Fails Closed
43. PP01 Failure of Plant Process Computer
44. RD04 Control Rod Failure - Stuck
45. RD08 Control Rod Failure - RPIS
46. RD36 CRD Flow Control Valve Failure - Closed
47. RD40 Reactor Manual Control System Timer Malfunction - Settle





48. RM03 Area Radiation Monitor Drawer Upscale
49. RP04 Reactor Protection System Failure to Scram - Automatic
50. RP08 Anticipated Transient Without Scram (ATWS)
51. RR04 Recirculation Pump 11 Control Signal Failure
52. RR08 Recirculation Pump 12 Seizure
53. RR12 Recirc Pump 13 Field Breaker Trip
54. RR16 Recirc Pump 14 Drive Breaker Trip
55. RR20 Recirc Pump 14 Incomplete Start Sequence
56. RR24 Recirc Pump 15 Control Signal Failure
57. RR27 Master Recirc Flow Controller Failure - Low
58. RR31 Reactor Vessel Pressure Recorder Failure - Low
59. RR35 Reactor Vessel Pressure Indicator Failure - Upscale
60. RR39 Reactor Vessel Level Recorder Failure - Downscale
61. RR43 Rx Vessel Level Indication (Control Sys) Fail - as is
62. RR47 Recirc Pump Discharge Valve Stem Separates From Gate
63. RR51 Rx Vessel Level Transmitter (RPS Input) Fails - High
64. RR55 Rx Vessel Level Transmitter (Control Input) Fails - Low
65. RR59 Rx Vessel Pressure Transmitter (RPS Input) Fails as is
66. RR63 Reactor Recirc Pump 12 Inner Seal Failure
67. RR67 Reactor Recirc Pump 15 Tachometer Fails - Oscillates
68. RR71 Reactor Safety Valve Inadvertently Opens
69. RX02 Increased Rod Worth
70. TC02 Turbine Governor Fails - High
71. TC06 Electrical Pressure Regulator Fails - Oscillates
72. TC10 First Bypass Valve Sticks Open
73. TU01 Exhaust Hood Spray Valve Fails Closed
74. TU05 Main Turbine Bearing High Temperature
75. CU05 RWCU High Pressure Control Valve Fails Open

V. Acceptance Criteria

- A. All malfunction tests completed satisfactorily in accordance with applicable ATP sections and Malfunction Cause and Effect

_____ / _____	Satisfactory	_____ / _____	Unsatisfactory
Initial/Date		Initial/Date	



VI. Remarks:

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
B. Approved by SCCB	_____		_____
	Signature		Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(1) MANUAL SCRAM TRANSIENT

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B121"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a personal computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor Power (Neutron Flux %)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Wide Range Reactor Pressure                             | D373 |
| 5. Narrow Range Reactor Pressure                           | D372 |
| 6. Wide Range Reactor Water Level                          | J342 |
| 7. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 8. Generator Gross Electrical Power                        | F414 |
| 9. Turbine Steam Flow<br>(By First Stage Shell Press)      | B465 |
| 10. Total Core Flow (Total Recirc Flow)                    | A445 |

ANSI 3.5 B1.2(1) TRANSIENT TEST -1



C: Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following:
1. Insert the following malfunction with delay time start of problem time 1:00 minute
    - a. RPO3-----Reactor Scram
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B





V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____

B. Approved by SCCB \_\_\_\_\_  
Signature Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(2) SIMULTANEOUS TRIP OF ALL FEEDWATER PUMPS

I. Initial conditions: Full power steady state, end of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called ANSI DATA COLLECTION option - 1 seconds before the transient and lasting for 10 minutes of the transient
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Wide Range Reactor Pressure                             | D373 |
| 5. Narrow Range Reactor Pressure                           | D372 |
| 6. Wide Range Reactor Water Level                          | J342 |
| 7. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 8. Generator Gross Electrical Power                        | F414 |
| 9. Turbine Steam Flow<br>(By First Stage Shell Press)      | B465 |
| 10. Total Core Flow (Total Recirc Flow)                    | A445 |

ANSI 3.5 B1.2(2) TRANSIENT TEST -1



- C. Supplemental Data
  - 1. Alarm Typer Printout
  - 2. Sequence of Events Log Printout
- III. Prerequisites
  - A. All participants read test procedure and fill out Section VII.a (performed by)
- IV. Procedure
  - A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following:
    - 1. Insert the following malfunction with delay time start of problem time 1:00 minute
      - a. FW01A----"A" feedwater pump trip
      - b. FW01B----"B" feedwater pump trip
      - c. FW01C----"C" feedwater pump trip
    - 2. Activate the data gathering program specified (II.A.1)
    - 3. Roll ahead the printer paper for a clean start point
    - 4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
    - 5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
    - 6. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
    - 7. Download the collected data to a PC and graph the information
    - 8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
    - 9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_ / \_\_\_\_\_ Satisfactory \_\_\_\_\_ / \_\_\_\_\_ Unsatisfactory  
 Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_ / \_\_\_\_\_ Satisfactory \_\_\_\_\_ / \_\_\_\_\_ Unsatisfactory  
 Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_ / \_\_\_\_\_ Satisfactory \_\_\_\_\_ / \_\_\_\_\_ Unsatisfactory  
 Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____ / _____
	_____	_____	_____ / _____
	_____	_____	_____ / _____
	_____	_____	_____ / _____
	_____	_____	_____ / _____

B. Approved by SCCB \_\_\_\_\_  
 Signature Date





# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(3) SIMULTANEOUS CLOSURE OF ALL MAIN STEAM ISOLATION VALVE

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B123"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor Power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Wide Range Reactor Pressure                             | D373 |
| 5. Narrow Range Reactor Pressure                           | D372 |
| 6. Wide Range Reactor Water Level                          | J342 |
| 7. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 8. Generator Gross Electrical Power                        | F414 |
| 9. Turbine Steam Flow<br>(By First Stage Shell Press)      | B465 |
| 10. Total Core Flow (Total Recirc Flow)                    | A445 |

ANSI 3.5 B1.2(3) TRANSIENT TEST -1



C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following:
1. Insert the following malfunction with delay time start of problem time 1:00 minute
    - a. RPO6----Vessel Isolation
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
B. Approved by SCCB	_____		_____
		Signature	Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(4) SIMULTANEOUS TRIP OF ALL  
RECIRCULATION PUMPS

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B124"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Narrow Range Reactor Pressure                           | D372 |
| 5. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 6. Total Core Flow = (Total Recirc Flow)                   | A445 |
| 7. Individual Recirculation Loop Flows                     |      |
| a. Loop 11   | A430 |
| b. Loop 12   | A434 |
| c. Loop 13   | A438 |
| d. Loop 14   | A442 |
| e. Loop 15   | A446 |





C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
1. Insert the following malfunction with delay time start of problem time 1:00 minute
    - a. RR01----- Pump 11 Trip
    - b. RR06----- Pump 12 Trip
    - c. RR11----- Pump 13 Trip
    - d. RR16----- Pump 14 Trip
    - e. RR21----- Pump 15 Trip
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____

B. Approved by SCCB \_\_\_\_\_  
Signature Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1

Reference Plant: NINE MILE POINT UNIT - 1

Performance Test: 1989 ANSI APPENDIX "B" B1.2(5) SINGLE RECIRCULATION PUMP TRIP

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B125"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Narrow Range Reactor Pressure                           | D372 |
| 5. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 6. Total Core Flow (accurate indication not available)     |      |
| 7. Individual Recirculation Loop Flows                     |      |
| a. Loop 11   | A430 |
| b. Loop 12   | A434 |
| c. Loop 13   | A438 |
| d. Loop 14   | A442 |
| e. Loop 15   | A446 |

ANSI 3.5 B1.2(5) TRANSIENT TEST -1



C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
  1. Insert the following malfunction with delay time start of problem time 1:00 minute
    - a. RR21----- Pump 15 Trip
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B





V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_/\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_/\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_/\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____

B. Approved by SCCB \_\_\_\_\_  
Signature Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(6) MAIN TURBINE TRIP TRANSIENT TEST

I. Initial conditions: Maximum power level which does not result in immediate reactor scram, and normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B126"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Wide Range Reactor Pressure                             | D373 |
| 5. Narrow Range Reactor Pressure                           | D372 |
| 6. Wide Range Reactor Water Level                          | J342 |
| 7. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 8. Generator Gross Electrical Power                        | F414 |
| 9. Turbine Steam Flow<br>(By First Stage Shell Press)      | B465 |
| 10. Total Core Flow (Total Recirc Flow)                    | A445 |

ANSI 3.5 B1.2(6) TRANSIENT TEST -1



C. Supplemental Data


1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to full power steady state, end of cycle, with normal reference plant equipment lineup, and perform the following
1. Reduce reactor power until annunciator F3-4-6 comes in, in accordance with N1-OP-43
  2. Stabilize power and snap shot a test initial condition (IC) labeled as ANSI B1.2(6)
  3. Reset to the test IC, DO NOT TAKE OUT OF FREEZE
  4. Insert the following malfunction with delay time start of problem time 1:00 minute
    - a. TCO1----- Turbine Trip
  5. Activate the data gathering program specified (II.A.1)
  6. Roll ahead the printer paper for a clean start point
  7. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  8. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  9. Evaluate the printouts for acceptance criteria V.B and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  10. Download the collected data to a PC and graph the information
  11. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  12. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
B. Approved by SCCB	_____		_____
		Signature	Date





# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1

Reference Plant: NINE MILE POINT UNIT - 1

Performance Test: 1989 ANSI APPENDIX "B" B1.2(7) MAXIMUM RATE POWER RAMP  
(100% - 75% - 100%)

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B127"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |  |      |
|--|------|
| 1. Reactor power (% neutron flux)                          | H441 |
| 2. Total Steam Flow  | D376 |
| 3. Total Feedwater Flow                                    | A391 |
| 4. Wide Range Reactor Pressure                             | D373 |
| 5. Narrow Range Reactor Pressure                           | D372 |
| 6. Wide Range Reactor Water Level                          | J342 |
| 7. Narrow Range Reactor Water Level<br>(Feedwater Control) | D377 |
| 8. Generator Gross Electrical Power                        | F414 |
| 9. Turbine Steam Flow<br>(By First Stage Shell Press)      | B465 |
| 10. Total Core Flow (Total Recirc Flow)                    | A445 |

ANSI 3.5 B1.2(7) TRANSIENT TEST -1



C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
  1. Activate the data gathering program specified (II.A.1)
  2. Roll ahead the printer paper for a clean start point
  3. Un-freeze the Simulator and wait for 1 minute problem time
  4. At problem time = 1 minute, using the Master Controller, Ramp reactor power at a rate of 6 MWE/SEC by reducing recirculation flow until reactor power is 75%, then raise recirculation flow until reactor power is 97.5%
    - a. In accordance with NI-OP-43
  5. When reactor power = 97.5%, raise reactor power to 100% at 5 MWE per hour using the Master recirc flow controller
  6. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  7. Evaluate the printouts for acceptance criteria V.B. and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  8. Download the collected data to a PC and graph the information
  9. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  10. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____

B. Approved by SCCB \_\_\_\_\_  
Signature Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(8) MAXIMUM SIZE REACTOR COOLANT SYSTEM RUPTURE (LOCA) COMBINED WITH LOSS OF ALL OFF SITE POWER (LCOP)

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B128"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |   |      |
|---|------|
| 1. Reactor power (% neutron flux)                                       | H441 |
| 2. Total Steam Flow   | D376 |
| 3. Total Feedwater/High Pressure Coolant Injection Flow                 | A391 |
| 4. Wide Range Reactor Pressure  | D373 |
| 5. Wide Range Reactor Water Level                                       | J342 |
| 6. Fuel Zone Water Level  | H447 |
| 7. Torus Water Temperature  | H478 |
| 8. Torus Air Temperature  | H477 |
| 9. Torus Pressure   | D324 |
| 10. Drywell Temperature   | D322 |
| 11. Drywell Pressure  | D320 |
| 12. Low Pressure Core Spray Flow (No Point Available See FI RV-35A & B) |      |





C. Supplemental Data


1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
  1. Insert the following malfunctions with delay time start of problem time 1:00 minute
    - a. RR29----- RRP Suction Break
    - b. ED01AB--- Loss of 115KV
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B. and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
B. Approved by SCCB	_____		_____
		Signature	Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(9) MAXIMUM SIZE UNISOLABLE MAIN  
STEAM LINE RUPTURE

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method


1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B129"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |   |      |
|---|------|
| 1. Reactor power (% neutron flux)                                       | H441 |
| 2. Total Steam Flow   | D376 |
| 3. Total Feedwater/High Pressure Coolant Injection Flow                 | A391 |
| 4. Wide Range Reactor Pressure  | D373 |
| 5. Wide Range Reactor Water Level                                       | J342 |
| 6. Fuel Zone Water Level  | H447 |
| 7. Torus Water Temperature  | H478 |
| 8. Torus Air Temperature  | H477 |
| 9. Torus Pressure   | D324 |
| 10. Drywell Temperature   | D322 |
| 11. Drywell Pressure  | D320 |
| 12. Low Pressure Core Spray Flow (No Point Available See FI RV-35A & B) |      |

ANSI 3.5 B1.2(9) TRANSIENT TEST -1



C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
1. Insert the following malfunctions with delay time start of problem time 1:00 minute
    - a. MS04----- Steam Line Rupture Inside Primary Containment
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B. and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B





V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_ Unsatisfactory  
Initial/Date Initial/Date

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____
	_____	_____	_____/_____

B. Approved by SCCB \_\_\_\_\_  
Signature Date



# NIAGARA MOHAWK SIMULATION FACILITY

## PERFORMANCE TEST

Simulation facility: NINE MILE POINT UNIT - 1  
Reference Plant: NINE MILE POINT UNIT - 1  
Performance Test: 1989 ANSI APPENDIX "B" B1.2(10) SIMULTANEOUS CLOSURE OF ALL MAIN STEAM ISOLATION VALVES (MSIV) COMBINED WITH SINGLE STUCK OPEN ELECTROMATIC RELIEF VALVE TRANSIENT TEST

I. Initial conditions: Full power steady state, middle of cycle, with normal reference plant equipment lineup

II. Data Collection:

A. Method

1. Data will be gathered on the critical parameters using a Simulator program called "ANSI B1210"
  - a. Data is gathered at 0.5 second intervals, starting 15 seconds before the transient and lasting for 10 minutes of the transient
  - b. Data is then down loaded to a Personal Computer (PC) and graphed for evaluation
2. Process Plant Computer (PPC) alarm and Sequence of Events (SOE) printouts will be gathered for alarm and automatic action evaluation

B. Critical Parameters:

Computer Point

- |   |      |
|---|------|
| 1. Reactor power (% neutron flux)                                       | H441 |
| 2. Total Steam Flow   | D376 |
| 3. Total Feedwater/High Pressure Coolant Injection Flow                 | A391 |
| 4. Wide Range Reactor Pressure  | D373 |
| 5. Wide Range Reactor Water Level                                       | J342 |
| 6. Fuel Zone Water Level  | H447 |
| 7. Torus Water Temperature  | H478 |
| 8. Torus Air Temperature  | H477 |
| 9. Torus Pressure   | D324 |
| 10. Drywell Temperature   | D322 |
| 11. Drywell Pressure  | D320 |
| 12. Low Pressure Core Spray Flow (No Point Available See FI RV-35A & B) |      |



C. Supplemental Data

1. Alarm Typer Printout
2. Sequence of Events Log Printout

III. Prerequisites

- A. All participants read test procedure and fill out Section VII.a (performed by)

IV. Procedure

- A. Reset to initial conditions specified in Section "I.", DO NOT TAKE OUT OF FREEZE, and perform the following
  1. Insert the following malfunctions with delay time start of problem time 1:00 minute
    - a. RP06----- Vessel Isolation
    - b. AD06----- ERV 111 Sticks Open
  2. Activate the data gathering program specified (II.A.1)
  3. Roll ahead the printer paper for a clean start point
  4. Un-freeze the Simulator and allow the transient to progress with NO operator actions
  5. At problem time 11:30 freeze the simulator and gather the PPC printouts, and label with the performance test title and date
  6. Evaluate the printouts for acceptance criteria V.B. and V.C, initial the appropriate acceptance blocks, write any DR's, and enter any appropriate remarks in Section VI.
  7. Download the collected data to a PC and graph the information
  8. Evaluate the critical parameter graphs or raw data for acceptance criteria V.A, initial the appropriate acceptance block, write any DR's, and enter any appropriate remarks in Section VI.
  9. Simulator Configuration Control Board (SCCB) review and approve test results, Section VII.B



V. Acceptance Criteria

A. The observable change in the Simulator monitored parameter corresponds in direction to those expected in the reference plant

Re: Critical parameter raw data or PC graph

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

B. The Simulator caused alarms and automatic actions that would have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

C. The Simulator did not cause an alarm or automatic action that would NOT have happened in the reference plant

Re: PPC alarm and SOE printouts

\_\_\_\_\_/\_\_\_\_\_ Satisfactory \_\_\_\_\_/\_\_\_\_\_  
Initial/Date Initial/Date Unsatisfactory

VI. Remarks

VII. Acceptance

	INITIALS	SIGNATURE	PRINTED NAME /DEPARTMENT
A. Performed By:	_____	_____	_____/_____ _____/_____ _____/_____ _____/_____ _____/_____
B. Approved by SCCB		_____	_____ Signature Date





MALF ED09 AC POWER BOARD ELECTRICAL FAULT  
(PB 13 SECTION A)

01 INITIALIZE THE TRAINER TO A FULL POWER IC.

PCM:  
TRAINER RESET

02 INSERT MALF ED09

PCM:  
MALF ED09 ACTIVE

THIS RESULTS IN THE TRIPPING OF THE MANUAL  
SUPPLY BREAKER FROM AUXILIARY FEEDER 11.

A4-4-3: "POWER BOARD 13-14-15 LOW BUS VOLTAGE"  
REF: C-19426-2

\_\_\_\_\_  
INITIAL      DATE

THE FOLLOWING LOADS (BUS TABLE 7-3A) WILL  
EXPERIENCE A TOTAL LOSS OF POWER:

1. POWER BOARD 131A. REFER TO BUS TABLE  
7-11A FOR A LIST OF AFFECTED LOADS.
2. MECHANICAL VACUUM PUMP 11
3. STATOR WATER CIRC PUMP 11. REFER TO  
SECTION 3.076 FOR DETAILS.
4. REACTOR TRIP MG SET. REFER TO BUS TABLE  
7-29A.

\_\_\_\_\_  
INITIAL      DATE

03 ATTEMPT TO CLOSE THE MANUAL SUPPLY BREKAER  
FROM FEEDER 11 TO PB 13 SECTION A.

PCM:  
REMOTE FUNCTION RED26 CLOSSES BREAKER, BUT  
BREAKER IMMEDIATELY TRIPS OPEN.

\_\_\_\_\_  
INITIAL      DATE

04 ATTEMPT TO CLOSE THE MANUAL SUPPLY BREAKER  
FROM POWER BORAD 13 SECTION B.

PCM:  
REMOTE FUNCTION RED03 CLOSSES BREAKER, BUT  
BREAKER IMMEDIATELY TRIPS OPEN.

\_\_\_\_\_  
INITIAL      DATE



05 CLOSE THE MANUAL SUPPLY BREAKER FROM PB 131A  
TO PB 131B.

PCM:  
REMOTE FUNCTION RED15 OPENS MANUAL SUPPLY  
TO PB 131A FROM PB 13A AND CLOSES SUPPLY  
BREAKER FROM PB 131B.

POWER IS RESTORED TO PB 131A.

                            
INITIAL              DATE

06 REMOVE MALF ED09

PCM:  
MALF ED09 REMOVED

RECLOSE THE MANUAL SUPPLY BREAKER FROM  
FEEDER 11 TO POWER BOARD 13 SECTION A

PCM:  
REMOTE FUNCTION RED26 CLOSES THE BREAKER

A4-4-3 CLEARS: "POWER BOARD 13-14-15 LOW  
BUS VOLTAGE"

POWER IS RESTORED TO PB 13A

                            
INITIAL              DATE

                            
INITIAL              DATE

END OF MALF ED09



NINE MILE PT #1 MALFUNCTION CAUSE AND EFFECTS

MALF  
NO.

MALFUNCTION TITLE/RANGE/CAUSE AND EFFECT

ED09 AC POWER BOARD ELECTRICAL FAULT (PB13 SECTION A)

TYPE:

ED - DISCRETE

CAUSE:

SHORT TO GROUND ON PB13A BUS BAR.

PLANT STATUS:

100% POWER

EFFECTS:

THIS MALFUNCTION WILL RESULT IN THE TRIPPING OF THE SUPPLY BREAKER TO PB13A FROM AUXILIARY FEEDER 11. IF THE TIE BREAKER BETWEEN SECTIONS A AND B IS CLOSED IN (BY USE OF REMOTE FUNCTION) IT WILL TRIP. THIS RESULTS IN A TOTAL LOSS OF POWER TO PB13A.

THE FOLLOWING ANNUNCIATOR WILL BE RECEIVED IMMEDIATELY:

PANEL	WINDOW	ENGRAVING
-------	--------	-----------

- A4	A4-27	POWER BOARD 13-14-15 LOW BUS VOLTAGE
------	-------	--------------------------------------

REFER TO BUS TABLE 7-3A FOR EQUIPMENT THAT WILL BE AFFECTED

EACH SYSTEM AFFECTED BY THIS MALFUNCTION WILL RESPOND APPROPRIATELY FOR THE LOSS OF THE VARIOUS COMPONENTS.

ALL APPROPRIATE ALARMS AND INDICATIONS WILL ACTUATE.

REMOVAL OF THIS MALFUNCTION WILL REMOVE THE SHORT FROM THE BUS BAR. THE MANUAL SUPPLY BREAKER FROM AUXILIARY FEEDER 11 WILL CLOSE WHEN THE MALFUNCTION IS REMOVED.

REF: C-19426-C



ANSI/ANS 3.5 ANNUAL REPORT

prepared for  
NIAGARA MOHAWK POWER CORPORATION

GP-R-115007  
March 1, 1986

GENERAL PHYSICS CORPORATION  
Oswego, New York





## I. SIMULATOR INFORMATION

This section provides pertinent descriptive information on the Nine Mile Point Unit One simulator. This section summarizes the relevant information concerning the simulator and its suitability and applicability as an operator training device.

## A. General

1. The Nine Mile Point Unit One simulator is owned by General Physics Niagara Corporation, a wholly owned subsidiary of General Physics Corporation. The simulator is operated jointly by Niagara Mohawk Power Corporation and General Physics Niagara Corporation instructors. All maintenance and modifications have been performed by General Physics at the direction of Niagara Mohawk Power Corporation. The simulator was manufactured by Singer/Link.
2. The Nine Mile Point Unit One simulator is a full-scope control room simulator which simulates the Nine Mile Point Unit One plant, owned and operated by Niagara Mohawk Power Corporation. Nine Mile Point Unit One is an 1850-MWt BWR-2 manufactured by General Electric. The rated electrical output is 620 MWe.
3. The Nine Mile Point Unit One simulator was declared Ready for Training on 1 September, 1984.
4. This report is the initial report on the Unit One simulator performance. This report was prepared to document simulator modifications since the Ready for Training date and to document the simulator's performance subsequent to the modifications.

As of 1 March, 1986, the simulator has been updated to reflect all modifications made to the reference plant through 1 September, 1984. In addition, the simulator has been modified to reflect actual plant performance characteristics for several additional parameters.



7



**B. Control Room**

1. The physical configuration of the reference plant control room is shown in Figure 1. The physical configuration of the simulator control room is shown in Figure 2. A comparison of these figures reveals a high degree of similarity between the simulator and the reference plant control room. The following differences exist in the physical arrangements:

Simulator

- Has the instructor console next to the NSSS typer.
- Does not have the ASSS office addition.
- No simulation of plant Meteorological Computer.

Reference Plant

- Has a desk at this location.
- Has an addition on the SSS office for the ASSS.
- A Meteorological Computer is located in the control room.

**2. Panels and Equipment**

The Nine Mile Point Unit One simulator contains all the panels which are in the reference plant control room, and it fully simulates all front panel and back panel controls and indications. Some equipment which has neither controls nor indications is cosmetically simulated. The following list summarizes the equipment differences between the simulator and the reference plant control room:

- RPS relays are installed but are non-functional in the simulator.
- Electrical protective relays are cosmetically simulated utilizing photographs mounted inside the relay enclosures.
- The simulator utilizes one operating TIP machine and a selector switch to functionally simulate the four plant TIP machines; the three remaining three TIP machines have all panel hardware installed but remain non-functional.



### 3. Systems

All the systems which are operable from the reference plant control room are fully simulated. For completeness, Attachment 1 lists those systems which are fully simulated.

### 4. Simulator Control Room Environment

The simulator control room was specifically designed to duplicate as nearly as possible the reference plant control room environment. The floor tile and lighting systems are identical. The physical configuration of the panels is dimensionally identical, and false doors and posts are placed in the simulator control room at the same locations in which they occur in the reference plant.

All instrumentation, controls, mimic, labels, and operator aids are identical within the limits of hardware availability. The paint color and shade used on the panels is very nearly the same. All communications equipment provided in the reference plant is provided in the simulator. The ambient noise levels in the simulator are approximately the same as those in the reference plant control room.

### C. Instructor Interface

1. There are twenty initial condition sets available for instructor use. See Attachment 2 for a description of these. Thirty additional initial condition sets are available for use by the instructors.
2. The malfunctions are listed on Attachment 3.
3. The remote functions, for controls located outside the control room are listed on Attachment 4.



## 4. Additional instructor aids include:

- Display of Monitored Parameters: DMP is available on an instructor station computer terminal; the instructor may select and display up to sixteen of the 100 available monitored plant parameters. Parameters are listed on Attachment 5.
- Line Printer Plotter: The LPP function permits the instructor to print simultaneously up to 12 DMP variables on the computer room line printer. The time resolution of the LPP function is 0.1 seconds.
- Record/Replay is an instructor-controlled feature by which the instructor may record trainee actions to magnetic tape in real time and later play this back through the simulator to enable a discussion of these actions.

## D. Reference Plant Operating Procedures

Trainees in the simulator utilize a controlled set of plant procedures whenever they are operating the simulator. When a plant procedure is inappropriate or cannot be utilized on the simulator, such as when a plant modification has not been incorporated into the simulator at the time of a procedure revision, the difference is identified in the operating procedure in accordance with the Niagara Mohawk Power Corporation Nuclear Training Instruction for Simulator Instruction.

## II. SIMULATOR DESIGN DATA

The simulator initial design data is listed in the original Database document on file at the simulator library. The initial simulator design data was frozen in April, 1982. Since the Ready for Training date (1 September, 1984), a number of modifications have been made to the simulator, based on changes made to the reference plant.

As a result of these modifications, many new data items have been added to the simulator database, and several original database prints have been upgraded to more recent revision numbers. Simulator modifications and affected documents for the current reporting period are listed on Attachment 6.





## III. SIMULATOR TESTS

The simulator underwent a series of tests in the period between January 13, 1986 and February 28, 1986. Testing was done to verify real time operation, steady state and transient performance, and malfunction responses.

Documentation of the tests is available in the simulator database and records under the title "Simulator Performance Test Data - March 1986".

## A. Computer Real Time Test

Simulator real time testing was performed by measuring the individual simulation model times during steady state and accident conditions. During this testing, no frame slippage or program overtimes accrued. In addition to the verification of timing, the simulator has designed safeguards which preclude operation outside of real time with two exceptions. The exceptions to real time operation are two instructor- controlled aids: Fast Time; and Slow Time. In slow time all simulator responses are in one-half of normal or real time. Fast time operation is specially handled and only affects reactor core xenon, condenser evacuation, and turbine warming.

## B. Steady State and Normal Operations

Steady state performance and simulator stability have been verified at four power levels against reference plant Balance of Plant Logs. The testing power levels utilized were approximately 25, 50, 75 and 100 percent of rated power. Normal operation testing was performed by doing a plant startup and shutdown in accordance with reference plant procedures. Strip charts and process computer logs which document the acceptable stability of the simulator are contained in Volume 2 of the Simulator Performance Test Data books.



## C. Transient Tests

The following transient tests were performed on the Nine Mile Point Unit One simulator:

- (1) Manual Scram
- (2) Simultaneous trip of all feedwater pumps
- (3) Simultaneous closure of all main steam isolation valves
- (4) Simultaneous trip of all recirculation pumps
- (5) Single recirculation pump trip
- (6) Main turbine trip (maximum power level which does not result in immediate reactor scram)
- (7) Maximum rate power ramp (master recirculation flow controller in "manual") down to approximately 75% and back up to 100%
- (8) Maximum size reactor coolant system rupture combined with loss of all offsite power
- (9) Maximum size unisolable main steam line rupture
- (10) Simultaneous closure of all main steam isolation valves combined with single stuck open safety/relief valve (inhibit activation of high pressure Emergency Core Cooling Systems)

No actual plant response data is available for these specific transients. However, a number of other plant transients (e.g., pressure control failure; turbine trip from rated power) have occurred. The simulator performance for these events compares very favorably with actual plant data.

The Final Safety Analysis Report (FSAR) analyzed six of the above transients. Four of the listed transients have neither specific plant data nor FSAR analysis. Those transients are the following: manual scram; main turbine trip at 35% power; maximum rate power ramp - 100% to 75% to 100%; simultaneous closure of all MSIVs; with stuck open relief valve, and no high pressure ECCS. For these four events, the best-estimate method was used to evaluate simulator performance.



The transients were tested, and data was obtained in accordance with ANSI/ANS 3.5-1985 Appendix B. The following comments apply to the tested transients:

(1) Manual scram

The simulator showed a 10 psi pressure spike when the turbine tripped, and a 6 psi pressure spike when the MSIVs closed on low pressure (no operator action). Opinion varies on the accuracy of these magnitudes. However, no plant data exists for this event (a procedural violation would be required), and the FSAR does not follow this event through MSIV closure.

(2) Simultaneous trip of all feedwater pumps

The FSAR did not analyze a simultaneous trip of all feedwater pumps. However, in the interest of comparing simulator performance to analyzed data, this event was compared to the Feedwater Controller (zero demand) Malfunction. This changed the timing of the feedwater flow decrease, but otherwise the events are very similar.

The FSAR predicts a small, gradual increase in recirculation flow of approximately 5% over a period of about 5 seconds. The simulator shows no change in recirculation flow throughout the event. The reason for the discrepancy appears to be that recirculation flow increases due to the effects of reduced two-phase core flow. The simulator does not dynamically model two-phase pressure drop and flow effects. Since the discrepancy is slight and occurs after the low level scram, it is judged to be non-critical. This difference has no effect on training.

(3) Main steam isolation valve closure

The simulator performance correlated very well with the FSAR prediction.



## (4) Simultaneous trip of all recirculation pumps

The simulator performance correlated very well with the FSAR prediction.

## (5) Single recirculation pump trip

The simulator performance correlated very well with the FSAR prediction.

## (6) Main turbine trip (maximum power level which does not result in immediate reactor scram)

The FSAR does not analyze this event, since it has no safety implications. There is no reference plant data available for this event. Therefore the simulator performance was compared to the best estimate. All measured parameters showed smooth, predictable responses. Reactor pressure rose very slightly (approximately 5 psi). This was expected on the basis that the bypass valves present a slightly different flow resistance than the turbine does. A very mild feedwater flow transient occurred. This was also predicted based on the automatic trip of #13 feedwater pump and the automatic initiation of the HPCI mode of feedwater.

## (7) Maximum rate power ramp (master recirculation flow controller in "manual") down to approximately 75% and back up to 100%

This event was neither analyzed in the FSAR nor performed at the plant as a test or normal evolution. The simulator performance was smooth and predictable on all parameters. No abnormalities were noted.





- (8) Maximum size reactor coolant system rupture combined with loss of all offsite power

The simulator response was very close to the FSAR prediction for all parameters except two: reactor vessel pressure response and drywell pressure response. The reactor vessel pressure decreased to zero in approximately 30 seconds on the simulator; the FSAR predicts that the pressure will reach zero in about 15 seconds. The simulator drywell pressure reached a maximum of approximately 21 psi; the FSAR predicts a peak of about 33 psi. The simulator drywell pressure peaks in approximately 20 seconds; the FSAR predicts that drywell pressure will peak in about 2 seconds. The discrepancy between the simulator performance and the FSAR prediction is traceable to the vessel blowdown rate, and lower plenum flashing. These problems are being addressed by the software support group. As a practical matter, this has no effect on training, since the operator doesn't have time to analyze this type of data until all immediate actions are taken, and the plant condition is stabilized. This discrepancy does not mask any valid indications, nor does it produce any false indications. No operator or automatic protective actions are affected.

- (9) Maximum size unisolable main steam line rupture

The simulator performance correlated very well with the FSAR prediction.

- (10) Simultaneous closure of all main steam isolation valves combined with single stuck open safety/relief valve (inhibit activation of high pressure Emergency Core Cooling Systems)

This event was not analyzed in the FSAR, and it has never occurred in the reference plant. The simulator performance correlated very closely with the FSAR prediction for MSIV Closure. When the simulator relief valve stuck open, the pressure response departed from the FSAR prediction as expected. For the duration of the event, all parameters showed smooth, predictable response.



In addition, the following five events were tested:

1. Turbine trip without bypass
2. Recirculation pump stall (seizure)
3. Inadvertant actuation of an EMRV
4. Safety valve actuation
5. EPR/MPR failure (reactor pressure decreases)

Although these transients are not part of the testing which is required for this report, they were performed because FSAR analysis data is available for them. In all five transients, the simulator performance correlated very closely with the FSAR prediction.

#### D. Malfunction Tests

All malfunctions were tested during the Customer Acceptance Test at the manufacturer's facility during the first half of 1984. Approximately 30 percent of the malfunctions were re-tested for this report. See Attachment 7 for a list of all malfunctions verified during this testing period. The malfunctions to be tested were chosen to include all generic malfunctions required to be simulated by ANSI/ANS 3.5 Regulatory Guide 1.149. Minor discrepancies were noted during the 1986 testing. These discrepancies were documented and are scheduled for correction in accordance with the discrepancy reporting system.

#### IV. DISCREPANCY RESOLUTION AND UPDATING

Discrepancies, modifications, and enhancements are all addressed by the Niagara Mohawk Power Corporation Nuclear Training Instruction 4.5.3, "Simulator Configuration Management." Discrepancy reports may be initiated by any individual utilizing the simulator for testing or training. Plant modifications are tracked by a computerized configuration management system.




SYSTEMS FULLY SIMULATED

1. Nuclear Boiler and Instrumentation
2. Reactor Recirculation System
  - a. Reactor Recirculation Loops
  - b. Boiler Process Instrumentation
  - c. Recirculation Flow Control
3. Control Rod Drive and Hydraulics System (CRDHS)
4. Reactor Manual Control System (RMCS)
5. Reactor Core (Physics and Thermodynamics)
  - a. Reactor Core Neutron Kinetics
  - b. Reactor Core Thermodynamics
6. Rod Worth Minimizer (RWM)
7. Main Steam Systems
  - a. Main Steam and Main Steam Bypass Systems
  - b. Moisture Separators-Reheaters
  - c. Extraction Steam System
  - d. Auxiliary Steam System
8. Reactor Water Cleanup System
9. Nuclear Instrumentation System
  - a. Source Range Monitor (SRM) System
  - b. Intermediate Range Monitor (IRM) System
  - c. Local Power Range Monitoring (LPRM) System
  - d. Average Power Range Monitoring (APRM) System
  - e. Rod Block Monitor (RBM) System
  - f. Traversing In-Core Probe (TIP) System
10. Reactor Protection System
11. Simulation of the Primary Containment and Isolation System
  - a. Primary Containment
  - b. Primary Containment Isolation System
12. Secondary Containment
13. Emergency Ventilation
  - a. Reactor Building Ventilation
  - b. Turbine Building Ventilation
  - c. Building Ventilation
14. Primary Containment Atmosphere Control and Sampling System



15. Emergency Core Cooling Systems
  - a. Automatic Depressurization and Pressure Relief System
  - b. Core Spray
  - c. High Pressure Coolant Injection (HPCI) System
  - d. Containment Spray
  - e. Emergency Cooling System
16. Shutdown Cooling
17. Standby Liquid Control (SLC) System
18. Condensate and Feedwater System
  - a. Condensate System
  - b. Condensate Demineralizer System
  - c. Feedwater System
  - d. Condensate Storage and Transfer System
  - e. Reactor Vessel Level Control System
  - f. Feedwater Heaters, Vents and Drains
19. Off-Gas Recombiner and Condenser Air Removal
20. Main Condenser
21. Circulating Water System
22. Reactor Building Closed Loop Cooling
23. Turbine Building Closed Loop Cooling
24. Service Water System
25. Instrument, Service, and Breathing Air
26. Area Radiation Monitoring System
27. Process Radiation Monitoring System
28. Ventilation Radiation Monitoring System
29. Main Turbine and Turbine Control
  - a. Turbine Oil System
  - b. Turbine Kinematics
  - c. Turbine Mechanics
  - d. Turbine Supervisory and Safety System
  - e. Gland Seal System
  - f. Low Pressure Hood Spray System
  - g. Moisture Separator and Reheat System
  - h. Main Turbine Electro-Hydraulic Control System





30. Plant Electrical System
  - a. Main Generator and Auxiliary Systems
    - 1) Main Generator Synchronous Machine
    - 2) Excitation and Voltage Regulator System
    - 3) Synchroscope
    - 4) Hydrogen Cooling System
    - 5) Stator and Iso-Phase Duct Cooling System
    - 6) Hydrogen Seal Oil System
  - b. Electrical Distribution System
    - 1) Buses and Transformers
    - 2) Breakers
    - 3) Currents, Voltages, and Frequencies
    - 4) DC Electrical Distribution and Control
    - 5) Power System Electrical Grid
  - c. Diesel Generators
31. Containment Atmosphere Dilution, Vent and Purge System
32. Radiation Waste Disposal System Containment Equipment and Floor Drain Sump
33. Plant Carbon Dioxide System
34. Diesel Fire Pump and Pressurized Water Fire System
35. Fire Control Ventilation Systems
36. Control Room Heating, Ventilation, and Air Conditioning
37. Communication System
38. Plant Process Computer System
  - a. Applicable Experience
39. Meteorological Experience
40. Plant Annunciators and Fire System Alarm




INITIAL CONDITIONS

01	COLD SHUTDOWN
02	COLD SHUTDOWN, AUXILIARY SYSTEMS RUNNING
03	STARTUP, 10 RODS SUBCRITICAL
04	9 RODS SUBCRITICAL SEQUENCE A
05	15 RODS SUBCRITICAL
06	HOT SCRAM RECOVERY
07	STARTUP, 75 PSIG
08	STARTUP, 375 PSIG
09	STARTUP, 800 PSIG
10	3.5 BYPASSES - COLD TURBINE
11	HOT TURBINE, 3.5 BYPASSES OPEN
12	NUMBER 13 FEEDWATER PUMP STARTUP
13	50% POWER
14	FULL POWER
15	FULL POWER ALL RODS OUT
16	POWER DECREASE FROM 100% POWER
17	FOUR HOURS AFTER SCRAM
18	PRECONDITIONING
19	
20	



NINE MILE POINT UNIT ONE MALFUNCTIONS

AD01 ADS FAILURE TO INITIATE - PRIMARY VALVES  
AD02 ADS FAILURE TO INITIATE - COMPLETE  
AD03 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - SOLENOID  
AD04 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - VALVE LEAKS  
AD05 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - OPENS  
INADVERTENTLY  
AD06 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - STUCK OPEN  
AN01 CONTROL ROOM ANNUNCIATOR SYSTEM FAILURE  
CS01 CORE SPRAY PUMP TRIP (111, 112, 121, 122, OR ANY)  
CS02 CORE SPRAY TOPPING PUMP TRIP (111, 112, 121, 122, OR ANY)  
CS03 CORE SPRAY INBOARD INJECTION VALVE FAILURE TO OPEN (IV40-01, IV40-09,  
IV40-11, IV40-10, OR ANY)  
CT01 CONTAINMENT SPRAY PUMP TRIP (111, 112, 121, 122, OR ANY)  
CT02 CONTAINMENT SPRAY RAW WATER PUMP TRIP (111, 112, 121, 122, OR ANY)  
CT03 CONTAINMENT SPRAY HEAT EXCHANGER (111, 112, OR BOTH) TUBE LEAK  
CU01 COOLANT LEAKAGE INSIDE PRIMARY CONTAINMENT  
CU02 REACTOR WATER CLEANUP PUMP TRIP (11, 12, OR BOTH)  
CU03 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS OPEN  
CU04 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS CLOSED  
CU05 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
OPEN  
CU06 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
CLOSED  
CU07 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS OPEN  
CU08 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS  
CLOSED  
CU09 REACTOR WATER CLEANUP NON REGENERATIVE HEAT EXCHANGER TUBE LEAK  
CU10 REACTOR WATER CLEANUP DEMINERALIZER RESIN DEPLETION (11, 12, OR BOTH)



CU11 COOLANT LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
CW01 HIGH RADIATION IN SERVICE WATER  
CW02 SERVICE WATER PUMP TRIP (11, 12, OR BOTH)  
CW03 EMERGENCY SERVICE WATER PUMP TRIP (11, 12, OR BOTH)  
CW04 REACTOR BUILDING CLOSED LOOP COOLING (11, 12, 13, OR ANY) PUMP TRIP  
CW05 TURBINE BUILDING CLOSED LOOP COOLING PUMP TRIP (11, 12, OR BOTH)  
CW06 CIRCULATING WATER PUMP TRIP (11, 12, OR BOTH)  
CW07 CIRCULATING WATER EXPANSION JOINT LEAKAGE  
CW08 CIRCULATING WATER INTAKE STRUCTURE ICING  
CW09 LOSS OF DRYWELL COOLING  
CW10 MAIN CONDENSER TUBE LEAK  
DG01 DIESEL GENERATOR FAILURE TO START (102, 103, OR BOTH)  
DG02 DIESEL GENERATOR TRIP (102, 103, OR BOTH)  
EC01 STEAM LEAKAGE INSIDE PRIMARY CONTAINMENT  
EC02 STEAM LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
EC03 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS OPEN (IV39-05, IV39-06,  
OR BOTH)  
EC04 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS TO OPEN (IV39-05, IV39-06,  
OR BOTH)  
EC05 EMERGENCY COOLING SYSTEM EMERGENCY CONDENSER MAKEUP CONTROL VALVE FAILS  
CLOSED (LCV60-17, LCV60-18, OR BOTH)  
EC06 EMERGENCY CONDENSER TUBE LEAK (111, 121, OR BOTH)  
ED01 LOSS OF OFFSITE 115 KV POWER SOURCES (LIGHTHOUSE HILL-JAF, OSWEGO  
STEAM, OR BOTH)  
ED02 BATTERY CHARGER AND EMERGENCY LIGHTING SUPPLY MOTOR GENERATOR TRIPS  
(161, 171, OR BOTH)  
ED03 COMPUTER POWER SUPPLY MOTOR GENERATOR TRIPS (167)  
ED04 AC POWERBOARD ELECTRICAL FAULT (PB11)  
ED05 AC POWERBOARD ELECTRICAL FAULT (PB12)





ED06 AC POWERBOARD ELECTRICAL FAULT (PB101)  
ED07 AC POWERBOARD ELECTRICAL FAULT (PB102)  
ED08 AC POWERBOARD ELECTRICAL FAULT (PB103)  
ED09 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION A)  
ED10 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION B)  
ED11 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION C)  
ED12 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION A)  
ED13 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION B)  
ED14 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION C)  
ED15 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION A)  
ED16 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION B)  
ED17 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION C)  
ED18 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION A)  
ED19 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION B)  
ED20 AC POWERBOARD ELECTRICAL FAULT (PB17 SECTION A)  
ED21 AC POWERBOARD ELECTRICAL FAULT (PB18 SECTION B)  
ED22 DC POWERBOARD ELECTRICAL FAULT (11, 12, OR BOTH)  
ED23 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL  
ED24 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - ALTERNATE  
ED25 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL AND ALTERNATE  
EG01 MAIN GENERATOR TRIP - ELECTRICAL FAULT  
EG02 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - INCREASE  
EG03 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - DECREASE  
EG04 MAIN GENERATOR CORE INTERNAL HEATING  
EG05 MAIN TRANSFORMER LOSS OF COOLING  
EG06 GENERATOR HYDROGEN COOLING SYSTEM LEAKAGE



EG07 GENERATOR HYDROGEN MAIN SEAL OIL PUMP FAILURE  
EG08 GENERATOR HYDROGEN EMERGENCY SEAL OIL PUMP FAILURE  
EG09 STATOR COOLING PUMP TRIP (11, 12, OR BOTH)  
EG10 LOSS OF CONTROL AIR TO 345 KV BREAKER (R-915, R-925, OR BOTH)  
EG11 POWER GRID NETWORK LOAD TRANSIENT - INCREASE  
EG12 POWER GRID NETWORK LOAD TRANSIENT - DECREASE  
EG13 STATOR WATER COOLING DEMINERALIZER RESIN DEPLETION  
FP01 DIESEL FIRE PUMP FAILURE  
FP02 ELECTRIC FIRE PUMP FAILURE  
FP03 AC FOAM PUMP FAILURE  
FP04 DC FOAM PUMP FAILURE  
FP05 TURBINE ISLAND FIRE DETECTION (D-1195, D-1155, D-1165, D-1175, D-1061, DA-1114, DA-1131, OR ANY)  
FP06 CONTROL ROOM FIRE DETECTION (FIRE PANEL 2, CONTROL CONSOLE, "L" PANEL, "K" PANEL, "H" PANEL, "F" PANEL, "A" PANEL, OR ANY)  
FP07 TURBINE BUILDING FIRE DETECTION (DA-22092MG, DA-2083M, DA-2081S, DA2092E, D-2102, OR ANY)  
FP08 DIESEL ROOM FIRE DETECTION (DX-2113A, DX-2113B, DX-2141A, DA-2141, DX-2151B, DA-2151, D-2151, OR ANY)  
FP09 AUXILIARY CONTROL ROOM/CABLE SPREADING ROOM FIRE DETECTION (D-3031PL, DX-3031A, DX-3011B, WD-8131, WD-8082, OR ANY)  
FP10 REACTOR BUILDING FIRE DETECTION (DX-4217A, DA-4116W, DA-4076E, D-4207, D-4156, SP-4126, D-4086, OR ANY)  
FW01 CONDENSATE PUMP TRIP (11, 12, 13, OR ANY)  
FW02 FEEDWATER BOOSTER PUMP TRIP (11, 12, 13, OR ANY)  
FW03 FEEDWATER PUMP TRIP (11, 12, OR BOTH)  
FW04 SHAFT DRIVEN FEEDWATER PUMP 13 FAILURE  
FW05 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO ENGAGE  
FW06 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO DISENGAGE  
FW07 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS HIGH




FW08 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS LOW  
FW09 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS HIGH  
FW10 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS LOW  
FW11 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS HIGH  
FW12 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS LOW  
FW13 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS AS IS  
FW14 FEEDWATER MASTER CONTROLLER FAILS HIGH  
FW15 FEEDWATER MASTER CONTROLLER FAILS LOW  
FW16 FEEDWATER MASTER CONTROLLER FAILS AS IS  
FW17 CONDENSATE DEMINERALIZER DEPLETION  
FW18 FEEDWATER CONDUCTIVITY INCREASE  
FW19 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS OPEN  
FW20 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS CLOSED  
FW21 FEEDWATER BOOSTER PUMP RECIRCULATION VALVE FAILS OPEN (FCV 51-58,  
FCV 51-59, FCV 51-60, OR ANY)  
FW22 FEEDWATER HEATER TUBE LEAK  
FW23 FEEDWATER PUMP RECIRCULATION VALVES FAIL OPEN (11, 12, 13, OR ANY)  
FW24 FEEDWATER CONTROL VALVE FAILS CLOSED (13A, 13B, OR BOTH)  
FW25 THREE MILE ISLAND ACCIDENT (BWR EQUIVALENT)  
FW26 CONDENSATE BYPASS SPRAY TO MAIN CONDENSER FLOW CONTROL VALVE  
(FCV 50-22) FAILS CLOSED  
FW27 LOSS OF COMPENSATION TO FEEDWATER FLOW TRANSMITTER  
FW28 HPCI MODE FAILURE TO INITIATE (11, 12, OR BOTH)  
FW29 HPCI MODE INADVERTANT INITIATION (11, 12, OR BOTH)  
HV01 REACTOR BUILDING EXHAUST FAN TRIP (11, 12, OR BOTH)  
HV02 EMERGENCY VENTILATION FAN TRIP (11, 12, OR BOTH)  
IA01 LOSS OF INSTRUMENT AIR  
LP01 LIQUID POISON PUMP TRIP (A, B, OR BOTH)



MC01 MAIN CONDENSER AIR INLEAKAGE  
MC02 STEAM JET AIR EJECTOR STEAM SUPPLY VALVE FAILS CLOSED  
MC03 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL HIGH  
MC04 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL LOW  
MC05 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL AS IS  
MC06 EXPLOSION IN AIR EJECTOR DISCHARGE PIPING  
MS01 STEAM LEAK RUPTURE OUTSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
MS02 MSIV DISC SEPARATES FROM STEM  
MS03 ONE MSIV FAILS CLOSED (VALVE 122)  
MS04 STEAM LINE RUPTURE INSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
MS05 TURBINE STEAM SEAL REGULATOR FAILS CLOSED  
MS06 MOISTURE SEPARATOR DRAIN TANK LEVEL CONTROL FAILS LOW  
MS07 FIRST STAGE REHEATER 111 STEAM SUPPLY VALVE CLOSES  
MS08 SECOND STAGE REHEATER 112 STEAM SUPPLY VALVE CLOSES  
MS09 SECOND STAGE REHEATER 112 DRAIN TANK LEVEL CONTROL FAILS LOW  
MS10 LOSS OF EXTRACTION STEAM TO HIGH PRESSURE FEEDWATER HEATER  
(115, 125, 135, OR ANY)  
MS11 LOSS OF COMPENSATION TO STEAM FLOW TRANSMITTER  
NM01 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - UPSCALE  
NM02 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - DOWNSCALE  
NM03 SRM CHANNEL RECORDER FAILURE (RED, BLACK, OR BOTH PENS)  
NM04 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - INOPERATIVE  
NM05 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - UPSCALE, RECORDER  
INOPERATIVE  
NM06 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - DOWNSCALE  
NM07 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - RECORDER  
NM08 SRM CHANNEL (11, 12, 13, 14, OR ANY) FAILURE - INOPERATIVE





NM09 SRM CHANNEL (11, 12, 13, 14, OR ANY) DETECTOR STUCK

NM10 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
UPSCALE

NM11 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
DOWNSCALE

NM12 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
RECORDER

NM13 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
INOPERATIVE

NM14 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE - UPSCALE

NM15 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
DOWNSCALE

NM16 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
RECORDER

NM17 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) INOPERATIVE

NM18 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) DETECTOR STUCK

NM19 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE - UPSCALE

NM20 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
DOWNSCALE

NM21 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
INOPERATIVE

NM22 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE - UPSCALE

NM23 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
DOWNSCALE

NM24 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18, OR ANY) FAILURE -  
INOPERATIVE

NM25 ANY LPRM (X-Y-J) FAILURE - UPSCALE


NM26 ANY LPRM (X-Y-J) FAILURE - UPSCALE

NM27 ANY LPRM (X-Y-J) FAILURE - UPSCALE

NM28 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE

NM29 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE

NM30 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE



NM31 ANY LPRM (X-Y-J0 FAILURE - DOWNSCALE  
NM33 TIP DETECTOR STUCK IN CORE  
NM34 ANY LPRM (X-Y-J) DRIFT +/- 25%  
NM35 ANY LPRM (X-Y-J) DRIFT +/- 25%  
NM36 RECIRC FLOW CONVERTER CHANNEL (11, 12, OR BOTH) FAILURE - UPSCALE  
NM37 RECIRC FLOW CONVERTER CHANNEL (11, 12, OR BOTH) FAILURE - DOWNSCALE  
NM38 RECIRC FLOW CONVERTER CHANNEL (11, 12, OR BOTH) FAILURE - AS IS  
NM39 RECIRC FLOW CONVERTER CHANNEL (11, 12, OR BOTH) FAILURE - INOPERATIVE  
NM40 RECIRC FLOW CONVERTER (11, 12, OR BOTH) FAILURE - COMPARATOR  
OG01 OFF GAS RECOMBINER PREHEATER STEAM SUPPLY FAILS CLOSED  
OG02 OFF GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS OPEN  
OG03 OFF GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS CLOSED  
OG04 OFF GAS DISCHARGE TO STACK ISOLATION VALVE FAILS CLOSED  
PC01 DRYWELL-TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - INCREASE  
PC02 DRYWELL-TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - DECREASE  
PC03 PRIMARY CONTAINMENT LEAKAGE  
PP01 FAILURE OF PLANT PROCESS COMPUTER  
RD01 CONTROL ROD XX-YY FAILURE - DRIFT IN  
RD02 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
RD03 CONTROL ROD XX-YY FAILURE - ACCUMULATOR STUCK  
RD04 CONTROL ROD XX-YY FAILURE - STUCK  
RD05 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
RD06 CONTROL ROD XX-YY FAILURE - SCRAMMED  
RD07 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
RD08 CONTROL ROD XX-YY FAILURE - RPIS  
RD09 CONTROL ROD XX-YY FAILURE - DRIFT IN  
RD10 CONTROL ROD XX-YY FAILURE - DRIFT OUT



of



RD11 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
RD12 CONTROL ROD XX-YY FAILURE - STUCK  
RD13 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
RD14 CONTROL ROD XX-YY FAILURE - SCRAMMED  
RD15 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
RD16 CONTROL ROD XX-YY FAILURE - RPIS  
RD17 CONTROL ROD XX-YY FAILURE - DRIFT IN  
RD18 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
RD19 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
RD20 CONTROL ROD XX-YY FAILURE - STUCK  
RD21 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
RD22 CONTROL ROD XX-YY FAILURE - SCRAMMED  
RD23 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
RD24 CONTROL ROD XX-YY FAILURE - RPIS  
RD25 CONTROL ROD XX-YY FAILURE - DRIFT IN  
RD26 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
RD27 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
RD28 CONTROL ROD XX-YY FAILURE - STUCK  
RD29 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
RD30 CONTROL ROD XX-YY FAILURE - SCRAMMED  
RD31 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
RD32 CONTROL ROD XX-YY FAILURE - RPIS  
RD33 CONTROL ROD BANK FAILURE TO SCRAM (BANK I, II, III, IV, V, OR ANY)  
RD34 LOSS OF CRD INSTRUMENT AIR PRESSURE  
RD35 CRD HYDRAULIC PUMP TRIP (11, 12, OR BOTH)  
RD36 CRD FLOW CONTROL VALVE FAILURE - CLOSED (11, 12, OR BOTH)



RD37 RPIS FAILURE - COMPLETE SYSTEM FAILURE

RD38 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - WITHDRAWN

RD39 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - INSERT

RD40 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - SETTLE

RD41 SCRAM DISCHARGE VOLUME RUPTURE

RM01 DRAWER INOPERATIVE FOR ANY PROCESS RADIATION MONITOR SIMULATED  
(INSTRUCTOR SELECT)

RM02 DRAWER DOWNSCALE FOR ANY AREA RADIATION MONITOR SIMULATED (INSTRUCTOR  
SELECT)

RM03 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED

RM04 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED

RM05 CONTINUOUS AIR MONITOR FAILURE (TURBINE BUILDING, REACTOR BUILDING,  
WASTE BUILDING, DRYWELL)

RM06 ANY PROCESS RADIATION MONITOR FAILURE

RP01 REACTOR TRIP POWER SUPPLY MOTOR GENERATOR (131, 141, OR BOTH)

RP02 CONTROL POWER SUPPLY BOTH MOTOR GENERATOR TRIPS (162, 172, OR BOTH)

RP03 REACTOR SCRAM

RP04 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - AUTOMATIC

RP05 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - COMPLETE

RP06 REACTOR VESSEL ISOLATION

RP07 PRIMARY CONTAINMENT ISOLATION

RP08 ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS)

RP09 EMERGENCY CONDENSER FAILS TO ISOLATE (11, 12, OR BOTH)

RR01 RECIRCULATION PUMP 11 DRIVE BREAKER TRIP

RR02 RECIRCULATION PUMP 11 FIELD BREAKER TRIP

RR03 RECIRCULATION PUMP 11 SEIZURE

RR04 RECIRCULATION PUMP 11 CONTROL SIGNAL FAILURE

RR05 RECIRCULATION PUMP 11 INCOMPLETE START SEQUENCE





RR06 RECIRCULATION PUMP 12 DRIVE BREAKER TRIP  
RR07 RECIRCULATION PUMP 12 FIELD BREAKER TRIP  
RR08 RECIRCULATION PUMP 12 SEIZURE  
RR09 RECIRCULATION PUMP 12 CONTROL SIGNAL FAILURE  
RR10 RECIRCULATION PUMP 12 INCOMPLETE START SEQUENCE  
RR11 RECIRCULATION PUMP 13 DRIVE BREAKER TRIP  
RR12 RECIRCULATION PUMP 13 FIELD BREAKER TRIP  
RR13 RECIRCULATION PUMP 13 SEIZURE  
RR14 RECIRCULATION PUMP 13 CONTROL SIGNAL FAILURE  
RR15 RECIRCULATION PUMP 13 INCOMPLETE START SEQUENCE  
RR16 RECIRCULATION PUMP 14 DRIVE BREAKER TRIP  
RR17 RECIRCULATION PUMP 14 FIELD BREAKER TRIP  
RR18 RECIRCULATION PUMP 14 SEIZURE  
RR19 RECIRCULATION PUMP 14 CONTROL SIGNAL FAILURE  
RR20 RECIRCULATION PUMP 14 INCOMPLETE START SEQUENCE  
RR21 RECIRCULATION PUMP 15 DRIVE BREAKER TRIP  
RR22 RECIRCULATION PUMP 15 FIELD BREAKER TRIP  
RR23 RECIRCULATION PUMP 15 SEIZURE  
RR24 RECIRCULATION PUMP 15 CONTROL SIGNAL FAILURE  
RR25 RECIRCULATION PUMP 15 INCOMPLETE START SEQUENCE  
RR26 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - HIGH  
RR27 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - LOW  
RR28 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - AS IS  
RR30 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - UPSCALE  
RR31 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - DOWNSCALE  
RR32 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - AS IS  
RR33 RECIRCULATION PUMP LOWER (INNER) SEAL FAILURE - PUMP 11



- RR34 RECIRCULATION PUMP UPPER (OUTER) SEAL FAILURE - PUMP 11
- RR35 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - UPSCALE
- RR36 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - DOWNSCALE
- RR37 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - AS IS
- RR38 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - UPSCALE
- RR39 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - DOWNSCALE
- RR40 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - AS IS
- RR41 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - UPSCALE (ID59D)
- RR42 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - DOWNSCALE (ID59D)
- RR43 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - AS IS (ID59D)
- RR44 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE - UPSCALE (LI 36-19, CH.12)
- RR45 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE - DOWNSCALE (LI 36-19, CH.12)
- RR46 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE - AS IS (LI 36-19, CH.12)
- RR47 RECIRCULATION PUMP DISCHARGE VALVE STEM SEPARATES FROM VALVE GATE (11,12,13,14,15,OR ANY)
- RR48 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE - UPSCALE
- RR49 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE - DOWNSCALE
- RR50 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE - AS IS
- RR51 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - HIGH
- RR52 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - LOW
- RR53 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - AS IS



- RR54 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - HIGH
- RR55 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - LOW
- RR56 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - AS IS
- RR57 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - HIGH
- RR58 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - LOW
- RR59 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM INPUT) FAILS - AS IS
- RR60 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - HIGH
- RR61 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - LOW
- RR62 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS - AS IS
- RR63 REACTOR RECIRCULATION PUMP 12 INNER SEAL FAILURE
- RR64 REACTOR RECIRCULATION PUMP 12 OUTER SEAL FAILURE
- RR65 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - HIGH
- RR66 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - LOW
- RR67 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - OSCILLATES
- RR68 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - INCREASE (11, 12, 13, 14, 15, OR ANY)
- RR69 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - DECREASE (11, 12, 13, 14, 15, OR ANY)
- RR70 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - AS IS (11, 12, 13, 14, 15, OR ANY)
- RR71 REACTOR SAFETY VALVE INADVERTENTLY OPENS (PSV NR28A)
- RR72 LOSS OF LEVEL COMPENSATION TO FEEDWATER CONTROL SYSTEM (GEMAC) LEVEL TRANSMITTER
- RW01 ROD WORTH MINIMIZER FAILURE



RX01 FUEL CLADDING FAILURE  
RX02 INCREASED ROD WORTH FOR ANY CONTROL ROD  
SC01 SHUTDOWN COOLING PUMP TRIP (11, 12, 13, OR ANY)  
SC02 SHUTDOWN COOLING HEAT EXCHANGER TUBE LEAK (11, 12, 13, OR ANY)  
TC01 MAIN TURBINE TRIP  
TC02 TURBINE GOVERNOR FAILS - HIGH  
TC03 TURBINE GOVERNOR FAILS - LOW  
TC04 ELECTRICAL PRESSURE REGULATOR FAILS - HIGH  
TC05 ELECTRICAL PRESSURE REGULATOR FAILS - LOW  
TC06 ELECTRICAL PRESSURE REGULATOR FAILS - OSCILLATES  
TC07 MECHANICAL PRESSURE REGULATOR FAILS - HIGH  
TC08 MECHANICAL PRESSURE REGULATOR FAILS - LOW  
TC09 MECHANICAL PRESSURE REGULATOR FAILS - OSCILLATES  
TC10 FIRST BYPASS VALVE STICKS OPEN  
TC11 ALL BYPASS VALVES FAIL - OPEN  
TC12 ALL BYPASS VALVES FAIL - CLOSED  
TC13 TURBINE CONTROL VALVE FAILS CLOSED (11, 12, 13, 14, OR ANY)  
TU01 EXHAUST HOOD SPRAY VALVE FAILS CLOSED  
TU02 MAIN TURBINE HIGH VIBRATION BEARINGS #5 AND #6  
TU03 MAIN TURBINE HIGH ECCENTRICITY  
TU04 MAIN TURBINE BEARING OIL LOW PRESSURE  
TU05 MAIN TURBINE BEARING HIGH TEMPERATURE  
TU06 MAIN TURBINE THRUST BEARING WEAR





REMOTE FUNCTIONS

<u>AD</u>			
ADS	NONE		
<u>AN</u>			
ANNUNCIATOR SYSTEM	NONE		
<u>CS</u>			
CORE SPRAY	NONE		
<u>CT</u>			
CONTAINMENT SPRAY	RCT 1 80-43 TEST LINE TO TORUS BV	OPEN	CLOSE
	RCT 2 80-42 WASTE DISP MAN ISOLATION	OPEN	CLOSE
<u>CU</u>			
REACTOR CLEANUP	RCU1 CU-16 PCV ND37 MANUAL ISOLATION	OPEN	CLOSE
	RCU2 CU-19 FILTER BYPASS VALVE	OPEN	CLOSE
	RCU3 CU FILTER 11 INLET/OUTLET VALVES	OPEN	CLOSE
	RCU4 CU FILTER 12 INLET/OUTLET VALVES	OPEN	CLOSE
	RCU5 CU DEMIN 11 INLET/OUTLET VALVES	OPEN	CLOSE
	RCU6 CU DEMIN 12 INLET/OUTLET VALVES	OPEN	CLOSE
	RCU7 CU-20 DEMIN BYPASS VALVES	OPEN	CLOSE
<u>CW1</u>			
AUXILIARY WATER	RCW1 INTAKE WATER TEMPERATURE	32/80 DEG	75.00
	RCW2 INTAKE TUNNEL REVERSE FLOW	YES	NO
	RCW3 UPPER WIND SPEED	0.100 MPH	52.00
	RCW4 UPPER WIND SPEED VARIATION	0/30 MPH	5.00
	RCW5 LOWER WIND SPEED	0/100 MPH	45.00
	RCW6 LOWER WIND SPEED VARIATION	0/30 MPH	5.00
	RCW7 UPPER WIND DIRECTION	0/360 MPH	5.00
	RCW8 UPPER WIND DIRECTION VARIATION	0/90 DEG	150.00
	RCW9 LOWER WIND DIRECTION	0/360 DEG	150.00
	RCW10 LOWER WIND DIRECTION VARIATION	0/90 DEG	5.00
	RCW11 AMBIENT AIR TEMPERATURE	-30/+120 DEG	90.00
	RCW12 DELTA TEMPERATURE	-10/+120 DEG	10.00



<u>CW2</u>			
AUXILIARY WATER	NONE		
<u>DG</u>			
DIESEL GENERATOR	RDG1 DG 102 GOVERNOR SPEED DROOP	SET	RESET
	RDG2 DG 103 GOVERNOR SPEED DROOP	SET	RESET
<u>EC</u>			
EMERGENCY COOLING	REC1 IV 39-05 VALVE POSITION LIMIT	0/100%	100.00
	REC2 IV 39-06 VALVE POSITION LIMIT	0/100%	100.00
<u>ED1</u>			
ELECTRICAL DISTRIB.	RED1 SOUTH OSWEGO 115 KV BKR R10	OPEN	CLOSE
	RED2 FITZ 115 KV BKR R40	OPEN	CLOSE
	RED3 PB 13 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED4 PB 13 BUS TIE BKR SEC B-SEC C	OPEN	CLOSE
	RED5 PB 14 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
<u>ED1</u>			
ELECTRICAL DISTRIB.	RED6 PB 14 BUS TIE BKR SEC B-SEC C	OPEN	CLOSE
	RED7 PB 15 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED8 PB 16 BUS TIE BKR SEC B-SEC C	OPEN	CLOSE
	RED9 MG-SET 167 AC POWER SELECT	PB16	PB17
	RED10 MG-SET 167 DC POWER SELECT	PB11	PB12
	RED11 COMPUTER POWER SUPPLY SELECT	NORM	EMER
	RED12 IC BUS 130 NORM PWR BKR	OPEN	CLOSE
	RED13 IC BUS 130 ALT PWR BKR	OPEN	CLOSE
	RED14 PB1671 BUS TIE BKR	OPEN	CLOSE
	RED15 PB131 CLOSE A-B, OPEN 13A SUPPLY	YES	NO
	RED16 PB131 CLOSE A-B, OPEN 13C SUPPLY	YES	NO
	RED17 PB141 CLOSE A-B, OPEN 14A SUPPLY	YES	NO
	RED18 PB141 CLOSE A-B, OPEN 14C SUPPLY	YES	NO
<u>ED2</u>			
ELECTRICAL DISTRIB.	RED19 PB151 CLOSE A-B, OPEN 15A SUPPLY	YES	NO
	RED20 PB151 CLOSE A-B, OPEN 15C SUPPLY	YES	NO
	RED21 PB176 CLOSE A-B, OPEN 17A SUPPLY	YES	NO
	RED22 PB176 CLOSE AOB, OPEN 16A SUPPLY	YES	NO
	RED23 BAT BD11 EQUIP SW TO ALT	BB11	BB12



<u>ED2</u>			
ELECTRICAL DISTRIB.	RED24 BAT BD12 EQUIP SW TO ALT	BB12	BB11
	RED25 PB143 FEEDER BREAKER	14A	14C
<u>ED3</u>			
ELECTRICAL DISTRIB.	NONE		
<u>EG1</u>			
MAIN GENERATOR	REG1 345 KV BKR 100 42	OPEN	CLOSE
	REG2 345 KB MAN DISC 917	OPEN	CLOSE
	REG3 345 KV MAN DISC 926, 927	OPEN	CLOSE
	REG4 345 KV MOD SW 18	OPEN	CLOSE
	REG5 345 KV BKR R915/10	OPEN	CLOSE
	REG6 345 KV BKR R925/20	OPEN	CLOSE
	REG7 MAIN SEAL OIL PMP STATUS	STAT	NEUT
	REG8 EMER SEAL OIL PMP STATUS	START	NEUT
	REG9 EMER SEAL OIL PMP STATUS	TRIP	AUTO
	REG10 GEN STATOR COOLING PMP 11	START	NEUT
	REG11 GEN STATOR COOLING PMP 11	TRIP	AUTO
	REG12 GEN STATOR COOLING PMP 12	START	NEUT
	REG13 GEN STATOR COOLING PMP 12	TRIP	AUTO
<u>EG1</u>			
MAIN GENERATOR	REG14 GENERATOR OUTPUT LINKS	OPEN	CLOSE
	REG15 GEN HYDROGEN SUPPLY VALVE	OPEN	CLOSE
	REG16 BACKFEED INTERLOCKS	ON	OFF
<u>EG2</u>			
MAIN GENERATOR	NONE		
<u>FP</u>			
FIRE PROTECTION	RFP1 CITY WATER SUPPLY TO FP HDR	OPEN	CLOSE
	RFP2 SUPPLY TO EMER COOL MU TANK 11	OPEN	CLOSE
	RFP3 SUPPLY TO EMER COOL MU TANK 12	OPEN	CLOSE
	RFP4 SUPPLY TO FEEDWATER SYSTEM	OPEN	CLOSE
	RFP5 DIESEL FIRE PUMP STATUS	OFF	AUTO



<u>FW1</u> FEEDWATER	RFW1 50-10 COND PUMP 11 DISCH VLV	OPEN	CLOSE
	RFW2 50-11 COND PUMP 12 DISCH VLV	OPEN	CLOSE
	RFW3 50-12 COND PUMP 13 DISCH VLV	OPEN	CLOSE
	RFW4 50-31 COND DEMIN BYPASS VLV	OPEN	CLOSE
	RFW5 COND DEMIN 11 INLET/OUTLET VLV	OPEN	CLOSE
	RFW6 COND DEMIN 12 INLET/OUTLET VLV	OPEN	CLOSE
	RFW7 COND DEMIN 13 INLET/OUTLET VLV	OPEN	CLOSE
	RFW8 COND DEMIN 14 INLET/OUTLET VLV	OPEN	CLOSE
	RFW9 COND DEMIN 15 INLET/OUTLET VLV	OPEN	CLOSE
	RFW10 COND DEMIN 16 INLET/OUTLET VLV	OPEN	CLOSE
	RFW11 50-20 SJAE BYPASS FCB	0/100%	50.00
	RFW12 50-40 BOOSTER PUMP 11 SUCTION V	OPEN	CLOSE
	RFW13 50-39 BOOSTER PUMP 12 SUCTION V	OPEN	CLOSE
	RFW14 50-38 BOOSTER PUMP 13 SUCTION V	OPEN	CLOSE
	RFW15 FW HEATER STRING 11 ISOL VLVS	OPEN	CLOSE
	RFW16 FW HEATER STRING 12 ISOL VLVS	OPEN	CLOSE
	RFW17 FW HEATER STRING 13 ISOL VLVS	OPEN	CLOSE
	RFW18 DEMIN WATER STORAGE TANK REFILL	OPEN	CLOSE
<u>FW2</u> FEEDWATER	RFW19 50-16 BYPASS AROUND FCV 50-22	OPEN	CLOSE
	RFW20 MANUAL OPERATION OF LCV50-15	0/100%	0.00
	RFW21 MANUAL OPERATION OF LCV50-07,08	0/100%	0.00
	RFW22 FW HEATER 135 ISOL VALVES	OPEN	CLOSE
	RFW23 HOTWELL LEVEL CONTROL	MAN	AUTO
<u>FW3</u> FEEDWATER	NONE		
<u>HV</u> HVAC	NONE		
<u>IA</u> INSTRUMENT AIR	RIA1 INST AIR SUP TO BREATHING AIR	OPEN	CLOSE
	RIA2 BRW-G-6 WASTE DISPOSAL XTIE	OPEN	CLOSE
	RIA3 94-42 CONT SPRAY AIR RCVR ISOL	OPEN	CLOSE
	RIA4 SERV AIR TO INST AIR BV	TRIP	RESET





<u>LP</u>			
LIQUID POISON	RLP1 LIQ POISON PMP 11 LOCAL START	ON	OFF
	RLP2 LIQ POISON PMP 12 LOCAL START	ON	OFF
	RLP3 DEMIN WATER TO LP PUMPS	OPEN	CLOSE
<u>MC</u>			
CONDENSER	RMC1 OG-1,2 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
	RMC2 OG-3,4 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
	RMC3 MS 14,15 PRIM JET STEAM VALVES	OPEN	CLOSE
	RMC4 MS-16,17 PRIM JET STEAM VALVES	OPEN	CLOSE
	RMC5 OG-9,10 SEC JET VAPOR SUCT VALVES	OPEN	CLOSE
	RMC6 MS-19,20 SEC JET STEAM VALVES	OPEN	CLOSE
	RMC7 MS-12 SJAЕ PCV BYPASS	OPEN	CLOSE
<u>MS1</u>			
MAIN STEAM	RMS1 HP FW HTR 115 RESET	TRIP	RESET
	RMS2 HP FW HTR 125 RESET	TRIP	RESET
	RMS3 HP FW HTR 135 RESET	TRIP	RESET
	RMS4 HP FW HTR STRING 11 RESET	TRIP	RESET
	RMS5 HP FW HTR STRING 12 RESET	TRIP	RESET
	RMS6 HP FW HTR STRING 13 RESET	TRIP	RESET
	RMS7 MS-8 MAIN STEAM LINE ISOL	OPEN	CLOSE
	RMS8 SPE 11 SUCTION VALVE	OPEN	CLOSE
	RMS9 SPE 12 SUCTION VALVE	OPEN	CLOSE
	RMS10 TRIP ALL FW HTR EXTR NRVS	TRIP	RESET
<u>MS1</u>			
MAIN STEAM	NONE		
<u>NM1</u>			
NEUTRON MONITOR	RNM1 APRM 11 GAIN	0/100%	2.43
	RNM2 APRM 12 GAIN	0/100%	2.38
	RNM3 APRM 13 GAIN	0/100%	2.36
	RNM4 APRM 14 GAIN	0/100%	2.39
	RNM5 APRM 15 GAIN	0/100%	2.20
	RNM6 APRM 16 GAIN	0/100%	2.18
	RNM7 APRM 17 GAIN	0/100%	2.16
	RNM8 APRM 18 GAIN	0/100%	2.17
<u>NM2</u>			
NEUTRON MONITOR	NONE		



<u>NM3</u>				
NEUTRON MONITOR	NONE			
<u>OD</u>				
ON DEMAND	NON-FUNCTIONAL			
<u>DG</u>				
OFF-GAS/RAD WASTE	RDG1 DG 102 GOVERNOR SPEED DROOP	SET		RESET
	RDG2 DG 103 GOVERNOR SPEED DROOP	SET		RESET
<u>PC</u>				
CONTAINMENT	RPC1 NITROGEN FROM VAPORIZER	YES		NO
	RPC2 201.7-13 DW CAM ISOL VLV 11	OPEN		CLOSE
	RPC3 201.7-29 DW CAM ISOL VLV 12	OPEN		CLOSE
	RPC4 201-40,41 DW, TORUS TO VENT SYS	OPEN		CLOSE
	RPC5 201-44,46 DW, TORUS TO ATMOS	OPEN		CLOSE
	RPC6 BV201.2-135,136 INTERLOCK DEFEAT	YES		NO
	RPC7 IV201-31,32 ISOLATION DEFEAT	YES		NO
<u>PP</u>				
PROCESS COMPUTER	RPP01 MEMORY PROTECT PLAN	NORM		REMOVED
<u>RD1</u>				
CONTROL RODS	RRD1 301-2A CRD PUMP 11 DISCH VLV	OPEN		CLOSE
	RRD2 301-2B CRD PUMP 12 DISCH VLV	OPEN		CLOSE
	RRD3 301-8A CRD PUMP 11 HEAD SPRAY ISOL	OPEN		CLOSE
	RRD4 301-8B CRD PUMP 12 HEAD SPRAY ISOL	OPEN		CLOSE
	RRD5 301-8B CRD FLOW CONTROL VLV ISOL	NC30A		NC30B
<u>RD2</u>				
CONTROL RODS	NONE			
<u>RD3</u>				
CONTROL RODS	NONE			
<u>RM1</u>				
RAD MONITOR	NONE			
<u>RP</u>				
RPS	RRP1 RX TRIP BUS 131 PWR SOURCE	NORM		EMER
	RRP2 RX TRIP BUS 141 PWR SOURCE	NORM		EMER
	RRP3 RPS BUS 11 PWR SOURCE	NORM		EMER
	RRP4 BUS 12 PWR SOURCE	NORM		EMER




<u>RR1</u>				
REACTOR RECIRC	RRR1 RECIRC MG-SETS 11 LOCKOUT RELAY	TRIP	RESET	
	RRR2 RECIRC MG-SETS 12 LOCKOUT RELAY	TRIP	RESET	
	RRR3 RECIRC MG-SETS 13 LOCKOUT RELAY	TRIP	RESET	
	RRR4 RECIRC MG-SETS 14 LOCKOUT RELAY	TRIP	RESET	
	RRR5 RECIRC MG-SETS 15 LOCKOUT RELAY	TRIP	RESET	
<u>RR2</u>				
REACTOR RECIRC	NONE			
<u>RR3</u>				
REACTOR RECIRC	NONE			
<u>RR4</u>				
REACTOR RECIRC	NONE			
<u>RW</u>				
ROD WORTH MINIMIZER	RRW1 CONTROL ROD SEQUENCE SELECT	B	A	
<u>RX</u>				
REACTOR CORE	NONE			
<u>SC</u>				
SHUTDOWN COOLING	NONE			
<u>TC</u>				
TURBINE CONTROL	RTC1 REACTOR FLOW LIMIT	0-120%	120.00	
	RTC2 CONTROL VALVE LIMIT	0-120%	100.00	
<u>TU</u>				
MAIN TURBINE	NONE			



MONITORED PARAMETERS

1. CORE REACTIVITY DK/K
2. CORE THERMAL POWER, %
3. CORE FLOW, LBM/HR
4. CORE PLATE DIFFERENTIAL PRESSURE, PSIG
5. CORE BORON CONCENTRATION, PPM
6. CORE AVERAGE VOID FRACTION, %
7. CORE MINIMUM CRITICAL POWER RATIO
8. CORE MAXIMUM LINEAR HEAT GENERATION, KW/FT
9. CORE INLET SUB COOLING, BTU/LBM
10. CORE AVERAGE FUEL TEMPERATURE, DEG F
11. CORE AVERAGE CLADDING TEMPERATURE, DEG F
12. CORE AVERAGE EXIT QUALITY, %
13. (SPARE)
14. (SPARE)
15. REACTOR COOLANT ACTIVITY, UCI/ML
16. REACTOR COOLANT CONDUCTIVITY, UMHO/CM
17. REACTOR HEATUP/COOLDOWN RATE, DEG F/HR
18. REACTOR LEVEL-NARROW RANGE, INCHES
19. REACTOR LEVEL-WIDE RANGE, FEET
20. REACTOR PRESSURE, PSIG
21. RECIRCULATION LOOP 11 FLOW, LBM/HR
22. RECIRCULATION LOOP 12 FLOW, LBM/HR
23. RECIRCULATION LOOP 13 FLOW, LBM/HR
24. RECIRCULATION LOOP 14 FLOW, LBM/HR
25. RECIRCULATION LOOP 15 FLOW, LBM/HR
26. RECIRCULATION LOOP 11 SUCTION TEMPERATURE, DEG F
27. RECIRCULATION LOOP 12 SUCTION TEMPERATURE, DEG F
28. RECIRCULATION LOOP 13 SUCTION TEMPERATURE, DEG F
29. CRD SYSTEM FLOW, LBM/HR
30. DRYWELL PRESSURE, PSIG
31. DRYWELL AVERAGE TEMPERATURE, DEG F
32. DRYWELL HYDROGEN CONCENTRATION, %
33. DRYWELL OXYGEN CONCENTRATION, %





34. SUPPRESSION CHAMBER PRESSURE, PSIG
35. SUPPRESSION POOL WATER TEMPERATURE, DEG F
36. SUPPRESSION POOL WATER LEVEL, FEET
37. SRM COUNT RATE, CPS
38. SRM PERIOD, SEC
39. APRM POWER LEVEL, %
40. CORE XENON CONCENTRATION, % OF FULL POWER EQU
41. RWCU SYSTEM PRESSURE, PSIG
42. RWCU SYSTEM FLOW, LBM/HR
43. RWCU NON-REGEN HEAT EXCHAN OUTLET TEMPERATURE, DEG F
44. RWCU DUMP FLOW, LBM/HR
45. TOTAL MAIN STEAM LINE FLOW, MLBM/HR
46. MAIN STEAM TUNNEL TEMPERATURE, DEG F
47. MAIN STEAM LINE RADIATION LEVEL, MR/HR
48. TOTAL MAIN STEAM RELIEF VALVE FLOW, LBM/HR
49. TURBINE SPEED, RPM
50. TURBINE INLET PRESSURE, PSIG
51. TURBINE STEAM FLOW, LBM/HR
52. TURBINE BYPASS VALVE STEAM FLOW, LBM/HR
53. TURBINE FIRST STAGE PRESSURE, PSIG
54. TURBINE EXHAUST HOOD TEMPERATURE, DEG F
55. SECOND STAGE REHEATER OUTLET PRESSURE, PSIG
56. SECOND STAGE REHEATER OUTLET TEMPERATURE, DEG F
57. CONDENSER VACUUM, IN HG V
58. CONDENSER HOTWELL LEVEL, INCHES
59. CONDENSER HOTWELL CONDUCTIVITY, UMHO/CM
60. CONDENSER VACUUM MAKEUP FLOW, LBM/HR
61. CONDENSER HOTWELL REJECT FLOW, LBM/HR
62. CONDENSATE DEPRESSION, BTU/LBM
63. CIRCULATING WATER INLET TEMPERATURE, DEG F
64. CIRCULATING WATER OUTLET TEMPERATURE, DEG F
65. TOTAL CIRCULATING WATER FLOW, GPM
66. CONDENSATE DEMINERA OUTLET CONDUCT, UMHO/CM
67. TOTAL FEEDWATER SYSTEM FLOW, LBM/HR
68. FEEDWATER TEMPERATURE TO REACTOR, DEG F



69. GENERATOR LOAD, MWE
70. GENERATOR REACTIVE LOAD, MVAR
71. GENERATOR STATOR AMPS, AMP
72. GENERATOR TERMINAL VOLTS, VOLT
73. GENERATOR HYDROGEN PRESSURE, PSIG
74. DIESEL GENERATOR 102 LOAD, KWE
75. DIESEL GENERATOR 103 LOAD, KWE
76. OFF-GAS SYSTEM INLET FLOW, CFW
77. OFF-GAS SYSTEM OUTLET FLOW, CFW
78. OFF-GAS RECOMBINER INLET HYDROGEN CONCENTRATION, %
79. OFF-GAS RECOMBINER OUTLET HYDROGEN CONCENTRATION, %
80. OFF-GAS SYSTEM RADIATION LEVEL, MR/HR
81. CORE SPRAY LOOP 11 PRESSURE, PSIG
82. CORE SPRAY LOOP 12 PRESSURE, PSIG
83. CORE SPRAY LOOP 11 FLOW, LBM/HR
84. CORE SPRAY LOOP 12 FLOW, LBM/HR
85. EMERGENCY CONDENSER LOOP 11 FLOW, LBM/HR
86. EMERGENCY CONDENSER LOOP 12 FLOW, LBM/HR
87. EMERGENCY CONDENSER LOOP 11 RETURN TEMPERATURE, DEG F
88. EMERGENCY CONDENSER LOOP 12 RETURN TEMPERATURE, DEG F
89. EMERGENCY CONDENSER LOOP 11 VENT RAD LEVEL, MR/HR
90. EMERGENCY CONDENSER LOOP 12 VENT RAD LEVEL, MR/HR



NINE MILE POINT DATABASE CHANGES  
AS GENERATED BY PLANT MODIFICATIONS

Modification N18040 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
18009	1,2
18041	7
19437	9
19438	6,8,9
19440	11
19845	4
19854	3
19859	8,8A,9,10,11A,13,14,17,18A
19951	8,9
19954	2,3,5,8
22020	4,5
22373	2,4,5
22381	1,2,4,11
22382	2,4,5
22383	1,4,8
22387	2
23119	1
34841	1,2,3,4
34842	1
34845	1,2,3

Modification N18042 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
19409	6,9,10
19438	1,7,8
19440	2,8,9,10
19854	1,3
22374	1,3,4



Modification N18090 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
19412	1,1A
19413	1,2
19416	2A
19417	1
19418	2
19847	---
22238	2
22239	7
22242	1
23126	1
23127	1

Modification N18266 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
18013	1
18014	1
19859	22
26726	1
N1-OP-9	---





Modification N182801 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
19437	2,6,10
19438	3
19440	2,6,10,11
19842	2
19845	2
19859	2,3,5,6,8,8A,10,10A,18,23
19951	10
22005	5,6,8,9,11,12,14,15
22302	1,2,6,7
22373	11,12,13
22374	2,3,4,5
22379	3
22381	5,6,7,8,9,10
22382	1,3
22383	3,5,6
22386	1,2

Malfunction N183582 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
26726	1,2,3,4

Modification N183583 caused the following specifications and summary to be added to the database:

SPDS Functional Specification  
SPDS Software Design Specification  
Process Computer Point Summary dated 2/15/85



Modification N183586 caused the following prints/drawings to move up in revision level:

<u>PRINT NUMBER</u>	<u>SHEET NUMBER(S)</u>
19859	18,18A
22373	3
22385	11,12,13,14,16,16A,17,17A,18,18A, 19,19A
23032	4



MALFUNCTIONS TESTED FOR ANSI/ANS 3.5 REPORT, 1986

AD01	FW17	RR09
AD05	FW21	RR13
AN01	FW25	RR17
CS02	FW29	RR21
CT03	IA01	RR25
CU04	LP01	RR28
CU08	MC01	RR29
CW01	MC04	RR32
CW02	MS01	RR36
CW05	MS02	RR40
CW09	MS04	RR44
DG02	MS07 ← <i>msiq<sup>e</sup></i>	RR48
EC01	NM03	RR52
EC02	NM11	RR56
EC05	NM19	RR60
ED01	NM29	RR64
ED02	NM37	RR68
ED06	OG01	RR72
ED10	PC01	RX01
ED14	RD01	SC01
ED18	RD04	TC01
ED22	RD05	TC03
EG01	RD33	TC07
EG05	RD36	TC11
EG09	RD37	TU02
EG13	RD41	TU06
FP03	RM05	
FP07	RP01	
FW01	RP03	
FW05	RP05	
FW09	RR01	
FW13	RR05	







Figure 1 - Nine Mile Point Unit One Control Room







Legend

- 2 Main Fire Panel #2
- A Panel A Electric/Turbine Controls
- B Panel B Relays/Turbine Controls
- C Plant Process Computer Equipment
- D Chief Shift Operator Desk
- E E Panel Main Control Console
- F F Panel NSSS
- G G Panel Nuclear Instrumentation
- H H Panel Balance of Plant
- I Instructors Console
- J J Panel Radiation Monitoring
- K K Panel ECCS
- L L Panel Primary Containment
- M M Panel RPS
- N N Panel Turbine
- P Print Rack
- S Storage Cabinets
- T Tables

Figure 2 - Nine Mile Point Unit One Simulator Control Room



NINE MILE POINT NUCLEAR STATION  
UNIT 1 PLANT REFERENCED SIMULATOR

ANNUAL REPORT: ANSI 3.5 - 1985

FOR THE YEAR


1987

Testing Conducted April - May 1987

Report Prepared June 1987

Prepared By: George Roarick

Reviewed By:

  
\_\_\_\_\_  
Supervisor, Unit #1 Operations Training


9/18/87

Date

  
\_\_\_\_\_  
Asst. Superintendent of Training

10/1/87

Date

  
\_\_\_\_\_  
Superintendent of Training

10/1/87

Date



## I. SIMULATOR INFORMATION

The purpose of this section is to provide familiarization with the Nine Mile Point Unit 1 Plant Referenced Simulator and its applicability as an operator training device.

### A. General

1. The simulator is owned by the General Physics Niagara Corporation which is a wholly-owned subsidiary of General Physics Corporation. It is used jointly by General Physics Corporation and Niagara Mohawk Power Corporation instructors. It is maintained and modified by the General Physics Corporation under the direction of Niagara Mohawk Power Corporation. The simulator was built by Singer/Link.
2. The simulator is a full scope control room simulator that simulates the Nine Mile Unit #1 plant. The plant is an 1850 Megawatt Thermal, BWR-2 plant with an electrical output of 620 Megawatts.
3. The simulator was declared ready for training on September 1, 1984.
4. The initial report on the simulator was prepared in March 1986. This report was prepared to document modification since March 1984 and to document simulator performance subsequent to the modifications.
5. In addition to training, the simulator has been used by the Operations Department to validate procedures prior to their implementation at the plant.



B. Control Room (Physical Fidelity)

1. The physical layout of the Nine Mile Point Unit #1 Control Room is shown in Attachment "A". The physical layout of the simulator is shown in Attachment "B". A comparison of these two drawings shows a high degree of similarity between the two rooms. The following differences exist:
  - a. An additional office was added next to the "SSS" office at the plant. This office does not exist in the simulator (Note 1).
  - b. The instructor's station occupies the area between Main Fire Panel 2 and the "SSS" office. A desk occupies this area at the plant (Note 1).
  - c. A manual dose assessment calculator is mounted on the wall next to the stairwell in the plant's control room. A meteorological computer is located next to it. This equipment does not exist in the simulator.
  - d. There are some minor differences in the amount and type of furniture in both rooms (Note 2).
  - e. A TV camera is mounted on the wall above the NSSS typer at the plant. An emergency lighting system occupies this location in the simulator.

NOTES:

1. Plans have been approved to move the instructor's station to an 18" high platform that is located in the same area that is occupied by the additional office.
2. Items to correct this discrepancy are on order.





## 2. Panels and Equipment

The simulator contains all of the panels that are in the control room at the plant. All front panels and the "E" console are fully simulated. The back panels are fully simulated with the exception of the following:

- a. RPS relays are installed, but are not functional.
- b. Electrical protective relays are cosmetically simulated by photos mounted in the relay enclosures.
- c. Only one of the four Transversing In-Core Probe control panels is functional.
- d. Seismic Monitors are not functional.
- e. Radwaste Solidification/Storage Building Area Radiations Monitors are not installed (Note 1).
- f. The new Service Water, Radwaste Effluent and Control Room Vent Radiation Monitors are not installed (Note 2).

### NOTES:

1. This modification is in the fabrication stage.
2. This modification is in the evaluation/approval stage but the older Service Water and Radwaste Effluent Monitors are still installed.

## 3. Systems

All systems that are operable from the Nine Mile Point Unit #1 Control Room are simulated. See Attachment "C" for a list of these systems.

## 4. Simulator Control Room Environment

The Simulator Control Room was specifically designed to duplicate as nearly as possible the reference plant control room environment. Other than the discrepancies noted in Section 1 of this part, the following differences exist:



- a. Even though the lighting is identical to that in the plant, the lighting system is not functionally interfaced with the simulator. Plans to interface the lights and the simulator are being evaluated for training value.
- b. The ambient noise level that exists in the plant's control room is not simulated. The hardware to do this exists, but is not functional. Weighing the training impact against the financial considerations have warranted not pursuing this "luxury".

Phase I of the "Detailed Control Room Design Review" was completed and implemented in both the simulator and Plant Control Room in 1986. The initial study utilized the simulator to identify potential problems and try new concepts. Phase II is complete and scheduled for implementation in both the simulator and plant control room in early 1988.


### C. Instructor Interface (Control Capabilities)

#### 1. Initial Conditions

The instructor has the capability to initialize to any one of fifty (50) sets of initial conditions. The first twenty of these sets of conditions are guarded and can only be changed by the proper code. These initial conditions are the foundation to approximately 95% of the training. These twenty sets of initial conditions are listed in Attachment "D". The remaining thirty sets of initial conditions are set by the individual instructor and can be changed at any time.

#### 2. Malfunctions

Malfunctions vary from a discrete nature (i.e., pump trip) to ones of varying degrees of severity (i.e., leaks). They are listed in Attachment "E".



### 3. Remote Functions

The instructor has the capability to simulate most in-plant operation required to back-up control room operation. The only remote function, with major training impact, that is not simulated is the ability to jumper out the Low-Low Reactor Water Level MSIV isolation signal identified in Emergency Operating Procedures. Addition of this function is currently scheduled for late 1987 - early 1988 time frame. The list of remote functions can be found in Attachment "F".

### 4. Instructor Overrides

The instructor has the capability to override most functions that are simulated. This includes meter and chart recorder indications, indicating lights, annunciators and switch functions. A few discrepancies still exist in the I/O program, but are being documented for evaluation and repair as they are identified.

### 5. Monitoring

The instructor can monitor from the instructor station, up to sixteen (16) of any of ninety (90) parameters (See Attachment G). In addition, the instructor can select up to twelve (12) of the parameters to be plotted on the line printer in the control room.

### 6. Instructor Station Controls

Consists of three (3) keyboard/CRT's, two (2) for performing simulator functions, and one (1) which is used for minor troubleshooting. There are also various buttons which perform the following:




- a. Freeze - stops (freezes) simulation at any point or restarts it.
- b. Reset/Ready - initializes the simulator to a selected set of initial conditions. This button will turn green when all controls are properly positioned.
- c. Snapshot - records and stores a set of conditions into any one of the IC's.
- d. Malfunction Clear - clears the entire malfunction tableau.
- e. Backtrack - sets the simulator to step up or back to any point in time, within 60 minutes. This includes buttons to step up or back one minute at a time and to step forward or reverse.
- f. Manual Malfunction Control - Used to increase or decrease the severity level of up to three (3) of the variable malfunctions.
- g. Annunciator Silence - silences all annunciators.
- h. Recorder Off - shuts off power to all chart recorders.
- i. Test and Lamp Test - Testing and Troubleshooting.
- j. Emergency Stop - Kills all power to computer and simulator.
- k. Computer Alarm/Acknowledge - Warns of computer malfunctions.
- l. Record and Replay - Controls the tape recorder in the Computer Room.
- m. Fast Time/Slow Time - changes speed of simulator response.

#### 7. Record/Replay

If so desired, a scenario can be recorded on magnetic tape for replay at a later date. This function is controlled from the instructor station.






D. Reference Plant Operating Procedures

The simulator is operated using the same procedures used to operate the plant. The operations department makes use of the simulator to help validate certain new procedures or procedural revisions. Procedure steps that cannot be performed on the simulator are conspicuously identified in the simulator copy in accordance with established Nuclear Training Department Instructions.

E. Changes Since Last Report

The following plant modifications have been incorporated into the simulator since the last report (March 1986):

- 78-04 CAD Valve N<sub>2</sub> Supply
- 78-24 Remove FW Level Programmer
- 78-27 MSIV Monitoring (add Process Computer points)
- 78-32 CAD Alarm State Changes
- 79-06 Change TIP Controls
- 79-24 APRM Rod Block Scope
- 80-38 Fuel Zone Level Indicator Changes
- 80-41 Add Emergency Cooling Vent to Torus
- 80-74 Add Torus Temperature Indicators
- 80-84 Diesel Generator Annunciator Addition
- 81-14 "E" Gate Digital
- 81-29 Emergency Vent Valve Change
- 82-30 Reactor Recirc. Pump Monitoring
- 82-69 Feedwater Pump Low Flow Control Valves and Recirc. Valves
- 82-71 Powerboards 102/103 Undervoltage Relays
- 82-80 Core Spray Valve Logic Changes/Emergency Cooling High Rad
- 82-93 TIP Changeout to Gamma Detectors
- 83-29 Control Room LED Displays
- 83-53 Scriba Sub-Station Retirement
- 83-58 Revisions to Integrated Cosmetic Package and SPD's
- 83-61 Control Room Ventilation
- 83-89 #13 IAC Cooling Water Changeover
- 84-58 Feedwater Pump Control
- 85-26 ADS Inhibit



## II. SIMULATOR DESIGN DATA


The initial design data for the simulator is listed in the original database document on file in the simulator library and Simulator Configuration Management System. Plant modification design data for all modifications incorporated in the simulator prior to March 1986 are contained in the last annual report (March 1986). Documentation, data changes and test results for modification incorporated since March 1986 (see Part I, Section E) are contained in Attachment "H".

## III. SIMULATOR TESTS (PERFORMANCE TESTING)

During the April - May 1987 time frame, testing was done to verify real time operation, steady state and normal operation, transient performance and malfunction response. Documentation of these tests is available in the simulator database and records under the title "Simulator Performance Test Data - May 1987".


### A. Computer Real Time Tests

Simulator real time testing was performed by measuring individual model times during steady state and transient conditions. During this testing, no frame slippage or program overtimes occurred. The simulator contains safeguards which preclude operation outside of real time with the exception of two (2) instructor controlled functions. Slow time will slow all simulator responses to one-half real time. Fast time will step up response time to only three (3) functions, reactor xenon, condenser evacuation and turbine warming.



## B. Steady State and Normal Operation

1. Simulator stability was verified by comparing heat balances (P-1's) and critical parameter printout from the start and finish of a sixty (60) minute steady-state run. The only deviation outside acceptable limits ( $\pm 2\%$ ) existed in the calculated Core thermal Power printout on the heat balance obtained at the start of the run. This was attributed to a slight feedwater transient and the nature of the simulators PPC programs. This problem has been documented and corrected. The Core Thermal Power printout on the final P-1 and on both the initial and final Computer Point Printouts were within one (1) Megawatt thermal.
2. Fidelity in performance was verified by comparing heat balances (P-1) and Balance of Plant parameters from the plant and simulator at 25%, 55% 76% and 100% of rated power.
  - a. 25% Power - one of the most significant differences was plant efficiency. Plant data shows 125 MWE at 467 MWT while the simulator shows 164 MWE at 484 MWT. This in 26.7% eff. vs 33.8% eff. Plant data shows mismatching flows between the five recirc. pumps which, on the simulator is exactly equal. Plant data also shows a mismatch between level columns 11 and 12, which are also exactly equal on the simulator. Plant data for total steam flow is significantly different from simulator data, but the plant data appears incorrect.
  - b. 55% Power - The same problems with water level and plant efficiency were also evident at this power level. The plant was able to achieve the same power level with significantly less recirc. flow. The problem needs further investigation. The simulator is modeled for middle of cycle and the plant data is beginning of cycle. The difference in total steam flow also fall outside of tolerances and will need further investigation.



- c. 76% Power - The same problems with plant efficiency and water level that were previously noted were also present at this power level. Again the plant achieved this power level with less recirc flow. As stated before, this will be further investigated. The APRM readings were also outside of the acceptable tolerances, but this is attributed to the differences in the gain adjustment factors.
- d. 100% Power - The same problems with plant efficiency and water levels still exist. Recirc Pumps 12 and 14 flows were outside the tolerances. These flows differed  $\pm 2\%$  from the other three loops. The simulator shows all recirc. pump flows as being equal.

Except as noted above, all other parameters compared were within the acceptable tolerances. The problems with mismatching recirc. pump flows and water levels have no significant training impact. The problems with plant efficiency and power to flow relationship are documented and will be corrected.

### C. Transient Tests

- 1. The following transients are FSAR analyzed and were run on the simulator in real time.
  - a. Simultaneous trip of all feedwater pumps (compared with FSAR transient "Feedwater Malfunction, Zero Flow). The FSAR shows an increase in recirc. flow due to changes in two-phase flow. The simulator doesn't model two-phase flow closely enough to produce this; therefore, it doesn't change. This discrepancy has no training impact and will not be discussed further.
  - b. Simultaneous Closure of MSIV's - Consistent with FSAR.





- c. Simultaneous Trip of all Recirc Pumps - Consistant with FSAR.
  - d. Single Recirc. Pump Trip - The simulator shows a much more pronounced decrease and recovery of recirc. flow than the FSAR. The other parameters responded as predicted with regards to recirc. flow. Reactor Pressure matches the FSAR analysis.
  - e. Design Bases Loss of Coolant - Simulator response was consistent with the FSAR with the exception of one parameter. Drywell pressure spiked at approximately 22 psig in 31 seconds on the simulator. The FSAR predicts a pressure spike of 33 psig in two seconds. A discrepancy report has been written and this problem will be addressed by the simulator support group.
  - f. Design Bases Main Steam Line Break - The simulator response was consistent with FSAR results.
2. The following transients are not analyzed in the FSAR but are required by the standard (ANSI 3.5-1985).
- a. Manual Reactor Scram - The simulator was consistent with predicted response.
  - b. Turbine Trip at 40% Power (no scram) - The simulator was consistent with predicted response.
  - c. Maximum Ramp of Power; 100% to 75%; 75% to 100% - The simulator was consistent to predicted response.
  - d. MSIV closure with a stuck open ERC (No high pressure ECCS systems available) - Simulator was consistent with predicted response.




3. The following transients are not required by the standard (ANSI 3.5 - 1985) but were run because data exists in the FSAR.

- a. Turbine Trip without Bypass
- b. Recirc Pump Stall
- c. Inadvertant actuation of an ERV
- d. Safety Valve Actuation
- e. EPR/MPR Failure

In all cases, the simulator response was consistent with FSAR predictions.

D. Malfunction Test

During the course of testing to prepare this report, 25% of the existing malfunctions listed in Attachment "E" were tested in addition to those needed to obtain the data in Section C of the report. The malfunctions tested are listed in Attachment "I". During the course of performance testing, the malfunction and evolutions required for operator training by 10CFR55, "Operator Licenses", were conducted at least once. Minor discrepancies were identified while performance testing malfunctions. None of these problems have any significant training impact and will be addressed in accordance with NTI 4.5.3, "Simulator Configuration Management".



#### IV. SIMULATOR CONFIGURATION MANAGEMENT (DISCREPANCY RESOLUTION AND UPGRADING)


Discrepancy resolution and modifications are handled in accordance with NTI 4.5.3 "Simulator Configuration Management". A personal computer has been set up as a terminal for Niagara Mohawk Power Corporation's Nuclear Divisions' Configuration Management System. This system tracks plant modifications and all plant documents. A special program has been set up in this system to document plant modifications that impact the simulator and track associated data base changes. In addition to the Configuration Management System, other computer programs exist for tracking discrepancy reports and simulator database changes (modifications). All discrepancies and modifications are evaluated for training impact.

NOTE: All data collected and analyzed to formulate this report are on file at the Nine Mile Point Nuclear Training Center and are available for review.









Legend

- 2 Main Fire Panel #2
- A Panel A Electric/Turbine Controls
- B Panel B Relays/Turbine Controls
- C Plant Process Computer Equipment
- D Chief Shift Operator Desk
- E E Panel Main Control Console
- F F Panel NSSS
- G G Panel Nuclear Instrumentation
- H H Panel Balance of Plant
- I Instructors Console
- J J Panel Radiation Monitoring
- K K Panel ECCS
- L L Panel Primary Containment
- M M Panel RPS
- N N Panel Turbine
- P Print Rack
- S Storage Cabinets
- T Tables
- O Procedures
- B/S Bookshelf
- F/C False Column
- F/S False Stairway
- F/D False Door
- R/T Radio/Telephone Equipment




Figure 2 - Nine Mile Point Unit One Simulator Control Room

ATTACHMENT B



## Attachment C

### SYSTEMS FULLY SIMULATED

1. Nuclear Boiler and Instrumentation
2. Reactor Recirculation System
  - a. Reactor Recirculation Loops
  - b. Boiler Process Instrumentation
  - c. Recirculation Flow Control
3. Control Rod Drive and Hydraulics System (CRDHS)
4. Reactor Manual Control System (RMCS)
5. Reactor Core (Physics and Thermodynamics)
  - a. Reactor Core Neutron Kinetics
  - b. Reactor Core Thermodynamics
6. Rod Worth Minimizer (RWM)
7. Main Steam Systems
  - a. Main Steam and Main Steam Bypass Systems
  - b. Moisture Separators - Reheaters
  - c. Extraction Steam System
  - d. Auxiliary Steam System
8. Reactor Water Cleanup System
9. Nuclear Instrumentation System
  - a. Source Range Monitor (SRM) System
  - b. Intermediate Range Monitor (IRM) System
  - c. Local Power Range Monitoring (LPRM) System
  - d. Average Power Range Monitoring (APRM) System
  - e. Rod Block Monitor (RBM) System
  - f. Traversing In-Core Probe (TIP) System
10. Reactor Protection System
11. Simulation of the Primary Containment and Isolation System
  - a. Primary Containment
  - b. Primary Containment Isolation System
12. Secondary Containment
13. Emergency Ventilation
  - a. Reactor Building Ventilation
  - b. Turbine Building Ventilation
  - c. Building Ventilation
14. Primary Containment Atmosphere Control and Sampling System



15. Emergency Core Cooling Systems
  - a. Automatic Depressurization and pressure Relief System
  - b. Core Spray
  - c. High Pressure Coolant Injection (HPCI) System
  - d. Containment Spray
  - e. Emergency Cooling System
16. Shutdown Cooling
17. Standby Liquid Control (SLC) System
18. Condensate and Feedwater System
  - a. Condensate System
  - b. Condensate Demineralizer System
  - c. Feedwater System
  - d. Condensate Storage and Transfer System
  - e. Reactor Vessel Level Control System
  - f. Feedwater Heaters, Vents and Drains
19. Off-Gas Recombiner and Condenser Air Removal
20. Main Condenser
21. Circulating Water System
22. Reactor Building Closed Loop Cooling
23. Turbine Building Closed Loop Cooling
24. Service Water System
25. Instrument, Service and Breathing Air
26. Area Radiation Monitoring System
27. Process Radiation Monitoring System
28. Ventilation Radiation Monitoring System
29. Main Turbine and Turbine Control
  - a. Turbine Oil System
  - b. Turbine Kinematics
  - c. Turbine Mechanics
  - d. Turbine Supervisory and Safety System
  - e. Gland Seal System
  - f. Low Pressure Hood Spray System
  - g. Moisture Separator and Reheat System
  - h. Main Turbine Electro-Hydraulic Control System



30. Plant Electrical System

- a. Main Generator and Auxiliary Systems
  - 1. Main Generator Synchronous Machine
  - 2. Excitation and Voltage Regulator System
  - 3. Synchroscope
  - 4. Hydrogen Cooling System
  - 5. Stator and Iso-Phase Duct Cooling System
  - 6. Hydrogen Seal Oil System
- b. Electrical Distribution System
  - 1. Buses and Transformers
  - 2. Breakers
  - 3. Currents, Voltages and Frequencies
  - 4. DC Electrical Distribution and Control
  - 5. Power System Electrical Grid
- c. Diesel Generators

31. Containment Atmosphere Dilution, Vent and Purge System

32. Radiation Waste Disposal System Containment Equipment and Floor Drain Sump

33. Plant Carbon Dioxide System

34. Diesel Fire Pump and Pressurized Water Fire System

35. Fire Control Ventilation Systems

36. Control Room Heating, Ventilation and Air Conditioning

37. Communication System

38. Plant Process Computer System

- a. Applicable Experience

39. Meteorological Experience

40. Plant Annunciators and Fire System Alarm





X

ATTACHMENT D

GUARDED INITIAL CONDITIONS

<u>IC #</u>	<u>DESCRIPTION</u>
1.	Cold Iron - Rx is S/D and C/D, all systems off-line but electrical distribution
2.	Cold Startup - All support systems on-line, ready to commence rod pull
3.	Cold Startup - 5 rods subcritical
4.	Heatup 140°F - Rx in heating range
5.	Heatup 280°F - Rx in heating range
6.	Heatup 900 psig - Rx in heating range
7.	NOP, NOT, 1% Power
8.	Shutdown - inserting Rod Group 76
9.	Shutdown - Mode Switch in S/U
10.	Shutdown - All Rods In
11.	Turbine Startup - Turbine Warm
12.	Feedwater Pump #13 Startup
13.	50% Power - Preconditioning
14.	100% Power - Middle of Cycle
15.	Full Power - End of Cycle
16.	-Reserved for Future Use
17.	-Reserved for Future Use
18.	-Reserved for Future Use
19.	Cooldown - 200 psig
20.	Cooldown - SDC in Service



ATTACHMENT E

NINE MILE POINT UNIT ONE MALFUNCTIONS

AD01 ADS FAILURE TO INITIATE - PRIMARY VALVES  
AD02 ADS FAILURE TO INITIATE - COMPLETE  
AD03 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - SOLENOID  
AD04 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - VALVE LEAKS  
AD05 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - OPENS  
INADVERTENTLY  
AD06 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - STUCK OPEN  
AN01 CONTROL ROOM ANNUNCIATOR SYSTEM FAILURE  
CS01 CORE SPRAY PUMP TRIP (111, 112, 121, 122 OR ANY)  
CS02 CORE SPRAY TOPPING PUMP TRIP (111, 112, 121, 122 OR ANY)  
CS03 CORE SPRAY INBOARD INJECTION VALVE FAILURE TO OPEN (IV40-01, IV40-09,  
IV40-11, IV40-10 OR ANY)  
CT01 CONTAINMENT SPRAY PUMP TRIP (111, 112, 121, 122 OR ANY)  
CT02 CONTAINMENT SPRAY RAW WATER PUMP TRIP (111, 112, 121, 122 OR ANY)  
CT03 CONTAINMENT SPRAY HEAT EXCHANGER (111, 112, OR BOTH) TUBE LEAK  
CU01 COOLANT LEAKAGE INSIDE PRIMARY CONTAINMENT  
CU02 REACTOR WATER CLEANUP PUMP TRIP (11, 12 OR BOTH)  
CU03 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS OPEN  
CU04 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS  
CLOSED  
CU05 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
OPEN  
CU06 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
CLOSED  
CU07 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS OPEN  
CU08 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS  
CLOSED  
CU09 REACTOR WATER CLEANUP NON-REGENERATIVE HEAT EXCHANGER TUBE LEAK  
CU10 REACTOR WATER CLEANUP DEMINERALIZER RESIN DEPLETION (11, 12 OR BOTH)  
CU11 COOLANT LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
CW01 HIGH RADIATION IN SERVICE WATER  
CW02 SERVICE WATER PUMP TRIP (11, 12 OR BOTH)



CW03 EMERGENCY SERVICE WATER PUMP TRIP (11, 12 OR BOTH)  
 CW04 REACTOR BUILDING CLOSED LOOP COOLING (11, 12, 13 OR ANY) PUMP TRIP  
 CW05 TURBINE BUILDING CLOSED LOOP COOLING PUMP TRIP (11, 12 OR BOTH)  
 CW06 CIRCULATING WATER PUMP TRIP (11, 12 OR :BOTH)  
 CW07 CIRCULATING WATER EXPANSION JOINT LEAKAGE  
 CW08 CIRCULATING WATER INTAKE STRUCTURE ICING  
 CW09 LOSS OF DRYWELL COOLING  
 CW10 MAIN CONDENSER TUBE LEAK  
 DG01 DIESEL GENERATOR FAILURE TO START (102, 103 OR BOTH)  
 DG02 DIESEL GENERATOR TRIP (102, 103 OR BOTH)  
 EC01 STEAM LEAKAGE INSIDE PRIMARY CONTAINMENT  
 EC02 STEAM LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
 EC03 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS OPEN (IV39-05, IV39-06 OR BOTH)  
 EC04 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS TO OPEN (IV39-05, IV39-06 OR BOTH)  
 EC05 EMERGENCY COOLING SYSTEM EMERGENCY CONDENSER MAKEUP CONTROL VALVE FAILS CLOSED (LCV60-17, LCV60-18 OR BOTH)  
 EC06 EMERGENCY CONDENSER TUBE LEAK (111, 121 OR BOTH)  
 ED01 LOSS OF OFF-SITE 115 KV POWER SOURCES (LIGHTHOUSE HILL-JAF, OSWEGO STEAM, OR BOTH)  
 ED02 BATTERY CHARGER AND EMERGENCY LIGHTING SUPPLY MOTOR GENERATOR TRIPS (161, 171 OR BOTH)  
 ED03 COMPUTER POWER SUPPLY MOTOR GENERATOR TRIPS (167)  
 ED04 AC POWERBOARD ELECTRICAL FAULT (PB11)  
 ED05 AC POWERBOARD ELECTRICAL FAULT (PB12)  
 ED06 AC POWERBOARD ELECTRICAL FAULT (PB101)  
 ED07 AC POWERBOARD ELECTRICAL FAULT (PB102)  
 ED08 AC POWERBOARD ELECTRICAL FAULT (PB103)  
 ED09 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION A)  
 ED10 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION B)  
 ED11 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION C)  
 ED12 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION A)  
 ED13 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION B)  
 ED14 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION C)  
 ED15 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION A)  
 ED16 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION B)  
 ED17 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION C)



ED18 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION A)  
 ED19 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION B)  
 ED20 AC POWERBOARD ELECTRICAL FAULT (PB17 SECTION A)  
 ED21 AC POWERBOARD ELECTRICAL FAULT (PB18 SECTION B)  
 ED22 DC POWERBOARD ELECTRICAL FAULT (11, 12 OR BOTH)  
 ED23 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL  
 ED24 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - ALTERNATE  
 ED25 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL AND ALTERNATE  
 EG01 MAIN GENERATOR TRIP - ELECTRICAL FAULT  
 EG02 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - INCREASE  
 EG03 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - DECREASE  
 EG04 MAIN GENERATOR CORE INTERNAL HEATING  
 EG05 MAIN TRANSFORMER LOSS OF COOLING  
 EG06 GENERATOR HYDROGEN COOLING SYSTEM LEAKAGE  
 EG07 GENERATOR HYDROGEN MAIN SEAL OIL PUMP FAILURE  
 EG08 GENERATOR HYDROGEN EMERGENCY SEAL OIL PUMP FAILURE  
 EG09 STATOR COOLING PUMP TRIP (11, 12 OR BOTH)  
 EG10 LOSS OF CONTROL AIR TO 345 KV BREAKER (R-915, R-925 OR BOTH)  
 EG11 POWER GRID NETWORK LOAD TRANSIENT - INCREASE  
 EG12 POWER GRID NETWORK LOAD TRANSIENT - DECREASE  
 EG13 STATOR WATER COOLING DEMINERALIZER RESIN DEPLETION  
 FP01 DIESEL FIRE PUMP FAILURE  
 FP02 ELECTRIC FIRE PUMP FAILURE  
 FP03 AC FOAM PUMP FAILURE  
 FP04 DC FOAM PUMP FAILURE  
 FP05 TURBINE ISLAND FIRE DETECTION (D-1195, D-1155, D-1165, D-1175,  
 D-1061, D-1114, D-1131 OR ANY)  
 FP06 CONTROL ROOM FIRE DETECTION (FIRE PANEL 2, CONTROL CONSOLE, "L"  
 PANEL, "K" PANEL, "H" PANEL, "F" PANEL, "A" PANEL OR ANY)  
 FP07 TURBINE BUILDING FIRE DETECTION (DA-22092MG, DA-2083M, DA-2081S,  
 DA1092E, D-2102 OR ANY)  
 FP08 DIESEL ROOM FIRE DETECTION (DX-2113A, DX-2113B, DX-02141A, DA-2141,  
 DX-2151B, DA-2151, D-2151 OR ANY)  
 FP09 AUXILIARY CONTROL ROOM/cable spreading room fire detection (d-3031PL,  
 DX-3031A, DX-3111B, WD-8131, WD-8082 OR ANY)  
 FP10 REACTOR BUILDING FIRE DETECTION (DX-4217A, DA-4116W, DA-4076E,  
 D-4207, D-4156, SP-4126, D-4086 OR ANY)





FW01 CONDENSATE PUMP TRIP (11, 12, 13 OR ANY)  
 FW02 FEEDWATER BOOSTER PUMP TRIP (11, 12, 13 OR ANY)  
 FW03 FEEDWATER PUMP TRIP (11, 12 OR BOTH)  
 FW04 SHAFT DRIVEN FEEDWATER PUMP 13 FAILURE  
 FW05 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO ENGAGE  
 FW06 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO DISENGAGE  
 FW07 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS HIGH  
 FW08 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS LOW  
 FW09 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS HIGH  
 FW10 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS LOW  
 FW11 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS HIGH  
 FW12 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS LOW  
 FW13 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS AS IS  
 FW14 FEEDWATER MASTER CONTROLLER FAILS HIGH  
 FW15 FEEDWATER MASTER CONTROLLER FAILS LOW  
 FW16 FEEDWATER MASTER CONTROLLER FAILS AS IS  
 FW17 CONDENSATE DEMINERALIZER DEPLETION  
 FW18 FEEDWATER CONDUCTIVITY INCREASE  
 FW19 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS OPEN  
 FW20 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS CLOSED  
 FW21 FEEDWATER BOOSTER PUMP RECIRCULATION VALVE FAILS OPEN (FCV 51-58, FCV  
 51-59, FCV 51-60 OR ANY)  
 FW22 FEEDWATER HEATER TUBE LEAK  
 FW23 FEEDWATER PUMP RECIRCULATION VALVES FAIL OPEN (11, 12, 13 OR ANY)  
 FW24 FEEDWATER CONTROL VALVE FAILS CLOSED (13A, 13B OR BOTH)  
 FW25 THREE MILE ISLAND ACCIDENT (BWR EQUIVALENT)  
 FW26 CONDENSATE BYPASS SPRAY TO MAIN CONDENSER FLOW CONTROL VALVE (FCV  
 50-22) FAILS CLOSED  
 FW27 LOSS OF COMPENSATION TO FEEDWATER FLOW TRANSMITTER  
 FW28 HPCI MODE FAILURE TO INITIATE (11, 12 OR BOTH)  
 FW29 HPCI MODE INADVERTANT INITIATION (11, 12 OR BOTH)  
 HV01 REACTOR BUILDING EXHAUST FAN TRIP (11, 12 OR BOTH)  
 HV02 EMERGENCY VENTILATION FAN TRIP (11, 12 OR BOTH)  
 IA01 LOSS OF INSTRUMENT AIR  
 LP01 LIQUID POISON PUMP TRIP (A, B OR BOTH)



MC01 MAIN CONDENSER AIR IN LEAKAGE  
 MC02 STEAM JET AIR EJECTOR STEAM SUPPLY VALVE FAILS CLOSED  
 MC03 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL HIGH  
 MC04 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL LOW  
 MC05 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL AS IS  
 MC06 EXPLOSION IN AIR EJECTOR DISCHARGE PIPING  
 MS01 STEAM LEAK RUPTURE OUTSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
 MS02 MSIV DISC SEPARATES FROM STEM  
 MS03 ONE MSIV FAILS CLOSED (VALVE 122)  
 MS04 STEAM LINE RUPTURE INSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
 MS05 TURBINE STEAM SEAL REGULATOR FAILS CLOSED  
 MS06 MOISTURE SEPARATOR DRAIN TANK LEVEL CONTROL FAILS LOW  
 MS07 FIRST STAGE REHEATER 111 STEAM SUPPLY VALVE CLOSSES  
 MS08 SECOND STAGE REHEATER 112 STEAM SUPPLY VALVE CLOSSES  
 MS09 SECOND STAGE REHEATER 112 DRAIN TANK LEVEL CONTROL FAILS LOW  
 MS10 LOSS OF EXTRACTION STEAM TO HIGH PRESSURE FEEDWATER HEATER (115, 125,  
 135 OR ANY)  
 MS11 LOSS OF COMPENSATION TO STEAM FLOW TRANSMITTER  
 NM01 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - UPSCALE  
 NM02 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - DOWNSCALE  
 NM03 SRM CHANNEL RECORDER FAILURE (RED, BLACK OR BOTH PENS)  
 NM04 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - INOPERATIVE  
 NM05 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - UPSCALE, RECORDER  
 INOPERATIVE  
 NM06 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - DOWNSCALE  
 NM07 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - RECORDER  
 NM08 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - INOPERATIVE  
 NM09 SRM CHANNEL (11, 12, 13, 14 OR ANY) DETECTOR STUCK  
 NM10 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM11 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM12 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 RECORDER  
 NM13 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM14 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE



NM15 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM16 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 RECORDER  
 NM17 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) INOPERATIVE  
 NM18 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) DETECTOR STUCK  
 NM19 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM20 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM21 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM22 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM23 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM24 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM25 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM26 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM27 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM28 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM29 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM30 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM31 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM33 TIP DETECTOR STUCK IN CORE  
 NM34 ANY LPRM (X-Y-J) DRIFT +/- 25%  
 NM35 ANY LPRM (X-Y-J) DRIFT +/- 25%  
 NM36 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - UPSCALE  
 NM37 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - DOWNSCALE  
 NM38 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - AS IT  
 NM39 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - INOPERATIVE  
 NM40 RECIRC FLOW CONVERTER (11, 12 OR BOTH) FAILURE - COMPARATOR  
 OG01 OFF-GAS RECOMBINER PREHEATER STEAM SUPPLY FAILS CLOSED  
 OG02 OFF-GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS OPEN  
 OG03 OFF-GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS CLOSED  
 OG04 OFF-GAS DISCHARGE TO STACK ISOLATION VALVE FAILS CLOSED  
 PC01 DRYWELL TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - INCREASE  
 PC02 DRYWELL TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - DECREASE  
 PC03 PRIMARY CONTAIN LEAKAGE



PP01 FAILURE OF PLANT PROCESS COMPUTER  
 RD01 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD02 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD03 CONTROL ROD XX-YY FAILURE - ACCUMULATOR STUCK  
 RD04 CONTROL ROD XX-YY FAILURE - STUCK  
 RD05 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD06 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD07 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD08 CONTROL ROD XX-YY FAILURE - RPIS  
 RD09 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD10 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD11 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD12 CONTROL ROD XX-YY FAILURE - STUCK  
 RD13 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD14 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD15 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD16 CONTROL ROD XX-YY FAILURE - RPIS  
 RD17 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD18 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD19 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD20 CONTROL ROD XX-YY FAILURE - STUCK  
 RD21 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD22 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD23 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD24 CONTROL ROD XX-YY FAILURE - RPIS  
 RD25 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD26 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD27 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD28 CONTROL ROD XX-YY FAILURE - STUCK  
 RD29 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD30 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD31 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD32 CONTROL ROD XX-YY FAILURE - RPIS  
 RD33 CONTROL ROD BANK FAILURE TO SCRAM (BANK I, II, III, IV, V OR :ANY)  
 RD34 LOSS OF CRD INSTRUMENT AIR PRESSURE  
 RD35 CRD HYDRAULIC PUMP TRIP (11, 12 OR BOTH)  
 RD36 CRD FLOW CONTROL VALVE FAILURE - CLOSED (11, 12 OR BOTH)





RD37 RPIS FAILURE - COMPLETE SYSTEM FAILURE  
 RD38 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - WITHDRAWN  
 RD39 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - INSERT  
 RD40 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - SETTLE  
 RD41 SCRAM DISCHARGE VOLUME RUPTURE  
 RM01 DRAWER INOPERATIVE FOR ANY PROCESS RADIATION MONITOR SIMULATED  
 (INSTRUCTOR SELECT)  
 RM02 DRAWER DOWNSCALE FOR ANY AREA RADIATION MONITOR SIMULATED (INSTRUCTOR  
 SELECT)  
 RM03 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED  
 RM04 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED  
 RM05 CONTINUOUS AIR MONITOR FAILURE (TURBINE BUILDING, REACTOR BUILDING,  
 WASTE BUILDING, DRYWELL)  
 RM06 ANY PROCESS RADIATION MONITOR FAILURE  
 RP01 REACTOR TRIP POWER SUPPLY MOTOR GENERATOR (131, 141 OR BOTH)  
 RP02 CONTROL POWER SUPPLY BOTH MOTOR GENERATOR TRIPS (162, 172 OR BOTH)  
 RP03 REACTOR SCRAM  
 RP04 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - AUTOMATIC  
 RP05 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - COMPLETE  
 RP06 REACTOR VESSEL ISOLATION  
 RP07 PRIMARY CONTAINMENT ISOLATION  
 RP08 ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS)  
 RP09 EMERGENCY CONDENSER FAILS TO ISOLATE (11, 12 OR BOTH)  
 RR01 RECIRCULATION PUMP 11 DRIVE BREAKER TRIP  
 RR02 RECIRCULATION PUMP 11 FIELD BREAKER TRIP  
 RR03 RECIRCULATION PUMP 11 SEIZURE  
 RR04 RECIRCULATION PUMP 11 CONTROL SIGNAL FAILURE  
 RR05 RECIRCULATION PUMP 11 INCOMPLETE START SEQUENCE  
 RR06 RECIRCULATION PUMP 12 DRIVE BREAKER TRIP  
 RR07 RECIRCULATION PUMP 12 FIELD BREAKER TRIP  
 RR08 RECIRCULATION PUMP 12 SEIZURE  
 RR09 RECIRCULATION PUMP 12 CONTROL SIGNAL FAILURE  
 RR10 RECIRCULATION PUMP 12 INCOMPLETE START SEQUENCE  
 RR11 RECIRCULATION PUMP 13 DRIVE BREAKER TRIP  
 RR12 RECIRCULATION PUMP 13 FIELD BREAKER TRIP  
 RR13 RECIRCULATION PUMP 13 SEIZURE  
 RR14 RECIRCULATION PUMP 13 CONTROL SIGNAL FAILURE  
 RR15 RECIRCULATION PUMP 13 INCOMPLETE START SEQUENCE



RR17 RECIRCULATION PUMP 14 FIELD BREAKER TRIP  
 RR18 RECIRCULATION PUMP 14 SEIZURE  
 RR19 RECIRCULATION PUMP 14 CONTROL SIGNAL FAILURE  
 RR20 RECIRCULATION PUMP 14 INCOMPLETE START SEQUENCE  
 RR21 RECIRCULATION PUMP 15 DRIVE BREAKER TRIP  
 RR22 RECIRCULATION PUMP 15 FIELD BREAKER TRIP  
 RR23 RECIRCULATION PUMP 15 SEIZURE  
 RR24 RECIRCULATION PUMP 15 CONTROL SIGNAL FAILURE  
 RR25 RECIRCULATION PUMP 15 INCOMPLETE START SEQUENCE  
 RR26 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - HIGH  
 RR27 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - LOW  
 RR28 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - AS IS  
 RR30 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - UPSCALE  
 RR31 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - DOWNSCALE  
 RR32 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - AS IS  
 RR33 RECIRCULATION PUMP LOWER (INNER) SEAL FAILURE - PUMP 11  
 RR34 RECIRCULATION PUMP UPPER (OUTER) SEAL FAILURE - PUMP 11  
 RR35 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - UPSCALE  
 RR36 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - DOWNSCALE  
 RR37 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - AS IS  
 RR38 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - UPSCALE  
 RR39 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - DOWNSCALE  
 RR40 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - AS IS  
 RR41 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - UPSCALE  
 (ID59D)  
 RR42 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - DOWNSCALE  
 (ID59D)  
 RR43 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - AS IS  
 (ID59D)  
 RR44 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 UPSCALE (LI 36-19, CH.12)  
 RR45 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 DOWNSCALE (LI 36-19, CH.12)  
 RR46 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 AS IS (LI 36-19, CH.12)  
 RR47 RECIRCULATION PUMP DISCHARGE VALVE STEM SEPARATES FROM VALVE GATE  
 (11, 12, 13, 14, 15 OR ANY)



RR48 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
UPSCALE

RR49 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
DOWNSCALE

RR50 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
AS IS

RR51 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - HIGH

RR52 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - LOW

RR53 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - AS IS

RR54 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
HIGH

RR55 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
LOW

RR56 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
AS IS

RR57 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - HIGH

RR58 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - LOW

RR59 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - AS IS

RR60 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - HIGH

RR61 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - LOW

RR62 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - AS IS

RR63 REACTOR RECIRCULATION PUMP 12 INNER SEAL FAILURE

RR64 REACTOR RECIRCULATION PUMP 12 OUTER SEAL FAILURE

RR65 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - HIGH

RR66 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - LOW


RR67 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - OSCILLATES

RR68 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - INCREASE (11, 12,  
13, 14, 15 OR ANY)



RR69 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - DECREASE (11, 12,  
 13, 14, 15 OR ANY)  
 RR70 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - AS IS (11, 12, 13,  
 14, 15 OR ANY)  
 RR71 REACTOR SAFETY VALVE INADVERTENTLY OPENS (PSV NR28A)  
 RR72 LOSS OF LEVEL COMPENSATION TO FEEDWATER CONTROL SYSTEM (GEMAC) LEVEL  
 TRANSMITTER  
 RW01 ROD WORTH MINIMIZER FAILURE  
 RX01 FUEL CLADDING FAILURE  
 RX02 INCREASED ROD WORTH FOR ANY CONTROL ROD  
 SC01 SHUTDOWN COOLING PUMP TRIP (11, 12, 13 OR ANY)  
 SC02 SHUTDOWN COOLING HEAT EXCHANGER TUBE LEAK (11, 12, 13 OR ANY)  
 TC01 MAIN TURBINE TRIP  
 TC02 TURBINE GOVERNOR FAILS - HIGH  
 TC03 TURBINE GOVERNOR FAILS - LOW  
 TC04 ELECTRICAL PRESSURE REGULATOR FAILS - HIGH  
 TC05 ELECTRICAL PRESSURE REGULATOR FAILS - LOW  
 TC06 ELECTRICAL PRESSURE REGULATOR FAILS - OSCILLATES  
 TC07 MECHANICAL PRESSURE REGULATOR FAILS - HIGH  
 TC08 MECHANICAL PRESSURE REGULATOR FAILS - LOW  
 TC09 MECHANICAL PRESSURE REGULATOR FAILS - OSCILLATES  
 TC10 FIRST BYPASS VALVE STICKS OPEN  
 TC11 ALL BYPASS VALVES FAIL - OPEN  
 TC12 ALL BYPASS VALVES FAIL - CLOSED  
 TC13 TURBINE CONTROL VALVE FAILS CLOSED (11, 12, 13, 14 OR ANY)  
 TU01 EXHAUST HOOD SPRAY VALVE FAILS CLOSED  
 TU02 MAIN TURBINE HIGH VIBRATION BEARINGS #5 AND #6  
 TU03 MAIN TURBINE HIGH ECCENTRICITY  
 TU04 MAIN TURBINE BEARING OIL LOW PRESSURE  
 TU05 MAIN TURBINE BEARING HIGH TEMPERATURE  
 TU06 MAIN TURBINE THRUST BEARING WEAR





ATTACHMENT F

REMOTE FUNCTIONS

AD

ADS NONE

AN

ANNUNCIATOR SYSTEM NONE

CS

CORE SPRAY NONE

CT

CONTAINMENT SPRAY	RCT 1 80-43 TEST LINE TO TORUS BV	OPEN	CLOSE
	RCT 2 80-42 WASTE DISP MAN ISOLATION	OPEN	CLOSE

CU

REACTOR CLEANUP	RCU1 CU-16 PCV ND37 MANUAL ISOLATION	OPEN	CLOSE
	RCU2 CU-19 FILTER BYPASS VALVE	OPEN	CLOSE
	RCU3 CU FILTER 11 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU4 CU FILTER 12 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU5 CU DEMIN 11 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU6 CU DEMIN 12 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU7 CU-20 DEMIN BYPASS VALVES	OPEN	CLOSE

CW1

AUXILIARY WATER	RCW1 INTAKE WATER TEMPERATURE	32/80 DEG	75.00
	RCW2 INTAKE TUNNEL REVERSE FLOW	YES	NO
	RCW3 UPPER WIND SPEED	0.100 MPH	52.00
	RCW4 UPPER WIND SPED VARIATION	0/30 MPH	5.00
	RCW5 LOWER WIND SPEED	0/100 MPH	45.00
	RCW6 LOWER WIND SPEED VARIATION	0/30 MPH	5.00
	RCW7 UPPER WIND DIRECTION	0/360 MPH	5.00
	RCW8 UPPER WIND DIRECTION VARIATION	0/90 DEG	5.0
	RCW9 LOWER WIND DIRECTION	0/360 DEG	5.0
	RCW10 LOWER WIND DIRECTION VARIATION	0/90 DEG	5.00
	RCW11 AMBIENT AIR TEMPERATURE	-30/+120 DEG	90.00
	RCW12 DELTA TEMPERATURE	-10/+120 DEG	10.00

CW2

AUXILIARY WATER NONE



DG

DIESEL GENERATOR	RDG1 DG 102 GOVERNOR SPEED DROOP	SET	RESET
	RDG2 DG 103 GOVERNOR SPEED DROOP	SET	RESET

EC

EMERGENCY COOLING	REC1 IV 39-05 VALVE POSITION LIMIT	0/100%	100.00
	REC2 IV 39-06 VALVE POSITION LIMIT	0/100%	100.00

ED1

ELECTRICAL DISTRIB	RED1 SOUTH OSWEGO 115 KV BKR R10	OPEN	CLOSE
	RED2 FITZ 115 KV BKR R40	OPEN	CLOSE
	RED3 PB 13 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED4 PB 13 BUS TIE BKR SEC B-SEC C	OPEN	CLOSE
	RED5 PB 14 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED6 PB 14 BUS TIE BKR SEC B-SEC B	OPEN	CLOSE
	RED7 PB 15 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED8 PB 16 BUS TIE BKR SEC A-SEC C	OPEN	CLOSE
	RED9 MG-SET 167 AC POWER SELECT	PB16	PB17
	RED10 MG-SET 167 DC POWER SELECT	PB11	PB12
	RED11 COMPUTER POWER SUPPLY SELECT	NORM	EMER
	RED12 IC BUS 130 NORM BWR BKR	OPEN	CLOSE
	RED13 IC BUS 130 ALT PWR BKR	OPEN	CLOSE
	RED14 PB1671 BUS TIE BKR	OPEN	CLOSE
	RED15 PB131 CLOSE A-B, OPEN 13A SUPPLY	YES	NO
	RED16 PB131 CLOSE A-B, OPEN 13C SUPPLY	YES	NO
	RED17 PB141 CLOSE A-B, OPEN 14A SUPPLY	YES	NO
	RED18 PB141 CLOSE A-B, OPEN 14C SUPPLY	YES	NO

ED2

ELECTRICAL DISTRIB	RED19 PB151 CLOSE A-B, OPEN 15A SUPPLY	YES	NO
	RED20 PB151 CLOSE A-B, OPEN 15C SUPPLY	YES	NO
	RED21 PB176 CLOSE A-B, OPEN 17A SUPPLY	YES	NO
	RED22 PB176 CLOSE A-B, OPEN 16A SUPPLY	YES	NO
	RED23 BAT BD11 EQUIP SW TO ALT	BB11	BB12
	RED24 BAT BD12 EQUIP SW TO ALT	BB12	11
	RED25 PB143 FEEDER BREAKER	14A	14C

ED3

ELECTRICAL DISTRIB	NONE		
--------------------	------	--	--



EG1

MAIN GENERATOR

REG1 345 KV BKR 100 42	OPEN	CLOSE
REG2 345 KV MAN DISC 917	OPEN	CLOSE
REG3 345 KV MAN DISC 926, 927	OPEN	CLOSE
REG4 345 KV MOD SW 18	OPEN	CLOSE
REG5 345 KV BKR R915/10	OPEN	CLOSE
REG6 345 KV BKR R925/20	OPEN	CLOSE
REG7 MAIN SEAL OIL PMP STATUS	START	NEUT
REG8 EMER SEAL OIL PMP STATUS	START	NEUT
REG9 EMER SEAL OIL PMP STATUS	TRIP	AUTO
REG10 GEN STATOR COOLING PMP 11	START	NEUT
REG11 GEN STATOR COOLING PMP 11	TRIP	AUTO
REG12 GEN STATOR COOLING PMP 12	START	NEUT
REG13 GEN STATOR COOLING PMP 12	TRIP	AUTO
REG14 GENERATOR OUTPUT LINKS	OPEN	CLOSE
REG15 GEN HYDROGEN SUPPLY VALVE	OPEN	CLOSE
REG16 BACKFEED INTERLOCKS	ON	OFF

EG2

MAIN GENERATOR

NONE

FP

FIRE PROTECTION

RFP1 CITY WATER SUPPLY TO FP HDR	OPEN	CLOSE
RFP2 SUPPLY TO EMER COOL MU TANK 11	OPEN	CLOSE
RFP3 SUPPLY TO EMER COOL MU TANK 12	OPEN	CLOSE
RFP4 SUPPLY TO FEEDWATER SYSTEM	OPEN	CLOSE
RFP5 DIESEL FIRE PUMP STATUS	OFF	AUTO



FW1

## FEEDWATER

RFW1	50-10 COND PUMP 11 DISCH VLV	OPEN	CLOSE
RFW2	50-11 COND PUMP 12 DISCH VLV	OPEN	CLOSE
RFW3	50-12 COND PUMP 13 DISCH VLV	OPEN	CLOSE
RFW4	50-31 COND DEMIN BYPASS VLV	OPEN	CLOSE
RFW5	COND DEMIN 11 INLET/OUTLET VLV	OPEN	CLOSE
RFW6	COND DEMIN 12 INLET/OUTLET VLV	OPEN	CLOSE
RFW7	COND DEMIN 13 INLET/OUTLET VLV	OPEN	CLOSE
RFW8	COND DEMIN 14 INLET/OUTLET VLV	OPEN	CLOSE
RFW9	COND DEMIN 15 INLET/OUTLET VLV	OPEN	CLOSE
RFW10	COND DEMIN 16 INLET/OUTLET VLV	OPEN	CLOSE
RFW11	50-20 SJAE BYPASS FCB	0/100%	50.00
RFW12	50-40 BOOSTER PUMP 11 SUCTION V	OPEN	CLOSE
RFW13	50-39 BOOSTER PUMP 12 SUCTION V	OPEN	CLOSE
RFW14	50-38 BOOSTER PUMP 13 SUCTION V	OPEN	CLOSE
RFW15	FW HEATER STRING 11 ISOL VLVS	OPEN	CLOSE
RFW17	FW HEATER STRING 12 ISOL VLVS	OPEN	CLOSE
RFW18	DEMIN WATER STORAGE TANK REFILL	OPEN	CLOSE

FW2

## FEEDWATER

RFW19	50-16 BYPASS AROUND FCV 50-22	OPEN	CLOSE
RFW20	MANUAL OPERATION OF LCV50-15	0/100%	0.00
RFW21	MANUAL OPERATION OF LCV50-07,08	0/100%	0.00
RFW22	FW HEATER 135 ISOL VALVES	OPEN	CLOSE
RFW23	HOTWELL LEVEL CONTROL	MAN	AUTO

FW3

## FEEDWATER

NONE

HV

## HVAC

NONE

IA

## INSTRUMENT AIR

RIA1	INST AIR SUP TO BREATHING AIR	OPEN	CLOSE
RIA2	BRW-G-6 WASTE DISPOSAL XTIE	OPEN	CLOSE
RIA3	94-42 CONT SPRAY AIR RCVR ISOL	OPEN	CLOSE
RIA4	SERV AIR TO INST AIR BV	TRIP	RESET





LP

LIQUID POISON	RLP1 LIQ POISON PMP 11 LOCAL START	ON	OFF
	RLP2 LIQ POISON PUMP 12 LOCAL START	ON	OFF
	RLP3 DEMIN WATER TO LP PUMPS	OPEN	CLOSE

MC

CONDENSER	RMC1 OG-1,2 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
	RMC2 DG-3,4 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
	RMC3 MS 114,15 PRIM JET STEAM VALVES	OPEN	CLOSE
	RMC4 MS-16,1 PRIM JET STEAM VALVES	OPEN	CLOSE
	RMC5 OG-9,10 SEC JET VAPOR SUCT VALVES	OPEN	CLOSE
	RMC6 MS-19,20 SEC JET STEAM VALVES	OPEN	CLOSE
	RMC7 MS-12 SJAE PCV BYPASS	OPEN	CLOSE

MS1

MAIN STEAM	RMS1 HP FW HTR 115 RESET	TRIP	RESET
	RMS2 HP FW HTR 125 RESET	TRIP	RESET
	RMS3 HP FW HTR 135 RESET	TRIP	RESET
	RMS4 HP FW HTR STRING 11 RESET	TRIP	RESET
	RMS5 HP FW HTR STRING 12 RESET	TRIP	RESET
	RMS6 HP FW HTR STRING 13 RESET	TRIP	RESET
	RMS7 MS-8 MAIN STEAM LINE ISOL	OPEN	CLOSE
	RMS8 SPE 11 SUCTION VALVE	OPEN	CLOSE
	RMS9 SPE 12 SUCTION VALVE	OPEN	CLOSE
	RMS10 TRIP ALL FW HTR EXTR NRVS	TRIP	RESET

MS1

MAIN STEAM	NONE		
------------	------	--	--

NM1

NEUTRON MONITOR	RNM1 APRM 11 GAIN	0/100%	2.43
	RNM2 APRM 12 GAIN	0/100%	2.38
	RNM3 APRM 13 GAIN	0/100%	2.36
	RNM4 APRM 14 GAIN	0/100%	2.39
	RNM5 APRM 15 GAIN	0/100%	2.20
	RNM6 APRM 16 GAIN	0/100%	2.18
	RNM7 APRM 17 GAIN	0/100%	2.16
	RNM8 APRM 18 GAIN	0/100%	2.17

NM2

NEUTRON MONITOR	NONE		
-----------------	------	--	--

NM3

NEUTRON MONITOR.	NONE		
------------------	------	--	--



OD  
ON DEMAND

NON-FUNCTIONAL

PC  
CONTAINMENT

RPC1	NITROGEN FROM VAPORIZER	YES	NO
RPC2	201.7-13 DW CAM ISOL VLV 11	OPEN	CLOSE
RPC3	201.7-29 DW CAM ISOL VLV 12	OPEN	CLOSE
RPC4	201.40, 41 DW, TORUS TO VENT SYSTEM	OPEN	CLOSE
RPC5	201.44, 46 DW, TORUS TO ATMOS	OPEN	CLOSE
RPC6	BV201.2-135, 136 INTERLOCK DEFEAT	YES	NO
RPC7	IV201-31, 32 ISOLATION DEFEAT	YES	NO

PP  
PROCESS COMPUTER

RPP01	MEMORY PROTECT PLAN	NORM	REMOVED
-------	---------------------	------	---------

RD1  
CONTROL RODS

RRD1	301.2A CRD PUMP 11 DISCH VLV	OPEN	CLOSE
RRD2	301.2B CRD PUMP 12 DISCH VLV	OPEN	CLOSE
RRD3	301-8A CRD PUMP 11 HEAD SPRAY ISOL	OPEN	CLOSE
RRD4	301-8B CRD PUMP 12 HEAD SPRAY ISOL	OPEN	CLOSE
RRD5	301.8B CRD FLOW CONTROL VLV ISOL	NC30A	NC30B

RD2  
CONTROL RODS

NONE

RD3  
CONTROL RODS


NONE

RM1  
RAD MONITOR

NONE

RP  
RPS

RRP1	RX TRIP BUS 131 PWR SOURCE	NORM	EMER
RRP2	RX TRIP BUS 141 PWR SOURCE	NORM	EMER
RRP3	RPS BUS 11 PWR SOURCE	NORM	EMER
RRP4	BUS 12 PWR SOURCE	NORM	EMER



RR1

REACTOR RECIRC	RRR1 RECIRC MG-SETS 11 LOCKOUT RELAY	TRIP	RESET
	RRR2 RECIRC MG-SETS 12 LOCKOUT RELAY	TRIP	RESET
	RRR3 RECIRC MG-SETS 13 LOCKOUT RELAY	TRIP	RESET
	RRR4 RECIRC MG-SETS 14 LOCKOUT RELAY	TRIP	RESET
	RRR5 RECIRC MG-SETS 15 LOCKOUT RELAY	TRIP	RESET

RR2

REACTOR RECIRC	NONE
----------------	------

RR3

REACTOR RECIRC	NONE
----------------	------

RR4

REACTOR RECIRC	NONE
----------------	------

RW

ROD WORTH MINIMIZER	RRW1 CONTROL ROD SEQUENCE SELECT	B	A
---------------------	----------------------------------	---	---

RX

REACTOR CORE	NONE
--------------	------

SC


SHUTDOWN COOLING	NONE
------------------	------

TC

TURBINE CONTROL	RTC1 REACTOR FLOW LIMIT	0-120%	120.00
	RTC2 CONTROL VALVE LIMIT	0-120%	100.00

TU

MAIN TURBINE	NONE
--------------	------



ATTACHMENT "G"

MONITORED PARAMETERS

1. CORE REACTIVITY DK/K
2. CORE THERMAL POWER, %
3. CORE FLOW, LBM/HR
4. CORE PLATE DIFFERENTIAL PRESSURE, PSIG
5. CORE BORON CONCENTRATION, PPM
6. CORE AVERAGE VOID FRACTION, %
7. CORE MINIMUM CRITICAL POWER RATIO
8. CORE MAXIMUM LINEAR HEAT GENERATION, KW/FT
9. CORE INLET SUB COOLING, BTU/LBM
10. CORE AVERAGE FUEL TEMPERATURE, DEG F
11. CORE AVERAGE CLADDING TEMPERATURE, DEG F
12. CORE AVERAGE EXIT QUALITY, %
13. (SPARE)
14. (SPARE)
15. REACTOR COOLANT ACTIVITY, UCI/ML
16. REACTOR COOLANT CONDUCTIVITY, UMHO/CM
17. REACTOR HEATUP/COOLDOWN RATE, DEG F/HR
18. REACTOR LEVEL-NARROW RANGE, INCHES
19. REACTOR LEVEL-WIDE RANGE, FEET
20. REACTOR PRESSURE, PSIG
21. RECIRCULATION LOOP 11 FLOW, LBM/HR
22. RECIRCULATION LOOP 12 FLOW, LBM/HR
23. RECIRCULATION LOOP 13 FLOW, LBM/HR
24. RECIRCULATION LOOP 14 FLOW, LBM/HR
25. RECIRCULATION LOOP 15 FLOW, LBM/HR
26. RECIRCULATION LOOP 11 SUCTION TEMPERATURE, DEG F
27. RECIRCULATION LOOP 12 SUCTION TEMPERATURE, DEG F
28. RECIRCULATION LOOP 13 SUCTION TEMPERATURE, DEG F
29. CRD SYSTEM FLOW, LBM/HR
30. DRYWELL PRESSURE, PSIG
31. DRYWELL AVERAGE TEMPERATURE, DEG F
32. DRYWELL HYDROGEN CONCENTRATION, %
33. DRYWELL OXYGEN CONCENTRATION, %





34. SUPPRESSION CHAMBER PRESSURE, PSIG
35. SUPPRESSION POOL WATER TEMPERATURE, DEG F
36. SUPPRESSION POOL WATER LEVEL, FEET
37. SRM COUNT RATE, CPS
38. SRM PERIOD, SEC
39. APRM POWER LEVEL, %
40. CORE XENON CONCENTRATION, % OF FULL POWER EQU
41. RWCU SYSTEM PRESSURE, SPIG
42. RWCU SYSTEM FLOW, LBM/HR
43. RWCU NON-REGEN HEAT EXCHAN OUTLET TEMPERATURE, DEG F
44. RWCU DUMP FLOW, LBM/HR
45. TOTAL MAIN STEAM LINE FLOW, LBM/HR
46. MAIN STEAM TUNNEL TEMPERATURE, DEG F
47. MAIN STEAM LINE RADIATION LEVEL, MR/HR
48. TOTAL MAIN STEAM RELIEF VALVE FLOW, LBM/HR
49. TURBINE SPEED, RPM
50. TURBINE INLET PRESSURE, PSIG
51. TURBINE STEAM FLOW, LBM/HR
52. TURBINE BYPASS VALVE STEAM FLOW, LBM/HR
53. TURBINE FIRST STAGE PRESSURE, PSIG
54. TURBINE EXHAUST HOOD TEMPERATURE, DEG F
55. SECOND STAGE REHEATER OUTLET PRESSURE, PSIG
56. SECOND STAGE REHEATER OUTLET TEMPERATURE, DEG F
57. CONDENSER VACUUM, IN HG V
58. CONDENSER HOTWELL LEVEL, INCHES
59. CONDENSER HOTWELL CONDUCTIVITY, UMHO/CM
60. CONDENSER VACUUM MAKEUP FLOW, LBM/HR
61. CONDENSER HOTWELL REJECT FLOW, LBM/HR
62. CONDENSATE DEPRESSION, BTU/LBM
63. CIRCULATING WATER INLET TEMPERATURE, DEG F
64. CIRCULATING WATER OUTLET TEMPERATURE, DEG F
65. TOTAL CIRCULATING WATER FLOW, GPM
66. CONDENSATE DEMINERA OUTLET CONDUCT, UMHO/CM
67. TOTAL FEEDWATER SYSTEM FLOW, LBM/HR
68. FEEDWATER TEMPERATURE TO REACTOR, DEG F
69. GENERATOR LOAD, MWE
70. GENERATOR REACTIVE LOAD, MVAR



71. GENERATOR STATOR AMPS, AMP
72. GENERATOR TERMINAL VOLTS, VOLT
73. GENERATOR HYDROGEN PRESSURE, PSIG
74. DIESEL GENERATOR 102 LOAD, KWE
75. DIESEL GENERATOR 103 LOAD, KWE
76. OFF-GAS SYSTEM INLET FLOW, CFW
77. OFF-GAS SYSTEM OUTLET FLOW, CFW
78. OFF-GAS RECOMBINER INLET HYDROGEN CONCENTRATION, %
79. OFF-GAS RECOMBINER OUTLET HYDROGEN CONCENTRATION, %
80. OFF-GAS SYSTEM RADIATION LEVEL, MR/HR
81. CORE SPRAY LOOP 11 PRESSURE, PSIG
82. CORE SPRAY LOOP 12 PRESSURE, PSIG
83. CORE SPRAY LOOP 11, FLOW, LBM/HR
84. CORE SPRAY LOOP 12 FLOW, LBM/HR
85. EMERGENCY CONDENSER LOOP 11 FLOW, LBM/HR
86. EMERGENCY CONDENSER LOOP 12 FLOW, LBM/HR
87. EMERGENCY CONDENSER LOOP 11 RETURN TEMPERATURE, DEG F
88. EMERGENCY CONDENSER LOOP 12 RETURN TEMPERATURE, DEG F
89. EMERGENCY CONDENSER LOOP 11 VENT RAD LEVEL, MR/HR
90. EMERGENCY CONDENSER LOOP 12 VENT RAD LEVEL, MR/HR




X

ATTACHMENT H

SIMULATOR MODIFICATION DATA BASE CHANGES AND TEST RESULTS

- A. All the modifications listed in Part I, Section E of this report were operationally reverified on 27 May 1987. All modifications were functionally correct with the exception of:
1. 78-27 MSIV Monitoring - MSIV repositioning will initiate alarm printouts, but not the right ones.
  2. 83-61 Control Room Emergency Vents - Only the hardware portion of this modification is presently incorporated.
  3. 84-58 Feedwater Pump Control - Low Flow Bypass valves fail to close on HPCI initiation.
- B. Below is a list of Data Base changes by Modification Number:

<u>Mod #</u>	<u>Document #</u>	<u>Section</u>	<u>To Rev #</u>
N1-7804	C-180140C	3	5
"	C-35628-C	4	9
"	C-35674-C	-	1
"	C-27120-C	-	2
"	A-22110-C	36	2
"	"	23	3
"	B-22111-C	1	5
"	C-18014-C	1	1
"	"	2	20
"	C-22136-C	-	8
"	C-22137-C	-	10
"	C-18349-C	2	3
"	C-26990-C	2	2
"	C-22101-C	4A	1
N1-7824	No Document Changes		
N1-7827	C-19859-C	11	17
"	C-22374-C	1	28
"	C-22380-C	2	12
"	C-23088-C	1	16
"	C-22376-C	4	8
"	C-22025-C	3	6
"	C-220374C	5	8
"	"	7	18
"	C-22020-C	13	3
"	"	14	2
"	C-19859-C	4	21
"	"	7	21
"	C-19437-C	7	18
N1-7832	C-19859-C	14	18
"	"	21	6
N1-7906	C-22379-C	6	10
N1-7924	N1-ST-W6	-	6



X

MOD #

PLACED ON DATABASE

SHEET #

TO REV #

N1-8038

C-19954-C	2	8
"	3	5
"	5	5
"	8	7
C-19859-C	4	21
"	7	21
"	8	32
"	9	16
"	10	19
"	11	17
"	12	21
"	13	20
"	14	21
C-22374-C	1	28
"	2	6
"	3	19
"	4	32
C-22382-C	1	18
"	2	8
"	3	18
"	4	1
"	5	2
C-19440-C	11	3
C-19438-C	9	0
C-19437-C	10	3
C-34854-C	1	0
"	2	0
"	3	0
"	4	1
"	5	0
"	6	0
C-34853-C	1	0
"	2	0
"	3	0
"	4	0
"	5	0
"	6	0
"	6	0
C-22374-C	5	8
C-19859-C	10A	5
C-19440-C	6	14
	7	16
	10	6
C-19438-C	8	1
C-19437-C	6	14
"	7	18
"	9	12
C-23146-C	9	7
"	11	5
"	15	1
C-23145-C	3	7
C-22025-C	3	6
C-19957-C	1	22





MOD #

PLACED ON DATABASE

SHEET #

TO REV #

N1-8038

C-19866-C

0

5

C-19425-C

6

22

C-19424-C

5

20

C-19423-C

5

20

C-18015-C

0

16

C-19951-C

8

13

"

9

4

C-19854-C

3

10

N1-8041

C-18017-C

-

14

C-18006-C

2

5

C-18055-C

-

14

C-18355-C

1

15

C-18357-C

-

16

B-34028-C

2

1

C-19913-C

4

42

"

5

41

"

7

75

"

8

79

"

9

60

"

10

76

"

11

61

"

12

73

C-19914-C

7

29

C-19474-C

1

26

C-22442-C

2

11

"

3

16

"

4

12

C-23213-C

4

9

"

11

14

C-23214-C

10

8

"

11

5

"

18

3

"

12

4

"

13

4

"

25

12

"

26

5

C-23273-C

1

2

"

2

2

C-22381-C

10

12

"

8

18

"

11

1

C-34185-C

1

7

C-18006-C

9

8

C-19437-C

10

3

C-19859-C

9

11

C-19951-C

9

1

C-22381-C

5

12

"

11

New

C-22373-C

2

12

"

3

7

C-22381-C

2

12

"

4

10

"

10

10



X

MOD #


PLACED ON DATABASE

SHEET #

TO REV #

N1-8041

C-22383-C	1	14
C-22387-C	2	11
C-23046-C	2	9
C-23093-C	1	10
C-23100-C	-	6
C-26982-C	1	2
"	2	2
C-26992-C	-	4
C-26993-C	1	3
C-26997-C	-	4
C-26998-C	-	3
C-23109-C	3	6
C-18355-C	2	1
C-18672-C	-	12
C-18103-C	-	3
C-34185-C	-	0
A-22110-C	29	1
A-22110-C	39	1
C-22141-C	-	3
C-22140-C	-	3
C-22105-C	-	3
C-26726-C	2	11
B-19741-C	12	A
"	13	-
"	14	-
B-19758-C	2	C
"	3	E
B-34027-C	2	4
"	2	2
C-19468-C	1	38
C-19472-C	-	34
C-19473-C	2	10
C-19476-C	-	12
C-19478-C	-	16
C-19909-C	1	56
"	2	50
"	3	48
"	4	57
"	5	52
C-19818-C	-	2
C-19408-C	10	6
C-19438-C	1	8
C-22302-C	2	7
"	8	2
C-23107-C	2	6
C-19910-C	10	21
"	12	27
C-19450-C	4	46
C-19859-C	9	12
C-22020-C	4	4
"	5	4
C-22383-C	1	16
"	4	16
"	8	10



X

MOD #

PLACED ON DATABASE

SHEET #

TO REV #

N1-8041

C-22383-C

1

16

"

1

14

"

8

10

C-23046-C

2

10

C-19440-C

6

13

C-19409-C

10

14

C-19859-C

10

19

"

10A

5

"

8

32

"

17

10

C-19954-C

2

8

"

3

5

"

5

5

N1-8074

C-34829-C

1

2

C-34831-C

1

0

"

2

0

C-18014-C

1

35

"

2

26

C-19957-C

1

22

C-22020-C

2

7

"

12

3

"

16

0

C-22382-C

1

18

"

3

18

C-23146-C

8

7

"

11

5

"

15

1

C-26726-C

2

16

C-34853-C

1

0

"

4

1

"

5

0

"

6

0

C-34854-C

1

0

"

4

1

"

5

0

"

6

0

N1-8084

C-19410-C

10

7

C-19425-C

3

12

C-22239-C

1

15

C-22239-C

7

12

C-23145-C

4

5

"

5

5

N1-8114

No Additions

N1-8129

No Additions

N1-8230

C-22374-C

4

19

C-23042-C

1

6

"

2

5

"

4

6

C-19423-C

5

19

"

6

10

C-19424-C

5

19

C-19425-C

6

21

C-22364-C

13



MOD #

PLACED ON DATABASE

SHEET #

TO REV #

N1-8230

C-22365-C

-

14

C-22366-C

-

14

C-22367-C

-

15

C-22368-C

-

12

N1-8269

C-19473-C

9

1

C-99424-C

7

12

C-23076-C

C-19897-C

2

2

C-19423-C

8

3

C-19424-C

6

4

"

3

13

C-22374-C

5

4

C-23077-C

3

7

"

4

8

"

5

6

C-22386-C

2

6

"

1

7

C-22372-C

2

7

"

1

11

C-22030-C

3

5

C-22004-C

5

5

C-19954-C

4

7

C-19859-C

2

23

"

5

23

C-26726-C

3

9

C-23077-C

5

6

C-18005-C

1

10

"

2

10

C-26727-C

1

2

C-26726-C

4

17

C-19423-C

3

15

C-23077-C

1

10

"

2

6

N1-8271

C-23145-C

5

12

"

4

11

C-19409-C

3

17

C-19410-C

1

15

"

2

16

"

3

14

"

4

15

"

5

14

"

6

15

"

10

14

"

11

4

"

12

4

N1-8280

C-22005-C

11

5

"

12

4

"

14

6

C-22374-C

2

6

"

3

16

C-22382-C

1

16

"

3

14

C-22356-C

1

7

"

2

6





MOD #PLACED ON DATABASESHEET #TO REV #

N1-8280

C-19437-C

10

3

"

2

23

C-19440-C

11

3

C-22005-C

2

6

"

6

6

"

5

6

"

8

7

"

9

6

C-19859-C

3

24

"

6

24

"

8A

11

"

8

5

C-19437-C

10

3

C-19438-C

3

9

C-19842-C

2

4

C-19845-C

7

1

C-19859-C

2

24

"

5

24

"

10

16

"

10A

3

"

18

9

C-19440-C

2

22

"

6

10

"

10

6

N1-8293

C-22380-C

3

2

"

4

1

N1-8329

No Additions

N1-8353

A-22217-C

20

4

"

47

4

C-22238-C

1

16

"

2

23

C-22239-C

7

18

C-23305-C

-

5

C-23311-C

-

4

C-19940-C

1

22

C-19411-C

1

8

C-19415-C

1

19

"

2

18

C-19417-C

1

16

"

2

5

C-19418-C

1

14

"

2

19

"

3

10

"

4

16

N1-8358

C-26726-C

1

16

"

2

16

"

3

10

"

4

21

C-19859-C

18

11

"

18A

1

C-22105-C

2

8

N1-8361

C-22387-C

5

3

C-22388-C

1

6

"

3

2



X

<u>MOD #</u>	<u>PLACED ON DATABASE</u>	<u>SHEET #</u>	<u>TO REV #</u>
N1-8361	C-22387-C	1	7
	C-26726-C	6	8
N1-8384	C-18022-C	1	15
	"	2	8
	C-18022-C	1	1
	"	2	18
N1-8458	C-18027-C	2	5
	C-19951-C	3	13
	C-22004-C	2	11
	"	5	7
	C-23077-C	4	8
N1-8526	C-23146-C	7	9
	C-19859-C	18	11
	"	18A	1
	C-22373-C	11	9
	"	12	17
	"	13	19
	C-22374-C	4	28
	"	4	32
	"	5	8
	C-26726-C	4	21



ATTACHMENT I

MALFUNCTIONS TESTED IN 1987

FW14	RR37	EG06
FW18	RR41	EG10
FW22	RR45	EG14
FW26	RR49	FP04
HV01	RR53	FP08
MC01	RR57	FW02
MC05	RR61	FW06
MS03	RR65	FW10
MS06	RR69	
MS11	RW01	
NM04	SC02	
NM12	<del>RC04</del> TC04	
NM20	TC08	
NM33	TC12	
NM38	TU03	
OG02	AD02	
RD02	AD06	
RD06	CS03	
RD34	CU01	
RD38	<del>CU04</del> CU09	
RM01	CW02	
RM06	CW06	
RP02	CW10	
RP06	EC02	
RR02	EC06	
RR06	ED03	
<del>RR06</del> RR14	ED07	
RR14	ED11	
RR18	ED15	
RR22	ED19	
RR29	ED23	
RR33	EG02	



NINE MILE POINT NUCLEAR STATION  
UNIT 1 PLANT REFERENCED SIMULATOR

ANNUAL REPORT: ANSI 3.5 - 1985

FOR THE YEAR




1988

Testing Conducted April - May 1988

Report Prepared June 1988

Prepared By: George Roarick

Reviewed By:

<u></u>	<u>10/5/88</u>
Supervisor, Unit #1 Operations Training	Date
<u></u>	<u>10/5/88</u>
Asst. Superintendent of Training	Date
<u></u>	<u>10/6/88</u>
Superintendent of Training	Date






## I. SIMULATOR INFORMATION

The purpose of this section is to provide familiarization with the Nine Mile Point Unit 1 Plant Referenced Simulator and its applicability as an operator training device.

### A. General

1. The simulator is owned by the General Physics Niagara Corporation and is a wholly owned subsidiary of the General Physics Corporation. It is used jointly by General Physics Corporation and Niagara Mohawk Power Corporation instructors. It is maintained and modified by the General Physics Corporation under the direction of Niagara Mohawk Power Corporation. The simulator was built by Singer/Link.
2. The simulator is a full scope control room simulator that simulates the Nine Mile Unit #1 plant. The plant is an 1850 Megawatt Thermal, BWR-2 plant with an electrical output of 620 Megawatts. The plant uses a GE BWR Mark I Primary Containment.
3. The simulator was declared ready for training on September 1, 1984.
4. The initial report on the simulator was prepared in March of 1986. The first annual report was completed in June of 1987.
5. In addition to training, the simulator has been used by the Operations Department to validate procedures prior to their implementation.




## B. Control Room (Physical Fidelity)

1. The physical layout of the referenced plant's Control Room is shown in Attachment "A". The physical layout of the simulator is shown in Attachment "B". A comparison of these diagrams shows a high degree of similarity between the two rooms. The following differences exist:
  - a. The instructor's console in the simulator uses the same area occupied by the Control Room Clerk's Office in the reference plant's Control Room.
  - b. A manual dose assessment calculator is mounted on the wall next to the stairwell in the referenced plant's control room. A meteorological computer is located next to it. This equipment does not exist in the simulator.
  - c. A video camera is mounted on the wall above the NSSS typer. There are no video cameras permanently mounted in the simulator.
  - d. There are some minor differences in the amount and type of furniture in both rooms.
  
2. Panels and Equipment

The simulator contains all of the panels that are in the referenced plant's Control Room. All front panels and the "E" console are fully simulated. The back panels are fully simulated with the exception of the following:

- a. RPS relays are installed but are not functional.
- b. Electrical protective relaying is cosmetically simulated by photos in the relay enclosures.
- c. Only one of the four Transversing In-Core Probe panels is functional.
- d. Seismic Monitors are not functional.



### 3. Systems

All systems that are operable from the referenced plant's Control Room are simulated. See Attachment "C" for a list of these systems.

### 4. Simulator Control Room Environment

The Simulator Control Room was specifically designed to duplicate as nearly as possible the referenced plant's Control Room. Other than the discrepancies noted in Section 1 of this part, the following differences exist:

- a. Even though the lighting is identical to that at the referenced plant, the lighting system is not functionally interfaced with the simulator. Plans to interface the lights and the simulator are being evaluated.
- b. The ambient noise level of the referenced plant's Control Room is not simulated. The hardware in place to do this is installed but is not functional. Plans to do this are being evaluated.

## C. Instructor Interface (Control Capabilities)

### 1. Initial Conditions

The instructor has the capability to initialize the simulator to any one of fifty (50) sets of initial conditions. The first twenty of these sets of conditions are guarded and can only be changed by the proper code. The "guarded" initial conditions are the foundation for approximately 95% of the training. These twenty sets of initial conditions are listed in Attachment "D". The remaining thirty sets of initial conditions can be set at any time by the instructor.

### 2. Malfunctions

Malfunctions vary from a discrete nature (i.e. pump trip) to ones of varying degrees of severity (i.e. leaks). Attachment "E" is a complete list of malfunctions.



### 3. Remote Functions

The instructor has the capability to simulate most of the inplant operations needed to backup a Control Room evolution. Attachment "F" is a complete list of remote functions.

### 4. Instructor Override

The I/O function gives the instructor at the console the ability to override all switches, energize or deenergize any light or alarm, and drive all meters. A few problems exist in the I/O program, but are being documented for evaluation and repair as they are identified.

### 5. Monitoring


The instructor can monitor on the console, up to sixteen (16) of ninety (90) parameters. In addition, the instructor can set up a line plotter to any of these same ninety (90) parameters. Attachment "G" is a list of these monitored parameters.

### 6. Instructor Station Controls

Consists of three (3) keyboard/CRT's, two (2) are for performing simulator functions, one (1) is for minor trouble shooting and correction of the computer system. There are also various buttons which perform the following:

- a. Freeze - stops (freezes) simulation at any point or restarts it.
- b. Reset/Ready - initializes the simulator to a selected set of initial conditions. This button turns green when all controls are properly positioned.
- c. Snapshot - records and stores a set of conditions into any "IC".
- d. Malfunction Clear - clears the entire malfunction tableau.





- e. Backtrack - sets the simulator to step up or back to any point in time, within sixty 60 minutes. This includes buttons to step in one minute intervals and to step forward or reverse.
- f. Manual Malfunction Control - used to increase or decrease the severity of up to three (3) variable malfunctions.
- g. Annunciator Silence - silences, but does not acknowledge, all annunciators.
- h. Recorder Off - shuts off power to all chart recorders.
- i. Test and Lamp Test - testing and troubleshooting.
- j. Emergency Stop - kills all power to the computer and simulator.
- k. Computer Alarm/Acknowledge - warns of computer malfunctions.
- l. Program Overtime - warns of computers inability to complete a calculation within an allotted time frame. Depressing the button resets the timer.
- m. Record and Replay - starts and stops the tape recorder in the Computer Room when it is set put to record an exercise.
- n. Slow Time - slows simulator response to where two (2) real time seconds equal one (1) problem time second.
- o. Fast Time - speeds up response time of Xenon, condenser evacuation, and turbine warming.

## 7. Record/Replay

If so desired, a scenario can be recorded on magnetic tape for replay at a later date. This function is controlled from the instructor station.



D. Reference Plant Operating Procedures

The simulator is operated using the same procedures used to operate the plant. The Operations Department has used the simulator to validate new procedures or revisions.

E. Changes Since Last Report (June 1987)

1. Plant Modifications as of June 15, 1988

- a. J-Panel Upgrades - Installation of RSSB ARM meters (non-functional) and installation of new digital (Kaman) radiation monitoring panels for Control Room Ventilation, Service Water discharge, Rad Waste discharge. (Functional)
- b. NIY86M057 Rod Worth Minimizer - Added new process computer points for RWM failures.
- c. Mod #N1-80-072, Alternate Rod Injection (ARI) - Alternate Rod insertion is a redundant method of rod injection, utilizing two one inch DC solenoid valves in series with the Control Rod Scram Air Header System. Initiation signal to operate these valves will be ATWS LoLo water level and ATWS high reactor pressure.
- d. Mod #N1-85-098, Containment Isolation on High Radiation - Shuts N<sub>2</sub> & Air Vent & Purge valves on High Stack activity.

2. Physical Layout

- a. The instructor's station was moved onto a twenty inch (20") platform adjacent to the SSS's office. (This area at the plant is occupied by the ASSS/STA office - see Attachment "A").
- b. A direct phone link between the instructor's station and the CSO's desk was installed to simulate the direct phone link to the Energy Management Center and the NRC/state.



## II. SIMULATOR DESIGN DATA

The current design data base for the simulator is on file at the Training Center. A current listing of the design data base is available on the plant's Configuration Management System in the simulator data file. Changes to the design data base since June 1987 are listed in Attachment "H".

## III. SIMULATOR TESTS (PERFORMANCE TESTING)


During May of 1988, testing was done to verify real time operation, steady state and normal operation, transient performance and malfunction response. Documentation of these tests is on file and available at the Training Center.

### A. Computer Real Time Tests

Simulator real time testing was performed by measuring individual model times during steady state and transient conditions. During this testing, no frame slippage or program overtimes occurred. The simulator contains safeguards that preclude operation outside of real time with the exception of two (2) instructor controlled functions described in Section I.C.6 of this report (Fast Time/Slow Time).

### B. Steady State and Normal Operation

1. Simulator stability was verified by comparing heat balances (P-1 edits) and printouts of selected "critical" parameters from the start and finish of a sixty (60) minute steady state run. There was no deviation outside of acceptable limits in regards to the "critical" parameters. There is, however, a problem with rising exhaust hood temperatures. This problem was found to be generic to all power operating conditions and was documented for correction.



2. Fidelity in performance was verified by comparing heat balances and "critical" parameters from the plant at various power levels.

a. Generic Problems

- 1) Reactor Physics - Simulator was not able to duplicate the power to flow relationship from a cold startup configuration, even with all rods out.
- 2) Plant Efficiency - Even though the simulator was within tolerances at full power, during power ascension, the calculated efficiency was as much as five percent (5%) lower than that of the plant for a similar configuration.
- 3) Off-Gas System - During start up and power ascension, the Off-Gas System could not be operated in accordance with the procedure or ATP. The mechanical vacuum pumps were unable to achieve the vacuum they could at the plant within the actual time frame seen at the plant. Post recombine flow was erratic and too high and both the off-gas vacuum pumps were unable to maintain pressure. (It normally requires only one pump at the plant.)
- 4) Recirculation Pump Flows - Individual pump flows at the plant vary as much as 100,000 lbm/hr. On the simulator, they are almost equal.
- 5) Narrow Range GEMAC Level - At the plant, it runs about a two inch (2") difference in channel #11 and #12 NR GEMAC's. In the simulator, they are equal.

Of the generic problems noted, items 1, 2, and 3 were documented for correction and assigned immediate priority. Items 4 and 5 have very little if any training impact and will not be addressed any further.

b. 25% Power - Plant data for total steam flow is significantly different than that from the simulator, but the plant data appears to be incorrect based on the rest of the data. There were no other problems other than the generic ones listed above.






- c. 50% Power - Simulator data compared favorably with the plant data except for the generic problems listed above. One OG vacuum pump can handle the volume but flow is still too high and the slightest change causes off-gas to respond significantly.
- d. 75% Power - Simulator data compared favorably with plant data except for the generic problems listed above. OG system behavior was consistent to that experienced at 50% power.
- e. 100% Power - Simulator data compared favorably with plant data except for the generic problems noted above. OG system behavior was consistent to that at 50% and 75% power.

### C. Transient Tests

- 1. The following transients are analyzed in the FSAR and were run on the simulator in real time.
  - a. Simultaneous Trip of all Feedwater Pumps - (Feedwater Malfunction, Zero Flow). The FSAR shows an increase in recirculation control due to changes in two-phase flow. The simulator does not model two-phase flow closely enough to produce this; therefore, it does not change. This discrepancy has little or no training impact and will not be further addressed.
  - b. Simultaneous Closure of MSIV's - Consistent with FSAR.
  - c. Simultaneous Trip of all Recirculation Pumps - consistent with FSAR.
  - d. Single Recirculation Pump Trip - The simulator shows a much more pronounced decrease and recovery of recirculation flow than the FSAR. Parameters effected by flow respondent likewise.



- e. Loss of Coolant with a Loss of A/C Power - At time + 3.5 seconds, Drywell pressured spiked to 10 psig then dropped to 8 psig with an increasing trend to a maximum pressure of about 22 psig over a period of 30 seconds. This is inconsistent with the FSAR which shows a pressure spike to 33 psig in 2 seconds. This inconsistency was identified and documented last year.
2. The following transients are not analyzed in the FSAR but are required by ANSI 3.5 - 1985.
    - a. Main Steam Line Break Inside the Drywell - Drywell pressure in the first 3 seconds of the transient spiked to 11 psig. During the next second, it decreased to 8 psig before starting a steady increase to about 15 psig. This problem is documented for further evaluation and resolution. Otherwise, the simulator was consistent with predicted response.
    - b. Turbine Trip at less than 40% Power - The simulator was consistent with predicted response.
    - c. Power Change; 100 and 75% to 100% (Maximum Ramp) - The simulator was consistent with predicted response.
    - d. MSIV closure with a stuck open ERV and no high pressure ECCS available.  
The simulator was consistent with predicted response.
  3. The following transients are not required for the report by the standard but were conducted and compared to data from the FSAR.
    - a. Turbine Trip without Bypass
    - b. Inadvertent Actuation of an ERV
    - c. Safety Valve Actuation
    - d. EPR/MPR Failures

In all cases, the simulator response was consistent to the FSAR.



#### D. Malfunction Testing


In addition to the malfunctions used to create the transient tests above 25% of the available malfunctions (Attachment "E") were tested in accordance with the ATP. Attachment "I" is a list of the malfunctions tested. Operations Department personnel were on hand to help validate the response of the simulator to the malfunctions. A number of problems were documented. They will be handled in accordance with NTI-4.5.3 "Simulator Configuration Management".

#### IV. SIMULATOR CONFIGURATION MANAGEMENT

Discrepancy resolution and modifications are handled in accordance with NTI-4.5.3 "Simulator Configuration Management". This is a computer based tracking system. The system has identified seven modifications that fall outside the implementation guidelines of ANSI 3.5 - 1985. Attachment "J" provides a list of these modifications and the status of each at the writing of this report.

In 1987 the Plant's Configuration Management System was implemented to track and maintain the plant's data base, this system also contains a program for tracking, maintaining, and generating reports on the simulator's data base. Once an audit of the hard copy is complete and a more complete list is available, this information will be inputted on the system.

```
*****  
*                               *  
*           FINAL NOTE         *  
*                               *  
* All data used to compile this report as well *  
* as NTI-4.5.3 are on file and available for  *  
* inspection.                   *  
*****
```




ATTACHMENT A

Legend

2 Main Fire Panel #2  
A Panel A Electric/  
Turbine Controls  
B Panel B Relays/  
Turbine Controls  
C Plant Process  
Computer Equipment  
D Chief Shift Operator  
Desk  
E E Panel Main Control  
Console  
F F Panel NSSS  
G G Panel Nuclear  
Instrumentation  
H H Panel Balance of  
Plant  
I Instructors Console  
J J Panel Radiation  
Monitoring  
K K Panel ECCS  
L L Panel Primary  
Containment  
M M Panel RPS  
N N Panel Turbine  
P Print Rack  
S Storage Cabinets  
T Tables  
M/R Meteorological  
Computer  
R Manual Dose  
Assessment Calculator  
R/T Radio/Telephone  
Equipment  
O Procedures  
B/S Bookshelf  
D/K Desk

Figure 1 - Nine Mile Point Unit 1 Control Room





ATTACHMENT B

Legend

2 Main Fire Panel #2  
A Panel A Electric/  
Turbine Controls  
B Panel B Relays/  
Turbine Controls  
C Plant Process  
Computer Equipment  
D Chief Shift Operator  
Desk  
E E Panel Main Control  
Console  
F F Panel NSSS  
G G Panel Nuclear  
Instrumentation  
H H Panel Balance of  
Plant  
I Instructors Console  
J J Panel Radiation  
Monitoring  
K K Panel ECCS  
L L Panel Primary  
Containment  
M M Panel RPS  
N N Panel Turbine  
P Print Rack  
S Storage Cabinets  
T Tables  
O Procedures  
B/S Bookshelf  
F/C False Column  
F/S False Stairway  
F/D False Door  
R/T Radio/Telephone  
Equipment


Figure 2 - Nine Mile Point Unit 1 Simulator Control Room



Attachment C

SYSTEMS FULLY SIMULATED

1. Nuclear Boiler and Instrumentation
2. Reactor Recirculation System
  - a. Reactor Recirculation Loops
  - b. Boiler Process Instrumentation
  - c. Recirculation Flow Control
3. Control Rod Drive and Hydraulics System (CRDHS)
4. Reactor Manual Control System (RMCS)
5. Reactor Core (Physics and Thermodynamics)
  - a. Reactor Core Neutron Kinetics
  - b. Reactor Core Thermodynamics
6. Rod Worth Minimizer (RWM)
7. Main Steam Systems
  - a. Main Steam and Main Steam Bypass Systems
  - b. Moisture Separators - Reheaters
  - c. Extraction Steam System
  - d. Auxiliary Steam System
8. Reactor Water Cleanup System
9. Nuclear Instrumentation System
  - a. Source Range Monitor (SRM) System
  - b. Intermediate Range Monitor (IRM) System
  - c. Local Power Range Monitoring (LPRM) System
  - d. Average Power Range Monitoring (APRM) System
  - e. Rod Block Monitor (RBM) System
  - f. Traversing In-Core Probe (TIP) System
10. Reactor Protection System
11. Simulation of the Primary Containment and Isolation System
  - a. Primary Containment
  - b. Primary Containment Isolation System
12. Secondary Containment
13. Emergency Ventilation
  - a. Reactor Building Ventilation
  - b. Turbine Building Ventilation
  - c. Building Ventilation
14. Primary Containment Atmosphere Control and Sampling System



15. Emergency Core Cooling Systems
  - a. Automatic Depressurization and pressure Relief System
  - b. Core Spray
  - c. High Pressure Coolant Injection (HPCI) System
  - d. Containment Spray
  - e. Emergency Cooling System
16. Shutdown Cooling
17. Standby Liquid Control (SLC) System
18. Condensate and Feedwater System
  - a. Condensate System
  - b. Condensate Demineralizer System
  - c. Feedwater System
  - d. Condensate Storage and Transfer System
  - e. Reactor Vessel Level Control System
  - f. Feedwater Heaters, Vents and Drains
19. Off-Gas Recombiner and Condenser Air Removal
20. Main Condenser
21. Circulating Water System
22. Reactor Building Closed Loop Cooling
23. Turbine Building Closed Loop Cooling
24. Service Water System
25. Instrument, Service and Breathing Air
26. Area Radiation Monitoring System
27. Process Radiation Monitoring System
28. Ventilation Radiation Monitoring System
29. Main Turbine and Turbine Control
  - a. Turbine Oil System
  - b. Turbine Kinematics
  - c. Turbine Mechanics
  - d. Turbine Supervisory and Safety System
  - e. Gland Seal System
  - f. Low Pressure Hood Spray System
  - g. Moisture Separator and Reheat System
  - h. Main Turbine Electro-Hydraulic Control System



30. Plant Electrical System

- a. Main Generator and Auxiliary Systems
  - 1. Main Generator Synchronous Machine
  - 2. Excitation and Voltage Regulator System
  - 3. Synchroscope
  - 4. Hydrogen Cooling System
  - 5. Stator and Iso-Phase Duct Cooling System
  - 6. Hydrogen Seal Oil System
- b. Electrical Distribution System
  - 1. Buses and Transformers
  - 2. Breakers
  - 3. Currents, Voltages and Frequencies
  - 4. DC Electrical Distribution and Control
  - 5. Power System Electrical Grid
- c. Diesel Generators

31. Containment Atmosphere Dilution, Vent and Purge System

32. Radiation Waste Disposal System Containment Equipment and Floor Drain Sump

33. Plant Carbon Dioxide System

34. Diesel Fire Pump and Pressurized Water Fire System

35. Fire Control Ventilation Systems

36. Control Room Heating, Ventilation and Air Conditioning

37. Communication System


38. Plant Process Computer System

- a. Applicable Experience

39. Meteorological Experience

40. Plant Annunciators and Fire System Alarm






ATTACHMENT D

GUARDED INITIAL CONDITIONS


<u>IC #</u>	<u>DESCRIPTION</u>
1.	Cold Iron - All systems are off line with the exception of Service Water and Electrical Distribution. <u>This is not an approved plant lineup but is used to provide training in system startups in the Control Room.</u>
2.	Cold Startup - Shutdown Cooling in service with all systems needed for startup of the reactor on line and ready to pull rods. (After securing SDC.)
3.	Cold Startup - 5-10 rods subcritical, pulling in Group 4.
4.	Heatup 100# - Pulling Group 9
5.	Heatup 250# - Pulling Group 11
6.	Heatup 950# - Pulling Group 23
7.	Shutdown 80% Flow - Start of controlled plant shutdown per OP-43
8.	Shutdown Min Flow - Inserting Group 76
9.	Shutdown Min Flow - Mode Switch to "Shutdown", Inserting Group 33
10.	Shutdown Min Flow - All rods in
11.	Turbine Startup - 3.5 Bypass Valves Open, Turbine Warmed
12.	Feedwater Pump #13 Startup - 210 MWE, on two electric FWP's
13.	50% Power - Power accent to threshold and preconditioning
14.	100% Power - Normal full power configuration
15.	Coastdown - All rods out at end of cycle
16.	Startup - Rods at 100% target pattern, 30% flow
17.	Reserved for Future Use
18.	Reserved for Future Use
19.	Cooldown 200# - Plant Cooldown
20.	Cooldown 80# - Shutdown Cooling In Service




ATTACHMENT E

NINE MILE POINT UNIT ONE MALFUNCTIONS

AD01 ADS FAILURE TO INITIATE - PRIMARY VALVES  
AD02 ADS FAILURE TO INITIATE - COMPLETE  
AD03 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - SOLENOID  
AD04 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - VALVE LEAKS  
AD05 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - OPENS  
INADVERTENTLY  
AD06 SOLENOID ACTUATED PRESSURE RELIEF VALVE (#111) FAILURE - STUCK OPEN  
AN01 CONTROL ROOM ANNUNCIATOR SYSTEM FAILURE  
CS01 CORE SPRAY PUMP TRIP (111, 112, 121, 122 OR ANY)  
CS02 CORE SPRAY TOPPING PUMP TRIP (111, 112, 121, 122 OR ANY)  
CS03 CORE SPRAY INBOARD INJECTION VALVE FAILURE TO OPEN (IV40-01, IV40-09,  
IV40-11, IV40-10 OR ANY)  
CT01 CONTAINMENT SPRAY PUMP TRIP (111, 112, 121, 122 OR ANY)  
CT02 CONTAINMENT SPRAY RAW WATER PUMP TRIP (111, 112, 121, 122 OR ANY)  
CT03 CONTAINMENT SPRAY HEAT EXCHANGER (111, 112, OR BOTH) TUBE LEAK  
CU01 COOLANT LEAKAGE INSIDE PRIMARY CONTAINMENT  
CU02 REACTOR WATER CLEANUP PUMP TRIP (11, 12 OR BOTH)  
CU03 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS OPEN  
CU04 REACTOR WATER CLEANUP REJECT FLOW CONTROL VALVE (FCV-ND22) FAILS  
CLOSED  
CU05 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
OPEN  
CU06 REACTOR WATER CLEANUP HIGH PRESSURE CONTROL VALVE (PCV 33-39) FAILS  
CLOSED  
CU07 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS OPEN  
CU08 REACTOR WATER CLEANUP LOW PRESSURE CONTROL VALVE (PCV-ND37) FAILS  
CLOSED  
CU09 REACTOR WATER CLEANUP NON-REGENERATIVE HEAT EXCHANGER TUBE LEAK  
CU10 REACTOR WATER CLEANUP DEMINERALIZER RESIN DEPLETION (11, 12 OR BOTH)  
CU11 COOLANT LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
CW01 HIGH RADIATION IN SERVICE WATER  
CW02 SERVICE WATER PUMP TRIP (11, 12 OR BOTH)




CW03 EMERGENCY SERVICE WATER PUMP TRIP (11, 12 OR BOTH)  
 CW04 REACTOR BUILDING CLOSED LOOP COOLING (11, 12, 13 OR ANY) PUMP TRIP  
 CW05 TURBINE BUILDING CLOSED LOOP COOLING PUMP TRIP (11, 12 OR BOTH)  
 CW06 CIRCULATING WATER PUMP TRIP (11, 12 OR BOTH)  
 CW07 CIRCULATING WATER EXPANSION JOINT LEAKAGE  
 CW08 CIRCULATING WATER INTAKE STRUCTURE ICING  
 CW09 LOSS OF DRYWELL COOLING  
 CW10 MAIN CONDENSER TUBE LEAK  
 DG01 DIESEL GENERATOR FAILURE TO START (102, 103 OR BOTH)  
 DG02 DIESEL GENERATOR TRIP (102, 103 OR BOTH)  
 EC01 STEAM LEAKAGE INSIDE PRIMARY CONTAINMENT  
 EC02 STEAM LEAKAGE OUTSIDE PRIMARY CONTAINMENT  
 EC03 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS OPEN (IV39-05, IV39-06 OR BOTH)  
 EC04 EMERGENCY COOLING SYSTEM RETURN VALVE FAILS TO OPEN (IV39-05, IV39-06 OR BOTH)  
 EC05 EMERGENCY COOLING SYSTEM EMERGENCY CONDENSER MAKEUP CONTROL VALVE FAILS CLOSED (LCV60-17, LCV60-18 OR BOTH)  
 EC06 EMERGENCY CONDENSER TUBE LEAK (111, 121 OR BOTH)  
 ED01 LOSS OF OFF-SITE 115 KV POWER SOURCES (LIGHTHOUSE HILL-JAF, OSWEGO STEAM, OR BOTH)  
 ED02 BATTERY CHARGER AND EMERGENCY LIGHTING SUPPLY MOTOR GENERATOR TRIPS (161, 171 OR BOTH)  
 ED03 COMPUTER POWER SUPPLY MOTOR GENERATOR TRIPS (167)  
 ED04 AC POWERBOARD ELECTRICAL FAULT (PB11)  
 ED05 AC POWERBOARD ELECTRICAL FAULT (PB12)  
 ED06 AC POWERBOARD ELECTRICAL FAULT (PB101)  
 ED07 AC POWERBOARD ELECTRICAL FAULT (PB102)  
 ED08 AC POWERBOARD ELECTRICAL FAULT (PB103)  
 ED09 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION A)  
 ED10 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION B)  
 ED11 AC POWERBOARD ELECTRICAL FAULT (PB13 SECTION C)  
 ED12 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION A)  
 ED13 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION B)  
 ED14 AC POWERBOARD ELECTRICAL FAULT (PB14 SECTION C)  
 ED15 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION A)  
 ED16 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION B)  
 ED17 AC POWERBOARD ELECTRICAL FAULT (PB15 SECTION C)




ED18 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION A)  
 ED19 AC POWERBOARD ELECTRICAL FAULT (PB16 SECTION B)  
 ED20 AC POWERBOARD ELECTRICAL FAULT (PB17 SECTION A)  
 ED21 AC POWERBOARD ELECTRICAL FAULT (PB18 SECTION B)  
 ED22 DC POWERBOARD ELECTRICAL FAULT J(11, 12 OR BOTH)  
 ED23 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL  
 ED24 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - ALTERNATE  
 ED25 LOSS OF POWER TO INSTRUMENT CONTROL BUS 130 - NORMAL AND ALTERNATE  
 EG01 MAIN GENERATOR TRIP - ELECTRICAL FAULT  
 EG02 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - INCREASE  
 EG03 GENERATOR AUTOMATIC VOLTAGE REGULATOR FAILS - DECREASE  
 EG04 MAIN GENERATOR CORE INTERNAL HEATING  
 EG05 MAIN TRANSFORMER LOSS OF COOLING  
 EG06 GENERATOR HYDROGEN COOLING SYSTEM LEAKAGE  
 EG07 GENERATOR HYDROGEN MAIN SEAL OIL PUMP FAILURE  
 EG08 GENERATOR HYDROGEN EMERGENCY SEAL OIL PUMP FAILURE  
 EG09 STATOR COOLING PUMP TRIP (11, 12 OR BOTH)  
 EG10 LOSS OF CONTROL AIR TO 345 KV BREAKER (R-915, R-925 OR BOTH)  
 EG11 POWER GRID NETWORK LOAD TRANSIENT - INCREASE  
 EG12 POWER GRID NETWORK LOAD TRANSIENT - DECREASE  
 EG13 STATOR WATER COOLING DEMINERALIZER RESIN DEPLETION  
 FP01 DIESEL FIRE PUMP FAILURE  
 FP02 ELECTRIC FIRE PUMP FAILURE  
 FP03 AC FOAM PUMP FAILURE  
 FP04 DC FOAM PUMP FAILURE  
 FP05 TURBINE ISLAND FIRE DETECTION (D-1195, D-1155, D-1165, D-1175,  
 D-1061, D-1114, D-1131 OR ANY)  
 FP06 CONTROL ROOM FIRE DETECTION (FIRE PANEL 2, CONTROL CONSOLE, "L"  
 PANEL, "K" PANEL, "H" PANEL, "F" PANEL, "A" PANEL OR ANY)  
 FP07 TURBINE BUILDING FIRE DETECTION (DA-22092MG, DA-2083M, DA-2081S,  
 DA1092E, D-2102 OR ANY)  
 FP08 DIESEL ROOM FIRE DETECTION (DX-2113A, DX-2113B, DX-02141A, DA-2141,  
 DX-2151B, DA-2151, D-2151 OR ANY)  
 FP09 AUXILIARY CONTROL ROOM/cable spreading room fire detection (d-3031PL,  
 DX-3031A, DX-3111B, WD-8131, WD-8082 OR ANY)  
 FP10 REACTOR BUILDING FIRE DETECTION (DX-4217A, DA-4116W, DA-4076E,  
 D-4207, D-4156, SP-4126, D-4086 OR ANY)

-20 June 1988







FW01 CONDENSATE PUMP TRIP (11, 12, 13 OR ANY)  
 FW02 FEEDWATER BOOSTER PUMP TRIP (11, 12, 13 OR ANY)  
 FW03 FEEDWATER PUMP TRIP (11, 12 OR BOTH)  
 FW04 SHAFT DRIVEN FEEDWATER PUMP 13 FAILURE  
 FW05 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO ENGAGE  
 FW06 SHAFT DRIVEN FEEDWATER PUMP CLUTCH FAILURE TO DISENGAGE  
 FW07 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS HIGH  
 FW08 FEEDWATER CONTROL VALVE 11 CONTROLLER FAILS LOW  
 FW09 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS HIGH  
 FW10 FEEDWATER CONTROL VALVE 12 CONTROLLER FAILS LOW  
 FW11 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS HIGH  
 FW12 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS LOW  
 FW13 FEEDWATER CONTROL VALVE 13 CONTROLLER FAILS AS IS  
 FW14 FEEDWATER MASTER CONTROLLER FAILS HIGH  
 FW15 FEEDWATER MASTER CONTROLLER FAILS LOW  
 FW16 FEEDWATER MASTER CONTROLLER FAILS AS IS  
 FW17 CONDENSATE DEMINERALIZER DEPLETION  
 FW18 FEEDWATER CONDUCTIVITY INCREASE  
 FW19 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS OPEN  
 FW20 CONDENSATE RECIRCULATION VALVE (FCV 50-24) FAILS CLOSED  
 FW21 FEEDWATER BOOSTER PUMP RECIRCULATION VALVE FAILS OPEN (FCV 51-58, FCV  
 51-59, FCV 51-60 OR ANY)  
 FW22 FEEDWATER HEATER TUBE LEAK  
 FW23 FEEDWATER PUMP RECIRCULATION VALVES FAIL OPEN (11, 12, 13 OR ANY)  
 FW24 FEEDWATER CONTROL VALVE FAILS CLOSED (13A, 13B OR BOTH)  
 FW25 THREE MILE ISLAND ACCIDENT (BWR EQUIVALENT)  
 FW26 CONDENSATE BYPASS SPRAY TO MAIN CONDENSER FLOW CONTROL VALVE (FCV  
 50-22) FAILS CLOSED  
 FW27 LOSS OF COMPENSATION TO FEEDWATER FLOW TRANSMITTER  
 FW28 HPCI MODE FAILURE TO INITIATE (11, 12 OR BOTH)  
 FW29 HPCI MODE Inadvertent INITIATION (11, 12 OR BOTH)  
 HV01 REACTOR BUILDING EXHAUST FAN TRIP (11, 12 OR BOTH)  
 HV02 EMERGENCY VENTILATION FAN TRIP (11, 12 OR BOTH)  
 IA01 LOSS OF INSTRUMENT AIR  
 LP01 LIQUID POISON PUMP TRIP (A, B OR BOTH)



MC01 MAIN CONDENSER AIR IN LEAKAGE  
 MC02 STEAM JET AIR EJECTOR STEAM SUPPLY VALVE FAILS CLOSED  
 MC03 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL HIGH  
 MC04 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL LOW  
 MC05 HOTWELL LEVEL CONTROLLERS IN AUTO FAIL AS IS  
 MC06 EXPLOSION IN AIR EJECTOR DISCHARGE PIPING  
 MS01 STEAM LEAK RUPTURE OUTSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
 MS02 MSIV DISC SEPARATES FROM STEM  
 MS03 ONE MSIV FAILS CLOSED (VALVE 122)  
 MS04 STEAM LINE RUPTURE INSIDE PRIMARY CONTAINMENT (DESIGN BASIS)  
 MS05 TURBINE STEAM SEAL REGULATOR FAILS CLOSED  
 MS06 MOISTURE SEPARATOR DRAIN TANK LEVEL CONTROL FAILS LOW  
 MS07 FIRST STAGE REHEATER 111 STEAM SUPPLY VALVE CLOSES  
 MS08 SECOND STAGE REHEATER 112 STEAM SUPPLY VALVE CLOSES  
 MS09 SECOND STAGE REHEATER 112 DRAIN TANK LEVEL CONTROL FAILS LOW  
 MS10 LOSS OF EXTRACTION STEAM TO HIGH PRESSURE FEEDWATER HEATER (115, 125,  
 135 OR ANY)  
 MS11 LOSS OF COMPENSATION TO STEAM FLOW TRANSMITTER  
 NM01 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - UPSCALE  
 NM02 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - DOWNSCALE  
 NM03 SRM CHANNEL RECORDER FAILURE (RED, BLACK OR BOTH PENS)  
 NM04 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - INOPERATIVE  
 NM05 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - UPSCALE, RECORDER  
 INOPERATIVE  
 NM06 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - DOWNSCALE  
 NM07 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - RECORDER  
 NM08 SRM CHANNEL (11, 12, 13, 14 OR ANY) FAILURE - INOPERATIVE  
 NM09 SRM CHANNEL (11, 12, 13, 14 OR ANY) DETECTOR STUCK  
 NM10 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM11 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM12 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 RECORDER  
 NM13 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM14 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE




NM15 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM16 IRM/APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 RECORDER  
 NM17 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) INOPERATIVE  
 NM18 IRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) DETECTOR STUCK  
 NM19 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM20 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM21 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM22 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE - UPSCALE  
 NM23 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 DOWNSCALE  
 NM24 APRM CHANNEL (11, 12, 13, 14, 15, 16, 17, 18 OR ANY) FAILURE -  
 INOPERATIVE  
 NM25 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM26 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM27 ANY LPRM (X-Y-J) FAILURE - UPSCALE  
 NM28 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM29 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM30 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM31 ANY LPRM (X-Y-J) FAILURE - DOWNSCALE  
 NM33 TIP DETECTOR STUCK IN CORE  
 NM34 ANY LPRM (X-Y-J) DRIFT +/- 25%  
 NM35 ANY LPRM (X-Y-J) DRIFT +/- 25%  
 NM36 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - UPSCALE  
 NM37 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - DOWNSCALE  
 NM38 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - AS IT  
 NM39 RECIRC FLOW CONVERTER CHANNEL (11, 12 OR BOTH) FAILURE - INOPERATIVE  
 NM40 RECIRC FLOW CONVERTER (11, 12 OR BOTH) FAILURE - COMPARATOR  
 OG01 OFF-GAS RECOMBINER PREHEATER STEAM SUPPLY FAILS CLOSED  
 OG02 OFF-GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS OPEN  
 OG03 OFF-GAS RECOMBINER MIXING JET STEAM SUPPLY FAILS CLOSED  
 OG04 OFF-GAS DISCHARGE TO STACK ISOLATION VALVE FAILS CLOSED  
 PC01 DRYWELL TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - INCREASE  
 PC02 DRYWELL TORUS DIFFERENTIAL PRESSURE CONTROL FAILURE - DECREASE  
 PC03 PRIMARY CONTAIN. LEAKAGE



PP01 FAILURE OF PLANT PROCESS COMPUTER  
 RD01 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD02 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD03 CONTROL ROD XX-YY FAILURE - ACCUMULATOR STUCK  
 RD04 CONTROL ROD XX-YY FAILURE - STUCK  
 RD05 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD06 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD07 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD08 CONTROL ROD XX-YY FAILURE - RPIS  
 RD09 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD10 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD11 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD12 CONTROL ROD XX-YY FAILURE - STUCK  
 RD13 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD14 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD15 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD16 CONTROL ROD XX-YY FAILURE - RPIS  
 RD17 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD18 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD19 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD20 CONTROL ROD XX-YY FAILURE - STUCK  
 RD21 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD22 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD23 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD24 CONTROL ROD XX-YY FAILURE - RPIS  
 RD25 CONTROL ROD XX-YY FAILURE - DRIFT IN  
 RD26 CONTROL ROD XX-YY FAILURE - DRIFT OUT  
 RD27 CONTROL ROD XX-YY FAILURE - ACCUMULATOR TROUBLE  
 RD28 CONTROL ROD XX-YY FAILURE - STUCK  
 RD29 CONTROL ROD XX-YY FAILURE - UNCOUPLED  
 RD30 CONTROL ROD XX-YY FAILURE - SCRAMMED  
 RD31 CONTROL ROD XX-YY FAILURE - SLOW SCRAM TIME  
 RD32 CONTROL ROD XX-YY FAILURE - RPIS  
 RD33 CONTROL ROD BANK FAILURE TO SCRAM (BANK I, II, III, IV, V OR :ANY)  
 RD34 LOSS OF CRD INSTRUMENT AIR PRESSURE  
 RD35 CRD HYDRAULIC PUMP TRIP (11, 12 OR BOTH)  
 RD36 CRD FLOW CONTROL VALVE FAILURE - CLOSED (11, 12 OR BOTH)





RD37 RPIS FAILURE - COMPLETE SYSTEM FAILURE  
 RD38 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - WITHDRAWN  
 RD39 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - INSERT  
 RD40 REACTOR MANUAL CONTROL SYSTEM TIMER MALFUNCTION - SETTLE  
 RD41 SCRAM DISCHARGE VOLUME RUPTURE  
 RM01 DRAWER INOPERATIVE FOR ANY PROCESS RADIATION MONITOR SIMULATED  
 (INSTRUCTOR SELECT)  
 RM02 DRAWER DOWNSCALE FOR ANY AREA RADIATION MONITOR SIMULATED (INSTRUCTOR  
 SELECT)  
 RM03 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED  
 RM04 DRAWER UPSCALE FOR ANY AREA RADIATION MONITOR SIMULATED  
 RM05 CONTINUOUS AIR MONITOR FAILURE (TURBINE BUILDING, REACTOR BUILDING,  
 WASTE BUILDING, DRYWELL)  
 RM06 ANY PROCESS RADIATION MONITOR FAILURE  
 RP01 REACTOR TRIP POWER SUPPLY MOTOR GENERATOR (131, 141 OR BOTH)  
 RP02 CONTROL POWER SUPPLY BOTH MOTOR GENERATOR TRIPS (162, 172 OR BOTH)  
 RP03 REACTOR SCRAM  
 RP04 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - AUTOMATIC  
 RP05 REACTOR PROTECTION SYSTEM FAILURE TO SCRAM - COMPLETE  
 RP06 REACTOR VESSEL ISOLATION  
 RP07 PRIMARY CONTAINMENT ISOLATION  
 RP08 ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS)  
 RP09 EMERGENCY CONDENSER FAILS TO ISOLATE (11, 12 OR BOTH)  
 RR01 RECIRCULATION PUMP 11 DRIVE BREAKER TRIP  
 RR02 RECIRCULATION PUMP 11 FIELD BREAKER TRIP  
 RR03 RECIRCULATION PUMP 11 SEIZURE  
 RR04 RECIRCULATION PUMP 11 CONTROL SIGNAL FAILURE  
 RR05 RECIRCULATION PUMP 11 INCOMPLETE START SEQUENCE  
 RR06 RECIRCULATION PUMP 12 DRIVE BREAKER TRIP  
 RR07 RECIRCULATION PUMP 12 FIELD BREAKER TRIP  
 RR08 RECIRCULATION PUMP 12 SEIZURE  
 RR09 RECIRCULATION PUMP 12 CONTROL SIGNAL FAILURE  
 RR10 RECIRCULATION PUMP 12 INCOMPLETE START SEQUENCE  
 RR11 RECIRCULATION PUMP 13 DRIVE BREAKER TRIP  
 RR12 RECIRCULATION PUMP 13 FIELD BREAKER TRIP  
 RR13 RECIRCULATION PUMP 13 SEIZURE  
 RR14 RECIRCULATION PUMP 13 CONTROL SIGNAL FAILURE  
 RR15 RECIRCULATION PUMP 13 INCOMPLETE START SEQUENCE



RR17 RECIRCULATION PUMP 14 FIELD BREAKER TRIP  
 RR18 RECIRCULATION PUMP 14 SEIZURE  
 RR19 RECIRCULATION PUMP 14 CONTROL SIGNAL FAILURE  
 RR20 RECIRCULATION PUMP 14 INCOMPLETE START SEQUENCE  
 RR21 RECIRCULATION PUMP 15 DRIVE BREAKER TRIP  
 RR22 RECIRCULATION PUMP 15 FIELD BREAKER TRIP  
 RR23 RECIRCULATION PUMP 15 SEIZURE  
 RR24 RECIRCULATION PUMP 15 CONTROL SIGNAL FAILURE  
 RR25 RECIRCULATION PUMP 15 INCOMPLETE START SEQUENCE  
 RR26 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - HIGH  
 RR27 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - LOW  
 RR28 MASTER RECIRCULATION FLOW CONTROLLER FAILURE - AS IS  
 RR30 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - UPSCALE  
 RR31 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - DOWNSCALE  
 RR32 REACTOR VESSEL PRESSURE RECORDER FAILURE (ID77) - AS IS  
 RR33 RECIRCULATION PUMP LOWER (INNER) SEAL FAILURE - PUMP 11  
 RR34 RECIRCULATION PUMP UPPER (OUTER) SEAL FAILURE - PUMP 11  
 RR35 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - UPSCALE  
 RR36 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - DOWNSCALE  
 RR37 REACTOR VESSEL PRESSURE INDICATOR FAILURE (ID76C) - AS IS  
 RR38 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - UPSCALE  
 RR39 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - DOWNSCALE  
 RR40 REACTOR VESSEL LEVEL RECORDER FAILURE (ID14) - AS IS  
 RR41 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - UPSCALE  
 (ID59D)  
 RR42 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - DOWNSCALE  
 (ID59D)  
 RR43 REACTOR VESSEL LEVEL INDICATION (CONTROL SYSTEM) FAILURE - AS IS  
 (ID59D)  
 RR44 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 UPSCALE (LI 36-19, CH.12)  
 RR45 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 DOWNSCALE (LI 36-19, CH.12)  
 RR46 REACTOR VESSEL LEVEL INDICATION (WIDE RANGE SAFETY SYSTEM) FAILURE -  
 AS IS (LI 36-19, CH.12)  
 RR47 RECIRCULATION PUMP DISCHARGE VALVE STEM SEPARATES FROM VALVE GATE  
 (11, 12, 13, 14, 15 OR ANY)



RR48 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
UPSCALE

RR49 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
DOWNSCALE

RR50 REACTOR VESSEL LEVEL INDICATION (FUEL ZONE SAFETY SYSTEM) FAILURE -  
AS IS

RR51 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - HIGH

RR52 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - LOW

RR53 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - AS IS

RR54 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
HIGH

RR55 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
LOW

RR56 REACTOR VESSEL LEVEL TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT) FAILS -  
AS IS

RR57 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - HIGH

RR58 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - LOW

RR59 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-REACTOR PROTECTION SYSTEM  
INPUT) FAILS - AS IS

RR60 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - HIGH

RR61 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - LOW

RR62 REACTOR VESSEL PRESSURE TRANSMITTER (LOCAL-CONTROL SYSTEM INPUT)  
FAILS - AS IS

RR63 REACTOR RECIRCULATION PUMP 12 INNER SEAL FAILURE

RR64 REACTOR RECIRCULATION PUMP 12 OUTER SEAL FAILURE

RR65 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - HIGH

RR66 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - LOW

RR67 REACTOR RECIRCULATION PUMP 15 TACHOMETER FAILS - OSCILLATES

RR68 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - INCREASE (11, 12,  
13, 14, 15 OR ANY)

-27 June 1988



RR69 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - DECREASE (11, 12,  
 13, 14, 15 OR ANY)  
 RR70 REACTOR RECIRCULATION PUMP M/A STATION FAILURE - AS IS (11, 12, 13,  
 14, 15 OR ANY)  
 RR71 REACTOR SAFETY VALVE INADVERTENTLY OPENS (PSV NR28A)  
 RR72 LOSS OF LEVEL COMPENSATION TO FEEDWATER CONTROL SYSTEM (GEMAC) LEVEL  
 TRANSMITTER  
 RW01 ROD WORTH MINIMIZER FAILURE  
 RX01 FUEL CLADDING FAILURE  
 RX02 INCREASED ROD WORTH FOR ANY CONTROL ROD  
 SC01 SHUTDOWN COOLING PUMP TRIP (11, 12, 13 OR ANY)  
 SC02 SHUTDOWN COOLING HEAT EXCHANGER TUBE LEAK (11, 12, 13 OR ANY)  
 TC01 MAIN TURBINE TRIP  
 TC02 TURBINE GOVERNOR FAILS - HIGH  
 TC03 TURBINE GOVERNOR FAILS - LOW  
 TC04 ELECTRICAL PRESSURE REGULATOR FAILS - HIGH  
 TC05 ELECTRICAL PRESSURE REGULATOR FAILS - LOW  
 TC06 ELECTRICAL PRESSURE REGULATOR FAILS - OSCILLATES  
 TC07 MECHANICAL PRESSURE REGULATOR FAILS - HIGH  
 TC08 MECHANICAL PRESSURE REGULATOR FAILS - LOW  
 TC09 MECHANICAL PRESSURE REGULATOR FAILS - OSCILLATES  
 TC10 FIRST BYPASS VALVE STICKS OPEN  
 TC11 ALL BYPASS VALVES FAIL - OPEN  
 TC12 ALL BYPASS VALVES FAIL - CLOSED  
 TC13 TURBINE CONTROL VALVE FAILS CLOSED (11, 12, 13, 14 OR ANY)  
 TU01 EXHAUST HOOD SPRAY VALVE FAILS CLOSED  
 TU02 MAIN TURBINE HIGH VIBRATION BEARINGS #5 AND #6  
 TU03 MAIN TURBINE HIGH ECCENTRICITY  
 TU04 MAIN TURBINE BEARING OIL LOW PRESSURE  
 TU05 MAIN TURBINE BEARING HIGH TEMPERATURE  
 TU06 MAIN TURBINE THRUST BEARING WEAR





ATTACHMENT F

REMOTE FUNCTIONS

AD

ADS NONE

AN

ANNUNCIATOR SYSTEM NONE

CS

CORE SPRAY NONE

CT

CONTAINMENT SPRAY	RCT 1 80-43 TEST LINE TO TORUS BV	OPEN	CLOSE
	RCT 2 80-42 WASTE DISP MAN ISOLATION	OPEN	CLOSE

CU


REACTOR CLEANUP	RCU1 CU-16 PCV ND37 MANUAL ISOLATION	OPEN	CLOSE
	RCU2 CU-19 FILTER BYPASS VALVE	OPEN	CLOSE
	RCU3 CU FILTER 11 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU4 CU FILTER 12 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU5 CU DEMIN 11 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU6 CU DEMIN 12 INLET/OUTLET VALVE	OPEN	CLOSE
	RCU7 CU-20 DEMIN BYPASS VALVES	OPEN	CLOSE

CW1

AUXILIARY WATER	RCW1 INTAKE WATER TEMPERATURE	32/80 DEG	75.00
	RCW2 INTAKE TUNNEL REVERSE FLOW	YES	NO
	RCW3 UPPER WIND SPEED	0.100 MPH	52.00
	RCW4 UPPER WIND SPED VARIATION	0/30 MPH	5.00
	RCW5 LOWER WIND SPEED	0/100 MPH	45.00
	RCW6 LOWER WIND SPEED VARIATION	0/30 MPH	5.00
	RCW7 UPPER WIND DIRECTION	0/360 MPH	5.00
	RCW8 UPPER WIND DIRECTION VARIATION	0/90 DEG	5.0
	RCW9 LOWER WIND DIRECTION	0/360 DEG	5.0
	RCW10 LOWER WIND DIRECTION VARIATION	0/90 DEG	5.00
	RCW11 AMBIENT AIR TEMPERATURE	-30/+120 DEG	90.00
	RCW12 DELTA TEMPERATURE	-10/+120 DEG	10.00

CW2

AUXILIARY WATER NONE



DG

DIESEL GENERATOR	RDG1 DG 102 GOVERNOR SPEED DROOP	SET	RESET
	RDG2 DG 103 GOVERNOR SPEED DROOP	SET	RESET

EC

EMERGENCY COOLING	REC1 IV 39-05 VALVE POSITION LIMIT	0/100%	100.00
	REC2 IV 39-06 VALVE POSITION LIMIT	0/100%	100.00

ED1


ELECTRICAL DISTRIB	RED1 SOUTH OSWEGO 115 KV BKR R10	OPEN	CLOSE
	RED2 FITZ 115 KV BKR R40	OPEN	CLOSE
	RED3 PB 13 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED4 PB 13 BUS TIE BKR SEC B-SEC C	OPEN	CLOSE
	RED5 PB 14 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED6 PB 14 BUS TIE BKR SEC B-SEC B	OPEN	CLOSE
	RED7 PB 15 BUS TIE BKR SEC A-SEC B	OPEN	CLOSE
	RED8 PB 16 BUS TIE BKR SEC A-SEC C	OPEN	CLOSE
	RED9 MG-SET 167 AC POWER SELECT	PB16	17
	RED10 MG-SET 167 DC POWER SELECT	PB11	12
	RED11 COMPUTER POWER SUPPLY SELECT	NORM	EMER
	RED12 IC BUS 130 NORM PWR BKR	OPEN	CLOSE
	RED13 IC BUS 130 ALT PWR BKR	OPEN	CLOSE
	RED14 PB1671 BUS TIE BKR	OPEN	CLOSE
	RED15 PB131 CLOSE A-B, OPEN 13A SUPPLY	YES	NO
	RED16 PB131 CLOSE A-B, OPEN 13C SUPPLY	YES	NO
	RED17 PB141 CLOSE A-B, OPEN 14A SUPPLY	YES	NO
	RED18 PB141 CLOSE A-B, OPEN 14C SUPPLY	YES	NO

ED2

ELECTRICAL DISTRIB	RED19 PB151 CLOSE A-B, OPEN 15A SUPPLY	YES	NO
	RED20 PB151 CLOSE A-B, OPEN 15C SUPPLY	YES	NO
	RED21 PB176 CLOSE A-B, OPEN 17A SUPPLY	YES	NO
	RED22 PB176 CLOSE A-B, OPEN 16A SUPPLY	YES	NO
	RED23 BAT BD11 EQUIP SW TO ALT	BB11	BB12
	RED24 BAT BD12 EQUIP SW TO ALT	BB12	11
	RED25 PB143 FEEDER BREAKER	14A	14C

ED3

ELECTRICAL DISTRIB	NONE		
--------------------	------	--	--



EG1

## MAIN GENERATOR

REG1 345 KV BKR 100 42	OPEN	CLOSE
REG2 345 KV MAN DISC 917	OPEN	CLOSE
REG3 345 KV MAN DISC 926, 927	OPEN	CLOSE
REG4 345 KV MOD SW 18	OPEN	CLOSE
REG5 345 KV BKR R915/10	OPEN	CLOSE
REG6 345 KV BKR R925/20	OPEN	CLOSE
REG7 MAIN SEAL OIL PMP STATUS	START	NEUT
REG8 EMER SEAL OIL PMP STATUS	START	NEUT
REG9 EMER SEAL OIL PMP STATUS	TRIP	AUTO
REG10 GEN STATOR COOLING PMP 11	START	NEUT
REG11 GEN STATOR COOLING PMP 11	TRIP	AUTO
REG12 GEN STATOR COOLING PMP 12	START	NEUT
REG13 GEN STATOR COOLING PMP 12	TRIP	AUTO
REG14 GENERATOR OUTPUT LINKS	OPEN	CLOSE
REG15 GEN HYDROGEN SUPPLY VALVE	OPEN	CLOSE
REG16 BACKFEED INTERLOCKS	ON	OFF

EG2

## MAIN GENERATOR

NONE

FP

## FIRE PROTECTION

RFP1 CITY WATER SUPPLY TO FP HDR	OPEN	CLOSE
RFP2 SUPPLY TO EMER COOL MU TANK 11	OPEN	CLOSE
RFP3 SUPPLY TO EMER COOL MU TANK 12	OPEN	CLOSE
RFP4 SUPPLY TO FEEDWATER SYSTEM	OPEN	CLOSE
RFP5 DIESEL FIRE PUMP STATUS	OFF	AUTO



FW1

## FEEDWATER

RFW1 50-10 COND PUMP 11 DISCH VLV	OPEN	CLOSE
RFW2 50-11 COND PUMP 12 DISCH VLV	OPEN	CLOSE
RFW3 50-12 COND PUMP 13 DISCH VLV	OPEN	CLOSE
RFW4 50-31 COND DEMIN BYPASS VLV	OPEN	CLOSE
RFW5 COND DEMIN 11 INLET/OUTLET VLV	OPEN	CLOSE
RFW6 COND DEMIN 12 INLET/OUTLET VLV	OPEN	CLOSE
RFW7 COND DEMIN 13 INLET/OUTLET VLV	OPEN	CLOSE
RFW8 COND DEMIN 14 INLET/OUTLET VLV	OPEN	CLOSE
RFW9 COND DEMIN 15 INLET/OUTLET VLV	OPEN	CLOSE
RFW10 COND DEMIN 16 INLET/OUTLET VLV	OPEN	CLOSE
RFW11 50-20 SJAE BYPASS FCB	0/100%	50.00
RFW12 50-40 BOOSTER PUMP 11 SUCTION V	OPEN	CLOSE
RFW13 50-39 BOOSTER PUMP 12 SUCTION V	OPEN	CLOSE
RFW14 50-38 BOOSTER PUMP 13 SUCTION V	OPEN	CLOSE
RFW15 FW HEATER STRING 11 ISOL VLVS	OPEN	CLOSE
RFW17 FW HEATER STRING 12 ISOL VLVS	OPEN	CLOSE
RFW18 DEMIN WATER STORAGE TANK REFILL	OPEN	CLOSE

FW2

## FEEDWATER

RFW19 50-16 BYPASS AROUND FCV 50-22	OPEN	CLOSE
RFW20 MANUAL OPERATION OF LCV50-15	0/100%	0.00
RFW21 MANUAL OPERATION OF LCV50-07,08	0/100%	0.00
RFW22 FW HEATER 135 ISOL VALVES	OPEN	CLOSE
RFW23 HOTWELL LEVEL CONTROL	MAN	AUTO

FW3

## FEEDWATER

NONE

HV

## HVAC


NONE

IA

## INSTRUMENT AIR

RIA1 INST AIR SUP TO BREATHING AIR	OPEN	CLOSE
RIA2 BRW-G-6 WASTE DISPOSAL XTIE	OPEN	CLOSE
RIA3 94-42 CONT SPRAY AIR RCVR ISOL	OPEN	CLOSE
RIA4 SERV AIR TO INST AIR BV	TRIP	RESET





LP

## LIQUID POISON

RLP1 LIQ POISON PMP 11 LOCAL START	ON	OFF
RLP2 LIQ POISON PUMP 12 LOCAL START	ON	OFF
RLP3 DEMIN WATER TO LP PUMPS	OPEN	CLOSE

MC

## CONDENSER

RMC1 OG-1,2 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
RMC2 DG-3,4 PRIM JET VAP SUCT VALVES	OPEN	CLOSE
RMC3 MS 114,15 PRIM JET STEAM VALVES	OPEN	CLOSE
RMC4 MS-16,1 PRIM JET STEAM VALVES	OPEN	CLOSE
RMC5 OG-9,10 SEC JET VAPOR SUCT VALVES	OPEN	CLOSE
RMC6 MS-19,20 SEC JET STEAM VALVES	OPEN	CLOSE
RMC7 MS-12 SJAE PCV BYPASS	OPEN	CLOSE

MS1

## MAIN STEAM

RMS1 HP FW HTR 115 RESET	TRIP	RESET
RMS2 HP FW HTR 125 RESET	TRIP	RESET
RMS3 HP FW HTR 135 RESET	TRIP	RESET
RMS4 HP FW HTR STRING 11 RESET	TRIP	RESET
RMS5 HP FW HTR STRING 12 RESET	TRIP	RESET
RMS6 HP FW HTR STRING 13 RESET	TRIP	RESET
RMS7 MS-8 MAIN STEAM LINE ISOL	OPEN	CLOSE
RMS8 SPE 11 SUCTION VALVE	OPEN	CLOSE
RMS9 SPE 12 SUCTION VALVE	OPEN	CLOSE
RMS10 TRIP ALL FW HTR EXTR NRVS	TRIP	RESET

MS1

## MAIN STEAM

NONE

NM1

## NEUTRON MONITOR

RNM1 APRM 11 GAIN	0/100%	2.43
RNM2 APRM 12 GAIN	0/100%	2.38
RNM3 APRM 13 GAIN	0/100%	2.36
RNM4 APRM 14 GAIN	0/100%	2.39
RNM5 APRM 15 GAIN	0/100%	2.20
RNM6 APRM 16 GAIN	0/100%	2.18
RNM7 APRM 17 GAIN	0/100%	2.16
RNM8 APRM 18 GAIN	0/100%	2.17

NM2

## NEUTRON MONITOR

NONE

NM3

## NEUTRON MONITOR

NONE



OD  
ON DEMAND

NON-FUNCTIONAL

PC  
CONTAINMENT

RPC1	NITROGEN FROM VAPORIZER	YES	NO
RPC2	201.7-13 DW CAM ISOL VLV 11	OPEN	CLOSE
RPC3	201.7-29 DW CAM ISOL VLV 12	OPEN	CLOSE
RPC4	201.40,41 DW, TORUS TO VENT SYSTEM	OPEN	CLOSE
RPC5	201.44, 46 DW, TORUS TO ATMOS	OPEN	CLOSE
RPC6	BV201.2-135,136 INTERLOCK DEFEAT	YES	NO
RPC7	IV201-31,32 ISOLATION DEFEAT	YES	NO

PP  
PROCESS COMPUTER

RPP01	MEMORY PROTECT PLAN	NORM	REMOVED
-------	---------------------	------	---------

RD1  
CONTROL RODS

RRD1	301.2A CRD PUMP 11 DISCH VLV	OPEN	CLOSE
RRD2	301.2B CRD PUMP 12 DISCH VLV	OPEN	CLOSE
RRD3	301-8A CRD PUMP 11 HEAD SPRAY ISOL	OPEN	CLOSE
RRD4	301-8B CRD PUMP 12 HEAD SPRAY ISOL	OPEN	CLOSE
RRD5	301.8B CRD FLOW CONTROL VLV ISOL	NC30A	NC30B

RD2  
CONTROL RODS

NONE

RD3  
CONTROL RODS

NONE

RM1  
RAD MONITOR

NONE

RP  
RPS

RRP1	RX TRIP BUS 131 PWR SOURCE	NORM	EMER
RRP2	RX TRIP BUS 141 PWR SOURCE	NORM	EMER
RRP3	RPS BUS 11 PWR SOURCE	NORM	EMER
RRP4	BUS 12 PWR SOURCE	NORM	EMER



RR1

REACTOR RECIRC	RRR1 RECIRC MG-SETS 11 LOCKOUT RELAY	TRIP	RESET
	RRR2 RECIRC MG-SETS 12 LOCKOUT RELAY	TRIP	RESET
	RRR3 RECIRC MG-SETS 13 LOCKOUT RELAY	TRIP	RESET
	RRR4 RECIRC MG-SETS 14 LOCKOUT RELAY	TRIP	RESET
	RRR5 RECIRC MG-SETS 15 LOCKOUT RELAY	TRIP	RESET

RR2

REACTOR RECIRC	NONE
----------------	------

RR3

REACTOR RECIRC	NONE
----------------	------

RR4

REACTOR RECIRC	NONE
----------------	------

RW

ROD WORTH MINIMIZER	RRW1 CONTROL ROD SEQUENCE SELECT	B	A
---------------------	----------------------------------	---	---

RX

REACTOR CORE	NONE
--------------	------

SC


SHUTDOWN COOLING	NONE
------------------	------

TC

TURBINE CONTROL	RTC1 REACTOR FLOW LIMIT	0-120%	120.00
	RTC2 CONTROL VALVE LIMIT	0-120%	100.00

TU

MAIN TURBINE	NONE
--------------	------




ATTACHMENT "G"


MONITORED PARAMETERS

1. CORE REACTIVITY DK/K
2. CORE THERMAL POWER, %
3. CORE FLOW, LBM/HR
4. CORE PLATE DIFFERENTIAL PRESSURE, PSIG
5. CORE BORON CONCENTRATION, PPM
6. CORE AVERAGE VOID FRACTION, %
7. CORE MINIMUM CRITICAL POWER RATIO
8. CORE MAXIMUM LINEAR HEAT GENERATION, KW/FT
9. CORE INLET SUB COOLING, BTU/LBM
10. CORE AVERAGE FUEL TEMPERATURE, DEG F
11. CORE AVERAGE CLADDING TEMPERATURE, DEG F
12. CORE AVERAGE EXIT QUALITY, %
13. (SPARE)
14. (SPARE)
15. REACTOR COOLANT ACTIVITY, UCI/ML
16. REACTOR COOLANT CONDUCTIVITY, UMHO/CM
17. REACTOR HEATUP/COOLDOWN RATE, DEG F/HR
18. REACTOR LEVEL-NARROW RANGE, INCHES
19. REACTOR LEVEL-WIDE RANGE, FEET
20. REACTOR PRESSURE, PSIG
21. RECIRCULATION LOOP 11 FLOW, LBM/HR
22. RECIRCULATION LOOP 12 FLOW, LBM/HR
23. RECIRCULATION LOOP 13 FLOW, LBM/HR
24. RECIRCULATION LOOP 14 FLOW, LBM/HR
25. RECIRCULATION LOOP 15 FLOW, LBM/HR
26. RECIRCULATION LOOP 11 SUCTION TEMPERATURE, DEG F
27. RECIRCULATION LOOP 12 SUCTION TEMPERATURE, DEG F
28. RECIRCULATION LOOP 13 SUCTION TEMPERATURE, DEG F
29. CRD SYSTEM FLOW, LBM/HR :
30. DRYWELL PRESSURE, PSIG
31. DRYWELL AVERAGE TEMPERATURE, DEG F
32. DRYWELL HYDROGEN CONCENTRATION, %
33. DRYWELL OXYGEN CONCENTRATION, %






34. SUPPRESSION CHAMBER PRESSURE, PSIG
35. SUPPRESSION POOL WATER TEMPERATURE, DEG F
36. SUPPRESSION POOL WATER LEVEL, FEET
37. SRM COUNT RATE, CPS
38. SRM PERIOD, SEC
39. APRM POWER LEVEL, %
40. CORE XENON CONCENTRATION, % OF FULL POWER EQU
41. RWCU SYSTEM PRESSURE, SPIG
42. RWCU SYSTEM FLOW, LBM/HR
43. RWCU NON-REGEN HEAT EXCHAN OUTLET TEMPERATURE, DEG F
44. RWCU DUMP FLOW, LBM/HR
45. TOTAL MAIN STEAM LINE FLOW, LBM/HR
46. MAIN STEAM TUNNEL TEMPERATURE, DEG F
47. MAIN STEAM LINE RADIATION LEVEL, MR/HR
48. TOTAL MAIN STEAM RELIEF VALVE FLOW, LBM/HR
49. TURBINE SPEED, RPM
50. TURBINE INLET PRESSURE, PSIG
51. TURBINE STEAM FLOW, LBM/HR
52. TURBINE BYPASS VALVE STEAM FLOW, LBM/HR
53. TURBINE FIRST STAGE PRESSURE, PSIG
54. TURBINE EXHAUST HOOD TEMPERATURE, DEG F
55. SECOND STAGE REHEATER OUTLET PRESSURE, PSIG
56. SECOND STAGE REHEATER OUTLET TEMPERATURE, DEG F
57. CONDENSER VACUUM, IN HG V
58. CONDENSER HOTWELL LEVEL, INCHES
59. CONDENSER HOTWELL CONDUCTIVITY, UMHO/CM
60. CONDENSER VACUUM MAKEUP FLOW, LBM/HR
61. CONDENSER HOTWELL REJECT FLOW, LBM/HR
62. CONDENSATE DEPRESSION, BTU/LBM
63. CIRCULATING WATER INLET TEMPERATURE, DEG F
64. CIRCULATING WATER OUTLET TEMPERATURE, DEG F
65. TOTAL CIRCULATING WATER FLOW, GPM
66. CONDENSATE DEMINERA OUTLET CONDUCT, UMHO/CM
67. TOTAL FEEDWATER SYSTEM FLOW, LBM/HR
68. FEEDWATER TEMPERATURE TO REACTOR, DEG F
69. GENERATOR LOAD, MWE
70. GENERATOR REACTIVE LOAD, MVAR



71. GENERATOR STATOR AMPS, AMP
72. GENERATOR TERMINAL VOLTS, VOLT
73. GENERATOR HYDROGEN PRESSURE, PSIG
74. DIESEL GENERATOR 102 LOAD, KWE
75. DIESEL GENERATOR 103 LOAD, KWE
76. OFF-GAS SYSTEM INLET FLOW, CFM
77. OFF-GAS SYSTEM OUTLET FLOW, CFM
78. OFF-GAS RECOMBINER INLET HYDROGEN CONCENTRATION, %
79. OFF-GAS RECOMBINER OUTLET HYDROGEN CONCENTRATION, %
80. OFF-GAS SYSTEM RADIATION LEVEL, MR/HR
81. CORE SPRAY LOOP 11 PRESSURE, PSIG
82. CORE SPRAY LOOP 12 PRESSURE, PSIG
83. CORE SPRAY LOOP 11, FLOW, LBM/HR
84. CORE SPRAY LOOP 12 FLOW, LBM/HR
85. EMERGENCY CONDENSER LOOP 11 FLOW, LBM/HR
86. EMERGENCY CONDENSER LOOP 12 FLOW, LBM/HR
87. EMERGENCY CONDENSER LOOP 11 RETURN TEMPERATURE, DEG F
88. EMERGENCY CONDENSER LOOP 12 RETURN TEMPERATURE, DEG F
89. EMERGENCY CONDENSER LOOP 11 VENT RAD LEVEL, MR/HR
90. EMERGENCY CONDENSER LOOP 12 VENT RAD LEVEL, MR/HR



ATTACHMENT H

SIMULATOR MODIFICATION DATA BASE CHANGES AND TEST RESULTS

A. N1-86-057 RWM Inoperability

- 1) Test Results - Satisfactory
- 2) Data Base Changes

RWM Drawings: N1Y86MO57


<u>PRINT</u>	<u>SHEET</u>	<u>REV</u>	<u>INDEX</u>
C-22032-C	1	3	E21.2
C-22032-C	2	3	E21.2
C-22032-C	3	2	E21.2
C-22032-C	4	2	E21.2
C-22032-C	5	5	E21.2
C-22032-C	6	4	E21.2
C-22032-C	7	3	E21.2
C-22032-C	8	2	E21.2

B. N1-80-072 Alternate Rod Insertion

- 1) Test Results - Satisfactory
- 2) Data Base Changes

ARI Prints: N1-80-072

<u>DWG</u>	<u>SHEET</u>	<u>REV</u>	<u>INDEX</u>
C-34128-C	1	8	
C-34128-C	2	8	
C-34128-C	3	8	
C-18016-C	2		
C-22374-C	1	33	E9
C-22374-C	2	7	E9
C-22374-C	3	24	E9
C-22374-C	4	37	E9
C-22374-C	5	13	E9



ATTACHMENT H (Cont'd)

SIMULATOR MODIFICATION DATA BASE CHANGES AND TEST RESULTS


C. N1-85-098 Containment Isolation on High Radiation

- 1) Test Results Satisfactory
- 2) Data Base Changes

Simulator Modification Data Base Changes and Test Results

(.2)	<u>DWG</u>	<u>SHEET</u>	<u>REV</u>	<u>INDEX</u>
	C-22025-C	4	7	E21
	C-22379-C	3	23	E21
	C-22383-C	2	17	E21
	C-22383-C	6	16	E21
	C-22383-C	7	13	E21
	C-22385-C	1	30	E21
	C-22385-C	2	21	E21
	C-22385-C	3	21	E21
	C-22385-C	3A	1	E21
	C-22385-C	8	26	E21
	C-22385-C	10	22	E21






ANSI 3.5 REPORT - 1988

ATTACHMENT I

MALFUNCTIONS TESTED IN 1988

AD03	EG11	NM13	RR26
AN01	FP01	NM21	RR30
CT01	FP05	NM34	RR34
CU02	FP09	NM39	RR38
CU06	FW03	OG03	RR42
CU10	FW07	PC03	RR46
CW03	FW11	RD03	RR50
CW07	FW15	RD07	RR54
DG01	FW19	RD35	RR58
EC03	FW23	RD39	RR62
EC07	FW27	RM02	RR66
ED04	HV02	RP03	RR70
ED08	MC02	RP07	RX01
ED12	MC06	RR03	TC01
ED16	MS04	RR07	TC05
ED20	MS08	RR11	TC09
ED24	NM01	RR15	TC13
EG03	NM05	RR19	TU04
EG07	NM09	RR23	

I-1



ATTACHMENT J

LATE MODIFICATION STATUS

N1-81-029 Emergency Ventilation	Ready for Testing
N1-81-038 Drywell Cooling	Awaiting Data and Evaluation
N1-83-061 Control Room HVAC Upgrade	Ready for Testing
N1-84-013 Replace IA 222/223	Ready for Testing
N1-85-016 Scriba Substation Phase II	Awaiting Data & Evaluation
N1-85-017 Scriba Substation Phase III	In Progress
N1-85-022 Electric and Diesel Fire Pumps	Ready for Testing

Reflects modification status as of July 1, 1988



o

