

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION MBR:9502160048 DOC.DATE: 95/02/13 NOTARIZED: NO DOCKET #
 FACIL:50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 AUTH.NAME AUTHOR AFFILIATION
 SALAS,P. Tennessee Valley Authority
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

See Rpt.

SUBJECT: Forwards "Brown Ferry Nuclear Plant Unit 2,Cycle 7 ISI NIS-1 Rept," in accordance w/paragraphs IWA-6220 & IWA-6230 of ASME B&PV Code,Section XI,1986 Edition.

DISTRIBUTION CODE: A047D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2+500
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-4	1 1	PD2-4-PD	1 1
	WILLIAMS, J.	1 1		
INTERNAL:	ACRS	6 6	AEOD/SPD/RAB	1 1
	FILE CENTER OIP	1 1	NRR/DE/EMCB	1 1
	NRR/DE/EMEB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS3	1 0	RES/DSIR/EIB	1 1
EXTERNAL:	LITCO BROWN, B	1 1	LITCO RANSOME, C	1 1
	NOAC	1 1	NRC PDR	1 1


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 20 ENCL 19

MA2

P
R
I
O
R
I
T
Y
.
1
D
O
C
U
M
E
N
T





Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

February 13, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket No. 50-260
Tennessee Valley Authority)

**BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 2 CYCLE 7 INSERVICE
INSPECTION, REPAIR AND REPLACEMENT, AND PRESERVICE INSPECTION
SUMMARY REPORTS**

In accordance with paragraphs IWA-6220 and IWA-6230 of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 1986 Edition, TVA submits the BFN Unit 2 Cycle 7 summary reports for NRC review. In addition, TVA is including corrections to the BFN Unit 2 Cycle 6, inservice inspection and repair and replacement reports.

Enclosures 1 and 2 respectively contain historical records of BFN Unit 2 Cycle 7, inservice inspection and repair and replacement summary reports for Code Class 1 and 2 pressure retaining components and their supports. Enclosure 3 contains the preservice inspection report for Code Class 1 and 2 components. These reports are for activities that were performed from June 4, 1993 through November 23, 1994.

Additionally, Enclosure 4 provides corrections to BFN Unit 2 Cycle 6 inservice inspection and repair and replacement reports. The corrections included, changes such as revising a component's category item number and clarifying a component's examination type.

15-019

9502160048 950213
PDR ADDCK 05000260
Q PDR

AOA7
11




1 2

3 4

U.S. Nuclear Regulatory Commission
Page 2
February 13, 1995

There are no commitments contained in this letter. If you have any questions please contact me at (205) 729-2636.

Sincerely,



Pedro Salas
Manager of Site Licensing

Enclosures.

cc (Enclosures):

Mr. Mark S. Lesser, Section Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35611

Mr. J. F. Williams, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852


ENCLOSURE 1

BROWNS FERRY NUCLEAR PLANT

UNIT 2, CYCLE 7
INSERVICE INSPECTION NIS-1 REPORT

50-260
2/13/95

950216 0048



TENNESSEE VALLEY AUTHORITY

PREPARED BY: [Signature] TVA NDE L-III 1-12-95


PREPARED BY: [Signature] 1-12-95

REVIEWED BY: [Signature] 1-12-95

REVIEWED BY: [Signature] 1-12-95

H.L. WILLIAMS, MANAGER
ENGINEERING & MATERIALS

[Signature] 1/12/95



9502168048

ENCLOSURE 2

**BROWNS FERRY
NUCLEAR PLANT**

UNIT 2 CYCLE 7

ASME SECTION XI

NIS-2 DATA REPORT

OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

APPENDIX I _____ **Summary of Repair and
Replacement Activities**

APPENDIX II _____ **Form NIS-2 Owner's Report For
Repairs or Replacements**

Owner: TENNESSEE VALLEY AUTHORITY
Nuclear Power Group
1101 Market Street
Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

APPENDIX I

SUMMARY OF REPAIR AND REPLACEMENT ACTIVITIES



Owner: TENNESSEE VALLEY AUTHORITY
Nuclear Power Group
1101 Market Street
Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

The following compilation of Form NIS-2 Owner's Report For Repairs Or Replacements is an accounting of those Class 1 and Class 2 repairs and replacements performed during the Unit 2 Cycle 7 period of operation. Records of pump and valve inservice tests that were required to be performed as a result of a repair or replacement activity are listed on the applicable Form NIS-2.

Class 3 Form NIS-2 Owner's Report for Repairs Or Replacements are contained in the Browns Ferry Plant Report.



Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

<u>WID</u>	<u>SYS</u>	<u>ORG</u>	<u>CLASS</u>	<u>ACTIVITY</u>
92-60477-04	1	TVA	1	REPAIRED
92-60447-05	1	TVA	1	REPLACED
94-09849-00	1	TVA	1	REPLACED
94-09849-01	1	TVA	1	REPLACED
94-09849-02	1	TVA	1	REPLACED
94-09849-03	1	TVA	1	REPLACED
94-09849-04	1	TVA	1	REPLACED
94-09849-05	1	TVA	1	REPLACED
94-09849-06	1	TVA	1	REPLACED
94-09849-07	1	TVA	1	REPLACED
94-09849-08	1	TVA	1	REPLACED
94-09849-09	1	TVA	1	REPLACED
94-09849-10	1	TVA	1	REPLACED
94-09849-11	1	TVA	1	REPLACED
94-09849-12	1	TVA	1	REPLACED
94-15972-01	1	TVA	1	REPLACED
94-06277-00	63	TVA	2	REPLACED
94-00227-00	68	TVA	1	REPLACED
94-09648-00	68	GE	1	REPAIRED
94-11598-01	68	GE	1	REPAIRED
94-11598-02	68	GE	1	REPAIRED
94-13986-00	68	GE	1	REPLACEMENT
94-15880-00	68	GE	1	REPLACED/ REPLACEMENT
W21635-001	68	GE	1	REPAIRED
94-01951-00	71	TVA	2	REPLACED

Owner: TENNESSEE VALLEY AUTHORITY
Nuclear Power Group
1101 Market Street
Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

<u>WID</u>	<u>SYS</u>	<u>ORG</u>	<u>CLASS</u>	<u>ACTIVITY</u>
93-02108-00	74	TVA	2	REPLACED
94-09648-01	74	GE	1	REPAIRED
94-11598-03	74	GE	1	REPAIRED
94-09980-00	75	GE	1	REPAIRED
94-10308-00	85	NES	1	REPLACED/ REPLACEMENT
94-10308-01	85	NES	1	REPLACED/ REPLACEMENT
94-10308-02	85	NES	1	REPLACED/ REPLACEMENT
94-10308-03	85	NES	1	REPLACED/ REPLACEMENT
94-10308-04	85	NES	1	REPLACED/ REPLACEMENT
94-10308-05	85	NES	1	REPLACED/ REPLACEMENT
94-10308-06	85	NES	1	REPLACED/ REPLACEMENT
94-10308-07	85	NES	1	REPLACED/ REPLACEMENT
94-10308-08	85	NES	1	REPLACED/ REPLACEMENT
94-10308-09	85	NES	1	REPLACED/ REPLACEMENT
94-10308-10	85	NES	1	REPLACED/ REPLACEMENT
94-10308-11	85	NES	1	REPLACED/ REPLACEMENT

Owner: TENNESSEE VALLEY AUTHORITY
Nuclear Power Group
1101 Market Street
Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

<u>WID</u>	<u>SYS</u>	<u>ORG</u>	<u>CLASS</u>	<u>ACTIVITY</u>
94-10308-12	85	NES	1	REPLACED/ REPLACEMENT
94-10308-13	85	NES	1	REPLACED/ REPLACEMENT
94-10308-16	85	NES	1	REPLACED
94-10308-17	85	NES	1	REPLACED
94-10308-18	85	NES	1	REPLACED
94-10308-19	85	NES	1	REPLACED
94-10308-20	85	NES	1	REPLACED



Owner: TENNESSEE VALLEY AUTHORITY Nuclear Power Group 1101 Market Street Chattanooga, TN 37402-2801	Plant: Browns Ferry Nuclear Plant P.O. Box 2000 Decatur, AL 35609-2000
Unit: Two	Certificate of Authorization: Not Required
Commercial Service Date: March 1, 1975	
National Board Number For Unit: Not Required	

LEGEND

WID - Work Implementing Document

- ex. Wxxxxx-xxx refers to a workplan
- 9x-xxxxx-xx refers to a work order

SYS - System

- | | |
|-------------------------------------|----------------------------|
| 1 - Main Steam | 74 - Residual Heat Removal |
| 63 - Standby Liquid Control | 75 - Core Spray |
| 68 - Reactor Water Recirculation | 85 - Control Rod Drive |
| 71 - Reactor Core Isolation Cooling | |

ORG - Organization which performed the WID

- TVA - Work performed by TVA utilizing TVA and/or Stone and Webster Engineering Corporation personnel
- GE - General Electric Company
- NES - Work performed by Nuclear Energy Services utilizing TVA's Quality Assurance Program and procedures

CLASS - Refers to ASME Code Class 1 or 2

ACTIVITY - Classifies work activity as being repaired, replaced, or replacement as denoted on NIS-2 Form



Owner: TENNESSEE VALLEY AUTHORITY
Nuclear Power Group
1101 Market Street
Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

APPENDIX II

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date January 18, 1995

Sheet 1 of 7

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2
 Work Orders 92-60447-04
and 92-60447-05
Repair Organization P.O. No., Job No., etc.

3. Work Performed by TVA
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System System 1, Main Steam

5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Main Steam Line B Relief Valve	Target Rock Corp.	TVA stamped S/N 1033	N/A	2-PCV-001-0018	N/A	Repaired/Replaced	No
 	 	 	 	 	 	 	
 	 	 	 	 	 	 	
 	 	 	 	 	 	 	

Repaired indication in MSR V 2-PCV-001-0018 by grinding and replaced miscellaneous

7. Description of Work studs and nuts. The MSR V is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93
 * and ASME Section III, Article 9, 1965 Edition along with supplemental requirements contained within contract 66C60-90744

FORM NIS-2 (Back)

9. Remarks The MSR/V having S/N 1033 was originally removed from the position designated 2-PCV-1-34 during the Unit 2, Cycle 6 outage (reference WO 92-60447-00) for purposes of performing 0-SI-4.6.D-4, Disassemble One Relief Valve. WO 92-60447-04 contained the instructions for removing the indication and replacing various studs and nuts whereas WO 92-60447-05 installed the valve at the noted position of 2-PCV-1-18. In addition to performing a system leakage test per 2-SI-3.3.1.A following installation, tests conducted which were performed to satisfy ASME Sec. XI inservice test requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2, Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE repair and

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert SYSTEM ENGINEER Date JANUARY 18, 1995
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSBT & I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 9-13-94 to 11-10-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert T. Ladd Commissions NR 6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date Jan. 19, 1995

5557 1505



FORM N-2 N OR CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES*
 As Required by the Provisions of the ASME Code, Section III, Division 1
 Not To Exceed One Day's Production

Page 1 of 1

1. Manufactured and certified by Target Rock Corp.; 1966E Broadhollow Rd; Farmingdale, NY 11735
(name and address of certificate holder)

2. Manufactured for Tennessee Valley Authority C/O Bechtel Corp.; Athens, AL 35611
(name and address of purchaser)

3. Location of installation Browns Ferry Nuclear Plant; Near Athens, AL 35611
(name and address)

4. Type 102049-4 SA-193 B7 125 ksi N/A 1993
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)

5. ASME Code, Section III: 1968 Summer 1970 1 None
(edition) (addenda) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision N/A Date N/A
(No.)

7. Remarks: Spare parts for valve assembly 7567F-100-22
Stud QTY 10 Heat No. 25114

8. Nom. thickness (in.) N/A Min. design thickness (in.) N/A Dia. ID (ft. & in.) N/A Length overall (ft. & in.) N/A

9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
(1) N/A	N/A	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

ORIGINAL
 When Stamped in Red

10. Design pressure N/A psi Temp. N/A °F; Hydro. test pressure N/A at temp. °F.
(when applicable)

*Supplemental Information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in Items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.
 (6/85)-1 This form (E00040) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017.



FORM NIS-2 (back)

Mr. Serial No. N/A

CERTIFICATE OF DESIGN

Design specifications certified by R. R. Ghosh P. E. state CA Reg. no. 16371
(when applicable)
Design report* certified by D. M. Pattarini P. E. state NY Reg. no. 029841
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Part
conform to the rules of construction of the ASME Code, Section III:

NPT Certificate of Authorization no. 1498 Expires 12-12-95

Date 5/27/93 Name Target Rock Corporation Signed [Signature]
(NPT Certificate Holder) (Authorized representative)
E. Champey; Director, QA

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of New York and employed by Commercial Union Insurance Company of Boston, Mass. have inspected these items described in this data report on 5/27/93 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 5/27/93 Signed William A. Ireland Commission No. N. Y. STATE COMMISSION NO. 2288
(Authorized Inspector) (N.Y. State Commission No. 2288) ALSO COMMISSIONED IN PENN., OHIO & CONN.
(Nat'l. Bd. (incl. endorsements) state or prov. and no.)



0120 0868

6122 0857

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III, Division 1
Not To Exceed One Day's Production

Pg 1 of 1

- 1. Manufactured and certified by Target Rock Corp., 1966E Broadhollow Rd, E. Farmingdale, NY 11735
(name and address of certificate holder)
- 2. Manufactured for Tennessee Valley Authority, Chattanooga, Tennessee 37401
(name and address of purchaser)
- 3. Location of installation Browns Ferry Nuclear Plant, Athens Alabama 35611
(name and address)
- 4. Type PL-7567F-100-116 Rev- SA-194 GR 7 N/A N/A 1986
(drawing no) (mat'l. spec. no.) (tensile strength) (CRM) (year built)
- 5. ASME Code, Section III: 1968 S 1970 1 N/A
(edition) (edition) (class) (Code Case no)
- 6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision N/A Date N/A
(No.)
- 7. Remarks: Spare Parts for a completed valve assembly
(5/8-11 UNC-2 Hex Nut Drilled, 6 X 10 Safety Relief Valve) QTY 20

- 8. Nom. thickness (in.) N/A Min. design thickness (in.) N/A Dia. ID (ft. & in.) N/A Length overall (ft. & in.) N/A
- 9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
(1) <u>N/A</u>	<u>N/A</u>	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

- 10. Design pressure N/A psi Temp. N/A °F. Hydro. test pressure N/A at temp. °F.
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in Items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(6/85)-1 This form (E00040) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017.



0120 0869

FORM N-2 (back)

Mfr. Serial No. N/A

CERTIFICATE OF DESIGN

Design specifications certified by R. R. Ghosh P. E. state Calif. Reg. no. 16371
(when applicable)
Design report* certified by D. M. Pattarini P. E. state N.Y. Reg. no. 029841
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Part
conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. 1948 Expires 12-9-86

Date 12-9-86 Name Target Rock Corporation Signed R. Quiselen
(NPT Certificate Holder) QA SUPERVISOR
(Authorized Representative)
FOR G. Abruzzo, Q.A. Manager

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of New York and employed by Commercial Union Insurance Co.
of Boston, Mass. have inspected these items described in this data report on 12/9/86 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 12/9/86 Signed William A. Heland **NEW YORK STATE COMMISSION NO. 2**
(Authorized Inspector) COMMISSIONED IN Penn., Ohio & Conn.
(Natl. Bd. (incl. endorsements) state or prov. and no.)



375 0372

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III, Division 1
 Not To Exceed One Day's Production

Page 1 of 1

1. Manufactured and certified by Target Rock Corp., 1966E Broadhollow Rd, E. Farmingdale, NY 11735
(name and address of certificate holder)
2. Manufactured for Tennessee Valley Authority, Chattanooga, TN 37401
(name and address of purchaser)
3. Location of Installation Browns Ferry Nuclear Plant, Athens, Alabama 35611
(name and address)
4. Type See Back See Back See Back N/A 1988
(drawing no.) (mat'l. spec. no.) (design strength) (CRN) (year built)
5. ASME Code, Section III: 1968 Summer 1970 1 N/A
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision N/A Date N/A
(No.)
7. Remarks: Spare Parts for a completed valve assembly, 25 Bolts, Item 107, 688 Nuts, Item 115 for valve style 7567F-000

8. Nom. thickness (in.) N/A Min. design thickness (in.) N/A Dia. ID (ft. & in.) N/A Length overall (ft. & in.) N/A
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
(1) <u>N/A</u>	<u>N/A</u>	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure N/A psi Temp. N/A °F. Hydro. test pressure N/A at temp. °F.
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(6/85)-1

This form (E00040) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017.



.....

..

..



..

FORM N-2 (back)

Mfr. Serial No. N/A

CERTIFICATE OF DESIGN

Design specifications certified by R. R. Ghosh P. E. state Calif. Reg. no. 16371
(when applicable)

Design report certified by D. M. Pattarini P. E. state NY Reg. no. 029841
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Part conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. 1948 Expires 12-9-89

Date 6/7/88 Name Target Rock Corporation Signed William A. O'Reilly
(NPT Certificate Holder) (Authorized representative)
 For G. Abruzzo, Q.A. Manager

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of New York and employed by Commercial Union Insurance Company of Boston, Mass. have inspected these items described in this data report on 6/7/88 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 6/7/88 Signed William A. O'Reilly **NEW YORK STATE COMMISSION NO. 2285**
(Authorized Inspector) Commissioned in Pa., Ohio & Conn.
(Not. Bd. (incl. endorsements) state or prov. and no.)

PL ITEM #	PART NAME	PART NAME	MATERIAL	TENSILE	LOT CODE
107	Bolt	204018-1 Rev. A	SA-193 B7	125,000 MIN	SPS-B7
115	Nut	204041-1 Rev. B	SA-194 GR 7	-	SPS-7

1949
27 2011 1

1 0 10

1949 27 2011 1

1 0 10

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-00
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Stream Relief Valve	Target Rock Corp.	1014	N/A	as located on 2-PCV-1-180	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content and one bolt (part item #112). The MSR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1014. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Millert SYSTEM ENGINEER Date DECEMBER 22, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STEEL, BLR, TNSR + INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-27-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B.J. Rice Commissions NO. 9635, TN. A-N-I
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-01
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 19 68 Edition, * Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge For Main Steam Relief Valve	Target Rock Corp.	1026	N/A	as located on 2-PCV-1-179	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content and one bolt (part item #112). The MSR/V is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure:
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93
 * and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1026. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Gilbert SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STIM. BLD. TNSP. & GAS CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN. A-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-02
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1016	N/A	as located on 2-PCV-1-4	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVS is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1016. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SIM. BLD. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN. A-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-03
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III, 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam	Target Rock Corp.	1021	N/A	as located on 2-PCV-1-5	1978	Replaced	Yes
Relief Valve							

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1021. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STEEL, BLR, INSP & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, IN. F-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-04
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 19 68 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot/Cartridge for Main Steam Relief Valve	Target Rock Corp.	1079	N/A	as located on 2-PCV-1-18	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93
 * and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1033. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STMT. BLR. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] NO. 9635, TN. F-N-T,
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-05
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 19 68 Edition, *Summer 1970 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1022	N/A	as located on 2-PCV-1-19	1978.	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRV is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1022. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip S. Millert SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HARTFORD STIM. BLR. INSP. & INS. CO. of
HARTFORD, CONN. have inspected the components described
in this Owner's Report during the period 6-30-94 to 12-30-94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

B. F. Rice Commissions NO. 9635, IN. F-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date December 22, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-09849-06
Repair Organization P.O. No., Job No., etc.

3. Work Performed by TVA
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System System 1, Main Steam

5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, *Summer 1970 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1076	N/A	as located on 2-PCV-1-22	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVS is as ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi, Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1070. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip J. Milbert SYSTEM ENGINEER Date DECEMBER 22, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STEEL, BLDG. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN, F-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 22, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-07
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 19 68 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam	Target, Rock Corp.	1069	N/A	as located on 2-PCV-1-23	1978	Replaced	Yes
Relief Valve							

7. Description of Work Replace pilot disc (part item #55) with one having 0.3% platinum content. The MSRV is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
Applicable Manufacturer's Data Reports to be attached
S/N 1031. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SIM. BR. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN, F-N-I
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 22, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-08
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address
4. Identification of System Main Steam, System 1
5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1028	N/A	as located on 2-PCV-1-30	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1028. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Bill J. Millett SYSTEM ENGINEER Date DECEMBER 22, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HERFORD SIM. BLD. TANK & TNS. CO. of HERFORD, CONN have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN, A-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date December 22, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-09849-09
Repair Organization P.O. No., Job No., etc.

3. Work Performed by TVA
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System System 1, Main Steam

5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1020	N/A	as located on 2-PCV-1-31	1978	Replaced	Yes

7. Description of Work Replaced pilot disc. (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1020. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SITI, BUR. INSP. & INS. CO. of
HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions ND, 9635, TN, A-N-T,
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 22, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-10
Repair Organization P.O. No., Job No., etc.

3. Work Performed by TVA Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address

4. Identification of System System 1, Main Steam

5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1033	N/A	as located on 2-PCV-1-34	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
S/N 1063. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD, CONN. BLR. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B.F. Rice Commissions NO. 9635, TN. F-N-T.
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 22, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-09849-11 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1015	N/A	as located on 2-PCV-1-41	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93
 * and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
Applicable Manufacturer's Data Reports to be attached
S/N 1015. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed *Philip J. Millert* SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SIM. BR. INSP. & TNS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. F. Rice Commissions NO. 9635, TN. A-N-T
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 22, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09849-12
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Type Code Symbol Stamp N/A
Name Authorization No. N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Expiration Date N/A
Address
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code ASME Sec. III 1968 Edition, Summer 1970 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Cartridge for Main Steam Relief Valve	Target Rock Corp.	1032	N/A	as located on 2-PCV-1-42	1978	Replaced	Yes

7. Description of Work Replaced pilot disc (part item #55) with one having 0.3% platinum content. The MSRVR is an ASME Code Class 1 equivalent component.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* and as amended by additional quality assurance and design requirements contained within General Electric Purchase Order No. 205-AJ600

FORM NIS-2 (Back)

9. Remarks The valve body to which this pilot cartridge was installed on has TVA
Applicable Manufacturer's Data Reports to be attached
S/N 1084. In addition to performing a system leakage test per 2-SI-3.3.1.A,
tests conducted which were performed to meet ASME Sec. XI inservice test
requirements include 0-SI-4.6.D.1, Bench Test Relief Valves, and 2-SI-4.6.D.2,
Main Steam Relief Valves Manual Cycle Test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip S. Gilbert SYSTEM ENGINEER Date DECEMBER 22, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARRIFORD SIM. B.R. INSP. & INS. CO. of HARRIFORD, CONN. have inspected the components described in this Owner's Report during the period 6-30-94 to 12-30-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635, TN. A-N-I
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-30 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 9, 1994
1101 market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-15972-01 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 1, Main Steam
5. (a) Applicable Construction Code USAS B31.1.0 19 67 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Main Steam Line D Outboard Isolation Valve	Atwood and Morrill Co., Inc.	(unable to determine)	N/A	2-FCV-001-0052	N/A	Replaced	No

7. Description of Work Replaced stem assembly and two studs and nuts on 2-FCV-001-0052 (which is an ASME Code Class 1 equivalent component)

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

* as amended by additional quality assurance and design requirements contained within contract 66C31-90744

FORM NIS-2 (Back)

9. Remarks In addition to performing a system leakage test, other tests conducted
Applicable Manufacturer's Data Reports to be attached
which were performed to meet ASME inservice test requirements include 2-SI-
3.2.12, Verification of Fail-Safe Position for MSIVS; 2-SI-4.7.D.1.a-3, Main
Steam Isolation Valves Closure Time Test; and 2-SI-4.7.A.2.i-3/1d2, Primary
Containment Local Leak Rate Test Main Steam Line D Outboard: Penetration X-7D.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip S. Gilbert SYSTEM ENGINEER Date DECEMBER 9, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by Hartford Steam Boiler Insp & Ins. Co of Hartford, Conn have inspected the components described in this Owner's Report during the period 10-18-94 to 11-10-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

George J. Deat Commissions NB 7905 TN 3178
Inspector's Signature National Board, State, Province, and Endorsements

Date 1-6, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date May 3, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 3
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-06277-00
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 63, Standby Liquid Control System
5. (a) Applicable Construction Code USAS B31.1.0 19 67 Edition, * N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-FCV-63-008A Squib Valve	Conax Corp. Explosive Products Div.	24	N/A	Part Number 1832-117-01	1967	Replaced	No

7. Description of Work Replaced trigger assembly to squib valve 2-FCV-63-008A (ASME Code Class 2 equivalent) with like-for-like.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as amended by the additional procurement requirements contained within General Electric Specifications 21A5575 and 21A5576 (reference TVA contract 66C80-90744 and GE Purchase Order 205-58968).

FORM NIS-2 (Back)

9. Remarks Existing 2-FCV-63-008A experienced loss of electrical continuity alarm
Applicable Manufacturer's Data Reports to be attached
(continuity meter pegged high on increasing current), hence only the trigger
assembly was required to be replaced. The new trigger assembly, Conax part No.
N27006-02, was procured under contract P-94N2S-82307E (reference sheets 2 and
3 of this Form NIS-2 for documentation of manufacturer serial numbers and
National Board number as the trigger assembly is an ASME Code stamped part).

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Gilbert, SYSTEM ENGINEER Date JUNE 6, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of NORTH CAROLINA and employed by HSBI & I Co of HARTFORD, CT have inspected the components described in this Owner's Report during the period 6-10-94 to 6-21-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Neil Jackson Commissions NC 869
Inspector's Signature National Board, State, Province, and Endorsements

Date June 21 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS CONTINUATION SHEET

1. Owner TENNESSEE VALLEY AUTHORITY Date May 3, 1994
1101 Market St.; Chattanooga, TN 37402-2801 Sheet 2 of 3
 2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Job No. Work Order 94-06277-00
 3. Work Performed by TVA Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 63, Standby Liquid Control System
5. (a) Applicable Construction Code USAS 831.1.0 1967 Ed., as amended by the additional procurement requirements contained within General Electric Specifications 21A5575 and 21A5576 (reference TVA contract 66C80-90744 and GE Purchase Order 205-58968).
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Ident.	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped
2-FCV-63-008A Squib Valve	Conax Corp. Explosive Products Div.	24	N/A	Part No. 1832-117-01	1967	Replaced	No



2300 WALDEN AVENUE, BUFFALO, NY 14225-0273

Tabulation of Materials

Trigger Assembly
P/N N27006-02



Trigger Body		Primer Chamber	
P/N	N38018-01	P/N:	N38062-01
Vendor:	Vitco Nuclear Prod.	Vendor:	Energy Steel
P.O. No.:	N106414	P.O. No.:	N105706
Heat No.:	12035	Heat No.:	15017
C/N:	16585	C/N:	16394
		SEP S/N:	900
Ram			
P/N	N39012-01		
Vendor:	Carpenter Tech.		
P.O. No.:	N91896		
Heat No.:	53891		
C/N:	16459		

Trigger Subassembly S/N: 4363

Customer: Tennessee Valley Authority
 Project: Browns Ferry Nuclear Plant
 Customer P.O.: P94N2S-82307E-001
 Conax S.O.: 7K3V600

Conax Quality Control: *[Signature]*

Date: 05-03-94



**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

**As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production**

Form NIS-2
Sheet 3 of 3
WO #94-06277-00
Pg. 1 of 1

1. Manufactured and certified by Conax Buffalo Corporation, 2300 Walden Avenue, Cheektowaga, NY 14225
(Name and address of NPT Certificate Holder)
2. Manufactured for Tennessee Valley Authority, Knoxville, TN 37901-8500
(Name and address of Purchaser)
3. Location of installation Browne Ferry Nuclear Plant, Athens, AL 35811
(Name and address)
4. Type: N20000, Rev. F SA479 3046ST 75 K61 N/A 1993
(drawing no.) (mat'l spec. no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III, Division 1: 77 S77 1 N/A
(edition) (addenda date) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision Date
(no.)
7. Remarks: Trigger Body Subassembly for explosive actuated valve replacement kit for standby liquid control system.
Para. NB-2121 (b) is applicable to ram. Press Fit/Seal on .328 & .4375 diameters: Overall subassembly length is 2.5 .
Pneumatic Pressure Test at 2800 psi for 10 minutes.
8. Nom. thickness (in.) See Remarks Min. design thickness (in.) See Remarks Dia. ID (ft & in.) See Remarks Length overall (ft & in.) See Remarks
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(1) 4360	4360
(2) 4361	4361
(3) 4362	4362
(4) 4363	4363
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 1400 psi. Temp. 150 °F. Hydro. test pressure See Remarks at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Certificate Holder's Serial Nos. 4380 through 4383

CERTIFICATION OF DESIGN

Design specifications certified by Clyde T. Nish P.E. State CA Reg. no. 15587
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Trigger Body Subassemblies
 conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 1995

Date 12/3/93 Name Conax Buffalo Corporation Signed *Curt M. Poth*
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of NY
 and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, CT have inspected these items described in this Data Report on 12-6-93, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 12-6-93 Signed *Robert L. Bosman* Commissions NB7784N
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 5, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-00227-00
Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name N/A Type Code Symbol Stamp
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
Name Expiration Date N/A
4. Identification of System System 68, Reactor Water Recirculation
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Jet Pumps Supply Header	Anchor/Darling	(unable to verify)	N/A	2-FCV-68-33	N/A	Replaced	No
Isolation Valve							

Replaced stud and nut in 2-FCV-68-33 with like-for-like items

7. Description of Work (valve is ASME Code Class 1 equivalent)
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This form (E00030) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300. REPRINT 4/93

* as amended by the additional quality assurance and design requirements contained in contract 66C60-90744

FORM NIS-2 (Back)

9. Remarks TVA elected to replace a stud and nut on 2-FCV-68-33 to facilitate completion of field work.

Applicable Manufacturer's Data Reports to be attached

WO 94-00227-00 was written for the purpose of performing a VT-3 visual examination for corrosion of one stud and nut on this valve as a result of finding leakage at the valve's body-to-bonnet flange during the Unit 2, Cycle 6 Reactor Pressure Vessel leakage test. Approval to delay inspection of a stud/nut for one operating cycle and to inspect in accordance with Paragraph IWA-5250 of the 1992 Edition of the ASME Code was granted by the NRC in response to TVA's submittal of System Pressure Test Program Request for Relief No. SPT-7.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip S. Gilbert SYSTEM ENGINEER Date DECEMBER 5, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSBT&I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 7-15-94 to 10-21-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert T. Todd Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date Dec. 6 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 16, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-09648-00 Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System Reactor Water Recirculation, System 68
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Recirc Pipe Weld	TVA	N/A	N/A	GR-2-19	N/A	Repaired	No
Recirc Pipe Weld	TVA	N/A	N/A	GR-2-38	N/A	Repaired	No

7. Description of Work Repaired (by removal) indications in welds GR-2-19 & GR-2-38 by grinding in accordance with MCI-O-000-PRP002. Welds located on ASME Class 1 equivalent piping.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) - This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip A. Millant SYSTEM ENGINEER Date NOVEMBER 16, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by Hartford Steam Boiler Insp. & T.S. Co. of Hartford, Conn. ⁴ have inspected the components described in this Owner's Report during the period 10-18-94 to 11-16-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

George F. Deane Commissions NB 7905 TN 3178
Inspector's Signature National Board, State, Province, and Endorsements

Date 11-16 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date November 15, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-11598-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by General Electric
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System Reactor Water Recirculation System.(68)

5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Recirc Sys. Pipe Weld	TVA	N/A	N/A	GR-2-25	N/A	Repaired	No

7. Description of Work Removed indication in weld GR-2-25 by grinding in accordance with MCI-0-000-PRP002

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

*with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip L. Millett, SYSTEM ENGINEER Date NOVEMBER 15, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by Hartford Steam Bldg. Insp. + Tns. Co of Hartford, Conn have inspected the components described in this Owner's Report during the period 10-14-94 to 11-11-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

George F. Deat _____ Commissions NB 7905 TN3178
Inspector's Signature National Board, State, Province, and Endorsements

Date 11-16 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date November 15, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-11598-02
Repair Organization P.O. No., Job No., etc.

3. Work Performed by General Electric
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System Reactor Water Recirculation, System 68

5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Recirc Sys. Pipe Weld	TVA	N/A	N/A	GR-2-52	N/A	Repaired	No
 							
 							
 							

7. Description of Work Removed two indications in weld GR-2-52 by grinding in accordance with MCI-0-000-PRP-2. Weld located on ASME Class 1 equivalent piping.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82)

This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

*with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip L. Millett SYSTEM ENGINEER Date NOVEMBER 15, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSBT & I of HARTFORD, CT. have inspected the components described in this Owner's Report during the period 10/18/94 to 11/14/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Ladd _____ Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date Nov. 16 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 3
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-13986-00 Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
The James Building Name
735 Broad Street Suite 804; Chattanooga, TN 37402 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 68, Reactor Water Recirculation (Reactor Pressure Vessel)
5. (a) Applicable Construction Code ASME Sec. III 19 65 Edition, * Summer 1965 Addenda, 1332-1, 1332-3, 1334
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86 Code Case 1335-2, 1336

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Instrument Dry Tube	GE Reuter-Stokes	L3244	N/A	Core Location 40-21	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3242	N/A	Core Location 48-53	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3254	N/A	Core Location 24-29	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3241	N/A	Core Location 48-13	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3253	N/A	Core Location 16-45	N/A	Replacement	No

7. Description of Work Replacement of Instrument Dry Tubes
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* and as amended by additional quality assurance and design requirements contained in contract 21042-GE-00016Q

FORM NIS-2 (Back)

9. Remarks Dry Tube replacement due to IVVI Inspection revealing unacceptable
indications. A system leakage test of the Reactor Pressure Vessel and associated
pipng was performed per Surveillance instruction 2-SI-3.3.1.A of which the
aforementioned Instrument Dry Tubes being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed John L. Gilbert SYSTEM ENGINEER Date DECEMBER 2, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HISBZFI of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/16/94 to 10/24/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Ladd Commissions NB6908 TN 3/35
Inspector's Signature National Board, State, Province, and Endorsements

Date Dec. 6 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS CONTINUATION SHEET

- | | |
|---|---|
| <p>1. Owner <u>TENNESSEE VALLEY AUTHORITY</u>
 <u>1101 Market St.; Chattanooga, TN 37402-2801</u></p> <p>2. Plant <u>Browns Ferry Nuclear Plant</u>
 <u>P.O. Box 2000; Decatur, AL 35609-2000</u></p> <p>3. Work Performed by <u>General Electric</u>
 <u>The James Building</u>
 <u>734 Broad St. Suite 804; Chattanooga, TN 37402</u></p> <p>4. Identification of System <u>System 68, Reactor Water Recirculation (Reactor Pressure Vessel)</u></p> <p>5. (a) Applicable Construction Code <u>ASME Section III, 1965 Edition w/ Summer 1965 Addenda, 1332-1, 1332-3, 1334, 1335-2, & 1336 Code Cases, and as amended by additional quality assurance and design requirements contained in contract 21042-GE-00016Q</u></p> <p>(b) Applicable Edition of Section XI Utilized for Repairs or Replacements <u>1986</u></p> <p>6. Identification of Components Repaired or Replaced and Replacement Components</p> | <p>Date <u>November 21, 1994</u></p> <p>Sheet <u>2</u> of <u>3</u></p> <p>Unit <u>2</u></p> <p>Job No. <u>Work Order 94-13986-00</u></p> <p>Type Code Symbol Stamp <u>N/A</u></p> <p>Authorization No. <u>N/A</u></p> <p>Expiration Date <u>N/A</u></p> |
|---|---|

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped
Instrument Dry Tube	GE Reuter-Stokes	L3247	N/A	Core Location 32-29	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3250	N/A	Core Location 40-45	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3248	N/A	Core Location 24-37	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3243	N/A	Core Location 32-37	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3245	N/A	Core Location 16-21	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3251	N/A	Core Location 16-13	N/A	Replacement	No
Instrument Dry Tube	GE Reuter-Stokes	L3252	N/A	Core Location 16-53	N/A	Replacement	No



... ..

...

FORM N-2 MANUFACTURERS DATA REPORT FOR NUCLEAR PART AND APPURTENANCES

As required by the Provisions of the ASME Code Rules

1. (a) Manufactured by GE REUTER-STOKES, INC., 8499 DARROW ROAD, TWINSBURG, OHIO 44087
(Name and address of Manufacturer of part)
- (b) Manufactured for BROWNS FERRY, TVA, DECATUR, ALABAMA
(Name and address of Manufacturer of completed nuclear component)
2. Identification-Manufacturer's Serial No. of Part L3241 THRU L3254 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. RS-E5-1500-201 Drawing Prepared by GE REUTER-STOKES
- (b) Description of Part Inspected UNIVERSAL DRY TUBE
- (c) Applicable ASME Code: Section III, Edition 1977, Addenda date SUMMER 1977, Case No. N/A Class 1
3. Remarks: DESIGN: PRESSURE 1250 PSIG, TEMPERATURE - VESSEL 575°F, FLANGE 300°F
(Brief description of service for which component was designed)
- HYDROSTATIC TEST PRESSURE: 1925 PSIG

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the part Manufacturer. An appurtenance manufacturer is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included component Design Specification and Stress Report.)

Date 9-24 1992 Signed GE REUTER-STOKES By James V. Holmes
(Manufacturer) QUALITY ASSURANCE

Certificate of Authorization Expires SEPTEMBER 16, 1994 Certificate of Authorization No. N-2703

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at GE REUTER-STOKES TWINSBURG, OHIO CDS-C-5600-1

Stress analysis report on file at GE REUTER-STOKES TWINSBURG, OHIO CDR-C-5600-01

Design specifications certified by DOUGLAS E. BACSO Prof. Eng. State OH Reg. No. E-044071

Stress analysis report certified by SURINDER L. KAMPANI Prof. Eng. State OH Reg. No. E-034113

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of OHIO and employed by H.S.B.I. & I. Co. of HARTFORD, CT

have inspected the part of a pressure vessel described in this Manufacturer's Partial Data Report on 9-25 1992, and state that to the best of my knowledge and belief, the Manufacturer has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 9-25 1992

Paul C. Schell Inspector's Signature
Commissions NB 7920-OHIO-PAWC2454-N
National Board, State, Province and No.



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 23, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-15880-00 Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
James Bldg. #804 Name
735 Broad St.; Chattanooga, TN 37402 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 68, Reactor Water Recirculation (Reactor Vessel)
5. (a) Applicable Construction Code ASME III, CL 1 1974 Edition, Winter 75 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
In-Core Flange @ location 08-25	General Electric	N3230-2-1	ASME Cert. of Auth.	GE Part No. 107C5053G001	N/A	Replaced	No
			N-1888	HT #7638N			
In-Core Flange cap screws @ location 08-25	General Electric	N/A	ASME Cert. of Auth.	GE Part No. 117C4515P001	N/A	Replacement	No
			N-1888	HT #M51481			

7. Description of Work Replaced in-core flange and cap screws at location 08-25 with new components.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Since the replacement activity involved only the disassembly and
reassembly of a mechanical joint, a system pressure test of IWA-5211(a)
(system leakage test) was performed per Surveillance Instruction 2-SI-3.3.1.A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Millett, SYSTEM ENGINEER Date NOVEMBER 23, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARFORD SITH. BLR. INSP. & INS. CO. of HARFORD, CONN. have inspected the components described in this Owner's Report during the period 10-16-94 to 11-29-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions 9635, TN, 2430, A-N-T.
Inspector's Signature National Board, State, Province, and Endorsements

Date 11-29 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 21, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Workplan 21635-001
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
640 Freedom Bus. Ctr. Name Authorization No. N/A
King of Prussia, PA 19406 Address Expiration Date N/A
4. Identification of System System 68, Reactor Water Recirculation
5. (a) Applicable Construction Code USAS B31.1.0 19 67 Edition, * N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Recirc Pipe Weld	N/A	N/A	N/A	Pipe Weld GR-2-64 (OL)	N/A	Repaired	No
/							

7. Description of Work Applied a full structural weld overlay to repair Recirc pipe weld GR-2-64 (Code Class 1 equivalent) per Design Change Notice (DCN) W21635A.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks TVA elected to invoke ASME Code Case N-504-1 as an acceptable alternative
in repairing Recirc weld GR-2-64 by application of a full structural weld
overlay. This alternative was subsequently approved by the NRC as an acceptable
means of repair. Since the pressure boundary was not penetrated while applying
the overlay, the Code Case requirement of performing a pressure test in
accordance with IWA-5000 was met by performing a system leakage test per
Surveillance Instruction 2-SI-3.3.1.A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Phillip L. Gilbert SYSTEM ENGINEER Date NOVEMBER 24, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD STEEL BLDG. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-17-94 to 11-6-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions 9635, TN, 2430, A-N-T.
Inspector's Signature National Board, State, Province, and Endorsements

Date 11-29 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 12, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-01951-00
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 71, Reactor Core Isolation Cooling
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RCIC Steam Supply Line	Bergen-Paterson	G56410-4R (TVA Serial No: M0346)	N/A	2-SNUB-071-5010	N/A	Replaced	No
Snubber	Pipesupport Corp.						

7. Description of Work Replaced cylinder on snubber 2-SNUB-071-5010 with like-for-like item (snubber is an ASME Code Class 2 equivalent component)
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks None

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert SYSTEM ENGINEER Date DECEMBER 13, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SIM. BLR. INSP. & INS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 10-7-94 to 12-29-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

B. J. Rice Commissions NO. 9635 TN. A-N-T.
Inspector's Signature National Board, State, Province, and Endorsements

Date 12-29 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date December 4, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 93-02108-00
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Name Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 74, Residual Heat Removal
5. (a) Applicable Construction Code USAS B31.1.0 19 67 Edition, * N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RHR Sys II Discharge Cross-tie Valve to U-3	William Powell	(unable to verify)	N/A	2-FCV-74-101	N/A	Replaced	No

7. Description of Work Replaced valve's gate (wedge) with like-for-like item (valve is ASME Code Class 2 equivalent)

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as amended by additional quality assurance and design requirements contained within contract 68C37-91062

FORM NIS-2 (Back)

9. Remarks Although wedge was originally procured QA Level 0 per contract 75P52-49395, the wedge was upgraded to QA Level 2 per PEG Evaluation 9300009438A0 and contract P-93NJV-81108E.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] SYSTEM ENGINEER Date DECEMBER 5, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSB I & T of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/6/94 to 10/23/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NA6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date Dec. 6 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 15, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-09648-01
Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System Residual Heat Removal, System 74
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, * N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RHR Pipe Weld	TVA	N/A	N/A	DRHR-2-07	N/A	Repaired	No
 							

- Repaired (by removal) indication in weld DRHR-2-07 by grinding in accordance with
7. Description of Work MCI-0-000-PRP002. Weld located on ASME Class 1 equivalent piping.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A

Signed Philip J. Gilbert, SYSTEM ENGINEER Date NOVEMBER 15, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSBZET of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/19/94 to 11/14/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Zell Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV 17 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801 Address

Date November 15, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant Name
P.O. Box 2000; Decatur, AL 35609-2000 Address

Unit 2

Work Order 94-11598-03
Repair Organization P.O. No., Job No., etc.

3. Work Performed by General Electric Name
P.O. Box 2000; Decatur, AL 35609-2000 Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System Residual Heat Removal, System 74

5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RHR Pipe Weld	TVA	N/A	N/A	DRHR-2-04	N/A	Repaired	No
Removed indication in weld DRHR-2-04 by grinding/buffing in accordance with							

7. Description of Work MCI-0-000-FRP002. Weld located on ASME Class 1 equivalent piping.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A Expiration Date _____ N/A

Signed Philip J. Gilbert, SYSTEM ENGINEER Date NOVEMBER 15, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSBT & T of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/19/94 to 11/14/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Todd _____ Commissions NB 6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 16 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 16, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-09980-00 Repair Organization P.O. No., Job No., etc.
3. Work Performed by General Electric Type Code Symbol Stamp N/A
P.O. Box 2000; Decatur, AL 35609-2000 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System Core Spray, System 75
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CS Pipe Weld	TVA	N/A	N/A	DCS-2-05	N/A	Repaired	No
CS Pipe Weld	TVA	N/A	N/A	DCS-2-14	N/A	Repaired	No

7. Description of Work Repaired (by removal) indications in welds DCS-2-05 & DCS-2-14 by grinding in accordance with MCI-0-000-FRPO02. Welds located on ASME Class 1 equivalent piping.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* with supplemental requirements

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip L. Milbost SYSTEM ENGINEER Date NOVEMBER 16, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by Hartford STEAM Bldg. Insp. & Ins. Co. of Hartford, Conn have inspected the components described in this Owner's Report during the period 10-14-94 to 11-16-94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

George F. Deat _____ Commissions NB 7905 TN 3178
Inspector's Signature National Board, State, Province, and Endorsements

Date 11-16 1994

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
Name
1101 Market St.
Address
Chattanooga, TN 37402-2801 Sheet 1 of 4
2. Plant Browns Ferry nuclear Plant Unit 2
Name
P.O. Box 2000; Decatur, AL 35609-2000 Work Order 94-10308-00
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Name Authorization No. N/A
Shelter Rock Road; Danbury, CT 06810 Expiration Date N/A
Address
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 02-39	General Electric	A5381	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 02-39	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HSB I & T of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Todd Commissions NA6908 TV3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV 23 19 94

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5381 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92Signed GE-NEBG-NF & CM-OA
(NPT Certificate Holder)By [Signature]
(SCQA Representative)Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPT N-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, CaliforniaStress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1

Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1

Stress analysis report certified by Edward Yoshlo Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 6/26, 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/29, 1992
Date[Signature]
Inspector's SignatureNC 1231, Ohio, WC 3686 PA
National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)



100-100000-1

FORM N-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets, vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 Incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____


18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE N F & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/M of Part : A5381 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model #7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.





210

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-01
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 06-19	General Electric	A4442	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 06-19	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HF # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
Applicable Manufacturer's Data Reports to be attached
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip J. Gilbert SYSTEM ENGINEER Date NOVEMBER 20, 1994
Owner or Owner's Designee, Title
Rest 11/20/94

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HSAI & P of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert T. Ladd _____ Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23, 1994

5022.5190

SHEET 2 of 4
Form NIS-2 ATTACHMENT
WO # 94-10308-01

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4442 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D.L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 09/10/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (QC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 8/25, 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/10, 1992 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)

FORM N-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ (Material, Spec. No., T.S. Size Number) Other fastening _____ (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

Page 10 of 10


6022-5192

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GENFCM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4442 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev. 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4518P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-02
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Name Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 10-23	General Electric	A5486	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 10-23	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed W.D. Hillert SYSTEM ENGINEER Date NOVEMBER 19, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HSB I & T of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury, or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Tadd Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 19 94

6022.4289

FORM NIS-2 ATTACHMENT
SHEET 2 OF 4
WO # 94-10308-02

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5486 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D.L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 9/14/92 Signed GE - NEBG - NF & CM - QA By [Signature]
(NPT Certificate Holder) (SC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 9/2, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/14/92 Jerome P. Evans NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 3. "REMARKS".

(87/90)



Page 10 of 10

FORM N-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) _____	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ Inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 Incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) Top, bottom, ends	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - # Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.



Page 10 of 10

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I


Form NTS-2 Attachment
SHEET 4 OF 4

WO #94-10308-02

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing - (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina-28401
(Name and Address of NPT Certificate Holder.)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component.)
2. Identification - Certificate Holder's S/M of Part : A5486 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev. 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi min.
(Brief description of service for which component was designed.)

Sheet 2 of 2

1. Cap 16639274P001
SA162 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 16639313P001
SA312 - TP316
3/4" o.d. 40 - annealed pipe
0.113" wall thickness
1.053" max. dia.
3. Plug 163A1170P001
SA162 - F304
1/4" thick x 0.812" OD
4. Flange 918D010P001 (718E474)
SA162 - F304
3.37" thick x 9 5/8" OD
5. Cap 137C3311P001
SA162 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B3122P002, P003
137C8151P001, P002
SA162 - F304
1" thick x 8.0" OD x 1.75" ID
7. Cap Screw 117C4510P002
SA163 - C3
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 173A7631P001
SA162 - F304
0.37" thick x 1.307" dia.
9. Nut 137C3334P001
304 - 19 SA479
1.30" thick x 2.62" dia.



100-1000

100-1000



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-03
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 10-31	General Electric	A3831	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 10-31	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HF # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] SYSTEM ENGINEER Date NOVEMBER 19, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSBI & I of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

[Signature] Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 1994

6022-5300

FORM NIS-2 ATTACHMENT
SHEET 2 OF 4
WO # 94-10308-03

FORM NIS-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
 (Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
 (Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A3831 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev. 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psi. min.
 (Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 09/10/92 Signed GE-NEBG-NF & CM-OA By [Signature]
 (NPT Certificate Holder) (SC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 9/10, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/10, 1992 [Signature] NG 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/88)

5300

Items 4-8 Incl. to be completed for single wall vessels, jackets (vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as edge and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ¹ _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

ESTD 1959


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
 As required by the Provision of the ASME Code Rules, Section III, Div. 1

WD # 94-1038-03

1. Manufactured & Certified by: General Electric Company Nuclear Fuel & Components Manufacturing (GE N F & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
 (Name and Address of NPT Certificate Holder)
- (b) Manufactured for: TVA Chattanooga, Tennessee 37402-2127
 (Name and Address of Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part: A3831 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev. B Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psl. min.
 (Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B0274P001
SA102 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.005" max. dia.
3. Plug 158A1176P001
SA102 - F304
1/4" thick x 0.812" OD
4. Flange 916D810P001 (716E474)
SA102 - F304
3.37" thick x 8 5/8" OD
5. Base 137C9311P001
SA102 - F304
7/8" thick x 2.075" dia.
6. Ring Flange 114D3122P002, P003
137C0151P001, P002
SA102 - F304
1" thick x 6.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - E8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 178A7631P001
SA102 - F304
0.33" thick x 1.307" dia.
9. Nut 137C9334P001
XM - 19 SA479
1.30" thick x 2.62" dia.



10/10/2000

23

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-04
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19_86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 10-35	General Electric	A4255	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 10-35	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HF # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Millett SYSTEM ENGINEER Date NOVEMBER 19, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSB&I of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert J. Ladd Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date Nov. 23 19 94

5022.5168

SHEET 2 OF 4
Form NIS-2 ATTACHMENT
WO # 94-10308-04

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4255 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 09/10/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (QC Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 9/10, 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/10, 1992 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 3. "REMARKS".

(07/90)



Page 11 of 11

FORM N-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. if bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - if Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

6022 5170


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. 1

WD # 94-10308-04

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Folder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4255 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B6
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7981P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



1 2 3 4



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-05 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 14-39	General Electric	A5434	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 14-39	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip L. Hill SYSTEM ENGINEER Date NOVEMBER 19, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSBI&I of
HAATFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Hill Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 19 94

6022-4311

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GENF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
 (Name and Address of NPT Certificate Holder)
2. Manufactured for : TVA Chattanooga, Tennessee 37402-2127
 (Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5434 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
 (Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 9/14/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (QC QA Representative)

Certificate of Authorization Expires: 8/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/8, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/14/92 J. P. Eason NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)



10

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)

(a) _____
(b) _____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F
Drop Weight _____ Charpy Impact _____ ft-lb

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 Incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)

(a) Top, bottom, ends _____
(b) Channel _____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F
Drop Weight _____ Charpy Impact _____ ft-lb

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.

11-11-61



Page 11

FORM N-2 NPT CERTIFICATE HOLDER'S DATA SHEET FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. 1

WO # 94-10308-05

- 1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
- 2. Identification - Certificate Holder's S/N of Part : A5434 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 788E534G008 Rev 9 Dwg. Prepared by D.L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
- 3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD

2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.

3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD

4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD


5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.

6. Ring Flange 114D5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID

7. Cap Screw 117C4516P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle

8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.

9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.





1950

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date November 19, 1994

Sheet 1 of 4

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-10308-06
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Nuclear Energy Services
Name
Shelter Rock Road; Danbury, CT 06810
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System System 85, Control Rod Drive

5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 14-55	General Electric	A5608	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 14-55	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Gilbert SYSTEM ENGINEER Date NOVEMBER 19, 19 94
Owner or Owner's Designee, Title REX 11/19/94

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSB I & I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 7/6/94 to 11/23/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Ladd Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV 23, 19 94

5022.3215

FORM NIS-2 ATTACHMENT
SHEET 2 OF 4
WO # 94-10308-06

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
- Identification - Certificate Holder's S/N of Part : A5608 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92 Signed GE-NEBG-NF & CM-QA By [Signature]
(NPT Certificate Holder) (SC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/27, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/27, 1992 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)

10 0301

FORM H-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ Inches or gage. Number _____ Type _____
(St. or U)

Items 11 - 14 Incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.

2 - Use other internal or external pressure with coincident temperature when applicable.

11



11


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

WD # 94-10308-06

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5608 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008-Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psl. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 139A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D810P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



11 12 13 14



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-07
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 18-11	General Electric	A3543	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD Location 18-11	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date NOVEMBER 19, 1994
Owner or Owner's Designer, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HSBIEI of
HAATFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11-23-94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Todd Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 1994

5022.3193.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A3543 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psl. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (GC OA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPT N-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California
 Stress analysis report on file at GE Company, San Jose, California
 DC22A6253 Rev. 1
 Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570
 DC22A6254 Rev 1
 Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. MQ18646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina, and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/14, 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/29, 1992 Date [Signature] Inspector's Signature NC 1231, Ohio, WC 3686 PA National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(87/90)



1950-1951

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ (Material, Spec. No., T.S. Size Number) Other fastening _____ (Describe or attach sketch)

7. Jacket Closure: _____ (Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____ (Welded, Bolted)
(Kind & Spec. No.) (Subject to pressure)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____ (Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.



6022 3195


FORM N-2 ATTACHMENTS
SHEET 4 OF 4
WO # 94-10308-07

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A3543 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev. 9 Dwg. Prepared by D.L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B6
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7981P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 19, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
 Name
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-08 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
 Name
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 18-19	General Electric	A4130	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 18-19	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting

7. Description of Work material on Control Rod Drive Mechanism flange.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed per
Applicable Manufacturer's Data Reports to be attached
Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the inspection
boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Millert, SYSTEM ENGINEER Date NOVEMBER 19, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSBI&I of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Todd Commissions NA6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV 23 19 94

6022.4772

SHEET 2 of 4
FORM NIS-2 ATTACHMENT
WO# 94-10308-08

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured / Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4130 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 9/14/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (NSC QA Representative)

Certificate of Authorization Expires: 8/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 9/8, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/14/92 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(87/96)

1950
1951

6022.4773

FORM NIS-2 ATTACHMENT
SHEET 3 of 4
WO # 94-10308-08

FORM N-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Bx, or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

1952

FORM N-2 NPT CERTIFICATE HOLDERS DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

SHEET 4 OF 4
FORM NIS-2 ATTACHMENT

WO # 94-10308-08

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)

2117 Castle Hayne Road, Wilmington, North Carolina 28401

(Name and Address of NPT Certificate Holder)

(b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127

(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification - Certificate Holder's S/M of Part : A4130 Nat'l Bd. No. N/A

(a) Constructed According to Drawing No: 768E534G008 Rev. 9 Dwg. Prepared by D. L. Peterson

(b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1

3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi/min.

(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD

2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" ech 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.

3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD

4. Flange 919D810P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD


5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.

6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID

7. Cap Screw 117C4516P002
SA193 - E8
6 ea. 1/2" dia. on 4 1/8" bolt circle

8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.

9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



1130 P 13TH

1000 1000 1000
1000 1000 1000



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-09
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 18-35	General Electric	A5436	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 18-35	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Millett, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN. and employed by HSBZ ET of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Todd Commissions MB6908 TN 3135
Inspector's Signature NB6908 TN 3135
National Board, State, Province, and Endorsements

Date NOV. 23 19 94

6022 .4257

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5436 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 9/14/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (SC OR Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570


DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/2, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/14/92 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".



FORM N-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Code & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
 Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a)	_____	_____	_____	_____	_____	_____	_____	_____
(b)	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as edge and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

Drop Weight _____
 Charpy Impact _____ ft-lb

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Code & Spec. No.) (Subject to pressure) (Welded, Bolted)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10 Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Code & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
 Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) Top, bottom, ends	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

Drop Weight _____
 Charpy Impact _____ ft-lb

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____


Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17 Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.

2 - List other internal or external pressure with coincident temperature when applicable.




FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
 As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
 (Name and Address of NPT Certificate Holder)
 - (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
 (Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5436 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
 (Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
 SA182 - F304
 3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
 SA312 - TP316
 3/4" sch 40 - seamless pipe
 0.113" wall thickness
 1.065" max. dia.
3. Plug 159A1176P001
 SA182 - F304
 1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
 SA182 - F304
 3.37" thick x 9 5/8" OD
5. Base 137C5311P00
 SA182 - F304
 7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
 137C8151P001, P002
 SA182 - F304
 1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
 SA193 - B8
 6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7061P001
 SA182 - F304
 0.38" thick x 1.307" dia.
9. Nut 137C5934P001
 XM - 19 SA479
 1.30" thick x 2.62" dia.



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date November 20, 1994

Sheet 1 of 4

2. Plant Browns Ferry Nuclear Plant
Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-10308-10
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Nuclear Energy Services
Name
Shelter Rock Road; Danbury, CT 06810
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System System 85, Control Rod Drive

5. (a) Applicable Construction Code (see Remarks) 19 _____ Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 18-59	General Electric	A4494	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 18-59	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replace Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Hillbert SYSTEM ENGINEER Date NOVEMBER 20, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSBT & I of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert T. Hill Commissions NA6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 19 94

5022.2819

SHEET 2 of 4
FORM NIS-2 ATTACHMENT
WO # 94-10308-10

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)

(b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification - Certificate Holder's S/N of Part : A4494 Nat'l Bd. No. N/A

(a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson

(b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1

3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (SC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Bjorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/29/92, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/29/1992 Date [Signature] Inspector's Signature NC 1231, Ohio, WC 3686 PA
National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)

100-100000-100000

100-100000-100000

FORM N-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____ ft-lb
Charpy Impact _____ ° F

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F
Drop Weight _____ ft-lb
Charpy Impact _____

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.

100




FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

WO # 94-10308-10

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4494 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psl. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B6
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XA, - 19 SA479
1.30" thick x 2.62" dia.



1900

1901

1902



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-11 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 22-19	General Electric	A5463	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 22-19	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replace Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1: Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Millett, SYSTEM ENGINEER Date NOVEMBER 20, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by H502 & I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 7/6/94 to 11/23/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert T. Todd Commissions NR6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 1994

FORM NIS-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
- Identification - Certificate Holder's S/N of Part : A5463 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92

Signed GE-NEBG-NF & CM-OA
(NPT Certificate Holder)

By [Signature]
(SC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

QC22A6253 Rev. 1
Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

QC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 6/26, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/27, 1992 [Signature]
Date Inspector's Signature

NC 1231, Ohio, WC 3686 PA
National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(67/88)

Handwritten text, possibly a date or reference number, located in the upper left corner.

FORM N-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
Drop Weight _____ ft-lb
Charpy Impact _____

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) Top, bottom, ends _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F
Drop Weight _____ ft-lb
Charpy Impact _____

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - Use other internal or external pressure with coincident temperature when applicable.

1957
1958

1956 TO 1957

6022-2843


FORM N-2 ATTACHMENT
SHEET 4 OF 4
WO # 94-10308-11

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GENF&CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5463 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



1930-1931

1932-1933

1934-1935

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-12
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19.86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 38-23	General Electric	A4280	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 38-23	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert SYSTEM ENGINEER Date NOVEMBER 20, 1994
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of TENN and employed by HSBT EI of
HARTFORD, CT have inspected the components described
in this Owner's Report during the period 7/6/94 to 11/23/94, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

Albert Todd Commissions NR6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 19 94

5022 5146

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufacturer & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road - Wilmington - North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4280 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 0 Dwg. Prepared by D.L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Data W75, Case No. N207 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date: 09/10/92 Signed GE-NEBG-NF & CM-OA By [Signature]
(NPT Certificate Holder) (SC OR Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPT N-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blom Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshlo Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina, and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel, described in this Partial Data Report on 8/24, 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

9/10, 1992 James P. Evers NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)

1950
1951

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) _____	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

Drop Weight _____ ft-lb
Charpy Impact _____

8. Design pressure ² _____ 1250 _____ psi at _____ 575 _____ ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 Incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) Top, bottom, ends	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

Drop Weight _____ ft-lb
Charpy Impact _____

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.

Handwritten text at the top left, possibly a date or reference number.



6022-5148


FORM NIS-2 ATTACHMENT
SHEET 4 OF 4
WO #94-10308-12

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder, for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A4280 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Codes: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psl. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B6
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



THE UNIVERSITY OF CHICAGO
LIBRARY
540 EAST 57TH STREET
CHICAGO, ILL. 60637



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 4
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-13 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code (see Remarks) 19 Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive @ location 38-31	General Electric	A5342	N/A	P/N 768E534G008	1992	Replacement	Yes
Bolting (8 ea) for CRD location 38-31	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced Code Class 1 equivalent Control Rod Drive Mechanism and bolting material on Control Rod Drive Mechanism flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated piping was performed
per Surveillance Instruction 2-SI-3.3.1.A of which the aforementioned CRDM being within the
inspection boundary.
Applicable Constr. Code - CRDM: ASME Sec. III Class 1, 1974 Edition w/ W'75 Addenda, Code Case No.
N207 1361-2 Class 1; Bolting Material: USAS B31.1.0 1967 Edition as augmented by General Electric
Installation Specification 22A2125.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip J. Gilbert SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSB I & D of HARTFORD, CT have inspected the components described in this Owner's Report during the period 7/6/94 to 11/23/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Todd _____ Commissions NB 6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 23 19 94

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

WO # 94-10308-13

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5342 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9 Dwg. Prepared by D. L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive, Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 07/29/92 Signed GE - NEBG - NF & CM - QA By [Signature]
(NPT Certificate Holder) (QC QA Representative)

Certificate of Authorization Expires: 6/16/93 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 1
Design specification certified by Blorn Haaberg Prof. Eng. State Calif. Reg. No. 15570

DC22A6254 Rev 1
Stress analysis report certified by Edward Yoshio Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 7/13, 1992 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

7/27, 1992 [Signature] NC 1231, Ohio, WC 3686 PA
Date Inspector's Signature National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

(07/90)

100-100-100

100-100-100

FORM N-2 (back)

Items 4-8 Incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T. ¹ _____ R.T. _____ Efficiency _____ %
 Girth _____ H.T. ¹ _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
 Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
 (a) _____
 (b) _____
 If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as open and weld, bar, etc. if bar give dimensions, if bolts, describe or sketch)
 Drop Weight _____ ft-lb
 Charpy Impact _____ ° F

8. Design pressure ² _____ 1250 psi at _____ 575 ° F at temp of _____ ° F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)
 Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____
(Str. or U)

Items 11 - 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T. ¹ _____ R.T. _____ Efficiency _____ %
 Girth _____ H.T. ¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
 Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
 (a) Top, bottom, ends _____
 (b) Channel _____
 If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
 Drop Weight _____ ft-lb
 Charpy Impact _____ ° F

14. Design pressure ² _____ psi at _____ ° F at temp of _____ ° F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles: Purpose (Inlet, Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material How Attached

17. Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

1 - If Postweld Heat-Treated.
2 - List other internal or external pressure with coincident temperature when applicable.

100-100000

100-100000


6022-3239

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. Manufactured & Certified by : General Electric Company Nuclear Fuel & Components Manufacturing (GE NF & CM)
2117 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : TVA Chattanooga, Tennessee 37402-2127
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A5342 Nat'l Bd. No. N/A
 - (a) Constructed According to Drawing No: 768E534G008 Rev 9, Dwg. Prepared by D.L. Peterson
 - (b) Description of Part Inspected: Control Rod Drive Model # 7RDB144FG005
 - (c) Applicable ASME Code: Section III, Edition: 1974, Addenda Date W75, Case No. N207 1361-2, Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi, min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 166B9274P001
SA182 - F304
3/8" thick x 1 1/16" OD
2. Indicator Tube 166B9313P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 159A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D610P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Base 137C5311P001
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002, P003
137C8151P001, P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B8
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 137C5934P001
XM - 19 SA479
1.30" thick x 2.62" dia.



RECEIVED
FEB 19 1964

1964 FEB 19

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-16
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Bolting (8 ea) for CRD location 42-47	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced bolting material on Code Class 1 equivalent Control Rod Drive Mechanism 42-47 flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as augmented by General Electric Installation Specification 22A2125

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip J. Hillert, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSBI&I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/5/94 to 11/22/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Teal Commissions NB6908 TU 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 22 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address Work Order 94-10308-17
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address Authorization No. N/A
Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Bolting (8 ea) for CRD location 06-27	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced bolting material on Code Class 1 equivalent Control Rod Drive Mechanism 06-27 flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82)

This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as augmented by General Electric Installation Specification 22A2125

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by HSB I ET of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/5/94 to 11/22/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Todd Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 22 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-18 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code USAS B31.1.0 19 67 Edition, * N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Bolting (8 ea) for CRD location 18-39	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced bolting material on Code Class 1 equivalent Control Rod Drive Mechanism 18-39 flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82)

This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as augmented by General Electric Installation Specification 22A2125

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Millett SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSBT & I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/5/94 to 11/22/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Ladd Commissions NB 6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 22 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date November 20, 1994
1101 Market St. Name
Chattanooga, TN 37402-2801 Address
 Sheet 1 of 1
2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609-2000 Address
Work Order 94-10308-19 Repair Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Energy Services Type Code Symbol Stamp N/A
Shelter Rock Road; Danbury, CT 06810 Address
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System System 85, Control Rod Drive
5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1986

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Bolting (8 ea) for CRD location 26-59	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

Replaced bolting material on Code Class 1 equivalent Control Rod

7. Description of Work Drive Mechanism 26-59 flange.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as augmented by General Electric Installation Specification 22A2125

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Philip L. Milbort, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HSBTE & T of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/5/94 to 11/22/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Ladd _____ Commissions NB6908 TN 3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV. 22 19 94

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
1101 Market St. Name
Chattanooga, TN 37402-2801
Address

Date November 20, 1994

Sheet 1 of 1

2. Plant Browns Ferry Nuclear Plant Name
P.O. Box 2000; Decatur, AL 35609-2000
Address

Unit 2

Work Order 94-10308-20
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Nuclear Energy Services Name
Shelter Rock Road; Danbury, CT 06810
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System System 85, Control Rod Drive

5. (a) Applicable Construction Code USAS B31.1.0 1967 Edition, * N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19_86

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Bolting (8 ea) for CRD location 34-59	Vitco Nuclear Products, Inc	N/A	N/A	P/N 137C9293P001 HT # 61811	N/A	Replaced	No

7. Description of Work Replaced bolting material on Code Class 1 equivalent Control Rod Drive Mechanism 34-59 flange.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82) This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

* as augmented by General Electric Installation Specification 22A2125

FORM NIS-2 (Back)

9. Remarks A system leakage test of the Reactor Pressure Vessel and associated
Applicable Manufacturer's Data Reports to be attached
pipng was performed per Surveillance Instruction 2-SI-3.3.1.A of which the
aforementioned CRDM being within the inspection boundary.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Philip L. Gilbert, SYSTEM ENGINEER Date NOVEMBER 20, 19 94
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN and employed by H5871T of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10/5/94 to 11/22/94, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Albert Todd Commissions NB6908 TN3135
Inspector's Signature National Board, State, Province, and Endorsements

Date NOV 22 19 94

ENCLOSURE 3

**BROWNS FERRY
NUCLEAR PLANT**

UNIT 2 CYCLE 7

ASME SECTION XI

PRESERVICE INSPECTION REPORT

Owner: TENNESSEE VALLEY AUTHORITY Nuclear Power Group 1101 Market Street Chattanooga, TN 37402-2801	Plant: Browns Ferry Nuclear Plant P.O. Box 2000 Decatur, AL 35609-2000
Unit: Two	Certificate of Authorization: Not Required
Commercial Service Date: March 1, 1975	
National Board Number For Unit: Not Required	

The following printout is an Outage Preservice Inspection (PSI) report designed to meet the reporting requirements of IWA-6000 of the ASME Section XI Code. This report contains PSI data for Class 1 and Class 2 components. A legend is given in Appendix 5 of the NIS-1 Report which will describe the abbreviations and features found in the PSI report. No augmented or voluntary examinations are contained in this report.

Class 3 PSI reports are contained in the Browns Ferry Preservice Inspection Plant Report.



Owner: TENNESSEE VALLEY AUTHORITY Plant: Browns Ferry Nuclear Plant
 Nuclear Power Group P.O. Box 2000
 1101 Market Street Decatur, AL 35609-2000
 Chattanooga, TN 37402-2801

Unit: Two Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
N NUTECH TENNESSEE VALLEY AUTHORITY PRISIM
N BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
N ISI DATA BASE
N POST OUTAGE EXAMINATION RESULTS REPORT
N EXAM REQUIREMENT : R25-02 CYCLE : 07
N INTERVAL : 02 PERIOD : 1
*****
SYSTEM : HSS MAIN STEAM SYSTEM - 001
ISONETRIC NUMBER : HSC-0021-C SHEET : 01
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
DHS-2-15	PIPE -ELOW	C-F-2 CS.51	R00000455			HT	19941022	PASS	YES			

```

*****
N NUTECH TENNESSEE VALLEY AUTHORITY PRISIM
N BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
N ISI DATA BASE
N POST OUTAGE EXAMINATION RESULTS REPORT
N EXAM REQUIREMENT : R17-02 CYCLE : 07
N INTERVAL : 02 PERIOD : 1
*****
SYSTEM : HSS MAIN STEAM SYSTEM - 001
ISONETRIC NUMBER : ISI-0412-C SHEET : 02
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
47B2401-03	MSNUB-2	F-A FL.30C	R00000451			VT-3	19941114	PASS	YES			
47B2401-51	MSNUB-2	F-A FL.30C	R00000304			VT-3	19941019	PASS	YES			



TO TURBINE STOP VALVES EL. 615'

FOR HEADER WELDS SEE HEADER DETAIL

REFERENCE DRAWINGS
 47W335-1
 47W400 SERIES
 47W801 SERIES
 GE 945D695 (CONT. 3-91062)
 DRAVO E-2478 IC-1
 DRAVO 550037-1
 ISI-0079-C (SH. 1) SUPPORT MAP

MATERIAL SPECIFICATIONS:
 A155KC70
 25.25" O.D. X 1.625" NOM WALL. CS
 A-106-B
 24" X 1.219" NOM. WALL THK. SCH. 80
 24" X 2.5" NOM. WALL THK. CS
 18" X 0.938" NOM WALL THK. SCH. 80
 A-234 WPB
 26" X 1.219" NOM. WALL THK. SCH. 80
 ASME CC-2 (EQUIVALENT)

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402


PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

ENGINEER SERVICE DATE: MARCH 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

MATCH LINE E
 SHEET 2
 (6" SWEEPolet)
 DMS-2-29

Page 3 of 28



HEADER DETAIL

4	PHD	WJS	WJS	WJS	3/13/92
REDRWN, ADD HEADER DETAIL, REVISED LONGHAND, WELD SPECS					
2	PHD	JJA	JES	GLB	4-26-91
DEL. CADBLK., ADD MATERIAL SPEC., ADD M.D.S. 6, 12, 18, 25, 44, 45, 46					
2	PHD	JES	EDC	GLB	6-5-89
REVISED MATCH LINES & REFERENCE BLOCK					
1	RPO	JES	EDC	GLB	2-2-87
REDRWN & REVISED FOR PRISM					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
HARDWARE: IBM 5045		SOFTWARE: CADAM		USER: ISTOP	
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2 MAIN STEAM SYSTEM WELD LOCATIONS					
DRWN. KEY	SUBMITTED	APPROVED	SCALE	MIS	
DATE: 6-30-81	DATE:	DATE:	SHEET	01 OF 02 SHEETS	
CHECKED: JFL			REV		
DATE:			GLB	MSG-0021-C04	



OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975

NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED
 (A) 79°



REFERENCE DRAWINGS
 47W401 SERIES

LEGEND

✱ VARIABLE SUPPORT
 ● MECHANICAL SNUBBER

ASME CC-3 (EQUIVALENT)

Page 4 of 28



REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2					
MAIN STEAM RELIEF VALVE SYSTEM VENT PIPING SUPPORT LOCATIONS					
DRAWN: PFB	DATE: 7/1/92	SCALE: NTS	CADW/ISTOP		
CHECKED: GFB	APPROVED: [Signature]	SHEET 02 OF 09		REV	
SUBMITTED: [Signature]		ISI-0412-C00			



Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975


National Board Number For Unit: Not Required

```

*****
NUTECH                               TENNESSEE VALLEY AUTHORITY                               PRISM
BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
      ISI DATA BASE
POST OUTAGE EXAMINATION RESULTS REPORT
EXAM REQUIREMENT : R20-02    CYCLE : 07
INTERVAL : 02    PERIOD : 1
*****
SYSTEM      : HSS  MAIN STEAM SYSTEM - 001
ISOHETRIC NUMBER : ISI-0222-C SHEET : 01
*****
FEATURE NUMBER  COMPONENT  CATGORY/  EXAMINATION  CAL.  CAL.  EXAM  EXAM  EXAM  SEC XI  RELIEF  INDICATION  INDICATION
DESCRPT.       ITEM NO.  REPORT NO. REPORT NO. STD.  TYPE  DATE  RESULT CREDIT REQST.  TYPE      RESOLUTION
-----
FCV-01-052    VAL INT   B-H-2    R00000338          VT-1  19941022 PASS  YES
      B12.50
*****
  
```

```

*****
NUTECH                               TENNESSEE VALLEY AUTHORITY                               PRISM
BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
      ISI DATA BASE
POST OUTAGE EXAMINATION RESULTS REPORT
EXAM REQUIREMENT : R19-02    CYCLE : 07
INTERVAL : 02    PERIOD : 1
*****
SYSTEM      : HSS  MAIN STEAM SYSTEM - 001
ISOHETRIC NUMBER : ISI-0222-C SHEET : 01
*****
FEATURE NUMBER  COMPONENT  CATGORY/  EXAMINATION  CAL.  CAL.  EXAM  EXAM  EXAM  SEC XI  RELIEF  INDICATION  INDICATION
DESCRPT.       ITEM NO.  REPORT NO. REPORT NO. STD.  TYPE  DATE  RESULT CREDIT REQST.  TYPE      RESOLUTION
-----
FCV-01-052-BC VALBLTG  B-G-2    R00000432          VT-1  19941022 PASS  YES
      B7.70
*****
  
```



REFERENCE DRAWINGS:

- 47K1767
- 47K335-1
- KELLOGG 729E229
- CHM-2087-C (SH. 1) SUPPORT MAP
- NOTE: THIS DRAWING SUPERCEDES CHM-2069-C (SH. 1)

PIPE DATA

ASME CC-1 (EQUIVALENT)
 ASTM A-155 KC 70
 26" X 0.950 NOM. WALL THK. (CS)
 6" X 0.719 NOM. WALL THK. (SCH. 160 CS)

NOTES:

ALL FIELD WELDS WERE MADE BY TVA

NOTE:



1. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-1D (DOWNSTREAM)
- (BASE WELD NO.)-LS-2D (DOWNSTREAM)
- (BASE WELD NO.)-LS-1U (UPSTREAM)
- (BASE WELD NO.)-LS-2U (UPSTREAM)

THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHERMOST FROM 0° ON THE PIPE. (e.g., -LS-1 AT 130°, AND -LS-2 AT 310°)

2. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-D (DOWNSTREAM)
- (BASE WELD NO.)-LS-U (UPSTREAM)



CD/ISSUED IN 28-311 ASD 12-11-78 ISSUED TO CREATE CDD, SUPERSEDES AND IS-0222-C-1 (S) ADDED DETAIL'S A,B (IST REVISION)			
TENNESSEE VALLEY AUTHORITY			
S BROWNS FERRY NUCLEAR PLANT UNIT 2 MAIN STEAM SYSTEM WELD LOCATIONS			
DATE: 01-02-79	DESIGNED BY: EDC	CHECKED BY: GLB	SCALE: 2-IST-022-C
DATE: 01-02-79	ISSUED BY: EDC	DATE: 01-02-79	SCALE: 2-IST-022-C

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1701 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P. O. BOX 2000
 DECATUR, ALABAMA 35602
 UNIT: TWO
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR DWT: NOT REQUIRED
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED



Owner: TENNESSEE VALLEY AUTHORITY Plant: Browns Ferry Nuclear Plant
 Nuclear Power Group P.O. Box 2000
 1101 Market Street Decatur, AL 35609-2000
 Chattanooga, TN 37402-2801

Unit: Two Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
M NUTECH TENNESSEE VALLEY AUTHORITY PRISM M
M BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2. M
M ISI DATA BASE M
M POST OUTAGE EXAMINATION RESULTS REPORT M
M EXAM REQUIREMENT : R23-02 CYCLE : 07 M
M INTERVAL : 02 PERIOD : 1 M
M PAGE 2 M
M REVISION 0002 M
M DATE 01/12/95 M
*****
M SYSTEM : RECIR REACTOR WATER RECIRCULATING SYSTEM - 068 M
M ISOMETRIC NUMBER : ISI-0270-C SHEET : 01 M
M
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
GR-2-19	SWPOLET -PIPE	B-J B9.11	R00000294			PT	19941018	PASS	YES			
GR-2-25	PIPE -VALVE	B-J B9.11	R00000324			PT	19941018	PASS	YES			

```

*****
M NUTECH TENNESSEE VALLEY AUTHORITY PRISM M
M BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2 M
M ISI DATA BASE M
M POST OUTAGE EXAMINATION RESULTS REPORT M
M EXAM REQUIREMENT : R23-02 CYCLE : 07 M
M INTERVAL : 02 PERIOD : 1 M
M PAGE 3 M
M REVISION 0002 M
M DATE 01/12/95 M
*****
M SYSTEM : RECIR REACTOR WATER RECIRCULATING SYSTEM - 068 M
M ISOMETRIC NUMBER : ISI-0270-C SHEET : 02 M
M
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
GR-2-38	SWPOLET -PIPE	B-J B9.11	R00000353			PT	19941020	PASS	YES			
GR-2-52	VALVE -PIPE	B-J B9.11	R00000456			PT	19941020	PASS	YES			
GR-2-64(OL)	OVERLAY	B-J B9.11	R00000433			PT	19941028	PASS	YES			
			R00000434	C00000317	BF-83	UT-0	19941028	PASS	YES			
			R00000434	C00000328	BF-83	UT-0L	19941030	PASS	YES			
			R00000434	C00000318	BF-83	UT-60L	19941025	PASS	YES			SUBSURF, ROU EVALUATED,OK
			R00000434	C00000327	BF-83	UT-60L	19941030	PASS	YES			SUBSURF, ROU EVALUATED,OK
			R00000434	C00000319	BF-83	UT-70L	19941026	PASS	YES			SUBSURF, ROU EVALUATED,OK




UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975

NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

A - LOOP




REFERENCE DRAWING

47W2408-8.9 (S.E. h.)
 GE 769E963 (S.E. REPL.)
 TVA 47K1544-2
 GE 153F754
 KELLOGG BF 2-180
 NOTE: THIS DRAWING SUPERSEDES
 CHN-2068-C ALL SHEETS

MATERIAL SPECIFICATIONS:

A358, TP 304
 4" X 0.337" NOM WALL THK. (SS)
 12" X 0.569" NOM. WALL THK. (SS)
 22" X 1.030" NOM. WALL THK. (SS)
 28" X 1.138" NOM. WALL THK. (SS) SUCTION
 28" X 1.322" NOM. WALL THK. (SS) DISCHARGE
 2" SCH. 80 A-376, TP304
 2" FITTINGS A-182, F304
 SAFE END REPLACEMENT
 12" X 0.688 NOM. WALL THK. (SS)
 SA 403 MP 316 N.G.


ASME CC-1 (EQUIVALENT)



RISER DETAIL

- NOTES:
1. WELDS 2RX1 ARE THE NOZZLE TO SAFE-END WELDS
 2. ALL 2" WELDS ARE SOCKET WELDED EXCEPT WHERE NOTED.
 3. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:
 (BASE WELD NO.)-LS-ID (DOWNSTREAM)
 (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 (BASE WELD NO.)-LS-1U (UPSTREAM)
 (BASE WELD NO.)-LS-2U (UPSTREAM)
 THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHERMOST FROM 0° ON THE PIPE. (i.e. -LS-1 AT 130°, AND -LS-2 AT 310°)
 4. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS
 (BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)


Page 8 of 28



04	PH	6-1-92	DEL ONE BC NOTE FROM VALVE IDENTIFIER ADD 4" NOTES	DP	1	1	1
03	PH	3-13-92	ADD LONGSEAM IDENTIFIER NOTES	RPC	JES	GLB	
02	PH	9-20-91	DEL CADRAW, ADD 2" LINE, MTL. SPEC.	JAA	JES	GLB	
01	PH	3-28-89	REDRAW INTO TWO SHEETS	JES	EDC	GLB	
REV	BY	DATE	DESCRIPTION	EX'D	SLB	APP	
HARDWARE, IBM SOBS				SOFTWARE, CADAM	USER, ISTCHP		
TENNESSEE VALLEY AUTHORITY							
BROWNS FERRY NUCLEAR PLANT							
UNIT 2							
RECIRCULATION SYSTEM							
WELD LOCATIONS							
DRAWN: PH	DATE: 5-10-87	SCALE: NTS	DATE: 4-14-88	DATE: 4-14-88	SHEET: 1 OF 2 SHEETS		
CHECKED: JES	DATE: 4-14-88	EDC	GLB	REV	DRAWING NO.		
DATE: 4-14-88					ISI-0270-C 04		



2025



REFERENCE DRAW.

47W2408-8,9 (S.E. 2NT)
 GE 769E963 (S.E. REPLACEMENT)
 TVA 47K1544-2
 GE 153F754
 KELLOGG BF 2-180
 NOTE: THIS DRAWING SUPERSEDES
 CHM-2068-C ALL SHEETS

MATERIAL SPECIFICATIONS:

A358, TP 304
 4" X 0.377" NOM WALL THK. (SS)
 12" X 0.569" NOM WALL THK. (SS)
 22" X 1.030" NOM WALL THK. (SS)
 28" X 1.138" NOM WALL THK. (SS) SUCTION
 28" X 1.322" NOM WALL THK. (SS) DISCHARGE
 2" SCH. 80, A376, TP304
 2" FITTINGS A182,F304
 SAFE END REPLACEMENT
 12" X 0.688 NOM. WALL THK. (SS)
 SA 403 WP 316 N.G.
 ASME CC-1 (EQUIVALENT)

NOTES:

- ALL 2" WELDS ARE SOCKET WELDED EXCEPT WHERE NOTED.
- PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:
 (BASE WELD NO.)-LS-ID (DOWNSTREAM)
 (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 (BASE WELD NO.)-LS-1U (UPSTREAM)
 (BASE WELD NO.)-LS-2U (UPSTREAM)
 THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHEST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)
- PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS
 (BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)

OWNER: TENNESSEE VALLEY AUTHORITY NUCLEAR POWER GROUP
 1101 MARKET STREET CHATTANOOGA, TENNESSEE 37402
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000 DECATUR, ALABAMA 35602

UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

REV	BY	DATE	DESCRIPTION	CHK'D	APP'D
04	PHB	1-1-77	ADD 4" LINE SIZES		
03	PHB	3-13-92	ADD LONGSEAM IDENTIFIER NOTES MODIFY LONGSEAM WELD ID'S		
02	PHB	9-20-91	DEL EXCER, ADD 2" LINE, MATL. SPEC.	JAA	JES GLB
01	PHB	11-9-89	CORRECT VALVE NO. FCV-68-79	JES	EDC GLB
HARDWARE: IBM 5083 SOFTWARE: CADAM USER: ISTCHP					
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT					
UNIT 2					
RECIRCULATION SYSTEM					
WELD LOCATIONS					
DRAWN: PHB	DESIGNED: JES	APPROVED: JES	SCALE: NTS		
DATE: 3-28-89	DATE: 3-28-89	DATE: 12-11-89	SHEET 2 OF 2 SHEET(S)		
GRAND: JES	EDC	GLB	DRAWING NO.		
DATE: 3-3-89			IST-0270-C(04)		

K = KELLOGG SHOP WELD
 G = GE FIELD WELD
 SYSTEM UNIT NO. WELD NO.
 UNIT NO. SYSTEM RISER LETTER WELD NO.



Owner: TENNESSEE VALLEY AUTHORITY Plant: Browns Ferry Nuclear Plant
 Nuclear Power Group P.O. Box 2000
 1101 Market Street Decatur, AL 35609-2000
 Chattanooga, TN 37402-2801

Unit: Two Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
NUTECH                                      TENNESSEE VALLEY AUTHORITY                      PRISIH
                                             BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
                                             ISI DATA BASE
                                             POST OUTAGE EXAMINATION RESULTS REPORT
                                             EXAH REQUIREMENT : R19-02    CYCLE : 07
                                             INTERVAL : 02            PERIOD : 1
                                             *****
                                             * PAGE                    3
                                             * REVISION            0002
                                             * DATE                 01/12/95
                                             *****
SYSTEM                                      : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
ISOHERMIC NUMBER                        : ISI-0292-C SHEET : 01
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAH TYPE	EXAH DATE	EXAH RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
CRDN-2-0239-BC	BOLTS	B-G-2 B7.80	R00000253			VT-1	19941012	PASS	YES			
CRDN-2-0619-BC	BOLTS	B-G-2 B7.80	R00000252			VT-1	19941012	PASS	YES			
CRDN-2-0627-BC	BOLTS	B-G-2 B7.80	R00000257			VT-1	19941012	PASS	YES			
CRDN-2-1023-BC	BOLTS	B-G-2 B7.80	R00000251			VT-1	19941012	PASS	YES			
CRDN-2-1031-BC	BOLTS	B-G-2 B7.80	R00000262			VT-1	19941012	PASS	YES			
CRDN-2-1035-BC	BOLTS	B-G-2 B7.80	R00000256			VT-1	19941012	PASS	YES			
CRDN-2-1439-BC	BOLTS	B-G-2 B7.80	R00000261			VT-1	19941012	PASS	YES			
CRDN-2-1455-BC	BOLTS	B-G-2 B7.80	R00000267			VT-1	19941012	PASS	YES			
CRDN-2-1811-BC	BOLTS	B-G-2 B7.80	R00000266			VT-1	19941012	PASS	YES			
CRDN-2-1819-BC	BOLTS	B-G-2 B7.80	R00000265			VT-1	19941012	PASS	YES			
CRDN-2-1835-BC	BOLTS	B-G-2 B7.80	R00000260			VT-1	19941012	PASS	YES			

```

*****
NUTECH                                      TENNESSEE VALLEY AUTHORITY                      PRISIH
                                             BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
                                             ISI DATA BASE
                                             POST OUTAGE EXAMINATION RESULTS REPORT
                                             EXAH REQUIREMENT : R19-02    CYCLE : 07
                                             INTERVAL : 02            PERIOD : 1
                                             *****
                                             * PAGE                    2
                                             * REVISION            0002
                                             * DATE                 01/12/95
                                             *****
SYSTEM                                      : RECIR REACTOR WATER RECIRCULATING SYSTEM - 068
ISOHERMIC NUMBER                        : ISI-0270-C SHEET : 02
*****

```


FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAH TYPE	EXAH DATE	EXAH RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
FCV-68-33-BC	VALBLTG	B-G-2 B7.70	R00000365			VT-1	19941021	PASS	YES			

Z

ASSUMED NORTH LOOKING
DOWN ON VESSEL


EXAMPLES OF TVA NUMBERS

WELD NO. CRDW-2-1011
NOZZLE NO. CRDN-2-0615



NOTES:

1. THIS DRAWING SUPERSEDES CHM-2002-C (UNIT 2)
2. NOZZLES ARE SPECIFIED BY CRDN-2-#Z#W#.
3. WELDS ARE SPECIFIED BY CRDW-2-#Z#W#.



CRD HOUSING DETAIL


OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602
 UNIT: TWO
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

X	V	U	S	R	P	N	L	K	H	G	E	D	B	A	B & W NUMBER
58	54	50	46	42	38	34	30	26	22	18	14	10	06	02	TVA NUMBER

W

2	PHS	3/10/92	ADD SHEET 2, REVISE TITLE, MODIFY GUIDE LINES, ADD HOUSING DETAIL	AD	LES	MLB
1	PHS	9-20-91	REDRAW ADD NOTES, CORRECT NORTH	JAA	LES	DLB
REV BY	DATE	DESCRIPTION	CHK'D	SUB	APP	
HARDWARE	IBM 5045	SOFTWARE	CADAM	USER	ISTDP	
TENNESSEE VALLEY AUTHORITY						
BROWNS FERRY NUCLEAR PLANT						
UNIT 2						
REACTOR VESSEL PENETRATIONS CONTROL ROD DRIVE						
DRAWN: PHS	DESIGNED	APPROVED	SCALE NTS	SHEET 01 OF 02	DATE	REV
DATE: 2-13-89	DATE: 3-5-89	DATE: 3-17-89				
CHECKED: LES	EDC	DLB	DRAWING NO.	REV		
DATE: 5-2-89			IG-0292-C102			





REFERENCE DRAW.
 47N2408-8,9 (S.E. ENT)
 GE 769E963 (S.E. REPLACEMENT)
 TVA 47K1544-2
 GE 153F754
 KELLOGG BF 2-180
 NOTE: THIS DRAWING SUPERSEDES
 CHM-2068-C ALL SHEETS

MATERIAL SPECIFICATIONS:
 A358, TP 304
 4" X 0.337" NOM WALL THK. (SS)
 12" X 0.569" NOM. WALL THK. (SS)
 22" X 1.030" NOM. WALL THK. (SS)
 28" X 1.138" NOM. WALL THK. (SS) SUCTION
 28" X 1.322" NOM. WALL THK. (SS) DISCHARGE

2" SCH. 80, A376, TP304
 2" FITTINGS A182, F304

SAFE END REPLACEMENT
 12" X 0.688 NOM. WALL THK. (SS)
 SA 403 WP 316 N.G.

ASME CC-1 (EQUIVALENT)

- NOTES:**
- ALL 2" WELDS ARE SOCKET WELDED EXCEPT WHERE NOTED.
 - PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:
 (BASE WELD NO.)-LS-1D (DOWNSTREAM)
 (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 (BASE WELD NO.)-LS-1U (UPSTREAM)
 (BASE WELD NO.)-LS-2U (UPSTREAM)
 THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHEST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)
 - PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS
 (BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

REV	BY	DATE	DESCRIPTION	CHK'D	APP'D
04	PHB	1-1-91	ADD 4" LINE SIZES		
03	PHB	3-13-92	ADD LONGSEAM IDENTIFIER NOTES MODIFY LONGSEAM WELD ID'S	PHB	JES CLB
02	PHB	9-20-91	DEL CADBLK, ADD 2" LINE, MATL. SPEC.	JAA	JES CLB
01	PHB	11-9-89	CORRECT VALVE NO. FCV-68-79	JES	EDC CLB
HARDWARE: IBM 3043 SOFTWARE: CADAM USER: ISTOP					
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2 RECIRCULATION SYSTEM WELD LOCATIONS					
DRAWN: PHB	SUBMITTED	APPROVED	SCALE NTE		
DATE: 3-28-89	DATE: 3-8-89	DATE: 3-17-89	SHEET 2 OF 2 SHEET(S)		
CHECKED: JES	EDC	GLB	DRAWING NO.		
DATE: 3-3-89			TSI-0270-C 04		

K = KELLOGG SHOP WELD
 G = GE FIELD WELD

WELD NO. UNIT NO. SYSTEM

2RXN WELD NO. UNIT NO. SYSTEM

2RXN RISER LETTER



1951

Owner: TENNESSEE VALLEY AUTHORITY Plant: Browns Ferry Nuclear Plant
 Nuclear Power Group P.O. Box 2000
 1101 Market Street Decatur, AL 35609-2000
 Chattanooga, TN 37402-2801

Unit: Two Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
* NUTECH                               TENNESSEE VALLEY AUTHORITY                               PRISM
*                                     BROHNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
* POST OUTAGE EXAMINATION RESULTS REPORT
* EXAM REQUIREMENT : R01-02 CYCLE : 07
* INTERVAL : 02 PERIOD : 1
*                                     *****
*                                     * PAGE 2
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : RECIR REACTOR WATER RECIRCULATING SYSTEM - 068
* ISOHETRIC NUMBER : ISI-0278-C SHEET : 01
*
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-47B408S0056	CFORCE2	F-A F1.40C	R00000167			VT-3	19941006	PASS	YES			
2-47B408S0066	C FORCE	F-A F1.40C	R00000448			VT-3	19941104	PASS	YES			


```

*****
* NUTECH                               TENNESSEE VALLEY AUTHORITY                               PRISM
*                                     BROHNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
* POST OUTAGE EXAMINATION RESULTS REPORT
* EXAM REQUIREMENT : R19-02 CYCLE : 07
* INTERVAL : 02 PERIOD : 1
*                                     *****
*                                     * PAGE 4
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
* ISOHETRIC NUMBER : ISI-0292-C SHEET : 01
*
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
CRDN-2-1839-BC	BOLTS	B-G-2 B7.80	R00000250			VT-1	19941012	PASS	YES			
CRDN-2-1859-BC	BOLTS	B-G-2 B7.80	R00000259			VT-1	19941012	PASS	YES			
CRDN-2-2219-BC	BOLTS	B-G-2 B7.80	R00000264			VT-1	19941012	PASS	YES			
CRDN-2-2659-BC	BOLTS	B-G-2 B7.80	R00000255			VT-1	19941012	PASS	YES			
CRDN-2-3459-BC	BOLTS	B-G-2 B7.30	R00000249			VT-1	19941012	PASS	YES			
CRDN-2-3823-BC	CH BLTG	B-G-2 B7.80	R00000258			VT-1	19941012	PASS	YES			
CRDN-2-3831-BC	BOLTS	B-G-2 B7.80	R00000263			VT-1	19941012	PASS	YES			
CRDN-2-4247-BC	BOLTS	B-G-2 B7.80	R00000254			VT-1	19941012	PASS	YES			
FLUXMON-2-23-BC	BOLTS	B-G-2 B7.10	R00000311			VT-1	19941019	PASS	YES			

A - LOOP



REFERENCE DRAWINGS:
 2-47W2408-8.9 (S.E. REPI INT)
 GE 769E963 (S.E. REPLAC
 TVA 47K1544-2
 2-153F754
 KELLOGG BF 2-180
 NOTE: THIS DRAWING SUPERSEDES
 CHM-2068-C ALL SHEETS

LEGEND:
 ● RIGID HANGER
 ✕ VARIABLE SUPPORT
 ○ HYDRAULIC SNUBBER
 ✕ CONSTANT FORCE SUPPORT (CF)


CALCULATION BRANCH/PROJECT IDENTIFIER:
 CD-02068-871118

ASME CC-1 (EQUIVALENT)

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED



CONTROLLED

CD/ISS	11-10-94	MPT	JIC	IVA	WSP	GAA	RE	MC	WELL
ISSUED TO CREATE CD, SUPERSEDES AND ISI-0278-C, TAMS REVISED SUPPORT MAPS AND ADDS CALCULATION HISTORY, 1121 REVISION									
REV	CHANGE NO	DATE	BY	CHK	DRGN	INVR	APPD	APPD	ISSD
1									
TENNESSEE VALLEY AUTHORITY									
BROWNS FERRY NUCLEAR PLANT UNIT 2 RECIRCULATION SYSTEM SUPPORT LOCATIONS									
DRAWN	FWB	SUBMITTED	APPROVED	SCALE	N/A				
DATE	2-22-87	DATE	2-18-84	DATE	2-11-84	SHEET 1 OF 2 SHEET(S)			
DESIGNED BY	EDC	DRAWING NO.	GLB	DATE	2-11-84	CD			
DATE	6-10-88								




ASME CC-1 (EOL .ENT)

ASSUMED NORTH LOOKING
DOWN ON VESSEL


EXAMPLES OF TVA NUMBERS

WELD NO. CRDW-2-1011
NOZZLE NO. CRDN-2-0615



NOTES:

1. THIS DRAWING SUPERSEDES CHM-2002-C (UNIT 2)
2. NOZZLES ARE SPECIFIED BY CRDN-2-"Z"-"W".
3. WELDS ARE SPECIFIED BY CRDW-2-"Z"-"W".



Z

OWNER: TENNESSEE VALLEY AUTHORITY
NUCLEAR POWER GROUP
1101 MARKET STREET
CHAFFALOCCA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
P.O. BOX 2000
DECATUR, ALABAMA 35602

UNIT: TWO
COMMERCIAL SERVICE DATE: MARCH 1, 1975
NATIONAL BOARD NUMBER FOR UNIT: NOT DESIGNATED
CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

X	V	U	S	R	P	N	L	K	H	G	E	D	B	A	B & W NUMBER
58	54	50	46	42	38	34	30	26	22	18	14	10	06	02	TVA NUMBER

2	PRE	3/10/92	ADD SHEET 2, REVISE TITLE, MODIFY GUIDE LINES, ADD HOUSING DETAIL	APR 1992
1	PHO	9-20-91	RETRAV ADD NOTES, CORRECT NORTH	JAN 1992
REV BY	DATE	DESCRIPTION	CHK'D	SLD APP
HARDWARE: IBM 5045	SOFTWARE: CADAM	USER: ISTOMP		
TENNESSEE VALLEY AUTHORITY				
BROWNS FERRY NUCLEAR PLANT				
UNIT 2				
(REACTOR VESSEL PENETRATIONS CONTROL ROD DRIVE)				
DRAWN: JES	DATE: 2-13-92	SCALE: NTS	SHEET: 01 OF 02	DATE: 3-17-92
CHECKED: JES	DATE: 5-2-92	APPROVED: JES	DRAWING NO: ICS-0292-C02	REV: 1



Owner: TENNESSEE VALLEY AUTHORITY Plant: Browns Ferry Nuclear Plant
 Nuclear Power Group P.O. Box 2000
 1101 Market Street Decatur, AL 35609-2000
 Chattanooga, TN 37402-2801

Unit: Two Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
* NUTECH TENNESSEE VALLEY AUTHORITY PRISIH *
* BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2 *
* ISI DATA BASE *
* POST OUTAGE EXAMINATION RESULTS REPORT *
* EXAM REQUIREMENT : R02-02 CYCLE : 07 *
* INTERVAL : 02 PERIOD : 1 *
*****
* SYSTEM : RECIR REACTOR WATER RECIRCULATING SYSTEM - 068 *
* ISOMETRIC NUMBER : ISI-0278-C SHEET : 02 *
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-47B408S0051	C FORCE	F-A F1.40C	R00000447			VT-3	19941104	PASS		YES		

```

*****
* NUTECH TENNESSEE VALLEY AUTHORITY PRISIH *
* BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2 *
* ISI DATA BASE *
* POST OUTAGE EXAMINATION RESULTS REPORT *
* EXAM REQUIREMENT : R06-02 CYCLE : 07 *
* INTERVAL : 02 PERIOD : 1 *
*****
* SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068 *
* ISOMETRIC NUMBER : ISI-0292-C SHEET : 01 *
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
CRDN-2-0619-BC	BOLTS	B-G-2 B7.80	R00000383			HT	19941026	PASS		YES		
CRDN-2-0627-BC	BOLTS	B-G-2 B7.80	R00000430			HT	19941026	ENGR		YES	SURF, LINEAR	ANALYZED, OK
CRDN-2-1835-BC	BOLTS	B-G-2 B7.80	R00000384			HT	19941026	ENGR		YES	SURF, LINEAR	ANALYZED, OK
CRDN-2-1839-BC	BOLTS	B-G-2 B7.80	R00000386			HT	19941026	ENGR		YES	SURF, LINEAR	ANALYZED, OK
CRDN-2-2219-BC	BOLTS	B-G-2 B7.80	R00000385			HT	19941026	ENGR		YES	SURF, LINEAR	ANALYZED, OK



RECIRCULATION BRANCH/PROJECT
IDENTIFIER: CD-02068-871118


REFERENCE DRAWINGS:

TVA 47K1544-2
GE 153F754
KELLOGG BF 2-180
NOTE: THIS DRAWING SUPERSEDES -
CHN-2068-C ALL SHEETS

LEGEND:

- RIGID HANGER
- ⊗ VARIABLE SUPPORT
- HYDRAULIC SNUBBER
- ⊗ CONSTANT FORCE SUPPORT (CF)
- RIGID STRUT
- ASME CC-1 (EQUIVALENT)

B - LOOP



CONTROLLED

OWNER: TENNESSEE VALLEY AUTHORITY
NUCLEAR ENERGY RESEARCH GROUP
1101 MARSH STREET
CHATTAHOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
P.O. BOX 2000
DECATUR, ALABAMA 35602

UNIT: TWO
CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975
NATIONAL STAND NUMBER FOR UNIT: NOT REQUIRED


TVA 47K1544-2									
ISSUED TO CREATE CCD SUPPORTS AND ISI-0276-C-3 NOS. REVISED DRAWING TO REFLECT REVIEW OF PIPE STRESS CALC FOR INTERFACES									
REV	CHANGE NO	DATE	BY	CHK	DESN	INVR	APPD	APPR	ISSD
TENNESSEE VALLEY AUTHORITY									
BROWNS FERRY NUCLEAR PLANT UNIT 2 RECIRCULATION SYSTEM SUPPORT LOCATIONS									
DRWN	ENG	SUBMITTED	APPROVED	SCALE: NIS					
DATE: 3-28-75	DATE: 2-10-75	DATE: 11-18-74	DATE: 11-18-74	SHEET 2 OF 2 SHEETS					
REQD BY: EDC	DATE: 3-2-75	EDC	GLB	DRAWING NO. 2-151-0276-C1000					
CCD									



ASSUMED NORTH LOOKING
DOWN ON VESSEL


EXAMPLES OF TVA NUMBERS

WELD NO. CRDW-2- $\frac{Z}{V}$ 1011
NOZZLE NO. CRDN-2- $\frac{Z}{V}$ 0615



NOTES:

1. THIS DRAWING SUPERSEDES CHM-2002-C (UNIT 2)
2. NOZZLES ARE SPECIFIED BY CRDN-2-"Z"/"V".
3. WELDS ARE SPECIFIED BY CRDW-2-"Z"/"V".



OWNER: TENNESSEE VALLEY AUTHORITY
NUCLEAR POWER GROUP
1101 MARKET STREET
CHAHTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
P.O. BOX 2000
DECATUR, ALABAMA 35602

UNIT: TWO
COMMERCIAL SERVICE DATE: MARCH 1, 1975
CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

2	PK	3/11/92	ADD SHEET 2, REVISE TITLE, MODIFY GUIDE LINES, ADD HOUSING DETAIL	AS	CS	WB
1	PK	9-20-91	REDRAW ADD NOTES, CORRECT NORTH	JA	LES	CLB
REV	BY	DATE	DESCRIPTION	CHK'D	APP	
HARDWARE: IBM 5043		SOFTWARE: CADAM		USER: ISTOP		
TENNESSEE VALLEY AUTHORITY						
BROWNS FERRY NUCLEAR PLANT UNIT 2 REACTOR VESSEL PENETRATIONS CONTROL ROD DRIVE						
DRAWN	PK	DATE	2-13-87	SCALE	MIS	
CHECKED	AS	DATE	3-9-89	SHEET	01 OF 02	
DATE	3-6-89	LOC	02	DRAWING NO.	TVA-0292-C-02	



Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIM
                                      BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
                                      ISI DATA BASE
                                      POST OUTAGE EXAMINATION RESULTS REPORT
                                      EXAM REQUIREMENT : R15-02   CYCLE : 07
                                      INTERVAL : 02   PERIOD : 1
*****
SYSTEM : RWCUS REACTOR WATER CLEANUP SYSTEM - 069
ISOMETRIC NUMBER : ISI-0274-C SHEET : 01
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-47B406S0012	RIG HGR	F-A Fl.10B	R00000213			VT-3	19941013	PASS	YES		
2-47B406S0018	VSPRING	F-A Fl.10C	R00000218			VT-3	19941012	PASS	YES		

```

*****
NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIM
                                      BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
                                      ISI DATA BASE
                                      POST OUTAGE EXAMINATION RESULTS REPORT
                                      EXAM REQUIREMENT : R23-02   CYCLE : 07
                                      INTERVAL : 02   PERIOD : 1
*****
SYSTEM : RWCUS REACTOR WATER CLEANUP SYSTEM - 069
ISOMETRIC NUMBER : ISI-0272-C SHEET : 01
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
DRWC-2-02	ELBOW -VALVE	B-J B9.11	R00000139			PT	19941004	PASS	YES		
DSRWC-2-01	PIPE -ELBOW	B-J B9.11	R00000140			PT	19941004	PASS	YES		
DSRWC-2-01A	PIPE -ELBOW	B-J B9.11	R00000141			PT	19941004	PASS	YES		
DSRWC-2-02	ELBOW -PIPE.	B-J B9.11	R00000142			PT	19941004	PASS	YES		
DSRWC-2-06	ELBOW -PIPE	B-J B9.11	R00000143			PT	19941004	PASS	YES		



REFERENCE DRAWINGS:
 TVA 47N335-14
 TVA 47N335-17
 TVA 47K1778
 ISI-0272-C (SH. 1) WEL.

NOTE:
 THIS DRAWING SUPERSEDES CHM-2082-C
 (ALL SHEETS)



LEGEND:

- VARIABLE SUPPORT
- RIGID HANGER
- HYDRAULIC SMUBBER
- ▬ RIGID STRUT

CALCULATION BRANCH/PROJECT IDENTIFIER:

CD-02069 - 900011
 CD-02071 - 880988

ASME CC-1 (EQUIVALENT)



345290272
 2498 884885
 CD 1 2-121-8214-C
 000001
 102494 000


CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD	CD
001	002	003	004	005	006	007	008	009	010	011	012	013	014	015	016	017	018	019	020
ISSUED TO CREATE CD, SUPERSEDES A/D ISI-0274-C (1) 807; ADDED PIPING UPSTREAM OF VALVE 2-49-630 AND ADDED CALCULATION IDENTIFIERS																			
CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH	CH
TENNESSEE VALLEY AUTHORITY																			
BROWNS FERRY NUCLEAR PLANT																			
UNIT 2																			
REACTOR WATER CLEAN-UP, RCIC, AND CRO																			
HYDRAULIC RETURN LINE, SUPPORT IDENTIFICATION																			
DRW	ENG	DATE	6-13-68	SCALE	N/A	COMMITTEE													
CHECKED	JES	APPROVED	CLB	SHEET	01	OF	03	REV											
SUBMITTED	EDC	CLB	2-ISI-0274-C		000														
CCD																			

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2600
 DECATUR, ALABAMA 35502

UNIT: TWO
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

Page 20 of 28




REFERENCE DRAWINGS
 CRD-2-005
 RCIC-2-004
 RWC-2-001, -17
 47W335-14, -17

NOTE:
 THIS DRAWING SUPERSEDES CH-2075-C
 AND CH-2072-C (ALL SHEETS)

MATERIAL SPECIFICATIONS
STAINLESS STEEL
FITTINGS
 6" SA403 WP316NG SCH. 80 SS
PIPING
 6" SA376 TP316NG SCH. 80 SS

CARBON STEEL
 4" SCH. 80 A-333, GR1 (SEAMLESS) CS
 6" X 0.562" NOM WALL SCH. 120 CS
 8" X 0.593" NOM WALL SCH. 100 CS
VALVE
 2-69-630 SA182 F316

 ASME CC-1 (EQUIVALENT)



01	REV	001	ISS	1-8-85	1-8-85
REVISION TO DRAWING: ADD R7 WELD FOR 2001-2002 THERMAL TEE COMPLETE WELDED CONNECTIONS, ADD FATIGUE DETAILS, CLASS BOUNDARY NOTATION, NEW VALVE 2-69-630 AND MATERIAL SPEC., REPLACE DRWC-2-01 WITH DRWC-2-01A AND WELD RWC-2-001-007, REVISE RCRD-2-01 AND RCRD-2-02 TO CLS WELDS DRWC-2-001, -002, -003, -004, -005, DRWC-2-01 WITH WELDS RWC-2-001-001, -002, -003, -004, TRCIC-2-001 WITH WELDS RWC-2-001-001, DRWC-2-01 WITH WELDS RWC-2-001-001, AND MATERIAL TRANSMISSION TO VALVE 2-69-630					
02	REV	002	ISS	6-2-89	6-2-89
REV. REV. DRWC-2-01					
03	REV	003	ISS	7-20-91	7-20-91
CLS, CADUCE, ADD MATERIAL & MATCH LINE					
04	REV	004	ISS	10-18-89	10-18-89
REV. REV. DRWC-2-01					
05	REV	005	ISS	5-22-89	5-22-89
ADD HTR, REV. LDR, AND CORRECT MATCH LDR					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY BROWNS FERRY NUCLEAR PLANT UNIT 2 REACTOR WATER CLEAN UP, RCIC, AND CRD WELD IDENTIFICATION					
DRAWN:	REV	DATE:	SCALE:	TITLE:	GROUP:
CHECKED:	ISS	APPROVED:	CLS	SHEET 01 OF 03	REV
SUBMITTED:	ISS			ISI-0272-C	05

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402
 UNIT: TWO
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN, 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
* HUTCH                               TENNESSEE VALLEY AUTHORITY                               PRISM
*                                     BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
*                                     POST OUTAGE EXAMINATION RESULTS REPORT
*                                     EXAM REQUIREMENT : R01-02   CYCLE : 07
*                                     INTERVAL : 02   PERIOD : 1
*                                     *****
*                                     * PAGE 1
*                                     * REVISION 002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : HPCIS HIGH PRESSURE COOLANT INJECTION SYSTEM - 073
* ISOHETRIC NUMBER : ISI-0130-C SHEET : 01
*
*****


```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-47B455H0056	VSPRING	F-A F1.20C	R00000222 R00000449			VT-3 VT-3	19941014 19941104	FAIL PASS	YES YES		INC SETTING	COMP RESET
2-47B455H0059	VSPRING	F-A F1.20C	R00000223			VT-3	19941014	PASS	YES			
2-47B455H0060	VSPRING	F-A F1.20C	R00000224			VT-3L	19941014	PASS	YES			
2-47B455H0062	VSPRING	F-A F1.20C	R00000214			VT-3	19941013	PASS	YES			



REFERENCE DRAWINGS
 47H455-H-6, 7, 203
 ISI-0128-C (SH. 1) WELD MAP

LEGEND
 ● RIGID HANGER
 ○ VARIABLE SUPPORT
 ○ HYDRAULIC SNUBBER
 ○ MECHANICAL SNUBBER
 ▲ ANCHOR
 ▬ RIGID STRUT
 ASME CC-2 (EQUIVALENT)



OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

04	REV 13-92	REVISE SUPPORT NUMBERS TO MATCH NEW NUMBERS FROM ENGINEERING. DELETE SUPPORTS OUTSIDE BOUNDARY.	028	000	011
03	REV 2-13-91	DEL CHECK ADD WORKDOWN DATA	JAN	23	028
02	REV 9-14-88	REVISED MATCH LINE A	SEP	10	028
01	REV 5-28-87	REWORK & REVISED FOR PRISM	SEP	10	028
REV BY	DATE	DESCRIPTION	BY	DATE	APP
HARDWARE: TEX 4129 SOFTWARE: TECHCAD 1.0 PLOTT: B-04					

TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT					
UNIT # 2					
HIGH PRESSURE COOLANT INJECTION SYSTEM					
SUPPORT LOCATIONS					
DRWN	REV	SUBMITTED	APPROVED	SCALE	MIS
DATE	1-12-81	DATE	DATE	SHEET	01 OF 03 SHEET(S)
CREATED	JUL	DATE	GLB	DRAWING NO.	REV
DATE				ISI-0130-C	04

Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
* NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIN
*                                     BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
*                                     POST OUTAGE EXAMINATION RESULTS REPORT
*                                     EXAM REQUIREMENT : R17-02   CYCLE : 07
*                                     INTERVAL : 02   PERIOD : 1
*                                     *****
*                                     * PAGE 2
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : RHRS RESIDUAL HEAT REMOVAL SYSTEM - 074
* ISOHETRIC NUMBER : ISI-0324-C SHEET : 05
*
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-47B452R0077	H SNUB	F-A F1.20C	R00Q00087			VT-3	19940713	PASS	YES		

```

*****
* NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIN
*                                     BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
*                                     POST OUTAGE EXAMINATION RESULTS REPORT
*                                     EXAM REQUIREMENT : R23-02   CYCLE : 07
*                                     INTERVAL : 02   PERIOD : 1
*                                     *****
*                                     * PAGE 4
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : RHRS RESIDUAL HEAT REMOVAL SYSTEM - 074
* ISOHETRIC NUMBER : ISI-0221-C SHEET : 01
*
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
DRHR-2-04	PENPIPE -ELBOW	B-J B9.11	R00000317			PT	19941021	PASS	YES		
DRHR-2-07	ELBOW -VALVE	B-J B9.11	R00000297			PT	19941019	PASS	YES		



OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402


UNIT: TWO

COMMERCIAL SERVICE DATE: MARCH 1, 1975

NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602



REFERENCE DRAWINGS
 47W452 SERIES
 47N335-7
 MSG-0018-C (SH. 5) WELD MAP
 THIS DRAWING SUPERSEDES MSG-0023-C SH. 2
 (SEE NOTE 1)

LEGEND:

- RIGID HANGER
- ⊗ VARIABLE SUPPORT
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- ▬ RIGID STRUT
- ASME CC-2 (EQUIVALENT)

NOTES:
 1.) DRAWINGS ISI-0324-C SH. 4-7 MAKE UP
 SUPERCEDED DRAWING MSG-0023-C (SH. 2)

REV	DATE	DESCRIPTION	BY	CHKD	APP
05	6-1-89	REVISE SUPPORT LOCATIONS TO MATCH	EDC	JES	GLB
04	2-15-81	ADD VALVE DATA TO SHEET	JES	EDC	GLB
03	8-28-80	MODIFY SUPPORTS, REMOVE CADBLOCK	JES	EDC	GLB
02	1-8-80	ADD NEW SUPPORT TO S. ABOVE, RED.	JES	EDC	GLB
01	4-4-89	REMOVED HYD. SNUBBER, ADDED MECH. SNUBBER, NEW SUPPORT & NOTE, AND REVISED SUPPORT LOCATIONS	JES	EDC	GLB

REV BY DATE DESCRIPTION BY CHKD APP
 HARDWARE: TEK 4120 SOFTWARE: TEK/EDC 1 B* PLOT: 8-10

TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT					
UNIT 2					
RESIDUAL HEAT REMOVAL SYSTEM					
SUPPORT LOCATIONS					
DRAWN	PHB	SCALE	NTS	DATE	DATE
DATE	DATE	DATE	DATE	DATE	DATE
DATE	EDC	GLB	DATE	DATE	DATE
DATE	EDC	GLB	DATE	DATE	DATE



NOTE:


1. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-1D (DOWNSTREAM)
- (BASE WELD NO.)-LS-2D (DOWNSTREAM)
- (BASE WELD NO.)-LS-1U (UPSTREAM)
- (BASE WELD NO.)-LS-2U (UPSTREAM)

THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHERMOST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)

2. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS:

- (BASE WELD NO.)-LS-D (DOWNSTREAM)
- (BASE WELD NO.)-LS-U (UPSTREAM)



REFERENCE DRAWINGS:

47N1568
 47N335-4 86
 47N452 SERIES
 DRAVO E-2458-IC-31, 32, & 33
 ISI-0276-C SHI
 NOTE: THIS DRAWING SUPERCEDES
 CHM-2070-C ALL SHEETS.

MATERIAL SPECIFICATION:

STAINLESS PIPE A-358, GR 304, CL. 1
 STAINLESS FITTINGS A-403MP304
 24" X 1.219" NOM. WALL THK. SCH. 80 SS
 20" X 1.031" NOM. WALL THK. SCH. 80 SS
 20" X 1.031" NOM. WALL THK. SCH. 80 CS
 6" X 0.432" NOM. WALL THK. SCH. 80S SS

ASME CC-1 (EQUIVALENT)

NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975

UNIT: T/YO

CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

OWNER: TENNESSEE VALLEY AUTHORITY
 PROJECT: BROWNS FERRY NUCLEAR PLANT
 UNIT: T/YO
 CHAINING: ALABAMA 35602
 DECATUR, ALABAMA 35602

1	PH	JES	EDC	CLB	10-11-72
ADD SHEET 2, ADD MATCH LINES TO 2" LINES					
2	PH	RFC	JES	CLB	7/2/73
REMOVE BOLTED CONNECTIONS					
3	PH	REC	JES	CLB	6-3-72
CHANGE DSRHR-18 TO DRHR-19, CORRECT REF. DRAWING NO.					
4	PH	RFC	JES	CLB	3-13-72
ADD LONGSEAM IDENTIFIER NOTE CORRECT WELD ID.					
5	PH	JAM	JES	CLB	9-20-71
REDRAW TO CADAM, CORRECT MATERIAL SPEC, ADD LONG SEAMS					
6	PH	JES	EDC	CLB	9-27-69
ADD LONG SEAMS & CORRECT WELD, CHANGE MATCH LINES					
REV.	BY	CHECKED	DESIGNED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2 RESIDUAL HEAT REMOVAL SYSTEM WELD LOCATIONS					
DRAWN:	RFC	DATE:	6-20-68	SCALE:	NIS
CHECKED:	JES	APPROVED:	CLB	SHEET:	01 OF 02
DESIGNED:	EDC	REV ISI-0221-C-06			

RHR-2-X-X
 UNIT SUPPORT NO.
 RESIDUAL HEAT REMOVAL

Owner: TENNESSEE VALLEY AUTHORITY
 Nuclear Power Group
 1101 Market Street
 Chattanooga, TN 37402-2801

Plant: Browns Ferry Nuclear Plant
 P.O. Box 2000
 Decatur, AL 35609-2000

Unit: Two

Certificate of Authorization: Not Required

Commercial Service Date: March 1, 1975

National Board Number For Unit: Not Required

```

*****
* NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIH
*                                     BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
*                                     POST OUTAGE EXAMINATION RESULTS REPORT
*                                     EXAM REQUIREMENT : R23-02   CYCLE : 07
*                                     INTERVAL : 02   PERIOD : 1
*                                     *****
*                                     * PAGE 1
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : CSS CORE SPRAY SYSTEM - 075
* ISOMETRIC NUMBER : ISI-0271-C SHEET : 01
*
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
DCS-2-05	PIPE -VALVE	B-J B9.11	R00000325			PT	19941015	PASS	YES		

```

*****
* NUTECH                                TENNESSEE VALLEY AUTHORITY                                PRISIH
*                                     BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*                                     ISI DATA BASE
*                                     POST OUTAGE EXAMINATION RESULTS REPORT
*                                     EXAM REQUIREMENT : R22-02   CYCLE : 07
*                                     INTERVAL : 02   PERIOD : 1
*                                     *****
*                                     * PAGE 1
*                                     * REVISION 0002
*                                     * DATE 01/12/95
*                                     *****
*
* SYSTEM : CSS CORE SPRAY SYSTEM - 075
* ISOMETRIC NUMBER : ISI-0271-C SHEET : 01
*
*****

```

FEATURE NUMBER	COMPONENT DESCRPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT REQST.	INDICATION TYPE	INDICATION RESOLUTION
TCS-2-405	VALVE -ELBOW	B-F B5.130	R00000138			PT	19941004	PASS	YES		
TCS-2-406	PIPE -VALVE	B-F B5.130	R00000137			PT	19941004	PASS	YES		



OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402

PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED

COMMERCIAL SERVICE DATE: MARCH 1, 1975

NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

REFERENCE DRAWINGS


DRAVO E-2450-IC-34
 DRAVO E-2458-IC-35

NOTE: THIS DRAWING SUPERSEDES CHN-2071-C
 ALL SHEETS

MATERIAL SPECIFICATIONS


12" SCH. 80 SA 333 GR6 CS
 12.75" X .687" NOM. WALL THK.
 12" SCH. 80 ASTM A358 GR 304 SS
 12.75" X .687" NOM. WALL THK.
 10" SCH. 80 SA 333 GR6 CS
 10.75" X .593" NOM. WALL THK.
 10" SCH. 80 ASTM A358 GR 304 SS
 10.75" X .593" NOM. WALL THK.

ASME CC-1 (EQUIVALENT)



- NOTE:
1. WELDS DCS-2-07 AND DCS-2-13A ARE DRAVO SHOP WELDS.
 2. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS:

(BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)



7	PHB	DES	GLB	RME	2/11/93
ADD (OL) TO TCS-2-421 PER FCDT-93-10					
8	PHB	JES	GLB	RME	2/11/93
DELETE LONG SEAMS TCS-2-405-LS-1, -405-LS-2, -410-LS, -421-LS-1, -421-LS-2, -425-LS, TCS-2-409-LS, -424-LS, REVISED REP. DRAWINGS, ADD FLUED HEAD WELDS DSCS-2-16A, -16B, DELETED BOLTED CONNECTIONS FCV-75-25-BC, -25-BC, REDRAW TO CADAM, ADD NOTE 1 REF.					
9	PHB	RPO	JES	GLB	3-13-92
ADD LONGSEAM IDENTIFIER NOTE					
4	PHB	JUA	JES	GLB	9-20-91
MODIFY MATERIAL SPECS., ADD LONG SEAMS					

03	PHB	JES	EDC	GLB	4-23-90
ADD CS & SS BOUNDARY, CS SPEC, DEL CADAM					
02	PHB	JES	EDC	GLB	1-4-90
ADD NOTE 2					
01	PHB	JES	EDC	GLB	12-15-88
ADD LONGSEAM WELD TCS-2-424-LS, CORRECT MATERIAL SPECS					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT UNIT 2 CORE SPRAY SYSTEM WELD LOCATIONS					
DRAWN:	PHB	DATE:	5-17-89	SCALE:	NTP CADAM/STOP
CHECKED:	JES	APPROVED:	GLB	SHEET	01 OF 01 REV
SUBMITTED:	EDC	ISI-0271-C07			

Page 28 of 28



ENCLOSURE 4

**BROWNS FERRY
NUCLEAR PLANT**

CORRECTIONS TO THE

UNIT 2 CYCLE 6

NIS-1 AND NIS-2 REPORTS

DESCRIPTION OF THE CORRECTIONS TO
BFN UNIT 2 CYCLE 6 NIS-1 AND NIS-2 REPORTS

This enclosure contains corrections to the BFN Unit 2 Cycle 6 NIS-1 and NIS-2 reports. The corrections are described below:

- Deleted ASME credit for RPV instrument nozzles N-11A and N-11B examination category B-E, item number B4.13.
- Deleted ASME credit for RWCU valve 69-580 examination category B-M-2, item number B12.50. Revised to show that a VT-2 examination of valve 69-580 was performed after repair/replacement. The VT-2 was performed during the pressure test.
- Revised item number for RPV stud examination from B6.30 to B6.20.
- Added ASME credit for VT-2 examination for RHR nozzle weep holes examination category C-B, item number C2.33.
- Revised NIS-2 for RWCU pipe/valve replacement to delete reference to code exception for RWCU-2-004-G073 and RWCU-2-004-74, since construction code volumetric examination (radiography) was utilized for preservice examination in conjunction with ASME Section XI ultrasonic examination to achieve the code required examination volume.

 NUTECH
 TENNESSEE VALLEY AUTHORITY
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : 86E-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 PRISM

 PAGE 27
 REVISION 0002
 DATE 07/19/93

 SYSTEM : RHRSH RHR SERVICE WATER SYSTEM - 023
 ISOMETRIC NUMBER : N/A SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT	INDICATION TYPE	INDICATION RESOLUTION
2-SI-3.3.13	HYDRO	D-B D2.10	R00000313			VT-2	19930419	PASS	YES		

 NUTECH
 TENNESSEE VALLEY AUTHORITY
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : 86E-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 PRISM

 PAGE 28
 REVISION 0002
 DATE 07/19/93

 SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
 ISOMETRIC NUMBER : CHM-2046-C SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI RELIEF CREDIT	INDICATION TYPE	INDICATION RESOLUTION
N11A	INS NOZ	B-E 04-13	R00000323			VT-2	19930511	PASS	YES		
N11B	INS NOZ	1-2 04-13	R00000323			VT-2	19930511	PASS	YES		

DTK
 1-5-95
 1/18/95

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602
 UNIT: TWO CERTIFICATE OF AUTHORIZATION: NOT REQUIRED
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED



SYSTEM : RWCUS REACTOR WATER CLEANUP SYSTEM - 069
 ISOMETRIC NUMBER : ISI-0272-C SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
FCV-69-001	VAL INT	B-H-2 B12.50	R00000198			VT-3	19930312	PASS		YES		
TRWCU-2-2	VALVE -VALVE	B-J B9.11	R00000259 R00000260	C00000129	BF-01	HT UT-45	19930325 19930325	PASS PASS		YES YES	GEOMETRIC GEOMETRIC GEOMETRIC	NON-RELEVANT NON-RELEVANT NON-RELEVANT
			R00000260 R00000260	C00000130 C00000131	BF-01 BF-01	UT-45L UT-60	19930325 19930325	PASS PASS		YES YES		
69-500	VAL INT	B-H-2 B12.50	R00000553			VT-2	19930520	PASS		YES		

JTR 1-6-95
 JTR 1/4/95

SYSTEM : RWCUS REACTOR WATER CLEANUP SYSTEM - 069
 ISOMETRIC NUMBER : ISI-0272-C SHEET : 02

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
2-RDL-2	PIPE -ELBOW	B-J B9.40	R00000075			PT	19930218	PASS		YES		

OWNER: TENNESSEE VALLEY AUTHORITY
 NUCLEAR POWER GROUP
 1101 MARKET STREET
 CHATTANOOGA, TENNESSEE 37402
 PLANT: BROWNS FERRY NUCLEAR PLANT
 P.O. BOX 2000
 DECATUR, ALABAMA 35602

UNIT: TWO
 CERTIFICATE OF AUTHORIZATION: NOT REQUIRED
 COMMERCIAL SERVICE DATE: MARCH 1, 1975
 NATIONAL BOARD NUMBER FOR UNIT: NOT REQUIRED

 NUTECH TENNESSEE VALLEY AUTHORITY PRISM
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : R27-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 SYSTEM : RWCUS REACTOR WATER CLEANUP SYSTEM - 069
 ISOMETRIC NUMBER : ISI-0272-C SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIP.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
69-580	VAL INT	B-P B15.10	R00000333			VT-2	19930520	PASS	YES			

Plant. Lewis 1-6-95

Albert L. Ford 1/18/95
ANII



 NUTECH TENNESSEE VALLEY AUTHORITY PRISM
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : 86E-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
 ISOMETRIC NUMBER : ISI-0266-C SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIPT.	CATEGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
RPV-STUDS-2-08	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-10	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES		GEOMETRIC	NON-RELEVANT
RPV-STUDS-2-12	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-14	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-16	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-20	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-26	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-28	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-30	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-32	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-34	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			

John T. Lewis 1-5-95

Albert [unclear] 1/19/95
AN II

 NUTECH TENNESSEE VALLEY AUTHORITY PRISM
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : 86E-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
 ISOMETRIC NUMBER : ISI-0266-C SHEET : 01.

FEATURE NUMBER	COMPONENT DESCRIPT.	CATEGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
RPV-STUDS-2-34	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000003 C00000003	BF-73	UT-60	19930131	PASS	YES			
RPV-STUDS-2-36	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-38	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-40	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-43	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-44	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES			
RPV-STUDS-2-46	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000004 C00000003	BF-73	UT-CRP	19930131	PASS	YES		GEOMETRIC	NON-RELEVANT
RPV-STUDS-2-52	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000003 C00000006	BF-73	UT-60	19930131	PASS	YES			
RPV-STUDS-2-54	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000003 C00000006	BF-73	UT-60	19930131	PASS	YES			
RPV-STUDS-2-56	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000003 C00000006	BF-73	UT-60	19930131	PASS	YES			
RPV-STUDS-2-58	CH BLTG	B-G-1 B6. 20	R00000035 R00000035	C00000003 C00000003	BF-73	UT-60	19930131	PASS	YES			

Page 5 of 9



 NUTECH TENNESSEE VALLEY AUTHORITY PRISM
 BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
 ISI DATA BASE
 POST OUTAGE EXAMINATION RESULTS REPORT
 EXAM REQUIREMENT : 86E-02 CYCLE : 06
 INTERVAL : 02 PERIOD : 1

 PAGE 38
 REVISION 0002
 DATE 01/03/95

SYSTEM : RPV REACTOR PRESSURE VESSEL (NUCLEAR BOILER) - 068
 ISOMETRIC NUMBER : ISI-0266-C SHEET : 01

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAM TYPE	EXAM DATE	EXAM RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
RPV-STUDS-2-58	CH BLTG	B-G-1 B6. 20	R00000035	C00000006	BF-73	UT-90	19930131	PASS	YES			
RPV-STUDS-2-60	CH BLTG	B-G-1 B6. 20	R00000035	C00000005	BF-73	UT-60	19930131	PASS	YES			
			R00000035	C00000006	BF-73	UT-90	19930131	PASS	YES			

John T. Lewis 1-5-95

Albert T. Ladd 1/19/95
 ANII

```

*****
NUTECH                               TENNESSEE VALLEY AUTHORITY                PRISM
*****                               BROWNS FERRY NUCLEAR POWER PLANT - UNIT 2
*****                               ISI DATA BASE
*****                               POST OUTAGE EXAMINATION RESULTS REPORT
*****                               EXAH REQUIREMENT : 86E-02   CYCLE : 06
*****                               INTERVAL : 02         PERIOD : 1
*****                               *****
*****                               SYSTEM      : RHRS RESIDUAL HEAT REMOVAL SYSTEM - 074
*****                               ISOHERMIC NUMBER : ISI-0406-C SHEET : 01
*****

```

FEATURE NUMBER	COMPONENT DESCRIPT.	CATGORY/ ITEM NO.	EXAMINATION REPORT NO.	CAL. REPORT NO.	CAL. STD.	EXAH TYPE	EXAH DATE	EXAH RESULT	SEC XI CREDIT	RELIEF REQST.	INDICATION TYPE	INDICATION RESOLUTION
RHRG-2-05-A	VES NOZ	C-B C2.33	R00000315			VT-2	19930423	PASS	YES			
RHRG-2-06-A	VES NOZ	C-B C2.33	R00000315			VT-2	19930423	PASS	YES			

Plant Lewis 1-5-95

Albert Field 1/19/95
ANII

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Tennessee Valley Authority Date June 14, 1993
1101 Market St. Name
Chattanooga, TN 37402-2801 Address Sheet 1 of 8

2. Plant Browns Ferry Nuclear Plant Unit 2
P.O. Box 2000; Decatur, AL 35609 Address Name Work Orders 93-00754-00, 93-00754-01, and
King of Prussia, PA 19406 Address Name noted Work Plans for DCN W18298
Repair Organization P.O. No., Job No., etc.

3. Work Performed by General Electric Company Type Code Symbol Stamp N/A
640 Freedom Business Center Name Authorization No. N/A
King of Prussia, PA 19406 Address Expiration Date N/A

4. Identification of System System 69, Reactor Water Cleanup

* 5. (a) Applicable Construction Code _____ 19 _____ Edition, _____ Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 86

* 6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

7. Description of Work Replaced various portions of the RWCU piping, removed and replaced two hangers, and installed new check valve 2-69-630

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1150/1110 psi Test Temp. 78/71 °F
 per WO 93-00754-00 and 93-00754-01 respectively

Page 8 of 9

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82)

This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

*For information required in Items 5 and 6, see attached sheets 2 through 8.

Page 65 of 185



FORM NIS-2 (Back)

Work Order 93-00754-00 was performed by TVA personnel which hydrostatically pressure tested the RWCU piping between valves 2-FCV-69-2, 2-69-500, and 2-10-505. TVA personnel also performed the hydrostatic pressure test of check valve 2-69-630 and associated welds per WO 93-00754-01 following installation by General Electric. Both tests fulfilled the hydrostatic pressure test requirements for ASME Code Class 1 equivalent components.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI...

... with the exception as noted below.* Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed J. Gilbert SYSTEM ENGINEER Date JUNE 14, 19 93

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENN. and employed by HARTFORD SIM. BLD. TRSP & TRS. CO. of HARTFORD, CONN. have inspected the components described in this Owner's Report during the period 4-16-93 to 6-16-93...

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report.

B. F. Rice Inspector's Signature Commissions 9635, TENN. - A-N-T National Board, State, Province, and Endorsements

Date 6-16 19 93

Exception to Code requirement - Preservice examination for welds RWCU-2-004-G073 and RWCU-2-004-G074 were unable to be 100% volumetrically examined as documented in Work Plan 2554-92; percent coverage was limited to 87.2% and 32.0% respectively.