

A CMS Energy Company

Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043

Tel: 616 764 2276
Fax: 616 764 2490

Nathan L. Haskell
Director, Licensing

December 22, 1998

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT
SUBMITTAL OF SUPPLEMENTARY INFORMATION IN SUPPORT OF RELIEF
REQUEST NO. RR-13

In a letter dated December 20, 1998, Consumers Energy Company submitted for NRC approval a request for relief from certain requirements of Section XI of the ASME Boiler and Pressure Vessel Code. In response to questions raised during a series of telephone conference calls on December 21, 1998, additional supplementary information was transmitted by fax to facilitate staff review. The purpose of this letter is to docket that supplementary information.

Attachment 1 provides a brief discussion of reasons why seismic loading cases are not controlling in the analysis of Primary Coolant Pump casing bolt stresses. Attachment 2 discusses the additional casing bolt stress and fatigue considerations which would result from eccentricity due to bolt wastage. Consumers Energy will incorporate this information into a revision of Engineering Analysis EA-C-PAL-98-1939-01 and submit the revised analysis under separate cover.

In addition to the technical information, Consumers Energy Company provided an additional commitment relating to methods of monitoring for Primary Coolant System leakage. That commitment is restated below.


9812300295 981222
PDR ADOCK 05000255
P PDR

A047'11

SUMMARY OF COMMITMENTS

This letter contains two new commitments and no revisions to existing commitments. The new commitments are:

1. The information provided in Attachments 1 and 2 will be incorporated into a revision of Engineering Analysis EA-C-PAL-98-1939-01. The revised analysis will be submitted to the NRC.
2. With the plant at steady state power, if a Primary Coolant System leak rate calculation indicates an unidentified leak rate in excess of 0.3 gpm, or the containment sump level trend indicated by the Plant Process Computer indicates a change in unidentified sump inleakage rate in excess of 0.2 gpm, a confirmatory Primary Coolant System leak rate calculation will be performed as soon as possible. If the confirmatory calculation verifies that the unidentified Primary Coolant System leak rate is greater than 0.3 gpm, and the reason for this leak rate is not understood, action will be initiated within 24 hours to place the plant in Hot Standby. Before the plant is returned to power operation, it will be verified that indication of leakage was not a result of significant additional degradation of Primary Coolant Pump P-50A.



Nathan L. Haskell
Director, Licensing

CC Administrator, Region III, USNRC
Project Manager, NRR, USNRC
NRC Resident Inspector - Palisades

Attachment

ATTACHMENT 1

**CONSUMERS ENERGY COMPANY
PALISADES PLANT
DOCKET 50-255**

**SUBMITTAL OF SUPPLEMENTARY INFORMATION
IN SUPPORT OF RELIEF REQUEST NO. RR-13**

**DISCUSSION OF SEISMIC LOADING CASES
IN ANALYSIS OF PRIMARY COOLANT PUMP CASING BOLT STRESSES**

The initial seismic design of Palisades NSSS components was conducted in a very simplistic, static manner. In the 1986 time frame, Palisades elected to use the ASME Section III, Code Case N 411-1 damping in conducting seismic response spectrum analysis. This entailed using the response spectrum curves provided Palisades by the NRC via NUREG/CR 1833.

The implementation of these curves required the determination of seismic anchor movements for piping attached to the primary coolant system. At about the same time, it was necessary for Palisades to determine time history input to the reactor vessel in order to conduct nonlinear seismic analysis on the new fuel bundles. Each of these analysis demands required that the primary coolant system vessels and piping be decoupled from the stick building model for the development of an interaction model. The vessels themselves (reactor vessel, steam generator, pressurizer and primary coolant pumps) were characterized by stick model members. This enabled the analysts to calculate seismic loads directly at critical cross sections.

This experience demonstrated that the interaction of the primary coolant system components with the concrete internal structure was such that the combined system/structure (original lumped mass) model was adequate for overall structural response and the seismic loading as previously calculated by the static ZPA methods was acceptable. The seismic loading was very modest and noncontrolling with respect to the other load cases and the seismic anchor movements of the primary coolant components could be ignored. This is the basis for the conclusion that seismic loadings cases and combinations are not limiting in the analysis of primary system components.

ATTACHMENT 2

**CONSUMERS ENERGY COMPANY
PALISADES PLANT
DOCKET 50-255**

**SUBMITTAL OF SUPPLEMENTARY INFORMATION
IN SUPPORT OF RELIEF REQUEST NO. RR-13**

**CASING BOLT STRESS AND FATIGUE CONSIDERATIONS DUE TO
ECCENTRICITY OF DEGRADED PRIMARY COOLANT PUMP CASING BOLTS**

1 Bolt Eccentricity

2
3
4 Preload and bending load stresses
5 are deflection limited secondary loads.
6 Therefore, ASME Code Stress Intensity limit
7 is $2S_y$ or 122 ksi
8

9 Preload + bending load stress intensity
10 range = $37.32 + 38.5 = 76 \text{ ksi} < 122 \text{ ksi}$
11

12 Therefore, bolt eccentricity due to corrosion
13 is acceptable.
14

15 Peak Alternating stresses are determined to
16 be 115 ksi, well within the fatigue resistance
17

18 See attached.
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38

Reference/Comment

See sheet 3
for 38.5 ksi

Reference/Comment

Operating Pressure = 2060 psi

$$\text{Pressure Load on joint} = 2060 \times 48 \times \frac{\sqrt{14}}{4}$$

$$= 3727.7 \text{ Kips}$$

Load of the equipment 112.3 Kips

Net Pressure load = 3605.4 Kips

$$\text{Pressure Load/bolt} = 225.3 \text{ kips}$$

Stress in the corroded bolt


$$= \frac{225.3}{12.21} = 18.5 \text{ ksi}$$

Stress Combination

Preload Stress + Op. Pressure stress $\times \phi$

$$= 32.71 + 18.5 \times 0.25 = 37.32 \text{ ksi}$$

C.G. of the combined section ($\frac{1}{2}$ circle + $\frac{1}{2}$ ellipse) is 0.48" into the half circle as shown.



CG of Corroded Section

1 Moment of Inertia about CG axis
 2 = 9.32 in⁴
 3

4 Tension will be on reduced area side
 5

6 Bending stress due to moment (Local)
 7

$$8 = \frac{37.32 \times 12.21 \times 0.48}{9.32} \times 1.64 = 38.5 \text{ KSI}$$

10 Using a stress concentration factor of 5
 11

12 Peak Bending Stress = 38.5 x 5 = 192.5 KSI
 13

14 Total Peak Stress = 37.32 + 192.5
 15 = 230 KSI
 16

17 Peak Alternating Stress = $\frac{230}{2} = 115 \text{ KSI}$
 18

19 For 10 cycles, from ASME section III - 1998
 20

21 Code, Fig. I-9.4, the maximum peak
 22 stress = 1000 KSI
 23

24 Peak stresses are less than allowable
 25 maximum stresses. Therefore, the degraded
 26 stud is acceptable.
 27

Reference/Comment

NB-3228.5
 1998 ASME
 Code