



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649



LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

July 16, 1976

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 76-19 (14-day report), Release of liquid
radioactive waste without continuous operation of a gross
activity monitor
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:


In accordance with Technical Specifications, Article 6.9.2a, the attached
report of Reportable Occurrence 76-19, 14-day, is hereby submitted. Two
additional copies of this letter and the attachment are enclosed.

Very truly yours,

L. D. White, Jr.

Attachment

cc: Dr. Ernst Volgenau (40)
Mr. William G. McDonald (3)



LER 76-19/1T
LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME: 1 N Y R E G 1
 LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0
 LICENSE TYPE: 4 1 1 1 1
 EVENT TYPE: 0 1

CATEGORY: 01 CONT
 REPORT TYPE: T
 REPORT SOURCE: L
 DOCKET NUMBER: 0 5 0 - 0 2 4 4
 EVENT DATE: 0 7 0 8 7 6
 REPORT DATE: 0 7 1 6 7 6

EVENT DESCRIPTION

2 During reclaiming of steam generator blowdown water by processing in main water
3 treatment plant demineralizers, it was determined that, from 6/17/76 to 7/6/76, 11
4 releases were made from the neutralizing tank with activity ranging from less than
5 2.25×10^{-7} to less than 3.96×10^{-6} uCi/cc. Although activity was determined by
6 sampling prior to each release, the releases were (cont'd. under Additional Factors)

SYSTEM CODE: 07 M A
 CAUSE CODE: B
 COMPONENT CODE: Z Z Z Z Z
 PRIME COMPONENT SUPPLIER: Z
 COMPONENT MANUFACTURER: Z 9 9 9
 VIOLATION: Y

CAUSE DESCRIPTION

8 The recently installed blowdown recovery system processes the blowdown water as des-
9 cribed above. The demineralizer resins concentrate the small amount of activity in the
10 blowdown water. The resins are then regenerated and the (cont'd. on attached sheet)

FACILITY STATUS: E
 % POWER: 1 0 0
 OTHER STATUS: NA
 METHOD OF DISCOVERY: a
 DISCOVERY DESCRIPTION: H.P. Supervisor review
 FORM OF ACTIVITY RELEASED: L
 CONTENT OF RELEASE: M
 AMOUNT OF ACTIVITY: less than 0.00087 Ci
 LOCATION OF RELEASE: Naturalizing tank to discharge canal

PERSONNEL EXPOSURES

13 NUMBER: 0 0 0
 TYPE: Z
 DESCRIPTION: NA

PERSONNEL INJURIES

14 NUMBER: 0 0 0
 DESCRIPTION: NA

OFFSITE CONSEQUENCES

15 Max. concentration in canal was 2.7×10^{-9} uCi/cc; no hazard was posed to general public

LOSS OR DAMAGE TO FACILITY

16 TYPE: Z
 DESCRIPTION: NA

PUBLICITY

17 NA

ADDITIONAL FACTORS (cont'd. from Event Description)

18 made without continuous use of a gross activity monitor. The blowdown has been
19 diverted to the blowdown tank where continuous gross activity monitor is in service.
19 (Reportable Occurrence 76-19, 14-day).

NAME: Duane Filkins PHONE: 716/546-2700, ext. 291-219

RECEIVED.
U.S.N.R.C.
JUL 20 1976
KING OF PRUSSIA, PA.

Licensee Event Report
Reportable Occurrence 50-244/76-19

Cause Description (cont'd.)

spent regenerants are collected in the neutralizing tank. This tank is then sampled and the contents analyzed for pH and activity prior to release to the discharge canal.

A temporary line has been installed to release the neutralizing tank through the liquid radioactive waste discharge monitor (R-18). An Engineering Work Request has been issued to study the possibility of installing a monitor on secondary plant waste discharge and/or the installation of permanent tie in to R-18.

Car 1083 has been issued to document the corrective actions.

