



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61N
St. Francisville, LA 70775
Tel 225-381-4374

William F. Maguire
Site Vice President
River Bend Station

RBG-47895

August 15, 2018

Attn: Document Control Desk
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: Supplement to the Response to License Amendment Request (LAR) for Review and Approval Of Relocation Of The Reactor Core Isolation Cooling (RCIC) Injection Point NRC Request for Additional Information (RAI)
River Bend Station, Unit 1
Docket No. 50-458
License No. NPF-47

RBF1-18-0168

- References: 1) Entergy Letter: License Amendment Request (LAR) (RBG-47823 dated January 29, 2018) (ADAMS Accession No. ML18029A187)
- 2) NRC email: River Bend Station, Unit 1, Request for Additional Information dated May 24, 2018 (ADAMS Accession No. ML18149A288)
- 3) Entergy Letter: RAI Response (RBG-47876 dated June 21, 2018) (ADAMS Accession No. ML18172A142)

Dear Sir or Madam:

In Reference 1, Entergy Operations, Inc (Entergy) submitted a request for the review and approval of relocation of the RCIC Injection Point from the Reactor Vessel Head Spray Nozzle to the 'A' Feedwater Line via the 'A' Residual Heat Removal (RHR) Shutdown Cooling Return Line. In an email dated May 24, 2018, (Reference 2) the NRC staff made a request for additional information, needed to complete the license amendment request. On June 21, 2018 Entergy submitted responses to the RAI (Reference 3). A clarification call for the RAI response was held with the NRC on July 17, 2018 where it was determined additional information was required by the NRC.

Enclosure 1 provides the additional information requested during the July 17, 2018 clarification call with the NRC. Attachment 1 contains the original load cases and thermal modes table from calculation AX-017D Revision 3. Attachment 2 contains the thermal transient table from AX-17D Addendum 3K. Attachment 3 contains Cumulative Usage Factor (CUF) Summaries for AX-17D Rev 3, Addendum 3J, and Addendum 3K. Attachment 4 contains the cover pages from AX-17D Addendum 3J and 3K. Attachment 5 contains Addendum 3J Stress/CUF comparison with Addendum 3B

This letter does not contain any new commitments.

If you require additional information, please contact Mr. Tim Schenk at (225) 381-4177 or tschenk@entergy.com.

In accordance with 10 CFR 50.91(b)(1), Entergy is notifying the State of Louisiana and the State of Texas by transmitting a copy of this letter to the designated State Official.

I declare under penalty of perjury that the foregoing is true and correct. Executed on August 15, 2018.

Sincerely,



WFM/BJ

- Enclosure 1: Supplement to the Request for Additional Information (ML18172A142)
- Attachment 1: Original Load Cases and Thermal Modes Table from AX-017D
- Attachment 2: Thermal Transient Loss of Feed Water Pumps Aux Power Trip without Bypass and Reactor Core Isolation Cooling (RCIC) Injection AX-17D Rev 3K
- Attachment 3: Cumulative Usage Factor (CUF) Summaries AX-17D Rev 3, Addendum 3J, and Addendum 3K
- Attachment 4: Addendum 3J and 3K Cover Pages
- Attachment 5: Addendum 3J Stress/ Cumulative Usage Factor (CUF) comparison with Addendum 3B

cc: U.S. Nuclear Regulatory Commission
Region IV
1600 E. Lamar Blvd.
Arlington, TX 76011-4511

U.S. Nuclear Regulatory Commission
Attn: Ms. Lisa M. Regner, Project Manager
09-D-14
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

NRC Senior Resident Inspector
Attn: Mr. Jeff Sowa
5485 U.S. Highway 61, Ste. NRC
St. Francisville, LA 70775

Department of Environmental Quality
Office of Environmental Compliance
Radiological Emergency Planning and Response Section
Ji Young Wiley
P.O. Box 4312
Baton Rouge, LA 70821-4312

Public Utility Commission of Texas
Attn: PUC Filing Clerk
1701 N. Congress Avenue
P. O. Box 13326
Austin, TX 78711-3326

RBG-47895
Enclosure 1
Page 1 of 4

RBG-47895

Enclosure 1

Supplement to the Request for Additional Information (ML18172A142)

Supplement to the Request for Additional Information (ML18172A142)
RIVER BEND STATION, UNIT 1
DOCKET NO.: 50-458

Background

The NRC staff would like to have a clarification call with you concerning your RAI response dated June 21, 2018. Specifically, the staff would like to discuss the below topics to determine if a follow-up RAI is needed: In your response dated June 21, 2018, you explained that the Cumulative Usage Factors (CUF) reduced significantly from 0.35 to 0.16 at point 1W and from 0.59 to 0.23 at point 71W as indicated in Table 3.6A-9a of the Updated Safety Analysis Report (USAR), as a result of installing a nozzle check valve into the feedwater system instead of using a swing check valve. The staff notes that the CUF for the piping system is from thermal transients.

Question

What thermal modes or transient changes and loading condition changes occurred since the cumulative usage factors and stresses decreased?

The reason for this significant CUFs reduction should be explained in detail including:

- old/new transients curves/cycles,
- fatigue stresses/cycles (S-N) combination summary, and
- the method to combine the CUFs for:
 - before the change (from 1986 beginning of the operation to the modification) and
 - after the change (after the modification to end of the operating license period).

Response

MR 96-0069 rerouted the Reactor Core Isolation Cooling (RCIC) Injection point from the Reactor Head Spray connection to the "A" Loop of Feedwater via the "A" Reactor Heat Removal (RHR) Shutdown Cooling return. This modification issued addendum 3K to calculation AX-017D (Pipe Stress Calculation for Feedwater Piping in Reactor and Auxiliary Bldgs, West Loop, Normal/Upset Condition Class 1 Analysis) to analyze the changes made to the feedwater piping system with the RCIC injection connection. Addendum 3K also administratively incorporated the approved AX-017D addenda 3B, 3E, 3F, 3G, 3H, and 3J. The changes made by each of these addenda are summarized below:

Addendum 3B revised the temperature drop during the feedwater heater loss event from 322 deg F to 320 deg F. This change was associated with LAR 88-006 and analyzed operation with lower feedwater temperature associated with operation in Single Loop Operation with Feedwater Heaters Out of Service. This change increased the severity of this transient and increased stresses and CUF. A summary of the class 1 stresses and CUF values can be seen below on the Addendum 3J Stress/CUF comparison with Addendum 3B.

Addendum 3E evaluated a change in a 3' segment of pipe from Sch. 60 to Sch. 80 associated

with plant modification MR 91-0080. The resulting stresses, moments and loads due to the upgrade of the piping to schedule 80 from schedule 60 were determined to be within the allowable limits. The model changes associated with this addendum were incorporated into addendum 3K.

Addendum 3F evaluated the effects of smaller mass (500 lb to 275 lb) on a valve actuator/ valve center accelerations, pipe stress, usage factor, pipe support loads, penetration loads, and the potential impact on stress reports caused by a lighter weight motor installed on outboard feedwater valve FWS-MOV7A. Based on an assessment of relative reduction of mass and increase of valve natural frequency it was concluded that the deadweight and combined dynamic loads for the new configuration were bounded by the corresponding loads of the old configuration.

Addendum 3G evaluated the addition of a 12" sch 60 to 12" sch 60 field weld between nodes 108 and 109. The stresses and CUF for the new weld fall between those of the two previously analyzed adjacent nodes as they were both previously analyzed and qualified as weld points.

Addendum 3H reduced the total combined normal/upset and faulted accelerations computed for FWS-MOV065A by applying Code Case N-411 damping spectra. This change was superseded by addendum 3K because all of the seismic and hydraulic events were analyzed using N-411 damping curves in addendum 3K.

Addendum 3J reduced the dynamic loads for OBE, SRV 1V, SRV 2V, and SRV 16V load cases by using Code Case N-411 damping in the stress analysis. Attachment 4 contains the cover page to AX-017D Addendum 3J for reference. The analyzed Class 1 stresses and CUF were reduced as a result. The reduction of stresses and CUF due to the use of Code Case N-411 damping values are shown below on the Addendum 3J Stress/CUF comparison with Addendum 3B, see Attachment 5. As can be seen, stresses and CUF for most of the class 1 node points analyzed were reduced significantly.

3K incorporated the changes made by addenda 3B, 3E, 3F, 3G, 3H, and 3J. Addendum 3K evaluated the Feedwater piping for the new function of RCIC injection in addition to the existing Feedwater functions. Attachment 4 contains the cover page to AX-017D Addendum 3K for reference. The added check valve FWS-V3052 was added to the model and new thermal mode 36 was introduced for the injection of 40 deg F RCIC into the feedwater piping. This new thermal transient includes 10 postulated events with 3 injections per event (total of 30 cycles) with no feedwater flowing. In addition to these 10 injection sequences, there are 40 postulated spurious injections with feedwater flowing. The spurious injection of RCIC with feedwater flowing events were excluded from the analysis as the contribution to stress is minimal due to the low change in feedwater temperature. The thermal transient diagram for the new thermal transient is shown in Attachment 2.

Due to the changes made by MR 96-0069 (RCIC Reroute to Feedwater) and the aggregate of the incorporated addenda 3B, 3E, 3F, 3G, 3H, and 3J, there was a net decrease in stresses and CUF of the break points reported out on RBS USAR tables 3.6A-9a and 10a. However, this decrease is largely due to the use of Code Case N-411 damping on the dynamic transient cases. It can be seen from a comparison of the results of addendum 3J (re-evaluated dynamic load cases with N-411 damping curves) to addendum 3K (MR 96-0069 RCIC Reroute Modification) that the stresses and CUF values of break points 60AW, BW, CW (corresponds

with AX-017D Node Point 82), 70W (corresponds with AX-017D Node point 97), and 71W (corresponds with AX-017D Node Point 85) increased from the results of 3J. This increase is caused by the aggregate of the incorporated changes made by addenda 3B, 3E, 3F, and 3G and the change to the routing of the RCIC system.

The reason for this significant CUFs reduction should be explained in detail including:

- ***old/new transients curves/cycles,***

The load cases and thermal modes from Revision 3 of AX-017D are located in Attachment 1. A new thermal transient was added with addendum 3K, the transient curve can be found in Attachment 2.

- ***fatigue stresses/cycles (S-N) combination summary***

Attachment 3 shows the original CUF values from AX-017D; the load combination summary and stress/CUF combinations for node points 82, 85, and 87 from AX-017D addendum 3J (implemented Code Case N-411 damping curves; and the load combination summary and stress/CUF combinations for node points 82, 85, and 87 from AX-017D addendum 3K (MR 96-0069 and addenda incorporation)

- ***the method to combine the CUFs for:***
 - ***before the change (from 1986 beginning of the operation to the modification) and***
 - ***after the change (after the modification to end of the operating license period).***

The piping model analyzes the cumulative effects of postulated transients and normal operating conditions on the piping system. The change associated with MR 96-0069 added a new transient to the feedwater piping system (spurious injection of RCIC). The new thermal transient was added with a postulated number of occurrences of 10. This new thermal transient was added to the model and was added to the calculated stresses and CUF. For this change it was not necessary to break out the stresses that would have occurred before and after this modification.

If a situation were to occur where a physical change to the plant reduced the severity of a postulated transient, but that transient had already occurred X number of times prior to the physical change then that transient would need to be broken out into two different transients. One would track or estimate the stress/usage caused by the transients that had occurred under the previous configuration and one would track the stress/fatigue due to the new postulated, but less severe transient.

RBG-47895

Attachment 1

Original Load Cases and Thermal Modes Table from AX-017D

Original Load Cases Table from AX-017D:

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>163</u>																																																																																						
JO. OR WO. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE																																																																																							
REF.																																																																																										
	5.0 <u>LOADING CONDITIONS ANALYZED</u>																																																																																									
	5.1 <u>DESCRIPTION FOR LOAD CASES</u>																																																																																									
	<table border="0"> <thead> <tr> <th style="text-align: left;"><u>LOAD CASE</u></th> <th style="text-align: left;"><u>DESCRIPTION</u></th> </tr> <tr> <th style="text-align: left;"><u>NUMBER</u></th> <th style="text-align: left;"><u>DESCRIPTION</u></th> </tr> </thead> <tbody> <tr> <td></td> <td>Normal/upset condition (Run 004)</td> </tr> <tr> <td>1</td> <td>FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)</td> </tr> <tr> <td>2</td> <td>OBEI= OBE INERTIA.....GROUPING BY STD SRSS</td> </tr> <tr> <td>3</td> <td>SSEI= SSE INERTIA.....GROUPING BY STD SRSS</td> </tr> <tr> <td>4</td> <td>SRV (1V,2V,SRVCO2V).....GROUPING BY STD SRSS</td> </tr> <tr> <td>5</td> <td>SRV (16V,SRVCO16V).....GROUPING BY STD SRSS</td> </tr> <tr> <td>6</td> <td>COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS</td> </tr> <tr> <td>7</td> <td>PS= POOL SWELL.....GROUPING BY STD SRSS</td> </tr> <tr> <td>8</td> <td>APMSB= ANNULUS PRESSURIZATION M.S.B... GROUPING BY STD SRSS</td> </tr> <tr> <td>9</td> <td>APRCB= ANNULUS PRESSURIZATION R.C.B....GROUPING BY STD SRSS</td> </tr> <tr> <td>10</td> <td>APFWB= ANNULUS PRESSURIZATION P.W.B....GROUPING BY STD SRSS</td> </tr> <tr> <td>11</td> <td>DL= DEADWEIGHT ANALYSIS: TLOAD=3,(FOSH = COLDSET LOAD)</td> </tr> <tr> <td>12</td> <td>X-DIR OBE ANCHOR MVMTS</td> </tr> <tr> <td>13</td> <td>Y-DIR OBE ANCHOR MVMTS</td> </tr> <tr> <td>14</td> <td>Z-DIR OBE ANCHOR MVMTS</td> </tr> <tr> <td>15</td> <td>THERM 1= NORMAL OPERATING: (12) PPG @ 420/420/420 F RPV @ 552/528/528</td> </tr> <tr> <td>16</td> <td>THERM 2= TURB ROLL COLD: (4A-1..) PPG @ 70/70/70 F RPV @ 552/552/450</td> </tr> <tr> <td>17</td> <td>THERM 3= BOLT-UP,LEAK TEST: (3A-1..) 70-100</td> </tr> <tr> <td>18</td> <td>THERM 4= HYDROTEST: (2A) 100-180-100</td> </tr> <tr> <td>19</td> <td>THERM 5= START-UP:{UP} (3A-2..) 100-486</td> </tr> <tr> <td>20</td> <td>THERM 6= START-UP:{UP} (3B-2) 100-486</td> </tr> <tr> <td>21</td> <td>THERM 7= TURB ROLL: (4A-2..) 70-325</td> </tr> <tr> <td>22</td> <td>THERM 8= TURB ROLL: (4B-1+2) 180-70-325</td> </tr> <tr> <td>23</td> <td>THERM 9= TURB ROLL: (4A-3..) 325-420</td> </tr> <tr> <td>24</td> <td>THERM 10= DAILY PWR REDCTN : (5-1+2..) 420-354</td> </tr> <tr> <td>25</td> <td>THERM 11= DAILY PWR INCR : (5-3..) 354-420</td> </tr> <tr> <td>26</td> <td>THERM 12= WEEKLY PWR REDCTN : (6-1+2) 420-326</td> </tr> <tr> <td>27</td> <td>THERM 13= FW HTR LOSS: (9-1+2) 420-352</td> </tr> <tr> <td>28</td> <td>THERM 14= FW HTR RESTORTN: (9-3) 352-420</td> </tr> <tr> <td>29</td> <td>THERM 15= SCRAMS: (22-1+2..) 420-275</td> </tr> <tr> <td>30</td> <td>THERM 16= PWR REDUCTN: (13) 420-190</td> </tr> <tr> <td>31</td> <td>THERM 17= HOT STDBY: (14A) 190-70</td> </tr> <tr> <td>32</td> <td>THERM 18= HOT STDBY: (14B-1..) 190-435</td> </tr> <tr> <td>33</td> <td>THERM 19= HOT STDBY: (14B-2) 435-190</td> </tr> <tr> <td>34</td> <td>THERM 20= SHUT-DOWN INITIATN: (15B-1) 435-156</td> </tr> <tr> <td>35</td> <td>THERM 21= SHUT-DOWN INITITN:{UP} (15B-2) 156-395</td> </tr> <tr> <td>36</td> <td>THERM 22= VESSEL FLOODING: (16A-1) 70-157</td> </tr> <tr> <td>37</td> <td>THERM 23= VESSEL FLOODING: (16A-3..) 167-108</td> </tr> <tr> <td>38</td> <td>THERM 24= VESSEL FLOODING: (16A-4..) 108-167</td> </tr> <tr> <td>39</td> <td>THERM 25= VESSEL FLOODING: (16B-1+2) 149-66-152</td> </tr> <tr> <td>40</td> <td>THERM 26= SHUT-DOWN, UNBOLT: (17A..) 167-100</td> </tr> </tbody> </table>				<u>LOAD CASE</u>	<u>DESCRIPTION</u>	<u>NUMBER</u>	<u>DESCRIPTION</u>		Normal/upset condition (Run 004)	1	FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)	2	OBEI= OBE INERTIA.....GROUPING BY STD SRSS	3	SSEI= SSE INERTIA.....GROUPING BY STD SRSS	4	SRV (1V,2V,SRVCO2V).....GROUPING BY STD SRSS	5	SRV (16V,SRVCO16V).....GROUPING BY STD SRSS	6	COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS	7	PS= POOL SWELL.....GROUPING BY STD SRSS	8	APMSB= ANNULUS PRESSURIZATION M.S.B... GROUPING BY STD SRSS	9	APRCB= ANNULUS PRESSURIZATION R.C.B....GROUPING BY STD SRSS	10	APFWB= ANNULUS PRESSURIZATION P.W.B....GROUPING BY STD SRSS	11	DL= DEADWEIGHT ANALYSIS: TLOAD=3,(FOSH = COLDSET LOAD)	12	X-DIR OBE ANCHOR MVMTS	13	Y-DIR OBE ANCHOR MVMTS	14	Z-DIR OBE ANCHOR MVMTS	15	THERM 1= NORMAL OPERATING: (12) PPG @ 420/420/420 F RPV @ 552/528/528	16	THERM 2= TURB ROLL COLD: (4A-1..) PPG @ 70/70/70 F RPV @ 552/552/450	17	THERM 3= BOLT-UP,LEAK TEST: (3A-1..) 70-100	18	THERM 4= HYDROTEST: (2A) 100-180-100	19	THERM 5= START-UP:{UP} (3A-2..) 100-486	20	THERM 6= START-UP:{UP} (3B-2) 100-486	21	THERM 7= TURB ROLL: (4A-2..) 70-325	22	THERM 8= TURB ROLL: (4B-1+2) 180-70-325	23	THERM 9= TURB ROLL: (4A-3..) 325-420	24	THERM 10= DAILY PWR REDCTN : (5-1+2..) 420-354	25	THERM 11= DAILY PWR INCR : (5-3..) 354-420	26	THERM 12= WEEKLY PWR REDCTN : (6-1+2) 420-326	27	THERM 13= FW HTR LOSS: (9-1+2) 420-352	28	THERM 14= FW HTR RESTORTN: (9-3) 352-420	29	THERM 15= SCRAMS: (22-1+2..) 420-275	30	THERM 16= PWR REDUCTN: (13) 420-190	31	THERM 17= HOT STDBY: (14A) 190-70	32	THERM 18= HOT STDBY: (14B-1..) 190-435	33	THERM 19= HOT STDBY: (14B-2) 435-190	34	THERM 20= SHUT-DOWN INITIATN: (15B-1) 435-156	35	THERM 21= SHUT-DOWN INITITN:{UP} (15B-2) 156-395	36	THERM 22= VESSEL FLOODING: (16A-1) 70-157	37	THERM 23= VESSEL FLOODING: (16A-3..) 167-108	38	THERM 24= VESSEL FLOODING: (16A-4..) 108-167	39	THERM 25= VESSEL FLOODING: (16B-1+2) 149-66-152	40	THERM 26= SHUT-DOWN, UNBOLT: (17A..) 167-100
<u>LOAD CASE</u>	<u>DESCRIPTION</u>																																																																																									
<u>NUMBER</u>	<u>DESCRIPTION</u>																																																																																									
	Normal/upset condition (Run 004)																																																																																									
1	FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)																																																																																									
2	OBEI= OBE INERTIA.....GROUPING BY STD SRSS																																																																																									
3	SSEI= SSE INERTIA.....GROUPING BY STD SRSS																																																																																									
4	SRV (1V,2V,SRVCO2V).....GROUPING BY STD SRSS																																																																																									
5	SRV (16V,SRVCO16V).....GROUPING BY STD SRSS																																																																																									
6	COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS																																																																																									
7	PS= POOL SWELL.....GROUPING BY STD SRSS																																																																																									
8	APMSB= ANNULUS PRESSURIZATION M.S.B... GROUPING BY STD SRSS																																																																																									
9	APRCB= ANNULUS PRESSURIZATION R.C.B....GROUPING BY STD SRSS																																																																																									
10	APFWB= ANNULUS PRESSURIZATION P.W.B....GROUPING BY STD SRSS																																																																																									
11	DL= DEADWEIGHT ANALYSIS: TLOAD=3,(FOSH = COLDSET LOAD)																																																																																									
12	X-DIR OBE ANCHOR MVMTS																																																																																									
13	Y-DIR OBE ANCHOR MVMTS																																																																																									
14	Z-DIR OBE ANCHOR MVMTS																																																																																									
15	THERM 1= NORMAL OPERATING: (12) PPG @ 420/420/420 F RPV @ 552/528/528																																																																																									
16	THERM 2= TURB ROLL COLD: (4A-1..) PPG @ 70/70/70 F RPV @ 552/552/450																																																																																									
17	THERM 3= BOLT-UP,LEAK TEST: (3A-1..) 70-100																																																																																									
18	THERM 4= HYDROTEST: (2A) 100-180-100																																																																																									
19	THERM 5= START-UP:{UP} (3A-2..) 100-486																																																																																									
20	THERM 6= START-UP:{UP} (3B-2) 100-486																																																																																									
21	THERM 7= TURB ROLL: (4A-2..) 70-325																																																																																									
22	THERM 8= TURB ROLL: (4B-1+2) 180-70-325																																																																																									
23	THERM 9= TURB ROLL: (4A-3..) 325-420																																																																																									
24	THERM 10= DAILY PWR REDCTN : (5-1+2..) 420-354																																																																																									
25	THERM 11= DAILY PWR INCR : (5-3..) 354-420																																																																																									
26	THERM 12= WEEKLY PWR REDCTN : (6-1+2) 420-326																																																																																									
27	THERM 13= FW HTR LOSS: (9-1+2) 420-352																																																																																									
28	THERM 14= FW HTR RESTORTN: (9-3) 352-420																																																																																									
29	THERM 15= SCRAMS: (22-1+2..) 420-275																																																																																									
30	THERM 16= PWR REDUCTN: (13) 420-190																																																																																									
31	THERM 17= HOT STDBY: (14A) 190-70																																																																																									
32	THERM 18= HOT STDBY: (14B-1..) 190-435																																																																																									
33	THERM 19= HOT STDBY: (14B-2) 435-190																																																																																									
34	THERM 20= SHUT-DOWN INITIATN: (15B-1) 435-156																																																																																									
35	THERM 21= SHUT-DOWN INITITN:{UP} (15B-2) 156-395																																																																																									
36	THERM 22= VESSEL FLOODING: (16A-1) 70-157																																																																																									
37	THERM 23= VESSEL FLOODING: (16A-3..) 167-108																																																																																									
38	THERM 24= VESSEL FLOODING: (16A-4..) 108-167																																																																																									
39	THERM 25= VESSEL FLOODING: (16B-1+2) 149-66-152																																																																																									
40	THERM 26= SHUT-DOWN, UNBOLT: (17A..) 167-100																																																																																									

Original Load Cases Table from AX-017D, pg. 2:

STONE & WEBSTER ENGINEERING CORPORATION

CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>164</u>
JO. OR WO. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE	
REF.				
	5.0 <u>LOADING CONDITIONS ANALYZED</u> (CONT'D)			
	5.1 <u>DESCRIPTION FOR LOAD CASES</u>			
	<u>LOAD CASE NUMBER</u>	<u>DESCRIPTION</u>		
	41	THERM 27= LOSS OF FW PUMP:{UP} (20-1..) 420-573-485		
	42	THERM 28= PIPE RUPTURE: (27-1+2) 420-259-70		
	43	THERM 29= START-UP:{DN} (3A-3..) 486-70		
	44	THERM 30= START-UP:{DN} (3B-3) 486-180		
	45	THERM 31= SHUT-DOWN INITIATN:{DN} (15B-3) 395-149		
	46	THERM 32= LOSS OF FWP:{DN} (20-13+14) 485-70		
	47	THERM 33= TMODE 2 WITH P=0 PSI		
	48	THERM 34= TMODE 15 WITH P=1516 PSI		
	49	THERM 35= TMODE 15 WITH P=1175 PSI		
	50	X+Y DIR. OBE ANCHOR MVMTS.....CASES 12+13 BY SRSS		
	51	OBEA= X+Y+Z EARTHQUAKE ANCHOR MVMTS....CASES 12+13+14 BY SRSS		
	52	SRV= (SRV MAX).....CASES 4+5 BY MAXIMUM VALUE		
	53	SRSS(SRV,FT).....CASES 52+1 BY SRSS		
	54	SRSS(OBEI,OCU)= SRSS(OBEI,SRV,FT)...CASES 2+52+1 BY SRSS		
	55	OBEI= ABS(OBEI + OBEA).....CASES 2+51 BY ABS. SUM		
	56	SRSS(OBEI,OCU)= SRSS(ABS(OBEI+OBEA),SRV,FT)..CASES55+53 BY SRSS		
	57	SRSS(OBEI,FT).....CASES 1+2 BY SRSS (FOR 9CN CARD ONLY)		
	58	FT= FLUID TRANSIENT TIME HISTORY(3 PUMP-TRIP)....(FOR SUMMARY ONLY)		
	59	OBEI= OBE INERTIA (CASE REPEATED FOR SUMMARY ONLY)		
	60	SRV(1V,2V,SRVCO2V).....(CASE REPEATED FOR 9N CARD ONLY)		
	61	SRV(16V.SRVCO16V)..... (CASE REPEATED FOR 9N CARD ONLY)		
		(RUN 007)		
	1	SETTLE1 = BLDG. SETTLEMENT ... REACTOR BLDG. SETTLES DOWN BY .66"		
	2	SETTLE2 = BLDG. SETTLEMENT ... AUX. BLDG. SETTLES DOWN BY .18"		

Original Load Cases (Emergency/Faulted) Table from AX-017D

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>165</u>																																																				
JO. OR WO. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE																																																					
REF.																																																								
	5.0 <u>LOADING CONDITIONS ANALYZED</u> (CONT'D)																																																							
	5.1 <u>DESCRIPTION FOR LOAD CASES</u>																																																							
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; width: 20%;"><u>LOAD CASE NUMBER</u></th> <th style="text-align: left;"><u>DESCRIPTION</u></th> </tr> </thead> <tbody> <tr> <td></td> <td>EMERGENCY & FAULTED CONDITIONS (RUN 005)</td> </tr> <tr> <td>1</td> <td>FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)</td> </tr> <tr> <td>2</td> <td>OBEI= OBE INERTIA.....GROUPING BY STD SRSS</td> </tr> <tr> <td>3</td> <td>SSEI= SSE INERTIA.....GROUPING BY STD SRSS</td> </tr> <tr> <td>4</td> <td>SRV (1V,ZV,SRVCO2V).....GROUPING BY STD SRSS</td> </tr> <tr> <td>5</td> <td>SRV (16V,SRVCO16V).....GROUPING BY STD SRSS</td> </tr> <tr> <td>6</td> <td>COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS</td> </tr> <tr> <td>7</td> <td>PS= POOL SHELL.....GROUPING BY STD SRSS</td> </tr> <tr> <td>8</td> <td>APHSB= ANNULUS PRESSURIZATION H.S.B... GROUPING BY STD SRSS</td> </tr> <tr> <td>9</td> <td>APRCB= ANNULUS PRESSURIZATION R.C.B...GROUPING BY STD SRSS</td> </tr> <tr> <td>10</td> <td>APFHB= ANNULUS PRESSURIZATION F.H.B...GROUPING BY STD SRSS</td> </tr> <tr> <td>11</td> <td>DL= DEADHEIGHT ANALYSIS: TLOAD=3,(P0SH = COLDSET LOAD)</td> </tr> <tr> <td>12</td> <td>SRV= (SRV MAX).....CASES 4+5 BY MAXIMUM VALUE</td> </tr> <tr> <td>13</td> <td>SRSS(SRV,FT).....CASES 12+1 BY SRSS</td> </tr> <tr> <td>14</td> <td>SRSS(OBEI,SRV,FT).....CASES 2+12+1 BY SRSS</td> </tr> <tr> <td>15</td> <td>SRSS(OBEI,OCCE)=SRSS(OBEI,SRV,FT,COCH).....CASES 2+12+1+6 BY SRSS</td> </tr> <tr> <td>16</td> <td>SRSS(SSEI,SRV,FT).....CASES 3+12+1 BY SRSS</td> </tr> <tr> <td>17</td> <td>MAX(COCH,PS).....CASES 6+7 BY MAX VALUE</td> </tr> <tr> <td>18</td> <td>MAX(APHSB,APRCB).....CASES 8+9 BY MAX VALUE</td> </tr> <tr> <td>19</td> <td>AP= ANNULUS PRESS:MAX AP(HSB,RCB,FHB)...CASES 8+9+10 BY MAX VALUE</td> </tr> <tr> <td>20</td> <td>SRSS(SSEI,FT).....CASES 3+1 BY SRSS</td> </tr> <tr> <td>21</td> <td>SRSS(SSEI,OCCE1)=SRSS(SSEI,SRV,FT,MAX(COCH,PS))..CASES 3+12+1+17 BY SRSS</td> </tr> <tr> <td>22</td> <td>SRSS(SSEI,OCCE2)=SRSS(SSEI,FT,AP).....CASES 3+1+19 BY SRSS</td> </tr> <tr> <td>23</td> <td>SSEI= SSE INERTIA.....(CASE REPEATED FOR SUMMARY ONLY)</td> </tr> <tr> <td>24</td> <td>COCH= CONDENS.OSCILL & CHUGGING...(CASE REPEATED FOR SUMMARY ONLY)</td> </tr> </tbody> </table>				<u>LOAD CASE NUMBER</u>	<u>DESCRIPTION</u>		EMERGENCY & FAULTED CONDITIONS (RUN 005)	1	FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)	2	OBEI= OBE INERTIA.....GROUPING BY STD SRSS	3	SSEI= SSE INERTIA.....GROUPING BY STD SRSS	4	SRV (1V,ZV,SRVCO2V).....GROUPING BY STD SRSS	5	SRV (16V,SRVCO16V).....GROUPING BY STD SRSS	6	COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS	7	PS= POOL SHELL.....GROUPING BY STD SRSS	8	APHSB= ANNULUS PRESSURIZATION H.S.B... GROUPING BY STD SRSS	9	APRCB= ANNULUS PRESSURIZATION R.C.B...GROUPING BY STD SRSS	10	APFHB= ANNULUS PRESSURIZATION F.H.B...GROUPING BY STD SRSS	11	DL= DEADHEIGHT ANALYSIS: TLOAD=3,(P0SH = COLDSET LOAD)	12	SRV= (SRV MAX).....CASES 4+5 BY MAXIMUM VALUE	13	SRSS(SRV,FT).....CASES 12+1 BY SRSS	14	SRSS(OBEI,SRV,FT).....CASES 2+12+1 BY SRSS	15	SRSS(OBEI,OCCE)=SRSS(OBEI,SRV,FT,COCH).....CASES 2+12+1+6 BY SRSS	16	SRSS(SSEI,SRV,FT).....CASES 3+12+1 BY SRSS	17	MAX(COCH,PS).....CASES 6+7 BY MAX VALUE	18	MAX(APHSB,APRCB).....CASES 8+9 BY MAX VALUE	19	AP= ANNULUS PRESS:MAX AP(HSB,RCB,FHB)...CASES 8+9+10 BY MAX VALUE	20	SRSS(SSEI,FT).....CASES 3+1 BY SRSS	21	SRSS(SSEI,OCCE1)=SRSS(SSEI,SRV,FT,MAX(COCH,PS))..CASES 3+12+1+17 BY SRSS	22	SRSS(SSEI,OCCE2)=SRSS(SSEI,FT,AP).....CASES 3+1+19 BY SRSS	23	SSEI= SSE INERTIA.....(CASE REPEATED FOR SUMMARY ONLY)	24	COCH= CONDENS.OSCILL & CHUGGING...(CASE REPEATED FOR SUMMARY ONLY)
<u>LOAD CASE NUMBER</u>	<u>DESCRIPTION</u>																																																							
	EMERGENCY & FAULTED CONDITIONS (RUN 005)																																																							
1	FT= FLUID TRANSIENT TIME HISTORY (3-PUMP-TRIP)																																																							
2	OBEI= OBE INERTIA.....GROUPING BY STD SRSS																																																							
3	SSEI= SSE INERTIA.....GROUPING BY STD SRSS																																																							
4	SRV (1V,ZV,SRVCO2V).....GROUPING BY STD SRSS																																																							
5	SRV (16V,SRVCO16V).....GROUPING BY STD SRSS																																																							
6	COCH= CONDENS.OSCILL & CHUGGING.....GROUPING BY STD SRSS																																																							
7	PS= POOL SHELL.....GROUPING BY STD SRSS																																																							
8	APHSB= ANNULUS PRESSURIZATION H.S.B... GROUPING BY STD SRSS																																																							
9	APRCB= ANNULUS PRESSURIZATION R.C.B...GROUPING BY STD SRSS																																																							
10	APFHB= ANNULUS PRESSURIZATION F.H.B...GROUPING BY STD SRSS																																																							
11	DL= DEADHEIGHT ANALYSIS: TLOAD=3,(P0SH = COLDSET LOAD)																																																							
12	SRV= (SRV MAX).....CASES 4+5 BY MAXIMUM VALUE																																																							
13	SRSS(SRV,FT).....CASES 12+1 BY SRSS																																																							
14	SRSS(OBEI,SRV,FT).....CASES 2+12+1 BY SRSS																																																							
15	SRSS(OBEI,OCCE)=SRSS(OBEI,SRV,FT,COCH).....CASES 2+12+1+6 BY SRSS																																																							
16	SRSS(SSEI,SRV,FT).....CASES 3+12+1 BY SRSS																																																							
17	MAX(COCH,PS).....CASES 6+7 BY MAX VALUE																																																							
18	MAX(APHSB,APRCB).....CASES 8+9 BY MAX VALUE																																																							
19	AP= ANNULUS PRESS:MAX AP(HSB,RCB,FHB)...CASES 8+9+10 BY MAX VALUE																																																							
20	SRSS(SSEI,FT).....CASES 3+1 BY SRSS																																																							
21	SRSS(SSEI,OCCE1)=SRSS(SSEI,SRV,FT,MAX(COCH,PS))..CASES 3+12+1+17 BY SRSS																																																							
22	SRSS(SSEI,OCCE2)=SRSS(SSEI,FT,AP).....CASES 3+1+19 BY SRSS																																																							
23	SSEI= SSE INERTIA.....(CASE REPEATED FOR SUMMARY ONLY)																																																							
24	COCH= CONDENS.OSCILL & CHUGGING...(CASE REPEATED FOR SUMMARY ONLY)																																																							

Original Thermal Modes Table from AX-017D

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE 166
JC. OR WO. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE	
REF.	5.0 <u>LOADING CONDITIONS ANALYZED (CONT'D)</u>			
	5.2 <u>DESCRIPTION FOR THERMAL MODES</u>			
	<u>MODE NUMBER</u>	<u>DESCRIPTION</u>		
	1	THERM 1= NORMAL OPERATING: (12) PPG @ 420/420/420 F RPV @ 552/528/528		
	2	THERM 2= TURB ROLL COLD: (4A-1..) PPG @ 70/70/70 F RPV @ 552/552/450		
	3	THERM 3= BOLT-UP, LEAK TEST: (3A-1..) 70-100		
	4	THERM 4= HYDROTEST: (2A) 100-180-100		
	5	THERM 5= START-UP:{UP} (3A-2..) 100-486		
	6	THERM 6= START-UP:{UP} (3B-2) 100-486		
	7	THERM 7= TURB ROLL: (4A-2..) 70-325		
	8	THERM 8= TURB ROLL: (4B-1+2) 180-70-325		
	9	THERM 9= TURB ROLL: (4A-3..) 325-420		
	10	THERM 10= DAILY PWR REDCTN : (5-1+2..) 420-354		
	11	THERM 11= DAILY PWR INCR : (5-3..) 354-420		
	12	THERM 12= WEEKLY PWR REDCTN : (6-1+2) 420-326		
	13	THERM 13= FW HTR LOSS: (9-1+2) 420-352		
	14	THERM 14= FW HTR RESTORTN: (9-3) 352-420		
	15	THERM 15= SCRAMS: (22-1+2..) 420-275		
	16	THERM 16= PWR REDUCTN: (13) 420-190		
	17	THERM 17= HOT STDBY: (14A) 190-70		
	18	THERM 18= HOT STDBY: (14B-1..) 190-435		
	19	THERM 19= HOT STDBY: (14B-2) 435-190		
	20	THERM 20= SHUT-DOWN INITIATN: (15B-1) 435-156		
	21	THERM 21= SHUT-DOWN INITITN:{UP} (15B-2) 156-395		
	22	THERM 22= VESSEL FLOODING: (16A-1) 70-157		
	23	THERM 23= VESSEL FLOODING: (16A-3..) 167-108		
	24	THERM 24= VESSEL FLOODING: (16A-4..) 108-167		
	25	THERM 25= VESSEL FLOODING: (16B-1+2) 149-66-152		
	26	THERM 26= SHUT-DOWN, UNBOLT: (17A..) 167-100		
	27	THERM 27= LOSS OF FW PUMP:{UP} (20-1..) 420-573-485		
	28	THERM 28= PIPE RUPTURE: (27-1+2) 420-259-70		
	29	THERM 29= START-UP:{DN} (3A-3..) 486-70		
	30	THERM 30= START-UP:{DN} (3B-3) 486-180		
	31	THERM 31= SHUT-DOWN INITITN:{DN} (15B-3) 395-149		
	32	THERM 32= LOSS OF FWP:{DN} (20-13+14) 485-70		
	33	THERM 33= TMODE 2 WITH P=0 PSI		
	34	THERM 34= TMODE 15 WITH P=1516 PSI		
	35	THERM 35= TMODE 15 WITH P=1175 PSI		

RBG-47895

Attachment 2

Thermal Transient Loss of Feed Water Pumps Aux Power Trip without Bypass and
Reactor Core Isolation Cooling (RCIC) Injection AX-17D Rev 3K


Thermal Transient Loss of FW Pumps Aux Power Trip without Bypass and RCIC injection.

AX-17D REV. 3K PAGE 10

PICLCN 17-01

PICL AP-17

ATTACHMENT A, PAGE 127a



NOTE:
FLOW IS RCIC INJ. WATER AND EXISTS ONLY
DOWNSTREAM OF LINE RHS-010-65-2 IN
FEEDW. LOOP A.

THERMAL TRANSIENTS
FEEDWATER SYSTEM (FWS)
12210-SK-TRI7-A-2

RBG-47895

Attachment 3

Cumulative Usage Factor (CUF) Summaries AX-17D Rev 3, Addendum 3J, and
Addendum 3K

Original CUF from Calc Rev. 3

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>226</u>		
JO. OR WO. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE			
REF.	<p>9.0 <u>SUMMARY OF RESULTS (CONT'D)</u></p> <p>9.5 <u>CUMULATIVE USAGE FACTOR (CUF)</u></p> <p>9.5.1 <u>CUF FOR OTHER THAN BREAK EXCLUSION AREAS</u> Selected Points: ELB & CUF >.02</p> <p style="margin-left: 40px;">Allowable CUF = 1.0 (Ref. 1 NB-3600)</p>					
	Node Point	Type of Element	Equation 12 (Ref. 1)	Equation 13 (Ref. 1)	CUF	Remarks
	4	ELB	30043	24156	.0212	
	10	ELB	26592	22726	.0144	
	45	ELB	27084	26309	.0185	
	70	ELB	4271	21321	.0048	
	80	GRUN	1953	20547	.0178	
	83	GRUN	13062	19698	.0268	
	85	GELB	46162	22499	.5908	
	86	GELB	46620	21932	.5378	
	87	GELB	43990	22566	.3598	
	88	GRUN	18905	21862	.0370	
	95	GRUN	11783	22970	.0216	
	97	GRUN	18783	21000	.0390	
	98	GRUN	46688	21895	.0641	
	100	ELB	47850	19386	.0603	
	105	ELB	40465	19118	.0342	
	106	GRUN	38522	21718	.0336	
	109	GRUN	25187	25151	.0173	

Original CUF from Calc Rev. 3 pg. 3

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>228</u>		
JO. OR WD. NO. 12210	DIVISION & GROUP NP(C)	CALCULATION NO. AX-17D-4	OPTIONAL TASK CODE			
REF.	<p>9.0 <u>SUMMARY OF RESULTS</u> (CONT'D)</p> <p>9.5 <u>CUMULATIVE USAGE FACTOR (CUF)</u></p> <p>9.5.2 <u>CUF FOR BREAK EXCLUSION AREAS</u></p> <p style="padding-left: 40px;">Allowable CUF = 0.1 (Ref. 1 NB-3600)</p>					
	Node Point	Type of Element	Equation 12 (Ref. 1)	Equation 13 (Ref. 1)	CUF	Remarks
	150	ELB	13888	18042	.0095	
	152	GRUN	8474	16886	.0213	
	153	GRUN	8255	16503	.0202	
	155	GRUN _(HAND)	8703	22108	.0418	
	159	GRUN _(HAND)	6859	21232	.0752	
	161	GRUN	6611	17146	.0572	
	162	GRUN	6037	15432	.0374	
	163	GRUN	3956	11738	.0294	
	171	GRUN	1481	13385	.0386	
	173	GRUN	899	9251	.0291	
	202	GRUN	1312	18507	.0761	
	205	GRUN _(HAND)	1307	27326	.0911	← See p. 271-272
	215	GRUN _(HAND)	1250	24542	.0514	
	280	FIN	1583	17525	.0040	

Load Combinations for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

07/17/96 HT5513 PAGE 8

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ. 11 AT LOCATION 82 (TEE)

LOAD SET NO.	LOAD SET DESCRIPTION	NO. OF CYCLES	P	LEG	X *	Y *	Z *	DT1	DT2	TA	TB
1	1 DWT, DYNITL*2	45	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
2	2 DWT, SRVFT*2	45	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
3	3 DWT, SRV*2	7875	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
4	4 P, THMD28, DYNITL	1	.020	RUN	.0	221.6	18.1	-66.0	-14.0	70.0	104.0
				RUN	.0	.0	.0				
				BRA	413.2	432.2	-131.8				
5	5 P, THMD15, DYNITL	4	.020	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
6	6 P, THMD15, SRVFT	5	.020	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
7	7 P, THMD15, SRV16V	191	.020	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
8	8 P, THMD34, SRV16V	1	1.516	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
9	9 P, THMD35, SRV16V	98	1.175	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
10	10 P, THMD35, SRV1V	92	1.175	RUN	.0	530.0	50.0	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
11	11 P, THMD32, SRV1V	10	.120	RUN	.0	530.0	50.0	-16.0	-2.0	70.0	95.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
12	12 P, THMD31, SRV1V	15	.200	RUN	.0	418.7	39.5	-40.0	-6.0	70.0	90.0
				RUN	.0	.0	.0				
				BRA	709.3	865.4	-241.9				
13	13 P, THMD23, SRV1V	126	.050	RUN	.0	113.6	9.3	-20.0	-3.0	70.0	77.0
				RUN	.0	.0	.0				
				BRA	211.9	221.6	-67.6				
14	14 P, THMD29, SRV1V	106	1.100	RUN	.0	530.0	50.0	.0	.0	70.0	70.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				

TABLE CONTINUED

Load Combinations for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3J pg. 2

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

07/17/96 HT5513 PAGE 9

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ. 11 AT LOCATION 82 (TEB)

LOAD SET NO.	LOAD SET DESCRIPTION	NO. OF CYCLES	P	LEG	X	Y	Z	DT1	DT2	TA	TB
15	15 P, THMD26, SRV1V	249	.000	RUN	.0	122.7	10.0	-1.0	.0	70.0	71.0
				RUN	.0	.0	.0				
				BRA	228.8	239.4	-73.0				
16	16 P, THMD20, SRV1V	15	.700	RUN	.0	445.2	42.0	-49.0	-7.0	70.0	97.0
				RUN	.0	.0	.0				
				BRA	754.2	920.2	-257.2				
17	17 P, THMD04, SRV1V	40	1.250	RUN	.0	74.1	22.3	.0	.0	180.0	180.0
				RUN	.0	.0	.0				
				BRA	29.6	162.6	-19.7				
18	18 P, THMD02, SRV1V	442	1.100	RUN	.0	530.0	50.0	.0	.0	70.0	70.0
				RUN	.0	.0	.0				
				BRA	897.8	1095.5	-306.2				
19	19 P, THMD07	307	1.100	RUN	.0	371.2	114.3	57.0	8.0	97.0	70.0
				RUN	.0	.0	.0				
				BRA	75.1	864.4	-92.2				
20	20 P, THMD22	96	.050	RUN	.0	109.1	8.9	28.0	4.0	80.0	70.0
				RUN	.0	.0	.0				
				BRA	203.4	212.8	-64.9				
21	21 P, THMD08	15	1.100	RUN	.0	371.2	114.3	55.0	8.0	90.0	70.0
				RUN	.0	.0	.0				
				BRA	75.1	864.4	-92.2				
22	22 P, THMD14	70	1.100	RUN	.0	31.6	140.9	27.0	4.0	81.0	70.0
				RUN	.0	.0	.0				
				BRA	-270.3	767.9	-2.7				
23	23 P, THMD11	9999	1.100	RUN	.0	31.6	140.9	2.0	.0	71.0	70.0
				RUN	.0	.0	.0				
				BRA	-270.3	767.9	-2.7				
24	24 P, THMD18	30	1.050	RUN	.0	30.7	136.6	22.0	3.0	91.0	70.0
				RUN	.0	.0	.0				
				BRA	-262.2	744.9	-2.6				
25	25 P, THMD21	15	.700	RUN	.0	28.5	126.8	26.0	4.0	92.0	70.0
				RUN	.0	.0	.0				
				BRA	-243.3	691.1	-2.5				
26	26 P, THMD27	10	1.335	RUN	.0	.0	.1	3.0	1.0	70.0	70.0
				RUN	.0	.0	.0				
				BRA	-312.1	800.4	-4.2				
27	27 P, THMD24	207	.050	RUN	.0	79.7	23.9	20.0	3.0	77.0	70.0
				RUN	.0	.0	.0				
				BRA	31.8	174.8	-21.2				

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSYS

ME101/M4 RB/562367

07/17/96 HT5513 PAGE 13

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 82 (TEE)

LOAD PAIR:	EQ.11		EQ.14	OCCURENCE		SET	CYCLES LEFT	ALLOW.	FATIGUE	
I : J	S-P	K-E	SP*KE/2	N-I	N-J	BLIM- INATED:	N-I	N-J	N-D	USAGE FACTOR
5 : 17	110.618	1.278	70.688	4	40	4 : 5, 5	0	36	1560	.0026
8 : 27	114.409	1.117	63.908	1	207	1 : 8, 8	0	206	2116	.0005
6 : 17	105.304	1.099	57.861	5	36	5 : 6, 6	0	31	2872	.0017
7 : 17	104.913	1.086	56.954	191	31	31 : 17, 17	160	0	3015	.0103
4 : 19	102.164	1.055	53.886	1	307	1 : 4, 4	0	306	3575	.0003
7 : 26	103.322	1.000	51.661	160	10	10 : 26, 26	150	0	4070	.0025
9 : 27	99.310	1.000	49.655	98	206	98 : 9, 9	0	108	4589	.0214
7 : 22	97.888	1.000	48.944	150	70	70 : 22, 22	80	0	4782	.0146
10 : 27	97.096	1.000	48.548	92	108	92 : 10, 10	0	16	4894	.0188
7 : 19	96.828	1.000	48.414	80	306	80 : 7, 7	0	226	4932	.0162
11 : 19	84.396	1.000	42.198	10	226	10 : 11, 11	0	216	7297	.0014
13 : 18	83.494	1.000	41.747	126	442	126 : 13, 13	0	316	7524	.0167
18 : 27	81.278	1.000	40.639	316	16	16 : 27, 27	300	0	8124	.0020
15 : 18	81.176	1.000	40.588	249	300	249 : 15, 15	0	51	8153	.0305
18 : 20	80.354	1.000	40.177	51	96	51 : 18, 18	0	45	8393	.0061
14 : 20	80.354	1.000	40.177	106	45	45 : 20, 20	61	0	8393	.0054
12 : 19	78.891	1.000	39.445	15	216	15 : 12, 12	0	201	8860	.0017
16 : 19	60.394	1.000	30.197	15	201	15 : 16, 16	0	186	19614	.0008
14 : 25	54.973	1.000	27.487	61	15	15 : 25, 25	46	0	28304	.0005
14 : 24	38.532	1.000	19.266	46	30	30 : 24, 24	16	0	118363	.0003
14 : 19	34.341	1.000	17.171	16	186	16 : 14, 14	0	170	198889	.0001
1 : 1	27.725	1.000	13.863	45	45	45 : 1, 1	0	0	521826	.0001
19 : 23	21.741	1.000	10.870	170	9999	170 : 19, 19	0	9829	>1.E6	0
21 : 23	20.312	1.000	10.156	15	9829	15 : 21, 21	0	9814	>1.E6	0
2 : 2	16.195	1.000	8.097	45	45	45 : 2, 2	0	0	>1.E6	0
3 : 3	15.242	1.000	7.621	7875	7875	7875 : 3, 3	0	0	>1.E6	0
TOTAL USAGE FACTOR=										.1543

Load Combinations for location 85 (Break Point 71W) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

07/17/96 HT5513 PAGE 14

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ.11 AT LOCATION 85 (CURB)

LOAD SET NO.	LOAD SET DESCRIPTION	NO. OF CYCLES	P	X *	Y *	Z *	DT1	DT2	TA	TB
1	1 DWT, DYNITL*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0
2	2 DWT, SRVFT*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0
3	3 DWT, SRV*2	7875	.000	.0	.0	.0	.0	.0	420.0	420.0
4	4 P, THMD28, DYNITL	1	.020	413.2	-48.0	-139.8	-57.0	-10.0	70.0	70.0
5	5 P, THMD15, DYNITL	4	.020	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
6	6 P, THMD15, SRVFT	5	.020	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
7	7 P, THMD15, SRV16V	191	.020	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
8	8 P, THMD34, SRV16V	1	1.516	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
9	9 P, THMD35, SRV16V	98	1.175	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
10	10 P, THMD35, SRV1V	92	1.175	897.8	-118.4	-411.6	-36.0	-5.0	70.0	70.0
11	11 P, THMD32, SRV1V	10	.120	897.8	-118.4	-411.6	-12.0	-2.0	70.0	70.0
12	12 P, THMD31, SRV1V	15	.200	709.3	-93.6	-325.2	-30.0	-4.0	70.0	70.0
13	13 P, THMD23, SRV1V	126	.050	211.9	-24.6	-71.7	-13.0	-2.0	70.0	70.0
14	14 P, THMD29, SRV1V	106	1.100	897.8	-118.4	-411.6	.0	.0	70.0	70.0
15	15 P, THMD26, SRV1V	249	.000	228.8	-26.6	-77.4	-3.0	.0	70.0	70.0
16	16 P, THMD20, SRV1V	15	.700	754.2	-99.5	-345.8	-36.0	-5.0	70.0	70.0
17	17 P, THMD04, SRV1V	40	1.250	29.6	-8.6	-88.8	.0	.0	180.0	180.0
18	18 P, THMD02, SRV1V	442	1.100	897.8	-118.4	-411.6	.0	.0	70.0	70.0
19	19 P, THMD07	307	1.100	75.1	-46.3	-505.0	31.0	4.0	70.0	70.0
20	20 P, THMD22	96	.050	203.4	-23.7	-68.8	19.0	3.0	70.0	70.0
21	21 P, THMD08	15	1.100	75.1	-46.3	-505.0	31.0	4.0	70.0	70.0
22	22 P, THMD14	70	1.100	-270.3	-16.6	-546.5	15.0	2.0	70.0	70.0
23	23 P, THMD11	9999	1.100	-270.3	-16.6	-546.5	1.0	.0	70.0	70.0
24	24 P, THMD18	30	1.050	-262.2	-16.1	-530.1	16.0	2.0	70.0	70.0
25	25 P, THMD21	15	.700	-243.3	-14.9	-491.9	17.0	3.0	70.0	70.0
26	26 P, THMD27	10	1.335	-312.1	-25.8	-597.5	3.0	.0	70.0	70.0
27	27 P, THMD24	207	.050	31.8	-9.3	-95.5	13.0	2.0	70.0	70.0

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 85 (Break Point 71 W) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

07/17/96 HT5513 PAGE 17

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 85 (CURB)

LOAD PAIR:		EQ.11		EQ.14	OCCURENCE			SET	CYCLES LEFT		ALLOW.	FATIGUE	
: I : J :		S-P	K-E	SP*KE/2	N-I	N-J	N	ELIM- INATED:	N-I	N-J	N-D	CYCLES : USAGE	FACTOR :
5	26	122.449	1.138	69.654	4	10	4	5, 5	0	6	1624	.0025	
6	26	106.705	1.000	53.353	5	6	5	6, 6	0	1	3686	.0014	
7	26	106.629	1.000	53.314	191	1	1	26,26	190	0	3694	.0003	
7	22	103.506	1.000	51.753	190	70	70	22,22	120	0	4047	.0173	
7	24	102.375	1.000	51.188	120	30	30	24,24	90	0	4186	.0072	
7	23	99.903	1.000	49.952	90	9999	90	7, 7	0	9909	4512	.0199	
4	23	99.293	1.000	49.646	1	9909	1	4, 4	0	9908	4591	.0002	
8	25	98.410	1.000	49.205	1	15	1	8, 8	0	14	4710	.0002	
9	25	93.735	1.000	46.868	98	14	14	25,25	84	0	5411	.0026	
11	23	91.062	1.000	45.531	10	9908	10	11,11	0	9898	5876	.0017	
9	27	89.750	1.000	44.875	84	207	84	9, 9	0	123	6124	.0137	
10	27	87.926	1.000	43.963	92	123	92	10,10	0	31	6493	.0142	
12	23	84.395	1.000	42.197	15	9898	15	12,12	0	9883	7298	.0021	
16	23	81.435	1.000	40.717	15	9883	15	16,16	0	9868	8080	.0019	
18	27	77.671	1.000	38.835	442	31	31	27,27	411	0	9280	.0033	
18	23	74.465	1.000	37.233	411	9868	411	18,18	0	9457	10520	.0391	
14	23	74.465	1.000	37.233	106	9457	106	14,14	0	9351	10520	.0101	
13	23	63.650	1.000	31.825	126	9351	126	13,13	0	9225	16778	.0075	
15	23	62.078	1.000	31.039	249	9225	249	15,15	0	8976	18073	.0138	
20	23	59.884	1.000	29.942	96	8976	96	20,20	0	8880	20154	.0048	
1	1	43.433	1.000	21.716	45	45	45	1, 1	0	0	72123	.0006	
17	23	40.325	1.000	20.162	40	8880	40	17,17	0	8840	96840	.0004	
21	23	28.791	1.000	14.396	15	8840	15	21,21	0	8825	440221	.0000	
19	23	28.791	1.000	14.396	307	8825	307	19,19	0	8518	440221	.0007	
2	2	15.333	1.000	7.667	45	45	45	2, 2	0	0	>1.E6	0	
3	3	14.855	1.000	7.427	7875	7875	7875	3, 3	0	0	>1.E6	0	
TOTAL USAGE FACTOR-												.1653	

Load Combinations for location 87 (Break Point 70W) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSYS

ME101/N4 RB/562367

07/17/96 HT5513 PAGE 18

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ.11 AT LOCATION 87 (CURE)

LOAD	NO. OF									
SET NO	LOAD SET DESCRIPTION	CYCLES	P	X *	Y *	Z *	DT1	DT2	TA	TB
1	1 DWT,DYNTTL*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0
2	2 DWT,SRVFT*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0
3	3 DWT,SRV*2	7875	.000	.0	.0	.0	.0	.0	420.0	420.0
4	4 P,THMD28,DYNTTL	1	.020	34.3	-317.9	-150.1	-46.0	-8.0	70.0	103.0
5	5 P,THMD15,DYNTTL	4	.020	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
6	6 P,THMD15,SRVFT	5	.020	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
7	7 P,THMD15,SRV16V	191	.020	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
8	8 P,THMD34,SRV16V	1	1.516	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
9	9 P,THMD35,SRV16V	98	1.175	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
10	10 P,THMD35,SRV1V	92	1.175	66.1	-649.7	-359.0	-21.0	-3.0	70.0	80.0
11	11 P,THMD32,SRV1V	10	.120	66.1	-649.7	-359.0	-9.0	-1.0	70.0	94.0
12	12 P,THMD31,SRV1V	15	.200	52.2	-513.3	-283.6	-21.0	-3.0	70.0	91.0
13	13 P,THMD23,SRV1V	126	.050	17.6	-163.0	-77.0	-8.0	-1.0	70.0	75.0
14	14 P,THMD29,SRV1V	106	1.100	66.1	-649.7	-359.0	.0	.0	70.0	70.0
15	15 P,THMD26,SRV1V	249	.000	19.0	-176.0	-83.1	.0	.0	70.0	70.0
16	16 P,THMD20,SRV1V	15	.700	55.5	-545.7	-301.6	-25.0	-4.0	70.0	94.0
17	17 P,THMD04,SRV1V	40	1.250	2.3	-2.0	-24.5	.0	.0	180.0	180.0
18	18 P,THMD02,SRV1V	442	1.100	66.1	-649.7	-359.0	.0	.0	70.0	70.0
19	19 P,THMD07	307	1.100	-1.3	76.7	-119.2	17.0	3.0	81.0	70.0
20	20 P,THMD22	96	.050	16.9	-156.5	-73.9	12.0	2.0	78.0	70.0
21	21 P,THMD08	15	1.100	-1.3	76.7	-119.2	17.0	3.0	81.0	70.0
22	22 P,THMD14	70	1.100	-30.2	383.9	-21.0	8.0	1.0	75.0	70.0
23	23 P,THMD11	9999	1.100	-30.2	383.9	-21.0	1.0	.0	70.0	70.0
24	24 P,THMD18	30	1.050	-29.3	372.4	-20.3	11.0	2.0	90.0	70.0
25	25 P,THMD21	15	.700	-27.2	345.5	-18.9	12.0	2.0	90.0	70.0
26	26 P,THMD27	10	1.335	-47.1	449.7	-38.4	2.0	.0	72.0	70.0
27	27 P,THMD24	207	.050	2.5	-2.1	-26.3	8.0	1.0	75.0	70.0

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 87 (Break Point 70W) Addendum 3J

CLASS 1 CODE COMPLIANCE ANALYSYS

MR101/N4 RB/562367

07/17/96 HT5513 PAGE 21

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 87 (CURE)

LOAD PAIR:	EQ.11	K-E	BQ.14	OCCURENCE	SET	CYCLES LEFT	ALLOW.	FATIGUE
I : J	S-P		SP*KE/2	N-I : N-J	ELIM- INATED:	N-I : N-J	CYCLES : N-D	USAGE : FACTOR :
5 : 26	116.448	1.032	60.069	4 : 10	4 : 5, 5	0 :	6 : 2560	.0016 :
6 : 24	107.363	1.000	53.681	5 : 30	5 : 6, 6	0 :	25 : 3617	.0014 :
7 : 24	107.052	1.000	53.526	191 : 25	25 : 24, 24	166 :	0 : 3649	.0068 :
7 : 26	106.937	1.000	53.469	166 : 6	6 : 26, 26	160 :	0 : 3661	.0016 :
8 : 25	103.054	1.000	51.527	1 : 15	1 : 8, 8	0 :	14 : 4102	.0002 :
7 : 22	102.808	1.000	51.404	160 : 70	70 : 22, 22	90 :	0 : 4132	.0169 :
7 : 25	101.398	1.000	50.699	90 : 14	14 : 25, 25	76 :	0 : 4312	.0032 :
7 : 23	99.464	1.000	49.732	76 : 9999	76 : 7, 7	0 :	9923 : 4569	.0166 :
4 : 23	97.942	1.000	48.971	1 : 9923	1 : 4, 4	0 :	9922 : 4774	.0002 :
11 : 23	97.159	1.000	48.580	10 : 9922	10 : 11, 11	0 :	9912 : 4885	.0020 :
12 : 23	88.400	1.000	44.200	15 : 9912	15 : 12, 12	0 :	9897 : 6394	.0023 :
9 : 23	87.226	1.000	43.613	98 : 9897	98 : 9, 9	0 :	9799 : 6643	.0148 :
16 : 23	86.759	1.000	43.379	15 : 9799	15 : 16, 16	0 :	9784 : 6745	.0022 :
10 : 23	84.983	1.000	42.492	92 : 9784	92 : 10, 10	0 :	9692 : 7155	.0129 :
18 : 23	75.581	1.000	37.791	442 : 9692	442 : 18, 18	0 :	9250 : 10064	.0439 :
14 : 23	75.581	1.000	37.791	106 : 9250	106 : 14, 14	0 :	9144 : 10064	.0105 :
13 : 23	56.410	1.000	28.205	126 : 9144	126 : 13, 13	0 :	9018 : 25549	.0049 :
15 : 23	54.364	1.000	27.182	249 : 9018	249 : 15, 15	0 :	8769 : 29585	.0084 :
20 : 23	53.661	1.000	26.831	96 : 8769	96 : 20, 20	0 :	8673 : 31153	.0031 :
23 : 27	41.342	1.000	20.671	8673 : 207	207 : 27, 27	8466 :	0 : 87718	.0024 :
1 : 1	34.312	1.000	17.156	45 : 45	45 : 1, 1	0 :	0 : 199658	.0002 :
17 : 23	30.989	1.000	15.495	40 : 8466	40 : 17, 17	0 :	8426 : 315988	.0001 :
21 : 23	28.768	1.000	14.384	15 : 8426	15 : 21, 21	0 :	8411 : 441844	.0000 :
19 : 23	28.768	1.000	14.384	307 : 8411	307 : 19, 19	0 :	8104 : 441844	.0007 :
2 : 2	14.504	1.000	7.252	45 : 45	45 : 2, 2	0 :	0 : >1.E6	0 :
3 : 3	13.928	1.000	6.964	7875 : 7875	7875 : 3, 3	0 :	0 : >1.E6	0 :

TOTAL USAGE FACTOR- .1572

Load Combinations for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3K (M96-0069)

AX-17D REV. 3K ATTACHMENT "D" PAGE 64 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

MR101/N4 RB/562367

06/13/97 IP2010 PAGE 8

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ. 11 AT LOCATION 82 (TEE)

LOAD SET NO.	LOAD SET DESCRIPTION	NO. OF CYCLES	P	LEG	X	Y	Z	DT1	DT2	TA	TB
1	1 DWT, DYNITL*2	45	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
2	2 DWT, SRVFT*2	45	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
3	3 DWT, SRV*2	7545	.000	RUN	.0	.0	.0	.0	.0	420.0	420.0
				RUN	.0	.0	.0				
				BRA	.0	.0	.0				
4	4 P, THMD35, DYNITL	5	1.050	RUN	.0	664.7	60.2	-75.0	-12.0	70.0	94.0
				RUN	.0	.0	.0				
				BRA	965.3	1081.8	-306.5				
5	5 P, THMD35, SRVFT	5	1.050	RUN	.0	664.7	60.2	-75.0	-12.0	70.0	94.0
				RUN	.0	.0	.0				
				BRA	965.3	1081.8	-306.5				
6	6 P, THMD15, SRV16V	200	.020	RUN	.0	644.8	58.4	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
7	7 P, THMD17, SRV16V	96	1.050	RUN	.0	644.8	58.4	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
8	8 P, THMD29, SRV16V	106	1.100	RUN	.0	644.8	58.4	.0	.0	70.0	70.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
9	9 P, THMD32, SRV1V	10	.120	RUN	.0	644.8	58.4	-16.0	-2.0	70.0	95.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
10	10 P, THMD33, SRV1V	632	1.100	RUN	.0	644.8	58.4	.0	.0	190.0	190.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
11	11 P, THMD34, SRV1V	1	1.516	RUN	.0	644.8	58.4	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
12	12 P, THMD35, SRV1V	190	1.175	RUN	.0	644.8	58.4	-60.0	-9.0	70.0	88.0
				RUN	.0	.0	.0				
				BRA	936.4	1049.3	-297.3				
13	13 P, THMD26, SRV1V	249	.000	RUN	.0	624.8	56.6	-1.0	.0	70.0	71.0
				RUN	.0	.0	.0				
				BRA	907.4	1016.9	-288.1				
14	14 P, THMD29, SRV1V	15	1.030	RUN	.0	555.2	69.8	3.0	1.0	70.0	70.0
				RUN	.0	.0	.0				
				BRA	621.0	963.1	-216.3				

TABLE CONTINUED

Load Combinations for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3K (M96-0069) pg. 2

AX-17D REV. 3K ATTACHMENT "D" PAGE 65 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/16/97 IP2010 PAGE 9

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ. 11 AT LOCATION 82 (TEE)

LOAD	NO. OF	LEG	X*	Y*	Z*	DT1	DT2	TA	TB
15	15 P, THMD20, SRVIV	15: .700:RUN:	.0:	578.4:	72.7:	-49.0:	-7.0:	70.0:	97.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	646.8:	1003.3:	-225.4:	:	:	:	:
16	16 P, THMD28, SRVIV	1: .020:RUN:	.0:	323.9:	40.7:	-66.0:	-14.0:	70.0:	104.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	362.2:	561.8:	-126.2:	:	:	:	:
17	17 P, THMD31, SRVIV	15: .200:RUN:	.0:	537.9:	67.7:	-46.0:	-6.0:	70.0:	90.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	601.5:	933.0:	-209.6:	:	:	:	:
18	18 P, THMD06	15:1.100:RUN:	.0:	113.6:	137.1:	26.0:	4.0:	92.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-245.7:	777.0:	-2.7:	:	:	:	:
19	19 P, THMD07	307:1.100:RUN:	.0:	439.0:	109.1:	97.0:	8.0:	97.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	110.6:	851.7:	-90.4:	:	:	:	:
20	20 P, THMD08	15:1.100:RUN:	.0:	439.0:	109.1:	55.0:	8.0:	90.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	110.6:	851.7:	-90.4:	:	:	:	:
21	21 P, THMD11	9999:1.100:RUN:	.0:	109.2:	131.8:	2.0:	.0:	71.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-236.2:	747.1:	-2.6:	:	:	:	:
22	22 P, THMD14	70:1.100:RUN:	.0:	109.2:	131.8:	27.0:	4.0:	81.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-236.2:	747.1:	-2.6:	:	:	:	:
23	23 P, THMD18	30:1.050:RUN:	.0:	108.1:	130.5:	22.0:	3.0:	91.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-233.9:	739.6:	-2.6:	:	:	:	:
24	24 P, THMD21	15: .700:RUN:	.0:	102.7:	123.9:	26.0:	4.0:	92.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-222.1:	782.3:	-2.5:	:	:	:	:
25	25 P, THMD22	96: .050:RUN:	.0:	159.8:	26.7:	28.0:	4.0:	80.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	143.7:	281.8:	-53.3:	:	:	:	:
26	26 P, THMD23	126: .050:RUN:	.0:	137.2:	10.7:	-20.0:	-3.0:	70.0:	77.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	213.8:	223.6:	-65.0:	:	:	:	:
27	27 P, THMD24	207: .050:RUN:	.0:	65.5:	79.1:	20.0:	3.0:	77.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-141.7:	448.3:	-1.6:	:	:	:	:
28	28 P, THMD27	10:1.335:RUN:	.0:	111.4:	134.4:	9.0:	1.0:	70.0:	70.0:
		: : :RUN:	.0:	.0:	.0:	:	:	:	:
		: : :BRA:	-241.0:	762.1:	-2.7:	:	:	:	:

TABLE CONTINUED

Load Combinations for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3K (M96-0069) pg. 3

AX-17D REV. 3K ATTACHMENT "D" PAGE 66 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 10

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ. 11 AT LOCATION 82 (TEE)

LOAD	NO. OF	P	LEG	X *	Y *	Z *	DT1	DT2	TA	TB
29 129 P, THMD36, SRV16V	20:1.050:RUN:			.0:	664.7:	60.2:	-75.0:	-12.0:	70.0:	94.0:
				.0:	.0:	.0:				
			BRA:	965.3:	1081.8:	-306.5:				

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 82 Tee (Break Points 60AW, BW, and CW) Addendum 3K

AX-17D REV. 3K ATTACHMENT "D" PAGE 71 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 15

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 82 (TEE)

:LOAD PAIR:	EQ.11		EQ.14	OCURRENCE		SET	CYCLES LEFT	ALLOW.	FATIGUE	
:	:	K-L	:	:	N	ELIM	:	CYCLES	USAGE	
: I : J :	S-P :		SP*KE/2 :	N-I :	N-J :	INATED:	N-I :	N-J :	N-D :	
:	:		:	:	:	:	:	:	FACTOR :	
: 4 : 27 :	103.823:	1.257:	65.278:	5:	207:	5: 4, 4 :	0:	202:	1983 :	.0025:
: 11 : 27 :	112.569:	1.055:	59.387:	1:	202:	1: 11,11 :	0:	201:	2651 :	.0004:
: 5 : 27 :	98.334:	1.079:	53.171:	5:	201:	5: 5, 5 :	0:	196:	3725 :	.0013:
: 27 : 29 :	98.504:	1.078:	53.104:	196:	20:	20: 29,29 :	176:	0:	3739 :	.0053:
: 6 : 18 :	99.899:	1.052:	52.548:	200:	15:	15: 18,18 :	185:	0:	3862 :	.0039:
: 6 : 28 :	103.086:	1.000:	51.543:	185:	10:	10: 28,28 :	175:	0:	4098 :	.0024:
: 6 : 22 :	98.205:	1.000:	49.102:	175:	70:	70: 22,22 :	105:	0:	4738 :	.0148:
: 6 : 23 :	96.852:	1.013:	49.078:	105:	30:	30: 23,23 :	75:	0:	4745 :	.0063:
: 12 : 27 :	97.469:	1.000:	48.734:	190:	176:	176: 27,27 :	14:	0:	4841 :	.0364:
: 6 : 19 :	97.222:	1.000:	48.611:	75:	307:	75: 6, 6 :	0:	232:	4876 :	.0154:
: 12 : 25 :	96.701:	1.000:	48.351:	14:	96:	14: 12,12 :	0:	82:	4951 :	.0028:
: 8 : 16 :	94.192:	1.000:	47.096:	106:	1:	1: 16,16 :	105:	0:	5336 :	.0002:
: 7 : 25 :	93.420:	1.000:	46.710:	96:	82:	82: 25,25 :	14:	0:	5463 :	.0150:
: 9 : 19 :	84.885:	1.000:	42.428:	10:	232:	10: 9, 9 :	0:	222:	7186 :	.0014:
: 7 : 26 :	83.197:	1.000:	41.599:	14:	126:	14: 7, 7 :	0:	112:	7601 :	.0018:
: 13 : 19 :	83.005:	1.000:	41.502:	249:	222:	222: 19,19 :	27:	0:	7652 :	.0290:
: 8 : 26 :	81.585:	1.000:	40.792:	105:	112:	105: 8, 8 :	0:	7:	8037 :	.0131:
: 13 : 20 :	81.576:	1.000:	40.788:	27:	15:	15: 20,20 :	12:	0:	8040 :	.0019:
: 10 : 26 :	79.310:	1.000:	39.655:	632:	7:	7: 26,26 :	625:	0:	8721 :	.0008:
: 13 : 21 :	78.348:	1.000:	39.174:	12:	9999:	12: 13,13 :	0:	9987:	9044 :	.0013:
: 17 : 21 :	72.651:	1.000:	36.325:	15:	9987:	15: 17,17 :	0:	9972:	11321 :	.0013:
: 10 : 24 :	55.382:	1.000:	27.691:	625:	15:	15: 24,24 :	610:	0:	27495 :	.0005:
: 15 : 21 :	54.490:	1.000:	27.245:	15:	9972:	15: 15,15 :	0:	9957:	29315 :	.0005:
: 10 : 21 :	30.154:	1.000:	15.077:	610:	9957:	610: 10,10 :	0:	9347:	357409 :	.0017:
: 1 : 1 :	26.979:	1.000:	13.489:	45:	45:	45: 1, 1 :	0:	0:	590146 :	.0001:
: 14 : 21 :	26.066:	1.000:	13.033:	15:	9347:	15: 14,14 :	0:	9332:	689158 :	.0000:
: 2 : 2 :	17.585:	1.000:	8.792:	45:	45:	45: 2, 2 :	0:	0:	>1.E6 :	0 :
: 3 : 3 :	17.511:	1.000:	8.756:	7545:	7545:	7545: 3, 3 :	0:	0:	>1.E6 :	0 :
TOTAL USAGE FACTOR=									.1603	

Load Combinations for location 85 (Break Point 71W) Addendum 3K

AX-17D REV. 3K ATTACHMENT "D" PAGE 72 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 16

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ.11 AT LOCATION 85 (CURB)

LOAD	NO. OF											
SET NO:	LOAD SET DESCRIPTION:	CYCLES:	P	X *	Y *	Z *	DT1	DT2	TA	TB		
1	1 DWT, DYNITL*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0		
2	2 DWT, SRVET*2	45	.000	.0	.0	.0	.0	.0	420.0	420.0		
3	3 DWT, SRV*2	7545	.000	.0	.0	.0	.0	.0	420.0	420.0		
4	4 P, THMD36, DYNITL	5	1.050	965.3	-117.3	-374.9	-50.0	-8.0	70.0	96.0		
5	5 P, THMD36, SRVET	5	1.050	965.3	-117.3	-374.9	-50.0	-8.0	70.0	96.0		
6	6 P, THMD15, SRV16V	200	.020	936.4	-113.8	-363.6	-36.0	-5.0	70.0	70.0		
7	7 P, THMD17, SRV16V	96	1.050	936.4	-113.8	-363.6	-36.0	-5.0	70.0	70.0		
8	8 P, THMD29, SRV16V	106	1.100	936.4	-113.8	-363.6	.0	.0	70.0	70.0		
9	9 P, THMD32, SRV1V	10	.120	936.4	-113.8	-363.6	-12.0	-2.0	70.0	70.0		
10	10 P, THMD33, SRV1V	632	1.100	936.4	-113.8	-363.6	.0	.0	190.0	190.0		
11	11 P, THMD34, SRV1V	1	1.518	936.4	-113.8	-363.6	-36.0	-5.0	70.0	70.0		
12	12 P, THMD35, SRV1V	190	1.175	936.4	-113.8	-363.6	-36.0	-5.0	70.0	70.0		
13	13 P, THMD26, SRV1V	249	.000	907.4	-110.3	-352.4	-3.0	.0	70.0	70.0		
14	14 P, THMD19, SRV1V	15	1.050	621.0	-85.2	-401.7	-22.0	-4.0	70.0	70.0		
15	15 P, THMD20, SRV1V	15	.700	646.8	-86.8	-418.4	-36.0	-5.0	70.0	70.0		
16	16 P, THMD28, SRV1V	1	.020	362.2	-49.7	-234.3	-57.0	-10.0	70.0	70.0		
17	17 P, THMD31, SRV1V	15	.200	601.5	-82.5	-389.1	-30.0	-4.0	70.0	70.0		
18	18 P, THMD06	15	1.100	-245.7	-13.4	-540.6	.3	.1	70.0	70.0		
19	19 P, THMD07	307	1.100	110.6	-42.8	-482.1	31.0	4.0	70.0	70.0		
20	20 P, THMD08	15	1.100	110.6	-42.8	-482.1	31.0	4.0	70.0	70.0		
21	21 P, THMD11	9999	1.100	-236.2	-12.9	-519.8	1.0	.0	70.0	70.0		
22	22 P, THMD14	70	1.100	-236.2	-12.9	-519.8	15.0	2.0	70.0	70.0		
23	23 P, THMD18	30	1.050	-233.9	-12.8	-514.6	16.0	2.0	70.0	70.0		
24	24 P, THMD21	15	.700	-222.1	-12.1	-488.6	17.0	3.0	70.0	70.0		
25	25 P, THMD22	96	.050	143.7	-20.8	-126.4	19.0	3.0	70.0	70.0		
26	26 P, THMD23	126	.050	213.8	-23.7	-71.4	-13.0	-2.0	70.0	70.0		
27	27 P, THMD24	207	.050	-141.7	-7.7	-311.9	13.0	2.0	70.0	70.0		
28	28 P, THMD27	10	1.335	-241.0	-13.1	-530.2	3.0	.0	70.0	70.0		
29	29 P, THMD36, SRV16V	20	1.050	965.3	-117.3	-374.9	-50.0	-8.0	70.0	96.0		

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 85 (Break Point 71W) Addendum 3K
AX-17D REV. 3K ATTACHMENT "D" PAGE 75 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 19

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 85 (CURB)

LOAD PAIR:	EQ.11		EQ.14	OCCURENCE		SET	CYCLES LEFT	ALLOW.	FATIGUE	
I : J	S-P	K-E	SP*KE/2	N-I	N-J	ELIM- INATED:	N-I	N-J	CYCLES : N-D	USAGE : FACTOR :
4 : 27	123.386	1.109	68.435	5:	207:	5: 4, 4	0:	202:	1715 :	.0029:
3 : 27	109.099	1.000	54.550	5:	202:	5: 9, 5	0:	197:	3443 :	.0015:
27 : 29	109.080	1.000	54.540	197:	20:	20: 29,29	177:	0:	3445 :	.0059:
6 : 28	104.127	1.000	52.064	200:	10:	10: 28,28	190:	0:	3974 :	.0025:
6 : 22	103.648	1.000	51.824	190:	70:	70: 22,22	120:	0:	4030 :	.0174:
6 : 23	102.975	1.000	51.487	120:	30:	30: 23,23	90:	0:	4112 :	.0073:
6 : 18	100.761	1.000	50.380	90:	15:	15: 18,18	75:	0:	4396 :	.0034:
11 : 27	100.742	1.000	50.371	1:	177:	1: 11,11	0:	176:	4398 :	.0002:
6 : 21	100.045	1.000	50.023	75:	9999:	75: 6, 6	0:	9924:	4493 :	.0167:
12 : 27	96.067	1.000	48.034	190:	176:	176: 27,27	14:	0:	5045 :	.0349:
12 : 24	93.741	1.000	46.870	14:	15:	14: 12,12	0:	1:	5410 :	.0026:
7 : 24	93.105	1.000	46.552	96:	1:	1: 24,24	95:	0:	5516 :	.0002:
9 : 21	91.493	1.000	45.747	10:	9924:	10: 9, 9	0:	9914:	5797 :	.0017:
13 : 21	89.054	1.000	44.527	249:	9914:	249: 13,13	0:	9665:	6261 :	.0399:
7 : 21	85.925	1.000	42.963	95:	9665:	95: 7, 7	0:	9570:	6933 :	.0137:
8 : 21	76.012	1.000	38.006	106:	9570:	106: 8, 8	0:	9464:	9896 :	.0107:
10 : 21	74.897	1.000	37.448	632:	9464:	632: 10,10	0:	8832:	10341 :	.0611:
16 : 21	74.731	1.000	37.368	1:	8832:	1: 16,16	0:	8831:	10409 :	.0001:
17 : 21	74.692	1.000	37.346	15:	8831:	15: 17,17	0:	8816:	10425 :	.0014:
15 : 21	71.702	1.000	35.851	15:	8816:	15: 15,15	0:	8801:	11772 :	.0013:
14 : 25	62.869	1.000	31.434	15:	96:	15: 14,14	0:	81:	17406 :	.0009:
21 : 26	56.475	1.000	28.237	8801:	126:	126: 26,26	8675:	0:	25434 :	.0050:
21 : 25	52.266	1.000	26.133	8675:	81:	81: 23,23	8594:	0:	34388 :	.0023:
1 : 1	40.008	1.000	20.004	45:	45:	45: 1, 1	0:	0:	99915 :	.0005:
20 : 21	28.853	1.000	14.426	15:	8594:	15: 20,20	0:	8579:	436018 :	.0000:
19 : 21	28.853	1.000	14.426	307:	8579:	307: 19,19	0:	8272:	436018 :	.0007:
2 : 2	16.381	1.000	8.191	45:	45:	45: 2, 2	0:	0:	>1.E6 :	0 :
3 : 3	16.338	1.000	8.169	7545:	7545:	7545: 3, 3	0:	0:	>1.E6 :	0 :

TOTAL USAGE FACTOR= .2345

Load Combinations for location 87 (Break Point 70W) Addendum 3K
AX-17D REV. 3K ATTACHMENT "D" PAGE 76 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 20

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

LOAD TABLE FOR EQ.11 AT LOCATION 87 (CURE)

: LOAD :	: NO. OF :	: X * :	: Y * :	: Z * :	: DT1 :	: DT2 :	: TA :	: TB :
:SET NO:LOAD SET DESCRIPTION:CYCLES: P :								
: 1 : 1 DWT,DYNTTL*2 : 45 : .000 : .0 : .0 : .0 : .0 : .0 : 420.0 : 420.0 :								
: 2 : 2 DWT,SRVFT*2 : 45 : .000 : .0 : .0 : .0 : .0 : .0 : 420.0 : 420.0 :								
: 3 : 3 DWT,SRV*2 : 7545 : .000 : .0 : .0 : .0 : .0 : .0 : 420.0 : 420.0 :								
: 4 : 4 P,THMD36,DYNTTL : 5 : 1.050 : 68.5 : -736.1 : -366.3 : -50.0 : -8.0 : 70.0 : 96.0 :								
: 5 : 5 P,THMD36,SRVFT : 5 : 1.050 : 68.5 : -736.1 : -366.3 : -50.0 : -8.0 : 70.0 : 96.0 :								
: 6 : 6 P,THMD13,SRV16V : 200 : .020 : 66.5 : -714.0 : -355.3 : -21.0 : -3.0 : 70.0 : 80.0 :								
: 7 : 7 P,THMD17,SRV16V : 96 : 1.050 : 66.5 : -714.0 : -355.3 : -21.0 : -3.0 : 70.0 : 80.0 :								
: 8 : 8 P,THMD29,SRV16V : 106 : 1.100 : 66.5 : -714.0 : -355.3 : .0 : .0 : 70.0 : 70.0 :								
: 9 : 9 P,THMD32,SRV1V : 10 : .120 : 66.5 : -714.0 : -355.3 : -9.0 : -1.0 : 70.0 : 94.0 :								
: 10 : 10 P,THMD33,SRV1V : 632 : 1.100 : 66.5 : -714.0 : -355.3 : .0 : .0 : 190.0 : 190.0 :								
: 11 : 11 P,THMD34,SRV1V : 1 : 1.516 : 66.5 : -714.0 : -355.3 : -21.0 : -3.0 : 70.0 : 80.0 :								
: 12 : 12 P,THMD35,SRV1V : 190 : 1.175 : 66.5 : -714.0 : -355.3 : -21.0 : -3.0 : 70.0 : 80.0 :								
: 13 : 13 P,THMD26,SRV1V : 249 : .000 : 64.4 : -691.9 : -344.3 : .0 : .0 : 70.0 : 70.0 :								
: 14 : 14 P,THMD19,SRV1V : 15 : 1.050 : 43.7 : -431.6 : -264.2 : -22.0 : -4.0 : 70.0 : 91.0 :								
: 15 : 15 P,THMD20,SRV1V : 15 : .700 : 45.5 : -449.6 : -275.2 : -25.0 : -4.0 : 70.0 : 94.0 :								
: 16 : 16 P,THMD28,SRV1V : 1 : .020 : 25.5 : -251.8 : -154.1 : -46.0 : -8.0 : 70.0 : 103.0 :								
: 17 : 17 P,THMD31,SRV1V : 15 : .200 : 42.3 : -418.1 : -256.0 : -21.0 : -3.0 : 70.0 : 91.0 :								
: 18 : 18 P,THMD06 : 15 : 1.100 : -23.9 : 356.1 : -23.4 : .3 : .1 : 71.0 : 70.0 :								
: 19 : 19 P,THMD07 : 307 : 1.100 : 4.0 : 31.6 : -121.9 : 17.0 : 3.0 : 81.0 : 70.0 :								
: 20 : 20 P,THMD08 : 15 : 1.100 : 4.0 : 31.6 : -121.9 : 17.0 : 3.0 : 81.0 : 70.0 :								
: 21 : 21 P,THMD11 : 9999 : 1.100 : -23.0 : 342.4 : -22.5 : 1.0 : .0 : 70.0 : 70.0 :								
: 22 : 22 P,THMD14 : 70 : 1.100 : -23.0 : 342.4 : -22.5 : 8.0 : 1.0 : 75.0 : 70.0 :								
: 23 : 23 P,THMD18 : 30 : 1.050 : -22.7 : 339.0 : -22.3 : 11.0 : 2.0 : 90.0 : 70.0 :								
: 24 : 24 P,THMD21 : 15 : .700 : -21.6 : 321.9 : -21.2 : 12.0 : 2.0 : 90.0 : 70.0 :								
: 25 : 25 P,THMD22 : 96 : .050 : 11.1 : -92.9 : -65.2 : 12.0 : 2.0 : 78.0 : 70.0 :								
: 26 : 26 P,THMD23 : 126 : .050 : 15.8 : -167.7 : -77.3 : -8.0 : -1.0 : 70.0 : 75.0 :								
: 27 : 27 P,THMD24 : 207 : .050 : -13.8 : 205.4 : -13.5 : 8.0 : 1.0 : 75.0 : 70.0 :								
: 28 : 28 P,THMD27 : 10 : 1.335 : -23.4 : 349.2 : -23.0 : 2.0 : .0 : 72.0 : 70.0 :								
: 29 : 29 P,THMD36,SRV16V : 20 : 1.050 : 68.5 : -736.1 : -366.3 : -50.0 : -8.0 : 70.0 : 96.0 :								

*NOTE: OBE AND SAM MOMENTS ARE INCLUDED IN RANGE VALUE CALCULATIONS NOT IN THESE SINGLE SET COMBINED MOMENTS.

CUF Summary for location 87 (Break Point 70W) Addendum 3K

AX-17D REV. 3K ATTACHMENT "D" PAGE 79 OF 156

1

CLASS 1 CODE COMPLIANCE ANALYSIS

ME101/N4 RB/562367

06/18/97 IP2010 PAGE 23

RUN NO.2 FOR NODE POINTS 82, 85, 87, 100, 105, 110 & 125 OF AX-17D

SUMMARY OF CALCULATIONS OF CUMULATIVE USAGE FACTOR AT LOCATION 87 (CURE)

LOAD PAIR:	EQ.11		EQ.14	OCCURENCE		SET	CYCLES LEFT	ALLOW.	FATIGUE
I : J	S-P	K-E	SP*KE/2	N-I : N-J	N	ELIM- INATED:	N-I : N-J	N-D	USAGE :
4 : 24	122.380	1.021	62.492	5: 15	5	4, 4	0:	10:	2267 : .0022:
5 : 24	113.304	1.000	56.652	5: 10	5	5, 5	0:	5:	3065 : .0016:
24 : 29	113.263	1.000	56.632	5: 20	5	24,24	0:	15:	3068 : .0016:
23 : 29	109.811	1.000	54.905	30: 15	15	29,29	15:	0:	3375 : .0044:
6 : 23	108.136	1.000	54.068	200: 15	15	23,23	185:	0:	3538 : .0042:
6 : 28	104.173	1.000	52.087	185: 10	10	28,28	175:	0:	3968 : .0025:
6 : 22	103.405	1.000	51.702	175: 70	70	22,22	105:	0:	4059 : .0172:
6 : 18	101.068	1.000	50.834	105: 15	15	18,18	90:	0:	4355 : .0034:
6 : 21	100.061	1.000	50.031	90: 9999	90	6, 6	0:	9909:	4491 : .0200:
9 : 21	98.186	1.000	49.093	10: 9909	10	9, 9	0:	9899:	4741 : .0021:
11 : 27	98.099	1.000	49.049	1: 207	1	11,11	0:	206:	4753 : .0002:
7 : 27	94.254	1.000	47.127	96: 206	96	7, 7	0:	110:	5326 : .0180:
12 : 27	93.947	1.000	46.973	190: 110	110	27,27	80:	0:	5376 : .0205:
13 : 21	89.408	1.000	44.204	249: 9899	249	13,13	0:	9650:	6393 : .0389:
12 : 21	88.010	1.000	43.005	80: 9650	80	12,12	0:	9570:	6914 : .0116:
16 : 21	79.449	1.000	39.725	1: 9570	1	16,16	0:	9569:	8676 : .0001:
17 : 21	79.085	1.000	39.542	15: 9569	15	17,17	0:	9554:	8796 : .0017:
8 : 21	78.421	1.000	39.211	106: 9554	106	8, 8	0:	9448:	9019 : .0118:
15 : 21	77.415	1.000	38.707	15: 9448	15	15,15	0:	9433:	9372 : .0016:
10 : 21	76.808	1.000	38.304	632: 9433	632	10,10	0:	8801:	9669 : .0654:
14 : 21	70.221	1.000	35.111	15: 8801	15	14,14	0:	8786:	12526 : .0012:
21 : 26	50.055	1.000	25.028	8786: 126	126	26,26	8660:	0:	41060 : .0031:
21 : 25	46.743	1.000	23.372	8660: 96	96	25,25	8564:	0:	53880 : .0018:
1 : 1	31.950	1.000	15.975	45: 45	45	1, 1	0:	0:	275367 : .0002:
20 : 21	28.997	1.000	14.498	15: 8564	15	20,20	0:	8549:	426330 : .0000:
19 : 21	28.997	1.000	14.498	307: 8549	307	19,19	0:	8242:	426330 : .0007:
2 : 2	12.656	1.000	6.328	45: 45	45	2, 2	0:	0:	>1.E6 : 0 :
3 : 3	12.572	1.000	6.286	7545: 7545	7545	3, 3	0:	0:	>1.E6 : 0 :


TOTAL USAGE FACTOR= .2362

RBG-47895


Attachment 4

Addendum 3J and 3K Cover Pages:

Addendum 3J Cover Page:

 ENERGY	CALCULATION TITLE PAGE ENGINEERING DEPARTMENT ENERGY OPERATIONS INCORP.		1. CALCULATION NUMBER AX-17D	REV OR ADD: 3J	
				JB1 NO. G13.18.10.2	
				PAGE 1 OF 365	
2. CALCULATION TITLE: ME101 class 1 pipe stress analysis using Code Case N-411 damping for selected components			3. SUPERSEDES: N/A SUPPLEMENTS: AX-17D REV. 3		
4. OBJECTIVE OF CALCULATION: The objective of this addendum is to reduce the dynamic loads for OBE and SRV 1V, 2V and 16V cases by using the Code Case N-411 damping in stress analysis, then to perform the class 1 pipe stress analysis for the critical piping components such as elbow, reducer, tee, taper transition, and RPV nozzle.					
5. CALCULATION METHOD / ASSUMPTIONS: See page 3					
6. SOURCES OF DATA/EQUATIONS (REFERENCES): (1) Calculation AX-17D Rev. 3 (2) ME101 Computer Program, Version N4 (3) G13.18.1.5*08 Rev. 1 Peak-spread ARS for Seismic Events Including Curves with N-411-1 Damping (4) Code Case N-411-1 Alternative Damping Values for Response Spectra Analysis of Class 1, 2, and 3 Piping Section III, Division 1, dated Feb. 20, 1986					
7. CONCLUSIONS: 1. The class 1 results from ME101C1 analysis are consistent with those from NUPIPE analysis. The Class 1 stresses as well as CUF went down slightly as expected. There is no need to revise the support loads, equipment loads, and valve accelerations in this addendum. 2. Stress report for feedwater system SR-504 needs not to be revised per the above reasons.					
RECEIVED NOV 07 1996					
8. REASON FOR REVISION (IF APPLICABLE): SDC This calculation is used as a basis for the class 1 qualification of some fittings affected by flow accelerated corrosion (FAC) to determine the remaining life.					
9. RELATED DOCUMENTS: N/A			10. Q-CLASS <input checked="" type="checkbox"/> 1 - NUCLEAR SAFETY RELATED <input type="checkbox"/> 2 <input type="checkbox"/> 3 QAPA? Y ___ N <input checked="" type="checkbox"/>		
11. <i>Y. S. Sun</i> Y. SUN 0667 9/5/96 PREPARER KCN DATE		12. <i>Hung K. Lee</i> Hung K. Lee KCN 0996 9/10/96 CHECKER/REVIEWER DATE		13. <i>Lothar Kuhn</i> Lothar Kuhn KCN 1105 9/11/96 INDEPENDENT REVIEWER DATE	
14. DATA REQUIRING CONFIRMATION: _____ DATA CONFIRMED BY: DATE			15. APPROVED: <i>Lothar Kuhn</i> For. Eng. (086) 10/31/96 SIGNATURE KCN DATE		

Addendum 3K Cover Page:


 ENERGY	CALCULATION COVER PAGE ENGINEERING DEPARTMENT RIVER BEND STATION		CALC. NO. - REV. ADDENDUM AX-17D, Revision 3K
			ATTACHMENT NO.: JBI NO.: G13.10.2.2 <i>Am 7/1/98</i> PAGE 1 OF 2040 <i>539</i>
TITLE: Pipe Stress Analysis for FWS-Piping in Reactor and Auxiliary Bldgs (West Loop)		SUPERSEDES: Rev. 3B, E, F, G, H, J SUPPLEMENTS: AX-17D, Rev. 3	
CALCULATION STATUS: <input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> PENDING <input type="checkbox"/> CANCELED			
SYSTEM NO.: 107		MARK NO.:	
CLASSIFICATION: <input checked="" type="checkbox"/> SAFETY RELATED		NON-SAFETY RELATED: <input type="checkbox"/> QAPA <input type="checkbox"/> NON-QAPA	
PURPOSE / SCOPE / OBJECTIVE: MR 96-0069 reroutes the RCIC Injection Line from its original connection to the RPV Head to the FWS system through a short portion of the RHS piping. The objective of Revision 3K is to evaluate the FWS piping for the new function of RCIC injection in addition to the existing FWS function. A new check valve is to be added in the Auxiliary Building (see worksketch). The piping is to be evaluated for thermal and fluid transient events associated with RCIC Injection into feedwater loop A. The information contained in Revisions 3B, 3E, 3F, 3G, 3H, and 3J has been incorporated into the input file. See also comment cards in the input listings. Class 1 piping analysis covers only the critical components such as Reducer, Tee, Taper Transition (Valve), Elbow, and RPV nozzle junction.			
CONCLUSION: The analysis demonstrates the acceptability of the piping for MR 96-0069.		RECEIVED JUL 01 1998 SDC	
SOFTWARE USED FOR CALCULATION: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO SDDF #: 6229.400-100-001A Manufacturer: <u>Bechtel</u> Name: <u>ME101</u> Version/Release No. <u>N4</u>			
CONFIRMATIONS REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		CONFIRMATION COMPLETE: <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	
KEYWORDS: MR 96-0069, PIPE STRESS, FWS, ICS, N411			
REVIEW & APPROVAL			
<i>J-S Sun (0667) 6-19-97</i> (Signature/Date) Preparer (Printed Name, KCN, or SSN)	<i>Renu Ja (0956) 6-19-97</i> (Signature/Date) <input type="checkbox"/> Reviewer (Non-Safety) <input type="checkbox"/> Design Verification Reviewer (Printed Name, KCN, or SSN)	<i>Rajesh Gupta / 11-20-97</i> (Signature/Date) Supervisor (Printed Name, KCN, or SSN) RAJESH GUPTA	

RBG-47895

Attachment 5

Addendum 3J Stress/ Cumulative Usage Factor (CUF) comparison with Addendum 3B

Addendum 3J Stress/CUF comparison with Addendum 3B

 ENTERGY	CALCULATION WORK SHEET	EOI CALCULATION NUMBER: AX-17D Rev. 3J
	ENTERGY OPERATIONS INCORP.	JBI No.
		PAGE 24 of

SUMMARY OF RESULTS (continued)

CLASS I STRESS COMPARISON Rev. 3J vs Rev. 3B

N.P.	EQ. 9 (psi)		EQ. 10 (psi)			EQ. 12 (psi)			EQ. 13 (psi)		CUF		
	3J	3B	3J	3J	3B	3J	3J	3B	3J	3B	3J	3J	3B
				inc3.3%			inc3.3%					inc3.3%	
2	11101	9577	39074	40363	37894						0.0142	0.0147	0.0189
4	18361	16971	52562	54297	49781						0.0116	0.0120	0.0213
6	17417	16472	50785	52461	48087						0.0099	0.0102	0.0182
10	17158	15898	47934	49516	46011						0.0081	0.0084	0.0145
12	16113	15851	43694	45136	44357						0.0048	0.0050	0.0096
35	19991	20729	47543	49112	48198						0.0060	0.0062	0.0138
45	18212	18586	54237	56027	53924						0.0079	0.0082	0.0186
58	15032	15849	32984	34072	35051						0.0096	0.0099	0.0178
59	15372	15693	37159	38385	35451						0.0161	0.0166	0.0175
65	14770	19879	37991	39245	44172						0.0031	0.0032	0.0058
70	14077	19203	37154	38380	42829						0.0028	0.0029	0.0050
82	18183	20548	67590	69820	70498	26034	26893	29393	29533	31388	0.1543	0.1594	0.6490
85	15493	16056	72596	74992	77836	41302	42665	46162	21027	24027	0.1653	0.1708	0.6512
87	14651	15084	68996	71273	71289	41599	42972	43990	20622	23946	0.1572	0.1624	0.3722
100	12723	13656	67082	69296	67257						0.0348	0.0359	0.0604
105	12684	13455	61324	63348	59836						0.0186	0.0192	0.0343
110	14670	16324	51770	53478	46983						0.0106	0.0109	0.0161
115	13909	15696	63300	65389	61591						0.0327	0.0338	0.0386
119	13073	13934	71583	73945	74505	40462	41797	46486	27701	32653	0.2802	0.2894	0.4038
125	10800	11483	56865	58742	60116						0.0461	0.0476	0.0657
140	10283	10191	45867	47381	46369						0.0318	0.0328	0.0346
145	14325	14040	45513	47015	45871						0.0064	0.0066	0.0074
150	14408	14449	46576	48113	47032						0.0089	0.0092	0.0097
155	10332	10479	46919	48467	47823						0.0390	0.0403	0.0424
159	9522	9670	46636	48175	54351						0.0381	0.0394	0.0763
205	12239	12968	56705	58576	67775						0.0424	0.0438	0.0940
215	10239	10416	52147	53868	55567						0.0326	0.0337	0.0522

Note:

The thermal stresses from ME101 run would be expected to be nearly identical to those from NUPIPE. However, in the ME101 model the nozzle elements (nodes 1-2 & 119-120) were not included. As a result, the piping is slightly stiffer. This explains why EQ. 9 & 10 stresses are different from those of the NUPIPE analysis. The purpose of this addendum is to provide a reference for wall thinning analysis (FAC), and critical wall thickness calculation.