



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

WBL-19-029

April 24, 2019

10 CFR 50.4

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001


Watts Bar Nuclear Plant, Unit 2
Facility Operating License No. NPF-96
NRC Docket No. 50-391

Subject: **REVISION 0 OF THE UNIT 2 CYCLE 3 CORE OPERATING LIMITS
REPORT (COLR)**

Pursuant to Watts Bar Nuclear Plant Technical Specifications Section 5.9.5.d, Tennessee Valley Authority (TVA) has enclosed Revision 0 of the Unit 2 Cycle 3 COLR. The analytical methods used to determine the core operating limits were previously reviewed and approved by the NRC.

There are no regulatory commitments contained in this letter or the enclosure. Should you have questions regarding this submittal, please contact Kim Hulvey at (423) 365-7720.

Respectfully,



Anthony L. Williams IV
Site Vice President
Watts Bar Nuclear Plant

Enclosure: Watts Bar Nuclear Plant, Unit 2, Cycle 3 Core Operating Limits Report
Revision 0 April 2019

U.S. Nuclear Regulatory Commission

Page 2

April 24, 2019

cc (Enclosure):

NRC Regional Administrator - Region II

NRR Project Manager - Watts Bar Nuclear Plant

NRC Senior Resident Inspector - Watts Bar Nuclear Plant

ENCLOSURE

**Watts Bar Nuclear Plant, Unit 2, Cycle 3
Core Operating Limits Report
Revision 0
April 2019**

QA Record
L36 190228 800


WATTS BAR NUCLEAR PLANT, UNIT 2, CYCLE 3

CORE OPERATING LIMITS REPORT


Revision 0

April 2019

Prepared by:


_____, 4/2/19
John A. Ritchie, PWR Fuel Engineering Date

Verified by:



_____, 4/2/19
Gary T. Wolfram, PWR Fuel Engineering (Signed per telecon) Date

Reviewed by:


_____, 4/2/19
Christine A. Setter, Manager, PWR Fuel Engineering Date


_____, 4/3/19
Bryan T. Mack, Manager, Reactor Engineering Date

Approved by:


_____, 4/9/19
PORC Chairman Date


_____, 4/9/2019
Plant Manager Date

Revision	Date of PORC Approval	Affected Pages	Reason for Revision
0	See above	All	Initial issue

1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for Watts Bar Unit 2 Cycle 3 has been prepared in accordance with the requirements of the Technical Specifications (TS) 5.9.5.

The Technical Specifications affected by this report are listed below:

- 3.1.4 Moderator Temperature Coefficient (MTC)
- 3.1.5 Rod Group Alignment Limits
- 3.1.6 Shutdown Bank Insertion Limits
- 3.1.7 Control Bank Insertion Limits
- 3.2.1 Heat Flux Hot Channel Factor ($F_Q(Z)$)
- 3.2.2 Nuclear Enthalpy Rise Hot Channel Factor ($F_{\Delta H}^N$)
- 3.2.3 Axial Flux Difference (AFD)
- 3.9.1 Boron Concentration

2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in section 1.0 are presented in the following subsections. These limits have been developed using the NRC approved methodologies specified in the Technical Specifications Section 5.9.5.

The following abbreviations are used in this section:

BOL	--	Beginning of Cycle Life
ARO	--	All Rods Out
HZP	--	Hot Zero Thermal Power
EOL	--	End of Cycle Life
RTP	--	Rated Thermal Power

2.1 MODERATOR TEMPERATURE COEFFICIENT - MTC (LCO 3.1.4)

2.1.1 The MTC limits are:

The ARO/HZP - MTC shall be less positive than or equal to $0 \Delta k/k/^\circ F$ (upper limit). With the measured BOL/ARO/HZP - MTC more positive than $-1.93 \times 10^{-5} \Delta k/k/^\circ F$ (as-measured MTC limit), establish control rod withdrawal limits to ensure the MTC remains less positive than or equal to $0 \Delta k/k/^\circ F$ (upper limit) for all times in core life.

The EOL/ARO/RTP - MTC shall be less negative than or equal to $-4.50 \times 10^{-4} \Delta k/k/^\circ F$ (lower limit).

2.1.2 The 300 ppm surveillance limit is:

The measured 300 ppm /ARO/RTP-MTC should be less negative than or equal to $-3.75 \times 10^{-4} \Delta k/k/^\circ F$.

2.1.3 The 60 ppm surveillance limit is:

The measured 60 ppm /ARO/RTP-MTC should be less negative than or equal to $-4.28 \times 10^{-4} \Delta k/k/^\circ F$.

2.2 SHUTDOWN MARGIN – SDM (LCO 3.1.5, 3.1.6, 3.1.7)

2.2.1 For TS 3.1.5, SDM shall be $\geq 1.6\% \Delta k/k$ in MODE 1 and MODE 2.

2.2.2 For TS 3.1.6, SDM shall be $\geq 1.6\% \Delta k/k$ in MODE 1 and MODE 2.

2.2.3 For TS 3.1.7, SDM shall be $\geq 1.6\% \Delta k/k$ in MODE 1 and MODE 2 with $k_{eff} \geq 1.0$.

2.3 SHUTDOWN BANK INSERTION LIMITS (LCO 3.1.6)

2.3.1 The shutdown banks shall be withdrawn to a position greater than or equal to 225 steps withdrawn.

2.4 CONTROL BANK INSERTION LIMITS (LCO 3.1.7)

2.4.1 The control banks are fully withdrawn or shall be limited in physical insertion as shown in Figure 1.

2.4.2 Each control bank shall be considered fully withdrawn from the core at greater than or equal to 225 steps.

2.4.3 The control banks shall be operated in sequence by withdrawal of Bank A, Bank B, Bank C, and Bank D. The control banks shall be sequenced in reverse order upon insertion.

2.4.4 Each control bank not fully withdrawn from the core shall be operated with the following overlap as a function of park position.

Park Position (steps)	Bank Overlap (steps)	Bank Difference (steps)
225	109	116
226	110	116
227	111	116
228	112	116
229	113	116
230	114	116
231	115	116

2.5 HEAT FLUX HOT CHANNEL FACTOR - $F_Q(Z)$ (LCO 3.2.1)

$$F_Q(Z) \leq [CFQ / P] * K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq [CFQ / 0.5] * K(Z) \quad \text{for } P \leq 0.5$$

Where $P = \text{Thermal Power} / \text{Rated Thermal Power}$

2.5.1 $CFQ = 2.50$

2.5.2 $K(Z)$ is provided in Figure 2.

2.5.3 $F_Q^W(Z) = F_Q^c(Z) * W(Z)/P$ for $P > 0.5$

$$F_Q^W(Z) = F_Q^c(Z) * W(Z)/0.5 \quad \text{for } P \leq 0.5$$

where: $W(Z)$ values are provided in Table A.1. The table provides sufficient information to determine $W(Z)$ versus core height for all cycle burnups.

2.5.4 Part power $W(Z)$ values are only required to be used when the part power surveillance is performed using the fixed incore detector system.

2.5.5 $F_Q^W(Z)$ Penalty Factor

The $F_Q^W(Z)$ penalty factor is provided in Table A.2.

2.6 NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR – $F_{\Delta H}^N$ (LCO 3.2.2)

$$F_{\Delta H}^N \leq F_{\Delta H}^{RTP} * (1 + PF * (1-P))$$

where P = Thermal Power / Rated Thermal Power

$F_{\Delta H}^{RTP} = 1.65$ for RFA-2 fuel, and

$$PF = 0.3$$

2.7 AXIAL FLUX DIFFERENCE - AFD (LCO 3.2.3)

2.7.1 The AFD limits for Cycle 3 are provided in Figure 3.

2.8 REFUELING BORON CONCENTRATION (LCO 3.9.1)

2.8.1 The refueling boron concentration shall be ≥ 2000 ppm.




Figure 1
Control Bank Insertion Limits Versus Thermal Power
Four Loop Operation

Note: Fully withdrawn region shall be the condition where shutdown and control banks are at a position within the interval of ≥ 225 and ≤ 231 steps withdrawn.




Figure 2
K(Z) - Normalized $F_Q(Z)$ as a Function of Core Height




Figure 3
Axial Flux Difference Acceptable Operation Limits as a function of Rated Thermal Power (RAOC)

**Table A.1
RAOC W(Z) Surveillance Factors**

Height (ft)	Max W(z) at 150 MWD/MTU (30% Power)	Max W(z) at 150 MWD/MTU (75% Power)	Max W(z) at 150 MWD/MTU (100% Power)	Max W(z) at 2000 MWD/MTU (100% Power)	Max W(z) at 4000 MWD/MTU (100% Power)	Max W(z) at 8000 MWD/MTU (100% Power)	Max W(z) at 12000 MWD/MTU (100% Power)	Max W(z) at 16000 MWD/MTU (100% Power)
12.0720	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
11.8708	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
11.6696	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
11.4684	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
11.2672	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
11.0660	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
10.8648	1.2400	1.2668	1.1709	1.2105	1.2056	1.1685	1.1536	1.1475
10.6636	1.2317	1.2490	1.1671	1.2043	1.1950	1.1611	1.1479	1.1471
10.4624	1.2260	1.2347	1.1640	1.2038	1.1976	1.1591	1.1403	1.1458
10.2612	1.2171	1.2200	1.1611	1.2003	1.1951	1.1559	1.1399	1.1440
10.0600	1.2078	1.2082	1.1597	1.1943	1.1962	1.1544	1.1398	1.1424
9.8588	1.1977	1.1951	1.1630	1.1877	1.1952	1.1543	1.1391	1.1484
9.6576	1.1833	1.1800	1.1645	1.1802	1.1922	1.1566	1.1377	1.1552
9.4564	1.1639	1.1647	1.1639	1.1833	1.1961	1.1572	1.1433	1.1593
9.2552	1.1536	1.1566	1.1695	1.1830	1.1911	1.1564	1.1552	1.1682
9.0540	1.1466	1.1504	1.1790	1.1830	1.1870	1.1547	1.1674	1.1752
8.8528	1.1284	1.1466	1.1843	1.1836	1.1844	1.1510	1.1763	1.1787
8.6516	1.1151	1.1421	1.1888	1.1887	1.1859	1.1499	1.1880	1.1799
8.4504	1.1078	1.1436	1.1999	1.1941	1.1903	1.1603	1.2048	1.1829
8.2492	1.1120	1.1563	1.2130	1.1983	1.1938	1.1760	1.2206	1.1937
8.0480	1.0973	1.1513	1.2233	1.2003	1.1950	1.1886	1.2344	1.2042
7.8468	1.0922	1.1558	1.2311	1.2004	1.1946	1.1990	1.2458	1.2159
7.6456	1.0891	1.1588	1.2349	1.1975	1.1913	1.2063	1.2538	1.2288
7.4444	1.0835	1.1593	1.2366	1.1934	1.1867	1.2118	1.2598	1.2393
7.2432	1.0789	1.1596	1.2358	1.1886	1.1799	1.2148	1.2624	1.2465
7.0420	1.0748	1.1584	1.2334	1.1828	1.1730	1.2158	1.2626	1.2512
6.8408	1.0712	1.1562	1.2286	1.1790	1.1692	1.2147	1.2604	1.2536
6.6396	1.0649	1.1506	1.2216	1.1750	1.1651	1.2118	1.2560	1.2532
6.4384	1.0611	1.1460	1.2136	1.1703	1.1602	1.2076	1.2498	1.2516
6.2372	1.0557	1.1400	1.2045	1.1647	1.1544	1.2019	1.2414	1.2478
6.0360	1.0519	1.1333	1.1937	1.1592	1.1470	1.1944	1.2311	1.2418
5.8348	1.0435	1.1232	1.1809	1.1553	1.1426	1.1851	1.2185	1.2337
5.6336	1.0404	1.1169	1.1691	1.1509	1.1385	1.1745	1.2042	1.2238
5.4324	1.0441	1.1160	1.1647	1.1468	1.1363	1.1634	1.1895	1.2107
5.2312	1.0521	1.1195	1.1639	1.1444	1.1365	1.1625	1.1885	1.2032
5.0300	1.0607	1.1221	1.1620	1.1437	1.1377	1.1643	1.1877	1.2020
4.8288	1.0676	1.1240	1.1598	1.1447	1.1394	1.1647	1.1855	1.1983
4.6276	1.0769	1.1277	1.1589	1.1462	1.1413	1.1642	1.1821	1.1933
4.4264	1.0876	1.1320	1.1577	1.1470	1.1425	1.1627	1.1776	1.1870
4.2252	1.0942	1.1332	1.1555	1.1470	1.1430	1.1603	1.1719	1.1796
4.0240	1.0995	1.1342	1.1523	1.1462	1.1428	1.1567	1.1652	1.1712
3.8228	1.1095	1.1355	1.1486	1.1451	1.1422	1.1536	1.1576	1.1613
3.6216	1.1206	1.1387	1.1472	1.1434	1.1413	1.1507	1.1535	1.1555
3.4204	1.1340	1.1460	1.1503	1.1431	1.1393	1.1503	1.1509	1.1512
3.2192	1.1541	1.1563	1.1548	1.1450	1.1418	1.1502	1.1486	1.1521
3.0180	1.1715	1.1670	1.1618	1.1468	1.1550	1.1535	1.1556	1.1565
2.8168	1.2045	1.1904	1.1797	1.1598	1.1761	1.1647	1.1700	1.1693
2.6156	1.2427	1.2191	1.2033	1.1849	1.1991	1.1775	1.1828	1.1870
2.4144	1.2791	1.2458	1.2262	1.2086	1.2217	1.1895	1.1957	1.2032
2.2132	1.3138	1.2739	1.2492	1.2330	1.2445	1.2016	1.2085	1.2197
2.0120	1.3571	1.3028	1.2724	1.2575	1.2674	1.2133	1.2205	1.2349
1.8108	1.3973	1.3319	1.2951	1.2816	1.2898	1.2242	1.2316	1.2487
1.6096	1.4326	1.3573	1.3160	1.3039	1.3105	1.2341	1.2417	1.2615
1.4084	1.4736	1.3828	1.3350	1.3243	1.3293	1.2431	1.2513	1.2737
1.2072	1.5094	1.4059	1.3524	1.3427	1.3462	1.2510	1.2600	1.2852
1.0060	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.8048	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.6036	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.4024	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.2012	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Table A.2
 $F_Q^W(Z)$ Penalty Factor

Burnup (MWD/MTU)	Penalty Factor
448	1.0200
597	1.0205
746	1.0221
895	1.0235
1043	1.0227
1192	1.0200

Note:

1. The Penalty Factor, which is applied to $F_Q^W(Z)$ for compliance with Surveillance Requirement 3.2.1.2, is the maximum factor by which $F_Q^W(Z)$ is expected to increase per 31 Effective Full Power Days (EFPD) starting from the burnup at which the $F_Q^W(Z)$ was determined.