



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

**REGION IV
1600 EAST LAMAR BOULEVARD
ARLINGTON, TEXAS 76011-4511**

May 6, 2019

Mr. Brad Sawatzke, Chief Executive Officer
Energy Northwest
MD 1023
P.O. Box 968
Richland, WA 99352

**SUBJECT: COLUMBIA GENERATING STATION – NRC INTEGRATED INSPECTION
REPORT 05000397/2019001**

Dear Mr. Sawatzke:

On March 31, 2019, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at your Columbia Generating Station. On April 11, 2019, the NRC inspectors discussed the results of this inspection with Mr. A. Javorik, Vice President of Engineering, and other members of your staff. The results of this inspection are documented in the enclosed report.

NRC inspectors documented one finding of very low safety significance (Green) in this report. The finding did not involve a violation of NRC requirements.

If you disagree with a cross-cutting aspect assignment or a finding not associated with a regulatory requirement in this report, you should provide a response within 30 days of the date of this inspection report, with the basis for your disagreement, to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555-0001; with copies to the Regional Administrator, Region IV; and the NRC resident inspector at the Columbia Generating Station.

This letter, its enclosure, and your response (if any) will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document

Room in accordance with 10 CFR 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Sincerely,

/RA/

Mark S. Haire, Branch Chief
Project Branch A
Division of Reactor Projects

Docket No. 05000397
License No. NPF-21

Enclosure:
Inspection Report 05000397/2019001
w/attachment: Documents Reviewed

**U.S. NUCLEAR REGULATORY COMMISSION
Inspection Report**

Docket Number(s): 05000397

License Number(s): NPF-21

Report Number(s): 05000397/2019001

Enterprise Identifier: I-2019-001-0010

Licensee: Energy Northwest

Facility: Columbia Generating Station

Location: North Power Plant Loop
Richland, WA 99354

Inspection Dates: January 1, 2019, to March 31, 2019

Inspectors: G. Kolcum, Senior Resident Inspector
L. Merker, Senior Resident Inspector
R. Alexander, Senior Project Engineer
E. Combs, Project Engineer/Acting Resident Inspector
P. Elkmann, Senior Emergency Preparedness Inspector

Approved By: Mark S. Haire, Chief
Project Branch A
Division of Reactor Projects

SUMMARY

The U.S. Nuclear Regulatory Commission (NRC) continued monitoring the licensee’s performance by conducting a Quarterly inspection at Columbia Generating Station in accordance with the Reactor Oversight Process. The Reactor Oversight Process is the NRC’s program for overseeing the safe operation of commercial nuclear power reactors. Refer to <https://www.nrc.gov/reactors/operating/oversight.html> for more information. Findings being considered in the NRC’s assessment are summarized in the table below.

List of Findings and Violations

| | | | |
|--|--|----------------------------------|----------------|
| Failure to Enter the Operational Decision-Making Process for a Condition Reducing Operating Margin in Accordance with Station Procedures | | | |
| Cornerstone | Significance | Cross-cutting Aspect | Report Section |
| Initiating Events | Green FIN 05000397/2019001-01 Closed | [H.14] - Conservative Bias | 71111.13 |
| The inspectors identified a Green finding for the licensee’s failure to adhere to station procedure, Plant Procedures Manual 1.3.67, “Operational Decision-Making Process,” Revision 17, Step 6.1, for a condition that creates an actual or potential reduction in operating or design margin. Specifically, the station failed to enter the Operational Decision-Making (ODM) process for degraded startup auxiliary power transformer oil level that reduced operating margin. This resulted in a lockout of the transformer requiring an unplanned entry into Technical Specification 3.8.1, “AC Sources – Operating,” Condition A for one offsite circuit inoperable and elevation of plant risk level to Orange Risk for emergent maintenance. | | | |

Additional Tracking Items

| Type | Issue Number | Title | Report Section | Status |
|------|---------------------|--|----------------|--------|
| LER | 05000397/2018001-00 | Automatic Reactor Scram Due to Main Transformer Trip | 71153 | Closed |
| LER | 05000397/2018001-01 | Automatic Reactor Scram Due to Main Transformer Trip | 71153 | Closed |

PLANT STATUS

The plant began the inspection period at 100 percent rated thermal power.

On January 12, 2019, the unit was down powered to 65 percent to perform a control rod sequence exchange. Reactor power returned to 100 percent on January 13, 2019.

On January 21, 2019, the unit was down powered to 65 percent due to condensate booster pump 2C discharge check valve COND-V-119C leakage. Reactor power returned to 100 percent on January 24, 2019, and remained at or near rated thermal power for the remainder of the inspection period.

INSPECTION SCOPES

Inspections were conducted using the appropriate portions of the inspection procedures (IPs) in effect at the beginning of the inspection unless otherwise noted. Currently approved IPs with their attached revision histories are located on the public website at

<http://www.nrc.gov/reading-rm/doc-collections/insp-manual/inspection-procedure/index.html>.

Samples were declared complete when the IP requirements most appropriate to the inspection activity were met consistent with Inspection Manual Chapter (IMC) 2515, "Light-Water Reactor Inspection Program - Operations Phase." The inspectors performed plant status activities described in IMC 2515, Appendix D, "Plant Status," and conducted routine reviews using IP 71152, "Problem Identification and Resolution." The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel to assess licensee performance and compliance with Commission rules and regulations, license conditions, site procedures, and standards.

REACTOR SAFETY

71111.01 - Adverse Weather Protection

Impending Severe Weather Sample (IP Section 03.03) (2 Samples)

- (1) The inspectors evaluated readiness for impending adverse weather conditions for extreme cold weather during the week of February 4, 2019.
- (2) The inspectors evaluated readiness for impending adverse weather conditions for winds greater than 30 mph during a snowstorm, on February 9, 2019.

External Flooding Sample (IP Section 03.04) (1 Sample)

The inspectors evaluated readiness to cope with external flooding for the standby service water pump rooms, on February 15, 2019.

71111.04 - Equipment Alignment

Partial Walkdown (IP Section 02.01) (4 Samples)

The inspectors evaluated system configurations during partial walkdowns of the following systems/trains:

- (1) 125V dc system, on January 11, 2019
- (2) reactor core isolation coolant system lineup with diesel generator 3 maintenance, on January 28, 2019
- (3) seismic monitoring system on February 28, 2019
- (4) standby service water system A with standby service water system B inoperability, on March 22, 2019

71111.04S - Equipment Alignment

Complete Walkdown (IP Section 02.02) (1 Sample)

The inspectors evaluated system configurations during a complete walkdown of the 125/250 VDC breaker lineup system on February 8, 2019.

71111.05Q - Fire Protection

Quarterly Inspection (IP Section 03.01) (5 Samples)

The inspectors evaluated fire protection program implementation in the following selected areas:

- (1) Fire Area RC-4/1: Electrical Equip and RPS Rooms Division 1, on February 8, 2019
- (2) Fire Area RC-5/1: Battery and Security Equip Rooms Division 1, on February 15, 2019
- (3) Fire Area RC-6/2: Battery Room Division 2, on February 22, 2019
- (4) Fire Area RC-7/2: Electrical Equip and RPS Rooms Division 2, on March 1, 2019
- (5) Fire Area RC-14, SM-7: Switchgear Room Division 1, on March 18, 2019

71111.06 - Flood Protection Measures

Inspection Activities - Internal Flooding (IP Section 02.02a.) (1 Sample)

The inspectors evaluated internal flooding mitigation protections in the Division 1 and Division 2 switchgear rooms, on March 8, 2019.

71111.11Q - Licensed Operator Requalification Program and Licensed Operator Performance

Licensed Operator Performance in the Actual Plant/Main Control Room (IP Section 03.01) (1 Sample)

The inspectors observed and evaluated licensed operator performance in the Control Room during a down-power and removal of the 2C condensate booster pump for maintenance on January 21, 2019, and restart of the 2C condensate booster pump on January 24, 2019.

Licensed Operator Requalification Training/Examinations (IP Section 03.02) (1 Sample)

The inspectors observed and evaluated the licensed operator requalification evaluated scenario (Crew C) on January 14, 2019.

71111.12 - Maintenance Effectiveness

Routine Maintenance Effectiveness Inspection (IP Section 02.01) (4 Samples)

The inspectors evaluated the effectiveness of routine maintenance activities associated with the following equipment and/or safety significant functions:

- (1) standby service water system A planned maintenance, week of January 7, 2019
- (2) condensate booster pump 2C discharge check valve packing leakage, on January 21, 2019
- (3) startup transformer lockout due to low oil level, on February 7, 2019
- (4) residual heat removal system A pump and motor replacement, on March 29, 2019

71111.13 - Maintenance Risk Assessments and Emergent Work Control

Risk Assessment and Management Sample (IP Section 03.01) (8 Samples)

The inspectors evaluated the risk assessments for the following planned and emergent work activities:

- (1) yellow risk due to standby service water system A planned maintenance, week of January 7, 2019
- (2) high risk troubleshooting of control room reactor vessel wide range water level, on January 18, 2019
- (3) yellow risk due to diesel generator 3 planned maintenance, week of January 27, 2019
- (4) high risk work during lifting and landing leads for scram discharge volume trip transmitter, on February 1, 2019
- (5) orange risk due to start up transformer lockout caused by low oil level, on February 7, 2019
- (6) high risk lift plan for new fuel receipt, on February 18, 2019
- (7) yellow plant risk and blue fire risk due to diesel generator 2 out-of-service for planned major maintenance, on March 18, 2019
- (8) yellow risk for standby service water pump 1B maintenance, on March 23, 2019

71111.15 - Operability Determinations and Functionality Assessments

Sample Selection (IP Section 02.01) (7 Samples)

The inspectors evaluated the following operability determinations and functionality assessments:

- (1) diverse and flexible coping strategy (FLEX) components environmental qualifications for site extreme temperatures, on January 15, 2019
- (2) reactor level switch MS-LS-300C and reactor level indicating switch MS-LIS-200C operability, on January 18, 2019
- (3) main steam isolation valve indication during surveillance, on January 23, 2019
- (4) low oil level in startup transformer, on February 7, 2019
- (5) diesel generator 1 governor setting, on March 1, 2019
- (6) vital island fire detector fault, on March 8, 2019
- (7) standby service water pump 1B failure to run, on March 22, 2019

71111.18 - Plant Modifications

Temporary Modifications and/or Permanent Modifications (IP Section 03.01 and/or 03.02) (1 Sample)

The inspectors evaluated permanent modification Engineering Change (EC) 15891, seismic monitoring system replacement, on March 21, 2019.

71111.19 - Post Maintenance Testing

Post Maintenance Test Sample (IP Section 03.01) (9 Samples)

The inspectors evaluated the following post maintenance tests:

- (1) standby service water pump room fan 1A, on January 7, 2019
- (2) standby service water pump A, on January 9, 2019
- (3) low-pressure core spray water leg pump, on January 10, 2019
- (4) condensate booster pump 2C, discharge check valve packing maintenance run, on January 23, 2019
- (5) circulating water pump B, on January 28, 2019
- (6) high voltage power supply replacement of intermediate range channel F monitor, on January 29, 2019

- (7) rod drive control system post maintenance testing, on February 15, 2019
- (8) diesel fire pump leak on coupling during pump run, on February 18, 2019
- (9) standby service water pump 1B, on March 23, 2019

71111.22 - Surveillance Testing

The inspectors evaluated the following surveillance tests:

In Service Testing (IST) (IP Section 03.01) (1 Sample)

The inspectors evaluated OSP-SLC/IST-Q701, standby liquid control pumps operability test, on January 15, 2019.

Surveillance Testing (IP Section 03.01) (4 Samples)

- (1) PPM OSP-SW-M101, perform standby service water pump A flow balance, on January 8, 2019
- (2) OSP-CCH/IST-M701, control room emergency chiller system A operation, on January 9, 2019
- (3) OSP-ELEC-M701, diesel generator 1 monthly operation, on January 9, 2019
- (4) OSP-ELEC-M702, diesel generator 2 monthly operation, on January 22, 2019

71114.02 - Alert and Notification System Testing

Inspection Review (IP Section 02.01-02.04) (1 Sample)

The inspectors evaluated the maintenance and testing of the licensee's offsite alert and notification system for the public on January 31, 2019.

71114.03 - Emergency Response Organization Staffing and Augmentation System

Inspection Review (IP Section 02.01-02.02) (1 Sample)

The inspectors evaluated the staffing and readiness of the licensee's Emergency Preparedness Organization on January 31, 2019.

71114.04 - Emergency Action Level and Emergency Plan Changes

Inspection Review (IP Section 02.01-02.03) (1 Sample)

The inspectors evaluated the following submitted Emergency Action Level and Emergency Plan changes:

- Columbia Generating Station Emergency Plan, Revision 66
- EPIP 13.1.1A, "Classifying the Emergency, Technical Bases," Revision 34

This evaluation does not constitute NRC approval.

71114.05 - Maintenance of Emergency Preparedness

Inspection Review (IP Section 02.01 - 02.11) (1 Sample)

The inspectors evaluated the licensee's maintenance of their emergency preparedness program on January 28 and 29, 2019.

71114.06 - Drill Evaluation

Emergency Preparedness (EP) Drill (IP Section 02.01) (1 Sample)

The inspectors evaluated the emergency planning drill on February 19, 2019.

OTHER ACTIVITIES – BASELINE

71151 - Performance Indicator Verification

The inspectors verified licensee performance indicators listed below:

IE01: Unplanned Scrams per 7000 Critical Hours Sample (IP Section 02.01) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

IE03: Unplanned Power Changes per 7000 Critical Hours Sample (IP Section 02.02) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

IE04: Unplanned Scrams with Complications (USwC) Sample (IP Section 02.03) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

Drill/Exercise Performance (IP Section 02.12) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

ERO Drill Participation (IP Section 02.13) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

Alert & Notification System Reliability (IP Section 02.14) (1 Sample)

Date Range: January 1, 2018, through December 31, 2018

71152 - Problem Identification and Resolution

Annual Follow-up of Selected Issues (IP Section 02.03) (2 Samples)

The inspectors reviewed the licensee's implementation of its corrective action program related to the following issues:

- (1) root cause evaluation for the May 18, 2018, reactor scram
- (2) evaluation of the December 13, 2018, reactor core isolation cooling system minimum flow valve, RCIC-V-19, trip on thermal overloads

71153 - Followup of Events and Notices of Enforcement Discretion

Event Report (IP Section 03.02) (2 Samples)

The inspectors evaluated the following Licensee Event Reports (LERs) which can be accessed at <https://lersearch.inl.gov/LERSearchCriteria.aspx>:

- (1) LER 0500397/2018-001-00, Automatic Reactor Scram Due to Main Transformer Trip, on May 18, 2018.

The inspectors determined it was not reasonable to foresee or correct the cause discussed in the LER; therefore, no performance deficiency was identified. The inspectors also concluded that no violation of NRC requirements occurred.

- (2) LER 0500397/2018-001-01, Automatic Reactor Scram Due to Main Transformer Trip, on May 18, 2018.

The inspectors reviewed the updated LER submittal. The inspectors determined that it was not reasonable to foresee or correct the cause discussed in the LER; therefore, no performance deficiency was identified. The inspectors also concluded that no violation of NRC requirements occurred.

INSPECTION RESULTS

| Failure to Enter the Operational Decision-Making Process for a Condition Reducing Operating Margin in Accordance with Station Procedures | | | |
|--|--|----------------------------------|----------------|
| Cornerstone | Significance | Cross-cutting Aspect | Report Section |
| Initiating Events | Green FIN 05000397/2019001-01 Closed | [H.14] - Conservative Bias | 71111.13 |
| <p>The inspectors identified a Green finding for the licensee’s failure to adhere to station procedure, Plant Procedures Manual 1.3.67, “Operational Decision-Making Process,” Revision 17, Step 6.1, for a condition that creates an actual or potential reduction in operating or design margin. Specifically, the station failed to enter the Operational Decision-Making (ODM) process for degraded startup auxiliary power transformer oil level that reduced operating margin. This resulted in a lockout of the transformer requiring an unplanned entry into Technical Specification 3.8.1, “AC Sources – Operating,” Condition A for one offsite circuit inoperable and elevation of plant risk level to Orange Risk for emergent maintenance.</p> <p><u>Description:</u> At 4:07 a.m. on February 7, 2019, the plant entered abnormal procedures ABN-Transformer and ABN-Grid after the startup auxiliary power transformer, E-TR-S, locked out on low oil level. An operator in the field reported the oil level out-of-sight low with no observable oil leakage in the vicinity of the transformer.</p> <p>The licensee determined a significant decrease in oil volume occurred as already sub-freezing outside temperatures dropped an additional 15°F that night. Because the pre-event level was already below the normal operating band, the level change due to temperature was sufficient to lockout the transformer on low oil level.</p> <p>The inspectors’ review of the transformer yard logs found that E-TR-S oil level had been consistently recorded through the operating cycle as low in the indicating range, just above the alarm setpoint. Action Reports for alarms received during winter months in previous years indicate that the low temperatures of winter periodically caused the oil volume to shrink to the point of causing an oil level alarm. This phenomenon was a known issue and a nuisance to operators. Those Action Reports were either closed as being complete or closed to trending with no actionable assignments made. Work Requests related to oil addition to the transformer were deferred to the R24 Refueling Outage with the contingency to add oil online.</p> <p>Plant Procedures Manual (PPM) 1.3.67, “Operational Decision-Making (ODM) Process,” provides “a systematic method for making operational decisions that could significantly challenge plant safety, reduce operating margins, threaten generation, or pose risks to personnel or equipment.” It is intended to “be performed when there is an actual or potential reduction in operating or design margin.” Maintaining the E-TR-S oil level low outside the normal operating band reduced the operating margin by increasing the transformer’s susceptibility to weather induced level fluctuations with the potential to cause a lockout. Yet, the licensee failed to enter the ODM process to address this reduction in operating margin during the several month period where the transformer oil level was consistently recorded as low. Operators should have entered the ODM process and corrected the low oil level condition to prevent the low temperatures from causing the level to shrink to the point that a transformer low oil level lockout occurred.</p> | | | |

Corrective Action(s): The licensee coordinated with Bonneville Power Authority to add oil to E-TR-S. Additional corrective actions include assignments to revise the transformer yard logs to reflect the markings on the level instruments for both startup and backup transformers and to align the methods used by Engineering and Operations to more accurately record and track transformer oil levels.

Corrective Action Reference(s): Action Reports 389753, 389843, 374476, 387608, and 376707

Performance Assessment:

Performance Deficiency: The failure to adhere to station procedures was a performance deficiency.

Screening: The inspectors determined the performance deficiency was more than minor because it could reasonably be viewed as a precursor to a significant event. The inspectors determined the performance deficiency was more than minor because it adversely affected the Equipment Performance attribute of the Initiating Events cornerstone and its objective to limit the frequency of those events and operations that upset plant stability and challenge critical safety functions, during shutdown as well as power operations. Specifically, the failure to enter a chronic, degraded startup auxiliary power transformer oil level condition that reduced the plant operational margin into the ODM process for tracking and resolution resulted in an unexpected lockout of the transformer on low oil level caused by fluctuation in volume due to cold weather conditions. Loss of the startup auxiliary power transformer resulted in an abnormal electrical distribution and left the backup auxiliary power transformer as the only remaining offsite power source, therefore elevating plant risk level to Orange Risk.

Significance: The inspectors assessed the significance of the finding using Appendix A, "Significance Determination of Reactor Inspection Findings for At - Power Situations." Using the questions in Exhibit 1, "Initiating Events Screening Questions," the finding was determined to be of very low safety significance (Green) because (1) the finding did not result in exceeding the reactor coolant system leak rate for a small loss-of-coolant-accident and (2) did not affect other systems used to mitigate a loss-of-coolant-accident resulting in a total loss of their function.

Cross-cutting Aspect: H.14 - Conservative Bias: Individuals use decision-making-practices that emphasize prudent choices over those that are simply allowable. A proposed action is determined to be safe in order to proceed, rather than unsafe in order to stop. Rather, in this situation the licensee tolerated a degraded condition that reduced operating margin for operational convenience as opposed to identifying the issue as a challenge to plant reliability and entering it into the ODM process for higher visibility, tracking, and resolution.

Enforcement: Inspectors did not identify a violation of regulatory requirements associated with this finding.

EXIT MEETINGS AND DEBRIEFS

The inspectors verified no proprietary information was retained or documented in this report.

- On January 31, 2019, the inspectors presented the results of the emergency preparedness inspection results to Mr. B. Schuetz, Site Vice President, and other members of the licensee staff.
- On April 11, 2019, the inspectors presented the integrated inspection results for the quarter to Mr. A. Javorik, Vice President of Engineering, and other members of the licensee staff.

DOCUMENTS REVIEWED

71111.01 – Adverse Weather Protection

| Procedures Number | Title | Revision |
|-----------------------------|----------------------------|----------|
| 1.3.76 | Integrated Risk Management | 054 |
| ABN-FLOODING | Flooding | 020 |
| ABN-WIND | Tornado/High Winds | 032 |
| SOP- COLDWEATHER- OPS | Cold Weather Operations | 032 |

71111.04 – Equipment Alignment

| Procedures Number | Title | Revision |
|----------------------------|--|----------|
| ABN- EARTHQUAKE | Earthquake | 014 |
| ABN-ELEC- 125VDC | Plant BOP, Div 1,2, & 3 125 VDC Distribution System Failures | 015 |
| ABN-ELEC- 24VDC | Plant 24VDC Distribution System Failures | 005 |
| ABN-ELEC- 250VDC | Plant 250VDC Distribution System Failures | 004 |
| OSP-SW-M101 | Standby Service Water Loop A Valve Position Verification | 039 |
| SOP-ELEC-125V- OPS | 125 VDC System Operation | 003 |
| SOP-ELEC-125V- SHUTDOWN | 125 VDC System Shutdown | 003 |
| SOP-ELEC-125V- START | 125 VDC System Start | 009 |
| SOP-ELEC-24V- OPS | 24 VDC System Operations | 004 |
| SOP-ELEC-24V- SHUTDOWN | 24 VDC System Shutdown | 002 |
| SOP-ELEC-24V- START | 24 VDC System Start | 003 |
| SOP-ELEC-250V- OPS | 250 VDC System Operations | 002 |

| | | |
|----------------------------|---------------------------------------|-----|
| SOP-ELEC-250V- SHUTDOWN | 250 VDC System Shutdown | 001 |
| SOP-ELEC-250V- START | 250 VDC Startup of the 250 VDC System | 002 |

Miscellaneous Documents

| Number | Title | Revision |
|-------------|------------------------------------|----------|
| EC 15891 | Seismic System Replacement | 001 |
| LCS 1.3.7.2 | Seismic Monitoring Instrumentation | 073 |

71111.05 – Fire Protection Annual/Quarterly

| Procedures Number | Title | Revision |
|---------------------|---|----------|
| 1.3.10 | Plant Fire Protection Program Implementation | 034 |
| 1.3.10A | Control of Ignition Sources | 017 |
| 1.3.10B | Active Fire System Operability and Impairment Control | 016 |
| 1.3.10C | Control of Transient Combustibles | 020 |
| 1.3.85 | On-Line Fire Risk Management | 005 |
| SOP-FP-DRAIN | Fire Protection System Drain | 001 |
| SOP-FP-FILL | Fire Protection System Fill | 003 |
| SOP-FP-LU | Fire Protection System Valve and Breaker Lineup | 009 |
| SOP-FP-OPS | Fire Protection System Operations | 015 |
| SOP-FP- SHUTDOWN | Fire Protection System Shutdown | 006 |
| SOP-FP-START | Fire Protection System Startup | 006 |

Miscellaneous Documents

| Number | Title | Revision |
|---------|---|----------|
| RC-14/1 | Pre-Fire Plan: Radwaste 467' Division 1 Switchgear Room | 003 |

71111.06 – Flood Protection Measures

| Procedures Number | Title | Revision |
|-------------------|--|----------|
| 1.3.57 | Barrier Impairment | 037 |
| ABN-FLOODING | Flooding | 020 |
| FSAR-01 | Final Safety Analysis Report | 064 |
| ISP-FED-X301 | ECCS Pump Room Flood Level – Calibration | 003 |

71111.11 – Licensed Operator Requalification Program and Licensed Operator Performance

| Procedures Number | Title | Revision |
|-------------------|---|----------|
| 3.3.1-QC | Reactor Scram Quick Card | 001 |
| 3.3.1 | Reactor Scram | 065 |
| 5.1.1 | RPV Control | 021 |
| 5.1.3 | Emergency RPV Depressurization | 021 |
| 5.2.1 | Primary Containment Control | 027 |
| 5.3.1 | Secondary Containment Control | 020 |
| 5.5.25 | Alternate Injection Using the SLC System | 006 |
| 13.1.1 | Classifying the Emergency | 049 |
| 13.1.1A | Classifying the Emergency Technical Bases | 034 |
| ABN-CORE | Unplanned Core Operating Conditions | 017 |
| ABN-FLOODING | Flooding | 020 |
| OI-09 | Operations Standards and Expectation | 070 |

Miscellaneous Documents

| Number | Title | Revision |
|----------|--|----------|
| | Crew C Evaluated Scenario Cycle 19-1, 4.0 Critique Summary | 000 |
| LR002447 | Cycle 19-1 Evaluated Scenario | 000 |

71111.12 – Maintenance Effectiveness

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 389079 | 389087 | 389183 | 389224 | 389753 |
| 375957 | 374476 | 387700 | | |

Work Orders

| | | | | | | |
|----------|----------|----------|----------|----------|----------|----------|
| 02126449 | 02084428 | 02114328 | 02116386 | 02087947 | 02138264 | 02042797 |
| 02072877 | 29155963 | | | | | |

Drawings

| Number | Title | Revision |
|------------|---|----------|
| 43-00.84.2 | Cast Steel Swing Check Valve ASME Class 600 | 001 |
| M504-1 | Flow Diagram Condensate and Feed Water Systems (Condensate) | 111 |

71111.13 – Maintenance Risk Assessments and Emergent Work Control

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 388934 | 388951 | 389016 | 389111 | 384850 |
|--------|--------|--------|--------|--------|

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 389115 | 389182 | 365352 | 389753 | 391347 |
| 391337 | 391352 | | | |

Work Orders

| | | | |
|----------|----------|----------|----------|
| 02118830 | 02138131 | 02138018 | 02138019 |
|----------|----------|----------|----------|

Procedures

| Number | Title | Revision |
|--------------------|---|----------|
| 1.3.10 | Plant Fire Protection Program Implementation | 034 |
| 1.3.76 | Integrated Risk Management | 052 |
| 1.3.76 | Integrated Risk Management | 054 |
| 1.3.83 | Protected Equipment Program | 029 |
| ABN-ELEC-GRID | Degraded Off Site Power Grid | 011 |
| ABN-TRANSFORMER | Transformer Abnormal Operation | 024 |
| SOP-ELEC-230KV-OPS | Removing/Restoring TR-S, From/To Service | 006 |
| SOP-ELEC-4160V-OPS | 4160 Volt AC Electrical Power Distribution System Operation | 016 |
| SWP-MAI-03 | Emergent Issue Management | 013 |

71111.15 – Operability Determinations and Functionality Assessments

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 388768 | 381457 | 388934 | 388951 | 389016 |
| 389111 | 384850 | 389115 | 389182 | 365352 |
| 390459 | 390460 | 390461 | 389753 | 375957 |
| 374476 | 390732 | 391347 | 391337 | 391352 |

Work Orders

| | | | |
|----------|----------|----------|----------|
| 02118830 | 02138131 | 29155963 | 29147704 |
|----------|----------|----------|----------|

Procedures

| Number | Title | Revision |
|---------------|---|----------|
| 4.603.A7 | 603.A7 Annunciator Panel Alarms | 054 |
| ABN-BKR-FAULT | Failure of MOC Switch Activation for Safety Related Breakers | 002 |
| ABN-FSG-002 | Water Makeup Strategies for RPV, SFP, DW, WW During an Extended Loss of AC Power or Other Beyond Design Basis Event | 005 |
| ABN-FSG-002 | Water Makeup Strategies for RPV, SFP, DW, WW During an Extended Loss of AC Power or Other Beyond Design Basis Event | 006 |
| ABN-FSG-002 | Water Makeup Strategies for RPV, SFP, DW, WW During an | 007 |

| Procedures Number | Title | Revision |
|-------------------|--|----------|
| | Extended Loss of AC Power or Other Beyond Design Basis Event | |
| ABN-SW | Service Water Trouble | 015 |

| Drawings Number | Title | Revision |
|-----------------|--|----------|
| EWD-15E-045 | Electrical Wiring Diagram Reactor Protection System CRD-LT-12C & MS-LT-61C | 003 |
| EWD-15E-017 | Electrical Wiring Diagram Reactor Protection System Scram Discharge Volume High Water Level | 000 |
| EWD-15E-47C | Electrical Wiring Diagram Reactor Protection System Power Panel RPS-PP-C72/P001 Circuit Detail | 001 |

71111.18 – Plant Modifications

Action Reports

| | |
|--------|--------|
| 391305 | 391308 |
|--------|--------|

| Procedures Number | Title | Revision |
|-------------------|---|----------|
| 13.1.1a | Classifying the Emergency – Technical Bases | 034 |
| 13.14.11 | EP Equipment | 013 |
| ABN-EARTHQUAKE | Earthquake | 013 |
| ABN-EARTHQUAKE | Earthquake | 014 |
| ISP-SEIS-X308 | Seismic System Channel Calibration | 002 |

Miscellaneous Documents

| Number | Title | Revision |
|-------------|------------------------------------|----------|
| EC 15891 | Seismic System Replacement | 001 |
| LCS 1.3.7.2 | Seismic Monitoring Instrumentation | 073 |

71111.19 – Post Maintenance Testing

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 390045 | 390058 | 389996 | 391347 | 391337 |
| 391352 | | | | |

Work Orders

| | | | | | | |
|----------|----------|----------|----------|----------|----------|----------|
| 02136285 | 02117702 | 02117263 | 02129637 | 02129644 | 02136433 | 02139024 |
| 02138999 | 02109071 | | | | | |

| Procedures Number | Title | Revision |
|-------------------|--|----------|
| ISP-IRM-X306 | Intermediate Range Monitor Channel F Calibration | 012 |
| OSP-LPCS-A702 | Low Pressure Core Spray Keep Fill Integrity Test | 003 |
| OSP-SW/IST-Q702 | Standby Service Water Loop B Operability | 034 |

71111.22 – Surveillance Testing

Work Orders

| | | | | |
|----------|----------|----------|----------|----------|
| 02129604 | 02129646 | 02136285 | 02130187 | 02117438 |
|----------|----------|----------|----------|----------|

71114.02 – Alert and Notification Systems Testing

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 360339 | 360457 | 366785 | 368711 | 369725 |
| 371570 | 372186 | 372307 | 373723 | 384925 |
| 385894 | 388026 | | | |

| Procedures | Title | Revision |
|--------------|--|----------|
| EPIP 13.14.4 | Emergency Equipment Maintenance and Testing | 054 |
| EPI-14 | Actions in the event of an Automated Notification System Failure | 008 |

Miscellaneous Documents

| Title | Date |
|---|------------|
| Columbia Generating Station Alert and Notification System Design Report, Revision 2 | 11/15/2016 |
| Preventative Maintenance Records for Alert and Notification System Sirens | 2018 |

71114.03 – Emergency Response Organization Staffing and Augmentation

Action Reports

| | | |
|--------|--------|--------|
| 371855 | 371856 | 371868 |
|--------|--------|--------|

| Procedures Number | Title | Revision |
|-------------------|-------------------------------|----------|
| EPIP 13.4.1 | Emergency Notifications | 042, 043 |
| EPIP 13.14.9 | Emergency Program Maintenance | 029 |
| EPI-11 | ERO Administration Program | 008 |

| Miscellaneous Documents | Title | Date |
|-------------------------|--|------------|
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted March 11, 2017 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted May 2, 2017 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted September 27, 2017 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted December 12, 2017 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted March 30, 2018 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted June 20, 2018 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted August 21, 2018 | |
| | Quarterly Autodialer and Pager Notification Drill Results for the drill conducted December 18, 2018 | |
| | After Action Report/Improvement Plan for ERO Team B, Report for the January 17, 2017, Exercise | 02/07/2017 |
| | After Action Report/Improvement Plan for ERO Team D, Report for the March 14, 2017, Exercise | 04/24/2017 |
| | After Action Report/Improvement Plan for ERO Team A, Report for the July 18, 2017, Exercise | 08/15/2017 |
| | After Action Report/Improvement Plan for ERO Team C, Report for the October 31, 2017, Exercise | 11/31/2017 |
| | After Action Report/Improvement Plan for ERO Team C, Report for the February 27, 2018, Exercise | |
| | After Action Report/Improvement Plan for ERO Team C, Report for the March 27, 2018, Exercise | 04/24/2018 |
| | After Action Report/Improvement Plan for ERO Team A, Report for the May 15, 2018, Exercise | |
| | After Action Report/Improvement Plan for ERO Team B, Report for the July 10, 2018, Exercise | |
| | After Action Report/Improvement Plan for ERO Team D, Report for the September 25, 2018, Exercise | |

71114.04 – Emergency Plan and Emergency Action Level Changes

No additional documents were reviewed.

71114.05 – Maintenance of Emergency Preparedness

| Action Reports | | | | |
|----------------|--------|--------|--------|--------|
| 360252 | 360335 | 360588 | 361134 | 361135 |

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 361174 | 361195 | 363014 | 366094 | 366567 |
| 366884 | 367907 | 369130 | 369258 | 369531 |
| 370195 | 372372 | 373237 | 374115 | 375545 |
| 375759 | 375786 | 377563 | 381009 | 381736 |
| 382375 | 382707 | 362053 | 371979 | 375287 |
| 380821 | 362180 | 370962 | 374425 | 380971 |
| 359611 | | | | |

Work Orders

| | | | | | | |
|----------|----------|----------|----------|----------|----------|----------|
| 02107621 | 02083554 | 02096734 | 02096731 | 02103436 | 02109006 | 02105740 |
| 02121618 | 02113624 | 02106177 | 02098392 | 02110759 | 02110805 | |

Procedures

| Number | Title | Revision |
|--------------|--|----------|
| EPIP 13.13.2 | Emergency Event Termination and Recovery Operations | 018 |
| | After-Action Reporting | 010 |
| | Emergency Equipment Maintenance and Testing | 018 |
| EPIP 13.14.8 | Drill and Exercise Program | 018 |
| EPIP 13.14.9 | Emergency Program Maintenance | 029 |
| EPI-08 | Emergency Preparedness Sign Maintenance | 005 |
| EPI-11 | ERO Administration Program | 008 |
| EPI-16 | 50.54(Q) Change Evaluation | 015 |
| EPI-17 | After-Action Report/Improvement Plan Formatting, Distribution, and Retention | 008 |
| EPI-21 | Drill and Exercise Development and Implementation | 018 |
| SWP-ASI-01 | Evaluation of Programs, Processes and Suppliers | 031 |
| 1.3.10 | Plant Fire Protection Program Implementation | 34-1 |

Miscellaneous Documents

| Title | Revision/Date |
|---|---------------|
| Columbia Generating Station Emergency Plan | 066 |
| After Action Report/Improvement Plan for ERO Team B, Report for the January 17, 2017, Exercise | 02/07/2017 |
| After Action Report/Improvement Plan for ERO Team D, Report for the March 14, 2017, Exercise | 04/24/2017 |
| After Action Report/Improvement Plan for ERO Team A, Report for the July 18, 2017, Exercise | 08/15/2017 |
| After Action Report/Improvement Plan for ERO Team C, Report for the October 31, 2017, Exercise | 11/31/2017 |
| After Action Report/Improvement Plan for ERO Team C, Report for the February 27, 2018, Exercise | |
| After Action Report/Improvement Plan for ERO Team C, Report for the March 27, 2018, Exercise | 04/24/2018 |

| Miscellaneous Documents | Title | Revision/ Date |
|-------------------------|--|----------------|
| | After Action Report/Improvement Plan for ERO Team A, Report for the May 15, 2018, Exercise | |
| | After Action Report/Improvement Plan for ERO Team B, Report for the July 10, 2018, Exercise | |
| | After Action Report/Improvement Plan for ERO Team D, Report for the September 25, 2018, Exercise | |
| | After Action Report for the November 28, 2018, First Responder Drill (Contaminated/Injured Man) | |
| AU-EP-17 | Quality Services Audit Report: Emergency Preparedness Program | 02/23/2017 |
| AU-EP-18 | Quality Services Audit Report: Emergency Preparedness Program | 03/12/2018 |
| AU-EP-7 | Checklist #8, Offsite Agency Interfaces | |
| | 2018 Emergency Preparedness Program 12-month Audit Frequency Evaluation | 02/05/2018 |
| | Continuous Monitoring Report SR-18-02, Revision 1, January through May 2018 | 07/05/2018 |
| | Continuous Monitoring Report SR-18-03, June through September 2018 | 10/23/2018 |
| 2017-03 | 50.54(q) Screening and Evaluation, , TSC Administrative Manager Checklist, Revision 5 | 02/28/2017 |
| 2017-16 | 50.54(q) Screening and Evaluation, EPC 26532, Revision 3 | 05/02/2017 |
| 2017-20 | 50.54(q) Screening and Evaluation, SWP-EPP-01, Revision 22 | 02/06/2018 |
| 2017-24 | 50.54(q) Screening and Evaluation, Cassadian Airbus VESTA Communications System Version 5, | 08/02/2017 |
| 2017-25 | 50.54(q) Screening and Evaluation, EPI-27, Revision 2 | 09/07/2017 |
| 2017-27 | 50.54(q) Screening and Evaluation, PPM 13.9.1, Revision 45 and PPM 13.95, Revision 17 | 09/27/2017 |
| 2017-31 | 50.54(q) Screening and Evaluation, EP Siren Site Inspections, Revision 1 | |
| 2018-03 | 50.54(q) Screening and Evaluation, PPM 13.14.11, Revision 13 | 01/09/2018 |
| 2018-04 | 50.54(q) Screening and Evaluation, NRC Liaison Checklist, Revision 3, RPM Checklist, Revision 5, and HPN Communicator Checklist, Revision 1 | 01/31/2018 |
| 2018-17 | 50.54(q) Screening and Evaluation, EAL Technical Bases, Revision 34, Emergency Plan 66, and Emergency Event Termination and Recovery Operations, Revision 18 | 08/14/2018 |
| 2018-21 | 50.54(q) Screening and Evaluation, EOF Manager Checklist, Revision 9 | 06/05/2018 |
| 2018-32 | 50.54(q) Screening and Evaluation, EP 2.003, Onshift | 06/27/2018 |

| Miscellaneous Documents | Title | Revision/Date |
|-------------------------|---|---------------|
| | Staffing Analysis Report | |
| 2018-39 | 50.54(q) Screening and Evaluation, Plant Administrative Manager Checklist, Revision 6 | 08/28/2018 |
| 2018-42 | 50.54(q) Screening and Evaluation, Dose Projection Health Physics Checklist, Revision 4 | 11/13/2018 |
| 2018-45 | 50.54(q) Screening and Evaluation, PPM 13.4.1, Emergency Notifications, Revision 43-5 | 10/08/2018 |
| 2018-46 | 50.54(q) Screening and Evaluation, PPM 13.8.1, Emergency Dose Projection System Operations, Revision 39-1 | 10/09/2018 |
| 2018-50 | 50.54(q) Screening and Evaluation, PPM 13.14.11, Revision 1 | 11/08/2018 |
| | URI-RASCAL Practice Cases (Draft): January 2019, April 2019, August 2019, October 2019, December 2019 | |
| | Just In Time Training Lesson Plan, URI Pathway JITT | 08/15/2018 |
| SA370464 | Snapshot Self Assessment | |
| SA340626 | Focused Self Assessment, Emergency Preparedness Exercise Year Self Assessment | |
| SA371464 | Snapshot Self Assessment | 10/25/2018 |

71114.06 – Drill Evaluation

| Procedures Number | Title | Revision |
|-------------------|---|----------|
| 13.1.1 | Classifying the Emergency | 049 |
| 13.1.1A | Classifying the Emergency-Technical Bases | 034 |
| 13.10.1 | 035 004 2/14/2017 Control Room Operation and Shift Manager Duties | 035 |
| 13.10.14 | Maintenance Manager Duties | 009 |
| 13.10.16 | Chemistry/Effluent Manager Duties | 003 |
| 13.10.17 | TSC Ventilation Radiation Monitor System Operations | 005 |
| 13.10.2 | TSC Manager Duties | 035 |
| 13.10.3 | Technical Manager and Staff Duties | 023 |
| 13.10.4 | Radiation Protection Manager Duties | 033 |
| 13.10.5 | 15 Operations Manager Duties | 012 |
| 13.10.6 | Plant / NRC Liaison Duties | 025 |
| 13.10.7 | Plant Administrative Manager Duties | 024 |
| 13.10.8 | Security Lieutenant and Security Force Duties | 025 |
| 13.10.9 | Operations Support Center Manager and Staff Duties | 049 |
| 13.11.1 | EOF Manager Duties | 044 |

| Procedures Number | Title | Revision |
|-------------------|---|----------|
| 13.11.10 | Security Manager Duties | 022 |
| 13.11.12 | EOF Engineering Manager and Staff Duties | 031 |
| 13.11.2 | Assistant EOF Manager Duties | 010 |
| 13.11.3 | Site Support Manager and Staff Duties | 032 |
| 13.11.7 | Radiological Emergency Manager Duties | 037 |
| 13.12.19 | JIC Management | 024 |
| 13.13.1 | Reentry Operations | 010 |
| 13.13.2 | Emergency Event Termination and Recovery Operations | 018 |

71151 – Performance Indicator Verification

| Procedures Number | Title | Revision |
|-------------------|---|----------|
| EPIP 13.14.4 | Emergency Equipment Maintenance and Testing | 054 |
| EPI-18 | Emergency Preparedness Performance Indicators | 026 |
| EPI-21 | Drill and Exercise Development and Implementation | 018 |

71152 – Problem Identification and Resolution

Action Reports

| | | | | |
|--------|--------|--------|--------|--------|
| 386750 | 386956 | 387833 | 387990 | 380257 |
| 380412 | 380341 | 380427 | 387479 | |

Work Orders

| | | | | | | |
|----------|----------|----------|----------|----------|----------|----------|
| 29146086 | 29146159 | 29146182 | 29146189 | 02049828 | 02137070 | 02105341 |
| 02128700 | | | | | | |

| Procedures Number | Title | Revision |
|-------------------|------------------------------------|----------|
| 1.3.5 | Reactor Trip Report | 026 |
| 3.3.1 | Reactor Scram | 064 |
| ABN-RRC-LOSS | Loss of Reactor Recirculation Flow | 013 |
| ABN-SRV | Safety Relief Valve Opening | 006 |
| ABN-TRANSFORMER | Transformer Abnormal Operation | 022 |
| ESP-MOVTOL-B301 | MOV Thermal Overload Testing – CC | 022 |
| OSP-RCIC/IST-Q701 | RCIC Operability Test | 062 |

| Drawings Number | Title | Revision |
|--------------------|--|----------|
| 250-00.47.1 | Valve Assembly, 2 inch. Y Type, Globe Valve, Motor Operated, C.S | 000 |
| 1205-00.17 | Generator Step-up Transformer Schematic Diagram | 001 |

| Miscellaneous Documents Number | Title | Revision |
|--------------------------------------|--|----------|
| 776-00.1.1 | Stack Monitoring System Equipment, Instrumentation, Dual Sum, Amplifier, Power Supply, Modular System and Coaxicon Vendor Manual | 002 |
| RCIC-MO-19 | MOV Master Data Sheet | 013 |

| Modifications Number | Title | Revision |
|-------------------------|------------------------|----------|
| EC 11288 | Replace Stack Monitors | 008 |

| Calculations Number | Title | Revision |
|------------------------|--|----------|
| NE-02-09-12 | CGS Emergency Action Levels (EALs) Technical Bases | 004 |
| NE-02-13-10 | Determination of Low Range Stack Monitor Xe-133 Equivalent Efficiency | 000 |
| NE-02-15-07 | Setpoint Calculation for Reactor Building Elevated Discharge Radiation Monitor (Stack Monitor) | 000 |

71153 – Follow-up of Events and Notices of Enforcement Discretion

| Action Reports |
|--|
| 380257 380412 380341 380427 |

| Work Orders |
|-------------|
| 02128700 |

| Procedures Number | Title | Revision |
|----------------------|------------------------------------|----------|
| 1.3.5 | Reactor Trip Report | 026 |
| 3.3.1 | Reactor Scram | 064 |
| ABN-RRC-LOSS | Loss of Reactor Recirculation Flow | 013 |
| ABN-SRV | Safety Relief Valve Opening | 006 |
| ABN- TRANSFORMER | Transformer Abnormal Operation | 022 |

| Drawings Number | Title | Revision |
|--------------------|---|----------|
| 1205-00.17 | Generator Step-up Transformer Schematic Diagram | 001 |

COLUMBIA GENERATING STATION – NRC INTEGRATED INSPECTION
 REPORT 05000397/2019001 – May 6, 2019

DISTRIBUTION

SMorris, RA
 MShaffer, DRA
 AVegel, DRP
 MHay, DRP
 RLantz, DRS
 GMiller, DRS
 DCylkowski, RC
 MHaire, DRP
 MMcCoppin, RIV/OEDO
 VDricks, ORA
 JWeil, OCA
 JKlos, NRR
 AMoreno, RIV/CAO
 BMaier, RSLO
 RKellar, IPAT
 GKolcum, DRP
 LMerker, DRP
 MBennett, DRP
 RAlexander, DRP
 AAthar, DRP
 JVera, DRP
 PJayroe, IPAT
 MHerrera, DRMA
 R4Enforcement
 ROP Reports

Electronic Distribution for Columbia Generating Station

ADAMS ACCESSION NUMBER: ML19126A291

SUNSI Review ADAMS: Non-Publicly Available Non-Sensitive Keyword:
 By: Yes No Publicly Available Sensitive NRC-002

| | | | | | | |
|-----------|------------|----------------------|------------|------------|----------|-----------|
| OFFICE | SRI:DRP/A | RI:DRP/C | ARI:DRP/A | DRS/IPAT | DRS/EB1 | DRS/EB2 |
| NAME | GKolcum | LMerker | ECombs | RKellar | VGaddy | GPick |
| SIGNATURE | /RA/ | /RA/ | /RA/ | /RA/ | /RA/ | /RA/ |
| DATE | 04/25/2019 | 4/22/2019 | 5/1/2019 | 04/25/2019 | 4/26/19 | 4/25/2019 |
| OFFICE | DRS/RCB | DNMS/RIB | DRS/OB | SPE:DRP/A | BC:DRP/A | |
| NAME | NMakris | GWarnick | GWerner | RAlexander | MHaire | |
| SIGNATURE | /RA/ | /RA/ JKatanic for | /RA/ | /RA/ | /RA/ | |
| DATE | 04/25/2019 | 05/01/2019 | 04/25/2019 | 04/25/2019 | 05/6/19 | |

OFFICIAL RECORD COPY