

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | L | D | R | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | [] [] [] [] [] [] []

CON'T
01 | REPORT SOURCE | L | 0 | 5 | 0 | 0 | 0 | 2 | 3 | 7 | 0 | 5 | 0 | 9 | 7 | 9 | 0 | 6 | 0 | 7 | 7 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 | During routine inspection, crack found on the 2D1 feedwater heater emergency spill to
03 | condenser line (2-3509A-6). Crack located at pipe to condenser weld and continued
04 | approximately half way around weld. No previous leaks of this nature have occurred.
05 | Minimal safety significance since the leakage contained in the turbine building floor
06 | drain system.

09 | SYSTEM CODE | CH | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | B | 13 | COMPONENT CODE | P | I | P | E | X | X | 14 | COMP. SUBCODE | C | 15 | VALVE SUBCODE | Z | 16
17 | LER/RO REPORT NUMBER | 7 | 9 | EVENT YEAR | 7 | 9 | SEQUENTIAL REPORT NO. | 0 | 3 | 1 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0
18 | ACTION TAKEN | B | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | 2 | 21 | HOURS | 0 | 0 | 0 | ATTACHMENT SUBMITTED | N | 23 | NPD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | P | 2 | 1 | 2 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 | Precise cause unknown but probably mechanical failure assisted by long term vibration.
11 | Cracked portion of weld removed and rewelded. No further corrective action deemed
12 | necessary. Pipe material is class 150, carbon steel with rated pressure of 150 PSI
13 | and normally operating under a vacuum.

15 | FACILITY STATUS | F | 28 | % POWER | 0 | 4 | 5 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Routine Inspection | 32
16 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36
17 | PERSONNEL EXPENSES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39
18 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41
19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | TYPE | N/A | 43 | DESCRIPTION
20 | PUBLICITY | N | 44 | DESCRIPTION | N/A | 45

2285 044

7906120385 S

20 | NAME OF PREPARER | T. Jansen | PHONE: | X-265 | NRC USE ONLY