NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I L D R S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 3 7 (7) | 0 6 0 6 7 9 (8) | 0 6 1 5 7 9 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During normal unit operation the 2B recirc MG set field circuit breaker tripped open.
03 | In accordance with Tech Spec 3.6.H4 the speed of the remaining recirc pump was
04 | immediately reduced to less than 65%. This event has minimal safety significance
05 | since the 2A recirc pump remained operating. No previous occurrences of this nature
06 | have been reported.
07 |
08 | 7 8 9 80

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	C B (11)	E (12)	A (13)	I N S T R U (14)	E (15)	Z (16)
	9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 (21 22) — (23) SEQUENTIAL REPORT NO. 0 4 1 (24 26) / (27) OCCURRENCE CODE 0 3 (28 29) REPORT TYPE L (30) — (31) REVISION NO. 0 (32)

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	B (20)	Z (21)	0 0 1 8	N (23)	Y (24)	N (25)	H 1 5 7 (26)
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Cause was the field circuit breaker tripping open due to failure of potential
11 | transformer in voltage regulator circuit. Faulty transformer was replaced and the
12 | pump restarted satisfactorily. No additional corrective action necessary due to
13 | singular occurrence.
14 | 7 8 9 80

15 | FACILITY STATUS E (28) | % POWER 0 9 6 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A 2348 240
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A
8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY
7 8 9 10 68 69 80

7906220 291

NAME OF PREPARER John Dunbar PHONE: 489