

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

November 7, 2019

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555


Serial No.: 19-440
NRA/GDM: R0
Docket No.: 50-280
License No.: DPR-32

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION ENERGY VIRGINIA)
SURRY POWER STATION UNIT 1
CORE OPERATING LIMITS REPORT
SURRY 1 CYCLE 30 PATTERN APO REVISION 0

Pursuant to Surry Technical Specification (TS) 6.2.C, attached is a copy of the Core Operating Limits Report (COLR) for Surry Power Station Unit 1, Cycle 30, Pattern APO, Revision 0.

If you have any questions or require additional information, please contact Mr. Gary Miller at (804) 273-2771.

Sincerely,



B. E. Standley, Director
Nuclear Regulatory Affairs
Dominion Energy Services, Inc. for
Virginia Electric and Power Company

Attachment:
Core Operating Limits Report, Surry Unit 1 Cycle 30, Pattern APO, Revision 0

Commitment Summary: There are no new commitments contained in this letter.

cc: U.S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Avenue, NE
Suite 1200
Atlanta, Georgia 30303-1257

Mr. Vaughn Thomas
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 04 F-12
11555 Rockville Pike
Rockville, Maryland 20852-2738

Mr. G. Edward Miller
NRC Senior Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 09 E-3
11555 Rockville Pike
Rockville, Maryland 20852-2738

NRC Senior Resident Inspector
Surry Power Station

Attachment

CORE OPERATING LIMITS REPORT

**Surry Unit 1 Cycle 30
Pattern APO**

Revision 0

1.0 INTRODUCTION

This Core Operating Limits Report (COLR) for Surry Unit 1 Cycle 30 has been prepared in accordance with the requirements of Surry Technical Specification 6.2.C.

The Technical Specifications affected by this report are:

TS 2.1 – Safety Limit, Reactor Core
TS 2.3.A.2.d – Overtemperature ΔT
TS 2.3.A.2.e – Overpower ΔT
TS 3.1.E - Moderator Temperature Coefficient
TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limits
TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin
TS 3.12.B.1 and TS 3.12.B.2 - Power Distribution Limits (Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor)
TS 3.12.F – DNB Parameters
TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow

2.0 REFERENCES

1. VEP-FRD-42, Rev. 2.2-A, “Reload Nuclear Design Methodology,” October 2017.
Methodology for:
TS 2.1 – Safety Limit, Reactor Core
TS 3.1.E - Moderator Temperature Coefficient
TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limit
TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin
TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor
TS 3.12.F – DNB Parameters
TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow
2. WCAP-16009-P-A, “Realistic Large Break LOCA Evaluation Methodology Using the Automated Statistical Treatment of Uncertainty Method (ASTRUM),” (Westinghouse Proprietary), January 2005.
Methodology for:
TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor
3. WCAP-10054-P-A, “Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code,” (Westinghouse Proprietary), August 1985.
Methodology for:
TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

4. WCAP-10079-P-A, "NOTRUMP, A Nodal Transient Small Break and General Network Code," (Westinghouse Proprietary), August 1985.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

5. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Report," (Westinghouse Proprietary), April 1995.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

6. WCAP-12610-P-A and CENPD-404-P-A, Addendum 1-A, "Optimized ZIRLO," (Westinghouse Proprietary), July 2006.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

7. VEP-NE-2-A, Rev. 0, "Statistical DNBR Evaluation Methodology," June 1987.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

8. DOM-NAF-2-P-A, Rev. 0.3, "Reactor Core Thermal-Hydraulics Using the VIPRE-D Computer Code," including Appendix B, "Qualification of the Westinghouse WRB-1 CHF Correlation in the Dominion VIPRE-D Computer Code," and Appendix D, "Qualification of the ABB-NV and WLOP CHF Correlations in the Dominion VIPRE-D Computer Code," September 2014.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

9. WCAP-8745-P-A, "Design Bases for Thermal Overpower Delta-T and Thermal Overtemperature Delta-T Trip Function," September 1986.

Methodology for:

TS 2.3.A.2.d – Overtemperature ΔT

TS 2.3.A.2.e – Overpower ΔT

3.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.2.C and repeated in Section 2.0.

3.1 Safety Limit, Reactor Core (TS 2.1)

The Reactor Core Safety Limits are presented in **Figure A-1**.

3.2 Overtemperature ΔT (TS 2.3.A.2.d)

$$\Delta T \leq \Delta T_0 \left[K_1 - K_2 \left(\frac{1+t_1s}{1+t_2s} \right) (T - T') + K_3 (P - P') - f(\Delta I) \right]$$

Where:

ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RATED POWER, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature (T_{avg}), °F.

T' is the nominal T_{avg} at RATED POWER, $\leq 573.0^\circ\text{F}$.

P is the measured pressurizer pressure, psig.

P' is the nominal RCS operating pressure ≥ 2235 psig.

$$K_1 \leq 1.1425$$

$$K_2 \geq 0.01059 / ^\circ\text{F}$$

$$K_3 \geq 0.000765 / \text{psig}$$

$$t_1 \geq 29.7 \text{ seconds}$$

$$t_2 \leq 4.4 \text{ seconds}$$

$$f(\Delta I) \geq \begin{cases} 0.0268 \{-24 - (q_t - q_b)\}, & \text{when } (q_t - q_b) < -24.0\% \text{ RATED POWER} \\ 0, & \text{when } -24.0\% \text{ RATED POWER} \leq (q_t - q_b) \leq +8.0\% \text{ RATED POWER} \\ 0.0188 \{(q_t - q_b) - 8.0\}, & \text{when } (q_t - q_b) > +8.0\% \text{ RATED POWER} \end{cases}$$

Where q_t and q_b are percent RATED POWER in the upper and lower halves of the core, respectively, and $q_t + q_b$ is the total THERMAL POWER in percent RATED POWER.

3.3 Overpower ΔT (TS 2.3.A.2.e)

$$\Delta T \leq \Delta T_0 \left[K_4 - K_5 \left(\frac{t_3s}{1+t_3s} \right) T - K_6 (T - T') - f(\Delta I) \right]$$

Where:

ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RATED POWER, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature (T_{avg}), °F.

T' is the nominal T_{avg} at RATED POWER, $\leq 573.0^\circ\text{F}$.

$$K_4 \leq 1.0965$$

$$K_5 \geq 0.0198 / ^\circ\text{F} \text{ for increasing } T_{\text{avg}}$$

$$K_6 \geq 0.001074 / ^\circ\text{F} \text{ for } T > T'$$

$$\geq 0 / ^\circ\text{F} \text{ for decreasing } T_{\text{avg}}$$

$$\geq 0 \text{ for } T \leq T'$$

$$t_3 \geq 9.0 \text{ seconds}$$

$f(\Delta I) =$ as defined above for OT ΔT

3.4 Moderator Temperature Coefficient (TS 3.1.E)

The Moderator Temperature Coefficient (MTC) limits are:

+6.0 pcm/°F at less than 50 percent of RATED POWER, and

+6.0 pcm/°F at 50 percent of RATED POWER and linearly decreasing to 0 pcm/°F at RATED POWER

3.5 Control Bank Insertion Limits (TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3, and TS 3.12.C.3.b.1(b))

3.5.1 The control rod banks shall be limited in physical insertion as shown in **Figure A-2**.

3.5.2 The rod insertion limit for the A and B control banks is the fully withdrawn position as shown on **Figure A-2**.

3.5.3 The rod insertion limit for the A and B shutdown banks is the fully withdrawn position as shown on **Figure A-2**.

3.6 Shutdown Margin (TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G)

Shutdown margin (SDM) shall be $\geq 1.77 \% \Delta k/k$.

3.7 Power Distribution Limits (TS 3.12.B.1 and TS 3.12.B.2)

3.7.1 Heat Flux Hot Channel Factor - FQ(z)

$$FQ(z) \leq \frac{CFQ}{P} K(z) \text{ for } P > 0.5$$

$$FQ(z) \leq \frac{CFQ}{0.5} K(z) \text{ for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFQ = 2.5$$

$$K(z) = 1.0 \text{ for all core heights, } z$$

3.7.2 Nuclear Enthalpy Rise Hot Channel Factor - $F\Delta H(N)$

$$F\Delta H(N) \leq CFDH * \{1 + PFDH(1 - P)\}$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFDH = 1.635$$

$$PFDH = 0.3$$

3.8 **DNB Parameters** (TS 3.12.F and TS Table 4.1-2A)

Departure from Nucleate Boiling (DNB) Parameters shall be maintained within their limits during POWER OPERATION:

- Reactor Coolant System $T_{\text{avg}} \leq 577.0 \text{ }^\circ\text{F}$
- Pressurizer Pressure $\geq 2205 \text{ psig}$
- Reactor Coolant System Total Flow Rate $\geq 273,000 \text{ gpm}$ (Tech Spec Limit)
and $\geq 274,000 \text{ gpm}$ (COLR Limit)

Figure A-1

**REACTOR CORE SAFETY LIMITS
THREE LOOP OPERATION, 100% FLOW**




Figure A-2
Surry 1 Cycle 30
Rod Group Insertion Limits

Max w/d position = 227 steps

